



September 28, 2020

Gordon Criswell  
Director, Environmental & Compliance  
Talen Montana, LLC  
Colstrip Steam Electric Station  
580 Willow Avenue  
P.O. Box 38  
Colstrip, MT 59323

Dear Mr. Criswell:

Montana Air Quality Permit #0513-14 is deemed final as of September 26, 2020, by the Department of Environmental Quality (Department). This permit is for a coal-fired electric generating facility. All conditions of the Department's Decision remain the same. Enclosed is a copy of your permit with the final date indicated.

For the Department,

A handwritten signature in black ink that reads "Julie A. Merkel".

Julie A. Merkel  
Permitting Services Section Supervisor  
Air Quality Bureau  
(406) 444-3626

A handwritten signature in black ink that reads "Ed Warner".

Ed Warner  
Lead Engineer – Permitting Services Section  
Air Quality Bureau  
(406) 444-2467

JM:EW  
Enclosure

Montana Department of Environmental Quality  
Air, Energy & Mining Division

Montana Air Quality Permit #0513-14

Talen Montana, LLC  
Colstrip Steam Electric Station  
580 Willow Ave., P.O. Box 38  
Colstrip, MT 59323

September 26, 2020



## MONTANA AIR QUALITY PERMIT

Issued To: Talen Montana, LLC  
Colstrip Steam Electric Station  
580 Willow Ave., P.O. Box 38  
Colstrip, MT 59323

MAQP: #0513-14  
Administrative Amendment (AA)  
Request Received: 09/03/2020  
Department's Decision on AA: 09/10/2020  
Permit Final: 09/26/2020

A Montana Air Quality Permit (MAQP), with conditions, is hereby granted to Talen Montana, LLC (Talen), Colstrip Steam Electric Station (Colstrip), pursuant to Sections 75-2-204 and 211 of the Montana Code Annotated (MCA), as amended, and Administrative Rules of Montana (ARM) 17.8.740, *et seq.*, as amended, for the following:

### SECTION I: Permitted Facilities

#### A. Permitted Facility

Talen operates Colstrip Units 1, 2, 3, and 4 tangential coal-fired boilers and associated equipment for the generation of electricity. The Talen Colstrip facility is located in Section 34, Township 2 North, Range 41 East, in Rosebud County, Montana. A complete listing of facility equipment is found in the Permit Analysis.

#### B. Current Permit Action

On September 3, 2020, the Montana Department of Environmental Quality (Department) received a request to administratively amend MAQP #0513-13 from Talen. Talen requested to remove the permit modifications made in March 2019 authorizing (but not requiring) the construction and operation of coal unloading facilities to accommodate the use of coal obtained from certain mines other than the Rosebud Mine. The current permit action removes the permit conditions associated with that action.

### SECTION II: Conditions and Limitations

#### A. Emission Limitations

1. Talen shall not cause or authorize emissions to be discharged into the outdoor atmosphere from any sources installed on or before November 23, 1968, that exhibit an opacity of 40% or greater averaged over 6 consecutive minutes (ARM 17.8.304).
2. Talen shall not cause or authorize emissions to be discharged into the outdoor atmosphere from any sources installed after November 23, 1968, that exhibit an opacity of 20% or greater averaged over 6 consecutive minutes (ARM 17.8.304).
3. Talen shall not cause or authorize emissions to be discharged into the outdoor atmosphere from the truck dump and lime silo bin vent, that exhibit

an opacity of 20% or greater averaged over 6 consecutive minutes (ARM 17.8.752 and 40 CFR 60, Subpart Y).

4. Talen shall not cause or authorize emissions to be discharged into the atmosphere from haul roads, access roads, parking lots, or the general plant property without taking reasonable precautions to control emissions of airborne particulate matter (ARM 17.8.308).
5. Talen shall treat all unpaved portions of the access roads, parking lots, and general plant area with fresh water and/or chemical dust suppressant as necessary to maintain compliance with the reasonable precautions limitation in Section II.A.4 (ARM 17.8.749).
6. Talen shall comply with all applicable standards and limitations, and the reporting, recordkeeping, and notification requirements contained in 40 CFR 60, Subpart Y. Subpart Y affected sources include the truck dump station, the lime silo bin vent, and any other affected source constructed or modified after October 24, 1974 (ARM 17.8.340 and 40 CFR 60, Subpart Y).
7. Talen shall maintain and operate skirting, minimal volumes, and small drop distances at off-loading systems and bin vent filter systems to provide the maximum air pollution control for that which the systems were designed (ARM 17.8.752).
8. Units 1&2 shall be limited to a maximum of 700,800 tons of Syncoal during any rolling 12-month period (ARM 17.8.752).
9. Units 1&2 shall be limited to a maximum of 280,320 tons of petroleum coke during any rolling 12-month period (ARM 17.8.749).
10. The petroleum coke truck dump system particulate emissions shall be controlled by a partially enclosed dump basin, minimized dropping distances, covered conveyor belts, and an underground and enclosed feeder (ARM 17.8.749).
11. The petroleum coke rail dump system particulate emissions shall be controlled by an underground and enclosed dump basin, minimized dropping distances, covered conveyor belts, and an underground and enclosed feeder (ARM 17.8.749).
12. Talen shall maintain and operate the scrubbers to control emissions on Units 1&2 (ARM 17.8.749).
13. Talen shall be limited to a maximum fuel use of 28% petroleum coke for each of the Units 1&2, based on the maximum heat input value of the units (ARM 17.8.749).
14. Emissions of particulate matter from either Units 3 or 4 shall not exceed the following limits (ARM 17.8.749):

- a. 0.05 pounds per million British thermal units (lb/MMBtu); and
  - b. 379 pounds per hour (lb/hr).
15. Emissions of sulfur dioxide (SO<sub>2</sub>) from either Units 3 or 4 shall not exceed the following limits (these are stack emission limits; no percent sulfur reduction limit applies) (ARM 17.8.749):
- a. 761 lb/hr, averaged over any rolling 30-day period, calculated each day at midnight, using hourly data calculated each hour on the hour;
  - b. 0.18 lb/MMBtu heat input, averaged over any calendar-day, not to be exceeded more than once during any calendar-month;
  - c. 1363 lb/hr, averaged over any calendar-day, not to be exceeded more than once during any calendar-month; and
  - d. 1% sulfur content of the coal (as received).
16. Talen shall be limited to 4,140 lb/hr of SO<sub>2</sub>, averaged over any 3-hour rolling period from both Units 3 and 4 stacks combined (ARM 17.8.749).
17. Emissions of NO<sub>x</sub> from either Unit 3 or 4 shall not exceed the following limits:
- a. 0.70 lb/MMBtu heat input when burning coal. If fuel other than coal is burned, the allowable NO<sub>x</sub> emission rate shall be determined by the following equation (40 CFR 60, Subpart D):
 
$$E = \frac{0.2x + 0.3y + 0.7z}{x + y + z}$$

Where: E is the allowable emissions in lb/MMBtu heat input,  
 x is the fraction of total heat input derived from gaseous fuels,  
 y is the fraction of total heat input derived from liquid fuels,  
 z is the fraction of total heat input derived from solid fuels.
  - b. 5,301 lb/hr.
18. Beginning January 1, 2008, for Unit 3 and January 19, 2010, for Unit 4, Talen shall not exceed any of the following NO<sub>x</sub> emission limits from Units 3 or 4 (ARM 17.8.749 and Consent Decree CV-07-40-BLG-RFC-CSO entered 5/14/07):
- a. 30-day rolling average emission rate of:
    - i. 0.18 lb/MMBtu weighted average for each hour that either unit is operating above 400 gross megawatts (MW); and
    - ii. 0.30 lb/MMBtu weighted average for each hour that either unit is operating at or below 400 gross MW;

- b. 1,363 lb/hr 30-day rolling average emission rate for each unit;
- c. 24-hour average emission rate of:
  - i. 0.25 lb/MMBtu weighted average for each hour that either unit is operating above 400 gross MW; and
  - ii. 0.30 lb/MMBtu weighted average for each hour that either unit is operating at or below 400 gross MW;
- d. 1,893 lb/hr 24-hour average emission rate for each unit.

For the purposes of Section II.A.18, if a unit is operating above 400 MW for part of one hour and at or below 400 MW for the remainder of that hour, the applicable emissions limits shall be based on the average load for the hour. In addition, the emission rates for Section II.A.18 limits are considered for an operating day in which any fuel is combusted in the unit.

- 19. Talen shall operate digital controls, low-NOx burners and overfire air on Unit 3 sufficient to meet the emissions limits in Section II.A.18 (ARM 17.8.749 and Consent Decree CV-07-40-BLG-RFC-CSO entered 5/14/07).
- 20. By January 1, 2009, Talen shall complete the final design and by January 19, 2010, Talen shall install and operate digital controls, low-NOx burners and overfire air on Unit 4 sufficient to meet the Unit 4 emissions limits in Section II.A.18 (ARM 17.8.749 and Consent Decree CV-07-40-BLG-RFC-CSO entered 5/14/07 with stipulation filed 12/22/2009).
- 21. The Unit 3 and 4 NOx emission limits specified in Section II.A.18 shall apply at all times, including periods of start-up, shutdown, load fluctuation, maintenance and malfunction, regardless of cause (ARM 17.8.749 and Consent Decree CV-07-40-BLG-RFC-CSO entered 5/14/07).
- 22. Emissions from either Unit 3 or 4 shall not exhibit an opacity of 20% or greater over any 6-minute period. The opacity provisions of 40 CFR 60.42 are applicable (ARM 17.8.340).
- 23. Units 3 and 4 shall each be limited to a maximum heat input of  $6.63 \times 10^7$  MMBtu over any rolling 12-month period (ARM 17.8.749).
- 24. Beginning January 1, 2010, facility-wide emissions of mercury (Hg) shall not exceed 0.9 pounds mercury per trillion British thermal units (lb/TBtu), calculated as a rolling 12-month average. The facility-wide emissions shall be calculated according to the following equation (ARM 17.8.771):

$$\text{Facility-wide Hg emissions} = \frac{(\text{Unit1}_{\text{lbHg/TBtu}} + \text{Unit2}_{\text{lbHg/TBtu}} + \text{Unit3}_{\text{lbHg/TBtu}} + \text{Unit4}_{\text{lbHg/TBtu}})}{4}$$

Where:  $\text{Unit1}_{\text{lbHg/TBtu}}$  = rolling 12-month mercury emissions from Unit 1 as an average of the last 12 individual calendar monthly averages.

$\text{Unit2}_{\text{lbHg/TBtu}}$  = rolling 12-month mercury emissions from Unit 2 as an average of the last 12 individual calendar monthly averages.

$\text{Unit3}_{\text{lbHg/TBtu}}$  = rolling 12-month mercury emissions from Unit 3 as an average of the last 12 individual calendar monthly averages.

$\text{Unit4}_{\text{lbHg/TBtu}}$  = rolling 12-month mercury emissions from Unit 4 as an average of the last 12 individual calendar monthly averages.

25. On each Unit 1-4, Talen shall install a mercury control system that oxidizes and sorbs emissions of mercury. Talen shall implement the operation and maintenance of mercury control systems on or before January 1, 2010 (ARM 17.8.771).
26. Talen shall comply with all applicable standards and limitations, and the applicable operating, reporting, recordkeeping, and notification requirements contained in 40 CFR Part 75 (ARM 17.8.771).
27. Talen shall operate and maintain the mercury oxidizer/sorbent handling systems, including the bin vent filter systems, to provide the maximum air pollution control for that which the systems were designed (ARM 17.8.749).
28. The mechanical evaporators at the wastewater pond site each shall not exceed 2000 hours of operation during any rolling 12-month time period. This mechanical evaporation system shall consist of no more than (ARM 17.8.749 and 17.8.752):
  - a. 8 Minetek (or demonstrated equivalent) evaporator units.
  - b. 31 Slimline (or demonstrated equivalent) evaporator units.
29. Talen shall maintain wind fences at the wastewater pond site as shown in Attachment 3, at a minimum or to a greater extent, to provide containment of particulate matter generated from the evaporated water plumes (ARM 17.8.749).
30. Talen shall operate the mechanical evaporation system at the wastewater pond site using best management practices, including specific operational controls based on wind speed, wind direction, ambient air temperature, and relative humidity to help contain the potential evaporation drift within the pond. The evaporators shall not be operated during meteorological conditions that fall outside of the following operational parameters (ARM 17.8.752):

### Minetek Operational Parameters

Wind Direction		N	NE	E	SE	S	SW	W	NW	
Max Wind Speed (mph)		25	20	5	5	10	10	25	25	
Directional Parameters	Center (°)	0	45	90	135	180	225	270	315	
	Min (°)	337.5	22.5	67.5	112.5	157.5	202.5	247.5	292.5	
	Max (°)	22.5	67.5	112.5	157.5	202.5	247.5	292.5	337.5	
Wind Speed (mph)	<=5	Max Humidity (%)	90	90	60	60	60	60	90	90
		Min Temp. (°F)	47	47	47	47	47	47	47	47
	<=10	Max Humidity (%)	90	90					90	90
		Min Temp. (°F)	47	47					47	47
	<=15	Max Humidity (%)	90	90					90	90
		Min Temp. (°F)	47	47					47	47
	<=20	Max Humidity (%)	90	90					90	90
		Min Temp. (°F)	47	47					47	0
	<=25	Max Humidity (%)	90						90	90
		Min Temp. (°F)	47						47	47

### Slimline Operational Parameters

Wind Direction (Blowing From)		N	NE	E	SE	S	SW	W	NW	
Max Wind Speed (mph)		20	5	5	5	17	20	20	20	
Directional Parameters	Center (°)	0	45	90	135	180	225	270	315	
	Min (°)	337.5	22.5	67.5	112.5	157.5	202.5	247.5	292.5	
	Max (°)	22.5	67.5	112.5	157.5	202.5	247.5	292.5	337.5	
Wind Speed (mph)	<=5	Max Humidity (%)	70	65	65	65	65	70	65	65
		Min Temp. (°F)	50	50	50	50	50	50	50	50
	<=10	Max Humidity (%)	65				60	65	60	60
		Min Temp. (°F)	50				55	50	55	55
	<=15	Max Humidity (%)	60				60	60	60	60
		Min Temp. (°F)	55				55	55	55	55
	<=20	Max Humidity (%)	55					60	55	60
		Min Temp. (°F)	60					55	60	55
	<=25	Max Humidity (%)								
		Min Temp. (°F)								
	<=30	Max Humidity (%)								
		Min Temp. (°F)								

31. Talen may have in service up to nine propane-fired heaters not to exceed 2.4 MMBtu/hr heat input capacity each, or a demonstrated equivalent, for providing heat to maintenance and operations buildings on Units 1 and 2. These units may only be in service beginning on January 1, 2020 and concluding on April 30, 2020. After April 30, 2020, these nine units must be removed from service (ARM 17.8.749).
  
32. Talen may have in service up to two diesel-fired boilers not to exceed 89.4 MMBtu/hr heat input capacity each, or a demonstrated equivalent, for providing heat to maintenance and operations buildings on Units 3 and 4. After April 30, 2020, these two units must be removed from service. These



units may only be used in accordance with the following scenarios (ARM 17.8.749):

- a. When both Units 3 and 4 are not operating and when the loss of this usual heat source could cause an adverse effect on facility safety, consistent with ARM 17.8.744(1)(g), or
  - b. Any operation of these units that is not consistent with ARM 17.8.744(1)(g) may not exceed 39 hours for each heater, or demonstrated equivalent, during the time while they are in service.
33. Talen shall comply with all applicable standards and limitations, and the reporting, recordkeeping, and notification requirements contained in 40 CFR 63, Subpart UUUUU. Subpart UUUUU affected sources include Units 1, 2, 3, and 4 (ARM 17.8.342 and 40 CFR 63, Subpart UUUUU).
  34. Talen shall comply with all applicable standards and limitations, and the reporting, recordkeeping, and notification requirements contained in 40 CFR 63, Subpart ZZZZ. Subpart ZZZZ applies to the emergency diesel generators (ARM 17.8.342 and 40 CFR 63, Subpart ZZZZ).

#### B. Testing Requirements

1. Talen shall conduct annual stack tests, or another testing/monitoring schedule as may be approved by the Department, for total particulate and demonstrate compliance with the limitations in Section II.A.14. The testing shall be conducted in accordance with 40 CFR 60.46(b)(2)(i). Demonstrations of compliance with the opacity limits, if required during these tests, shall be based on certified opacity monitors unless otherwise specified by the Department (ARM 17.8.104 and ARM 17.8.105).
2. All compliance source tests shall conform to the requirements of the Montana Source Test Protocol and Procedures Manual (ARM 17.8.106).
3. The Department may require further testing (ARM 17.8.105).

#### C. Monitoring Requirements for Units 3 and 4

1. Talen shall install, operate, calibrate, and maintain continuous emission monitoring systems (CEMS) for the following:
  - a. A CEMS for the measurement of SO<sub>2</sub> shall be operated on each stack (ARM 17.8.340 and 40 CFR 60.45).
  - b. A CEMS for the measurement of NO<sub>x</sub> shall be operated on each stack (ARM 17.8.340 and 40 CFR 60.45).
  - c. A CEMS for measurement of carbon dioxide or oxygen shall be operated on each stack (ARM 17.8.340 and 40 CFR 60.45).

- d. A CEMS for the measurement of opacity shall be operated on each stack (ARM 17.8.340 and 40 CFR 60.45).
  - e. Continuous monitoring for stack gas temperature, stack gas moisture (where necessary), megawatt production, and Btu per hour (as a function of heat rate and megawatt production) shall be performed on each unit (40 CFR 52.21).
  - f. Talen shall maintain the data acquisition system such that load data in MW is recorded no less than once per minute (ARM 17.8.749 and Consent Decree CV-07-40-BLG-RFC-CSO entered 5/14/07).
2. All continuous monitors shall be operated, excess emissions reported, and performance tests conducted in accordance with the requirements of 40 CFR Part 60, Subpart D, 40 CFR 60.7, 60.8, 60.11, 60.13, and 40 CFR 60, Appendix B Performance Specifications #1, #2 and #3, subject to the following:
- a. The requirements of 40 CFR 60.48da - Compliance Provisions (40 CFR 60, Subpart Da) shall apply to Units 3 and 4 (40 CFR 52.21).
  - b. The requirements of 40 CFR 60.49da - Emission Monitoring (40 CFR 60, Subpart Da) shall apply to Units 3 and 4 (40 CFR 52.21).
  - c. The requirements of 40 CFR 60.50da - Compliance Determination Procedures and Methods (40 CFR 60, Subpart Da) shall apply to Units 3 and 4 (40 CFR 52.21).
  - d. The requirements of 40 CFR 60.51da - Reporting Requirements (40 CFR 60, Subpart Da) shall apply to Units 3 and 4 (40 CFR 52.21).
  - e. Talen shall operate the required monitors in accordance with the CEMS quality assurance (QA) plan submitted to the Environmental Protection Agency (EPA) in May 1998. This plan may be revised by Talen with the approval of the Department (40 CFR 52.21).
  - f. Compliance requirements of 40 CFR 60.11(a) shall be amended per Section II.D (40 CFR 52.21).
  - g. Each monitor modular part (i.e., opacity, SO<sub>2</sub>, NO<sub>x</sub>, diluent, and data handling units) of a continuous monitoring system shall attain a minimal annual on-line availability time of 85% and a minimal quarterly availability time of 75% for each individual quarter. Should any given yearly or quarterly availability time drop below these respective limits, Talen shall, within 90 days of the end of the first unexcused year or quarter in question, cause to be delivered to the facility factory-tested and compatible monitor module(s) able to replace the monitor module(s) that had unacceptable availability times, unless Talen can excuse the unacceptable performance by demonstrating within 10 calendar-days of the end of such year or quarter, that the reason for the poor availability

time has not caused another previous occurrence of unacceptable availability, and the reason for the particular unavailability in question will be prevented in the future by a more effective maintenance/inventory program (40 CFR 52.21).

- h. Upon two non-overlapping periods of unexcused, unacceptable availability of a module (yearly, quarterly, or combination), Talen shall (within 30 days of the end of the year or quarter of the second unacceptable availability period) install, calibrate, operate, maintain, and report emission data using the second compatible module required by Section II.C.2.g. above (40 CFR 52.21).
- i. Within 60 days of the end of the year of the quarter causing the second unacceptable availability period under Section II.C.2.h., Talen shall conduct a complete performance evaluation of the entire CEMS for that pollutant under 40 CFR 60.13(c) showing acceptability of the entire CEMS in question unless the module was the data handling unit alone. Within 75 days of the end of the year or quarter causing the second unacceptable availability period, Talen shall furnish the Department with a written report of such evaluations and tests demonstrating acceptability of the system (40 CFR 52.21).
- j. In the event of a conflict between the requirements of the referenced federal regulations and the requirements of this permit, the requirements of this permit shall apply.

D. Compliance

- 1. Compliance with the particulate emission limits in Section II.A.14 shall be based on the source tests required by Section II.B.1 (ARM 17.8.105).
- 2. Compliance with the SO<sub>2</sub> emission limits in Section II.A.15 and 16 shall be based on the CEMS required by Section II.C.1.a and from any stack tests required by the state under the authority of ARM 17.8.104 (ARM 17.8.105 and 40 CFR 52.21).
- 3. Compliance with the SO<sub>2</sub> emission limit in Section II.A.15.d shall be based on available daily composite coal samples as measured by 40 CFR 60, Appendix A, Method 19 or another sampling schedule as approved by the Department. Records shall be maintained according to II.E.7 (ARM 17.8.749).
- 4. Compliance with the NO<sub>x</sub> emission limits in Section II.A.17 shall be based on data from the CEMS required by Section II.C.1.b and from any stack tests required by the state under the authority of ARM 17.8.104 (ARM 17.8.105 and 17.8.104).
- 5. Compliance with the NO<sub>x</sub> emission limits in Section II.A.18 shall be based on data from the CEMS required by Section II.C.1.b and from any stack tests required by the state under the authority of ARM 17.8.104. The reference

methods for determining NO<sub>x</sub> emission rates shall be those specified in 40 CFR Part 60. The NO<sub>x</sub> CEMS shall be used in accordance with the operating requirements in 40 CFR Part 75 (ARM 17.8.104, 17.8.105, and Consent Decree CV-07-40-BLG-RFC-CSO entered 5/14/07).

6. Compliance with the opacity limit in Section II.A.22 shall be based on data from the opacity monitor required by Section II.C.1.d and visual emissions observations in accordance with 40 CFR, Part 60, Appendix A, Method 9 Visual Determination of Opacity of Emissions from Stationary Sources (ARM 17.8.105).
7. Compliance with the heat input limit of Section II.A.23 shall be determined based on the total tons of coal combusted in each unit multiplied by a representative average British thermal unit (Btu) content for the coal (ARM 17.8.105).
8. Enforcement of Section II.A.24, where applicable, shall be determined by utilizing data taken from Mercury Emission Monitoring Systems (MEMS), as required in Section II.F, installed on each Unit 1-4. The MEMS shall be comprised of equipment as required in 40 CFR 75.81(a) and defined in 40 CFR 72.2. The above does not relieve Talen from meeting any applicable requirements of 40 CFR Part 75. Testing requirements shall be as specified in 40 CFR Part 75, Section II.D, and II.F of MAQP #0513-11 (ARM 17.8.771).
9. Talen shall document, by month, the hours of operation for each of the mechanical evaporators at the wastewater pond site. By the 25th day of each month, Talen shall total the hours of operation for each evaporator for the previous month. The monthly information will be used to demonstrate compliance with the rolling 12-month limitation in Section II.A.28 (ARM 17.8.749).
10. Talen shall document the meteorological conditions corresponding to the operational controls as described in Section II.A.30 while the mechanical evaporators are operating. This information will be used to demonstrate compliance with the requirement to not operate the evaporators during meteorological conditions that fall outside of the operational controls as described in Section II.A.30 (ARM 17.8.749).
11. Talen shall document the hours of operation for each of the emergency-use boilers described in Section II.A.32. The operational state of both Units 3 and 4 must be documented for each hour of operation of either emergency-use boiler. This information will be used to demonstrate compliance with the operating scenarios in Section II.A.32 (ARM 17.8.749).
12. Talen shall provide notification to the Department when the heaters described in Section II.A.31 are removed from service within 15 days of their removal (ARM 17.8.749).

13. Talen shall provide notification to the Department when the emergency-use boilers described in Section II.A.32 are removed from service within 15 days of their removal (ARM 17.8.749).

E. Operational and Emission Inventory Reporting Requirements

1. Talen shall submit a written report of excess emissions and monitoring system performance as required by 40 CFR 60.7(c). For the purposes of the report, excess emissions shall be defined as any 6-minute, 3-hour, 24-hour or 30-day period, as applicable, in which the average emissions of the period of concern for opacity, NO<sub>x</sub>, or SO<sub>2</sub> as measured by the CEMS, exceed the applicable emission limitation in Section II.A. For the purposes of reporting excess emissions for the periods:
  - a. 6-minute average applies to each 6-minute non-overlapping period starting on the hour.
  - b. 3-hour period applies to any running 3-hour period containing three contiguous 1-hour periods, starting on the hour.
  - c. 24-hour period applies to any calendar-day.
  - d. 30-day period applies to any running period of 30 consecutive calendar-days.
2. Talen shall submit the following information along with the excess emission reports:
  - a. The fuel feed rate and associated production figures corresponding to all periods of excess emissions (40 CFR 52.21);
  - b. The proximate analysis of the weekly composite sample of the fuel fired in each unit (40 CFR 52.21); and
  - c. Date, time, and initial calibration values for each required calibration adjustment made on any monitor during the quarter, including any time that the monitor was removed or inoperable for any reason (40 CFR 52.21).
3. Talen will meet the performance standards and emission limitations established under Section II.A.18, to the number of significant digits provided. Talen shall report data to at least the number of significant digits in which the standard or limit is expressed (ARM 17.8.749 and Consent Decree CV-07-40-BLG-RFC-CSO entered 5/14/07).
4. Talen shall document, by month, the total Btu value of the fuel combusted in Units 3 and 4, based on the total tons of coal combusted in each unit multiplied by a representative average Btu content for the coal. By the 25th day of each month, Talen shall calculate the total amount of fuel combusted in Units 3 and 4 during the previous month. The monthly information will

be used to verify compliance with the rolling 12-month limitation in Section II.A.23. The information for each of the previous months shall be submitted along with the annual emission inventory (ARM 17.8.749).

5. Talen shall document, by month, the amount of Syncoal used. By the 25th day of each month, Units 1 and 2 shall total the amount of Syncoal used during the previous month. The monthly information will be used to verify compliance with the rolling 12-month limitation in Section II.A.8. The information for each of the previous months shall be submitted along with the annual emission inventory (ARM 17.8.749).
6. Talen shall document, by month, the amount of petroleum coke used. By the 25th day of each month, Units 1 and 2 shall total the amount of petroleum coke used during the previous month. The monthly information will be used to verify compliance with the rolling 12-month limitation in Section II.A.9. The information for each of the previous months shall be submitted along with the annual emission inventory (ARM 17.8.749).
7. Talen shall supply the Department with annual production information for all emission points, as required, by the Department in the annual emission inventory request. The request will include, but is not limited to, all sources of emissions identified in the emission inventory contained in the permit analysis.

Production information shall be gathered on a calendar-year basis and submitted to the Department by the date required in the emission inventory request. Information shall be in the units required by the Department. This information may be used for calculating operating fees, based on actual emissions from the facility, and/or to verify compliance with permit limitations (ARM 17.8.505).

8. Talen shall submit a written report to verify compliance with the limitation in Section II.A.13. The written report shall be submitted quarterly to the Department (ARM 17.8.749).
9. Talen shall notify the Department of any construction or improvement project conducted, pursuant to ARM 17.8.745, that would include the addition of a new emissions unit, change of control equipment, stack height, stack diameter, stack flow, stack gas temperature, source location, or fuel specifications, or would result in an increase in source capacity above its permitted operation. The notice must be submitted to the Department, in writing, 10 days prior to startup or use of the proposed de minimis change, or as soon as reasonably practicable in the event of an unanticipated circumstance causing the de minimis change, and must include the information requested in ARM 17.8.745(1)(d) (ARM 17.8.745).
10. All records compiled in accordance with this permit must be maintained by Talen as a permanent business record for at least 5 years following the date of the measurement, must be available at the plant site for inspection by the

Department, and must be submitted to the Department upon request (ARM 17.8.749).

11. All records compiled in response to Consent Decree CV-07-40-BLG-RFC-CSO shall be retained (Consent Decree CV-07-40-BLG-RFC-CSO entered 5/14/07):
  - a. Until December 31, 2020, for records concerning physical or operational changes undertaken in accordance with the require elements contained in Section II.A.18 – II.A.21; and
  - b. Until December 31, 2017, for all other records.
12. Talen shall report to the Department within 30 days after the end of each calendar quarter, as described in Attachment 2 (ARM 17.8.749):
  - a. For each Unit 1-4, the monthly average lb/TBtu mercury emission rate, for each month of the quarter;
  - b. For each Unit 1-4, the 12-month rolling average lb/TBtu mercury emission rate, for each month of the reporting quarter;
  - c. The 12-month facility-wide rolling average lb/TBtu mercury emission rate, calculated according to II.A.24, for each month of the reporting quarter; and
  - d. For each Unit 1-4, the number of operating hours that the MEMS were unavailable or not operating within quality assurance limits (monitor downtime).
  - e. The first quarterly report must be received by the Department by April 30, 2010, but shall not include 12-month rolling averages. The first quarterly report to include 12-month rolling averages must be received by the Department by January 30, 2011.

F. Mercury Emissions Monitoring Systems

A MEMS shall be installed, certified, and operating on each Unit 1-4 stack outlet on or before January 1, 2010. MEMS shall comply with the applicable provisions of 40 CFR Part 75. The monitors shall also conform with requirements included in Attachment 2 (ARM 17.8.771).

SECTION III: General Conditions

- A. Inspection – Talen shall allow the Department’s representatives access to the source at all reasonable times for the purpose of making inspections or surveys, collecting samples, obtaining data, auditing any monitoring equipment (MEMS, continuous emission monitoring system – CEMS, continuous emission rate monitoring system – CERMS) or observing any monitoring or testing, and otherwise conducting all necessary functions related to this permit.

- B. Waiver – The permit and the terms, conditions, and matters stated herein shall be deemed accepted if Talen fails to appeal as indicated below.
- C. Compliance with Statutes and Regulations – Nothing in this permit shall be construed as relieving Talen of the responsibility for complying with any applicable federal or Montana statute, rule, or standard, except as specifically provided in ARM 17.8.740, *et seq.* (ARM 17.8.756).
- D. Enforcement – Violations of limitations, conditions and requirements contained herein may constitute grounds for permit revocation, penalties, or other enforcement action as specified in Section 75-2-401, *et seq.*, MCA.
- E. Appeals – Any person or persons jointly or severally adversely affected by the Department’s decision may request, within 15 days after the Department renders its decision, upon affidavit setting forth the grounds therefor, a hearing before the Board of Environmental Review (Board). A hearing shall be held under the provisions of the Montana Administrative Procedures Act. The filing of a request for a hearing does not stay the Department’s decision, unless the Board issues a stay upon receipt of a petition and a finding that a stay is appropriate under Section 75-2-211(11)(b), MCA. The issuance of a stay on a permit by the Board postpones the effective date of the Department’s decision until conclusion of the hearing and issuance of a final decision by the Board. If a stay is not issued by the Board, the Department’s decision on the application is final 16 days after the Department’s decision is made.
- F. Permit Inspection – As required by ARM 17.8.755, Inspection of Permit, a copy of the air quality permit shall be made available for inspection by the Department at the location of the source.
- G. Permit Fee – Pursuant to Section 75-2-220, MCA, as amended by the 1991 Legislature, failure to pay the annual operation fee by Talen may be grounds for revocation of this permit, as required by that section and rules adopted thereunder by the Board.
- H. Duration of Permit – Construction or installation must begin or contractual obligations entered into that would constitute substantial loss within 3 years of permit issuance and proceed with due diligence until the project is complete or the permit shall expire (ARM 17.8.762).



## Attachment 2 (MEMS)

### MEMS

- a. For each Unit 1-4, Talen shall install, calibrate, certify, maintain, and operate a MEMS to monitor and record the rate of mercury emissions discharged into the atmosphere from all mercury emitting generating units (units) as defined in the Administrative Rules of Montana 17.8.740.
  - (1) The MEMS shall be comprised of equipment as required in 40 CFR 75.81(a) and defined in 40 CFR 72.2.
  - (2) The MEMS shall conform to all applicable requirements of 40 CFR Part 75.
  - (3) The MEMS data will be used to demonstrate compliance with the emission limitations contained in Section II.A.24.
- b. Talen shall prepare, maintain and submit a written MEMS Monitoring Plan to the Department.
  - (1) The monitoring plan shall contain sufficient information on the MEMS and the use of data derived from these systems to demonstrate that all the gaseous mercury stack emissions from each unit are monitored and reported.
  - (2) Whenever Talen makes a replacement, modification, or change in a MEMS or alternative monitoring system under 40 CFR 75 subpart E, including a change in the automated data acquisition and handling system (DAHS) or in the flue gas handling system, that affects information reported in the monitoring plan (e.g. a change to a serial number for a component of a monitoring system), then the owner or operator shall update the monitoring plan.
  - (3) If any monitoring plan information requires an update pursuant to Section b.(2), submission of the written monitoring plan update shall be completed prior to or concurrent with the submittal of the quarterly report required in c. below for the quarter in which the update is required.
  - (4) The initial submission of the Monitoring Plan to the Department shall include a copy of a written Quality Assurance/Quality Control (QA/QC) Plan as detailed in 40 CFR 75 Appendix B, Section 1. Subsequently, the QA/QC Plan need only be submitted to the Department when it is substantially revised. Substantial revisions can include items such as changes in QA/QC processes resulting from rule changes, modifications in the frequency or timing of QA/QC procedures, or the addition/deletion of equipment or procedures.
  - (5) The Monitoring Plan shall include, at a minimum, the following information:
    - (a) Facility summary including:
      - (i) A description of each mercury emitting generating unit at the facility.
      - (ii) Maximum and average loads (in megawatts (MW)) with fuels combusted and fuel flow rates at the maximum and average loads for each unit.

- (iii) A description of each unit's air pollution control equipment and a description of the physical characteristics of each unit's stack.
  - (b) Mercury emission control summary including a description of control strategies, equipment, and design process rates.
  - (c) MEMS description, including:
    - (i) Identification and description of each monitoring component in the MEMS including manufacturer and model identifications; monitoring method descriptions; and normal operating scale and units descriptions. Descriptions of stack flow, diluent gas, and moisture monitors (if used) in the system must be described in addition to the mercury monitor or monitors.
    - (ii) A description of the normal operating process for each monitor including a description of all QA/QC checks.
    - (iii) A description of the methods that will be employed to verify and maintain the accuracy and precision of the MEMS calibration equipment.
    - (iv) Identification and description of the DAHS, including major hardware and software components, conversion formulas, constants, factors, averaging processes, and missing data substitution procedures.
    - (v) A description of all initial certification and ongoing recertification tests and frequencies; as well as all accuracy auditing tests and frequencies.
  - (d) The Maximum Potential Concentration (MPC), Maximum Expected Concentration (MEC), span value, and range value as applicable and as defined in 40 CFR 75 Appendix A, 2.1.7.
  - (e) Examples of all data reports required in c. below.
- c. Talen shall submit written, Quarterly Mercury Monitoring Reports. The reports shall be received by the Department within 30 days following the end of each calendar quarter, and shall include, at a minimum, the following:
  - (1) Mercury emissions. The reports shall include:
    - (a) For each Unit 1-4, the monthly average lb/TBtu mercury emission rate for each month of the quarter;
    - (b) For each Unit 1-4, the 12-month rolling average lb/TBtu emission rate for each month of the reporting quarter. The rolling 12-month basis is an average of the last 12 individual calendar monthly averages, with each monthly average calculated at the end of each calendar month;
    - (c) For each Unit 1-4, the total heat input to the boiler (in TBtu) for each 12-month rolling period of the quarter; and

- (d) The 12-month facility-wide rolling average lb/TBtu mercury emission rate, calculated according to Permit Section II.A.24, for each month of the quarter.
- (2) Mercury excess emissions. The report shall describe the magnitude of excess mercury emissions experienced during the quarter, including:
- (a) The date and time of commencement and completion of each period of excess emissions. Periods of excess emissions shall be defined as those emissions calculated on a rolling 12-month basis which are greater than the limitation established in II.A.24.
  - (b) The nature and cause of each period of excess emissions and the corrective action taken or preventative measures adopted in response.
  - (c) If no periods of excess mercury emissions were experienced during the quarter, the report shall state that information.
- (3) MEMS performance. The report shall describe:
- (a) The number of operating hours that the MEMS was unavailable or not operating within quality assurance limits (monitor downtime) during the reporting quarter, broken down by the following categories:
    - Monitor equipment malfunctions;
    - Non-Monitor equipment malfunctions;
    - Quality assurance calibration;
    - Other known causes; and
    - Unknown causes.
  - (b) The percentage of unit operating time that the MEMS was unavailable or not operating within quality assurance limits (monitor downtime) during the reporting quarter. The percentage of monitor downtime in each calendar quarter shall be calculated according to the following formula:

$$MEMSDowntime\% = \left( \frac{MEMSDownHours}{OpHours} \right) \times 100 \quad \text{where}$$

MEMSDowntime% = Percentage of unit operating hours classified as MEMS monitor downtime during the reporting quarter.

MEMSDownHours = Total number of hours of MEMS monitor downtime during the reporting quarter.

OpHours = Total number of hours the unit operated during the reporting quarter.

- (c) For any reporting quarter in which monitor downtime exceeds 10%, a description of each time period during which the MEMS was inoperative or operating in a manner defined in 40 CFR Part 75 as “out of control.” Each description must include the date, start and end times, total downtime (in hours), the reason for the system downtime, and any necessary corrective actions that were taken. In addition, the report shall describe the values used for any periods when missing data substitution was necessary as detailed in 40 CFR 75.30, *et seq.*
  - (4) The quarterly report shall include the results of any QA/QC audits, checks, or tests conducted to satisfy the requirements of 40 CFR Part 75 Appendices A, B or K.
  - (5) Compliance certification. Each quarterly report shall contain a certification statement signed by the facility’s responsible official based on reasonable inquiry of those persons with primary responsibility for ensuring that all of the unit’s emissions are correctly and fully monitored. The certification shall indicate:
    - (a) Whether the monitoring data submitted were recorded in accordance with the applicable requirements of 40 CFR Part 75 including the QA/QC procedures and specifications of that part and its appendices, and any such requirements, procedures and specifications of an applicable excepted or approved alternative monitoring method as represented in the approved Monitoring Plan.
    - (b) That for all hours where data are substituted in accordance with 40 CFR 75.38, the add-on mercury emission controls were operating within the range of parameters listed in the quality-assurance plan for the unit, and that the substitute values do not systematically underestimate mercury emissions.
  - (6) The format of each component of the quarterly report may be negotiated with the Department’s representative to accommodate the capabilities and formats of the facility’s DAHS.
  - (7) Each quarterly report must be received by the Department within 30 days following the end of each calendar reporting period (January-March, April-June, July-September, and October-December).
  - (8) The electronic data reporting detailed in 40 CFR Part 75 shall not be required unless Montana is able to receive and process data in an electronic format.
- d. Talen shall maintain a file of all measurements and performance testing results from the MEMS; all MEMS performance evaluations; all MEMS or monitoring device calibration checks and audits; and records of all adjustments and maintenance performed on these systems or devices recorded in a permanent form suitable for inspection. The file shall be retained on site for at least five years following the date of such measurements and reports. Talen shall make these records available for inspection by the Department and shall supply these records to the Department upon request.

Attachment 3  
Wastewater Pond Site Wind Fence Locations  
(Wind fences shown as blue lines)



Source: Talen Montana, LLC Montana Air Quality Permit modification application #0513-10 (May 2018), Appendix D, Figure 4, Wind Fence Locations

Montana Air Quality Permit (MAQP) Analysis  
Talen Montana, LLC – Colstrip Steam Electric Station  
MAQP #0513-14

I. Introduction/Process Description

A. Facility Description

Talen Montana, LLC (Talen) operates Colstrip Steam Electric Station (Colstrip) Units 1, 2, 3 and 4 tangential coal-fired boilers and associated equipment for the generation of electricity. The Talen Colstrip facility is located in Section 34, Township 2 North, Range 41 East, in Rosebud County, Montana. A complete listing of facility equipment is found in the Permit Analysis.

B. Permitted Equipment

Talen operates the following equipment, including, but not limited to:

Units 1 and 2

- Unit #1 Tangential Coal-Fired Boiler
- Unit #2 Tangential Coal-Fired Boiler
- Coal Handling System
- Coal Piles
- Emergency Diesel Generators
- Internal Combustion Engine
- Plant Roads
- Process Ponds
- Underground Gasoline Tank
- Syncoal facility
- Petroleum Coke rail dump system
- Petroleum Coke truck dump system
- Unit #1 mercury emission control system (oxidizer/sorber injection system)
- Unit #2 mercury emission control system (oxidizer/sorber injection system)
- Units 1&2 mercury oxidizer/sorber handling system (one mercury sorbant storage silo that accommodates both Units 1&2, and associated fill and conveyance lines)
- Temporary propane-fired heaters for heating of maintenance and operations buildings

Units 3 and 4

- Unit #3 coal-fired boiler (778 Megawatts (MW))
- Unit #4 coal-fired boiler (778 MW)
- 16 venturi-type wet scrubbers (8 per unit) for particulate and sulfur dioxide (SO<sub>2</sub>) control
- Two stacks - 692 feet in height
- Coal transportation, storage and handling facilities
- Coal sampling facilities
- Auxiliary equipment

- Unit #3 mercury emission control system (oxidizer/sorber injection system)
- Unit #4 mercury emission control system (oxidizer/sorber injection system)
- Units 3&4 mercury oxidizer/sorber handling system (two mercury sorbant storage silos and associated fill and conveyance lines)
- Temporary diesel-fired emergency-use boilers for heating of maintenance and operations buildings

Mechanical Evaporation System

- 8 Minetek (or demonstrated equivalent) evaporator units
- 31 Slimline (or demonstrated equivalent) evaporator units

C. Permit History

On April 23, 1973, Montana Air Quality Permit (**MAQP**) #513-111472 (**#0513-00**) was issued to the Montana Power Company (MPC) Colstrip (Colstrip) for the construction of Colstrip Units 1&2, and on August 26, 1981, a permit with the same number was issued to Colstrip for the operation of Colstrip Units 1&2.

**MAQP #0513-01** was issued to Colstrip to include the installation and operation of a Syncoal Truck Dump and a lime silo bin vent. Syncoal fines and coarse product are combined to form a blend product that will be supplied to Units 1&2. The installation and operation of these sources will increase the allowable particulate emissions for Units 1&2 by 1.12 ton per year (TPY). MAQP #0513-01 replaced MAQP #0513-00 (513-111472).

**MAQP #1187** was issued to MPC on January 20, 1977, for the construction of Colstrip Units 3&4. Because the proposed facility was a major source under the Prevention of Significant Deterioration (PSD) program, the additional review requirements of the PSD program applied to the project. The state did not have authorization to implement the PSD program at the time of the application; therefore, the PSD review was conducted by the Environmental Protection Agency (EPA). EPA issued a PSD permit for the construction of the facility on September 11, 1979.

State **MAQP #1187-M** was issued on February 5, 1980, and **MAQP #1187-M2** was issued on May 26, 1981. The modifications were completed because of changes to the applicable rules and standards of the Administrative Rules of Montana (ARM).

On October 13, 1996, **MAQP #1187-03** was issued and correctly identified the actual maximum heat input capacity of Colstrip Units 3&4. The units are each rated at a heat-input capacity of 7,573 MMBtu/hour with a production capacity of 778 MW. These are nominal capacities for the facility and, depending on plant operating conditions, actual heat input to the facility may be as high as 8,000 MMBtu/hr.

MAQP #1187-M2 and the EPA permit contained emission limits for particulate, SO<sub>2</sub>, and oxides of nitrogen (NO<sub>x</sub>) with units of pounds per million British thermal units (lb/MMBtu). To ensure that emissions from the facility were not higher than those that the original analysis was based, this permit established emission limits for these pollutants in the units of pounds per hour (lb/hour).

The new emission limits were established based on the nominal heat input to the boilers of 7,573 MMBtu/hr multiplied by the current emission limits in lb/MMBtu. MAQP #1187-03 also placed a yearly fuel consumption limit on each unit. The limit was equal to the heat input of each unit operating at the nominal heat input rate of 7,573 MMBtu/hr for 8,760 hr/yr. This ensured that emissions of pollutants, that do not have limits in the permit, were not increased above current levels. The permit also incorporated requirements from the PSD permit issued by EPA in 1979. These requirements were incorporated at the request of MPC for the purpose of developing a comprehensive document that contained pertinent requirements from both the state permit and the EPA PSD permit. MAQP #1187-03 replaced MAQP #1187-M2.

On September 30, 1998, **MAQP #1187-04** was issued to MPC for the Colstrip 3&4 facility. The alteration included incorporation of a 3-hour rolling average SO<sub>2</sub> limit, the 1% inlet sulfur standard that was inadvertently removed during the previous modification, and the removal of the inlet monitor requirement.

The 3-hour SO<sub>2</sub> limit was incorporated in the permit to ensure protection of the 3-hour SO<sub>2</sub> standard. During the last permit action, the maximum heat inputs for Units 3&4 were discovered to be 8,000 MMBtu/hr. Because these heat inputs were higher than those in the original permit, the Department of Environmental Quality Air Quality Bureau (Department) and MPC agreed that short-term SO<sub>2</sub> and NO<sub>x</sub> emission limits would be implemented. The Department completed modeling for the short-term SO<sub>2</sub> emission limits. Colstrip was limited to a maximum of 4,273 lb/hr of SO<sub>2</sub>, averaged over any rolling 3-hour period from both stacks combined. These limits allowed MPC the flexibility of operating Unit 3 or Unit 4 at a higher level at any one time, while continuing to ensure protection of the standard.

The 1% inlet sulfur limit existed in the original permit, but was inadvertently removed during a previous permit action. MPC continued to maintain compliance with the 1% inlet sulfur limit, even though it was not stated in the permit.

The requirement for the inlet sulfur monitor as a compliance demonstration for the inlet sulfur content was replaced with an on-going fuel-sampling analysis. The on-going fuel-sampling analysis yielded a more accurate account of the sulfur content of the fuel, as compared to the sulfur content being correlated to SO<sub>2</sub> emissions.

The permitting action was an alteration of MAQP #1187-03 because of the change in the compliance demonstration for the 1% sulfur content limit. The 1% sulfur content limit and demonstration of compliance was included in the February 28, 1978, Board of Health and Environmental Sciences Findings of Fact and Conclusions of Law and Order. The alteration process allowed public involvement in the change in the compliance demonstration method. However, the permitting action did not result in any change in the emissions from the facility. MAQP #1187-04 replaced MAQP #1187-03.

In letters dated June 18, 1999, and August 16, 1999, the Montana Power Company and PPL Montana, LLC requested that the permits for Colstrip Units 1&2 and Colstrip Units 3&4 be transferred to reflect the new ownership. The transfer of the permits was to occur when the transfer of ownership to PPL Montana, LLC was



final. Through the Department's review, it was determined that Colstrip Units 1, 2, 3, and 4 would now be defined as one source. Therefore, the permit modification transferred ownership, as well as combined MAQPs #0513-01 and #1187-04. The permit conditions remained the same, but were simply combined into one permit. **MAQP #0513-02** replaced MAQPs #0513-01 and #1187-04.

On September 10, 2000, **MAQP #0513-03** was issued to Colstrip to conduct a test burn of petroleum coke/Syncoal/Rosebud coal fuel combination in Units 1&2. A petroleum coke consumption limit was placed in the permit to ensure that the proposed test burn did not exceed 15 tons per year of any pollutant. Because the emissions from this project were less than 15 tons per year of any pollutant, the project occurred in accordance with the ARM 17.8.745(1)(d). MAQP #0513-03 replaced MAQP #0513-02.

On July 7, 2001, **MAQP #0513-04** was issued to Colstrip to add petroleum coke to the list of fuels to be used in Units 1 and 2 that are currently permitted to burn Syncoal and Rosebud coal. The permitting action limited the amount of petroleum coke that may be burned in Units 1 and 2 and was not considered a major modification under the PSD regulations because the facility was capable of accommodating petroleum coke. The conditions associated with this permitting action are Section II.A.9, 10, 11, 12, and 13, Section II.B.3 and Section II.E. MAQP #0513-04 replaced MAQP #0513-03.

On January 11, 2005, Arnold & Porter LLP, on behalf of Colstrip, submitted a request for an administrative amendment to MAQP #0513-04. The request was to reduce the 3-hour rolling average SO<sub>2</sub> emissions limit (combined stack limit) for Units 3&4 from 4,273 lb/hr to 4,140 lb/hr.

The request was submitted in response to an outstanding concern of the Department and the Northern Cheyenne Tribe regarding emissions modeling for SO<sub>2</sub> increment consumption conducted for the issuance of the 1979 PSD permit for Units 3 and 4. Included in the permit application, Colstrip submitted AERMOD modeling to demonstrate compliance with the Class I PSD increment for SO<sub>2</sub> on the Northern Cheyenne Reservation. The Department, in consultation with EPA Region VIII and the Northern Cheyenne Tribe, requested an additional sensitivity analysis be conducted at a 75% load scenario to comply with national modeling guidance and the model's demonstrated sensitivity to plume rise. Colstrip submitted the sensitivity analysis demonstrating that the proposed SO<sub>2</sub> limit of 4,140 lb/hr would protect the 3-hour increment on the Northern Cheyenne Reservation.

In addition, Colstrip submitted a request to the Department on November 20, 2000, to remove the ambient air quality monitoring requirements from MAQP #0513-04 for Units 3&4. Based on the request and additional information submitted on October 3, 2001, the Department approved the removal of the monitoring requirements. The Department sent a letter on October 19, 2001, after PPL demonstrated that the potential to cause a violation of the ambient standard is minimal at all sites and monitoring may be removed as provided for in the October 1998 Department guidance.

The permit format, language, and rule references were updated to reflect current Department permit format, language and rule references. **MAQP #0513-05** replaced MAQP #0513-04.

On October 23, 2007, PPL Montana, LLC submitted a request for an administrative amendment to MAQP #0513-05. The request was to incorporate revised NO<sub>x</sub> standards for Colstrip's Units 3 and 4, as stipulated by Consent Decree CV-07-40-BLG-RFG-CSO entered on May 14, 2007 (Consent Decree). In addition, the Department was requested to clarify that the compliance demonstration for the revised limits would be demonstrated for an "operating day" firing any fuel, which would go beyond the Consent Decree requirements. **MAQP #0513-06** replaced MAQP #0513-05.

On December 31, 2008, PPLM submitted an application to modify MAQP #0513-06, with additional information submitted on January 8, 2009. The modification was to establish a mercury emission limit for each of PPLM Colstrip Units 1-4, pursuant to ARM 17.8.771, and to provide an analysis of potential mercury control options including, but not limited to, boiler technology, mercury emission control technology, and any other mercury control practices. The application also included a proposed mercury emission control strategy. MAQP #0513-07 established a mercury emission limit and associated operating requirements for Colstrip Units 1-4 in order to comply with ARM 17.8.771. **MAQP #0513-07** replaced MAQP #0513-06.

On January 28, 2010, PPLM requested an administrative amendment to MAQP #0513-07. The amendment was to update a compliance date for NO<sub>x</sub> emissions from Colstrip Unit 4 pursuant to its Consent Decree. A stipulation to the Consent Decree was filed on December 22, 2009, due to the occurrence of a Force Majeure incident, such that a new compliance date for installation and operation of the digital controls, low-NO<sub>x</sub> burners and overfire air was established to be March 31, 2010 or seven days after the completion of NO<sub>x</sub> emission controls tuning, whichever date is earlier. Tuning was completed on Unit 4 NO<sub>x</sub> control systems on January 12, 2010. This amendment updated the permit to reflect the changes to the Consent Decree; specifically, the applicable compliance dates in Sections II.A.18 and 20 were updated to January 19, 2010. **MAQP #0513-08** replaced MAQP #0513-07.

On May 7, 2015, the Department received an administrative amendment request to change the company name from PPL Montana, LLC to Talen Montana, LLC. Except for the name, the company continued with the same legal ownership interest and operator role concerning the Colstrip Steam Electric Station. Personnel, assets, and organization remained unchanged. The MAQP was also updated to reflect the current Department format and references to applicable federal regulations. **MAQP #0513-09** replaced MAQP #0513-08.

On May 7, 2018, the Department received a permit application from Talen to authorize the operation of a mechanical evaporation system for the existing wastewater ponds. Additional information was provided on May 24, 2018. The existing wastewater ponds are located approximately 2.5 miles southeast of the main power plant. The pond area is approximately 367 acres and contains several wastewater cells. Talen installed mechanical evaporators for the existing wastewater

ponds between 2006 and 2017 to aid in the reduction of excess water, to reduce potential of seepage from the ponds and help protect the groundwater, and to help ensure compliance with the United States Environmental Protection Agency (EPA) rules on disposal of Coal Combustion Residuals (CCR) from electric utilities under subtitle D of the Resource Conservation and Recovery Act (RCRA). As the water currently stored in the pond contains dissolved solids, the mechanical evaporation of water forms droplets that may result in the formation of PM as the water droplets evaporate. Talen had not considered the evaporation system to be a new source of air emissions since the wastewater ponds were already accounted for in the Title V Operating Permit. In October 2017, Talen conducted an emission factor development study to measure the ambient particulate matter concentrations resulting from emissions from these units and to reverse-model an emission rate for the two models of evaporators on site. These emission rates, in conjunction with the proposed limits on operation of the evaporators, were used to determine the maximum potential emissions from the evaporators. Talen had ceased operation of the evaporators since discovering that they trigger the need for an MAQP modification and did not restart them until issuance of this permit. Based on comments received during the public comment period on the draft permit, the Department added the specific operational parameters for wind speed, wind direction, ambient air temperature, and relative humidity that are part of the strategy to contain the potential evaporation drift within the pond to the permit condition related to best management practices before issuing the Department Decision. The condition at Section II.D.10 of the draft permit, which had required that Talen document these operational parameters and provide them to the Department upon request, was eliminated because they are now included in the enforceable permit condition at Section II.A.30. **MAQP #0513-10** replaced MAQP #0513-09.

On January 22, 2019, the Department received a permit application from Talen for the construction of a coal unloading facility. The application provided six different alternate operating scenarios and estimated the maximum potential increase in emissions from each scenario. The maximum amount of coal to be brought to the Colstrip facility via truck and/or railcar is 7 million tons per year. The scenarios summarized in the following table show the rank by particulate matter (PM) emissions from each throughput scenario. The maximum emissions scenario is ranked “1<sup>st</sup>”.

Scenario	Coal Throughput (Tons Per Year)	Delivery Method	PM Emissions Rank
1	1 Million	Haul Truck	6 <sup>th</sup> (Low)
2	3.5 Million	Haul Truck	3 <sup>rd</sup>
3	7 Million	Haul Truck	1 <sup>st</sup> (High)
4	1 Million	Railcar	5 <sup>th</sup>
5	3.5 Million	Railcar	4 <sup>th</sup>
6	7 Million	Railcar	2 <sup>nd</sup>

The coal would be unloaded from truck and/or rail and transferred via conveyor(s) or front end loader (FEL) to a coal storage pile and/or directly to the existing plant conveyor and coal storage system. Only a portion of the new storage pile would be active at any given time, and the remainder would be inactive and have chemical

surfactants applied in order to create a crust and prevent wind erosion. A FEL would be used to move the coal around the new storage pile. Coal would be transported via FEL to conveyors from the new storage pile into the existing plant conveyor and storage system. Only one new storage pile would be constructed as part of this project for Scenarios 2-6. Scenario 1 would use existing storage piles. Emissions would be generated from the new paved haul road, truck/railcar unloading, unpaved FEL path, conveyor material transfers, and wind erosion from the storage pile. **MAQP #0513-11** replaced MAQP #0513-10.

On April 8, 2019, the Department received an MAQP application in accordance with the requirements of ARM 17.8.771(9) to address the Best Available Control Technology (BACT) requirement for mercury emissions. ARM 17.8.771(9) requires that no later than 10 years after issuance of a permit containing a mercury emission limit under ARM 17.8.771(1)(b)(i), and every 10 years thereafter, the affected facility must file an application to establish a revised mercury emission limit. PPL Montana, LLC, the name of the operators of the Colstrip facility at the time, was issued an MAQP establishing a mercury emissions limit for Units 1 – 4 on April 9, 2009. This application fulfilled the ARM 17.8.771(9) requirement. Talen proposed to retain the mercury emission limit of 0.9 pounds per trillion British thermal units (lb/TBtu) on a rolling 12-month average basis. The Department concurred with the findings of the BACT analysis and maintained the mercury emission limit of 0.9 lb/TBtu on a rolling 12-month average basis in the MAQP. **MAQP #0513-12** replaced MAQP #0513-11.

On October 25, 2019, the Department received notification from Talen of their intent to place two temporary, diesel-fired boiler units for emergency heating of maintenance and operations buildings on Colstrip Units 3 and 4. These boilers would provide auxiliary steam for heating systems in the event that both Units 3 and 4 experienced a simultaneous outage during the timeframe beginning January 1, 2020 and concluding April 30, 2020. After January 1, 2020, the loss of the usual source of heat in these areas (auxiliary steam from Units 3 and/or 4) could lead to adverse effects on facility safety. Operation during this scenario is consistent with the exemption from requiring an MAQP as described in ARM 17.8.744(1)(g); however, the exemption only extends to operation to alleviate the adverse effects on facility safety.

On October 28, 2019, the Department received notification from Talen for the use of temporary propane-fired heating equipment for maintenance and operations buildings on Colstrip Units 1 and 2. The operation of these units meets the exemption from requiring an MAQP as a de minimis change described in ARM 17.8.745 when their operation is restricted by production limits as depicted in the notification and made enforceable in accordance with ARM 17.8.745(2).

The current permit action amends the MAQP in accordance with ARM 17.8.745(2) and ARM 17.8.764 to establish production limits on the operation of the equipment described in the October 25 and 28, 2019 notifications. **MAQP #0513-13** replaces MAQP #0513-12.

D. Current Permit Action

On September 3, 2020, the Department received a request to administratively amend MAQP #0513 from Talen. Talen requested to remove the permit modifications made in March 2019 (MAQP #0513-11) authorizing (but not requiring) the construction and operation of coal unloading facilities to accommodate the use of coal obtained from certain mines other than the Rosebud Mine. Talen made this request pursuant to the Settlement Agreement dated August 31, 2020 between the Department, Talen, Westmoreland Mining LLC, and Westmoreland Rosebud Mining LLC. Also addressed in the correspondence is the rescission of the 2019 Major Facility Siting Act (MFSA) certificate amendment which provided Talen with an option to procure and utilize coal from certain mines other than the Rosebud Mine. Rescission of the MFSA amendments and administrative amendment of the MAQP, as agreed to by the parties under the Settlement Agreement, is intended to restore the relevant MAQP and MFSA certificate to the situation as though the relevant March 2019 MAQP changes and the May 2019 MFSA amendments related to the coal unloading facilities and use of non-Rosebud coal never occurred. The current permit action removes the permit conditions associated with coal unloading facilities established as part of MAQP #0513-11. **MAQP #0513-14** replaces MAQP #0513-13.

E. Additional Information

Additional information, such as applicable rules and regulations, Best Available Control Technology (BACT) determinations, air quality impacts, and environmental assessments, is included in the analysis associated with each change to the permit.

II. Applicable Rules and Regulations

The following are partial explanations of some applicable rules and regulations that apply to the facility. The complete rules are stated in the ARM and are available, upon request, from the Department. Upon request, the Department will provide references for location of complete copies of all applicable rules and regulations or copies where appropriate.

A. ARM 17.8, Subchapter 1 – General Provisions, including but not limited to:

1. ARM 17.8.101 Definitions. This rule includes a list of applicable definitions used in this chapter, unless indicated otherwise in a specific subchapter.
2. ARM 17.8.105 Testing Requirements. Any person or persons responsible for the emission of any air contaminant into the outdoor atmosphere shall, upon written request of the Department, provide the facilities and necessary equipment (including instruments and sensing devices) and shall conduct tests, emission or ambient, for such periods of time as may be necessary using methods approved by the Department.
3. ARM 17.8.106 Source Testing Protocol. The requirements of this rule apply to any emission source testing conducted by the Department, any source or other entity as required by any rule in this chapter, or any permit or order

issued pursuant to this chapter, or the provisions of the Clean Air Act of Montana, 75-2-101, *et seq.*, Montana Code Annotated (MCA).

Talen shall comply with the requirements contained in the Montana Source Test Protocol and Procedures Manual, including, but not limited to, using the proper test methods and supplying the required reports. A copy of the Montana Source Test Protocol and Procedures Manual is available from the Department upon request.

4. ARM 17.8.110 Malfunctions. (2) The Department must be notified promptly by telephone whenever a malfunction occurs that can be expected to create emissions in excess of any applicable emission limitation or to continue for a period greater than 4 hours.
5. ARM 17.8.111 Circumvention. (1) No person shall cause or permit the installation or use of any device or any means that, without resulting in reduction of the total amount of air contaminant emitted, conceals or dilutes an emission of air contaminant that would otherwise violate an air pollution control regulation. (2) No equipment that may produce emissions shall be operated or maintained in such a manner as to create a public nuisance.

B. ARM 17.8, Subchapter 2 – Ambient Air Quality, including, but not limited to the following:

1. ARM 17.8.210 Ambient Air Quality Standards for Sulfur Dioxide
2. ARM 17.8.211 Ambient Air Quality Standards for Nitrogen Dioxide
3. ARM 17.8.212 Ambient Air Quality Standards for Carbon Monoxide
4. ARM 17.8.213 Ambient Air Quality Standard for Ozone
5. ARM 17.8.214 Ambient Air Quality Standard for Hydrogen Sulfide
6. ARM 17.8.220 Ambient Air Quality Standard for Settled Particulate Matter
7. ARM 17.8.221 Ambient Air Quality Standard for Visibility
8. ARM 17.8.222 Ambient Air Quality Standard for Lead
9. ARM 17.8.223 Ambient Air Quality Standard for PM-10

Talen must maintain compliance with the applicable ambient air quality standards.

C. ARM 17.8, Subchapter 3 – Emission Standards, including, but not limited to:

1. ARM 17.8.304 Visible Air Contaminants. (1) This rule requires that no person may cause or authorize emissions to be discharged into the outdoor atmosphere from any sources installed on or before November 23, 1968, that exhibit an opacity of 40% or greater averaged over 6 consecutive minutes. (2) This rule requires that no person may cause or authorize emissions to be discharged into the outdoor atmosphere from any source installed after November 23, 1968, that exhibit an opacity of 20% or greater averaged over 6 consecutive minutes.
2. ARM 17.8.308 Particulate Matter, Airborne. (1) This rule requires an opacity limitation of less than 20% for all fugitive emission sources and that reasonable precautions be taken to control emissions of airborne particulate

matter. (2) Under this rule, Talen shall not cause or authorize the use of any street, road, or parking lot without taking reasonable precautions to control emissions of airborne particulate matter.

3. ARM 17.8.309 Particulate Matter, Fuel Burning Equipment. This rule requires that no person shall cause, allow, or permit to be discharged into the atmosphere particulate matter caused by the combustion of fuel in excess of the amount determined by this rule.
4. ARM 17.8.310 Particulate Matter, Industrial Process. This rule requires that no person shall cause, allow, or permit to be discharged into the atmosphere particulate matter in excess of the amount set forth in this rule.
5. ARM 17.8.322 Sulfur Oxide Emissions--Sulfur in Fuel. (4) Commencing July 1, 1972, no person shall burn liquid or solid fuels containing sulfur in excess of 1 pound of sulfur per million British thermal units (Btu) fired. (5) Commencing July 1, 1971, no person shall burn any gaseous fuel containing sulfur compounds in excess of 50 grains per 100 cubic feet of gaseous fuel, calculated as hydrogen sulfide at standard conditions.
6. ARM 17.8.324 Hydrocarbon Emissions--Petroleum Products. (3) No person shall load or permit the loading of gasoline into any stationary tank with a capacity of 250 gallons or more from any tank truck or trailer, except through a permanent submerged fill pipe, unless such tank is equipped with a vapor loss control device as described in (1) of this rule, or is a pressure tank as described in (1) of this rule.
7. ARM 17.8.340 Standard of Performance for New Stationary Sources. This rule incorporates, by reference, 40 CFR Part 60, Standards of Performance for New Stationary Sources (NSPS).
  - a. Subpart A, General Provisions. This subpart applies to all equipment or facilities subject to an NSPS Subpart as listed below:
  - b. Subpart Y, Standards of Performance for Coal Preparation Plants. This subpart applies to the Syncoal truck dump and silo bin vent which are considered NSPS affected facilities because these sources meet the definition of a coal storage system and transfer and loading system constructed after October 24, 1974.
  - c. Subpart D, Standard of Performance for Fossil-Fuel Fired Steam Generators. This subpart does apply to Units 1, 2, 3, and 4 because they have the capabilities of firing fossil fuel at a heat input rate of more than 250 MMBtu/hr and were constructed after August 17, 1971.
  - d. Subpart Da, Standards of Performance for Electric Utility Steam Generating Units for Which Construction is Commenced After September 18, 1978. This section does not apply to Units 3 and 4 because construction on the units had commenced prior to 1978.

However, some sections of Subpart Da have been incorporated by reference into this permit.

8. ARM 17.8.342 Emission Standards for Hazardous Air Pollutants for Source Categories. The source, as defined and applied in 40 CFR Part 63, shall comply with the requirements of 40 CFR Part 63, as listed below:
  - a. 40 CFR 63, Subpart A – General Provisions apply to all equipment or facilities subject to an NESHAP Subpart as listed below:
  - b. 40 CFR 63, Subpart ZZZZ – National Emissions Standards for Hazardous Air Pollutants (HAPs) for Stationary Reciprocating Internal Combustion Engines (RICE). An owner or operator of a stationary reciprocating internal combustion engine (RICE) at a major or area source of HAP emissions is subject to this rule except if the stationary RICE is being tested at a stationary RICE test cell/stand. An area source of HAP emissions is a source that is not a major source. The emergency RICE at Talen Colstrip are subject to this regulation.
  - c. 40 CFR 63, Subpart UUUUU – National Emission Standards for Hazardous Air Pollutants: Coal- and Oil-Fired Electric Utility Steam Generating Units. Units 1, 2, 3, and 4 meet the definition of an affected source under this subpart.

D. ARM 17.8, Subchapter 5 – Air Quality Permit Application, Operation, and Open Burning Fees, including, but not limited to:

1. ARM 17.8.504 Air Quality Permit Application Fees. This rule requires that an applicant submit an air quality permit application fee concurrent with the submittal of an air quality permit application. A permit application is incomplete until the proper application fee is paid to the Department. A permit fee is not required for the current permit action because the permit action is considered an administrative permit change.
2. ARM 17.8.505 Air Quality Operation Fees. An annual air quality operation fee must, as a condition of continued operation, be submitted to the Department by each source of air contaminants holding an air quality permit (excluding an open burning permit) issued by the Department. The air quality operation fee is based on the actual or estimated actual amount of air pollutants emitted during the previous calendar year.

An air quality operation fee is separate and distinct from an air quality permit application fee. The annual assessment and collection of the air quality operation fee, described above, shall take place on a calendar-year basis. The Department may insert into any final permit issued after the effective date of these rules, such conditions as may be necessary to require the payment of an air quality operation fee on a calendar-year basis, including provisions that pro-rate the required fee amount.



- E. ARM 17.8, Subchapter 7 – Permit, Construction, and Operation of Air Contaminant Sources, including, but not limited to:
1. ARM 17.8.740 Definitions. This rule is a list of applicable definitions used in this chapter, unless indicated otherwise in a specific subchapter.
  2. ARM 17.8.743 Montana Air Quality Permits--When Required. This rule requires a person to obtain an air quality permit or permit modification to construct, modify, or use any air contaminant sources that have the potential to emit (PTE) greater than 25 tpy of any pollutant. Talen Colstrip has the PTE greater than 25 tons per year of NO<sub>x</sub>, SO<sub>2</sub>, carbon monoxide (CO), volatile organic compounds (VOC), particulate matter (PM), and particulate matter with an aerodynamic diameter of 10 microns or less (PM<sub>10</sub>); therefore, an air quality permit is required.
  3. ARM 17.8.744 Montana Air Quality Permits--General Exclusions. This rule identifies the activities that are not subject to the Montana Air Quality Permit program.
  4. ARM 17.8.745 Montana Air Quality Permits--Exclusion for De Minimis Changes. This rule identifies the de minimis changes at permitted facilities that do not require a permit under the Montana Air Quality Permit Program.
  5. ARM 17.8.748 New or Modified Emitting Units--Permit Application Requirements. (1) This rule requires that a permit application be submitted prior to installation, modification, or use of a source. A permit application was not required for the current permit action because the permit change is considered an administrative permit change. (7) This rule requires that the applicant notify the public by means of legal publication in a newspaper of general circulation in the area affected by the application for a permit. An affidavit of proof of publication of public notice was not required for the current permit action because the permit change is considered an administrative permit change.
  6. ARM 17.8.749 Conditions for Issuance or Denial of Permit. This rule requires that the permits issued by the Department must authorize the construction and operation of the facility or emitting unit subject to the conditions in the permit and the requirements of this subchapter. This rule also requires that the permit must contain any conditions necessary to assure compliance with the Federal Clean Air Act (FCAA), the Clean Air Act of Montana, and rules adopted under those acts.
  7. ARM 17.8.752 Emission Control Requirements. This rule requires a source to install the maximum air pollution control capability that is technically practicable and economically feasible, except that BACT shall be utilized. The required BACT analysis is included in Section III of this permit analysis.
  8. ARM 17.8.755 Inspection of Permit. This rule requires that air quality permits shall be made available for inspection by the Department at the location of the source.

9. ARM 17.8.756 Compliance with Other Requirements. This rule states that nothing in the permit shall be construed as relieving Talen of the responsibility for complying with any applicable federal or Montana statute, rule, or standard, except as specifically provided in ARM 17.8.740, *et seq.*
10. ARM 17.8.759 Review of Permit Applications. This rule describes the Department's responsibilities for processing permit applications and making permit decisions on those permit applications that do not require the preparation of an environmental impact statement.
11. ARM 17.8.762 Duration of Permit. An air quality permit shall be valid until revoked or modified, as provided in this subchapter, except that a permit issued prior to construction of a new or modified source may contain a condition providing that the permit will expire unless construction is commenced within the time specified in the permit, which in no event may be less than 1 year after the permit is issued.
12. ARM 17.8.763 Revocation of Permit. An air quality permit may be revoked upon written request of the permittee, or for violations of any requirement of the Clean Air Act of Montana, rules adopted under the Clean Air Act of Montana, the FCAA, rules adopted under the FCAA, or any applicable requirement contained in the Montana State Implementation Plan (SIP).
13. ARM 17.8.764 Administrative Amendment to Permit. An air quality permit may be amended for changes in any applicable rules and standards adopted by the Board of Environmental Review (Board) or changed conditions of operation at a source or stack that do not result in an increase of emissions as a result of those changed conditions. The owner or operator of a facility may not increase the facility's emissions beyond permit limits unless the increase meets the criteria in ARM 17.8.745 for a de minimis change not requiring a permit, or unless the owner or operator applies for and receives another permit in accordance with ARM 17.8.748, ARM 17.8.749, ARM 17.8.752, ARM 17.8.755, and ARM 17.8.756, and with all applicable requirements in ARM Title 17, Chapter 8, Subchapters 8, 9, and 10.
14. ARM 17.8.765 Transfer of Permit. This rule states that an air quality permit may be transferred from one person to another if written notice of intent to transfer, including the names of the transferor and the transferee, is sent to the Department.
15. ARM 17.8.771 Mercury Emission Standards for Mercury-Emitting Generating Units. This rule identifies mercury emission limitation requirements, mercury control strategy requirements, and application requirements for mercury-emitting generating units. (9) No later than ten years after issuance of the permit containing the mercury emission limit, and every ten years thereafter, the owner or operator of a mercury-emitting generating unit, for which the Department has established a mercury emission limit under this rule, shall file an application with the Department

to establish a revised mercury emission limit. The application associated with MAQP #0513-12 fulfills this requirement.

F. ARM 17.8, Subchapter 8 – Prevention of Significant Deterioration of Air Quality, including, but not limited to:

1. ARM 17.8.801 Definitions. This rule is a list of applicable definitions used in this subchapter.
2. ARM 17.8.818 Review of Major Stationary Sources and Major Modifications-Source Applicability and Exemptions. The requirements contained in ARM 17.8.819 through ARM 17.8.827 shall apply to any major stationary source and any major modification, with respect to each pollutant subject to regulation under the FCAA that it would emit, except as this subchapter would otherwise allow.

This facility is a listed source and has a PTE of 100 tpy or more of pollutants subject to regulation under the FCAA; therefore, the facility is major. However, this permit action will not result in a significant net emissions increase and therefore does not require a Prevention of Significant Deterioration (PSD) analysis.

G. ARM 17.8, Subchapter 12 – Operating Permit Program Applicability, including, but not limited to:

1. ARM 17.8.1201 Definitions. (23) Major Source under Section 7412 of the FCAA is defined as any source having:
  - a. PTE > 100 tpy of any pollutant;
  - b. PTE > 10 tpy of any one hazardous air pollutant (HAP), PTE > 25 tpy of a combination of all HAPs, or lesser quantity as the Department may establish by rule; or
  - c. PTE > 70 tpy of PM<sub>10</sub> in a serious PM<sub>10</sub> nonattainment area.
2. ARM 17.8.1204 Air Quality Operating Permit Program. (1) Title V of the FCAA amendments of 1990 requires that all sources, as defined in ARM 17.8.1204(1), obtain a Title V Operating Permit. In reviewing and issuing MAQP #0513-14 for Talen, the following conclusions were made:
  - a. The facility's PTE is greater than 100 tpy for several pollutants.
  - b. The facility's PTE is greater than 10 tpy of any one HAP and less than 25 tpy of all HAPs.
  - c. This source is not located in a serious PM<sub>10</sub> nonattainment area.
  - d. This facility is subject to 40 CFR 60, Subparts A, D, and Y.
  - e. This facility is subject to 40 CFR 63, Subparts A, UUUUU, and ZZZZ.

f. This source is a Title IV affected source.

g. This source is not an EPA designated Title V source.

Based on these facts, the Department has determined that Talen Colstrip is a major source of emissions as defined under Title V. Talen was issued a final and effective renewal of their Title V Operating Permit (#OP0513-14) on July 17, 2018.

### III. BACT Determination

A BACT determination is required for each new or modified source. Talen shall install on the new or modified source the maximum air pollution control capability which is technically practicable and economically feasible, except that BACT shall be utilized.

A BACT determination was not required for the current permit action because the permit change is considered an administrative permit change.

IV. Emission Inventory

**Units 1 & 2 Temporary Heaters (MAQP #0513-13)**

Equipment Description	Use	Period of Use <sup>a</sup>	Hours Used <sup>a</sup>	Size <sup>b</sup>	Fuel
Temporary Heating for Colstrip Units 1 & 2 Maintenance and Operations Buildings	Cold Weather Protection	January 1, 2020 through April 30, 2020	2904 (maximum allowed)	2.4 MMBtu/hr (9 total)	Propane

a – Estimate of maximum usage representing a January 1, 2020 start date and round-the-clock usage for the period 1/1/20 through 4/30/20; Actual usage will be less and will be dependent upon weather conditions

b – Cumulative heat input rating for 9 heaters of 2.4 MMBtu/hr rating each is 21.6 MMBtu/hr

Equipment Description	Size	Maximum Allowable Usage Hours	Emission Type	Estimated Annual Emissions (Tons)
Propane heating units – Colstrip Units 1&2 Temporary Heating	2.4 MMBtu/hr (9 total at 238.7 GPH <sup>c</sup> )	2904		
			CO	2.57
			NOx	4.46
			VOC	0.27
			SO2	0.51
			PM (total)	0.24
			PM (2.5)	0.07
			GHG CO2e <sup>d</sup>	4,382

c - Based upon propane heating value of 91,500 Btu/gallon from AP-42, Section 1.5.1, Chapter 1.5 – Liquid Propane Combustion, July 2008

d – Includes CO2, methane (CH4), and nitrous oxide (N2O)

The method for calculating the emissions is summarized below<sup>3</sup>. Estimated

Emissions from Propane-fired heating units:

$$E = FR \times H \times EF \times 0.001 \div 2000$$

Where:

E = Annual Emissions (Tons/Yr)

FR = Maximum Fuel Use Rating (GPH) H = Annual Hours of Operation per Year

EF<sup>4</sup> = Pollutant Emission Factor in lbs per 1000 Gallons

0.001 = conversion factor, lbs per 1000 gallons to lbs per gallon 2000 = conversion factor, pounds per ton

Example for carbon monoxide (CO):

$E = 238.7 \text{ GPH} \times 2904 \text{ Hours/year} \times 7.5 \text{ lb/1000 gallons (from Emission Factors Table)} \times 0.001 \text{ lbs per gallon per lbs per 1000 gallons} \div 2000 \text{ pounds per ton}$

$E = 238.7 \times 2904 \times 7.5 \times 0.001 \div 2000$

$E = 2.60 \text{ Tons/yr}$

<sup>3</sup> CO<sub>2</sub>e is calculated by first applying appropriate emission factors as demonstrated here for applicable GHG's, in this case CO<sub>2</sub>, methane (CH<sub>4</sub>), and nitrous oxide (N<sub>2</sub>O); then multiplying each GHG's calculated mass by its global warming potential (GWP) as defined in Table A-1 to subpart A of 40CFR98, which yields the CO<sub>2</sub>e of each GHG; and then summing the resulting CO<sub>2</sub>e of all GHG's; GWP for CH<sub>4</sub>: 21; GWP for N<sub>2</sub>O: 310

<sup>4</sup> From Emission Factors Table in This Letter

**Emission Factors<sup>5</sup>:**

Fuel Type	Emission	Emission Factor (lb/1000 gallons)
Propane	CO	7.50
	NO <sub>x</sub>	13.00
	VOC	0.8
	SO <sub>2</sub>	1.50
	PM (total)	0.70
	PM (2.5)	0.20
	GHGs	CO <sub>2</sub> : 12,500; CH <sub>4</sub> :0.2; N <sub>2</sub> O: 0.9

<sup>5</sup> AP-42, Section 1.5 - Liquid Petroleum Gas Combustion, Table 1.5-1 - Emission Factors for LPG Combustion, July, 2008. Sulfur concentration based on Gas Processors Association Engineering Data Book (Ninth Edition, 1972), Figure 15-50 (GPA Liquefied Petroleum Gas Specifications, rev. 1979), Commercial Propane = 15 gr/100 scf

**Units 3 & 4 Temporary Boilers (MAQP #0513-13)**

Equipment Description	Use	Period of Use <sup>a</sup>	Hours Used <sup>a</sup>	Size <sup>b</sup>	Fuel
Emergency Heating for Colstrip Units 3&4 Maintenance and Operations Buildings	Cold Weather Protection During Dual Unit Outage	Through April 30, 2020	39 (maximum allowed)	89.4 MMBtu/hr (2 total)	No. 2 Diesel

a – Estimate of maximum usage for situations that are not covered by ARM 17.8.744(1)(g)

b – Cumulative heat input rating for 2 boilers is 178.8 MMBtu/hr (89.4 MMBtu/hr rating each)

A summary of the maximum allowable emissions from the heating units for situations not covered by ARM 17.8.744(1)(g) is compiled below.

Equipment Description	Size	Maximum Allowable Usage (non-emergency) Hours	Emission Type	Estimated Annual Emissions (Tons)
Diesel fired heating units – Colstrip Units 3&4 Emergency Heating	89.4 MMBtu/hr (2 total at 1250 GPH <sup>c</sup> )	39		
			CO	0.12
			NOx	0.50
			VOC	0.01
			SO2	0.01
			PM (total)	0.08
			PM (2.5)	0.01
			GHG CO2e <sup>d</sup>	555

c – Rated Diesel Consumption from Manufacturer, Indeck Power, Inc.

d – Includes CO2, methane (CH4), and nitrous oxide (N2O)

The method for calculating the emissions is summarized below<sup>3</sup>.

Estimated Emissions from diesel fired heating units:

$$E = FR \times H \times EF \times 0.001 \div 2000$$

Where:

E = Annual Emissions (Tons/Yr)

FR = Maximum Fuel Use Rating (GPH) H =

Annual Hours of Operation per Year

EF<sup>4</sup> = Pollutant Emission Factor in lbs per 1000 Gallons

0.001 = conversion factor, lbs per 1000 gallons to lbs per gallon 2000 =  
conversion factor, pounds per ton

Example for carbon monoxide (CO):

E = 1250 GPH x 168 Hours/year x 5 lb/1000 gallons (from Emission Factors Table) x  
0.001 lbs per gallon per lbs per 1000 gallons ÷ 2000 pounds per ton

<sup>3</sup> CO<sub>2</sub>e is calculated by first applying appropriate emission factors as demonstrated here for applicable GHG's, in this case CO<sub>2</sub>, methane (CH<sub>4</sub>), and nitrous oxide (N<sub>2</sub>O); then multiplying each GHG's calculated mass by its global warming potential (GWP) as defined in Table A-1 to subpart A of 40CFR98, which yields the CO<sub>2</sub>e of each GHG; and then summing the resulting CO<sub>2</sub>e of all GHG's; GWP for CH<sub>4</sub>: 21; GWP for N<sub>2</sub>O: 310

<sup>4</sup> From Emission Factors Table in This Letter

**Emission Factors<sup>5</sup>:**

Fuel Type	Emission	Emission Factor (lb/1000 gallons)
Diesel	CO	5.00
	NOx	20
	VOC	0.20
	SO <sub>2</sub>	0.21
	PM (total)	1.32
	PM (2.5)	0.006
	GHGs	CO <sub>2</sub> : 22,300; CH <sub>4</sub> :0.052; N <sub>2</sub> O: 0.26

<sup>5</sup> AP-42, Section 1.3 – Fuel Oil Combustion, Table 1.3-1 – Criteria Pollutant Emission Factors for Fuel Oil Combustion; Table 1.3-3. Emission Factors for Total Organic Compounds [From Uncontrolled Fuel Oil Combustion]; Table 1.3-7. [Size-Specific Emission Factors [for] Uncontrolled Commercial Boilers Burning Residual or Distillate Oil]; Table 1.3-8. Emission factors for Nitrous Oxide (N<sub>2</sub>O), Polycyclic Organic Matter (POM), and Formaldehyde (HCOH) From Fuel Oil Combustion; and Table 1.3-12. Default CO<sub>2</sub> Emission Factors for Liquid Fuels; May 2010. Sulfur concentration is based on EPA Ultra Low Sulfur Standard of 15 ppm.

**Total Maximum Potential Emissions Increases from MAQP #0513-13**

	CO	NOx	VOC	SO <sub>2</sub>	PM (total)	PM (2.5)
Units 1&2 heaters (TPY)	2.57	4.46	0.27	0.51	0.24	0.07
Units 3&4 boilers (TPY)	0.12	0.50	0.01	0.01	0.08	0.01
<b>Totals (TPY)</b>	<b>2.69</b>	<b>4.96</b>	<b>0.28</b>	<b>0.52</b>	<b>0.32</b>	<b>0.08</b>



Evaporator Emission Factors based on Emission Factor Study

Evaporator Model	PM <sub>10</sub> Emission Controlled Factor (lb/hr/unit)	PM <sub>2.5</sub> Controlled Emission Factor (lb/hr/unit)
Minetek Evaporators	0.51	0.42
Slimline Turbomist Evaporators	0.16	0.15

Evaporator Emissions for MAQP #0513-10

Evaporator Type	Number of Units	Flowrate (10 <sup>3</sup> gal/hr)	Hours of Operation per Year	PM <sub>10</sub> Emissions (tpy)	PM <sub>2.5</sub> Emissions (tpy)
Minetek Evaporators	8	168	2,000	4.07	3.39
Slimline Turbomist Evaporators	31	149	2,000	4.94	4.57
<b>TOTAL</b>	<b>39</b>	<b>317</b>	<b>2,000</b>	<b>9.01</b>	<b>7.96</b>

Emission Source	Tons per Year					
	Hg	PM <sub>10</sub>	NO <sub>x</sub>	CO	VOC	SO <sub>2</sub>
Unit 1 boiler	0.013	89.1	5,994.0	428.1	59.9	17,982.1
Unit 2 boiler	0.013	89.1	5,994.0	428.1	59.9	17,982.1
Unit 3 boiler	0.03	224.0	5,970.5	999.1	139.9	3,333.2
Unit 4 boiler	0.03	224.0	5,970.5	999.1	139.9	3,333.2
Unit 1&2 Sorbent Handling System	--	0.00003	--	--	--	--
Unit 3&4 Sorbent Handling System	--	0.00005	--	--	--	--
<b>Total Emissions</b>	<b>0.086</b>	<b>626.2</b>	<b>23,929.0</b>	<b>2,854.4</b>	<b>399.6</b>	<b>42,630.6</b>

Note: The inventory is based on information provided in the mercury control application for #0513-07, and is specific to impacts from the operation of mercury control equipment.

Boiler Units 1 and 2 (emission per boiler)

Maximum nominal operating capacity: 195.5 tons coal per hour

Maximum operation: 8,760 hours per year

Heat content of coal (design value): 8,750 Btu/lb

*Mercury Emissions*

Emission Factor: 0.9 lb/TBtu (Montana limit)

Calculations: (195.5 tons coal/hr) \* (8,760 hr/yr) \* (2000 lb coal / ton coal) \* (8,750 Btu / lb coal) \* (TBtu / 10<sup>12</sup> Btu) \* (0.9 lb Hg/TBtu) \* (ton/2000 lb) = 0.013 tons Hg/yr

*PM<sub>10</sub> Emissions*

Percent ash in coal (accounting for added sorbent): 9.05%

Emission Factor: 2.3 lb PM<sub>10</sub> per ton coal, per % ash (AP-42)

Control Efficiency: 99.5% (wet scrubber)

Calculations: (195.5 tons coal/hr) \* (8,760 hr/yr) \* 9.05 % ash in coal \* (2.3 lb PM<sub>10</sub>/ton coal/%ash) \* (1 - 99.5/100) \* (ton/2000 lb) = 89.1 tons PM<sub>10</sub>/yr

*NO<sub>x</sub> Emissions (No change with mercury control, but change because of new standard)*

Emission Factor: 0.40 lb NO<sub>x</sub> / MMBtu (Acid Rain Standard, Phase II)

Calculations: (195.5 tons coal/hr) \* (8,760 hr/yr) \* (2000 lb coal / ton coal) \* (8,750 Btu/lb coal) \* (MMBtu/ 10<sup>6</sup> Btu) \* (0.40 lb NO<sub>x</sub>/MMBtu) \* (ton/2000 lb) = 5,994.0 tons NO<sub>x</sub>/yr

*CO Emissions (No change with mercury control)*

Emission Factor: 0.5 lb per ton coal (FIRE)

Calculations:  $(195.5 \text{ tons coal/hr}) * (8,760 \text{ hr/yr}) * (0.5 \text{ lb CO/ton coal}) * (\text{ton}/2000 \text{ lb}) = 428.1 \text{ tons CO/yr}$

*VOC Emissions (No change with mercury control)*

Emission Factor: 0.07 lb per ton coal (AP-42)

Calculations:  $(195.5 \text{ tons coal/hr}) * (8,760 \text{ hr/yr}) * (0.07 \text{ lb VOC/ton coal}) * (\text{ton}/2000 \text{ lb}) = 59.9 \text{ tons VOC/yr}$

*SO<sub>2</sub> Emissions (No change with mercury control)*

Emission Factor: 1.2 lb SO<sub>2</sub>/MMBtu (NSPS)

Calculations:  $(195.5 \text{ tons coal/hr}) * (8,760 \text{ hr/yr}) * (2000 \text{ lb coal/ton coal}) * (8,750 \text{ Btu/lb coal}) * (\text{MMBtu}/10^6 \text{ Btu}) * (1.2 \text{ lb SO}_2/\text{MMBtu}) * (\text{ton}/2000 \text{ lb}) = 17,982.1 \text{ tons SO}_2/\text{yr}$

Boiler Units 3 and 4 (emission per boiler)

Maximum nominal operating capacity: 456.2 tons coal per hour

Maximum operation: 8,760 hours per year

Heat content of coal (design value): 8,300 Btu/lb

*Mercury Emissions*

Emission Factor: 0.9 lb/TBtu (Montana limit)

Calculations:  $(456.2 \text{ tons coal/hr}) * (8,760 \text{ hr/yr}) * (2000 \text{ lb coal/ton coal}) * (8,300 \text{ Btu/lb coal}) * (\text{TBtu}/10^{12} \text{ Btu}) * (0.9 \text{ lb Hg/TBtu}) * (\text{ton}/2000 \text{ lb}) = 0.03 \text{ tons Hg/yr}$

*PM<sub>10</sub> Emissions*

Percent ash in coal (accounting for added sorbent): 9.75%

Emission Factor: 2.3 lb PM<sub>10</sub> per ton coal, per % ash (AP42)

Control Efficiency: 99.5% (wet scrubber)

Calculations:  $(456.2 \text{ tons coal/hr}) * (8,760 \text{ hr/yr}) * 9.75 \% \text{ ash in coal} * (2.3 \text{ lb PM}_{10}/\text{ton coal}/\% \text{ ash}) * (1 - 99.5/100) * (\text{ton}/2000 \text{ lb}) = 224.0 \text{ tons PM}_{10}/\text{yr}$

*NO<sub>x</sub> Emissions (No change with mercury control, but change because of May 14, 2007 Consent Decree standard)*

Emission Factor: 0.18 lb NO<sub>x</sub>/MMBtu (May 14, 2007 Consent Decree standard)

Calculations:  $(456.2 \text{ tons coal/hr}) * (8,760 \text{ hr/yr}) * (2000 \text{ lb coal/ton coal}) * (8,300 \text{ Btu/lb coal}) * (\text{MMBtu}/10^6 \text{ Btu}) * (0.18 \text{ lb NO}_x/\text{MMBtu}) * (\text{ton}/2000 \text{ lb}) = 5,970.5 \text{ tons NO}_x/\text{yr}$

*CO Emissions (No change with mercury control)*

Emission Factor: 0.5 lb per ton coal (FIRE)

Calculations:  $(456.2 \text{ tons coal/hr}) * (8,760 \text{ hr/yr}) * (0.5 \text{ lb CO/ton coal}) * (\text{ton}/2000 \text{ lb}) = 999.1 \text{ tons CO/yr}$

*VOC Emissions (No change with mercury control)*

Emission Factor: 0.07 lb per ton coal (AP-42)

Calculations:  $(456.2 \text{ tons coal/hr}) * (8,760 \text{ hr/yr}) * (0.07 \text{ lb VOC/ton coal}) * (\text{ton}/2000 \text{ lb}) = 139.9 \text{ tons VOC/yr}$

*SO<sub>2</sub> Emissions (No change with mercury control)*

Emission Factor: 761 lb SO<sub>2</sub>/hr (PSD Permit)

Calculations:  $(8,760 \text{ hr/yr}) * (761 \text{ lb SO}_2/\text{hr}) * (\text{ton}/2000 \text{ lb}) = 3,333.2 \text{ tons SO}_2/\text{yr}$

### Unit 1&2 Sorbent Handling System

Maximum operation: 8,760 hours per year

Maximum silo pass-through: 200 lb sorbent per hour

Emission Factor: 0.06 lb PM<sub>10</sub> / ton sorbent (1998 and 2000 Syncoal and petroleum coke air quality permit amendments for Colstrip Units 1&2)

Control Efficiency: 99.9% (bin filter)

Note: There is one storage silo for mercury sorbent. The emissions from the silo will be generated when the silo is filled and are comprised of filtered emissions through the silo bin vent. The silo is pneumatically loaded through sealed connections from material trucks. The maximum consumption of mercury sorbent is estimated to be 200 lb/hr. A 99.9% control efficiency is assumed. This is the rated control efficiency of the bin vent filter. Because of the sealed nature of the silo, fill and conveyance lines, no other emissions are expected. The only regulated pollutant emissions anticipated from this source is PM<sub>10</sub>.

Calculations:  $(200 \text{ lb sorbent / hr}) * (8,760 \text{ hr/yr}) * (t \text{ sorbent}/2000 \text{ lb sorbent}) * (0.06 \text{ lb PM}_{10}/\text{ton sorbent}) *$

$(t/2000 \text{ lb}) * (1 - 99.9/100) = 0.00003 \text{ tons PM}_{10}/\text{yr}$

### Unit 3&4 Sorbent Handling System

Maximum operation: 8,760 hours per year

Maximum silo pass-through: 400 lb sorbent per hour

Emission Factor: 0.06 lb PM<sub>10</sub>/ton sorbent (1998 and 2000 Syncoal and petroleum coke air quality permit amendments for Colstrip Units 1&2)

Control Efficiency: 99.9% (bin filter)

Note: There are two storage silos for mercury sorbent. The emissions from the silo will be generated when the silos are filled and are comprised of filtered emissions through the silo bin vents. The silos are pneumatically loaded through sealed connections from material trucks. The maximum consumption of mercury sorbent is estimated to be 400 lb/hr. A 99.9% control efficiency is assumed. This is the rated control efficiency of the bin vent filter. Because of the sealed nature of the silo, fill and conveyance lines, no other emissions are expected. The only regulated pollutant emissions anticipated from this source is PM<sub>10</sub>.

Calculations:  $(400 \text{ lb sorbent/hr}) * (8,760 \text{ hr/yr}) * (t \text{ sorbent}/2000 \text{ lb sorbent}) * (0.06 \text{ lb PM}_{10}/\text{ton sorbent}) * (t/2000 \text{ lb}) * (1 - 99.9/100) = 0.00005 \text{ tons PM}_{10}/\text{yr}$

## V. Existing Air Quality

The facility is located in Section 34, Township 2 N, Range 41 E in Rosebud County, Montana. The air quality of this area is classified as unclassified/attainment for the National Ambient Air Quality Standards (NAAQS) for criteria pollutants.

## VI. Ambient Air Impact Analysis

The current permit action is considered an administrative action to remove permit conditions associated with a project that Talen has not initiated and will no longer pursue. Therefore, the Department believes the permitting action will not cause or contribute to a violation of any ambient air quality standard.

VII. Taking or Damaging Implication Analysis

As required by 2-10-105, MCA, the Department conducted the following private property taking and damaging assessment.

YES	NO	
X		1. Does the action pertain to land or water management or environmental regulation affecting private real property or water rights?
	X	2. Does the action result in either a permanent or indefinite physical occupation of private property?
	X	3. Does the action deny a fundamental attribute of ownership? (e.g., right to exclude others, disposal of property)
	X	4. Does the action deprive the owner of all economically viable uses of the property?
	X	5. Does the action require a property owner to dedicate a portion of property or to grant an easement? [If no, go to (6)].
		5a. Is there a reasonable, specific connection between the government requirement and legitimate state interests?
		5b. Is the government requirement roughly proportional to the impact of the proposed use of the property?
	X	6. Does the action have a severe impact on the value of the property? (consider economic impact, investment-backed expectations, character of government action)
	X	7. Does the action damage the property by causing some physical disturbance with respect to the property in excess of that sustained by the public generally?
	X	7a. Is the impact of government action direct, peculiar, and significant?
	X	7b. Has government action resulted in the property becoming practically inaccessible, waterlogged or flooded?
	X	7c. Has government action lowered property values by more than 30% and necessitated the physical taking of adjacent property or property across a public way from the property in question?
	X	Takings or damaging implications? (Taking or damaging implications exist if YES is checked in response to question 1 and also to any one or more of the following questions: 2, 3, 4, 6, 7a, 7b, 7c; or if NO is checked in response to questions 5a or 5b; the shaded areas)

Based on this analysis, the Department determined there are no taking or damaging implications associated with this permit action.

VIII. Environmental Assessment

The current permit action is considered an administrative action to remove permit conditions associated with a project that Talen has not initiated and will no longer pursue. The permitting action will not result in an increase of emissions from the facility and therefore, an Environmental Assessment is not required.

Analysis Prepared By: Ed Warner  
Date: September 4, 2020