

STATEMENT OF ENERGY PERFORMANCE

DLI-Bozeman Job Service
121 N Willson
Bozeman MT 59715

Date: 8/24/2021
Year Built: 1973
Parent: N/A

	Baseline:	2012	2015	2017	2018	2019	Current:
Energy Date:	12/31/2007	12/31/2012	12/31/2015	12/31/2017	12/31/2018	12/31/2019	12/31/2020
Energy Star Score:	63	75	76	82	87	86	90
Gross Floor Area:	8,974	8,974	8,974	8,974	8,974	8,974	8,974 Sq. Ft.
Heating Degree Days	7094	7500	7452	8315	8331	9230	7828
Cooling Degree Days	591	314	243	340	202	163	247
Reported Annual Energy Use:							
Site Energy Use:	483.3	384.7	368.4	359.2	337.8	365.7	318.6 MBTU
Site EUI:	53,856	42,864	41,051	40,028	37,639	40,746	35,501 BTU/ft2
Electricity:	70,184	59,433	58,845	50,489	38,974	38,612	33,090 kWh
Max Electric Demand:	39.0	27.0	28.0	25.2	18.0	17.6	14.8 kW
Natural Gas:	2,438	1,819	1,676	1,869	2,048	2,339	2,057 Therms
Reported Annual Energy Cost:							
Electricity Cost:	\$7,171	\$6,668	\$7,176	\$6,308	\$4,749	\$4,954	\$4,152
Electric Demand Cost:	\$2,663	\$2,384	\$2,341	\$2,313	\$1,720	\$1,847	\$1,447
Natural Gas Cost:	\$2,713	\$1,673	\$1,481	\$1,532	\$1,588	\$1,729	\$1,571
Total Energy Cost:	\$9,883	\$8,341	\$8,657	\$7,840	\$6,337	\$6,683	\$5,723
Energy Cost/ft2	\$1.101	\$0.929	\$0.965	\$0.874	\$0.706	\$0.745	\$0.638
Weather Normalized Energy Use:							
Site Energy Use:	495.2	387.2	370.5	341.3	318.4	327.0	311.9 MBTU
Site EUI:	55,186	43,149	41,281	38,036	35,486	36,436	34,760 BTU/ft2
Electricity:	69,281	59,605	58,845	50,489	38,974	38,612	33,090 kWh
Natural Gas:	2,589	1,839	1,697	1,691	1,855	1,952	1,990 Therms
National Median Energy Use:							
Site Energy Use:	581.4	561.2	547.1	603.3	645.1	682.7	664.9 MBTU
Site EUI:	64,784	62,539	60,963	67,223	71,891	76,072	74,097 BTU/ft2
% Difference from National Median:							
Site EUI:	-16.87%	-31.46%	-32.66%	-40.45%	-47.64%	-46.44%	-52.09%
Annual Greenhouse Gas Emissions (Metric Tons CO2 equivalent):							
Direct Emissions:	13.0	9.7	8.9	9.9	10.9	12.4	10.9
Indirect Emissions:	20.5	20.8	17.2	14.7	11.4	11.3	9.7
Total Emissions:	33.4	27.0	26.1	24.7	22.3	23.7	20.6
National Median Annual Greenhouse Gas Emissions (Metric Tons CO2 equivalent):							
Total Emissions:	40.2	39.4	38.7	41.4	42.5	44.2	43.0
Adjusted Energy Based on Current Year:							
Site Energy Use:	481.6	385.9	373.2	350.0	334.4	354.0	318.6 MBTU
Site EUI:	53,665	43,001	41,588	39,005	37,259	39,444	35,501 BTU/ft2
% Difference Adjusted Site Energy Use							
2012 to Baseline	-19.87%						
2015 to Baseline	-22.50%						
2017 to Baseline	-27.32%						
2018 to Baseline	-30.57%						
2019 to Baseline	-26.50%						
Current to Baseline	-33.85%						
2019 to 2020	-10.00%						

Note: N/A has meanings as follows:
Energy Star Score: Not available for this type of property
Adjusted Energy Use: Not available for this property
Most other data: Not available due to insufficient or missing data