

STATEMENT OF ENERGY PERFORMANCE

DLI-Great Falls Job Service
 1018 7th St S
 Great Falls MT 59405

Date: 8/24/2021
 Year Built: 1971
 Parent: N/A

	Baseline:	2012	2015	2017	2018	2019	Current:
Energy Date:	12/31/2007	12/31/2012	12/31/2015	12/31/2017	12/31/2018	12/31/2019	1/31/2013
Energy Star Score:	20	23	N/A	N/A	N/A	N/A	25
Gross Floor Area:	18,155	18,155	18,155	18,155	18,155	18,155	18,155 Sq. Ft.
Heating Degree Days	7085	6724	6913	7640	7962	8695	6718
Cooling Degree Days	637	547	465	540	446	281	546
Reported Annual Energy Use:							
Site Energy Use:	1839.6	1878.2	N/A	N/A	N/A	N/A	1827.9 MBTU
Site EUI:	101,328	103,455	N/A	N/A	N/A	N/A	100,685 BTU/ft2
Electricity:	233,015	193,427	183,931	201,464	198,866	186,043	190,226 kWh
Max Electric Demand:	101.0	97.0	85.6	63.2	62.4	75.2	97.0 kW
Natural Gas:	10,446	12,182	N/A	N/A	N/A	N/A	11,789 Therms
Reported Annual Energy Cost:							
Electricity Cost:	\$22,507	\$20,843	\$22,168	\$22,202	\$21,132	\$21,263	\$20,691
Electric Demand Cost:	\$7,757	\$7,143	\$7,324	\$6,571	\$6,038	\$6,636	\$7,170
Natural Gas Cost:	\$10,826	\$8,194	N/A	N/A	N/A	N/A	\$7,776
Total Energy Cost:	\$33,333	\$29,038	N/A	N/A	N/A	N/A	\$28,467
Energy Cost/ft2	\$1.836	\$1.599	N/A	N/A	N/A	N/A	\$1.568
Weather Normalized Energy Use:							
Site Energy Use:	1892.2	2023.6	N/A	N/A	N/A	N/A	1965.3 MBTU
Site EUI:	104,224	111,460	N/A	N/A	N/A	N/A	108,253 BTU/ft2
Electricity:	223,025	189,878	181,780	196,080	198,161	184,710	186,362 kWh
Natural Gas:	11,312	13,757	N/A	N/A	N/A	N/A	13,295 Therms
National Median Energy Use:							
Site Energy Use:	1238.4	1320.9	959.5	959.5	959.5	959.5	1315.5 MBTU
Site EUI:	68,211	72,758	52,852	52,852	52,852	52,852	72,458 BTU/ft2
% Difference from National Median:							
Site EUI:	48.55%	42.19%	N/A	N/A	N/A	N/A	38.96%
Annual Greenhouse Gas Emissions (Metric Tons CO2 equivalent):							
Direct Emissions:	55.5	64.7	N/A	N/A	N/A	N/A	62.6
Indirect Emissions:	68.0	63.2	53.7	58.8	58.0	54.3	55.5
Total Emissions:	123.5	121.2	N/A	N/A	N/A	N/A	118.1
National Median Annual Greenhouse Gas Emissions (Metric Tons CO2 equivalent):							
Total Emissions:	83.1	85.2	73.9	73.9	73.9	73.9	85.0
Adjusted Energy Based on Current Year:							
Site Energy Use:	1808.2	1877.7	N/A	N/A	N/A	N/A	1827.9 MBTU
Site EUI:	99,597	103,428	N/A	N/A	N/A	N/A	100,685 BTU/ft2
% Difference Adjusted Site Energy Use							
2012 to Baseline	3.85%						
2015 to Baseline	N/A						
2017 to Baseline	N/A						
2018 to Baseline	N/A						
2019 to Baseline	N/A						
Current to Baseline	N/A						
2019 to 2020	N/A						

Note: N/A has meanings as follows:
 Energy Star Score: Not available for this type of property
 Adjusted Energy Use: Not available for this property
 Most other data: Not available due to insufficient or missing data