

STATEMENT OF ENERGY PERFORMANCE

DPHHS Headquarters
111 North Sanders
Helena, MT 59620

Date: 11/21/2023
Year Built: 1975
Parent: N/A

	Baseline:	2014	2017	2019	2020	2021	Current:
Energy Date:	12/31/2007	12/31/2014	12/31/2017	12/31/2019	12/31/2020	12/31/2021	12/31/2022
Energy Star Score:	21	72	64	58	72	73	66
Gross Floor Area:	48,112	48,112	48,112	48,112	48,112	48,112	48,112 Sq. Ft.
Heating Degree Days	6778	7428	7862	8591	6940	6908	7804
Cooling Degree Days	730	469	731	398	506	792	720

Reported Annual Energy Use:

Site Energy Use:	6671.5	3563.0	4058.8	4803.8	3622.8	3563.1	4322.7 MBTU
Site EUI:	138.7	74.1	84.4	99.8	75.3	74.1	89.8 kBTU/ft2
Electricity:	926,591	421,165	491,143	467,408	405,568	393,338	408,463 kWh
Max Electric Demand:	224.0	140.4	169.2	154.8	154.8	146.4	146.4 kW
Natural Gas:	35,100	21,260	23,830	32,090	22,390	22,210	29,290 Therms

Reported Annual Energy Cost:

Electricity Cost:	\$76,980	\$44,590	\$53,257	\$52,059	\$47,308	\$45,978	\$48,934
Electric Demand Cost:	\$18,790	\$12,955	\$15,136	\$15,465	\$16,118	\$631	N/A
Natural Gas Cost:	\$33,942	\$16,232	\$16,334	\$15,632	\$12,846	\$13,603	\$17,377
Total Energy Cost:	\$110,922	\$60,822	\$69,591	\$67,691	\$60,154	\$59,581	\$66,311
Energy Cost/ft2	\$2.31	\$1.26	\$1.45	\$1.41	\$1.25	\$1.24	\$1.38

Weather Normalized Energy Use:

Site Energy Use:	7018.6	3580.2	3901.9	4406.5	3800.7	3768.0	4291.5 MBTU
Site EUI:	145.9	74.4	81.1	91.6	79.0	78.3	89.2 kBTU/ft2
Electricity:	926,591	421,165	477,998	467,408	405,568	393,338	408,463 kWh
Natural Gas:	38,755	21,432	22,710	28,117	24,169	24,259	28,978 Therms

National Median Energy Use:

Site Energy Use:	4550.9	4895.9	4945.3	5391.6	4955.0	5027.9	5421.4 kBTU
Site EUI:	94.6	101.8	102.8	112.1	103.0	104.5	112.7 kBTU/ft2

% Difference from National Median:

Site EUI:	46.6%	-27.2%	-17.9%	-10.9%	-26.9%	-29.1%	-20.3%
-----------	-------	--------	--------	--------	--------	--------	--------

Annual Greenhouse Gas Emissions (Metric Tons CO2 equivalent):

Direct Emissions:	186.3	112.9	126.6	170.4	118.9	118.0	155.6
Indirect Emissions:	362.9	174.5	146.0	152.6	111.1	113.9	118.3
Total Emissions:	549.1	287.4	272.6	323.1	230.0	231.9	273.9

National Median Annual Greenhouse Gas Emissions (Metric Tons CO2 equivalent):

Total Emissions:	374.6	394.9	332.1	362.6	314.6	327.2	343.5
------------------	-------	-------	-------	-------	-------	-------	-------

Adjusted Energy Based on Current Year:

Site Energy Use:	6826.7	3627.3	4052.2	4780.7	3723.4	3628.5	4322.7 kBTU
Site EUI:	141.9	75.4	84.2	99.4	77.4	75.4	89.8 kBTU/ft2

% Difference Adjusted Site Energy Use

2014 to Baseline	-46.87%
2017 to Baseline	-40.64%
2019 to Baseline	-29.97%
2020 to Baseline	-45.46%
2021 to Baseline	-46.85%
Current to Baseline	-36.68%
2021 to 2022	19.13%

Note: N/A has meanings as follows:

Energy Star Score: Not available for this type of property

Adjusted Energy Use: Not available for this property

Most other data: Not available due to insufficient or missing data