

STATEMENT OF ENERGY PERFORMANCE

MDC Campus Church
Grizzly Drive
Boulder 59632

Date: 8/22/2022
Year Built: 2003
Parent: Montana Development Center

| | Baseline: | 2013 | 2016 | 2018 | 2019 | 2020 | Current: |
|---|------------------|--|-------------|-------------|-------------|-------------|-----------------|
| | 12/31/2007 | 12/31/2013 | 12/31/2016 | 12/31/2018 | 12/31/2019 | 12/31/2020 | 7/31/2021 |
| Energy Date: | 12/31/2007 | 12/31/2013 | 12/31/2016 | 12/31/2018 | 12/31/2019 | 12/31/2020 | 7/31/2021 |
| Energy Star Score: | N/A | N/A | N/A | N/A | N/A | N/A | N/A |
| Gross Floor Area: | 3,134 | 3,134 | 3,134 | 3,134 | 3,134 | 3,134 | 3,134 Sq. Ft. |
| Heating Degree Days | 6778 | 7351 | 6842 | 7820 | 8591 | 6940 | 7096 |
| Cooling Degree Days | 730 | 579 | 474 | 432 | 398 | 506 | 848 |
| Reported Annual Energy Use: | | | | | | | |
| Site Energy Use: | 20.6 | 27.7 | 28.6 | 18.1 | 17.9 | 14.4 | 17.4 MBTU |
| Site EUI: | 6.6 | 8.8 | 9.1 | 5.8 | 5.7 | 4.6 | 5.5 kBTU/ft2 |
| Electricity: | 6,041 | 8,115 | 8,393 | 5,317 | 5,238 | 4,206 | 5,086 kWh |
| Max Electric Demand: | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 kW |
| Natural Gas: | N/A | N/A | N/A | N/A | N/A | N/A | N/A Therms |
| Reported Annual Energy Cost: | | | | | | | |
| Electricity Cost: | \$669 | \$980 | \$1,091 | \$706 | \$739 | \$600 | \$712 |
| Electric Demand Cost: | \$0 | \$0 | \$0 | \$0 | \$0 | \$0 | N/A |
| Natural Gas Cost: | N/A | N/A | N/A | N/A | N/A | N/A | N/A |
| Total Energy Cost: | \$669 | \$980 | \$1,091 | \$706 | \$739 | \$600 | \$712 |
| Energy Cost/ft ² | \$0.21 | \$0.31 | \$0.35 | \$0.23 | \$0.24 | \$0.19 | \$0.23 |
| Weather Normalized Energy Use: | | | | | | | |
| Site Energy Use: | 21.7 | 28.1 | 29.3 | 17.8 | 17.0 | 14.9 | 18.0 MBTU |
| Site EUI: | 6.9 | 9.0 | 9.4 | 5.7 | 5.4 | 4.8 | 5.7 kBTU/ft2 |
| Electricity: | 6,358 | 8,228 | 8,593 | 5,229 | 4,976 | 4,370 | 5,272 kWh |
| Natural Gas: | N/A | N/A | N/A | N/A | N/A | N/A | N/A Therms |
| National Median Energy Use: | | | | | | | |
| Site Energy Use: | 65.4 | 65.4 | 65.4 | 65.4 | 65.4 | 65.4 | 65.4 MBTU |
| Site EUI: | 20.9 | 20.9 | 20.9 | 20.9 | 20.9 | 20.9 | 20.9 kBTU/ft2 |
| % Difference from National Median: | | | | | | | |
| Site EUI: | -68.5% | -57.7% | -56.2% | -72.3% | -72.7% | -78.1% | -73.5% |
| Annual Greenhouse Gas Emissions (Metric Tons CO₂ equivalent): | | | | | | | |
| Direct Emissions: | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| Indirect Emissions: | 2.0 | 2.6 | 2.7 | 1.7 | 1.7 | 1.4 | 1.7 |
| Total Emissions: | 2.0 | 2.6 | 2.7 | 1.7 | 1.7 | 1.4 | 1.7 |
| National Median Annual Greenhouse Gas Emissions (Metric Tons CO₂ equivalent): | | | | | | | |
| Total Emissions: | 6.3 | 6.3 | 6.3 | 6.3 | 6.3 | 6.3 | 6.3 |
| Adjusted Energy Based on Current Year: | | | | | | | |
| Site Energy Use: | N/A | N/A | N/A | N/A | N/A | N/A | N/A MBTU |
| Site EUI: | N/A | N/A | N/A | N/A | N/A | N/A | N/A kBTU/ft2 |
| % Difference Adjusted Site Energy Use | | | | | | | |
| 2013 to Baseline | N/A | Note: N/A has meanings as follows: | | | | | |
| 2016 to Baseline | N/A | Energy Star Score: Not available for this type of property | | | | | |
| 2018 to Baseline | N/A | Adjusted Energy Use: Not available for this property | | | | | |
| 2019 to Baseline | N/A | Most other data: Not available due to insufficient or missing data | | | | | |
| 2020 to Baseline | N/A | | | | | | |
| Current to Baseline | N/A | | | | | | |
| 2020 to 2021 | N/A | | | | | | |