

STATEMENT OF ENERGY PERFORMANCE

FWP-First Peoples Visitor Center
10 Miles South of Great Falls I-15
Ulm 59485

Date: 8/22/2022
Year Built: 1999
Parent: N/A

	Baseline:	2013	2016	2018	2019	2020	Current:
	12/31/2007	12/31/2013	12/31/2016	12/31/2018	12/31/2019	12/31/2020	12/31/2021
Energy Date:	12/31/2007	12/31/2013	12/31/2016	12/31/2018	12/31/2019	12/31/2020	12/31/2021
Energy Star Score:	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Gross Floor Area:	6,673	6,673	6,673	6,673	6,673	6,673	6,673 Sq. Ft.
Heating Degree Days	7085	7320	6926	7962	8695	7317	7374
Cooling Degree Days	637	468	296	446	281	356	605
Reported Annual Energy Use:							
Site Energy Use:	133.9	109.3	97.2	84.9	85.6	69.2	90.2 MBTU
Site EUI:	20.1	16.4	14.6	12.7	12.8	10.4	13.5 kBTU/ft2
Electricity:	39,252	32,037	28,496	24,891	25,100	20,283	26,422 kWh
Max Electric Demand:	30.0	32.0	25.0	25.0	27.7	24.1	31.4 kW
Natural Gas:	N/A	N/A	N/A	N/A	N/A	N/A	N/A Therms
Reported Annual Energy Cost:							
Electricity Cost:	\$4,914	\$4,289	\$4,111	\$3,397	\$3,721	\$3,479	\$4,032
Electric Demand Cost:	\$2,343	\$1,809	\$1,698	\$1,434	\$1,668	\$1,786	N/A
Natural Gas Cost:	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Total Energy Cost:	\$4,914	\$4,289	\$4,111	\$3,397	\$3,721	\$3,479	\$4,032
Energy Cost/ft ²	\$0.74	\$0.64	\$0.62	\$0.51	\$0.56	\$0.52	\$0.60
Weather Normalized Energy Use:							
Site Energy Use:	127.8	103.1	95.7	84.9	85.6	69.2	79.3 MBTU
Site EUI:	19.2	15.5	14.3	12.7	12.8	10.4	11.9 kBTU/ft2
Electricity:	37,466	30,216	28,035	24,891	25,100	20,283	23,232 kWh
Natural Gas:	N/A	N/A	N/A	N/A	N/A	N/A	N/A Therms
National Median Energy Use:							
Site Energy Use:	266.9	266.9	266.9	266.9	266.9	266.9	266.9 MBTU
Site EUI:	40.0	40.0	40.0	40.0	40.0	40.0	40.0 kBTU/ft2
% Difference from National Median:							
Site EUI:	-49.8%	-59.1%	-63.6%	-68.2%	-67.9%	-74.1%	-66.2%
Annual Greenhouse Gas Emissions (Metric Tons CO₂ equivalent):							
Direct Emissions:	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Indirect Emissions:	12.8	10.5	9.3	8.1	8.2	6.6	8.6
Total Emissions:	12.8	10.5	9.3	8.1	8.2	6.6	8.6
National Median Annual Greenhouse Gas Emissions (Metric Tons CO₂ equivalent):							
Total Emissions:	25.5	25.5	25.5	25.5	25.5	25.5	25.5
Adjusted Energy Based on Current Year:							
Site Energy Use:	N/A	N/A	N/A	N/A	N/A	N/A	N/A MBTU
Site EUI:	N/A	N/A	N/A	N/A	N/A	N/A	N/A kBTU/ft2
% Difference Adjusted Site Energy Use							
2013 to Baseline	N/A	Note: N/A has meanings as follows:					
2016 to Baseline	N/A	Energy Star Score: Not available for this type of property					
2018 to Baseline	N/A	Adjusted Energy Use: Not available for this property					
2019 to Baseline	N/A	Most other data: Not available due to insufficient or missing data					
2020 to Baseline	N/A						
Current to Baseline	N/A						
2020 to 2021	N/A						