

STATEMENT OF ENERGY PERFORMANCE

MDT-Glendive East
425 State Street
Glendive MT 59330

Date: 8/24/2021
Year Built: 1980
Parent: N/A

	Baseline:	2012	2015	2017	2018	2019	Current:
Energy Date:	12/31/2007	12/31/2012	12/31/2015	12/31/2017	12/31/2018	12/31/2019	12/31/2020
Energy Star Score:	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Gross Floor Area:	13,216	13,216	13,216	13,216	13,216	13,216	13,216 Sq. Ft.
Heating Degree Days	7024	6591	6751	7320	8476	8583	7321
Cooling Degree Days	1063	1124	820	1022	669	565	736
Reported Annual Energy Use:							
Site Energy Use:	491.4	369.2	503.7	578.5	619.7	760.2	617.8 MBTU
Site EUI:	37,183	27,936	38,109	43,776	46,893	57,521	46,743 BTU/ft2
Electricity:	41,773	46,245	61,879	52,612	53,585	61,782	61,986 kWh
Max Electric Demand:	0.0	14.2	15.6	11.6	13.6	12.0	11.4 kW
Natural Gas:	3,489	2,114	2,925	3,990	4,369	5,494	4,063 Therms
Reported Annual Energy Cost:							
Electricity Cost:	\$2,597	\$3,569	\$4,612	\$4,266	\$4,435	\$5,717	\$5,685
Electric Demand Cost:	N/A	N/A	\$141	\$42	\$71	\$76	\$32
Natural Gas Cost:	\$2,948	\$1,519	\$2,267	\$2,751	\$2,916	\$3,527	\$2,615
Total Energy Cost:	\$5,545	\$5,087	\$6,879	\$7,017	\$7,351	\$9,245	\$8,300
Energy Cost/ft2	\$0.420	\$0.385	\$0.520	\$0.531	\$0.556	\$0.699	\$0.628
Weather Normalized Energy Use:							
Site Energy Use:	529.3	424.1	565.0	598.2	525.3	658.1	647.5 MBTU
Site EUI:	40,048	32,093	42,751	45,262	39,749	49,794	48,996 BTU/ft2
Electricity:	42,537	47,426	63,519	53,642	49,688	58,760	62,683 kWh
Natural Gas:	3,841	2,623	3,483	4,152	3,558	4,576	4,337 Therms
National Median Energy Use:							
Site Energy Use:	757.5	656.2	661.5	740.6	753.3	768.5	715.4 MBTU
Site EUI:	57,315	49,654	50,052	56,041	56,997	58,148	54,133 BTU/ft2
% Difference from National Median:							
Site EUI:	-35.13%	-43.74%	-23.86%	-21.89%	-17.73%	-1.08%	-13.65%
Annual Greenhouse Gas Emissions (Metric Tons CO2 equivalent):							
Direct Emissions:	18.5	11.2	15.5	21.2	23.2	29.2	21.6
Indirect Emissions:	12.2	11.3	18.1	15.4	15.6	18.0	18.1
Total Emissions:	30.7	24.7	33.6	36.5	38.8	47.2	39.7
National Median Annual Greenhouse Gas Emissions (Metric Tons CO2 equivalent):							
Total Emissions:	47.4	43.9	44.1	46.8	47.2	47.7	45.9
Adjusted Energy Based on Current Year:							
Site Energy Use:	N/A	N/A	N/A	N/A	N/A	N/A	N/A MBTU
Site EUI:	N/A	N/A	N/A	N/A	N/A	N/A	N/A BTU/ft2
% Difference Adjusted Site Energy Use							
2012 to Baseline	N/A	Note: N/A has meanings as follows:					
2015 to Baseline	N/A	Energy Star Score: Not available for this type of property					
2017 to Baseline	N/A	Adjusted Energy Use: Not available for this property					
2018 to Baseline	N/A	Most other data: Not available due to insufficient or missing data					
2019 to Baseline	N/A						
Current to Baseline	N/A						
2019 to 2020	N/A						