

## STATEMENT OF ENERGY PERFORMANCE

MDT-Lodge Grass Office and Shop  
 1/2 Mile East of Lodge Grass Interchange  
 Lodge Grass MT 59050

Date: 8/24/2021  
 Year Built: 1981  
 Parent: N/A

	<b>Baseline:</b>	<b>2012</b>	<b>2015</b>	<b>2017</b>	<b>2018</b>	<b>2019</b>	<b>Current:</b>
Energy Date:	12/31/2007	12/31/2012	12/31/2015	12/31/2017	12/31/2018	12/31/2019	11/30/2012
Energy Star Score:	67	N/A	N/A	N/A	N/A	N/A	71
Gross Floor Area:	3,200	3,200	3,200	3,200	3,200	3,200	3,200 Sq. Ft.
Heating Degree Days	6634	6093	6079	6901	7387	7662	5988
Cooling Degree Days	841	945	723	844	517	748	945
<b>Reported Annual Energy Use:</b>							
Site Energy Use:	66.7	N/A	N/A	N/A	N/A	N/A	60.5 MBTU
Site EUI:	20,834	N/A	N/A	N/A	N/A	N/A	18,917 BTU/ft2
Electricity:	19,539	N/A	N/A	N/A	N/A	N/A	17,741 kWh
Max Electric Demand:	N/A	N/A	N/A	N/A	N/A	N/A	N/A kW
Natural Gas:	N/A	N/A	N/A	N/A	N/A	N/A	N/A Therms
<b>Reported Annual Energy Cost:</b>							
Electricity Cost:	\$2,010	N/A	N/A	N/A	N/A	N/A	\$1,714
Electric Demand Cost:	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Natural Gas Cost:	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Total Energy Cost:	\$2,010	N/A	N/A	N/A	N/A	N/A	\$1,714
Energy Cost/ft2	\$0.628	N/A	N/A	N/A	N/A	N/A	\$0.536
<b>Weather Normalized Energy Use:</b>							
Site Energy Use:	67.1	N/A	N/A	N/A	N/A	N/A	65.2 MBTU
Site EUI:	20,972	N/A	N/A	N/A	N/A	N/A	20,364 BTU/ft2
Electricity:	19,669	N/A	N/A	N/A	N/A	N/A	19,099 kWh
Natural Gas:	N/A	N/A	N/A	N/A	N/A	N/A	N/A Therms
<b>National Median Energy Use:</b>							
Site Energy Use:	84.9	169.1	169.1	169.1	169.1	169.1	81.9 MBTU
Site EUI:	26,535	52,852	52,852	52,852	52,852	52,852	25,593 BTU/ft2
<b>% Difference from National Median:</b>							
Site EUI:	-21.49%	N/A	N/A	N/A	N/A	N/A	-26.09%
<b>Annual Greenhouse Gas Emissions (Metric Tons CO2 equivalent):</b>							
Direct Emissions:	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Indirect Emissions:	5.7	5.7	N/A	N/A	N/A	N/A	5.2
Total Emissions:	5.7	N/A	N/A	N/A	N/A	N/A	5.2
<b>National Median Annual Greenhouse Gas Emissions (Metric Tons CO2 equivalent):</b>							
Total Emissions:	7.3	13.0	13.0	13.0	13.0	13.0	7.0
<b>Adjusted Energy Based on Current Year:</b>							
Site Energy Use:	64.3	N/A	N/A	N/A	N/A	N/A	60.5 MBTU
Site EUI:	20,095	N/A	N/A	N/A	N/A	N/A	18,917 BTU/ft2
<b>% Difference Adjusted Site Energy Use</b>							
2012 to Baseline	N/A	<b>Note:</b> N/A has meanings as follows:					
2015 to Baseline	N/A	Energy Star Score: Not available for this type of property					
2017 to Baseline	N/A	Adjusted Energy Use: Not available for this property					
2018 to Baseline	N/A	Most other data: Not available due to insufficient or missing data					
2019 to Baseline	N/A						
Current to Baseline	N/A						
2019 to 2020	N/A						