

STATEMENT OF ENERGY PERFORMANCE

MLEA Aspen Cottage
2260 Sierra Road East
Helena MT 59602

Date: 8/24/2021
Year Built: 1926
Parent: MT Law Enforcement Academy

	Baseline:	2012	2015	2017	2018	2019	Current:
Energy Date:	12/31/2007	12/31/2012	12/31/2015	12/31/2017	12/31/2018	12/31/2019	12/31/2020
Energy Star Score:	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Gross Floor Area:	7,979	7,979	7,979	7,979	7,979	7,979	7,979 Sq. Ft.
Heating Degree Days	6778	7046	6715	7862	7820	8591	6940
Cooling Degree Days	730	517	551	731	432	398	506
Reported Annual Energy Use:							
Site Energy Use:	694.7	712.5	729.0	813.4	783.6	245.0	207.3 MBTU
Site EUI:	87,065	89,291	91,366	101,948	98,206	30,703	25,986 BTU/ft2
Electricity:	N/A	N/A	N/A	N/A	N/A	N/A	N/A kWh
Max Electric Demand:	N/A	N/A	N/A	N/A	N/A	N/A	N/A kW
Natural Gas:	6,947	7,125	7,290	8,134	7,836	2,450	2,073 Therms
Reported Annual Energy Cost:							
Electricity Cost:	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Electric Demand Cost:	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Natural Gas Cost:	\$7,393	\$5,874	\$5,628	\$6,021	\$5,530	\$1,938	\$1,728
Total Energy Cost:	\$7,393	\$5,874	\$5,628	\$6,021	\$5,530	\$1,938	\$1,728
Energy Cost/ft2	\$0.927	\$0.736	\$0.705	\$0.755	\$0.693	\$0.243	\$0.217
Weather Normalized Energy Use:							
Site Energy Use:	757.8	760.3	801.7	799.6	758.4	245.0	221.9 MBTU
Site EUI:	94,968	95,289	100,472	100,211	95,054	30,703	27,805 BTU/ft2
Electricity:	N/A	N/A	N/A	N/A	N/A	N/A	N/A kWh
Natural Gas:	7,578	7,603	8,017	7,996	7,584	2,450	2,219 Therms
National Median Energy Use:							
Site Energy Use:	1620.1	1620.1	1620.1	1620.1	1620.1	1620.1	1620.1 MBTU
Site EUI:	203,048	203,048	203,048	203,048	203,048	203,048	203,048 BTU/ft2
% Difference from National Median:							
Site EUI:	-57.12%	-56.02%	-55.00%	-49.79%	-51.63%	-84.88%	-87.20%
Annual Greenhouse Gas Emissions (Metric Tons CO2 equivalent):							
Direct Emissions:	36.9	37.8	38.7	43.2	41.6	13.0	11.0
Indirect Emissions:	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Total Emissions:	36.9	37.8	38.7	43.2	41.6	13.0	11.0
National Median Annual Greenhouse Gas Emissions (Metric Tons CO2 equivalent):							
Total Emissions:	86.1	86.1	86.1	86.1	86.1	86.1	86.1
Adjusted Energy Based on Current Year:							
Site Energy Use:	N/A	N/A	N/A	N/A	N/A	N/A	N/A MBTU
Site EUI:	N/A	N/A	N/A	N/A	N/A	N/A	N/A BTU/ft2
% Difference Adjusted Site Energy Use							
2012 to Baseline	N/A	Note: N/A has meanings as follows:					
2015 to Baseline	N/A	Energy Star Score: Not available for this type of property					
2017 to Baseline	N/A	Adjusted Energy Use: Not available for this property					
2018 to Baseline	N/A	Most other data: Not available due to insufficient or missing data					
2019 to Baseline	N/A						
Current to Baseline	N/A						
2019 to 2020	N/A						