Facility Summary in Beaverhead County in the City of Dell

Location: DELL AIRPORT CANYON RANCH
Dell Airport
Dell, MT 59724 Beaverhead

System Facility ID:01-09843

Facility Code: 17682
Last Inspected On: 12/21/2023
Operating Permit Renewal Date: 12/26/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Montana Dept of Transportation	**(406) 444-7632**	**jradonich@mt.gov**
Operator Contact:	Joe Radonich	**(406) 444-9204**	**jradonich@mt.gov**

Owner/Operator: Montana Dept of Transportation (406) 444-7632 jradonich@mt.gov

Joe Radonich, UST Class A Operator jradonich@mt.gov

Joe Radonich, UST Class B Global Operator jradonich@mt.gov

Tank Number	01	**Tank Age**	36	**Tank Installed Date**	06/13/1989	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	No Piping	**Overfill Types**	High Level Alarm
Tag Number	516	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	None	**AST**	No
Status	**Temporarily Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**		**CP Met Types**	Galvanic
Product	Jet Fuel (Jet-A, Jet-A1, JP5)	**PLLD Test Date**		**Tank/Piping CP Test Date**	12/21/2023	**Primary Tank Leak Detection**	Manual Interstitial Monitoring	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					

Facility Summary in Beaverhead County in the City of Dell

Location: DELL MERC
24 Main St
Dell, MT 59724 Beaverhead

System Facility ID:01-01523

Facility Code: 17476
Last Inspected On: 07/14/2023
Operating Permit Renewal Date: 08/20/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Bear Paw Inc **(307) 871-5947** **cjshopper2017@outlook.com**

Operator Contact: Chad Mussard **(307) 871-5947**

Owner/Operator: Bear Paw Inc (307) 871-5947 cjshopper2017@outlook.com

Chad Mussard, UST Class A Operator

Chad Mussard, UST Class B Operator

Tank Number	04	**Tank Age**	20	**Tank Installed Date**	10/06/2005	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve;High Level Alarm
Tag Number	5045	**Spill Test Date**	09/09/2021	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	01/10/2024	**Sump Tightness Test Date**	09/12/2017	**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	01/10/2024	**Line Tightness Test Date**	12/28/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	01/10/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	05	**Tank Age**	20	**Tank Installed Date**	10/06/2005	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve;High Level Alarm
Tag Number	5046	**Spill Test Date**	09/09/2021	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	01/10/2024	**Sump Tightness Test Date**	09/12/2017	**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	5000	**ATG Test Date**	01/10/2024	**Line Tightness Test Date**	12/28/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	01/10/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Tank Number	06	**Tank Age**	20	**Tank Installed Date**	10/06/2005	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve;High Level Alarm
Tag Number	5047	**Spill Test Date**	12/01/2021	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	01/10/2024	**Sump Tightness Test Date**	09/12/2017	**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	01/10/2024	**Line Tightness Test Date**	12/28/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	01/10/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	07	**Tank Age**	20	**Tank Installed Date**	10/06/2005	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve;High Level Alarm
Tag Number	5048	**Spill Test Date**	09/09/2021	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	01/10/2024	**Sump Tightness Test Date**	09/12/2017	**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	01/10/2024	**Line Tightness Test Date**	12/28/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	01/10/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Beaverhead County in the City of Dillon

Location: COUNTY COURTHOUSE
2 S Pacific St
Dillon, MT 59725-4000 Beaverhead

System Facility ID:01-05668

Facility Code: 17574
Last Inspected On: 06/07/2023
Operating Permit Renewal Date: 05/04/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Beaverhead County Clerk	**(406) 683-5245**	**croffice@beaverheadcountymt.gov**
Operator Contact:	Shonna Graham;Beaverhead County	**(406) 596-1740**	**sgraham@beaverheadcountymt.gov**

Owner/Operator: Beaverhead County Clerk (406) 683-5245 croffice@beaverheadcountymt.gov

Shonna Graham, UST Class A Operator sgraham@beaverheadcountymt.gov

Shonna Graham, UST Class B Operator sgraham@beaverheadcountymt.gov

Tank Number	02	**Tank Age**	32	**Tank Installed Date**	02/01/1993	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Steel	**Overfill Types**	Flapper Valve
Tag Number	421	**Spill Test Date**	03/01/2022	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	None	**AST**	No
Status	**Temporarily Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	06/07/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	2000	**ATG Test Date**	03/01/2022	**Line Tightness Test Date**	03/01/2008	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**	Veeder Root/TLS-250				

Facility Summary in Beaverhead County in the City of Dillon

Location: DIETRICHS COLLEGE EXXON UST
636 S Atlantic St
Dillon, MT 59725-2725 Beaverhead

System Facility ID:01-05401

Facility Code: 17564
Last Inspected On: 12/20/2022
Operating Permit Renewal Date: 12/20/2025

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	TJ and Megan Dietrich	**(406) 683-0070**	**dietrichcollegeautorepair@gmail.com**
Operator Contact:	Timothy Dietrich	**(406) 683-0070**	**tdietrich55@gmail.com**

Owner/Operator:	TJ and Megan Dietrich	(406) 683-0070	dietrichcollegeautorepair@gmail.com
	Timothy Dietrich, UST Class A Operator		tdietrich55@gmail.com
	Timothy Dietrich, UST Class A Operator		tdietrich55@gmail.com
	Timothy Dietrich, UST Class B Global Operator		tdietrich55@gmail.com
	Timothy Dietrich, UST Class B Global Operator		tdietrich55@gmail.com

Tank Number	04	**Tank Age**	31	**Tank Installed Date**	07/01/1994	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	3226	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Temporarily Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	12/20/2022	**Primary Tank Leak Detection**	Inventory Reconciliation;Tank Tightness Testing	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	05	**Tank Age**	31	**Tank Installed Date**	07/01/1994	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	3227	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Temporarily Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	12/20/2022	**Primary Tank Leak Detection**	Inventory Reconciliation;Tank Tightness Testing	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No

		Overfill Test Date				**ATG Type**					

Facility Summary in Beaverhead County in the City of Dillon

Location: DILLON AIRPORT
2400 Airport Rd
Dillon, MT 59725-9500 Beaverhead

System Facility ID:56-13894

Facility Code: 30568
Last Inspected On: 01/24/2024
Operating Permit Renewal Date: 03/04/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Beaverhead County Clerk **(406) 683-5245** **croffice@beaverheadcountymt.gov**

Operator Contact: Shonna Graham;Beaverhead County **(406) 596-1740** **sgraham@beaverheadcountymt.gov**

Owner/Operator: Beaverhead County Clerk (406) 683-5245 croffice@beaverheadcountymt.gov

Shonna Graham, UST Class A Operator sgraham@beaverheadcountymt.gov

Shonna Graham, UST Class B Operator sgraham@beaverheadcountymt.gov

Tank Number	01	**Tank Age**	43	**Tank Installed Date**	04/01/1982	**Tank Material Construction**	Bare Steel	**Piping Material**	Steel	**Overfill Types**	Flapper Valve
Tag Number	3995	**Spill Test Date**	01/24/2024	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	01/24/2024	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Jet Fuel (Jet-A, Jet-A1, JP5)	**PLLD Test Date**		**Tank/Piping CP Test Date**	01/24/2024	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	01/24/2024	**Line Tightness Test Date**	01/24/2024	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	01/24/2024			**ATG Type**	Gilbarco/EMC Basic				
Tank Number	02	**Tank Age**	43	**Tank Installed Date**	04/01/1982	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Steel	**Overfill Types**	Flapper Valve
Tag Number	3996	**Spill Test Date**	01/24/2024	**Piping Installed Date**		**Tank Construction**	Lined Interior/Impressed Current	**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	01/24/2024	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Aviation Gas	**PLLD Test Date**		**Tank/Piping CP Test Date**	01/24/2024	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	01/24/2024	**Line Tightness Test Date**	01/24/2024	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	01/24/2024			**ATG Type**	Gilbarco/EMC Basic				

Facility Summary in Beaverhead County in the City of Dillon

Location: ROCKY MOUNTAIN SUPPLY INC DILLON
700 N Montana St
Dillon, MT 59725-3357 Beaverhead

System Facility ID:01-10034

Facility Code: 17685
Last Inspected On: 05/11/2023
Operating Permit Renewal Date: 09/06/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Rocky Mountain Supply Inc	**(406) 388-4009**	**billballiet@rmsi.coop**
Operator Contact:	Jason Rorabaugh	**(406) 388-6116**	**jasonrorabaugh@rmsi.coop**

Owner/Operator: Rocky Mountain Supply Inc (406) 388-4009 billballiet@rmsi.coop

Jason Rorabaugh, UST Class A Operator jasonrorabaugh@rmsi.coop
Tari Eaves, UST Class B Operator rockymtnsupply@hotmail.com
Tari Eaves, UST Class B Operator rockymtnsupply@hotmail.com

Tank Number	01	**Tank Age**	44	**Tank Installed Date**	01/12/1981	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	3900	**Spill Test Date**	05/10/2023	**Piping Installed Date**	03/01/2017	**Tank Construction**	Lined Interior/Impressed Current	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	05/10/2023	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Diesel	**PLLD Test Date**	10/13/2022	**Tank/Piping CP Test Date**	10/07/2021	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	10/13/2022	**Line Tightness Test Date**	06/07/2017	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date	10/13/2022			**ATG Type**	Veeder Root/TLS-450PLUS				
Tank Number	02	**Tank Age**	44	**Tank Installed Date**	01/12/1981	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	3901	**Spill Test Date**	05/07/2020	**Piping Installed Date**	03/01/2017	**Tank Construction**	Lined Interior/Impressed Current	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	05/06/2020	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Diesel	**PLLD Test Date**	10/09/2019	**Tank/Piping CP Test Date**	10/03/2018	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**		**Line Tightness Test Date**	06/08/2017	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No

		Overfill Test Date	05/07/2020			**ATG Type**	Veeder Root/TLS-450PLUS				
Tank Number	03	**Tank Age**	44	**Tank Installed Date**	01/12/1981	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	3902	**Spill Test Date**	05/07/2020	**Piping Installed Date**	03/01/2017	**Tank Construction**	Lined Interior/Impressed Current	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	05/06/2020	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Diesel	**PLLD Test Date**	10/09/2019	**Tank/Piping CP Test Date**	10/03/2018	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**		**Line Tightness Test Date**	06/08/2017	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date	05/07/2020			**ATG Type**	Veeder Root/TLS-450PLUS				
Tank Number	04	**Tank Age**	44	**Tank Installed Date**	01/12/1981	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	3903	**Spill Test Date**	05/07/2020	**Piping Installed Date**	03/01/2017	**Tank Construction**	Lined Interior/Impressed Current	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	05/06/2020	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Diesel	**PLLD Test Date**	10/09/2019	**Tank/Piping CP Test Date**	10/03/2018	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**		**Line Tightness Test Date**	06/07/2017	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date	05/07/2020			**ATG Type**	Veeder Root/TLS-450PLUS				
Tank Number	05	**Tank Age**	44	**Tank Installed Date**	01/12/1981	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	3904	**Spill Test Date**	05/07/2020	**Piping Installed Date**	03/01/2017	**Tank Construction**	Lined Interior/Impressed Current	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	05/06/2020	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Diesel	**PLLD Test Date**	10/09/2019	**Tank/Piping CP Test Date**	10/03/2018	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**		**Line Tightness Test Date**	06/07/2017	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date	05/07/2020			**ATG Type**	Veeder Root/TLS-450PLUS				
Tank Number	09	**Tank Age**	27	**Tank Installed Date**	12/01/1998	**Tank Material Construction**	Steel Clad	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve;High Level Alarm

Tag Number	3905	**Spill Test Date**	05/07/2020	**Piping Installed Date**	04/26/2023	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	05/06/2020	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	10/09/2019	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**		**Line Tightness Test Date**	04/18/2017	**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date	05/07/2020			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS;Veeder Root/TLS-450PLUS				
Tank Number	10	**Tank Age**	27	**Tank Installed Date**	12/01/1998	**Tank Material Construction**	Steel Clad	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	3906	**Spill Test Date**	05/07/2020	**Piping Installed Date**	03/01/2017	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	05/06/2020	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	10/09/2019	**Tank/Piping CP Test Date**	08/22/2017	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	4100	**ATG Test Date**		**Line Tightness Test Date**	04/18/2017	**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date	05/07/2020			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS;Veeder Root/TLS-450PLUS				
Tank Number	11	**Tank Age**	27	**Tank Installed Date**	12/01/1998	**Tank Material Construction**	Steel Clad	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	3907	**Spill Test Date**	05/07/2020	**Piping Installed Date**	03/01/2017	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	05/06/2020	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	10/09/2019	**Tank/Piping CP Test Date**	08/22/2017	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	7900	**ATG Test Date**		**Line Tightness Test Date**	04/18/2017	**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date	05/07/2020			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS;Veeder Root/TLS-450PLUS				

Tank Number	12	**Tank Age**	8	**Tank Installed Date**	04/18/2017	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	5738	**Spill Test Date**	05/07/2020	**Piping Installed Date**	03/01/2017	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	05/06/2020	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	10/09/2020	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**		**Line Tightness Test Date**	06/08/2017	**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	05/07/2020			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS;Veeder Root/TLS-450PLUS				
Tank Number	13	**Tank Age**	8	**Tank Installed Date**	04/18/2017	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	5739	**Spill Test Date**	05/07/2020	**Piping Installed Date**	04/26/2023	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	05/06/2020	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	10/09/2019	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**		**Line Tightness Test Date**	04/19/2017	**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	05/07/2020			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS;Veeder Root/TLS-450PLUS				
Tank Number	14	**Tank Age**	8	**Tank Installed Date**	04/18/2017	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	
Tag Number	5740	**Spill Test Date**		**Piping Installed Date**	03/01/2017	**Tank Construction**		**Piping Construction**		**AST**	No
Status	**Other**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**		**Piping Type**	Pressurized	**CP Met Types**	
Product	DEF (Not Regulated)	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Not Listed	**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				

Facility Summary in Beaverhead County in the City of Dillon

Location: SAFEWAY 1581 DILLON
760 Vine St.
Dillon, MT 59725-3315 Beaverhead

System Facility ID:56-13989

Facility Code: 30650
Last Inspected On: 05/19/2025
Operating Permit Renewal Date: 11/05/2025

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Safeway Stores Inc

Operator Contact: Jesse Wees;Rachel Jones **(208) 395-3269;(208) 412-7561** **jesse.wees@albertsons.com;rachel.jones@albertsons.com**

Owner/Operator: Safeway Stores Inc

Jesse Wees, UST Class A Operator	jesse.wees@albertsons.com
Jesse Wees, UST Class A Operator	jesse.wees@albertsons.com
Page Rost, UST Class B Global Operator	page.rost@albertsons.com
Page Rost, UST Class B Global Operator	page.rost@albertsons.com
Rachel Jones , UST Class A Operator	rachel.jones@albertsons.com
Rachel Jones , UST Class A Operator	rachel.jones@albertsons.com
Rachel Jones , UST Class B Global Operator	rachel.jones@albertsons.com
Rachel Jones , UST Class B Global Operator	rachel.jones@albertsons.com
Shanna Sunderlin, UST Class B Global Operator	
Shanna Sunderlin, UST Class B Global Operator	

Tank Number	01	**Tank Age**	25	**Tank Installed Date**	10/09/2000	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	4222	**Spill Test Date**	05/04/2022	**Piping Installed Date**	04/22/2022	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	05/04/2022	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	05/18/2022	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	20000	**ATG Test Date**	05/18/2022	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date	05/18/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-450				
Tank Number	02	**Tank Age**	25	**Tank Installed Date**	10/01/2000	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	4223	**Spill Test Date**	05/04/2022	**Piping Installed Date**	04/22/2022	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	05/04/2022	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible

Product	Gasoline	**PLLD Test Date**	05/18/2022	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	05/18/2022	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date	05/18/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-450				
Tank Number	03	**Tank Age**	25	**Tank Installed Date**	10/01/2000	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	4224	**Spill Test Date**	05/04/2022	**Piping Installed Date**	04/22/2022	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	05/04/2022	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	05/18/2022	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	05/18/2022	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date	05/18/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Beaverhead County in the City of Dillon

Location: SPEEDY SINGHS INC
4055 Rebich Ln
Dillon, MT 59725 Beaverhead

System Facility ID:01-13101

Facility Code: 17715
Last Inspected On: 02/02/2024
Operating Permit Renewal Date: 03/03/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	SPEEDY SINGHS INC	**(406) 683-6404**	**GATEWAYTRUCKSTOP@GMAIL.COM**
Operator Contact:	Sharanjit Multani;SPEEDY SINGHS INC	**(801) 928-3419;(406) 683-6404**	**sharan_jit@icloud.com;GATEWAYTRUCKSTOP@GMAIL.COM**

Owner/Operator: SPEEDY SINGHS INC (406) 683-6404 GATEWAYTRUCKSTOP@GMAIL.COM

Sharanjit Multani, UST Class A Operator GATEWAYTRUCKSTOP@GMAIL.COM

Tank Number	01	**Tank Age**	32	**Tank Installed Date**	07/01/1993	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	4634	**Spill Test Date**	02/02/2024	**Piping Installed Date**	03/12/2009	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	10/05/2023	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	03/13/2024	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	10/05/2023	**Line Tightness Test Date**	10/05/2023	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	04/03/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	02	**Tank Age**	32	**Tank Installed Date**	07/01/1993	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	4635	**Spill Test Date**	04/03/2024	**Piping Installed Date**	03/12/2009	**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	10/05/2023	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	03/13/2024	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	10/05/2023	**Line Tightness Test Date**	10/05/2023	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	04/03/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Tank Number	03	**Tank Age**	32	**Tank Installed Date**	07/01/1993	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	4636	**Spill Test Date**	04/03/2024	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	10/05/2023	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	03/13/2024	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	10/05/2023	**Line Tightness Test Date**	10/05/2023	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	04/03/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	04	**Tank Age**	32	**Tank Installed Date**	07/01/1993	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	4637	**Spill Test Date**	02/02/2024	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	10/05/2023	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	03/13/2024	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	10/05/2023	**Line Tightness Test Date**	04/18/2024	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	04/03/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	05	**Tank Age**	32	**Tank Installed Date**	07/01/1993	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	4638	**Spill Test Date**	04/03/2024	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	10/05/2023	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	03/13/2024	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	10/05/2023	**Line Tightness Test Date**	10/05/2023	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	04/03/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Beaverhead County in the City of Dillon

Location: THE MINI INC
410 N Montana St
Dillon, MT 59725 Beaverhead

System Facility ID:01-01215

Facility Code: 17471
Last Inspected On: 09/10/2024
Operating Permit Renewal Date: 10/13/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Jeff Dubose;The Mini Inc	**(406) 683-6168**	**theminiinc@hotmail.com**
Operator Contact:	Lori DuBose	**(406) 638-6168**	**theminiinc@hotmail.com**

Owner/Operator: Jeff Dubose (406) 683-6168

Owner/Operator: The Mini Inc (406) 683-6168

Lori DuBose, UST Class A Operator theminiinc@hotmail.com

Lori DuBose, UST Class B Operator theminiinc@hotmail.com

Tank Number	04	**Tank Age**	27	**Tank Installed Date**	05/06/1998	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	3088	**Spill Test Date**	11/04/2024	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	09/11/2018	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	05/21/2024	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	09/10/2024	**Line Tightness Test Date**	05/05/2021	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	09/10/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Number	05	**Tank Age**	27	**Tank Installed Date**	05/06/1998	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	3089	**Spill Test Date**	09/11/2024	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	09/11/2018	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	05/21/2024	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**	09/10/2024	**Line Tightness Test Date**	04/28/2021	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	09/10/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-450				

Tank Number	06	**Tank Age**	27	**Tank Installed Date**	05/06/1998	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	3090	**Spill Test Date**	09/10/2024	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	04/25/2022	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	05/21/2024	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	5000	**ATG Test Date**	09/10/2024	**Line Tightness Test Date**	04/13/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date	09/10/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-450				

Facility Summary in Beaverhead County in the City of Dillon

Location: TOWN PUMP INC DILLON 1
101 E Helena St
Dillon, MT 59725 Beaverhead

System Facility ID:01-08695

Facility Code: 17673
Last Inspected On: 05/20/2025
Operating Permit Renewal Date: 09/02/2025

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Dillon 1 Town Pump LLC	**(406) 497-6700**	**environmental@townpump.com**
Operator Contact:	Trent Biggers		**Trentb@townpump.com**

Owner/Operator:	Dillon 1 Town Pump LLC	(406) 497-6700	environmental@townpump.com
	Trent Biggers, UST Class A Operator		Trentb@townpump.com
	Trent Biggers, UST Class A Operator		Trentb@townpump.com
	Trent Biggers, UST Class B Global Operator		Trentb@townpump.com
	Trent Biggers, UST Class B Global Operator		Trentb@townpump.com

Tank Number	01	**Tank Age**	64	**Tank Installed Date**	04/14/1961	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve;Flapper Valve
Tag Number	4794	**Spill Test Date**	11/09/2024	**Piping Installed Date**	10/19/2002	**Tank Construction**	Lined Interior/Impressed Current	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Diesel	**PLLD Test Date**	06/12/2023	**Tank/Piping CP Test Date**	05/05/2021	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	06/12/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	11/09/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Number	04	**Tank Age**	39	**Tank Installed Date**	01/01/1986	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve;Flapper Valve
Tag Number	4795	**Spill Test Date**	11/09/2024	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**	06/12/2023	**Tank/Piping CP Test Date**	05/05/2021	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No

Capacity	10000	**ATG Test Date**	06/12/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	11/09/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Number	05	**Tank Age**	39	**Tank Installed Date**	01/01/1986	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve;Flapper Valve
Tag Number	4796	**Spill Test Date**	11/09/2024	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**	06/12/2023	**Tank/Piping CP Test Date**	05/05/2021	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	06/12/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	11/09/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				

Facility Summary in Beaverhead County in the City of Dillon

Location: TOWN PUMP OF DILLON 2
635 N Montana St
Dillon, MT 59725 Beaverhead

System Facility ID:01-08696

Facility Code: 17674
Last Inspected On: 08/30/2022
Operating Permit Renewal Date: 09/19/2025

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Dillon 2 Town Pump LLC **(406) 497-6700** **environmental@townpump.com**

Operator Contact: Trent Biggers **Trentb@townpump.com**

Owner/Operator: Dillon 2 Town Pump LLC (406) 497-6700 environmental@townpump.com

Trent Biggers, UST Class A Operator Trentb@townpump.com
Trent Biggers, UST Class A Operator Trentb@townpump.com
Trent Biggers, UST Class B Global Operator Trentb@townpump.com
Trent Biggers, UST Class B Global Operator Trentb@townpump.com

Tank Number	07	**Tank Age**	35	**Tank Installed Date**	09/10/1990	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	2372	**Spill Test Date**	11/15/2024	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	03/30/2015	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	06/30/2022	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	06/30/2022	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	07/08/2021			**ATG Type**	Gilbarco-Veeder Root/TLS-450				
Tank Number	08	**Tank Age**	35	**Tank Installed Date**	09/10/1990	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	2373	**Spill Test Date**	11/15/2024	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	03/30/2015	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	06/30/2022	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	06/30/2022	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	07/08/2021			**ATG Type**	Gilbarco-Veeder Root/TLS-450				

Tank Number	09	**Tank Age**	35	**Tank Installed Date**	09/10/1990	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	2374	**Spill Test Date**	11/15/2024	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	03/30/2015	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	06/30/2022	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	06/30/2022	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	07/08/2021			**ATG Type**	Gilbarco-Veeder Root/TLS-450				
Tank Number	10	**Tank Age**	35	**Tank Installed Date**	09/10/1990	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	2375	**Spill Test Date**	11/15/2024	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	03/30/2015	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	06/30/2022	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	06/30/2022	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	09/11/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-450				
Tank Number	11	**Tank Age**	35	**Tank Installed Date**	09/10/1990	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	2376	**Spill Test Date**	11/15/2024	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	10/15/2020	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	06/30/2022	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	06/30/2022	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	11/15/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-450				
Tank Number	14	**Tank Age**	24	**Tank Installed Date**	08/20/2001	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve
Tag Number	4356	**Spill Test Date**	07/08/2021	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	03/30/2015	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible

Product	Gasoline	**PLLD Test Date**	06/30/2022	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	06/30/2022	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	07/08/2021			**ATG Type**	Gilbarco-Veeder Root/TLS-450				
Tank Number	15	**Tank Age**	24	**Tank Installed Date**	08/20/2001	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve
Tag Number	4357	**Spill Test Date**	07/08/2021	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	03/30/2015	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel, Dyed	**PLLD Test Date**	06/30/2022	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	5000	**ATG Test Date**	06/30/2022	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	07/08/2021			**ATG Type**	Gilbarco-Veeder Root/TLS-450				
Tank Number	13	**Tank Age**	26	**Tank Installed Date**	05/01/1999	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve
Tag Number	4541	**Spill Test Date**	11/15/2024	**Piping Installed Date**	11/14/2024	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	11/14/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	06/30/2022	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	5000	**ATG Test Date**	06/30/2022	**Line Tightness Test Date**	11/16/2024	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	11/15/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-450				

Facility Summary in Beaverhead County in the City of Jackson

Location: CIRCLE S RANCH
30300 MT Hwy 278
Jackson, MT 59736-9700 Beaverhead

System Facility ID:01-07024

Facility Code: 17626
Last Inspected On: 03/17/2023
Operating Permit Renewal Date: 06/03/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: David Schuett **d.schuett@frontlineag.com**

Operator Contact: David Schuett **d.schuett@frontlineag.com**

Owner/Operator: David Schuett d.schuett@frontlineag.com

David Schuett, UST Class A Operator d.schuett@frontlineag.com

Tank Number	S1	**Tank Age**	45	**Tank Installed Date**	02/12/1980	**Tank Material Construction**	Bare Steel	**Piping Material**	Steel	**Overfill Types**	
Tag Number		**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**		**AST**	No
Status	**Deregulated under SB386**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**		**Piping Type**	Not Listed	**CP Met Types**	
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Not Listed	**Primary Pipe Leak Detection**	Not Listed	**Vapor Recovery**	No
Capacity	2000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	05	**Tank Age**	28	**Tank Installed Date**	07/01/1997	**Tank Material Construction**	Steel Clad	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	4228	**Spill Test Date**	03/17/2023	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	1000	**ATG Test Date**	03/17/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	03/17/2023			**ATG Type**	Other/Other				
Tank Number	06	**Tank Age**	28	**Tank Installed Date**	07/01/1997	**Tank Material Construction**	Steel Clad	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	4229	**Spill Test Date**	03/17/2023	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No

Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	1000	**ATG Test Date**	03/17/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	03/17/2023			**ATG Type**	Other/Other				

Facility Summary in Beaverhead County in the City of Lima

Location: LIMA SCHOOL DIST 12 INC
1 N Harrison St
Lima, MT 59739 Beaverhead

System Facility ID:01-07158

Facility Code: 17665
Last Inspected On: 12/21/2023
Operating Permit Renewal Date: 01/17/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: School Dist 12 Lima **(406) 276-3571** **rkluesner@limaschoolmt.org**

Operator Contact:

Owner/Operator: School Dist 12 Lima (406) 276-3571 rkluesner@limaschoolmt.org

Tank Number	03	**Tank Age**	33	**Tank Installed Date**	06/01/1992	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	1535	**Spill Test Date**	12/21/2023	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	U.S. Suction	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	07/27/2020	**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	3-Year Line Tightness Test	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**		**Line Tightness Test Date**	12/21/2023	**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	12/21/2023			**ATG Type**	Gilbarco-Veeder Root/ILS-250				

Facility Summary in Beaverhead County in the City of Lima

Location: RALPHS EXXON
114 S Harrison St
Lima, MT 59739 Beaverhead

System Facility ID:01-00671

Facility Code: 17463
Last Inspected On: 04/23/2025
Operating Permit Renewal Date: 09/21/2025

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Ralphs C-Store Inc	**(406) 925-1081**	**jdt.ralphs@gmail.com**
Operator Contact:	Branden Thornton;Justin Thornton		**branden.t@mail.com;jdt1986@comcast.net**

Owner/Operator:	Ralphs C-Store Inc	(406) 925-1081	jdt.ralphs@gmail.com
	Branden Thornton, UST Class A Operator		branden.t@mail.com
	Branden Thornton, UST Class A Operator		branden.t@mail.com
	Branden Thornton, UST Class B Global Operator		branden.t@mail.com
	Branden Thornton, UST Class B Global Operator		branden.t@mail.com
	Justin Thornton, UST Class A Operator		jdt1986@comcast.net
	Justin Thornton, UST Class A Operator		jdt1986@comcast.net
	Justin Thornton, UST Class B Global Operator		jdt1986@comcast.net
	Justin Thornton, UST Class B Global Operator		jdt1986@comcast.net

Tank Number	07	**Tank Age**	27	**Tank Installed Date**	09/01/1998	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve
Tag Number	2078	**Spill Test Date**	12/11/2024	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	10/14/2021	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	08/18/2022	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	08/18/2022	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	10/14/2021			**ATG Type**	Gilbarco/TLS-350				
Tank Number	08	**Tank Age**	27	**Tank Installed Date**	09/01/1998	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve
Tag Number	2079	**Spill Test Date**	11/15/2021	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	10/14/2021	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	08/18/2022	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No

Capacity	4000	**ATG Test Date**	08/18/2022	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	10/14/2021			**ATG Type**	Gilbarco/TLS-350				
Tank Number	S9	**Tank Age**	8	**Tank Installed Date**	11/14/2017	**Tank Material Construction**	Aboveground Tank	**Piping Material**	Flexible Plastic	**Overfill Types**	
Tag Number	5783	**Spill Test Date**		**Piping Installed Date**	09/01/2017	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	Yes
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	10/14/2021	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Diesel	**PLLD Test Date**	08/18/2022	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	08/18/2022	**Line Tightness Test Date**	11/14/2017	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date				**ATG Type**					

Facility Summary in Beaverhead County in the City of Wisdom

Location: PINTLER STATION
318 MT Hwy 43
Wisdom, MT 59761-0175 Beaverhead

System Facility ID:01-02173

Facility Code: 17490
Last Inspected On: 06/08/2023
Operating Permit Renewal Date: 07/30/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Chancy Campbell **ccfordman74@gmail.com**

Operator Contact: Sheila Campbell **scrappinann7874@gmail.com**

Owner/Operator: Chancy Campbell ccfordman74@gmail.com

Sheila Campbell, UST Class A Operator scrappinann7874@gmail.com

Sheila Campbell, UST Class B Operator scrappinann7874@gmail.com

Tank Number	01	**Tank Age**	40	**Tank Installed Date**	03/10/1985	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Steel	**Overfill Types**	Flapper Valve
Tag Number	3323	**Spill Test Date**	07/20/2023	**Piping Installed Date**		**Tank Construction**	Lined Interior/Impressed Current	**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	06/08/2023	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	2000	**ATG Test Date**		**Line Tightness Test Date**	05/03/2005	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	07/20/2023			**ATG Type**					
Tank Number	02	**Tank Age**	40	**Tank Installed Date**	03/10/1985	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Steel	**Overfill Types**	Flapper Valve
Tag Number	3324	**Spill Test Date**	06/08/2023	**Piping Installed Date**		**Tank Construction**	Lined Interior/Impressed Current	**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	06/08/2023	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	1000	**ATG Test Date**		**Line Tightness Test Date**	05/03/2005	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	07/20/2023			**ATG Type**					

Facility Summary in Beaverhead County in the City of Wise River

Location: WISE RIVER MERCANTILE
65221 Hwy 43
Wise River, MT 59762 Beaverhead

System Facility ID:01-02080

Facility Code: 17487
Last Inspected On: 04/24/2025
Operating Permit Renewal Date: 10/13/2025

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: JimCon Inc **(406) 832-3271**

Operator Contact: Connie Holland **(406) 832-3271** **Connieholland49@gmail.com**

Owner/Operator: JimCon Inc (406) 832-3271

Connie Holland, UST Class A Operator Connieholland49@gmail.com
Connie Holland, UST Class B Operator Connieholland49@gmail.com
Laura Delaney, UST Class B Global Operator

Tank Number	03	**Tank Age**	27	**Tank Installed Date**	06/01/1998	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	1224	**Spill Test Date**	11/09/2021	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	2000	**ATG Test Date**	11/15/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	11/09/2021			**ATG Type**	Gilbarco/EMC Basic				

Facility Summary in Big Horn County in the City of Crow Agency

Location: CROW NATION EXPRESS
US Hwy 212 & I-90
Crow Agency, MT 59022 Big Horn

System Facility ID:02-10867

Facility Code: 17827
Last Inspected On: 12/19/2023
Operating Permit Renewal Date: 01/06/2024

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Becky Wilson;Crow Tribe of Indians **(406) 638-2059;(406) 679-2400** **becky.wilson@crow-nsn.gov**

Operator Contact:

Owner/Operator: Becky Wilson (406) 679-2400 becky.wilson@crow-nsn.gov

Owner/Operator: Crow Tribe of Indians (406) 679-2400 becky.wilson@crow-nsn.gov

Tank Number	05	**Tank Age**	25	**Tank Installed Date**	02/01/2000	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	4174	**Spill Test Date**	12/18/2020	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	12/21/2011	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**		**Line Tightness Test Date**	08/02/2015	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	12/18/2020			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	06	**Tank Age**	25	**Tank Installed Date**	02/01/2000	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	4175	**Spill Test Date**	12/18/2020	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	12/21/2011	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**		**Line Tightness Test Date**	08/02/2015	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	12/18/2020			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Tank Number	07	**Tank Age**	25	**Tank Installed Date**	02/01/2000	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	4176	**Spill Test Date**	12/18/2020	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	12/21/2011	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**		**Line Tightness Test Date**	08/02/2015	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	12/18/2020			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	08	**Tank Age**	25	**Tank Installed Date**	02/01/2000	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	4177	**Spill Test Date**	12/18/2020	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	12/21/2011	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**		**Line Tightness Test Date**	08/02/2015	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	12/18/2020			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	09	**Tank Age**	25	**Tank Installed Date**	02/01/2000	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	4178	**Spill Test Date**	12/18/2020	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	12/21/2011	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**		**Line Tightness Test Date**	08/02/2015	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	12/18/2020			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Big Horn County in the City of Crow Agency

Location: TEEPEE SERVICE INC
6959 E Makawasha Ave
Crow Agency, MT 59022-0280 Big Horn

System Facility ID:02-07334

Facility Code: 17799
Last Inspected On: 04/09/2025
Operating Permit Renewal Date: 07/22/2028

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Teepee Service Inc **(406) 638-2269**

Operator Contact: James Watt **2teepee@nemont.net**

Owner/Operator: Teepee Service Inc (406) 638-2269

James Watt, UST Class A Operator 2teepee@nemont.net
James Watt, UST Class A Operator 2teepee@nemont.net
James Watt, UST Class B Operator 2teepee@nemont.net
James Watt, UST Class B Operator 2teepee@nemont.net

Tank Number	07	**Tank Age**	30	**Tank Installed Date**	07/03/1995	**Tank Material Construction**	Steel Clad	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	2097	**Spill Test Date**	04/09/2025	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	04/09/2025	**Tank/Piping CP Test Date**	04/16/2013	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	04/09/2025	**Line Tightness Test Date**	03/06/2022	**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	04/09/2025			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	08	**Tank Age**	30	**Tank Installed Date**	07/03/1995	**Tank Material Construction**	Steel Clad	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	2098	**Spill Test Date**	04/09/2025	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	04/09/2025	**Tank/Piping CP Test Date**	04/16/2013	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	04/09/2025	**Line Tightness Test Date**	02/18/2022	**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**		**Energy Act**	No

		Overfill Test Date	04/09/2025			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Big Horn County in the City of Fort Smith

Location: BIGHORN CANYON MAINTENANCE FACILITY (NPS)
5th Ave B
Fort Smith, MT 59035 Big Horn

System Facility ID:02-09815

Facility Code: 17820
Last Inspected On: 03/10/2021
Operating Permit Renewal Date: 03/21/2024

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: National Park Service Yellowtail **(406) 666-3311**

Operator Contact: Jesse Macklin;Kelly Peacock;Lyndon Driftwood;William Snell **(406) 666-3310;(406) 666-3312** **kelly_peacock@nps.gov;lyndon_driftwood@nps.gov**

Owner/Operator: National Park Service Yellowtail (406) 666-3311

Jesse Macklin, UST Class A Operator	
Jesse Macklin, UST Class B Global Operator	
Jesse Macklin, UST Class B Operator	
Kelly Peacock, UST Class A Operator	kelly_peacock@nps.gov
Kelly Peacock, UST Class B Operator	kelly_peacock@nps.gov
Lyndon Driftwood, UST Class A Operator	lyndon_driftwood@nps.gov
Lyndon Driftwood, UST Class B Global Operator	lyndon_driftwood@nps.gov
Norman Griffin, UST Class B Operator	
Roger Watson, UST Class B Global Operator	
William Snell, UST Class A Operator	
William Snell, UST Class B Global Operator	
William Snell, UST Class B Operator	

Tank Number	05	**Tank Age**	37	**Tank Installed Date**	01/01/1988	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass	**Overfill Types**	Ball Float Valve;High Level Alarm
Tag Number	1745	**Spill Test Date**	06/15/2023	**Piping Installed Date**	10/16/2017	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	03/10/2021	**Sump Tightness Test Date**	10/16/2017	**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	07/26/2019	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	2000	**ATG Test Date**		**Line Tightness Test Date**	03/10/2021	**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	MLLD Line Tightness Testing	**Energy Act**	No
		Overfill Test Date	06/15/2023			**ATG Type**	Veeder Root/TLS-300				
Tank Number	06	**Tank Age**	37	**Tank Installed Date**	01/01/1988	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass	**Overfill Types**	Ball Float Valve;High Level Alarm

Tag Number	1746	**Spill Test Date**	06/15/2023	**Piping Installed Date**	10/16/2017	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	03/10/2021	**Sump Tightness Test Date**	10/16/2017	**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	07/26/2019	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	2000	**ATG Test Date**		**Line Tightness Test Date**	03/10/2021	**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	MLLD Line Tightness Testing	**Energy Act**	No
		Overfill Test Date	06/15/2023			**ATG Type**	Veeder Root/TLS-300				

Facility Summary in Big Horn County in the City of Fort Smith

Location: OK A BEH MARINA
5 Ave B
Fort Smith, MT 59035 Big Horn

System Facility ID:56-13877

Facility Code: 30554
Last Inspected On: 05/08/2021
Operating Permit Renewal Date: 05/26/2022

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: National Park Service Yellowtail **(406) 666-3311**

Operator Contact: Christian Fighter;Jaris Pretty Paint;Kelly Peacock;Marvin Stewart;Shawn Backbone;Tristan Stewart **(406) 683-5313** **fighterchristian117@gmail.com;jprettypaint01@gmail.com;kelly_peacock@nps.gov;shawnbackbone78@gmail.com;tristantoddstewart@gmail.com**

Owner/Operator: National Park Service Yellowtail (406) 666-3311

Christian Fighter, UST Class A Operator	fighterchristian117@gmail.com
Christian Fighter, UST Class B Operator	fighterchristian117@gmail.com
Jaris Pretty Paint, UST Class A Operator	jprettypaint01@gmail.com
Kelly Peacock, UST Class A Operator	kelly_peacock@nps.gov
Kelly Peacock, UST Class B Operator	kelly_peacock@nps.gov
Marvin Stewart, UST Class A Operator	
Marvin Stewart, UST Class B Operator	
Shawn Backbone, UST Class A Operator	shawnbackbone78@gmail.com
Tristan Stewart, UST Class A Operator	tristantoddstewart@gmail.com
Tristan Stewart, UST Class B Operator	tristantoddstewart@gmail.com

Tank Number	07	**Tank Age**	35	**Tank Installed Date**	05/14/1990	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	1747	**Spill Test Date**	06/14/2023	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	06/02/2021	**Sump Tightness Test Date**	06/22/2016	**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	07/19/2020	**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	2000	**ATG Test Date**		**Line Tightness Test Date**	06/02/2021	**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/TLS-300;Veeder Root/TLS-300				

Facility Summary in Big Horn County in the City of Fort Smith

Location: YELLOWTAIL MARKET
Park Dale Ct
Fort Smith, MT 59035 Big Horn

System Facility ID:02-05862

Facility Code: 17785
Last Inspected On: 10/03/2024
Operating Permit Renewal Date: 10/20/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Crow Tribe of Indians **(406) 638-2059**

Operator Contact: Becky Wilson;John Wilson **(406) 638-2400;(406) 679-2400** **becky.wilson@crow-nsn.gov**

Owner/Operator: Crow Tribe of Indians (406) 638-2059

Becky Wilson, UST Class A Operator	becky.wilson@crow-nsn.gov
Becky Wilson, UST Class A Operator	becky.wilson@crow-nsn.gov
Becky Wilson, UST Class B Operator	becky.wilson@crow-nsn.gov
Becky Wilson, UST Class B Operator	becky.wilson@crow-nsn.gov
John Wilson, UST Class A Operator	
John Wilson, UST Class B Global Operator	

Tank Number	03	**Tank Age**	27	**Tank Installed Date**	03/01/1998	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	1210	**Spill Test Date**	10/03/2024	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**	01/10/2025	**Tank/Piping CP Test Date**	10/03/2024	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	10/03/2024	**Line Tightness Test Date**	03/04/2021	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	01/10/2025			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	04	**Tank Age**	27	**Tank Installed Date**	03/01/1998	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	1211	**Spill Test Date**	10/03/2024	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Single Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**	01/10/2025	**Tank/Piping CP Test Date**	10/03/2024	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	10/03/2024	**Line Tightness Test Date**	03/04/2021	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No

		Overfill Test Date	01/10/2025			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Big Horn County in the City of Garryowen

Location: GARRYOWEN CONOCO
200 Town Hall
Garryowen, MT 59031 Big Horn

System Facility ID:02-03284

Facility Code: 17761
Last Inspected On: 10/15/2021
Operating Permit Renewal Date: 10/25/2021

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Neda LLC **(406) 638-2020**

Operator Contact: Chris Kortlander **(406) 679-4444** **chris@historicalrarities.com**

Owner/Operator: Neda LLC (406) 638-2020

Chris Kortlander, UST Class A Operator chris@historicalrarities.com
Chris Kortlander, UST Class A Operator chris@historicalrarities.com
Petra Pretty On Top, UST Class B Global Operator
Petra Pretty On Top, UST Class B Global Operator

Tank Number	01	**Tank Age**	29	**Tank Installed Date**	06/21/1996	**Tank Material Construction**	Steel Clad	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	3392	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Secondary Containment Chase	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	07/29/2008	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**		**Line Tightness Test Date**	10/15/2018	**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date				**ATG Type**	Veeder Root/TLS-300				
Tank Number	02	**Tank Age**	29	**Tank Installed Date**	06/21/1996	**Tank Material Construction**	Steel Clad	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	3393	**Spill Test Date**		**Piping Installed Date**	06/11/2013	**Tank Construction**	Double-Walled	**Piping Construction**	Secondary Containment Chase	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	07/29/2008	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No

Capacity	12000	**ATG Test Date**		**Line Tightness Test Date**	10/15/2018	**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date				**ATG Type**	Veeder Root/TLS-300				

Facility Summary in Big Horn County in the City of Hardin

Location: BIG HORN COUNTY COMMUNITY SERVICE FACILITY
809 N Custer Ave
Hardin, MT 59034-1311 Big Horn

System Facility ID:02-10287

Facility Code: 17825
Last Inspected On: 01/08/2021
Operating Permit Renewal Date: 01/17/2024

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Big Horn County Health Dept **(406) 665-8720**

Operator Contact: Craig Taft **(406) 665-8724** **ctaft@co.bighorn.mt.us**

Craig Taft, UST Class A Operator ctaft@co.bighorn.mt.us
Craig Taft, UST Class A Operator ctaft@co.bighorn.mt.us
Craig Taft, UST Class B Global Operator ctaft@co.bighorn.mt.us
Craig Taft, UST Class B Global Operator ctaft@co.bighorn.mt.us

Tank Number	02	**Tank Age**	27	**Tank Installed Date**	11/01/1998	**Tank Material Construction**	Steel Clad	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	443	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	12/21/2011	**Primary Tank Leak Detection**	Manual Interstitial Monitoring	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					

Facility Summary in Big Horn County in the City of Hardin

Location: DOLLIES CONVENIENCE STORE
804 3rd St W
Hardin, MT 59034-1606 Big Horn

System Facility ID:02-00061

Facility Code: 17730
Last Inspected On: 12/16/2022
Operating Permit Renewal Date: 12/16/2025

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Jagadish LLC;Susan Greer	**(406) 665-1424;(605) 517-1140**	**cpatel8897@gmail.com**
Operator Contact:	Chetan Patel;Megan Ashinhurst	**(605) 517-1140**	**cpatel8897@gmail.com**

Owner/Operator:	Jagadish LLC	(605) 517-1140	cpatel8897@gmail.com
Owner/Operator:	Susan Greer	(605) 517-1140	cpatel8897@gmail.com
	Chetan Patel, UST Class A Operator		cpatel8897@gmail.com
	Chetan Patel, UST Class A Operator		cpatel8897@gmail.com
	Chetan Patel, UST Class B Operator		cpatel8897@gmail.com
	Chetan Patel, UST Class B Operator		cpatel8897@gmail.com
	Constance Weigand, UST Class B Operator		
	Constance Weigand, UST Class B Operator		
	Corri Duncan, UST Class B Operator		corriduncan@aol.com
	Corri Duncan, UST Class B Operator		corriduncan@aol.com
	Megan Ashinhurst, UST Class A Operator		
	Megan Ashinhurst, UST Class A Operator		
	Megan Ashinhurst, UST Class B Global Operator		
	Megan Ashinhurst, UST Class B Global Operator		

Tank Number	01	**Tank Age**	41	**Tank Installed Date**	12/20/1984	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	4463	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Single Walled	**AST**	No
Status	**Temporarily Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	12/16/2022	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.1;Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**		**Line Tightness Test Date**	01/21/2015	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**	Veeder Root/TLS-300				

Tank Number	03	**Tank Age**	23	**Tank Installed Date**	12/16/2002	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	4773	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Temporarily Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	12/16/2022	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.1;Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**		**Line Tightness Test Date**	01/21/2015	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**	Veeder Root/TLS-300				

Facility Summary in Big Horn County in the City of Hardin

Location: FORMER BAIRS TRUCK STOP HARDIN
315 13th St W
Hardin, MT 59034-1006 Big Horn

System Facility ID:02-05752

Facility Code: 17781
Last Inspected On: 03/09/2022
Operating Permit Renewal Date: 06/01/2025

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Hardin 2 RE2 LLC	**(406) 497-6700**	**environmental@townpump.com**
Operator Contact:	Trent Biggers;Town Pump		**Trentb@townpump.com;environmental@townpump.com**

Trent Biggers, UST Class A Operator	environmental@townpump.com
Trent Biggers, UST Class A Operator	environmental@townpump.com
Trent Biggers, UST Class B Operator	environmental@townpump.com
Trent Biggers, UST Class B Operator	environmental@townpump.com

Tank Number	01	**Tank Age**	56	**Tank Installed Date**	04/25/1969	**Tank Material Construction**	Bare Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	3894	**Spill Test Date**	08/31/2020	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**	08/13/2018	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	03/09/2022	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	40000	**ATG Test Date**		**Line Tightness Test Date**	02/07/2013	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date	08/31/2020			**ATG Type**					
Tank Number	03	**Tank Age**	46	**Tank Installed Date**	04/26/1979	**Tank Material Construction**	Bare Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	3895	**Spill Test Date**	06/20/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**	08/13/2018	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	03/09/2022	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	40000	**ATG Test Date**		**Line Tightness Test Date**	01/04/2013	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date	06/20/2022			**ATG Type**					

Tank Number	04	**Tank Age**	56	**Tank Installed Date**	04/25/1969	**Tank Material Construction**	Bare Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	3896	**Spill Test Date**	08/31/2020	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**	08/13/2018	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	03/09/2022	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	24000	**ATG Test Date**		**Line Tightness Test Date**	01/04/2013	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date	06/20/2022			**ATG Type**					

Facility Summary in Big Horn County in the City of Hardin

Location: GOOD 2 GO STORES LLC
1600 N Crawford Ave
Hardin, MT 59034 Big Horn

System Facility ID:02-00538

Facility Code: 17731
Last Inspected On: 05/14/2025
Operating Permit Renewal Date: 12/11/2025

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	#8 Hardin Montana Property LLC	**(208) 523-6582**	**compliance@southforkmanagement.com**
Operator Contact:	Amy Packard;Good 2 Go Stores LLC;Garry Wells;Good 2 Go Stores LLC;Jeanette Nette;Good 2 Go Stores LLC;Lisa Yates;Good 2 Go Stores LLC	**(208) 417-1590**	**gdubb350@gmail.com;licensing@good2gostores.com;jnetty1970@gmail.com;licensing@good2gostores.com;lisa.yates@good2go.com;licensing@good2gostores.com;store218@good2gostores.com;licensing@good2gostores.com**

Owner/Operator:	#8 Hardin Montana Property LLC	(208) 523-6582	compliance@southforkmanagement.com
	Amy Packard, UST Class A Operator		licensing@good2gostores.com
	Amy Packard, UST Class B Operator		licensing@good2gostores.com
	Garry Wells, UST Class A Operator		licensing@good2gostores.com
	Garry Wells, UST Class B Operator		licensing@good2gostores.com
	Jeanette Nette, UST Class A Operator		licensing@good2gostores.com
	Jeanette Nette, UST Class B Operator		licensing@good2gostores.com
	Lisa Yates, UST Class A Operator		licensing@good2gostores.com
	Lisa Yates, UST Class B Operator		licensing@good2gostores.com

Tank Number	03	**Tank Age**	51	**Tank Installed Date**	04/12/1974	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	3789	**Spill Test Date**	08/08/2022	**Piping Installed Date**	04/16/2010	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	08/12/2020	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	05/09/2022	**Tank/Piping CP Test Date**	08/28/2007	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**	08/08/2022	**Line Tightness Test Date**	07/26/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date	10/24/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	04	**Tank Age**	51	**Tank Installed Date**	04/12/1974	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	3790	**Spill Test Date**	08/08/2022	**Piping Installed Date**	04/16/2010	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	08/12/2020	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible

Product	Gasoline	**PLLD Test Date**	05/09/2022	**Tank/Piping CP Test Date**	08/08/2007	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**	08/08/2022	**Line Tightness Test Date**	04/24/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date	08/08/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	05	**Tank Age**	51	**Tank Installed Date**	04/12/1974	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	3791	**Spill Test Date**	08/08/2022	**Piping Installed Date**	04/16/2010	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	08/12/2020	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	05/09/2022	**Tank/Piping CP Test Date**	08/28/2007	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**	08/08/2022	**Line Tightness Test Date**	03/08/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date	08/08/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	06	**Tank Age**	51	**Tank Installed Date**	04/12/1974	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	3792	**Spill Test Date**	08/08/2022	**Piping Installed Date**	04/16/2010	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	08/12/2020	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	05/09/2022	**Tank/Piping CP Test Date**	09/07/2007	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**	08/08/2022	**Line Tightness Test Date**	07/26/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date	08/08/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Big Horn County in the City of Hardin

Location: HARDIN C STORE
1223 N Crawford Ave
Hardin, MT 59034-1009 Big Horn

System Facility ID:02-13635

Facility Code: 17852
Last Inspected On: 08/08/2022
Operating Permit Renewal Date: 12/10/2025

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Town and Country Supply Association **(406) 628-6314**

Operator Contact: Wes Burley **(406) 256-1020**

Owner/Operator: Town and Country Supply Association (406) 628-6314

Jennifer Reinhardt, UST Class B Global Operator jreinhardt@tandcsupply.com
Melanie Hale, UST Class B Operator mhale@tandcsupply.com
Wes Burley, UST Class A Operator

Tank Number	01	**Tank Age**	30	**Tank Installed Date**	07/01/1995	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	927	**Spill Test Date**	08/08/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**	08/08/2022	**Tank/Piping CP Test Date**	08/08/2022	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	16000	**ATG Test Date**	08/08/2022	**Line Tightness Test Date**	08/04/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	08/08/2022			**ATG Type**	Gilbarco/EMC Basic				
Tank Number	02	**Tank Age**	30	**Tank Installed Date**	07/01/1995	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	928	**Spill Test Date**	08/08/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**	08/08/2022	**Tank/Piping CP Test Date**	08/08/2022	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	16000	**ATG Test Date**	08/08/2022	**Line Tightness Test Date**	08/07/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	08/08/2022			**ATG Type**	Gilbarco/EMC Basic				
Tank Number	03	**Tank Age**	30	**Tank Installed Date**	07/01/1995	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm

Tag Number	929	**Spill Test Date**	08/08/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**	08/08/2022	**Tank/Piping CP Test Date**	08/08/2022	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	16000	**ATG Test Date**	08/08/2022	**Line Tightness Test Date**	07/30/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	08/08/2022			**ATG Type**	Gilbarco/EMC Basic				
Tank Number	04	**Tank Age**	30	**Tank Installed Date**	07/01/1995	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	930	**Spill Test Date**	08/08/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Diesel, Dyed	**PLLD Test Date**	08/08/2022	**Tank/Piping CP Test Date**	08/08/2022	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	08/08/2022	**Line Tightness Test Date**	07/30/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	08/08/2022			**ATG Type**	Gilbarco/EMC Basic				
Tank Number	05	**Tank Age**	30	**Tank Installed Date**	07/01/1995	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	931	**Spill Test Date**	08/08/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**	08/08/2022	**Tank/Piping CP Test Date**	08/08/2022	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**	08/08/2022	**Line Tightness Test Date**	07/20/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	08/08/2022			**ATG Type**	Gilbarco/EMC Basic				

Facility Summary in Big Horn County in the City of Hardin

Location: L and B LAST STOP
531 E Railway St
Hardin, MT 59034-1903 Big Horn

System Facility ID:02-05856

Facility Code: 17783
Last Inspected On: 04/17/2024
Operating Permit Renewal Date: 10/13/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Gary and Lynette VanDersloot **(406) 665-3414**

Operator Contact: Lynette VanDersloot **(406) 665-3414** **laststop531@gmail.com**

Owner/Operator: Gary and Lynette VanDersloot (406) 665-3414

Lynette VanDersloot, UST Class A Operator laststop531@gmail.com

Lynette VanDersloot, UST Class B Operator laststop531@gmail.com

Tank Number	03	**Tank Age**	26	**Tank Installed Date**	01/01/1999	**Tank Material Construction**	Steel Clad	**Piping Material**	Fiberglass	**Overfill Types**	Flapper Valve
Tag Number	3915	**Spill Test Date**	04/17/2024	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	05/29/2013	**Primary Tank Leak Detection**	Manual Interstitial Monitoring	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	10/03/2024			**ATG Type**					
Tank Number	04	**Tank Age**	26	**Tank Installed Date**	01/01/1999	**Tank Material Construction**	Steel Clad	**Piping Material**	Fiberglass	**Overfill Types**	Flapper Valve
Tag Number	3916	**Spill Test Date**	04/17/2024	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	05/29/2013	**Primary Tank Leak Detection**	Manual Interstitial Monitoring	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	2000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	04/17/2024			**ATG Type**					

Facility Summary in Big Horn County in the City of Hardin

Location: LOVES TRAVEL STOP HARDIN #679
1270 N State Hwy 47
Hardin, MT 59034 Big Horn

System Facility ID:60-15284

Facility Code: 30991
Last Inspected On: 06/30/2023
Operating Permit Renewal Date: 12/04/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Loves Travel Stops and Country Stores Inc		**environmental@loves.com**
Operator Contact:	Eric Bennett;Loves Travel Stops and Country Stores Inc;Ted Parrish	**(405) 779-3768;(615) 580-9096**	**environmental@loves.com;environmental@loves.com;tparrish@mvifieldservices.com**

Owner/Operator: Loves Travel Stops and Country Stores Inc — environmental@loves.com

Eric Bennett, UST Class A Operator	environmental@loves.com
Eric Bennett, UST Class B Operator	environmental@loves.com
Ted Parrish, UST Class A Operator	tparrish@mvifieldservices.com
Ted Parrish, UST Class A Operator	tparrish@mvifieldservices.com
Ted Parrish, UST Class B Global Operator	tparrish@mvifieldservices.com
Ted Parrish, UST Class B Global Operator	tparrish@mvifieldservices.com

Tank Number	01	**Tank Age**	8	**Tank Installed Date**	05/27/2017	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm;Positive Shutoff
Tag Number	5658	**Spill Test Date**	08/08/2023	**Piping Installed Date**	10/01/2016	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	08/08/2023	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	20000	**ATG Test Date**	07/01/2023	**Line Tightness Test Date**	06/29/2023	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	Yes
		Overfill Test Date				**ATG Type**	Incon/TS-5000 EVO				
Tank Number	02	**Tank Age**	8	**Tank Installed Date**	05/27/2017	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm;Positive Shutoff
Tag Number	5659	**Spill Test Date**		**Piping Installed Date**	10/01/2016	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	11/01/2020	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No

Capacity	12000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	Yes
		Overfill Test Date				**ATG Type**	Incon/TS-5000 EVO				
Tank Number	03	**Tank Age**	8	**Tank Installed Date**	05/27/2017	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm;Positive Shutoff
Tag Number	5660	**Spill Test Date**		**Piping Installed Date**	10/01/2016	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	11/01/2020	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	Yes
		Overfill Test Date				**ATG Type**	Incon/TS-5000 EVO				
Tank Number	04	**Tank Age**	8	**Tank Installed Date**	05/27/2017	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm;Positive Shutoff
Tag Number	5661	**Spill Test Date**		**Piping Installed Date**	10/01/2016	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	11/01/2020	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	30000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	Yes
		Overfill Test Date				**ATG Type**	Incon/TS-5000 EVO				
Tank Number	05	**Tank Age**	8	**Tank Installed Date**	05/27/2017	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm;Positive Shutoff
Tag Number	5662	**Spill Test Date**		**Piping Installed Date**	10/01/2016	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	11/01/2020	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	30000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	Yes
		Overfill Test Date				**ATG Type**	Incon/TS-5000 EVO				

Tank Number	06	**Tank Age**	8	**Tank Installed Date**	05/27/2017	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm;Positive Shutoff
Tag Number	5663	**Spill Test Date**		**Piping Installed Date**	10/01/2016	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	11/01/2020	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Biodiesel, <=B20	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	20000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	Yes
		Overfill Test Date				**ATG Type**	Incon/TS-5000 EVO				
Tank Number	07	**Tank Age**	8	**Tank Installed Date**	05/27/2017	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	
Tag Number	5664	**Spill Test Date**		**Piping Installed Date**	10/01/2016	**Tank Construction**		**Piping Construction**		**AST**	No
Status	**Other**	**MLLD Test Date**		**Sump Tightness Test Date**	06/05/2017	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	DEF (Not Regulated)	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	ELLD 0.2;ELLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	20000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring;Not Listed	**Energy Act**	No
		Overfill Test Date				**ATG Type**					

Facility Summary in Big Horn County in the City of Hardin

Location: MATOVICH OIL CO INC
900 4th St W
Hardin, MT 59034 Big Horn

System Facility ID:02-13423

Facility Code: 17850
Last Inspected On: 11/22/2023
Operating Permit Renewal Date: 03/05/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Matovich Oil Co Inc	**(406) 665-1400**	**cwittmato@yahoo.com**
Operator Contact:	Jon Matovich	**(406) 665-1400**	**cwittmato@yahoo.com**

Owner/Operator: Matovich Oil Co Inc (406) 665-1400 cwittmato@yahoo.com

Jon Matovich, UST Class A Operator cwittmato@yahoo.com
Jon Matovich, UST Class A Operator cwittmato@yahoo.com
Jon Matovich, UST Class B Operator cwittmato@yahoo.com
Jon Matovich, UST Class B Operator cwittmato@yahoo.com

Tank Number	01	**Tank Age**	31	**Tank Installed Date**	05/24/1994	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	1580	**Spill Test Date**	11/22/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**	11/22/2023	**Tank/Piping CP Test Date**	11/22/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	2000	**ATG Test Date**	11/22/2023	**Line Tightness Test Date**	09/24/2020	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	11/22/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	02	**Tank Age**	31	**Tank Installed Date**	05/24/1994	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	1581	**Spill Test Date**	11/22/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**	11/22/2023	**Tank/Piping CP Test Date**	11/22/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	2000	**ATG Test Date**	11/22/2023	**Line Tightness Test Date**	09/16/2020	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	11/22/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Tank Number	03	**Tank Age**	31	**Tank Installed Date**	05/24/1994	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	1582	**Spill Test Date**	11/22/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**	11/22/2023	**Tank/Piping CP Test Date**	11/22/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	11/22/2023	**Line Tightness Test Date**	09/02/2020	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	11/22/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	04	**Tank Age**	31	**Tank Installed Date**	05/24/1994	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	1583	**Spill Test Date**	11/22/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**	11/22/2023	**Tank/Piping CP Test Date**	03/28/2024	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	11/22/2023	**Line Tightness Test Date**	09/26/2020	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	11/22/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Big Horn County in the City of Hardin

Location: TOWN AND COUNTRY SUPPLY #48
225 W Railroad St
Hardin, MT 59034 Big Horn

System Facility ID:02-01403

Facility Code: 17744
Last Inspected On: 08/29/2022
Operating Permit Renewal Date: 12/10/2025

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Town and Country Supply Association **(406) 628-6314**

Operator Contact: Wes Burley;Town and Country Supply Association **(406) 256-1020;(406) 628-6314**

Owner/Operator: Town and Country Supply Association (406) 628-6314

Connie Roundtree, UST Class B Global Operator croundtree@tandcsupply.com
Jennifer Reinhardt, UST Class B Global Operator jreinhardt@tandcsupply.com
Wes Burley, UST Class A Operator

Tank Number	S6	**Tank Age**	35	**Tank Installed Date**	06/01/1990	**Tank Material Construction**	Bare Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	
Tag Number	923	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	Yes
Status	**Currently in Use**	**MLLD Test Date**	08/08/2022	**Sump Tightness Test Date**	08/08/2022	**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Diesel, Dyed	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Deferred	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**		**Line Tightness Test Date**	08/08/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	S7	**Tank Age**	35	**Tank Installed Date**	06/01/1990	**Tank Material Construction**	Bare Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	
Tag Number	924	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	Yes
Status	**Currently in Use**	**MLLD Test Date**	08/08/2022	**Sump Tightness Test Date**	08/08/2022	**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Deferred	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**		**Line Tightness Test Date**	08/08/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	S8	**Tank Age**	35	**Tank Installed Date**	06/01/1990	**Tank Material Construction**	Bare Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	

Tag Number	925	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	Yes
Status	**Currently in Use**	**MLLD Test Date**	08/08/2022	**Sump Tightness Test Date**	08/08/2022	**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Deferred	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**		**Line Tightness Test Date**	08/08/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	S9	**Tank Age**	35	**Tank Installed Date**	06/01/1990	**Tank Material Construction**	Bare Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	
Tag Number	926	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	Yes
Status	**Temporarily Out of Use**	**MLLD Test Date**	08/20/2019	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Deferred	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**		**Line Tightness Test Date**	08/20/2019	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					

Facility Summary in Big Horn County in the City of Hardin

Location: TOWN PUMP INC HARDIN
1010 N Crawford Ave
Hardin, MT 59034-1217 Big Horn

System Facility ID:02-08703

Facility Code: 17811
Last Inspected On: 03/07/2024
Operating Permit Renewal Date: 09/08/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Hardin 1 Town Pump LLC **(406) 497-6700** **environmental@townpump.com**

Operator Contact: Trent Biggers **Trentb@townpump.com**

Owner/Operator: Hardin 1 Town Pump LLC (406) 497-6700 environmental@townpump.com

Trent Biggers, UST Class A Operator Trentb@townpump.com
Trent Biggers, UST Class A Operator Trentb@townpump.com
Trent Biggers, UST Class B Global Operator Trentb@townpump.com
Trent Biggers, UST Class B Global Operator Trentb@townpump.com

Tank Number	01	**Tank Age**	41	**Tank Installed Date**	10/01/1984	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	2377	**Spill Test Date**	06/07/2021	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**	07/20/2022	**Tank/Piping CP Test Date**	08/29/2023	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	07/20/2022	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/TLS-350				
Tank Number	02	**Tank Age**	41	**Tank Installed Date**	10/01/1984	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	2378	**Spill Test Date**	06/07/2021	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**	07/20/2022	**Tank/Piping CP Test Date**	08/29/2023	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	07/20/2022	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No

		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/TLS-350				
Tank Number	03	**Tank Age**	41	**Tank Installed Date**	10/01/1984	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	2379	**Spill Test Date**	06/07/2021	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Diesel	**PLLD Test Date**	07/20/2022	**Tank/Piping CP Test Date**	08/29/2024	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	07/20/2022	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/TLS-350				
Tank Number	04	**Tank Age**	44	**Tank Installed Date**	04/14/1981	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	2380	**Spill Test Date**	08/18/2021	**Piping Installed Date**		**Tank Construction**	Lined Interior/Impressed Current	**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Diesel	**PLLD Test Date**	07/20/2022	**Tank/Piping CP Test Date**	08/29/2023	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	07/20/2022	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/TLS-350				
Tank Number	05	**Tank Age**	48	**Tank Installed Date**	01/01/1977	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Steel	**Overfill Types**	Flapper Valve
Tag Number	2381	**Spill Test Date**	12/20/2023	**Piping Installed Date**		**Tank Construction**	Lined Interior/Impressed Current	**Piping Construction**	Single Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	08/05/2022	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**	07/20/2022	**Tank/Piping CP Test Date**	08/29/2023	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**	07/20/2022	**Line Tightness Test Date**	08/05/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/TLS-350				
Tank Number	06	**Tank Age**	25	**Tank Installed Date**	05/01/2000	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve

Tag Number	4362	**Spill Test Date**	08/18/2021	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	07/20/2022	**Tank/Piping CP Test Date**	12/05/2018	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	07/20/2022	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/TLS-350				
Tank Number	07	**Tank Age**	25	**Tank Installed Date**	05/01/2000	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve
Tag Number	4363	**Spill Test Date**	06/07/2021	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	07/20/2022	**Tank/Piping CP Test Date**	12/14/2009	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	5000	**ATG Test Date**	07/20/2022	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/TLS-350				
Tank Number	08	**Tank Age**	25	**Tank Installed Date**	05/01/2000	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	4364	**Spill Test Date**	06/07/2021	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	07/20/2022	**Tank/Piping CP Test Date**	12/14/2009	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	07/20/2022	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	08/18/2021			**ATG Type**	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Big Horn County in the City of Hardin

Location: WAGNER TRAVEL SHOPPE EXPRESS STOP
1424 N Crawford Ave
Hardin, MT 59034-1008 Big Horn

System Facility ID:02-04841

Facility Code: 17774
Last Inspected On: 07/12/2023
Operating Permit Renewal Date: 07/12/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Stockton Oil Co Billings **office@stocktonoil.com**

Operator Contact:

Owner/Operator: Stockton Oil Co Billings office@stocktonoil.com

Christopher Stockton, UST Class B Global Operator cstockton@stocktonoil.com
Joseph Stockton, UST Class B Global Operator jstockton@stocktonoil.com
Joseph Stockton, UST Class B Global Operator jstockton@stocktonoil.com
Sue Nutgens, UST Class B Operator jmcconnell@stocktonoil.com
Sue Nutgens, UST Class B Operator jmcconnell@stocktonoil.com

Tank Number	07	**Tank Age**	35	**Tank Installed Date**	01/01/1990	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve;Flapper Valve
Tag Number	2231	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Temporarily Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.1;Automatic Tank Gauging 0.2;Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**		**Line Tightness Test Date**	05/26/2011	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	08	**Tank Age**	35	**Tank Installed Date**	01/01/1990	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve;Flapper Valve
Tag Number	2232	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Temporarily Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible

Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.1;Automatic Tank Gauging 0.2;Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**		**Line Tightness Test Date**	05/26/2011	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	09	**Tank Age**	35	**Tank Installed Date**	01/01/1990	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve;Flapper Valve
Tag Number	2233	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Temporarily Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.1;Automatic Tank Gauging 0.2;Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**		**Line Tightness Test Date**	05/26/2011	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	S4	**Tank Age**	46	**Tank Installed Date**	04/03/1979	**Tank Material Construction**	Bare Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	
Tag Number	2234	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	Yes
Status	**Temporarily Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Deferred	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	14000	**ATG Test Date**		**Line Tightness Test Date**	05/26/2011	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	S5	**Tank Age**	46	**Tank Installed Date**	04/03/1979	**Tank Material Construction**	Bare Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	
Tag Number	2235	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	Yes
Status	**Temporarily Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Deferred	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No

Capacity	14000	**ATG Test Date**		**Line Tightness Test Date**	05/26/2011	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	S6	**Tank Age**	46	**Tank Installed Date**	04/03/1979	**Tank Material Construction**	Bare Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	
Tag Number	2236	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	Yes
Status	**Temporarily Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Deferred	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	14000	**ATG Test Date**		**Line Tightness Test Date**	05/26/2011	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					

Facility Summary in Big Horn County in the City of Lodge Grass

Location: FARMERS UNION OIL CO LODGE GRASS
US Hwy 87
Lodge Grass, MT 59050-0560 Big Horn

System Facility ID:02-09976

Facility Code: 17822
Last Inspected On: 03/02/2024
Operating Permit Renewal Date: 07/20/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Farmers Union Oil Co Lodge Grass

Operator Contact: Debra Edwards;Farmers Union Oil Co Lodge Grass **2FUOC@NEMONT.NET**

Owner/Operator: Farmers Union Oil Co Lodge Grass

Alvin Edwards, UST Class B Operator	alvinbedwards78@yahoo.com
Alvin Edwards, UST Class B Operator	alvinbedwards78@yahoo.com
Darin BigMedicine, UST Class B Operator	dbigmedicine@facebook.com
Darin BigMedicine, UST Class B Operator	dbigmedicine@facebook.com
Debra Edwards, UST Class A Operator	2FUOC@NEMONT.NET
Debra Edwards, UST Class A Operator	2FUOC@NEMONT.NET
Debra Edwards, UST Class B Operator	2FUOC@NEMONT.NET
Debra Edwards, UST Class B Operator	2FUOC@NEMONT.NET
Lorene Flatmouth, UST Class B Operator	
Lorene Flatmouth, UST Class B Operator	
Merla Mullenberg, UST Class B Operator	mmullenberg@hotmail.com
Merla Mullenberg, UST Class B Operator	mmullenberg@hotmail.com

Tank Number	09	**Tank Age**	27	**Tank Installed Date**	12/01/1998	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	3603	**Spill Test Date**	02/29/2024	**Piping Installed Date**	05/09/2007	**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**	05/09/2024	**Tank/Piping CP Test Date**	02/29/2024	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	05/09/2024	**Line Tightness Test Date**	03/03/2021	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	02/29/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	10	**Tank Age**	27	**Tank Installed Date**	12/01/1998	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve

Tag Number	3604	**Spill Test Date**	02/29/2024	**Piping Installed Date**	05/09/2007	**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**	05/09/2024	**Tank/Piping CP Test Date**	02/29/2024	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	05/09/2024	**Line Tightness Test Date**	03/03/2021	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	02/29/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	11	**Tank Age**	27	**Tank Installed Date**	12/01/1998	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	3605	**Spill Test Date**	02/29/2024	**Piping Installed Date**	05/09/2007	**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**	05/09/2024	**Tank/Piping CP Test Date**	02/29/2024	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	05/09/2024	**Line Tightness Test Date**	03/03/2021	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	02/29/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Big Horn County in the City of Lodge Grass

Location: LODGE GRASS SCHOOL DIST 27
124 N George St
Lodge Grass, MT 59050 Big Horn

System Facility ID:02-10772

Facility Code: 17826
Last Inspected On: 03/15/2024
Operating Permit Renewal Date: 03/15/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: School Dist 27 Lodge Grass **(406) 639-2304**

Operator Contact:

Owner/Operator: School Dist 27 Lodge Grass (406) 639-2304

Donald Gardner, UST Class B Global Operator donald.gardner@lodgegrass.k12.mt.us
Leroy Wallace, UST Class B Operator
Steve Amyotte, UST Class B Operator steve.amyotte@lodgegrass.k12.mt.us

Tank Number	02	**Tank Age**	40	**Tank Installed Date**	04/04/1985	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	4361	**Spill Test Date**		**Piping Installed Date**	10/20/2006	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Temporarily Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	10/17/2011	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Deferred	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date				**ATG Type**	Veeder Root/TLS-300				

Facility Summary in Big Horn County in the City of Lodge Grass

Location: OUR LADY OF LORETTO CHURCH
Harding Ave & Helen St
Lodge Grass, MT 59050 Big Horn

System Facility ID:02-09970

Facility Code: 17821
Last Inspected On: 11/03/2023
Operating Permit Renewal Date: 02/11/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Our Lady of Loretto Church **(312) 995-0702**

Operator Contact: Michael Dorn;Tien Dinh **brmikedorn@gmail.com;tientxd@gmail.com**

Owner/Operator: Our Lady of Loretto Church (312) 995-0702

Michael Dorn, UST Class A Operator	brmikedorn@gmail.com
Michael Dorn, UST Class B Operator	brmikedorn@gmail.com
Tien Dinh, UST Class A Operator	tientxd@gmail.com
Tien Dinh, UST Class B Operator	tientxd@gmail.com

Tank Number	S2	**Tank Age**	35	**Tank Installed Date**	07/23/1990	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Copper	**Overfill Types**	High Level Alarm
Tag Number	1778	**Spill Test Date**	11/03/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	PVC	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	U.S. Suction	**CP Met Types**	Galvanic
Product	Heating Oil	**PLLD Test Date**		**Tank/Piping CP Test Date**	11/03/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	3-Year Line Tightness Test	**Vapor Recovery**	No
Capacity	3000	**ATG Test Date**	11/03/2023	**Line Tightness Test Date**	11/03/2023	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	11/03/2023			**ATG Type**	Gilbarco/EMC Basic				

Facility Summary in Big Horn County in the City of Pryor

Location: PLENTY COUPS HIGH SCHOOL
1 High School Ln
Pryor, MT 59066-0229 Big Horn

System Facility ID:02-01131

Facility Code: 17735
Last Inspected On: 07/03/2024
Operating Permit Renewal Date: 08/26/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Plenty Coups High School **(406) 259-7329**

Operator Contact: Craig Cliff;Plenty Coups High School **(406) 422-7289;(406) 259-7329** **craigcliff@pryorstaff.org**

Owner/Operator: Plenty Coups High School (406) 259-7329

Craig Cliff, UST Class A Operator craigcliff@pryorstaff.org
Craig Cliff, UST Class B Operator craigcliff@pryorstaff.org

Tank Number	05	**Tank Age**	27	**Tank Installed Date**	06/01/1998	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	1824	**Spill Test Date**	07/03/2024	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	07/02/2024	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	1000	**ATG Test Date**	01/24/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	07/03/2024			**ATG Type**	Veeder Root/TLS-300				
Tank Number	06	**Tank Age**	27	**Tank Installed Date**	06/01/1998	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	1825	**Spill Test Date**	07/03/2024	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	07/02/2024	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	2000	**ATG Test Date**	01/24/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	07/03/2024			**ATG Type**	Veeder Root/TLS-300				

Facility Summary in Big Horn County in the City of Pryor

Location: PRYOR SELF SERVICE
704 Mak Pua Ave
Pryor, MT 59066 Big Horn

System Facility ID:02-10164

Facility Code: 17823
Last Inspected On: 02/10/2023
Operating Permit Renewal Date: 05/16/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: William Hoffman

Operator Contact: William Hoffman

Owner/Operator: William Hoffman

William Hoffman, UST Class A Operator

William Hoffman, UST Class B Global Operator

Tank Number	03	**Tank Age**	27	**Tank Installed Date**	10/01/1998	**Tank Material Construction**	Steel Clad	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	1389	**Spill Test Date**	02/10/2023	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	02/04/2011	**Primary Tank Leak Detection**	Manual Interstitial Monitoring	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	2000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	02/10/2023			**ATG Type**					

Facility Summary in Big Horn County in the City of Pryor

Location: SAINT CHARLES MISSION
29 Pryor Gap Rd
Pryor, MT 59066 Big Horn

System Facility ID:56-04505

Facility Code: 29917
Last Inspected On: 05/09/2024
Operating Permit Renewal Date: 10/09/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	St Labre Indian School	**(406) 784-4994**	**STLMAINTINV@STLABRE.ORG**
Operator Contact:	Dana Davis;Leney Mcnac		**ddavis@stlabre.org;lmcnac@stlabre.org**

Owner/Operator: St Labre Indian School (406) 784-4994 STLMAINTINV@STLABRE.ORG

Dana Davis, UST Class A Operator	ddavis@stlabre.org
Dana Davis, UST Class B Global Operator	ddavis@stlabre.org
Leney Mcnac, UST Class A Operator	lmcnac@stlabre.org
Leney Mcnac, UST Class B Global Operator	lmcnac@stlabre.org

Tank Number	02	**Tank Age**	35	**Tank Installed Date**	08/20/1990	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Steel	**Overfill Types**	Flapper Valve
Tag Number	1958	**Spill Test Date**	05/09/2024	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	05/09/2024	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	1000	**ATG Test Date**	05/09/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	05/09/2024			**ATG Type**	Gilbarco/EMC Basic				

Facility Summary in Big Horn County in the City of Saint Xavier

Location: PRETTY EAGLE SCHOOL
1 mi W of St Xavier
Saint Xavier, MT 59075-0257 Big Horn

System Facility ID:02-04504

Facility Code: 17768
Last Inspected On: 05/09/2024
Operating Permit Renewal Date: 10/09/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: St Labre Indian School **(406) 784-4994** **STLMAINTINV@STLABRE.ORG**

Operator Contact: Dana Davis;Leney Mcnac **ddavis@stlabre.org;lmcnac@stlabre.org**

Owner/Operator: St Labre Indian School (406) 784-4994 STLMAINTINV@STLABRE.ORG

Dana Davis, UST Class A Operator ddavis@stlabre.org
Dana Davis, UST Class B Global Operator ddavis@stlabre.org
Leney Mcnac, UST Class A Operator lmcnac@stlabre.org
Leney Mcnac, UST Class B Global Operator lmcnac@stlabre.org

Tank Number	03	**Tank Age**	35	**Tank Installed Date**	04/01/1990	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	1956	**Spill Test Date**	07/17/2024	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	05/09/2024	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	1000	**ATG Test Date**	05/09/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	05/09/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350				
Tank Number	S4	**Tank Age**	35	**Tank Installed Date**	04/01/1990	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	3672	**Spill Test Date**	06/17/2021	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Temporarily Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Continuous Interstitial Monitoring	**Piping Type**	U.S. Suction	**CP Met Types**	Galvanic
Product	Heating Oil	**PLLD Test Date**		**Tank/Piping CP Test Date**	05/09/2024	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring;MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	06/17/2021	**Line Tightness Test Date**	11/05/2013	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No

		Overfill Test Date	06/17/2021			**ATG Type**	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Big Horn County in the City of Wyola

Location: WYOLA ELEMENTARY SCHOOL
1 Mondell Ave
Wyola, MT 59089 Big Horn

System Facility ID:02-13762

Facility Code: 17853
Last Inspected On: 05/02/2025
Operating Permit Renewal Date: 07/12/2028

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: School Dist 29 Wyola **(406) 343-2722**

Operator Contact: Bradford Crooked Arm **bradfordcrookedarm@gmail.com**

Owner/Operator: School Dist 29 Wyola (406) 343-2722

Bradford Crooked Arm, UST Class A Operator bradfordcrookedarm@gmail.com

Bradford Crooked Arm, UST Class B Global Operator bradfordcrookedarm@gmail.com

Tank Number	02	**Tank Age**	26	**Tank Installed Date**	07/01/1999	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Steel	**Overfill Types**	Flapper Valve
Tag Number	4370	**Spill Test Date**	05/02/2025	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	05/02/2025	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	1000	**ATG Test Date**	05/02/2025	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	05/02/2025			**ATG Type**	Veeder Root/TLS-300				

Facility Summary in Blaine County in the City of Chinook

Location: CHS BIG SKY CHINOOK
135 1st St
Chinook, MT 59523 Blaine

System Facility ID:03-10274

Facility Code: 17941
Last Inspected On: 04/30/2025
Operating Permit Renewal Date: 05/07/2028

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	CHS Inc Inver Grove Heights	**(651) 355-6343**	**Kirsten.Tindall@chsinc.com**
Operator Contact:	Saige Matteson	**(406) 599-1715**	**saige.matteson@chsinc.com**

Owner/Operator: CHS Inc Inver Grove Heights (651) 355-6343 Kirsten.Tindall@chsinc.com

Don Cornell, UST Class B Operator
Don Cornell, UST Class B Operator
Saige Matteson, UST Class A Operator saige.matteson@chsinc.com
Saige Matteson, UST Class B Operator jim.alford@chsinc.com

Tank Number	11	**Tank Age**	30	**Tank Installed Date**	04/01/1995	**Tank Material Construction**	Steel Clad	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	962	**Spill Test Date**	04/30/2025	**Piping Installed Date**	03/09/2013	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	04/30/2025	**Catastrophic L.D. Type 3.0**	Continuous Interstitial Monitoring;Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	04/30/2025	**Tank/Piping CP Test Date**	12/18/2012	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	04/29/2025	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	04/29/2025			**ATG Type**	Gilbarco-Veeder Root/TLS-450				
Tank Number	12	**Tank Age**	30	**Tank Installed Date**	04/01/1995	**Tank Material Construction**	Steel Clad	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	963	**Spill Test Date**	04/30/2025	**Piping Installed Date**	03/09/2013	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	04/30/2025	**Catastrophic L.D. Type 3.0**	Continuous Interstitial Monitoring;Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible

Product	Gasoline	**PLLD Test Date**	04/30/2025	**Tank/Piping CP Test Date**	12/18/2012	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	04/29/2025	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	04/29/2025			**ATG Type**	Gilbarco-Veeder Root/TLS-450				
Tank Number	13	**Tank Age**	30	**Tank Installed Date**	04/01/1995	**Tank Material Construction**	Steel Clad	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	964	**Spill Test Date**	04/30/2025	**Piping Installed Date**	03/09/2013	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	04/30/2025	**Catastrophic L.D. Type 3.0**	Continuous Interstitial Monitoring;Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	04/30/2025	**Tank/Piping CP Test Date**	12/18/2012	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	20000	**ATG Test Date**	04/29/2025	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	04/29/2025			**ATG Type**	Gilbarco-Veeder Root/TLS-450				
Tank Number	14	**Tank Age**	30	**Tank Installed Date**	04/01/1995	**Tank Material Construction**	Steel Clad	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	965	**Spill Test Date**	04/30/2025	**Piping Installed Date**	03/09/2013	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	04/30/2025	**Catastrophic L.D. Type 3.0**	Continuous Interstitial Monitoring;Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	04/30/2025	**Tank/Piping CP Test Date**	12/18/2012	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	04/29/2025	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	04/29/2025			**ATG Type**	Gilbarco-Veeder Root/TLS-450				
Tank Number	15	**Tank Age**	30	**Tank Installed Date**	04/01/1995	**Tank Material Construction**	Steel Clad	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	966	**Spill Test Date**	04/30/2025	**Piping Installed Date**	03/09/2013	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No

Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	04/30/2025	**Catastrophic L.D. Type 3.0**	Continuous Interstitial Monitoring;Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	04/30/2025	**Tank/Piping CP Test Date**	12/18/2012	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	04/29/2025	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	04/29/2025			**ATG Type**	Gilbarco-Veeder Root/TLS-450				
Tank Number	16	**Tank Age**	30	**Tank Installed Date**	04/01/1995	**Tank Material Construction**	Steel Clad	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	967	**Spill Test Date**	04/30/2025	**Piping Installed Date**	03/09/2013	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	04/30/2025	**Catastrophic L.D. Type 3.0**	Continuous Interstitial Monitoring;Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	04/30/2025	**Tank/Piping CP Test Date**	12/18/2012	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	04/29/2025	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	04/29/2025			**ATG Type**	Gilbarco-Veeder Root/TLS-450				
Tank Number	17	**Tank Age**	30	**Tank Installed Date**	04/01/1995	**Tank Material Construction**	Steel Clad	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	968	**Spill Test Date**	04/30/2025	**Piping Installed Date**	03/09/2013	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	04/30/2025	**Catastrophic L.D. Type 3.0**	Continuous Interstitial Monitoring;Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	04/30/2025	**Tank/Piping CP Test Date**	12/18/2012	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	04/29/2025	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date	04/29/2025			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Blaine County in the City of Chinook

Location: EZZIES WHOLESALE INC CHINOOK
40450 US Hwy 2
Chinook, MT 59523 Blaine

System Facility ID:03-07801

Facility Code: 17922
Last Inspected On: 05/14/2024
Operating Permit Renewal Date: 10/30/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Ezzies Wholesale Inc **bill@ezzies.com**

Operator Contact: Conor Moran;Ezzies Wholesale Inc **conor@ezzies.com;bill@ezzies.com**

Owner/Operator: Ezzies Wholesale Inc bill@ezzies.com

Conor Moran, UST Class A Operator bill@ezzies.com
Durwin Williams, UST Class B Operator durwinhwilliams@yahoo.com
Durwin Williams, UST Class B Operator durwinhwilliams@yahoo.com

Tank Number	06	**Tank Age**	13	**Tank Installed Date**	05/01/2012	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	5332	**Spill Test Date**	05/14/2024	**Piping Installed Date**	09/22/2011	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	05/14/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	05/14/2024	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	05/14/2024	**Line Tightness Test Date**	04/10/2021	**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	05/14/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350;Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	07	**Tank Age**	13	**Tank Installed Date**	05/01/2012	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	5333	**Spill Test Date**	05/14/2024	**Piping Installed Date**	09/22/2011	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	05/14/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	05/14/2024	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	5000	**ATG Test Date**	05/14/2024	**Line Tightness Test Date**	04/06/2021	**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes

		Overfill Test Date	05/14/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350;Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	08	**Tank Age**	13	**Tank Installed Date**	05/01/2012	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	5334	**Spill Test Date**	05/14/2024	**Piping Installed Date**	09/22/2011	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	05/14/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	05/14/2024	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	05/14/2024	**Line Tightness Test Date**	01/14/2021	**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	05/14/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350;Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	09	**Tank Age**	13	**Tank Installed Date**	05/01/2012	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	5335	**Spill Test Date**	05/14/2024	**Piping Installed Date**	09/22/2011	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	05/14/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	05/14/2024	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	5000	**ATG Test Date**	05/14/2024	**Line Tightness Test Date**	01/14/2021	**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	05/14/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350;Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	10	**Tank Age**	13	**Tank Installed Date**	05/01/2012	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	5336	**Spill Test Date**	05/14/2024	**Piping Installed Date**	09/22/2011	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	05/14/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	05/14/2024	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	15000	**ATG Test Date**	05/14/2024	**Line Tightness Test Date**	01/20/2021	**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes

		Overfill Test Date	05/14/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350;Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	11	**Tank Age**	13	**Tank Installed Date**	05/01/2012	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	5337	**Spill Test Date**	05/14/2024	**Piping Installed Date**	09/22/2011	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	05/14/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	05/14/2024	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	15000	**ATG Test Date**	05/14/2024	**Line Tightness Test Date**	02/15/2021	**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	05/14/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350;Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Blaine County in the City of Chinook

Location: TOWN PUMP CHINOOK
108 New York St
Chinook, MT 59523 Blaine

System Facility ID:03-08688

Facility Code: 17932
Last Inspected On: 02/27/2024
Operating Permit Renewal Date: 08/06/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Chinook 1 Town Pump LLC	**(406) 497-6700**	**environmental@townpump.com**
Operator Contact:	Trent Biggers		**Trentb@townpump.com**

Owner/Operator:	Chinook 1 Town Pump LLC	(406) 497-6700	environmental@townpump.com
	Trent Biggers, UST Class A Operator		Trentb@townpump.com
	Trent Biggers, UST Class A Operator		Trentb@townpump.com
	Trent Biggers, UST Class B Global Operator		Trentb@townpump.com
	Trent Biggers, UST Class B Global Operator		Trentb@townpump.com

Tank Number	06	**Tank Age**	32	**Tank Installed Date**	01/01/1993	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve;Flapper Valve
Tag Number	2382	**Spill Test Date**	07/26/2023	**Piping Installed Date**	10/03/2012	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	07/26/2023	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	07/26/2023	**Tank/Piping CP Test Date**	11/28/2012	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	02/27/2024	**Line Tightness Test Date**	11/03/2006	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	No
		Overfill Test Date	07/26/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350				
Tank Number	08	**Tank Age**	32	**Tank Installed Date**	01/01/1993	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve;Flapper Valve
Tag Number	2384	**Spill Test Date**	07/26/2023	**Piping Installed Date**	02/10/2020	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	07/26/2023	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	02/27/2024	**Tank/Piping CP Test Date**	11/28/2012	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	02/27/2024	**Line Tightness Test Date**	11/03/2006	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	No
		Overfill Test Date	07/26/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350				

Tank Number	09	**Tank Age**	32	**Tank Installed Date**	01/01/1993	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve;Flapper Valve
Tag Number	2385	**Spill Test Date**	07/26/2023	**Piping Installed Date**	02/10/2020	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	07/26/2023	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	02/27/2024	**Tank/Piping CP Test Date**	11/28/2012	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	02/27/2024	**Line Tightness Test Date**	11/03/2006	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	No
		Overfill Test Date	07/26/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350				
Tank Number	10	**Tank Age**	24	**Tank Installed Date**	06/01/2001	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve
Tag Number	4354	**Spill Test Date**	07/26/2023	**Piping Installed Date**	10/03/2012	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	07/26/2023	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel, Dyed	**PLLD Test Date**	02/27/2024	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	02/27/2024	**Line Tightness Test Date**	11/05/2006	**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	No
		Overfill Test Date	07/26/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350				
Tank Number	11	**Tank Age**	24	**Tank Installed Date**	06/01/2001	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve
Tag Number	4355	**Spill Test Date**	07/26/2023	**Piping Installed Date**	10/03/2012	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	07/26/2023	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	02/27/2024	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	5000	**ATG Test Date**	02/27/2024	**Line Tightness Test Date**	11/05/2006	**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	No
		Overfill Test Date	07/26/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350				
Tank Number	07	**Tank Age**	32	**Tank Installed Date**	01/01/1993	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve;Flapper Valve
Tag Number	4462	**Spill Test Date**	07/26/2023	**Piping Installed Date**	02/10/2020	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	07/26/2023	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible

Product	Diesel	**PLLD Test Date**	02/26/2024	**Tank/Piping CP Test Date**	11/28/2012	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	02/26/2024	**Line Tightness Test Date**	11/03/2006	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	No
		Overfill Test Date	07/26/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350				
Tank Number	12	**Tank Age**	0	**Tank Installed Date**		**Tank Material Construction**	Unknown	**Piping Material**	Unknown	**Overfill Types**	
Tag Number	5417	**Spill Test Date**		**Piping Installed Date**	10/03/2012	**Tank Construction**		**Piping Construction**		**AST**	No
Status	**Other**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**		**Piping Type**	Not Listed	**CP Met Types**	
Product	DEF (Not Regulated)	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Not Listed	**Primary Pipe Leak Detection**	Not Listed	**Vapor Recovery**	No
Capacity	5000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Not Listed	**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	13	**Tank Age**	5	**Tank Installed Date**	02/10/2020	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	5914	**Spill Test Date**	07/26/2023	**Piping Installed Date**	02/10/2020	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	07/26/2023	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	02/27/2024	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	Yes
Capacity	6000	**ATG Test Date**	02/27/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Statistical Inventory Reconciliation	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	Yes
		Overfill Test Date	07/26/2023			**ATG Type**					

Facility Summary in Blaine County in the City of Harlem

Location: E Z MART
42485 US Hwy 2
Harlem, MT 59526 Blaine

System Facility ID:03-05982

Facility Code: 17896
Last Inspected On: 03/17/2025
Operating Permit Renewal Date: 07/09/2028

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: E Z Mart **(406) 353-2335**

Operator Contact: Conor Moran;Ezzies Wholesale Inc **conor@ezzies.com;bill@ezzies.com**

Owner/Operator: E Z Mart (406) 353-2335

Bobby Dolphay, UST Class B Operator	harlem@ezzies.com
Conor Moran, UST Class A Operator	bill@ezzies.com
Deb Newman, UST Class B Operator	dnewman353@yahoo.com
Douglas McCracken, UST Class B Operator	flatland@ttc-cmc.net
Lorna Chavez, UST Class B Global Operator	lornachavez3@gmail.com

Tank Number	04	**Tank Age**	32	**Tank Installed Date**	08/01/1993	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	3265	**Spill Test Date**	05/14/2024	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	03/17/2025	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**	05/14/2024	**Tank/Piping CP Test Date**	03/17/2025	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	05/14/2024	**Line Tightness Test Date**	10/11/2021	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	05/14/2024			**ATG Type**	Gilbarco/EMC Basic				
Tank Number	05	**Tank Age**	32	**Tank Installed Date**	08/01/1993	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	3266	**Spill Test Date**	05/14/2024	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	03/17/2025	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**	05/14/2024	**Tank/Piping CP Test Date**	03/17/2025	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	05/14/2024	**Line Tightness Test Date**	01/21/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No

		Overfill Test Date	05/14/2024			**ATG Type**	Gilbarco/EMC Basic				
Tank Number	06	**Tank Age**	32	**Tank Installed Date**	08/01/1993	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	3267	**Spill Test Date**	05/14/2024	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	03/17/2025	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**	05/14/2024	**Tank/Piping CP Test Date**	03/17/2025	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	05/14/2024	**Line Tightness Test Date**	01/21/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	05/14/2024			**ATG Type**	Gilbarco/EMC Basic				
Tank Number	07	**Tank Age**	32	**Tank Installed Date**	08/01/1993	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	3268	**Spill Test Date**	05/14/2024	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	03/17/2025	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Diesel, Dyed	**PLLD Test Date**	05/14/2024	**Tank/Piping CP Test Date**	03/17/2025	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	05/14/2024	**Line Tightness Test Date**	01/21/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	05/14/2024			**ATG Type**	Gilbarco/EMC Basic				
Tank Number	08	**Tank Age**	32	**Tank Installed Date**	08/01/1993	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	3269	**Spill Test Date**	08/17/2021	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	03/17/2025	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**	05/14/2024	**Tank/Piping CP Test Date**	03/17/2025	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	05/14/2024	**Line Tightness Test Date**	01/21/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	05/14/2024			**ATG Type**	Gilbarco/EMC Basic				

Facility Summary in Blaine County in the City of Harlem

Location: LITTLE RIVER TRADING POST
148 Assiniboine Ave
Harlem, MT 59526 Blaine

System Facility ID:03-09729

Facility Code: 17939
Last Inspected On: 01/31/2024
Operating Permit Renewal Date: 03/10/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Fort Belknap Indian Community	**(406) 353-2205**	**ksnow@ftbelknap.org**
Operator Contact:	Cassandra Longtimesleeping;Little River Trading Post LLC;Eddie Moore;Little River Trading Post LLC;Kermit Snow;Fort Belknap Indian Community;Leslie Cochran;Little River Trading Post LLC	**(406) 301-1221;(406) 353-2205**	**cassandra.longtimesleeping@littlerivertp.com;eddie.moore@islandmtn.com;eddie.moore@islandmtn.com;eddie.moore@islandmtn.com;ksnow@ftbelknap.org;ksnow@ftbelknap.org;lespitkanen@gmail.com;eddie.moore@islandmtn.com**
Owner/Operator:	Fort Belknap Indian Community	(406) 353-2205	ksnow@ftbelknap.org
	Amelia Main, UST Class B Operator		eddie.moore@islandmtn.com
	Cassandra Longtimesleeping, UST Class A Operator		eddie.moore@islandmtn.com
	Eddie Moore, UST Class A Operator		eddie.moore@islandmtn.com
	Eddie Moore, UST Class B Operator		eddie.moore@islandmtn.com
	Josephine Longknife, UST Class B Operator		eddie.moore@islandmtn.com
	Kermit Snow, UST Class A Operator		ksnow@ftbelknap.org
	Kermit Snow, UST Class B Operator		ksnow@ftbelknap.org
	Leslie Cochran, UST Class A Operator		eddie.moore@islandmtn.com

Tank Number	01	**Tank Age**	37	**Tank Installed Date**	08/02/1988	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	3820	**Spill Test Date**	01/31/2024	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**	01/31/2024	**Tank/Piping CP Test Date**	08/08/2024	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	01/31/2024	**Line Tightness Test Date**	07/06/2020	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	01/31/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	02	**Tank Age**	37	**Tank Installed Date**	08/02/1988	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	3821	**Spill Test Date**	01/31/2024	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic

Product	Gasoline	**PLLD Test Date**	01/31/2024	**Tank/Piping CP Test Date**	08/08/2024	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	01/31/2024	**Line Tightness Test Date**	07/04/2020	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	01/31/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	03	**Tank Age**	37	**Tank Installed Date**	08/02/1988	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	3822	**Spill Test Date**	01/31/2024	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**	01/31/2024	**Tank/Piping CP Test Date**	08/08/2024	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**	01/31/2024	**Line Tightness Test Date**	07/04/2020	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	01/31/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	04	**Tank Age**	37	**Tank Installed Date**	08/02/1988	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	3823	**Spill Test Date**	01/31/2024	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**	01/31/2024	**Tank/Piping CP Test Date**	08/08/2024	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	01/31/2024	**Line Tightness Test Date**	07/06/2020	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	01/31/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Blaine County in the City of Turner

Location: CHS BIG SKY TURNER
US Hwy 241
Turner, MT 59542 Blaine

System Facility ID:56-13805

Facility Code: 30492
Last Inspected On: 06/15/2023
Operating Permit Renewal Date: 06/21/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	CHS Inc Inver Grove Heights	**(651) 355-6343**	**Kirsten.Tindall@chsinc.com**
Operator Contact:	Nick Ramberg;Steve Kleinjan	**(406) 357-2280**	**nick.ramberg@chsinc.com;steven.kleinjan@chsinc.com**

Owner/Operator: CHS Inc Inver Grove Heights (651) 355-6343 Kirsten.Tindall@chsinc.com

Don Cornell, UST Class B Operator	
Nick Ramberg, UST Class A Operator	nick.ramberg@chsinc.com
Nick Ramberg, UST Class B Global Operator	nick.ramberg@chsinc.com
Steve Kleinjan, UST Class A Operator	steven.kleinjan@chsinc.com
Steve Kleinjan, UST Class B Global Operator	steven.kleinjan@chsinc.com
Steve Kleinjan, UST Class B Operator	steven.kleinjan@chsinc.com

Tank Number	S5	**Tank Age**	28	**Tank Installed Date**	08/14/1997	**Tank Material Construction**	Unknown	**Piping Material**	Flexible Plastic	**Overfill Types**	
Tag Number	3606	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	Yes
Status	**Currently in Use**	**MLLD Test Date**	03/19/2020	**Sump Tightness Test Date**	05/05/2017	**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Not Listed	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**		**Line Tightness Test Date**	03/19/2020	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	S6	**Tank Age**	28	**Tank Installed Date**	08/14/1997	**Tank Material Construction**	Unknown	**Piping Material**	Flexible Plastic	**Overfill Types**	
Tag Number	3607	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	Yes
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	05/05/2017	**Catastrophic L.D. Type 3.0**	Continuous Interstitial Monitoring	**Piping Type**	Pressurized	**CP Met Types**	
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Not Listed	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No

Capacity	6000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	S1	**Tank Age**	28	**Tank Installed Date**	08/14/1997	**Tank Material Construction**	Unknown	**Piping Material**	Flexible Plastic	**Overfill Types**	
Tag Number	969	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	Yes
Status	**Currently in Use**	**MLLD Test Date**	03/19/2020	**Sump Tightness Test Date**	05/05/2017	**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Not Listed	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**		**Line Tightness Test Date**	03/19/2020	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	S2	**Tank Age**	28	**Tank Installed Date**	08/14/1997	**Tank Material Construction**	Unknown	**Piping Material**	Flexible Plastic	**Overfill Types**	
Tag Number	970	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	Yes
Status	**Currently in Use**	**MLLD Test Date**	03/19/2020	**Sump Tightness Test Date**	05/05/2017	**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**		**Line Tightness Test Date**	03/19/2020	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	S3	**Tank Age**	28	**Tank Installed Date**	08/14/1997	**Tank Material Construction**	Unknown	**Piping Material**	Flexible Plastic	**Overfill Types**	
Tag Number	971	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	Yes
Status	**Currently in Use**	**MLLD Test Date**	03/19/2020	**Sump Tightness Test Date**	05/05/2017	**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**		**Line Tightness Test Date**	03/19/2020	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	S4	**Tank Age**	28	**Tank Installed Date**	08/14/1997	**Tank Material Construction**	Unknown	**Piping Material**	Flexible Plastic	**Overfill Types**	
Tag Number	972	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	Yes

Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	05/05/2017	**Catastrophic L.D. Type 3.0**	Continuous Interstitial Monitoring	**Piping Type**	Pressurized	**CP Met Types**	
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Not Listed	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					

Facility Summary in Blaine County in the City of Turner

Location: EZZIES TURNER BULK PLANT
30153 Turner Road
Turner, MT 59542 Blaine

System Facility ID:60-15345

Facility Code: 32423
Last Inspected On: 01/23/2024
Operating Permit Renewal Date: 04/25/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Ezzies Wholesale Inc **bill@ezzies.com**

Operator Contact: Conor Moran;Ezzies Wholesale Inc **conor@ezzies.com;bill@ezzies.com**

Owner/Operator: Ezzies Wholesale Inc bill@ezzies.com

Conor Moran, UST Class A Operator bill@ezzies.com

David Jones, UST Class B Operator ezziesturner@gmail.com

Tank Number	1	**Tank Age**	5	**Tank Installed Date**	09/01/2020	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	5972	**Spill Test Date**	01/23/2024	**Piping Installed Date**	09/01/2020	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	01/23/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	Yes
Capacity	8000	**ATG Test Date**	09/05/2023	**Line Tightness Test Date**	02/07/2021	**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	04/02/2024			**ATG Type**					
Tank Number	2	**Tank Age**	5	**Tank Installed Date**	09/01/2020	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	5973	**Spill Test Date**	01/23/2024	**Piping Installed Date**	09/01/2020	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	01/23/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	Yes
Capacity	4000	**ATG Test Date**	09/05/2023	**Line Tightness Test Date**	02/06/2021	**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	04/02/2024			**ATG Type**					
Tank Number	3	**Tank Age**	5	**Tank Installed Date**	09/01/2020	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm

Tag Number	5974	**Spill Test Date**	01/23/2024	**Piping Installed Date**	09/01/2020	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	01/23/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	09/05/2023	**Line Tightness Test Date**	02/04/2021	**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	01/23/2024			**ATG Type**					
Tank Number	4	**Tank Age**	5	**Tank Installed Date**	09/21/2020	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	5975	**Spill Test Date**	01/23/2024	**Piping Installed Date**	09/01/2020	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	01/23/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	09/05/2023	**Line Tightness Test Date**	02/05/2021	**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	04/02/2024			**ATG Type**					
Tank Number	5	**Tank Age**	5	**Tank Installed Date**	09/01/2020	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	5976	**Spill Test Date**	01/23/2024	**Piping Installed Date**	09/01/2020	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	01/23/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	09/05/2023	**Line Tightness Test Date**	02/02/2021	**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	04/02/2024			**ATG Type**					
Tank Number	6	**Tank Age**	5	**Tank Installed Date**	09/01/2020	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	5977	**Spill Test Date**	01/23/2024	**Piping Installed Date**	09/01/2020	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	01/23/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No

Capacity	4000	**ATG Test Date**	09/05/2023	**Line Tightness Test Date**	02/03/2021	**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	04/02/2024			**ATG Type**					

Facility Summary in Broadwater County in the City of Townsend

Location: ROCKY MOUNTAIN SUPPLY
7847 US Highway 287
Townsend, MT 59644 Broadwater

System Facility ID:60-15352

Facility Code: 32438
Last Inspected On: 09/08/2022
Operating Permit Renewal Date: 11/14/2025

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Rocky Mountain Supply Inc	**(406) 388-4009**	**billballiet@rmsi.coop**
Operator Contact:	Jason Rorabaugh;Rocky Mountain Supply Inc Belgrade	**(406) 388-6116**	**jasonrorabaugh@rmsi.coop**

Owner/Operator: Rocky Mountain Supply Inc (406) 388-4009 billballiet@rmsi.coop

Desirae Bandy, UST Class B Operator billballiet@rmsi.coop

Jason Rorabaugh, UST Class A Operator jasonrorabaugh@rmsi.coop

Tank Number	1	**Tank Age**	3	**Tank Installed Date**	04/25/2022	**Tank Material Construction**	Steel Clad	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	6021	**Spill Test Date**	05/04/2022	**Piping Installed Date**	04/25/2022	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	05/03/2022	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	Yes
Capacity	20000	**ATG Test Date**	09/15/2022	**Line Tightness Test Date**	05/09/2022	**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	05/03/2022			**ATG Type**					
Tank Number	2	**Tank Age**	3	**Tank Installed Date**	04/25/2022	**Tank Material Construction**	Steel Clad	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	6022	**Spill Test Date**	06/05/2023	**Piping Installed Date**	04/25/2022	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	05/03/2022	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	20000	**ATG Test Date**	09/15/2022	**Line Tightness Test Date**	05/09/2022	**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	05/03/2022			**ATG Type**					
Tank Number	3	**Tank Age**	3	**Tank Installed Date**	04/25/2022	**Tank Material Construction**	Steel Clad	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm

Tag Number	6023	**Spill Test Date**	05/04/2022	**Piping Installed Date**	04/25/2022	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	05/03/2022	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	Yes
Capacity	8000	**ATG Test Date**	09/15/2022	**Line Tightness Test Date**	05/09/2022	**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	05/03/2022			**ATG Type**					
Tank Number	4	**Tank Age**	3	**Tank Installed Date**	04/25/2022	**Tank Material Construction**	Steel Clad	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	6024	**Spill Test Date**	05/04/2022	**Piping Installed Date**	04/25/2022	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	05/03/2022	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	Yes
Capacity	6000	**ATG Test Date**	09/15/2022	**Line Tightness Test Date**	05/09/2022	**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	05/03/2022			**ATG Type**					
Tank Number	5	**Tank Age**	3	**Tank Installed Date**	04/25/2022	**Tank Material Construction**	Steel Clad	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	6025	**Spill Test Date**	05/04/2022	**Piping Installed Date**	04/25/2022	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	09/15/2022	**Line Tightness Test Date**	05/09/2022	**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	05/03/2022			**ATG Type**					
Tank Number	6	**Tank Age**	3	**Tank Installed Date**	04/25/2022	**Tank Material Construction**	Steel Clad	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	6026	**Spill Test Date**	05/04/2022	**Piping Installed Date**	04/25/2022	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	05/03/2022	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No

Capacity	6000	**ATG Test Date**	09/15/2022	**Line Tightness Test Date**	05/09/2022	**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	05/03/2022			**ATG Type**					
Tank Number	7	**Tank Age**	3	**Tank Installed Date**	04/25/2022	**Tank Material Construction**	Steel Clad	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	6027	**Spill Test Date**	05/04/2022	**Piping Installed Date**	04/25/2022	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	05/03/2022	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	09/15/2022	**Line Tightness Test Date**	05/09/2022	**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	05/03/2022			**ATG Type**					
Tank Number	8	**Tank Age**	3	**Tank Installed Date**	04/25/2022	**Tank Material Construction**	Steel Clad	**Piping Material**	Flexible Plastic	**Overfill Types**	
Tag Number	6028	**Spill Test Date**	05/04/2022	**Piping Installed Date**	04/25/2022	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Other**	**MLLD Test Date**		**Sump Tightness Test Date**	05/03/2022	**Catastrophic L.D. Type 3.0**		**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	DEF (Not Regulated)	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	05/03/2022			**ATG Type**					

Facility Summary in Broadwater County in the City of Townsend

Location: ROCKY MOUNTAIN SUPPLY INC TOWNSEND - closed
310 S Front St
Townsend, MT 59644-2518 Broadwater

System Facility ID:04-07862

Facility Code: 18051
Last Inspected On: 01/31/2022
Operating Permit Renewal Date: 10/15/2022

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Rocky Mountain Supply Inc	**(406) 388-4009**	**billballiet@rmsi.coop**
Operator Contact:	Jason Rorabaugh	**(406) 388-6116**	**jasonrorabaugh@rmsi.coop**

Jason Rorabaugh, UST Class A Operator	jasonrorabaugh@rmsi.coop
Robert Michael, UST Class B Operator	robertmichael@rmsi.coop
Robert Michael, UST Class B Operator	robertmichael@rmsi.coop

Tank Number	10	**Tank Age**	30	**Tank Installed Date**	04/01/1995	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	4298	**Spill Test Date**	07/10/2019	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**	03/22/2021	**Tank/Piping CP Test Date**	12/12/2018	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	16000	**ATG Test Date**	03/22/2021	**Line Tightness Test Date**	11/30/2021	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.1	**Energy Act**	No
		Overfill Test Date	07/02/2019			**ATG Type**	Veeder Root/TLS-450				
Tank Number	08	**Tank Age**	30	**Tank Installed Date**	04/01/1995	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	4299	**Spill Test Date**	07/10/2019	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**	03/22/2021	**Tank/Piping CP Test Date**	12/12/2018	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	16000	**ATG Test Date**	03/22/2021	**Line Tightness Test Date**	11/22/2021	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.1	**Energy Act**	No
		Overfill Test Date	07/02/2019			**ATG Type**	Veeder Root/TLS-450				
Tank Number	09	**Tank Age**	30	**Tank Installed Date**	04/01/1995	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve

Tag Number	4300	**Spill Test Date**	07/10/2019	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**	03/22/2021	**Tank/Piping CP Test Date**	12/12/2018	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	32000	**ATG Test Date**	03/22/2021	**Line Tightness Test Date**	12/10/2021	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.1	**Energy Act**	No
		Overfill Test Date	07/02/2019			**ATG Type**	Veeder Root/TLS-450				
Tank Number	07	**Tank Age**	30	**Tank Installed Date**	04/01/1995	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	4301	**Spill Test Date**	07/10/2019	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**	03/22/2021	**Tank/Piping CP Test Date**	12/12/2018	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	32000	**ATG Test Date**	03/22/2021	**Line Tightness Test Date**	11/24/2021	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.1	**Energy Act**	No
		Overfill Test Date	07/10/2019			**ATG Type**	Veeder Root/TLS-450				
Tank Number	11	**Tank Age**	13	**Tank Installed Date**	08/01/2012	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	5382	**Spill Test Date**	07/10/2019	**Piping Installed Date**	07/27/2012	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**	07/11/2019	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	03/22/2021	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	48000	**ATG Test Date**	03/22/2021	**Line Tightness Test Date**	11/26/2021	**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	07/02/2019			**ATG Type**	Gilbarco-Veeder Root/TLS-450;Veeder Root/TLS-450				
Tank Number	12	**Tank Age**	13	**Tank Installed Date**	08/01/2012	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	5383	**Spill Test Date**	07/10/2019	**Piping Installed Date**	07/27/2012	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**	07/11/2019	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	03/22/2021	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No

Capacity	48000	**ATG Test Date**	03/22/2021	**Line Tightness Test Date**	11/22/2021	**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	07/02/2019			**ATG Type**	Gilbarco-Veeder Root/TLS-450;Veeder Root/TLS-450				

Facility Summary in Broadwater County in the City of Townsend

Location: TOWN PUMP INC TOWNSEND
202 N Front St
Townsend, MT 59644-2202 Broadwater

System Facility ID:04-03456

Facility Code: 17999
Last Inspected On: 05/19/2025
Operating Permit Renewal Date: 12/06/2025

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Townsend 1 Town Pump LLC **(406) 497-6700** **environmental@townpump.com**

Operator Contact: Trent Biggers **Trentb@townpump.com**

Owner/Operator: Townsend 1 Town Pump LLC (406) 497-6700 environmental@townpump.com

Trent Biggers, UST Class A Operator Trentb@townpump.com
Trent Biggers, UST Class A Operator Trentb@townpump.com
Trent Biggers, UST Class B Global Operator Trentb@townpump.com
Trent Biggers, UST Class B Global Operator Trentb@townpump.com

Tank Number	07	**Tank Age**	30	**Tank Installed Date**	03/15/1995	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve
Tag Number	2386	**Spill Test Date**	11/26/2024	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	04/27/2021	**Sump Tightness Test Date**	04/27/2021	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	07/06/2022	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	Yes
Capacity	10000	**ATG Test Date**	07/06/2022	**Line Tightness Test Date**	07/16/2015	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	12/04/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-450				
Tank Number	08	**Tank Age**	30	**Tank Installed Date**	03/15/1995	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve;Flapper Valve
Tag Number	2387	**Spill Test Date**	06/29/2021	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	04/27/2021	**Sump Tightness Test Date**	04/27/2021	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	07/06/2022	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	07/06/2022	**Line Tightness Test Date**	07/16/2015	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No

		Overfill Test Date	05/26/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-450				
Tank Number	09	**Tank Age**	30	**Tank Installed Date**	03/15/1995	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve;Flapper Valve
Tag Number	2388	**Spill Test Date**	11/26/2024	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	04/27/2021	**Sump Tightness Test Date**	04/27/2021	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	07/06/2022	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	Yes
Capacity	12000	**ATG Test Date**	07/06/2022	**Line Tightness Test Date**	07/16/2015	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	12/04/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-450				
Tank Number	10	**Tank Age**	30	**Tank Installed Date**	03/15/1995	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve;Flapper Valve
Tag Number	2389	**Spill Test Date**	04/27/2021	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	04/27/2021	**Sump Tightness Test Date**	04/27/2021	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	07/06/2022	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	Yes
Capacity	12000	**ATG Test Date**	07/06/2022	**Line Tightness Test Date**	07/16/2015	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	12/04/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-450				
Tank Number	11	**Tank Age**	12	**Tank Installed Date**	07/01/2013	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve
Tag Number	5428	**Spill Test Date**	04/27/2021	**Piping Installed Date**	06/28/2013	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	04/27/2021	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	07/06/2022	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**	07/06/2022	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Statistical Inventory Reconciliation	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	Yes
		Overfill Test Date	04/27/2021			**ATG Type**	Gilbarco-Veeder Root/TLS-450				
Tank Number	12	**Tank Age**	12	**Tank Installed Date**	07/01/2013	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve

Tag Number	5429	**Spill Test Date**	04/27/2021	**Piping Installed Date**	06/28/2013	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	04/27/2021	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel, Dyed	**PLLD Test Date**	07/06/2022	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**	07/06/2022	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Statistical Inventory Reconciliation	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	Yes
		Overfill Test Date	04/27/2021			**ATG Type**	Gilbarco-Veeder Root/TLS-450				
Tank Number	13	**Tank Age**	3	**Tank Installed Date**	06/01/2022	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	6096	**Spill Test Date**	05/19/2022	**Piping Installed Date**	06/01/2022	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	05/20/2022	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	06/01/2022	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	Yes
Capacity	12000	**ATG Test Date**	06/01/2022	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Statistical Inventory Reconciliation	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	Yes
		Overfill Test Date	05/26/2022			**ATG Type**					

Facility Summary in Broadwater County in the City of Winston

Location: WINSTON STORE
6473 US Hwy 287
Winston, MT 59647 Broadwater

System Facility ID:04-00280

Facility Code: 17957
Last Inspected On: 06/28/2020
Operating Permit Renewal Date: 06/28/2023

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Allen Brewer **(406) 227-5597**

Operator Contact: Allen Brewer **(406) 227-7080**

Allen Brewer, UST Class A Operator
Allen Brewer, UST Class A Operator
Allen Brewer, UST Class B Operator
Allen Brewer, UST Class B Operator

Tank Number	03	**Tank Age**	32	**Tank Installed Date**	09/01/1993	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	3152	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	06/06/2020	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.1;Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	2000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	04	**Tank Age**	32	**Tank Installed Date**	09/01/1993	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	3153	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	06/06/2020	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.1;Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	2000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No

		Overfill Test Date				**ATG Type**					

Facility Summary in Carbon County in the City of Belfry

Location: SALTAS BIG COUNTRY GARAGE
322 Broadway Avenue
Belfry, MT 59008 Carbon

System Facility ID:05-02954

Facility Code: 18153
Last Inspected On: 05/09/2025
Operating Permit Renewal Date: 05/08/2028

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Stephen Salta	**(702) 496-8356**	**eviesalta@gmail.com**

Operator Contact:	Stephen Salta	**(702) 496-8356**	**eviesalta@gmail.com**

Owner/Operator: Stephen Salta (702) 496-8356 eviesalta@gmail.com

Stephen Salta, UST Class A Operator eviesalta@gmail.com

Stephen Salta, UST Class B Global Operator eviesalta@gmail.com

Tank Number	S8	**Tank Age**	32	**Tank Installed Date**	05/01/1993	**Tank Material Construction**	Bare Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	
Tag Number	449	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	Yes
Status	**Temporarily Out of Use**	**MLLD Test Date**	01/09/2019	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	1000	**ATG Test Date**		**Line Tightness Test Date**	01/09/2019	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	S9	**Tank Age**	32	**Tank Installed Date**	05/01/1993	**Tank Material Construction**	Bare Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	
Tag Number	450	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	Yes
Status	**Temporarily Out of Use**	**MLLD Test Date**	01/09/2019	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	1000	**ATG Test Date**		**Line Tightness Test Date**	01/09/2019	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					

Facility Summary in Carbon County in the City of Bridger

Location: ESSENTIAL FUELS
US Highway 310
Bridger, MT 59014 Carbon

System Facility ID:00-32519

Facility Code: 32519
Last Inspected On: 11/08/2024
Operating Permit Renewal Date: 11/08/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Eric Reichert **(308) 633-3595**

Operator Contact: Paul Moe **(406) 425-3848** **paul.moe29@gmail.com**

Owner/Operator: Eric Reichert (308) 633-3595

Paul Moe, UST Class A Operator paul.moe29@gmail.com
Paul Moe, UST Class B Operator paul.moe29@gmail.com

Tank Number	01	**Tank Age**	2	**Tank Installed Date**	08/01/2023	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	6163	**Spill Test Date**	04/02/2024	**Piping Installed Date**	08/01/2023	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	04/02/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	15000	**ATG Test Date**	05/14/2024	**Line Tightness Test Date**	05/22/2024	**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	05/14/2024			**ATG Type**					
Tank Number	02	**Tank Age**	2	**Tank Installed Date**	08/01/2023	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	6164	**Spill Test Date**	04/02/2024	**Piping Installed Date**	08/01/2023	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	04/02/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Diesel, Dyed	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	05/14/2024	**Line Tightness Test Date**	05/22/2024	**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	05/14/2024			**ATG Type**					
Tank Number	03	**Tank Age**	2	**Tank Installed Date**	08/01/2023	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve

Tag Number	6165	**Spill Test Date**	04/02/2024	**Piping Installed Date**	08/01/2023	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	04/02/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	Yes
Capacity	25000	**ATG Test Date**	05/14/2024	**Line Tightness Test Date**	05/22/2024	**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	05/14/2024			**ATG Type**					
Tank Number	04	**Tank Age**	2	**Tank Installed Date**	08/01/2023	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	
Tag Number	6166	**Spill Test Date**		**Piping Installed Date**	08/01/2023	**Tank Construction**		**Piping Construction**		**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**		**Piping Type**	Pressurized	**CP Met Types**	
Product	DEF (Not Regulated)	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	Yes
		Overfill Test Date				**ATG Type**					
Tank Number	05	**Tank Age**	2	**Tank Installed Date**	08/01/2023	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	6167	**Spill Test Date**	04/02/2024	**Piping Installed Date**	08/01/2023	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	04/02/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	05/14/2024	**Line Tightness Test Date**	05/22/2024	**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	05/14/2024			**ATG Type**					
Tank Number	06	**Tank Age**	2	**Tank Installed Date**	08/01/2023	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	6168	**Spill Test Date**	04/02/2024	**Piping Installed Date**	08/01/2023	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	04/02/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	20000	**ATG Test Date**	05/14/2024	**Line Tightness Test Date**	05/22/2024	**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes

		Overfill Test Date	05/14/2024			**ATG Type**					

Facility Summary in Carbon County in the City of Bridger

Location: MAVERIK INC #7
3646 US Hwy 310
Bridger, MT 59014 Carbon

System Facility ID:05-00218

Facility Code: 18121
Last Inspected On: 08/02/2018
Operating Permit Renewal Date: 09/15/2021

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Maverik Inc	**(801) 910-7061**	**dennis.riding@maverik.com**
Operator Contact:	Dennis Riding		**dennis.riding@maverik.com**

Breann Christiansen, UST Class B Operator — breann.christiansen@maverik.com
Dennis Riding, UST Class A Operator — dennis.riding@maverik.com
Dennis Riding, UST Class B Operator — dennis.riding@maverik.com

Tank Number	04	**Tank Age**	34	**Tank Installed Date**	07/21/1991	**Tank Material Construction**	Steel Clad	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	530	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	24000	**ATG Test Date**		**Line Tightness Test Date**	01/20/2018	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD Line Tightness Testing;Statistical Inventory Reconciliation	**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	05	**Tank Age**	34	**Tank Installed Date**	07/21/1991	**Tank Material Construction**	Steel Clad	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	531	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No

Capacity	24000	**ATG Test Date**		**Line Tightness Test Date**	01/20/2018	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD Line Tightness Testing;Statistical Inventory Reconciliation	**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Carbon County in the City of Bridger

Location: TOWN AND COUNTRY SUPPLY BRIDGER
209 N Main St
Bridger, MT 59014 Carbon

System Facility ID:05-04498

Facility Code: 18171
Last Inspected On: 11/29/2023
Operating Permit Renewal Date: 05/03/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Town and Country Supply Association **(406) 628-6314**

Operator Contact: Landon Van Valkenburgh;Town and Country Supply Association;Wesley Burley **(406) 232-3520;(406) 628-6314** **lvanvalkenburgh@tandcsupply.onmicrosoft.com;wburley@tandcsupply.com**

Owner/Operator: Town and Country Supply Association (406) 628-6314

Landon Van Valkenburgh, UST Class A Operator	lvanvalkenburgh@tandcsupply.onmicrosoft.com
Landon Van Valkenburgh, UST Class B Operator	lvanvalkenburgh@tandcsupply.onmicrosoft.com
Melvin Hanley, UST Class B Operator	hanley41@hotmail.com
Wesley Burley, UST Class A Operator	wburley@tandcsupply.com
Wesley Burley, UST Class A Operator	wburley@tandcsupply.com

Tank Number	06	**Tank Age**	35	**Tank Installed Date**	05/18/1990	**Tank Material Construction**	Steel Clad	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	1515	**Spill Test Date**	11/29/2023	**Piping Installed Date**	08/13/2010	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	08/01/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	07/13/2023	**Tank/Piping CP Test Date**	11/29/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	07/13/2023	**Line Tightness Test Date**	04/22/2018	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date	11/29/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	07	**Tank Age**	35	**Tank Installed Date**	05/18/1990	**Tank Material Construction**	Steel Clad	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	1516	**Spill Test Date**	11/29/2023	**Piping Installed Date**	08/13/2010	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	08/01/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	07/13/2023	**Tank/Piping CP Test Date**	11/29/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	07/13/2023	**Line Tightness Test Date**	04/22/2018	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No

		Overfill Test Date	11/29/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	08	**Tank Age**	35	**Tank Installed Date**	05/18/1990	**Tank Material Construction**	Steel Clad	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	1517	**Spill Test Date**	11/29/2023	**Piping Installed Date**	08/13/2010	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	08/01/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	07/13/2023	**Tank/Piping CP Test Date**	11/29/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	07/13/2023	**Line Tightness Test Date**	04/20/2018	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date	11/29/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	09	**Tank Age**	22	**Tank Installed Date**	07/01/2003	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	4849	**Spill Test Date**	03/26/2024	**Piping Installed Date**	08/13/2010	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	08/01/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**	07/13/2023	**Tank/Piping CP Test Date**	11/29/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	2000	**ATG Test Date**	07/13/2023	**Line Tightness Test Date**	04/20/2018	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date	03/26/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Carbon County in the City of Joliet

Location: CARBON COUNTY DIST 2 SHOP
201 State St
Joliet, MT 59041 Carbon

System Facility ID:05-01853

Facility Code: 18140
Last Inspected On: 10/17/2024
Operating Permit Renewal Date: 02/23/2028

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Carbon County Road Dist **(406) 446-1595**

Operator Contact: Tim Blair;Carbon County Road Dist **(406) 672-0724;(406) 446-1595** **tblair@co.carbon.mt.us**

Owner/Operator: Carbon County Road Dist (406) 446-1595

Tim Blair, UST Class A Operator	tblair@co.carbon.mt.us
Tim Blair, UST Class A Operator	tblair@co.carbon.mt.us
Tim Blair, UST Class B Global Operator	tblair@co.carbon.mt.us
Tim Blair, UST Class B Global Operator	tblair@co.carbon.mt.us

Tank Number	03	**Tank Age**	33	**Tank Installed Date**	01/30/1992	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	518	**Spill Test Date**	10/17/2024	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	10/17/2024	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	1000	**ATG Test Date**	10/17/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	10/17/2024			**ATG Type**	Gilbarco/EMC Basic				
Tank Number	04	**Tank Age**	33	**Tank Installed Date**	01/30/1992	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	519	**Spill Test Date**	10/17/2024	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	10/17/2024	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	1000	**ATG Test Date**	10/17/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	10/17/2024			**ATG Type**	Gilbarco/EMC Basic				

Facility Summary in Carbon County in the City of Joliet

Location: COUNTRY CORNER JOLIET
110 E Front St
Joliet, MT 59041 Carbon

System Facility ID:05-05577

Facility Code: 18186
Last Inspected On: 02/22/2023
Operating Permit Renewal Date: 04/22/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Superpumper Inc **(701) 852-1194**

Operator Contact: Vern Patterson;Parkland USA Corporation **(701) 720-6649;(701) 852-1194** **vern.patterson@parklandusa.com;Jake.thomas@parklandusa.com**

Owner/Operator: Superpumper Inc (701) 852-1194

Curtis McBride, UST Class B Operator Jake.thomas@parklandusa.com
Vern Patterson, UST Class A Operator Jake.thomas@parklandusa.com
Vern Patterson, UST Class B Operator Jake.thomas@parklandusa.com

Tank Number	03	**Tank Age**	38	**Tank Installed Date**	02/22/1987	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	3925	**Spill Test Date**	02/22/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	03/10/2022	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	03/05/2021	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	05/25/2022	**Line Tightness Test Date**	03/10/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	02/22/2023			**ATG Type**	Gilbarco/EMC Basic				
Tank Number	04	**Tank Age**	37	**Tank Installed Date**	02/22/1988	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	3926	**Spill Test Date**	02/22/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	03/10/2022	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Diesel, Dyed	**PLLD Test Date**		**Tank/Piping CP Test Date**	03/05/2021	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	1500	**ATG Test Date**	05/25/2022	**Line Tightness Test Date**	03/08/2019	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	02/22/2023			**ATG Type**	Gilbarco/EMC Basic				
Tank Number	05	**Tank Age**	37	**Tank Installed Date**	02/22/1988	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve

Tag Number	3927	**Spill Test Date**	06/22/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Single Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	03/10/2022	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	03/05/2021	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	2500	**ATG Test Date**	05/25/2022	**Line Tightness Test Date**	03/10/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	06/22/2023			**ATG Type**	Gilbarco/EMC Basic				
Tank Number	06	**Tank Age**	26	**Tank Installed Date**	02/01/1999	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	3928	**Spill Test Date**	02/22/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	03/10/2022	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	03/05/2021	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	05/25/2022	**Line Tightness Test Date**	03/08/2019	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	02/22/2023			**ATG Type**	Gilbarco/EMC Basic				

Facility Summary in Carbon County in the City of Joliet

Location: JOLIET SCHOOL DIST 7
131 N Main St
Joliet, MT 59041 Carbon

System Facility ID:05-05353

Facility Code: 18183
Last Inspected On: 04/07/2023
Operating Permit Renewal Date: 06/25/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: School Dist 7 Joliet **(406) 962-3541**

Operator Contact: Samuel Smith **ssmith@joliet.k12.mt.us**

Owner/Operator: School Dist 7 Joliet (406) 962-3541

Samuel Smith, UST Class A Operator ssmith@joliet.k12.mt.us
Samuel Smith, UST Class B Operator ssmith@joliet.k12.mt.us

Tank Number	02	**Tank Age**	26	**Tank Installed Date**	07/01/1999	**Tank Material Construction**	Steel Clad	**Piping Material**	Steel	**Overfill Types**	Flapper Valve
Tag Number	4091	**Spill Test Date**	04/07/2023	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Manual Interstitial Monitoring	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	1000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	04/07/2023			**ATG Type**					

Facility Summary in Carbon County in the City of Joliet

Location: ROCKVALE TRAVEL PLAZA UST
4293 US Hwy 310
Joliet, MT 59041 Carbon

System Facility ID:05-07633

Facility Code: 18210
Last Inspected On: 08/10/2023
Operating Permit Renewal Date: 08/13/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Thomas McNew;Tom McNew **tom.mcnew59041@gmail.com**

Operator Contact: Thomas McNew **tom.mcnew59041@gmail.com**

Owner/Operator: Thomas McNew tom.mcnew59041@gmail.com

Owner/Operator: Tom McNew tom.mcnew59041@gmail.com

Thomas McNew, UST Class A Operator tom.mcnew59041@gmail.com
Thomas McNew, UST Class A Operator tom.mcnew59041@gmail.com
Thomas McNew, UST Class B Global Operator tom.mcnew59041@gmail.com
Thomas McNew, UST Class B Global Operator tom.mcnew59041@gmail.com

Tank Number	06	**Tank Age**	26	**Tank Installed Date**	07/01/1999	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	4112	**Spill Test Date**	08/10/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	12/10/2014	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**	01/25/2023	**Tank/Piping CP Test Date**	08/10/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	01/25/2023	**Line Tightness Test Date**	02/25/2023	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	01/25/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	07	**Tank Age**	26	**Tank Installed Date**	07/01/1999	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	4113	**Spill Test Date**	08/10/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	12/10/2014	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**	01/25/2023	**Tank/Piping CP Test Date**	08/10/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	01/25/2023	**Line Tightness Test Date**	08/04/2023	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No

		Overfill Test Date	01/25/2023			**ATG Type**	Gilbarco/EMC Basic				
Tank Number	08	**Tank Age**	26	**Tank Installed Date**	07/01/1999	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	4114	**Spill Test Date**	08/10/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	12/10/2014	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**	01/25/2023	**Tank/Piping CP Test Date**	08/10/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	01/25/2023	**Line Tightness Test Date**	08/08/2023	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	01/25/2023			**ATG Type**	Gilbarco/EMC Basic				

Facility Summary in Carbon County in the City of Joliet

Location: TOWN OF JOLIET
116 S Main St
Joliet, MT 59041 Carbon

System Facility ID:05-00189

Facility Code: 18119
Last Inspected On: 02/21/2023
Operating Permit Renewal Date: 05/16/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Town of Joliet **(406) 962-3567**

Operator Contact: Dale Limberhand **lockedout2001@yahoo.com**

Owner/Operator: Town of Joliet (406) 962-3567

Dale Limberhand, UST Class A Operator lockedout2001@yahoo.com
Dale Limberhand, UST Class B Operator lockedout2001@yahoo.com

Tank Number	02	**Tank Age**	28	**Tank Installed Date**	09/01/1997	**Tank Material Construction**	Steel Clad	**Piping Material**	Steel	**Overfill Types**	Flapper Valve
Tag Number	2127	**Spill Test Date**	02/22/2023	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	02/23/2023	**Primary Tank Leak Detection**	Manual Interstitial Monitoring	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	560	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	02/22/2023			**ATG Type**					

Facility Summary in Carbon County in the City of Red Lodge

Location: 6 ASSISTED LLC
600 21st St W
Red Lodge, MT 59068 Carbon

System Facility ID:05-09926

Facility Code: 18235
Last Inspected On: 10/02/2017
Operating Permit Renewal Date: 11/05/2013

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: 6 Assisted LLC Jamaica **(646) 380-8748**

Operator Contact: Bob Miner **minerb@beartoothhospital.org**

Owner/Operator: 6 Assisted LLC Jamaica (646) 380-8748

Bob Miner, UST Class A Operator minerb@beartoothhospital.org

Tank Number	02	**Tank Age**	27	**Tank Installed Date**	10/08/1998	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	3103	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Temporarily Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	08/04/2010	**Primary Tank Leak Detection**	Not Listed	**Primary Pipe Leak Detection**	Not Listed	**Vapor Recovery**	No
Capacity	1000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					

Facility Summary in Carbon County in the City of Red Lodge

Location: CENEX ZIP TRIP 74
902 N Broadway Ave
Red Lodge, MT 59068 Carbon

System Facility ID:56-13935

Facility Code: 30605
Last Inspected On: 01/14/2025
Operating Permit Renewal Date: 05/15/2028

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	CHS Inc Spokane Valley	**(509) 535-7701**	**Donald.Widdicombe@chsinc.com**
Operator Contact:	Jim Alford;Sean Hurley	**(509) 535-7701;(509) 536-7418**	**jim.alford@chsinc.com;sean.hurley@chsinc.com**

Owner/Operator:	CHS Inc Spokane Valley	(509) 535-7701	Donald.Widdicombe@chsinc.com
	Hannah Smith, UST Class B Operator		hannah.smith3@chsinc.com
	Jim Alford, UST Class A Operator		jim.alford@chsinc.com
	Jim Alford, UST Class A Operator		jim.alford@chsinc.com
	Jim Alford, UST Class B Operator		jim.alford@chsinc.com
	Jim Alford, UST Class B Operator		jim.alford@chsinc.com
	Luci Tuttle, UST Class B Operator		Lucinda.Tuttle@chsinc.com
	Sean Hurley, UST Class A Operator		sean.hurley@chsinc.com
	Sean Hurley, UST Class A Operator		sean.hurley@chsinc.com

Tank Number	05	**Tank Age**	10	**Tank Installed Date**	04/10/2015	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	5566	**Spill Test Date**	01/14/2025	**Piping Installed Date**	04/10/2015	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	01/14/2025	**Catastrophic L.D. Type 3.0**	Auto Dialer;Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	06/20/2024	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	15000	**ATG Test Date**	06/20/2024	**Line Tightness Test Date**	04/13/2015	**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	06/20/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350;Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	06	**Tank Age**	10	**Tank Installed Date**	04/10/2015	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	5567	**Spill Test Date**	01/14/2025	**Piping Installed Date**	04/10/2015	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No

Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	01/14/2025	**Catastrophic L.D. Type 3.0**	Auto Dialer;Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	06/20/2024	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	06/20/2024	**Line Tightness Test Date**	04/13/2015	**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	06/20/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350;Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	07	**Tank Age**	10	**Tank Installed Date**	04/10/2015	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	5568	**Spill Test Date**	01/14/2025	**Piping Installed Date**	04/10/2015	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	01/14/2025	**Catastrophic L.D. Type 3.0**	Auto Dialer;Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	06/20/2024	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	7000	**ATG Test Date**	06/20/2024	**Line Tightness Test Date**	04/13/2015	**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	01/14/2025			**ATG Type**	Gilbarco-Veeder Root/TLS-350;Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	08	**Tank Age**	10	**Tank Installed Date**	04/10/2015	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	5569	**Spill Test Date**	01/14/2025	**Piping Installed Date**	04/10/2015	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	01/14/2025	**Catastrophic L.D. Type 3.0**	Auto Dialer;Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel, Dyed	**PLLD Test Date**	06/20/2024	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	06/20/2024	**Line Tightness Test Date**	04/13/2015	**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	06/20/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350;Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Carbon County in the City of Red Lodge

Location: CIRCLE 17
1022 S Adams Ave
Red Lodge, MT 59068-9578 Carbon

System Facility ID:05-09748

Facility Code: 18233
Last Inspected On: 11/29/2023
Operating Permit Renewal Date: 03/05/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Circle 17 LLC;Mackenzie Alexander	**(406) 425-0395**	**circle17@outlook.com**
Operator Contact:	Mackenzie Alexander;Stephen Alexander	**(406) 425-0395;(406) 425-3997**	**circle17@outlook.com;madcap91@live.com**

Owner/Operator:	Circle 17 LLC	(406) 425-0395	circle17@outlook.com
Owner/Operator:	Mackenzie Alexander	(406) 425-0395	circle17@outlook.com
	Mackenzie Alexander, UST Class A Operator		circle17@outlook.com
	Mackenzie Alexander, UST Class A Operator		circle17@outlook.com
	Mackenzie Alexander, UST Class B Operator		circle17@outlook.com
	Mackenzie Alexander, UST Class B Operator		circle17@outlook.com
	Stephen Alexander, UST Class A Operator		madcap91@live.com
	Stephen Alexander, UST Class A Operator		madcap91@live.com
	Stephen Alexander, UST Class B Operator		madcap91@live.com
	Stephen Alexander, UST Class B Operator		madcap91@live.com

Tank Number	04	**Tank Age**	29	**Tank Installed Date**	07/01/1996	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	3389	**Spill Test Date**	11/29/2023	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**	03/17/2023	**Tank/Piping CP Test Date**	11/29/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	03/17/2023	**Line Tightness Test Date**	02/01/2021	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	03/17/2023			**ATG Type**	Gilbarco/EMC Basic				
Tank Number	05	**Tank Age**	29	**Tank Installed Date**	07/01/1996	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	3390	**Spill Test Date**	11/29/2023	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic

Product	Gasoline	**PLLD Test Date**	03/17/2023	**Tank/Piping CP Test Date**	11/29/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	03/17/2023	**Line Tightness Test Date**	02/03/2021	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	03/17/2023			**ATG Type**	Gilbarco/EMC Basic				

Facility Summary in Carbon County in the City of Red Lodge

Location: TOWN PUMP OF RED LODGE
710 N Broadway
Red Lodge, MT 59068 Carbon

System Facility ID:60-15212

Facility Code: 30932
Last Inspected On: 02/29/2024
Operating Permit Renewal Date: 08/09/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Red Lodge 1 Town Pump LLC **(406) 497-6700** **environmental@townpump.com**

Operator Contact: Trent Biggers **Trentb@townpump.com**

Owner/Operator: Red Lodge 1 Town Pump LLC (406) 497-6700 environmental@townpump.com

Trent Biggers, UST Class A Operator Trentb@townpump.com

Trent Biggers, UST Class B Global Operator Trentb@townpump.com

Tank Number	01	**Tank Age**	12	**Tank Installed Date**	01/16/2013	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	5377	**Spill Test Date**	08/23/2023	**Piping Installed Date**	01/16/2013	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	08/23/2023	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	02/29/2024	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	Yes
Capacity	20000	**ATG Test Date**	06/05/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Statistical Inventory Reconciliation	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	Yes
		Overfill Test Date	08/23/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Number	02	**Tank Age**	12	**Tank Installed Date**	01/16/2013	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	5378	**Spill Test Date**	08/23/2023	**Piping Installed Date**	01/16/2013	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	08/23/2023	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	02/29/2024	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	14000	**ATG Test Date**	06/05/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Statistical Inventory Reconciliation	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	Yes

		Overfill Test Date	08/23/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Number	03	**Tank Age**	12	**Tank Installed Date**	01/16/2013	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	5379	**Spill Test Date**	08/23/2023	**Piping Installed Date**	01/16/2013	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	08/23/2023	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	02/29/2024	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**	06/05/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Statistical Inventory Reconciliation	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	Yes
		Overfill Test Date	08/23/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Number	04	**Tank Age**	12	**Tank Installed Date**	01/16/2013	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	5380	**Spill Test Date**	06/14/2021	**Piping Installed Date**	01/16/2013	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	06/14/2021	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	07/19/2022	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	06/05/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Statistical Inventory Reconciliation	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	Yes
		Overfill Test Date	06/14/2021			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Number	05	**Tank Age**	12	**Tank Installed Date**	01/16/2013	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	5381	**Spill Test Date**	08/03/2021	**Piping Installed Date**	01/16/2013	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	06/14/2021	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	07/19/2022	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	06/05/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Statistical Inventory Reconciliation	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	Yes
		Overfill Test Date	06/14/2021			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				

Tank Number	06	**Tank Age**	8	**Tank Installed Date**	05/23/2017	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	5800	**Spill Test Date**	06/14/2021	**Piping Installed Date**	05/23/2017	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	06/14/2021	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	07/19/2022	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	Yes
Capacity	6000	**ATG Test Date**	06/05/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Statistical Inventory Reconciliation	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	Yes
		Overfill Test Date	06/14/2021			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				

Facility Summary in Carbon County in the City of Roberts

Location: Y STOP C STORE INC
4 Cooney Rd
Roberts, MT 59070 Carbon

System Facility ID:05-06599

Facility Code: 18197
Last Inspected On: 08/23/2023
Operating Permit Renewal Date: 02/20/2024

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Melton Enterprises Inc **(406) 426-0135** **robertsystop@aol.com**

Operator Contact: Rodney Melton **robertsystop@aol.com**

Owner/Operator: Melton Enterprises Inc (406) 426-0135 robertsystop@aol.com

Rodney Melton, UST Class A Operator robertsystop@aol.com

Rodney Melton, UST Class B Operator robertsystop@aol.com

Tank Number	05	**Tank Age**	33	**Tank Installed Date**	06/20/1992	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	3329	**Spill Test Date**	07/28/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Temporarily Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	07/28/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	5000	**ATG Test Date**	07/28/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	07/28/2023			**ATG Type**	Veeder Root/TLS-300				
Tank Number	06	**Tank Age**	33	**Tank Installed Date**	06/20/1992	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	3330	**Spill Test Date**	07/28/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Temporarily Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	07/28/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	3000	**ATG Test Date**	07/28/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	07/28/2023			**ATG Type**	Veeder Root/TLS-300				
Tank Number	07	**Tank Age**	33	**Tank Installed Date**	06/20/1992	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	3331	**Spill Test Date**	07/28/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No

Status	**Temporarily Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	07/28/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	3000	**ATG Test Date**	07/28/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	07/28/2023			**ATG Type**	Veeder Root/TLS-300				
Tank Number	08	**Tank Age**	33	**Tank Installed Date**	06/20/1992	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	3332	**Spill Test Date**	07/28/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Temporarily Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	07/28/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	5000	**ATG Test Date**	07/28/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	07/28/2023			**ATG Type**	Veeder Root/TLS-300				

Facility Summary in Carter County in the City of Alzada

Location: B AND J CONVENIENCE STORE
US Hwy 212 & Hwy 326
Alzada, MT 59311 Carter

System Facility ID:56-13910

Facility Code: 30580
Last Inspected On: 09/16/2024
Operating Permit Renewal Date: 09/17/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	B AND JS CONVENIENCE STORE LLC	**(406) 853-4312**	**tlhendrickson.tt@gmail.com**
Operator Contact:	Traci Tarno;William Walker	**(406) 828-4400**	**pook5451@yahoo.com;tlhendrickson.tt@gmail.com**

Owner/Operator: B AND JS CONVENIENCE STORE LLC (406) 853-4312 tlhendrickson.tt@gmail.com

Janet Walker, UST Class B Global Operator	pook5451@yahoo.com
Traci Tarno, UST Class A Operator	tlhendrickson.tt@gmail.com
Traci Tarno, UST Class B Operator	tlhendrickson.tt@gmail.com
William Walker, UST Class A Operator	pook5451@yahoo.com

Tank Number	01	**Tank Age**	27	**Tank Installed Date**	12/01/1998	**Tank Material Construction**	Steel Clad	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	3564	**Spill Test Date**	10/12/2022	**Piping Installed Date**	10/06/2022	**Tank Construction**	Double-Walled	**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	12/01/2022	**Line Tightness Test Date**	12/01/2022	**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date	10/12/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Number	02	**Tank Age**	27	**Tank Installed Date**	12/01/1998	**Tank Material Construction**	Steel Clad	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	3565	**Spill Test Date**	10/12/2022	**Piping Installed Date**	10/06/2022	**Tank Construction**	Double-Walled	**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	10/12/2022	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	Yes
Capacity	4000	**ATG Test Date**	12/01/2022	**Line Tightness Test Date**	12/01/2022	**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No

		Overfill Test Date	10/12/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Number	03	**Tank Age**	3	**Tank Installed Date**	09/15/2022	**Tank Material Construction**	Steel Clad	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	6114	**Spill Test Date**	10/12/2022	**Piping Installed Date**	10/06/2022	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	12/12/2022	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	Yes
Capacity	10000	**ATG Test Date**	12/01/2022	**Line Tightness Test Date**	12/01/2022	**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	12/12/2022			**ATG Type**					

Facility Summary in Carter County in the City of Ekalaka

Location: EKALAKA ELEMENTARY SCHOOL
106 E Park St
Ekalaka, MT 59324 Carter

System Facility ID:06-04710

Facility Code: 18291
Last Inspected On: 06/12/2018
Operating Permit Renewal Date: 02/02/2019

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Carter County	**(406) 775-8749**	**rtauck@cartercounty.us**
Operator Contact:	Shay Beyer	**(406) 978-3333**	

Shay Beyer, UST Class A Operator
Shay Beyer, UST Class A Operator
Shay Beyer, UST Class B Global Operator
Shay Beyer, UST Class B Global Operator

Tank Number	S2	**Tank Age**	34	**Tank Installed Date**	08/01/1991	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	859	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	U.S. Suction	**CP Met Types**	Galvanic
Product	Heating Oil	**PLLD Test Date**		**Tank/Piping CP Test Date**	06/12/2018	**Primary Tank Leak Detection**	Manual Interstitial Monitoring	**Primary Pipe Leak Detection**	Manual Interstitial Monitoring	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					

Facility Summary in Carter County in the City of Ekalaka

Location: FRUIT SERVICE AND REPAIR INC SR 323
31 MT Hwy 323
Ekalaka, MT 59324 Carter

System Facility ID:06-03234

Facility Code: 18280
Last Inspected On: 03/04/2024
Operating Permit Renewal Date: 08/17/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Fruit Service and Repair Inc

Operator Contact: Troy Fruit **(406) 775-6541** **fruit@midrivers.com**

Owner/Operator: Fruit Service and Repair Inc

Mikel Fruit, UST Class B Operator mjfruit@midrivers.com
Troy Fruit, UST Class A Operator fruit@midrivers.com

Tank Number	07	**Tank Age**	27	**Tank Installed Date**	04/01/1998	**Tank Material Construction**	Steel Clad	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	1135	**Spill Test Date**	03/04/2024	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Manual Interstitial Monitoring	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	4590	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	03/04/2024			**ATG Type**					
Tank Number	08	**Tank Age**	27	**Tank Installed Date**	04/01/1998	**Tank Material Construction**	Steel Clad	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	1136	**Spill Test Date**	03/04/2024	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Manual Interstitial Monitoring	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	2365	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	03/04/2024			**ATG Type**					
Tank Number	09	**Tank Age**	27	**Tank Installed Date**	04/01/1998	**Tank Material Construction**	Steel Clad	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	1137	**Spill Test Date**	03/04/2024	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No

Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Manual Interstitial Monitoring	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	9627	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	03/04/2024			**ATG Type**					
Tank Number	06	**Tank Age**	27	**Tank Installed Date**	04/01/1998	**Tank Material Construction**	Steel Clad	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	3617	**Spill Test Date**	03/04/2024	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Manual Interstitial Monitoring	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	5565	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	03/04/2024			**ATG Type**					

Facility Summary in Carter County in the City of Ekalaka

Location: HOSPITAL COURTHOUSE
101 Park St
Ekalaka, MT 59324 Carter

System Facility ID:06-00863

Facility Code: 18264
Last Inspected On: 07/25/2024
Operating Permit Renewal Date: 07/25/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Carter County	**(406) 775-8749**	**rtauck@cartercounty.us**
Operator Contact:	Robert (Bob) Jacobs	**(406) 975-8751**	

Robert (Bob) Jacobs, UST Class A Operator

Robert (Bob) Jacobs, UST Class B Global Operator

Tank Number	S3	**Tank Age**	34	**Tank Installed Date**	07/01/1991	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Steel	**Overfill Types**	Flapper Valve
Tag Number	532	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	None	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	U.S. Suction	**CP Met Types**	Impressed Current
Product	Heating Oil	**PLLD Test Date**		**Tank/Piping CP Test Date**	07/25/2024	**Primary Tank Leak Detection**	Manual Interstitial Monitoring	**Primary Pipe Leak Detection**	Manual Interstitial Monitoring	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					

Facility Summary in Carter County in the City of Ekalaka

Location: T AND M STANDARD LLC
40 Main St
Ekalaka, MT 59324 Carter

System Facility ID:06-01681

Facility Code: 18270
Last Inspected On: 03/04/2024
Operating Permit Renewal Date: 08/17/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	T & M STANDARD LLC;Troy Fruit	**(406) 775-6541**	**fruit@midrivers.com**
Operator Contact:	Troy Fruit	**(406) 775-6541**	**fruit@midrivers.com**

Owner/Operator:	T & M STANDARD LLC	(406) 775-6541	fruit@midrivers.com
Owner/Operator:	Troy Fruit	(406) 775-6541	fruit@midrivers.com
	Mikel Fruit, UST Class B Operator		mjfruit@midrivers.com
	Troy Fruit, UST Class A Operator		fruit@midrivers.com

Tank Number	03	**Tank Age**	35	**Tank Installed Date**	04/26/1990	**Tank Material Construction**	Steel Clad	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	1132	**Spill Test Date**	03/04/2024	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Manual Interstitial Monitoring	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	1000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	03/04/2024			**ATG Type**					
Tank Number	04	**Tank Age**	35	**Tank Installed Date**	04/26/1990	**Tank Material Construction**	Steel Clad	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	1133	**Spill Test Date**	03/04/2024	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Manual Interstitial Monitoring	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	1000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	03/04/2024			**ATG Type**					
Tank Number	05	**Tank Age**	35	**Tank Installed Date**	04/26/1990	**Tank Material Construction**	Steel Clad	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve

Tag Number	1134	**Spill Test Date**	03/04/2024	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Manual Interstitial Monitoring	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	1000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	03/04/2024			**ATG Type**					

Facility Summary in Cascade County in the City of Belt

Location: BELT PUBLIC SCHOOLS DIST 29 UST
1 Church St
Belt, MT 59412 Cascade

System Facility ID:07-04613

Facility Code: 18537
Last Inspected On: 05/05/2023
Operating Permit Renewal Date: 08/04/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: School Dist 29 Belt **(406) 277-3351**

Operator Contact: Joe Gaylord

Owner/Operator: School Dist 29 Belt (406) 277-3351

April Wells, UST Class B Operator awells@beltschool.com

Joe Gaylord, UST Class A Operator

Tank Number	S3	**Tank Age**	37	**Tank Installed Date**	10/01/1988	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Positive Shutoff
Tag Number	422	**Spill Test Date**	04/21/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	11/27/2023	**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	U.S. Suction	**CP Met Types**	Galvanic
Product	Heating Oil	**PLLD Test Date**		**Tank/Piping CP Test Date**	05/05/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	05/05/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	04/21/2022			**ATG Type**	Incon/TS-1000				

Facility Summary in Cascade County in the City of Belt

Location: BELT VALLEY GROCERY
65 Castner St
Belt, MT 59412 Cascade

System Facility ID:07-13653

Facility Code: 19054
Last Inspected On: 08/26/2022
Operating Permit Renewal Date: 11/29/2025

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Harry L Throckmorton **(406) 277-3523**

Operator Contact: Reed Throckmorton **rthrock77@gmail.com**

Owner/Operator: Harry L Throckmorton (406) 277-3523

Reed Throckmorton, UST Class A Operator rthrock77@gmail.com

Reed Throckmorton, UST Class B Operator rthrock77@gmail.com

Tank Number	01	**Tank Age**	30	**Tank Installed Date**	10/01/1995	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	4468	**Spill Test Date**	10/04/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	08/26/2022	**Sump Tightness Test Date**	10/14/2019	**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**	08/26/2022	**Line Tightness Test Date**	08/26/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	10/04/2022			**ATG Type**	OPW/EECO 1500				
Tank Number	02	**Tank Age**	30	**Tank Installed Date**	10/01/1995	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	4469	**Spill Test Date**	10/04/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	08/26/2022	**Sump Tightness Test Date**	10/14/2019	**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**	08/26/2022	**Line Tightness Test Date**	08/26/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	10/04/2022			**ATG Type**	OPW/EECO 1500				

Facility Summary in Cascade County in the City of Belt

Location: MALMSTROM AFB A 10
US Hwy 87/89
Belt, MT 59412 Cascade

System Facility ID:07-08984

Facility Code: 18745
Last Inspected On: 06/13/2024
Operating Permit Renewal Date: 10/07/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	341 CES CEANQ	**(406) 731-6188**	
Operator Contact:	Candace Ellsworth;Curtis Hester;William Smith	**(406) 731-6239;(406) 731-7128**	**candace.ellsworth@us.af.mil;william.smith@us.af.mil**

Owner/Operator: 341 CES CEANQ (406) 731-6188

Candace Ellsworth, UST Class A Operator	candace.ellsworth@us.af.mil
Candace Ellsworth, UST Class B Global Operator	candace.ellsworth@us.af.mil
Curtis Hester, UST Class A Operator	
Curtis Hester, UST Class B Global Operator	
William Smith, UST Class A Operator	william.smith@us.af.mil
William Smith, UST Class B Global Operator	william.smith@us.af.mil

Tank Number	02	**Tank Age**	33	**Tank Installed Date**	05/01/1992	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	115	**Spill Test Date**	05/08/2023	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	05/08/2023	**Catastrophic L.D. Type 3.0**	Auto Dialer	**Piping Type**	U.S. Suction	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	05/08/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	05/08/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Cascade County in the City of Belt

Location: MALMSTROM AFB A 11
US Hwy 87/89
Belt, MT 59412 Cascade

System Facility ID:07-08985

Facility Code: 18746
Last Inspected On: 06/13/2024
Operating Permit Renewal Date: 09/25/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: 341 CES CEANQ **(406) 731-6188**

Operator Contact: Candace Ellsworth;Curtis Hester;William Smith **(406) 731-6239;(406) 731-7128** **candace.ellsworth@us.af.mil;william.smith@us.af.mil**

Owner/Operator: 341 CES CEANQ (406) 731-6188

Candace Ellsworth, UST Class A Operator	candace.ellsworth@us.af.mil
Candace Ellsworth, UST Class B Global Operator	candace.ellsworth@us.af.mil
Curtis Hester, UST Class A Operator	
Curtis Hester, UST Class B Global Operator	
William Smith, UST Class A Operator	william.smith@us.af.mil
William Smith, UST Class B Global Operator	william.smith@us.af.mil

Tank Number	02	**Tank Age**	33	**Tank Installed Date**	05/01/1992	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	116	**Spill Test Date**	07/17/2020	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	05/19/2020	**Catastrophic L.D. Type 3.0**	Auto Dialer	**Piping Type**	U.S. Suction	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	05/03/2022	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	05/03/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Cascade County in the City of Belt

Location: MALMSTROM AFB A 2
US Hwy 87/89
Belt, MT 59412 Cascade

System Facility ID:07-08976

Facility Code: 18739
Last Inspected On: 06/13/2024
Operating Permit Renewal Date: 10/07/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	341 CES CEANQ	**(406) 731-6188**	
Operator Contact:	Candace Ellsworth;Curtis Hester;James Leigland;William Smith	**(406) 731-6239;(406) 731-7128;(406) 899-3635**	**candace.ellsworth@us.af.mil;jim@leigland.com;william.smith@us.af.mil**

Owner/Operator: 341 CES CEANQ (406) 731-6188

Candace Ellsworth, UST Class A Operator	candace.ellsworth@us.af.mil
Candace Ellsworth, UST Class B Global Operator	candace.ellsworth@us.af.mil
Curtis Hester, UST Class A Operator	
Curtis Hester, UST Class B Global Operator	
James Leigland, UST Class A Operator	jim@leigland.com
James Leigland, UST Class B Operator	jim@leigland.com
Mark Johnson, UST Class B Global Operator	
William Smith, UST Class A Operator	william.smith@us.af.mil
William Smith, UST Class B Global Operator	william.smith@us.af.mil

Tank Number	02	**Tank Age**	33	**Tank Installed Date**	06/01/1992	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	109	**Spill Test Date**	07/17/2020	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	05/19/2020	**Catastrophic L.D. Type 3.0**	Auto Dialer	**Piping Type**	U.S. Suction	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	05/05/2022	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	05/05/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Cascade County in the City of Black Eagle

Location: BLACK EAGLE SERVICE CENTER
1501 N River Rd
Black Eagle, MT 59414 Cascade

System Facility ID:07-01190

Facility Code: 18380
Last Inspected On: 08/17/2022
Operating Permit Renewal Date: 01/28/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Northwestern Energy Butte **(406) 655-2521** **beth.stimatz@northwestern.com**

Operator Contact: Brian Ranf **brian.ranf@northwestern.com**

Owner/Operator: Northwestern Energy Butte (406) 655-2521 beth.stimatz@northwestern.com

Brian Ranf, UST Class A Operator brian.ranf@northwestern.com
Colton Coffing, UST Class B Operator colton.coffing@northwestern.com
Colton Coffing, UST Class B Operator colton.coffing@northwestern.com

Tank Number	04	**Tank Age**	34	**Tank Installed Date**	12/01/1991	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	1676	**Spill Test Date**	08/19/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	2086	**ATG Test Date**	05/16/2022	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	07/29/2021			**ATG Type**	Veeder Root/TLS-300				
Tank Number	05	**Tank Age**	34	**Tank Installed Date**	12/01/1991	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	1677	**Spill Test Date**	08/19/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	2086	**ATG Test Date**	05/16/2022	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	07/29/2021			**ATG Type**	Veeder Root/TLS-300				

Facility Summary in Cascade County in the City of Black Eagle

Location: MOUNTAIN VIEW CO-OP
1105 Smelter Ave NE
Black Eagle, MT 59414 Cascade

System Facility ID:60-15312

Facility Code: 31011
Last Inspected On: 03/17/2025
Operating Permit Renewal Date: 03/19/2028

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Mountain View Coop Black Eagle **(406) 453-5900** **ddouglas@mountainviewcoop.com**

Operator Contact: David Douglas **ddouglas@mountainviewcoop.com**

Owner/Operator: Mountain View Coop Black Eagle (406) 453-5900 ddouglas@mountainviewcoop.com

David Douglas, UST Class A Operator ddouglas@mountainviewcoop.com
David Douglas, UST Class B Global Operator ddouglas@mountainviewcoop.com
Foster Sensibaugh, UST Class B Global Operator fsensibaugh@mountainviewcoop.com

Tank Number	01	**Tank Age**	8	**Tank Installed Date**	10/10/2017	**Tank Material Construction**	Steel Clad	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	5773	**Spill Test Date**	03/13/2025	**Piping Installed Date**	09/17/2017	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	01/20/2022	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	30000	**ATG Test Date**	03/13/2025	**Line Tightness Test Date**	06/01/2018	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	03/13/2025			**ATG Type**	Incon/TS-5000 EVO				
Tank Number	02	**Tank Age**	8	**Tank Installed Date**	10/10/2017	**Tank Material Construction**	Steel Clad	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	5774	**Spill Test Date**	03/13/2025	**Piping Installed Date**	09/17/2017	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	01/20/2022	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	15000	**ATG Test Date**	03/13/2025	**Line Tightness Test Date**	06/01/2018	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	03/13/2025			**ATG Type**	Incon/TS-5000 EVO				

Tank Number	03	**Tank Age**	8	**Tank Installed Date**	10/10/2017	**Tank Material Construction**	Steel Clad	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	5775	**Spill Test Date**	03/13/2025	**Piping Installed Date**	09/17/2017	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	01/20/2022	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	03/13/2025	**Line Tightness Test Date**	06/01/2018	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	03/13/2025			**ATG Type**	Incon/TS-5000 EVO				
Tank Number	04	**Tank Age**	8	**Tank Installed Date**	10/10/2017	**Tank Material Construction**	Steel Clad	**Piping Material**	Flexible Plastic	**Overfill Types**	Positive Shutoff
Tag Number	5776	**Spill Test Date**		**Piping Installed Date**	09/17/2017	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Other**	**MLLD Test Date**		**Sump Tightness Test Date**	12/05/2017	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	DEF (Not Regulated)	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	ELLD Line Tightness Testing;Not Listed	**Vapor Recovery**	No
Capacity	5000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring;Not Listed	**Energy Act**	Yes
		Overfill Test Date				**ATG Type**	Incon/TS-550 EVO				
Tank Number	05	**Tank Age**	8	**Tank Installed Date**	10/10/2017	**Tank Material Construction**	Steel Clad	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	5777	**Spill Test Date**	03/13/2025	**Piping Installed Date**	09/17/2017	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	01/20/2022	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	03/13/2025	**Line Tightness Test Date**	06/01/2018	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	03/13/2025			**ATG Type**	Incon/TS-5000 EVO				
Tank Number	06	**Tank Age**	8	**Tank Installed Date**	10/10/2017	**Tank Material Construction**	Steel Clad	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	5778	**Spill Test Date**	03/13/2025	**Piping Installed Date**	09/17/2017	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No

Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	01/20/2022	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	03/13/2025	**Line Tightness Test Date**	06/01/2018	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	03/13/2025			**ATG Type**	Incon/TS-5000 EVO				
Tank Number	07	**Tank Age**	8	**Tank Installed Date**	10/10/2017	**Tank Material Construction**	Steel Clad	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	5779	**Spill Test Date**	03/13/2025	**Piping Installed Date**	09/17/2017	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	01/20/2022	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	03/13/2025	**Line Tightness Test Date**	06/01/2018	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	03/13/2025			**ATG Type**	Incon/TS-5000 EVO				

Facility Summary in Cascade County in the City of Black Eagle

Location: MOUNTAIN VIEW COOP BLACK EAGLE
2200 Old Havre Hwy
Black Eagle, MT 59414-1043 Cascade

System Facility ID:07-04232

Facility Code: 18509
Last Inspected On: 06/22/2022
Operating Permit Renewal Date: 08/04/2025

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Mountain View Coop Black Eagle **(406) 453-5900** **ddouglas@mountainviewcoop.com**

Operator Contact: William (Ralph) Floyd;Mountain View Coop Great Falls **(406) 401-6025** **rfloyd@mvc.ag**

Owner/Operator: Mountain View Coop Black Eagle (406) 453-5900 ddouglas@mountainviewcoop.com

William (Ralph) Floyd, UST Class A Operator rfloyd@mvc.ag

William (Ralph) Floyd, UST Class B Operator rfloyd@mvc.ag

Tank Number	07	**Tank Age**	28	**Tank Installed Date**	12/02/1997	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	No Piping	**Overfill Types**	High Level Alarm
Tag Number	1015	**Spill Test Date**	03/08/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**		**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**		**Vapor Recovery**	Yes
Capacity	12000	**ATG Test Date**	01/09/2025	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	01/09/2025			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	08	**Tank Age**	28	**Tank Installed Date**	12/02/1997	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	No Piping	**Overfill Types**	High Level Alarm
Tag Number	1016	**Spill Test Date**	03/08/2023	**Piping Installed Date**	09/19/2007	**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**		**CP Met Types**	Non-corrodible
Product	Diesel, Dyed	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	01/09/2025	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	01/09/2025			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	09	**Tank Age**	28	**Tank Installed Date**	12/02/1997	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	No Piping	**Overfill Types**	High Level Alarm

Tag Number	1017	**Spill Test Date**	03/08/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**		**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**		**Vapor Recovery**	Yes
Capacity	4000	**ATG Test Date**	01/07/2025	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	01/07/2025			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	10	**Tank Age**	28	**Tank Installed Date**	12/02/1997	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	No Piping	**Overfill Types**	High Level Alarm
Tag Number	1018	**Spill Test Date**	03/08/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**		**CP Met Types**	Non-corrodible
Product	Diesel, Dyed	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	01/07/2025	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	01/07/2025			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	11	**Tank Age**	28	**Tank Installed Date**	12/02/1997	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	No Piping	**Overfill Types**	High Level Alarm
Tag Number	1019	**Spill Test Date**	03/08/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	01/07/2025	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	01/07/2025			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	12	**Tank Age**	28	**Tank Installed Date**	12/02/1997	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	No Piping	**Overfill Types**	High Level Alarm
Tag Number	1020	**Spill Test Date**	03/08/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	01/07/2025	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No

		Overfill Test Date	01/07/2025			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Cascade County in the City of Black Eagle

Location: MOUNTAIN VIEW COOP GREAT FALLS
1000 Smelter Ave NE
Black Eagle, MT 59414-1018 Cascade

System Facility ID:07-00004

Facility Code: 18320
Last Inspected On: 05/06/2019
Operating Permit Renewal Date: 08/04/2022

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Mountain View Coop Black Eagle	**(406) 453-5900**	**ddouglas@mountainviewcoop.com**
Operator Contact:	David Douglas;Kila Moore	**(406) 453-5900**	**ddouglas@mountainviewcoop.com;safety@mountainviewcoop.com**

Owner/Operator: Mountain View Coop Black Eagle (406) 453-5900 ddouglas@mountainviewcoop.com

David Douglas, UST Class A Operator	ddouglas@mountainviewcoop.com
David Douglas, UST Class B Global Operator	ddouglas@mountainviewcoop.com
Gary Boysun, UST Class B Operator	
Gary Boysun, UST Class B Operator	
Jasmin Nguyen, UST Class B Global Operator	jasmin_nguyen5@hotmail.com
Jasmin Nguyen, UST Class B Global Operator	jasmin_nguyen5@hotmail.com
Jasmin Nguyen, UST Class B Operator	jasmin_nguyen5@hotmail.com
Jasmin Nguyen, UST Class B Operator	jasmin_nguyen5@hotmail.com
John Malley, UST Class B Operator	jmalley@mountainviewcoop.com
John Malley, UST Class B Operator	jmalley@mountainviewcoop.com
Kila Moore, UST Class A Operator	safety@mountainviewcoop.com
Kila Moore, UST Class A Operator	safety@mountainviewcoop.com

Tank Number	07	**Tank Age**	30	**Tank Installed Date**	11/01/1995	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	1009	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	24000	**ATG Test Date**		**Line Tightness Test Date**	04/28/2019	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	08	**Tank Age**	30	**Tank Installed Date**	11/01/1995	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm

Tag Number	1010	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	24000	**ATG Test Date**		**Line Tightness Test Date**	04/30/2019	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	09	**Tank Age**	30	**Tank Installed Date**	11/01/1995	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	1011	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	24000	**ATG Test Date**		**Line Tightness Test Date**	04/29/2019	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	10	**Tank Age**	30	**Tank Installed Date**	11/01/1995	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	1012	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	24000	**ATG Test Date**		**Line Tightness Test Date**	05/03/2019	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	11	**Tank Age**	30	**Tank Installed Date**	11/01/1995	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	1013	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	24000	**ATG Test Date**		**Line Tightness Test Date**	04/29/2019	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No

		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	12	**Tank Age**	30	**Tank Installed Date**	11/01/1995	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	1014	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	U.S. Suction	**CP Met Types**	
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.1;ELLD 0.2;ELLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	24000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	14	**Tank Age**	3	**Tank Installed Date**	07/23/2022	**Tank Material Construction**	Steel Clad	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	6115	**Spill Test Date**	08/10/2022	**Piping Installed Date**	07/23/2022	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	08/10/2022	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	Yes
Capacity	10000	**ATG Test Date**	02/23/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	Yes
		Overfill Test Date	08/07/2022			**ATG Type**					
Tank Number	15	**Tank Age**	3	**Tank Installed Date**	07/23/2022	**Tank Material Construction**	Steel Clad	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	6116	**Spill Test Date**	08/10/2022	**Piping Installed Date**	07/23/2022	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	08/10/2022	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	Yes
Capacity	10000	**ATG Test Date**	02/23/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	08/07/2022			**ATG Type**					
Tank Number	16	**Tank Age**	3	**Tank Installed Date**	07/23/2022	**Tank Material Construction**	Steel Clad	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve

Tag Number	6117	**Spill Test Date**	08/10/2022	**Piping Installed Date**	07/23/2022	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	08/10/2022	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	Yes
Capacity	12000	**ATG Test Date**	02/23/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	08/07/2022			**ATG Type**					
Tank Number	17	**Tank Age**	3	**Tank Installed Date**	07/23/2022	**Tank Material Construction**	Steel Clad	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	6118	**Spill Test Date**	08/10/2022	**Piping Installed Date**	07/23/2022	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	08/10/2022	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	Yes
Capacity	8000	**ATG Test Date**	02/23/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	08/07/2022			**ATG Type**					
Tank Number	18	**Tank Age**	3	**Tank Installed Date**	07/23/2022	**Tank Material Construction**	Steel Clad	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	6119	**Spill Test Date**	08/10/2022	**Piping Installed Date**	07/23/2022	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	08/10/2022	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	02/23/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	08/07/2022			**ATG Type**					
Tank Number	19	**Tank Age**	3	**Tank Installed Date**	07/23/2022	**Tank Material Construction**	Steel Clad	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	6120	**Spill Test Date**	08/10/2022	**Piping Installed Date**	07/23/2022	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	08/10/2022	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Diesel, Dyed	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No

Capacity	8000	**ATG Test Date**	02/23/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	08/07/2022			**ATG Type**					

Facility Summary in Cascade County in the City of Cascade

Location: 468 MARKET
130 1st St N
Cascade, MT 59421-8353 Cascade

System Facility ID:07-04148

Facility Code: 18505
Last Inspected On: 07/13/2022
Operating Permit Renewal Date: 09/20/2025

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	DTK Foods Inc		**tomsmarket2252@yahoo.com**
Operator Contact:	Irene Strandell;Wesley Seabolt	**(406) 468-2252;(406) 781-2060**	**strandellhouse@prodigy.net;wes492@yahoo.com**

Owner/Operator: DTK Foods Inc — tomsmarket2252@yahoo.com

Irene Strandell, UST Class A Operator	strandellhouse@prodigy.net
Irene Strandell, UST Class B Operator	strandellhouse@prodigy.net
Wesley Seabolt, UST Class A Operator	wes492@yahoo.com
Wesley Seabolt, UST Class B Global Operator	wes492@yahoo.com

Tank Number	04	**Tank Age**	28	**Tank Installed Date**	05/01/1997	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	1490	**Spill Test Date**	01/12/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	01/11/2022	**Sump Tightness Test Date**	08/08/2016	**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	01/13/2022	**Line Tightness Test Date**	01/11/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	01/12/2022			**ATG Type**	Gilbarco/EMC Basic				
Tank Number	05	**Tank Age**	28	**Tank Installed Date**	05/01/1997	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	1491	**Spill Test Date**	01/12/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	01/11/2022	**Sump Tightness Test Date**	08/08/2016	**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**	01/13/2022	**Line Tightness Test Date**	01/11/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	01/12/2022			**ATG Type**	Gilbarco/EMC Basic				

Tank Number	06	**Tank Age**	28	**Tank Installed Date**	05/01/1997	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	1492	**Spill Test Date**	01/12/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	01/11/2022	**Sump Tightness Test Date**	08/08/2016	**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel, Dyed	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	5000	**ATG Test Date**	01/13/2022	**Line Tightness Test Date**	01/11/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	01/12/2022			**ATG Type**	Gilbarco/EMC Basic				
Tank Number	07	**Tank Age**	28	**Tank Installed Date**	05/01/1997	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	1493	**Spill Test Date**	01/12/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	01/11/2022	**Sump Tightness Test Date**	08/08/2016	**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**	01/13/2022	**Line Tightness Test Date**	01/11/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	01/12/2022			**ATG Type**	Gilbarco/EMC Basic				
Tank Number	08	**Tank Age**	28	**Tank Installed Date**	05/01/1997	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	1494	**Spill Test Date**	01/12/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	01/11/2022	**Sump Tightness Test Date**	08/08/2016	**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	5000	**ATG Test Date**	01/13/2022	**Line Tightness Test Date**	01/11/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	01/12/2022			**ATG Type**	Gilbarco/EMC Basic				

Facility Summary in Cascade County in the City of Cascade

Location: MALMSTROM AFB G 3
I-15
Cascade, MT 59421 Cascade

System Facility ID:07-09043

Facility Code: 18748
Last Inspected On: 04/18/2024
Operating Permit Renewal Date: 09/22/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: 341 CES CEANQ **(406) 731-6188**

Operator Contact: Candace Ellsworth;Curtis Hester;William Smith **(406) 731-6239;(406) 731-7128** **candace.ellsworth@us.af.mil;william.smith@us.af.mil**

Owner/Operator: 341 CES CEANQ (406) 731-6188

Candace Ellsworth, UST Class A Operator	candace.ellsworth@us.af.mil
Candace Ellsworth, UST Class B Global Operator	candace.ellsworth@us.af.mil
Curtis Hester, UST Class A Operator	
Curtis Hester, UST Class B Global Operator	
William Smith, UST Class A Operator	william.smith@us.af.mil
William Smith, UST Class B Global Operator	william.smith@us.af.mil

Tank Number	02	**Tank Age**	36	**Tank Installed Date**	06/21/1989	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	118	**Spill Test Date**	04/18/2024	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	04/18/2024	**Catastrophic L.D. Type 3.0**	Auto Dialer	**Piping Type**	U.S. Suction	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	04/18/2024	**Line Tightness Test Date**	06/25/2020	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	04/18/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Cascade County in the City of Cascade

Location: MALMSTROM AFB G 4
I-15
Cascade, MT 59421 Cascade

System Facility ID:07-09044

Facility Code: 18749
Last Inspected On: 04/18/2024
Operating Permit Renewal Date: 09/22/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: 341 CES CEANQ **(406) 731-6188**

Operator Contact: Candace Ellsworth;Curtis Hester;William Smith **(406) 731-6239;(406) 731-7128** **candace.ellsworth@us.af.mil;william.smith@us.af.mil**

Owner/Operator: 341 CES CEANQ (406) 731-6188

Candace Ellsworth, UST Class A Operator	candace.ellsworth@us.af.mil
Candace Ellsworth, UST Class B Global Operator	candace.ellsworth@us.af.mil
Curtis Hester, UST Class A Operator	
Curtis Hester, UST Class B Global Operator	
William Smith, UST Class A Operator	william.smith@us.af.mil
William Smith, UST Class B Global Operator	william.smith@us.af.mil

Tank Number	02	**Tank Age**	33	**Tank Installed Date**	05/01/1992	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	119	**Spill Test Date**	04/18/2024	**Piping Installed Date**	11/16/2016	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	04/18/2024	**Catastrophic L.D. Type 3.0**	Auto Dialer	**Piping Type**	U.S. Suction	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	04/18/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	04/18/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Cascade County in the City of Cascade

Location: MALMSTROM AFB G 5
I-15
Cascade, MT 59421 Cascade

System Facility ID:07-09045

Facility Code: 18750
Last Inspected On: 04/18/2024
Operating Permit Renewal Date: 09/22/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: 341 CES CEANQ **(406) 731-6188**

Operator Contact: Candace Ellsworth;Curtis Hester;William Smith **(406) 731-6239;(406) 731-7128** **candace.ellsworth@us.af.mil;william.smith@us.af.mil**

Owner/Operator: 341 CES CEANQ (406) 731-6188

Candace Ellsworth, UST Class A Operator	candace.ellsworth@us.af.mil
Candace Ellsworth, UST Class B Global Operator	candace.ellsworth@us.af.mil
Curtis Hester, UST Class A Operator	
Curtis Hester, UST Class B Global Operator	
William Smith, UST Class A Operator	william.smith@us.af.mil
William Smith, UST Class B Global Operator	william.smith@us.af.mil

Tank Number	02	**Tank Age**	33	**Tank Installed Date**	05/01/1992	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	120	**Spill Test Date**	04/18/2024	**Piping Installed Date**	05/17/2017	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	04/18/2024	**Catastrophic L.D. Type 3.0**	Auto Dialer	**Piping Type**	U.S. Suction	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	04/18/2024	**Line Tightness Test Date**	05/17/2017	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	04/18/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Cascade County in the City of Cascade

Location: MALMSTROM AFB I 1
Hwy 330
Cascade, MT 59421 Cascade

System Facility ID:07-09063

Facility Code: 18755
Last Inspected On: 05/16/2024
Operating Permit Renewal Date: 09/22/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: 341 CES CEANQ **(406) 731-6188**

Operator Contact: Candace Ellsworth;Curtis Hester;William Smith **(406) 731-6239;(406) 731-7128** **candace.ellsworth@us.af.mil;william.smith@us.af.mil**

Owner/Operator: 341 CES CEANQ (406) 731-6188

Candace Ellsworth, UST Class A Operator	candace.ellsworth@us.af.mil
Candace Ellsworth, UST Class B Global Operator	candace.ellsworth@us.af.mil
Curtis Hester, UST Class A Operator	
Curtis Hester, UST Class B Global Operator	
William Smith, UST Class A Operator	william.smith@us.af.mil
William Smith, UST Class B Global Operator	william.smith@us.af.mil

Tank Number	01	**Tank Age**	63	**Tank Installed Date**	06/02/1962	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	125	**Spill Test Date**	05/16/2024	**Piping Installed Date**		**Tank Construction**	Lined Interior/Impressed Current	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	05/16/2024	**Catastrophic L.D. Type 3.0**	Auto Dialer	**Piping Type**	U.S. Suction	**CP Met Types**	Impressed Current
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	05/13/2021	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	10/24/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	05/16/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				

Facility Summary in Cascade County in the City of Cascade

Location: MALMSTROM AFB I 3
Road 330
Cascade, MT 59421 Cascade

System Facility ID:07-09065

Facility Code: 18757
Last Inspected On: 04/19/2024
Operating Permit Renewal Date: 09/22/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: 341 CES CEANQ **(406) 731-6188**

Operator Contact: Candace Ellsworth;Curtis Hester;William Smith **(406) 731-6239;(406) 731-7128** **candace.ellsworth@us.af.mil;william.smith@us.af.mil**

Owner/Operator: 341 CES CEANQ (406) 731-6188

Candace Ellsworth, UST Class A Operator	candace.ellsworth@us.af.mil
Candace Ellsworth, UST Class B Global Operator	candace.ellsworth@us.af.mil
Curtis Hester, UST Class A Operator	
Curtis Hester, UST Class B Global Operator	
William Smith, UST Class A Operator	william.smith@us.af.mil
William Smith, UST Class B Global Operator	william.smith@us.af.mil

Tank Number	02	**Tank Age**	34	**Tank Installed Date**	10/01/1991	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	127	**Spill Test Date**	04/19/2024	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	04/19/2024	**Catastrophic L.D. Type 3.0**	Auto Dialer	**Piping Type**	U.S. Suction	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	04/19/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	04/19/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Cascade County in the City of Cascade

Location: MALMSTROM AFB I 4
Road 330
Cascade, MT 59421 Cascade

System Facility ID:07-09066

Facility Code: 18758
Last Inspected On: 04/19/2024
Operating Permit Renewal Date: 09/22/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	341 CES CEANQ	**(406) 731-6188**	
Operator Contact:	Candace Ellsworth;Curtis Hester;William Smith	**(406) 731-6239;(406) 731-7128**	**candace.ellsworth@us.af.mil;william.smith@us.af.mil**

Owner/Operator: 341 CES CEANQ (406) 731-6188

Candace Ellsworth, UST Class A Operator	candace.ellsworth@us.af.mil
Candace Ellsworth, UST Class B Global Operator	candace.ellsworth@us.af.mil
Curtis Hester, UST Class A Operator	
Curtis Hester, UST Class B Global Operator	
William Smith, UST Class A Operator	william.smith@us.af.mil
William Smith, UST Class B Global Operator	william.smith@us.af.mil

Tank Number	02	**Tank Age**	34	**Tank Installed Date**	10/01/1991	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	128	**Spill Test Date**	04/19/2024	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	04/19/2024	**Catastrophic L.D. Type 3.0**	Auto Dialer	**Piping Type**	U.S. Suction	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	04/19/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	04/19/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Cascade County in the City of Cascade

Location: MALMSTROM AFB I 5
Road 330
Cascade, MT 59421 Cascade

System Facility ID:07-09067

Facility Code: 18759
Last Inspected On: 04/19/2024
Operating Permit Renewal Date: 09/22/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: 341 CES CEANQ **(406) 731-6188**

Operator Contact: Candace Ellsworth;Curtis Hester;William Smith **(406) 731-6239;(406) 731-7128** **candace.ellsworth@us.af.mil;william.smith@us.af.mil**

Owner/Operator: 341 CES CEANQ (406) 731-6188

Candace Ellsworth, UST Class A Operator	candace.ellsworth@us.af.mil
Candace Ellsworth, UST Class B Global Operator	candace.ellsworth@us.af.mil
Curtis Hester, UST Class A Operator	
Curtis Hester, UST Class B Global Operator	
William Smith, UST Class A Operator	william.smith@us.af.mil
William Smith, UST Class B Global Operator	william.smith@us.af.mil

Tank Number	02	**Tank Age**	34	**Tank Installed Date**	10/01/1991	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	129	**Spill Test Date**	04/19/2024	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	04/19/2024	**Catastrophic L.D. Type 3.0**	Auto Dialer	**Piping Type**	U.S. Suction	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	04/19/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	04/19/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Cascade County in the City of Cascade

Location: MALMSTROM AFB I 6
I-15
Cascade, MT 59421 Cascade

System Facility ID:07-09068

Facility Code: 18760
Last Inspected On: 04/19/2024
Operating Permit Renewal Date: 09/22/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: 341 CES CEANQ **(406) 731-6188**

Operator Contact: Candace Ellsworth;Curtis Hester;William Smith **(406) 731-6239;(406) 731-7128** **candace.ellsworth@us.af.mil;william.smith@us.af.mil**

Owner/Operator: 341 CES CEANQ (406) 731-6188

Candace Ellsworth, UST Class A Operator	candace.ellsworth@us.af.mil
Candace Ellsworth, UST Class B Global Operator	candace.ellsworth@us.af.mil
Curtis Hester, UST Class A Operator	
Curtis Hester, UST Class B Global Operator	
William Smith, UST Class A Operator	william.smith@us.af.mil
William Smith, UST Class B Global Operator	william.smith@us.af.mil

Tank Number	02	**Tank Age**	33	**Tank Installed Date**	05/01/1992	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	130	**Spill Test Date**	04/19/2024	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	04/19/2024	**Catastrophic L.D. Type 3.0**	Auto Dialer	**Piping Type**	U.S. Suction	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	04/19/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	04/19/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Cascade County in the City of Cascade

Location: OLSON FARM
430 Klock Rd
Cascade, MT 59421-8014 Cascade

System Facility ID:07-04520

Facility Code: 18528
Last Inspected On: 01/09/2024
Operating Permit Renewal Date: 03/07/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Cory Olson;Orin Olson	**(406) 468-2457**	**cory_olson@hotmail.com**
Operator Contact:	Cory Olson		**cory_olson@hotmail.com**

Owner/Operator: Cory Olson — cory_olson@hotmail.com

Owner/Operator: Orin Olson — cory_olson@hotmail.com

Cory Olson, UST Class A Operator — cory_olson@hotmail.com

Cory Olson, UST Class B Operator — cory_olson@hotmail.com

Tank Number	02	**Tank Age**	26	**Tank Installed Date**	04/01/1999	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	4053	**Spill Test Date**	05/10/2024	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	01/09/2024	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	01/09/2024	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**	01/09/2024	**Line Tightness Test Date**	01/09/2024	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	05/10/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Cascade County in the City of Fort Shaw

Location: MALMSTROM AFB H 6
MT Hwy 21
Fort Shaw, MT 59443 Cascade

System Facility ID:07-09057

Facility Code: 18753
Last Inspected On: 04/04/2024
Operating Permit Renewal Date: 09/22/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: 341 CES CEANQ **(406) 731-6188**

Operator Contact: Candace Ellsworth;Curtis Hester;William Smith **(406) 731-6239;(406) 731-7128** **candace.ellsworth@us.af.mil;william.smith@us.af.mil**

Owner/Operator: 341 CES CEANQ (406) 731-6188

Candace Ellsworth, UST Class A Operator	candace.ellsworth@us.af.mil
Candace Ellsworth, UST Class B Global Operator	candace.ellsworth@us.af.mil
Curtis Hester, UST Class A Operator	
Curtis Hester, UST Class B Global Operator	
William Smith, UST Class A Operator	william.smith@us.af.mil
William Smith, UST Class B Global Operator	william.smith@us.af.mil

Tank Number	02	**Tank Age**	34	**Tank Installed Date**	09/01/1991	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	123	**Spill Test Date**	04/04/2024	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	04/04/2024	**Catastrophic L.D. Type 3.0**	Auto Dialer	**Piping Type**	U.S. Suction	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	04/04/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	04/04/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Cascade County in the City of Fort Shaw

Location: MALMSTROM AFB I 8
MT Hwy 21
Fort Shaw, MT 59443 Cascade

System Facility ID:07-10840

Facility Code: 18856
Last Inspected On: 04/22/2024
Operating Permit Renewal Date: 09/22/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: 341 CES CEANQ **(406) 731-6188**

Operator Contact: Candace Ellsworth;Curtis Hester;William Smith **(406) 731-6239;(406) 731-7128** **candace.ellsworth@us.af.mil;william.smith@us.af.mil**

Owner/Operator: 341 CES CEANQ (406) 731-6188

Candace Ellsworth, UST Class A Operator	candace.ellsworth@us.af.mil
Candace Ellsworth, UST Class B Global Operator	candace.ellsworth@us.af.mil
Curtis Hester, UST Class A Operator	
Curtis Hester, UST Class B Global Operator	
Kyle Topp, UST Class B Operator	kyle.topp@us.af.mil
William Hoffmeister, UST Class B Operator	william.hoffmeister@malmstrom.af.mil
William Smith, UST Class A Operator	william.smith@us.af.mil
William Smith, UST Class B Global Operator	william.smith@us.af.mil

Tank Number	01	**Tank Age**	36	**Tank Installed Date**	09/26/1989	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	152	**Spill Test Date**	04/22/2024	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	04/22/2024	**Catastrophic L.D. Type 3.0**	Auto Dialer	**Piping Type**	U.S. Suction	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	04/22/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	04/22/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Cascade County in the City of Fort Shaw

Location: MALMSTROM AFB I 9
MT Hwy 21
Fort Shaw, MT 59443 Cascade

System Facility ID:07-09071

Facility Code: 18763
Last Inspected On: 04/22/2024
Operating Permit Renewal Date: 09/22/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: 341 CES CEANQ **(406) 731-6188**

Operator Contact: Candace Ellsworth;Curtis Hester;William Smith **(406) 731-6239;(406) 731-7128** **candace.ellsworth@us.af.mil;william.smith@us.af.mil**

Owner/Operator: 341 CES CEANQ (406) 731-6188

Candace Ellsworth, UST Class A Operator	candace.ellsworth@us.af.mil
Candace Ellsworth, UST Class B Global Operator	candace.ellsworth@us.af.mil
Curtis Hester, UST Class A Operator	
Curtis Hester, UST Class B Global Operator	
William Smith, UST Class A Operator	william.smith@us.af.mil
William Smith, UST Class B Global Operator	william.smith@us.af.mil

Tank Number	02	**Tank Age**	34	**Tank Installed Date**	10/01/1991	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	132	**Spill Test Date**	04/22/2024	**Piping Installed Date**	11/16/2016	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	04/22/2024	**Catastrophic L.D. Type 3.0**	Auto Dialer	**Piping Type**	U.S. Suction	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	04/22/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	04/22/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Cascade County in the City of Great Falls

Location: 15TH STREET SERVICE
1501 10th Ave S
Great Falls, MT 59405-2625 Cascade

System Facility ID:07-07573

Facility Code: 18672
Last Inspected On: 12/04/2023
Operating Permit Renewal Date: 03/27/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Gary Maki	**(406) 453-2070**	**dgmaki@msn.com**
Operator Contact:	Gary Maki	**(406) 453-2070**	**dgmaki@msn.com**

Owner/Operator: Gary Maki (406) 453-2070 dgmaki@msn.com

Gary Maki, UST Class A Operator dgmaki@msn.com

Gary Maki, UST Class B Operator dgmaki@msn.com

Tank Number	05	**Tank Age**	36	**Tank Installed Date**	01/16/1989	**Tank Material Construction**	Steel Clad	**Piping Material**	Steel	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	3824	**Spill Test Date**	12/04/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	12/04/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**	12/04/2023	**Line Tightness Test Date**	12/13/2011	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	12/04/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	06	**Tank Age**	36	**Tank Installed Date**	01/16/1989	**Tank Material Construction**	Steel Clad	**Piping Material**	Steel	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	3825	**Spill Test Date**	12/04/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	12/04/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	12/04/2023	**Line Tightness Test Date**	12/13/2011	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	12/04/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	07	**Tank Age**	36	**Tank Installed Date**	01/16/1989	**Tank Material Construction**	Steel Clad	**Piping Material**	Steel	**Overfill Types**	Flapper Valve;High Level Alarm

Tag Number	3826	**Spill Test Date**	12/04/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	12/04/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	12/04/2023	**Line Tightness Test Date**	12/13/2011	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	12/04/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	08	**Tank Age**	36	**Tank Installed Date**	01/16/1989	**Tank Material Construction**	Steel Clad	**Piping Material**	Steel	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	3827	**Spill Test Date**	12/04/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	12/04/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	12/04/2023	**Line Tightness Test Date**	12/13/2011	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	12/04/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Cascade County in the City of Great Falls

Location: BENEFIS HEALTH CARE EAST CAMPUS UST
1101 26th St S
Great Falls, MT 59405-5161 Cascade

System Facility ID:07-06552

Facility Code: 18631
Last Inspected On: 09/06/2023
Operating Permit Renewal Date: 09/08/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Benefis Healthcare **(406) 455-5135**

Operator Contact: Scott Kincaid;Todd Boucher;Benefis Healthcare **(406) 590-0869;(406) 455-5135;(406) 868-9675** **scottkincaid@benefis.org;toddboucher@benefis.org**

Owner/Operator: Benefis Healthcare (406) 455-5135

Ben Konesky, UST Class B Operator	benkonesky@benefis.org
Scott Kincaid, UST Class A Operator	scottkincaid@benefis.org
Scott Kincaid, UST Class B Operator	scottkincaid@benefis.org
Todd Boucher, UST Class A Operator	toddboucher@benefis.org

Tank Number	S3	**Tank Age**	24	**Tank Installed Date**	03/30/2001	**Tank Material Construction**	Concrete	**Piping Material**	Flexible Plastic	**Overfill Types**	
Tag Number	4584	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	Yes
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	11/15/2023	**Catastrophic L.D. Type 3.0**	Auto Dialer	**Piping Type**	Pressurized	**CP Met Types**	
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	12/12/2005	**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	20000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	04	**Tank Age**	17	**Tank Installed Date**	08/22/2008	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Steel	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	5190	**Spill Test Date**	11/15/2023	**Piping Installed Date**	06/17/2008	**Tank Construction**	Double-Walled	**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Non-corrodible
Product	Jet Fuel (Jet-A, Jet-A1, JP5)	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	2500	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**	Veeder Root/TLS-300				

Facility Summary in Cascade County in the City of Great Falls

Location: BENEFIS HEALTH CARE WEST CAMPUS
500 15th Ave S
Great Falls, MT 59405-4304 Cascade

System Facility ID:07-03298

Facility Code: 18480
Last Inspected On: 10/02/2023
Operating Permit Renewal Date: 09/08/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Benefis Healthcare	**(406) 455-5135**	
Operator Contact:	Scott Kincaid;Todd Boucher;Benefis Healthcare	**(406) 590-0869;(406) 455-5135;(406) 868-9675**	**scottkincaid@benefis.org;toddboucher@benefis.org**

Owner/Operator: Benefis Healthcare (406) 455-5135

Ben Konesky, UST Class B Operator	benkonesky@benefis.org
Scott Kincaid, UST Class A Operator	scottkincaid@benefis.org
Scott Kincaid, UST Class B Operator	scottkincaid@benefis.org
Todd Boucher, UST Class A Operator	toddboucher@benefis.org

Tank Number	05	**Tank Age**	29	**Tank Installed Date**	07/01/1996	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	3401	**Spill Test Date**	09/05/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	09/08/2023	**Catastrophic L.D. Type 3.0**	Auto Dialer	**Piping Type**	U.S. Suction	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	2000	**ATG Test Date**	09/05/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	09/05/2023			**ATG Type**	EMCO Electronics/EECO 1500				
Tank Number	06	**Tank Age**	26	**Tank Installed Date**	05/01/1999	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	4003	**Spill Test Date**	09/05/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	09/08/2023	**Catastrophic L.D. Type 3.0**	Auto Dialer	**Piping Type**	U.S. Suction	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	15000	**ATG Test Date**	09/05/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No

		Overfill Test Date	09/05/2023			**ATG Type**	EMCO Electronics/EECO 1500				

Facility Summary in Cascade County in the City of Great Falls

Location: BEST OIL DISTRIBUTING INC
5401 River Dr N
Great Falls, MT 59405-1081 Cascade

System Facility ID:07-05852

Facility Code: 18596
Last Inspected On: 03/19/2024
Operating Permit Renewal Date: 04/11/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Best Oil Distributing Inc **(406) 453-0971**

Operator Contact: Seth Schimerowski **(406) 564-8856** **Schimer66@hotmail.com**

Owner/Operator: Best Oil Distributing Inc (406) 453-0971

Seth Schimerowski, UST Class A Operator Schimer66@hotmail.com
Seth Schimerowski, UST Class B Operator Schimer66@hotmail.com

Tank Number	01	**Tank Age**	44	**Tank Installed Date**	05/01/1981	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	1254	**Spill Test Date**	10/16/2023	**Piping Installed Date**	07/27/2007	**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	02/22/2024	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	15000	**ATG Test Date**	02/22/2024	**Line Tightness Test Date**	06/04/2003	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	02/22/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	02	**Tank Age**	44	**Tank Installed Date**	05/01/1981	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	1255	**Spill Test Date**	10/09/2023	**Piping Installed Date**	07/27/2007	**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	02/22/2024	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	15000	**ATG Test Date**	02/22/2024	**Line Tightness Test Date**	05/03/2002	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	02/22/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	03	**Tank Age**	44	**Tank Installed Date**	05/01/1981	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm

Tag Number	1256	**Spill Test Date**	10/09/2023	**Piping Installed Date**	07/27/2007	**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	02/22/2024	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	15000	**ATG Test Date**	02/22/2024	**Line Tightness Test Date**	07/01/2001	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	02/22/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	04	**Tank Age**	44	**Tank Installed Date**	05/01/1981	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	1257	**Spill Test Date**	10/09/2023	**Piping Installed Date**	07/27/2007	**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	02/22/2024	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	15000	**ATG Test Date**	02/22/2024	**Line Tightness Test Date**	05/29/2003	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	02/22/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	07	**Tank Age**	27	**Tank Installed Date**	04/01/1998	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	1258	**Spill Test Date**	10/16/2023	**Piping Installed Date**	07/27/2007	**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	02/22/2024	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	02/22/2024	**Line Tightness Test Date**	07/20/2001	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	02/22/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	08	**Tank Age**	27	**Tank Installed Date**	04/01/1998	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	1259	**Spill Test Date**	10/09/2023	**Piping Installed Date**	07/27/2007	**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	02/22/2024	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	02/22/2024	**Line Tightness Test Date**	09/24/2004	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No

		Overfill Test Date	02/22/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Cascade County in the City of Great Falls

Location: BIG O TIRES
1101 7th St S
Great Falls, MT 59405 Cascade

System Facility ID:60-15329

Facility Code: 31025
Last Inspected On:
Operating Permit Renewal Date: 05/07/2019

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Gus & Jacks Tire **(406) 799-5650** **bigotires26702@bresnan.net**

Operator Contact:

Tank Number	01	**Tank Age**	0	**Tank Installed Date**		**Tank Material Construction**	Bare Steel	**Piping Material**	No Piping	**Overfill Types**	
Tag Number	5895	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**		**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**		**Piping Type**	Not Listed	**CP Met Types**	
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Not Listed	**Primary Pipe Leak Detection**	Not Listed	**Vapor Recovery**	No
Capacity	1000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Not Listed	**Energy Act**	No
		Overfill Test Date				**ATG Type**					

Facility Summary in Cascade County in the City of Great Falls

Location: BISON FORD
500 10th Ave S
Great Falls, MT 59405-4047 Cascade

System Facility ID:07-00077

Facility Code: 18324
Last Inspected On: 06/26/2024
Operating Permit Renewal Date: 11/05/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Bison Motors **(406) 727-2552**

Operator Contact: Ryan Christensen **rchristensen@bisonford.com**

Owner/Operator: Bison Motors (406) 727-2552

Ryan Christensen, UST Class A Operator rchristensen@bisonford.com
Ryan Christensen, UST Class A Operator rchristensen@bisonford.com
Ryan Christensen, UST Class B Operator rchristensen@bisonford.com
Ryan Christensen, UST Class B Operator rchristensen@bisonford.com

Tank Number	07	**Tank Age**	37	**Tank Installed Date**	08/05/1988	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	
Tag Number	3908	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	04/10/2013	**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	U.S. Suction	**CP Met Types**	Non-corrodible
Product	Oil, Waste	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	3-Year Line Tightness Test	**Vapor Recovery**	No
Capacity	3000	**ATG Test Date**	06/26/2024	**Line Tightness Test Date**	06/26/2024	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**	OPW/Other				
Tank Number	08	**Tank Age**	37	**Tank Installed Date**	08/05/1988	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	
Tag Number	4303	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	04/10/2013	**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	U.S. Suction	**CP Met Types**	Non-corrodible
Product	Oil, Waste	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	3-Year Line Tightness Test	**Vapor Recovery**	No
Capacity	1000	**ATG Test Date**	06/26/2024	**Line Tightness Test Date**	06/26/2024	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					

Facility Summary in Cascade County in the City of Great Falls

Location: BRAKE TIME 253722
1225 Central Ave W
Great Falls, MT 59404-3968 Cascade

System Facility ID:07-05777

Facility Code: 18586
Last Inspected On: 01/07/2025
Operating Permit Renewal Date: 03/08/2028

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Central Ave Great falls LLC	**(832) 539-8190**	**licensing@btcmstores.com**
Operator Contact:	Chelsey Partridge;Holly Seymour;John Sumowski;Randal Liebnow;Theodore Bezel;Mini Mart Inc dba Loaf 'N Jug Pueblo	**(267) 799-8664;(406) 750-8563;(513) 964-1568**	**eglegaldept@eg-america.com;hseymour86@hotmail.com;randy.liebnow@loafnjug.com**

Owner/Operator:	Central Ave Great falls LLC	(832) 539-8190	licensing@btcmstores.com
	Chelsey Partridge, UST Class A Operator		
	Chelsey Partridge, UST Class A Operator		
	Chelsey Partridge, UST Class B Operator		
	Chelsey Partridge, UST Class B Operator		
	Hiede Richardson, UST Class B Global Operator		hiede.richardson@yahoo.com
	Holly Seymour, UST Class A Operator		hseymour86@hotmail.com
	Holly Seymour, UST Class A Operator		hseymour86@hotmail.com
	Holly Seymour, UST Class B Global Operator		hseymour86@hotmail.com
	Holly Seymour, UST Class B Global Operator		hseymour86@hotmail.com
	John Sumowski, UST Class A Operator		
	John Sumowski, UST Class A Operator		
	Randal Liebnow, UST Class A Operator		randy.liebnow@loafnjug.com
	Randal Liebnow, UST Class B Global Operator		randy.liebnow@loafnjug.com
	Scott Huether, UST Class B Global Operator		mtscorpion1963@msn.com
	Stevie Ulstad, UST Class B Operator		crazyfroggie2003@yahoo.com
	Theodore Bezel, UST Class A Operator		eglegaldept@eg-america.com
	Theodore Bezel, UST Class A Operator		eglegaldept@eg-america.com
	Theodore Bezel, UST Class B Global Operator		
	Theodore Bezel, UST Class B Global Operator		
	Theodore Bezel, UST Class B Operator		
	Theodore Bezel, UST Class B Operator		
	Toni Mullen, UST Class B Global Operator		

Tank Number	01	**Tank Age**	53	**Tank Installed Date**	04/26/1972	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	1630	**Spill Test Date**	08/28/2024	**Piping Installed Date**	10/19/2016	**Tank Construction**	Lined Interior/Impressed Current	**Piping Construction**	Double Walled	**AST**	No

Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	08/28/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Diesel	**PLLD Test Date**	08/28/2024	**Tank/Piping CP Test Date**	04/21/2022	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	08/28/2024	**Line Tightness Test Date**	01/07/2011	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date	11/21/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	02	**Tank Age**	53	**Tank Installed Date**	04/26/1972	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	1631	**Spill Test Date**	08/28/2024	**Piping Installed Date**	10/19/2016	**Tank Construction**	Lined Interior/Impressed Current	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	08/28/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**	08/28/2024	**Tank/Piping CP Test Date**	04/21/2022	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	08/28/2024	**Line Tightness Test Date**	01/07/2011	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date	11/21/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	03	**Tank Age**	53	**Tank Installed Date**	04/26/1972	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	1632	**Spill Test Date**	08/28/2024	**Piping Installed Date**	10/19/2016	**Tank Construction**	Lined Interior/Impressed Current	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	08/28/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**	08/28/2024	**Tank/Piping CP Test Date**	04/21/2022	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	08/28/2024	**Line Tightness Test Date**	01/07/2011	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date	11/21/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Cascade County in the City of Great Falls

Location: BRAKE TIME 253719
3726 2nd Ave N
Great Falls, MT 59401-3010 Cascade

System Facility ID:07-03920

Facility Code: 18493
Last Inspected On: 01/07/2025
Operating Permit Renewal Date: 03/06/2028

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	2ND AVE GREAT FALLS MT LLC;Muhammad Akhtar	**(406) 727-7917;(832) 539-8190**	**akhatarmuhammad65@gmail.com**
Operator Contact:	Muhammad Akhtar;Nicole Younger-Taylor;Theodore Bezel;Mini Mart Inc dba Loaf 'N Jug Pueblo	**(307) 871-7831;(513) 964-1568;(832) 539-8190**	**akhatarmuhammad65@gmail.com;eglegaldept@eg-america.com;nicole.younger-taylor@loafnjug.com**
Owner/Operator:	2ND AVE GREAT FALLS MT LLC	(406) 727-7917	akhatarmuhammad65@gmail.com
Owner/Operator:	Muhammad Akhtar	(406) 727-7917	akhatarmuhammad65@gmail.com
	Muhammad Akhtar, UST Class A Operator		akhatarmuhammad65@gmail.com
	Nicole Younger-Taylor, UST Class A Operator		nicole.younger-taylor@loafnjug.com
	Nicole Younger-Taylor, UST Class A Operator		nicole.younger-taylor@loafnjug.com
	Theodore Bezel, UST Class A Operator		eglegaldept@eg-america.com
	Theodore Bezel, UST Class A Operator		eglegaldept@eg-america.com
	Theodore Bezel, UST Class B Global Operator		
	Theodore Bezel, UST Class B Global Operator		
	Theodore Bezel, UST Class B Operator		
	Theodore Bezel, UST Class B Operator		
	Timothy Osterman, UST Class B Global Operator		bigoproductions@msn.com
	Timothy Osterman, UST Class B Operator		bigoproductions@msn.com

Tank Number	01	**Tank Age**	41	**Tank Installed Date**	03/24/1984	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	1624	**Spill Test Date**	12/19/2024	**Piping Installed Date**		**Tank Construction**	Lined Interior/Impressed Current	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**	08/05/2024	**Tank/Piping CP Test Date**	03/19/2024	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	07/25/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Manual Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	12/19/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	02	**Tank Age**	41	**Tank Installed Date**	03/24/1984	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve

Tag Number	1625	**Spill Test Date**	12/19/2024	**Piping Installed Date**		**Tank Construction**	Lined Interior/Impressed Current	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Diesel	**PLLD Test Date**	08/05/2024	**Tank/Piping CP Test Date**	03/26/2024	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	07/25/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Manual Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	12/19/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	03	**Tank Age**	41	**Tank Installed Date**	03/24/1984	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	1626	**Spill Test Date**	12/19/2024	**Piping Installed Date**		**Tank Construction**	Lined Interior/Impressed Current	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**	08/05/2024	**Tank/Piping CP Test Date**	03/26/2024	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	07/25/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Manual Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	12/19/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Cascade County in the City of Great Falls

Location: BRAKE TIME 253720
900 1st Ave N
Great Falls, MT 59401 Cascade

System Facility ID:07-05775

Facility Code: 18584
Last Inspected On: 02/10/2025
Operating Permit Renewal Date: 03/06/2028

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	1ST AVE GREAT FALLS MT LLC	**(832) 539-8190**	
Operator Contact:	John Sumowski;Nicole Younger-Taylor;Omair Bashir;Randal Liebnow;Theodore Bezel;Mini Mart Inc dba Loaf 'N Jug Pueblo	**(307) 871-7831;(513) 964-1568;(832) 539-8190**	**eglegaldept@eg-america.com;licensing@btcmstores.com;nicole.younger-taylor@loafnjug.com;randy.liebnow@loafnjug.com**

Owner/Operator: 1ST AVE GREAT FALLS MT LLC (832) 539-8190

John Sumowski, UST Class A Operator	
John Sumowski, UST Class A Operator	
Natalee Crumley, UST Class B Operator	
Natalee Crumley, UST Class B Operator	
Nicole Younger-Taylor, UST Class A Operator	nicole.younger-taylor@loafnjug.com
Nicole Younger-Taylor, UST Class A Operator	nicole.younger-taylor@loafnjug.com
Omair Bashir, UST Class A Operator	licensing@btcmstores.com
Randal Liebnow, UST Class A Operator	randy.liebnow@loafnjug.com
Scott Huether, UST Class B Global Operator	mtscorpion1963@msn.com
Stevie Ulstad, UST Class B Global Operator	crazyfroggie2003@yahoo.com
Stevie Ulstad, UST Class B Operator	crazyfroggie2003@yahoo.com
Theodore Bezel, UST Class A Operator	eglegaldept@eg-america.com
Theodore Bezel, UST Class A Operator	eglegaldept@eg-america.com
Theodore Bezel, UST Class B Global Operator	
Theodore Bezel, UST Class B Global Operator	
Theodore Bezel, UST Class B Operator	
Theodore Bezel, UST Class B Operator	
Timothy Osterman, UST Class B Global Operator	bigoproductions@msn.com

Tank Number	01	**Tank Age**	42	**Tank Installed Date**	04/27/1983	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	1627	**Spill Test Date**	09/29/2024	**Piping Installed Date**	10/23/1998	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**	08/05/2024	**Tank/Piping CP Test Date**	01/27/2025	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No

Capacity	8000	**ATG Test Date**	09/29/2024	**Line Tightness Test Date**	08/01/2019	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Manual Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	09/29/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	02	**Tank Age**	42	**Tank Installed Date**	04/27/1983	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	1628	**Spill Test Date**	09/29/2024	**Piping Installed Date**	10/23/1998	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**	08/05/2024	**Tank/Piping CP Test Date**	01/27/2025	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	01/27/2025	**Line Tightness Test Date**	08/01/2019	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Manual Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	01/27/2025			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	03	**Tank Age**	42	**Tank Installed Date**	04/27/1983	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	1629	**Spill Test Date**	01/27/2025	**Piping Installed Date**	10/23/1998	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**	08/05/2024	**Tank/Piping CP Test Date**	01/27/2024	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	01/27/2024	**Line Tightness Test Date**	08/01/2019	**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.1	**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	09/29/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Cascade County in the City of Great Falls

Location: BRAKE TIME 253721
601 Smelter Ave NW
Great Falls, MT 59404 Cascade

System Facility ID:07-05776

Facility Code: 18585
Last Inspected On: 02/10/2025
Operating Permit Renewal Date: 03/06/2028

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	SMELTER AVE GREAT FALL MT LLC	**(406) 727-8578**	**usmanbashir1254@gmail.com**
Operator Contact:	Nicole Younger-Taylor;Randal Liebnow;Theodore Bezel;Mini Mart Inc dba Loaf 'N Jug Pueblo	**(307) 871-7831;(513) 964-1568**	**eglegaldept@eg-america.com;nicole.younger-taylor@loafnjug.com;randy.liebnow@loafnjug.com**

Owner/Operator:	SMELTER AVE GREAT FALL MT LLC	(406) 727-8578	usmanbashir1254@gmail.com
	Hiede Richardson, UST Class B Global Operator		hiede.richardson@yahoo.com
	Hiede Richardson, UST Class B Global Operator		hiede.richardson@yahoo.com
	Jennifer Coleman, UST Class B Global Operator		
	Jennifer Coleman, UST Class B Global Operator		
	Nicole Younger-Taylor, UST Class A Operator		nicole.younger-taylor@loafnjug.com
	Nicole Younger-Taylor, UST Class A Operator		nicole.younger-taylor@loafnjug.com
	Nicole Younger-Taylor, UST Class A Operator		nicole.younger-taylor@loafnjug.com
	Randal Liebnow, UST Class A Operator		randy.liebnow@loafnjug.com
	Randal Liebnow, UST Class A Operator		randy.liebnow@loafnjug.com
	Randal Liebnow, UST Class B Global Operator		randy.liebnow@loafnjug.com
	Randal Liebnow, UST Class B Global Operator		randy.liebnow@loafnjug.com
	Scott Huether, UST Class B Global Operator		mtscorpion1963@msn.com
	Scott Huether, UST Class B Global Operator		mtscorpion1963@msn.com
	Stevie Ulstad, UST Class B Operator		crazyfroggie2003@yahoo.com
	Stevie Ulstad, UST Class B Operator		crazyfroggie2003@yahoo.com
	Theodore Bezel, UST Class A Operator		eglegaldept@eg-america.com
	Theodore Bezel, UST Class A Operator		eglegaldept@eg-america.com
	Theodore Bezel, UST Class A Operator		eglegaldept@eg-america.com
	Theodore Bezel, UST Class B Global Operator		
	Theodore Bezel, UST Class B Global Operator		
	Theodore Bezel, UST Class B Global Operator		
	Theodore Bezel, UST Class B Operator		
	Theodore Bezel, UST Class B Operator		
	Theodore Bezel, UST Class B Operator		
	Timothy Osterman, UST Class B Global Operator		bigoproductions@msn.com
	Timothy Osterman, UST Class B Global Operator		bigoproductions@msn.com

Timothy Osterman, UST Class B Operator bigoproductions@msn.com
Timothy Osterman, UST Class B Operator bigoproductions@msn.com
Toni Mullen, UST Class B Global Operator
Toni Mullen, UST Class B Global Operator

Tank Number	01	**Tank Age**	42	**Tank Installed Date**	04/27/1983	**Tank Material Construction**	STI - P3	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	3638	**Spill Test Date**	09/29/2024	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	09/29/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**	08/05/2024	**Tank/Piping CP Test Date**	01/25/2022	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring;ELLD 0.2	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	08/05/2024	**Line Tightness Test Date**	11/13/2020	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	01/27/2025			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	02	**Tank Age**	42	**Tank Installed Date**	04/27/1983	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	3639	**Spill Test Date**	01/27/2025	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	08/05/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**	09/29/2024	**Tank/Piping CP Test Date**	01/25/2022	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring;ELLD 0.2	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	08/05/2024	**Line Tightness Test Date**	11/13/2020	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	01/27/2025			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	03	**Tank Age**	42	**Tank Installed Date**	04/27/1983	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	3640	**Spill Test Date**	09/29/2024	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	08/05/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**	08/05/2024	**Tank/Piping CP Test Date**	01/25/2022	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring;ELLD 0.2	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	01/18/2023	**Line Tightness Test Date**	11/13/2020	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No

		Overfill Test Date	01/27/2025			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Cascade County in the City of Great Falls

Location: CARLS AUTOCARE INC
2300 10th Ave S
Great Falls, MT 59405-2968 Cascade

System Facility ID:07-00621

Facility Code: 18355
Last Inspected On: 12/05/2023
Operating Permit Renewal Date: 03/18/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Carl Halcro	**(406) 761-1342**	**carlsautocare@yahoo.com**
Operator Contact:	Carl Halcro	**(406) 761-1342**	**carlsautocare@yahoo.com**

Owner/Operator: Carl Halcro (406) 761-1342 carlsautocare@yahoo.com

Carl Halcro, UST Class A Operator carlsautocare@yahoo.com

Paul Halcro, UST Class B Operator phalcro1@yahoo.com

Tank Number	05	**Tank Age**	39	**Tank Installed Date**	01/27/1986	**Tank Material Construction**	Steel Clad	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	1264	**Spill Test Date**	12/05/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	03/28/2023	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	03/04/2021	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	03/12/2024	**Line Tightness Test Date**	03/03/2021	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	12/04/2023			**ATG Type**	Veeder Root/TLS-4I, B, C				
Tank Number	06	**Tank Age**	39	**Tank Installed Date**	01/27/1986	**Tank Material Construction**	Steel Clad	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	1265	**Spill Test Date**	12/05/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	03/28/2024	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	03/04/2021	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**	03/12/2024	**Line Tightness Test Date**	03/03/2021	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	12/04/2023			**ATG Type**	Veeder Root/TLS-4I, B, C				
Tank Number	07	**Tank Age**	39	**Tank Installed Date**	01/27/1986	**Tank Material Construction**	Steel Clad	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	1266	**Spill Test Date**	12/05/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No

Status	**Currently in Use**	**MLLD Test Date**	03/28/2023	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	03/04/2021	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**	03/12/2024	**Line Tightness Test Date**	03/03/2021	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	12/04/2023			**ATG Type**	Veeder Root/TLS-4I, B, C				

Facility Summary in Cascade County in the City of Great Falls

Location: CASCADE COUNTY SHERIFFS OFFICE
3800 Ulm N Frontage Rd
Great Falls, MT 59404-5574 Cascade

System Facility ID:07-13772

Facility Code: 19066
Last Inspected On: 08/31/2020
Operating Permit Renewal Date: 09/12/2023

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:

Operator Contact:

Tank Number	02	**Tank Age**	28	**Tank Installed Date**	05/06/1997	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	
Tag Number	4489	**Spill Test Date**	08/04/2021	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**	08/05/2021	**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	U.S. Suction	**CP Met Types**	Galvanic
Product	Oil, Waste	**PLLD Test Date**		**Tank/Piping CP Test Date**	11/10/2020	**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	3-Year Line Tightness Test	**Vapor Recovery**	No
Capacity	1200	**ATG Test Date**	08/04/2021	**Line Tightness Test Date**	11/20/2020	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	S1	**Tank Age**	28	**Tank Installed Date**	05/06/1997	**Tank Material Construction**	Unknown	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	537	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	Yes
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**	09/02/2014	**Catastrophic L.D. Type 3.0**	Continuous Interstitial Monitoring	**Piping Type**	Pressurized	**CP Met Types**	
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					

Facility Summary in Cascade County in the City of Great Falls

Location: CIRCLE K STORE 2746010
1601 Fox Farm Rd
Great Falls, MT 59404-3338 Cascade

System Facility ID:07-09914

Facility Code: 18792
Last Inspected On: 08/11/2023
Operating Permit Renewal Date: 12/04/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Rocky Mountain Oil LLC	**(602) 728-8000**	**NT-ESS@Circlek.com**
Operator Contact:	Veronica Rivera		**ESS-WestCoast@circlek.com**

Owner/Operator:	Rocky Mountain Oil LLC	(602) 728-8000	NT-ESS@Circlek.com
	Brad Lee, UST Class B Global Operator		brad.lee@holidaycompanies.com
	Brad Lee, UST Class B Global Operator		brad.lee@holidaycompanies.com
	Jeff Reed, UST Class B Global Operator		jeff.reed@holidaycompanies.com
	Jeff Reed, UST Class B Global Operator		jeff.reed@holidaycompanies.com
	Veronica Rivera, UST Class A Operator		ESS-WestCoast@circlek.com
	Veronica Rivera, UST Class A Operator		ESS-WestCoast@circlek.com

Tank Number	06	**Tank Age**	27	**Tank Installed Date**	06/16/1998	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve;High Level Alarm
Tag Number	1697	**Spill Test Date**	06/26/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	06/26/2023	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	Yes
Capacity	15000	**ATG Test Date**	06/26/2023	**Line Tightness Test Date**	04/11/2020	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	06/26/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	07	**Tank Age**	27	**Tank Installed Date**	06/16/1998	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve;High Level Alarm
Tag Number	1698	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	06/30/2020	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	Yes
Capacity	8000	**ATG Test Date**		**Line Tightness Test Date**	03/10/2020	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No

		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	08	**Tank Age**	27	**Tank Installed Date**	06/16/1998	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve;High Level Alarm
Tag Number	1699	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	06/30/2020	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**		**Line Tightness Test Date**	08/15/2020	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Cascade County in the City of Great Falls

Location: CIRCLE K STORE 2746059
601 Northwest Bypass
Great Falls, MT 59404-2480 Cascade

System Facility ID:07-13729

Facility Code: 19059
Last Inspected On: 06/26/2023
Operating Permit Renewal Date: 12/04/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Rocky Mountain Oil LLC	**(602) 728-8000**	**NT-ESS@Circlek.com**
Operator Contact:	Veronica Rivera		**ESS-WestCoast@circlek.com**

Owner/Operator:	Rocky Mountain Oil LLC	(602) 728-8000	NT-ESS@Circlek.com
	Brad Lee, UST Class B Operator		brad.lee@holidaycompanies.com
	Brad Lee, UST Class B Operator		brad.lee@holidaycompanies.com
	Brad Lee, UST Class B Operator		brad.lee@holidaycompanies.com
	Jeff Reed, UST Class B Global Operator		jeff.reed@holidaycompanies.com
	Jeff Reed, UST Class B Global Operator		jeff.reed@holidaycompanies.com
	Jeff Reed, UST Class B Global Operator		jeff.reed@holidaycompanies.com
	Veronica Rivera, UST Class A Operator		ESS-WestCoast@circlek.com
	Veronica Rivera, UST Class A Operator		ESS-WestCoast@circlek.com
	Veronica Rivera, UST Class A Operator		ESS-WestCoast@circlek.com

Tank Number	01	**Tank Age**	29	**Tank Installed Date**	07/17/1996	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	3359	**Spill Test Date**	06/26/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	07/14/2022	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	06/26/2023	**Tank/Piping CP Test Date**	11/06/2012	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	Yes
Capacity	12000	**ATG Test Date**	06/26/2023	**Line Tightness Test Date**	05/25/2017	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	06/26/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	02	**Tank Age**	29	**Tank Installed Date**	07/17/1996	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	3360	**Spill Test Date**	06/26/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	07/14/2022	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible

Product	Gasoline	**PLLD Test Date**	06/26/2023	**Tank/Piping CP Test Date**	11/06/2012	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	Yes
Capacity	8000	**ATG Test Date**	06/26/2023	**Line Tightness Test Date**	05/21/2017	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	06/26/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	03	**Tank Age**	29	**Tank Installed Date**	07/17/1996	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	3361	**Spill Test Date**	06/26/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	07/14/2022	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	06/26/2023	**Tank/Piping CP Test Date**	11/06/2012	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	06/26/2023	**Line Tightness Test Date**	05/17/2017	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	06/26/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Cascade County in the City of Great Falls

Location: CIRCLE K STORE 2746273
1020 15th St. N
Great Falls, MT 59401-1238 Cascade

System Facility ID:07-08069

Facility Code: 18687
Last Inspected On: 08/11/2023
Operating Permit Renewal Date: 12/04/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Rocky Mountain Oil LLC	**(602) 728-8000**	**NT-ESS@Circlek.com**
Operator Contact:	Veronica Rivera		**ESS-WestCoast@circlek.com**

Owner/Operator:	Rocky Mountain Oil LLC	(602) 728-8000	NT-ESS@Circlek.com
	Brad Lee, UST Class B Global Operator		brad.lee@holidaycompanies.com
	Brad Lee, UST Class B Global Operator		brad.lee@holidaycompanies.com
	Jeff Reed, UST Class B Global Operator		jeff.reed@holidaycompanies.com
	Jeff Reed, UST Class B Global Operator		jeff.reed@holidaycompanies.com
	Veronica Rivera, UST Class A Operator		ESS-WestCoast@circlek.com
	Veronica Rivera, UST Class A Operator		ESS-WestCoast@circlek.com

Tank Number	04	**Tank Age**	27	**Tank Installed Date**	05/15/1998	**Tank Material Construction**	Steel Clad	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	2995	**Spill Test Date**	07/21/2022	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**	06/30/2020	**Tank/Piping CP Test Date**	09/16/2009	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**		**Line Tightness Test Date**	03/08/2020	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	07/21/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	05	**Tank Age**	27	**Tank Installed Date**	05/15/1998	**Tank Material Construction**	Steel Clad	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	2996	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**	06/30/2020	**Tank/Piping CP Test Date**	09/16/2009	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No

Capacity	8000	**ATG Test Date**		**Line Tightness Test Date**	03/26/2020	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	06	**Tank Age**	27	**Tank Installed Date**	05/15/1998	**Tank Material Construction**	Steel Clad	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	2997	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**	06/30/2020	**Tank/Piping CP Test Date**	09/16/2009	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**		**Line Tightness Test Date**	03/06/2020	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Cascade County in the City of Great Falls

Location: CIRCLE K STORE 2746724
2260 10th Ave S
Great Falls, MT 59405 Cascade

System Facility ID:56-13975

Facility Code: 30637
Last Inspected On: 11/06/2024
Operating Permit Renewal Date: 03/30/2028

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Rocky Mountain Oil LLC **(602) 728-8000** **NT-ESS@Circlek.com**

Operator Contact: Veronica Rivera **ESS-WestCoast@circlek.com**

Owner/Operator: Rocky Mountain Oil LLC (602) 728-8000 NT-ESS@Circlek.com

Brad Lee, UST Class B Global Operator brad.lee@holidaycompanies.com
Jeff Reed, UST Class B Global Operator jeff.reed@holidaycompanies.com
Veronica Rivera, UST Class A Operator ESS-WestCoast@circlek.com

Tank Number	01	**Tank Age**	25	**Tank Installed Date**	10/01/2000	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve;High Level Alarm
Tag Number	4219	**Spill Test Date**	11/06/2024	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	06/25/2024	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	15000	**ATG Test Date**	06/25/2024	**Line Tightness Test Date**	07/20/2018	**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	06/25/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	02	**Tank Age**	25	**Tank Installed Date**	10/01/2000	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve;High Level Alarm
Tag Number	4220	**Spill Test Date**	11/06/2024	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	06/25/2024	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	06/25/2024	**Line Tightness Test Date**	07/20/2018	**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No

		Overfill Test Date	06/25/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Cascade County in the City of Great Falls

Location: CIRCLE K STORE 2746730
1428 3rd St NW
Great Falls, MT 59404-1928 Cascade

System Facility ID:56-13970

Facility Code: 30632
Last Inspected On: 11/06/2024
Operating Permit Renewal Date: 03/30/2028

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Rocky Mountain Oil LLC	**(602) 728-8000**	**NT-ESS@Circlek.com**
Operator Contact:	Veronica Rivera		**ESS-WestCoast@circlek.com**

Owner/Operator:	Rocky Mountain Oil LLC	(602) 728-8000	NT-ESS@Circlek.com
	Brad Lee, UST Class B Global Operator		brad.lee@holidaycompanies.com
	Brad Lee, UST Class B Global Operator		brad.lee@holidaycompanies.com
	Jeff Reed, UST Class B Global Operator		jeff.reed@holidaycompanies.com
	Jeff Reed, UST Class B Global Operator		jeff.reed@holidaycompanies.com
	Veronica Rivera, UST Class A Operator		ESS-WestCoast@circlek.com
	Veronica Rivera, UST Class A Operator		ESS-WestCoast@circlek.com

Tank Number	01	**Tank Age**	25	**Tank Installed Date**	07/07/2000	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve;High Level Alarm
Tag Number	4203	**Spill Test Date**	11/06/2024	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	06/25/2024	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	15000	**ATG Test Date**	06/25/2024	**Line Tightness Test Date**	10/29/2018	**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	06/25/2024			**ATG Type**	Veeder Root/TLS-450				
Tank Number	02	**Tank Age**	25	**Tank Installed Date**	07/07/2000	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve;High Level Alarm
Tag Number	4204	**Spill Test Date**	11/06/2024	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	06/25/2024	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	06/25/2024	**Line Tightness Test Date**	06/14/2018	**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No

		Overfill Test Date	06/25/2024			**ATG Type**	Veeder Root/TLS-450				

Facility Summary in Cascade County in the City of Great Falls

Location: CITY MOTOR CO INC
3900 10th Ave S
Great Falls, MT 59405-3648 Cascade

System Facility ID:07-05853

Facility Code: 18597
Last Inspected On: 03/27/2023
Operating Permit Renewal Date: 07/01/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: City Motors **(406) 761-4900** **johnk@citymotor.com**

Operator Contact: Kelly Qunell **kellyq@citymotor.com**

Owner/Operator: City Motors (406) 761-4900 johnk@citymotor.com

Kelly Qunell, UST Class A Operator kellyq@citymotor.com

Kelly Qunell, UST Class B Operator kellyq@citymotor.com

Tank Number	06	**Tank Age**	36	**Tank Installed Date**	09/01/1989	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	2365	**Spill Test Date**	03/27/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	02/04/2020	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	3000	**ATG Test Date**	03/27/2023	**Line Tightness Test Date**	02/04/2020	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	03/27/2023			**ATG Type**	EMCO Electronics/EECO 1500				
Tank Number	07	**Tank Age**	36	**Tank Installed Date**	09/01/1989	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	2366	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	U.S. Suction	**CP Met Types**	Non-corrodible
Product	Oil, Waste	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	3-Year Line Tightness Test	**Vapor Recovery**	No
Capacity	3000	**ATG Test Date**	03/27/2023	**Line Tightness Test Date**	03/27/2023	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**	EMCO Electronics/EECO 1500				

Facility Summary in Cascade County in the City of Great Falls

Location: CITY SHOP COMPLEX
1025 25th Ave NE
Great Falls, MT 59404-1602 Cascade

System Facility ID:07-05558

Facility Code: 18570
Last Inspected On: 01/02/2019
Operating Permit Renewal Date: 01/10/2022

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	City of Great Falls	**(406) 771-1258**	
Operator Contact:	Dale Calvert;Doug Alm	**(406) 771-1401**	**dalm@greatfallsmt.net;dcalvert@greatfallsmt.net**

Dale Calvert, UST Class A Operator	dcalvert@greatfallsmt.net
Dale Calvert, UST Class B Global Operator	dcalvert@greatfallsmt.net
Doug Alm, UST Class A Operator	dalm@greatfallsmt.net
Doug Alm, UST Class B Global Operator	dalm@greatfallsmt.net
Doug Alm, UST Class B Operator	dalm@greatfallsmt.net

Tank Number	06	**Tank Age**	35	**Tank Installed Date**	02/23/1990	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	640	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**	12/17/2018	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	05/16/2019	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	20000	**ATG Test Date**		**Line Tightness Test Date**	12/17/2018	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**	Veeder Root/TLS-450				
Tank Number	07	**Tank Age**	35	**Tank Installed Date**	02/23/1990	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	641	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**	12/17/2018	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	05/16/2019	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	20000	**ATG Test Date**		**Line Tightness Test Date**	12/17/2018	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**	Veeder Root/TLS-450				

Tank Number	08	**Tank Age**	35	**Tank Installed Date**	02/23/1990	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	642	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	05/16/2019	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**		**Line Tightness Test Date**	03/18/2013	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**	Veeder Root/TLS-450				

Facility Summary in Cascade County in the City of Great Falls

Location: FEDERAL AVIATION ADMIN AIRWAY TERMINAL
2830 Airport Ave A
Great Falls, MT 59404-5544 Cascade

System Facility ID:07-02558

Facility Code: 18445
Last Inspected On: 03/11/2021
Operating Permit Renewal Date: 03/26/2024

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Federal Aviation Admin Great Falls	**(406) 788-8041**	**joe.konesky@faa.gov**
Operator Contact:	Joe Konesky		**joe.konesky@faa.gov**

Joe Konesky, UST Class A Operator joe.konesky@faa.gov
Joe Konesky, UST Class B Global Operator joe.konesky@faa.gov

Tank Number	S2	**Tank Age**	28	**Tank Installed Date**	07/31/1997	**Tank Material Construction**	Unknown	**Piping Material**	Flexible Plastic	**Overfill Types**	
Tag Number	1048	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	Yes
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**	05/07/2012	**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	U.S. Suction	**CP Met Types**	
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Deferred	**Primary Pipe Leak Detection**	3-Year Line Tightness Test	**Vapor Recovery**	No
Capacity	1500	**ATG Test Date**		**Line Tightness Test Date**	03/11/2021	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					

Facility Summary in Cascade County in the City of Great Falls

Location: FEDERAL AVIATION ADMIN ARSR 4
Bootlegger Rdg
Great Falls, MT 59401 Cascade

System Facility ID:07-13710

Facility Code: 19056
Last Inspected On: 02/06/2024
Operating Permit Renewal Date: 06/15/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Federal Aviation Admin Great Falls	**(406) 788-8041**	**joe.konesky@faa.gov**
Operator Contact:	Joe Konesky		**joe.konesky@faa.gov**

Owner/Operator: Federal Aviation Admin Great Falls (406) 788-8041 joe.konesky@faa.gov

Joe Konesky, UST Class A Operator joe.konesky@faa.gov

Joe Konesky, UST Class B Global Operator joe.konesky@faa.gov

Tank Number	S1	**Tank Age**	29	**Tank Installed Date**	04/01/1996	**Tank Material Construction**	Unknown	**Piping Material**	Flexible Plastic	**Overfill Types**	
Tag Number	4564	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	Yes
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	03/24/2021	**Catastrophic L.D. Type 3.0**	Auto Dialer;Continuous Interstitial Monitoring	**Piping Type**	Pressurized	**CP Met Types**	
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	2000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					

Facility Summary in Cascade County in the City of Great Falls

Location: GAS N SHOP
101 Smelter Ave NE
Great Falls, MT 59404 Cascade

System Facility ID:07-05851

Facility Code: 18595
Last Inspected On: 12/04/2023
Operating Permit Renewal Date: 03/27/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Muhar LLC;Sandeep Muhar	**(406) 624-6912;(406) 750-0708**	**gasnshop133@gmail.com**
Operator Contact:	Gurinderbir Muhar;Harinder Singh	**(406) 868-2062;(408) 660-9884**	**gasnshop133@gmail.com;inder4030@yahoo.com**

Owner/Operator: Muhar LLC (406) 624-6912

Owner/Operator: Sandeep Muhar (406) 624-6912

Frank Kruse, UST Class B Operator	wfkruse79@yahoo.com
Gurinderbir Muhar, UST Class A Operator	gasnshop133@gmail.com
Gurinderbir Muhar, UST Class B Global Operator	gasnshop133@gmail.com
Harinder Singh, UST Class A Operator	inder4030@yahoo.com
Sandeep Muhar, UST Class B Global Operator	gasnshop133@gmail.com

Tank Number	06	**Tank Age**	37	**Tank Installed Date**	07/21/1988	**Tank Material Construction**	Steel Clad	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	1251	**Spill Test Date**	11/15/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	11/15/2023	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	11/15/2023	**Line Tightness Test Date**	02/28/2006	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	11/15/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	07	**Tank Age**	37	**Tank Installed Date**	07/21/1988	**Tank Material Construction**	Steel Clad	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	1252	**Spill Test Date**	11/15/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	11/15/2023	**Line Tightness Test Date**	09/26/2020	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No

		Overfill Test Date	11/15/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	08	**Tank Age**	37	**Tank Installed Date**	07/21/1988	**Tank Material Construction**	Steel Clad	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	1253	**Spill Test Date**	11/15/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	11/15/2023	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	11/15/2023	**Line Tightness Test Date**	09/28/2020	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	11/15/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Cascade County in the City of Great Falls

Location: GAS N SHOP 2
101 Truman Ave
Great Falls, MT 59404-6210 Cascade

System Facility ID:07-00097

Facility Code: 18333
Last Inspected On: 12/04/2023
Operating Permit Renewal Date: 03/13/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Sandeep Muhar	**(406) 750-0708**	**gasnshop133@gmail.com**
Operator Contact:	Gurinderbir Muhar;Perry Joyce	**(408) 660-9884**	**gasnshop133@gmail.com**

Owner/Operator: Sandeep Muhar (406) 750-0708 gasnshop133@gmail.com

Gurinderbir Muhar, UST Class A Operator gasnshop133@gmail.com
Gurinderbir Muhar, UST Class B Global Operator gasnshop133@gmail.com
Kevin Joyce, UST Class B Global Operator kjshamrock13@gmail.com
Kevin Joyce, UST Class B Global Operator kjshamrock13@gmail.com
Maureen Pettis, UST Class B Operator joycostroes.sp@gmail.com
Maureen Pettis, UST Class B Operator joycostroes.sp@gmail.com
Perry Joyce, UST Class A Operator
Perry Joyce, UST Class A Operator
Sandeep Muhar, UST Class B Global Operator gasnshop133@gmail.com

Tank Number	04	**Tank Age**	35	**Tank Installed Date**	03/04/1990	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve
Tag Number	3545	**Spill Test Date**	11/15/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	11/15/2023	**Tank/Piping CP Test Date**	02/14/2005	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	11/15/2023	**Line Tightness Test Date**	12/09/2020	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	11/15/2023			**ATG Type**	Veeder Root/TLS-450				
Tank Number	05	**Tank Age**	35	**Tank Installed Date**	03/04/1990	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	3546	**Spill Test Date**	11/15/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible

Product	Diesel	**PLLD Test Date**	11/15/2023	**Tank/Piping CP Test Date**	02/14/2005	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	11/15/2023	**Line Tightness Test Date**	12/09/2020	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	11/15/2023			**ATG Type**	Veeder Root/TLS-450				
Tank Number	06	**Tank Age**	35	**Tank Installed Date**	03/04/1990	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	3547	**Spill Test Date**	11/15/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	11/15/2023	**Tank/Piping CP Test Date**	02/14/2005	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	11/15/2023	**Line Tightness Test Date**	12/09/2020	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	11/15/2023			**ATG Type**	Veeder Root/TLS-450				

Facility Summary in Cascade County in the City of Great Falls

Location: GENERAL DISTRIBUTING CO INC
430 17th Ave NE
Great Falls, MT 59404-1936 Cascade

System Facility ID:07-00081

Facility Code: 18325
Last Inspected On: 04/07/2023
Operating Permit Renewal Date: 04/05/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: General Distributing Co Inc **(406) 454-1351**

Operator Contact: Sean Kelley **(406) 454-1351** **skelley@gendco.com**

Owner/Operator: General Distributing Co Inc (406) 454-1351

Sean Kelley, UST Class A Operator skelley@gendco.com

Sean Kelley, UST Class B Global Operator skelley@gendco.com

Tank Number	01	**Tank Age**	47	**Tank Installed Date**	02/14/1978	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	1206	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Temporarily Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Deferred	**Vapor Recovery**	No
Capacity	2000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	02	**Tank Age**	47	**Tank Installed Date**	02/14/1978	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	1207	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Temporarily Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Deferred	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	03	**Tank Age**	47	**Tank Installed Date**	02/14/1978	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve

Tag Number	1208	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Temporarily Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Deferred	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					

Facility Summary in Cascade County in the City of Great Falls

Location: GREAT FALLS FIRE STATION 1 GREAT FALLS
105 9th St S
Great Falls, MT 59401-3715 Cascade

System Facility ID:07-00680

Facility Code: 18359
Last Inspected On: 01/02/2019
Operating Permit Renewal Date: 01/10/2022

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	City of Great Falls	**(406) 771-1258**	
Operator Contact:	Dale Calvert;Doug Alm	**(406) 771-1401**	**dalm@greatfallsmt.net;dcalvert@greatfallsmt.net**

Dale Calvert, UST Class A Operator	dcalvert@greatfallsmt.net
Dale Calvert, UST Class A Operator	dcalvert@greatfallsmt.net
Doug Alm, UST Class A Operator	dalm@greatfallsmt.net
Doug Alm, UST Class A Operator	dalm@greatfallsmt.net
Doug Alm, UST Class B Global Operator	dalm@greatfallsmt.net
Doug Alm, UST Class B Global Operator	dalm@greatfallsmt.net
Doug Alm, UST Class B Operator	dalm@greatfallsmt.net
Doug Alm, UST Class B Operator	dalm@greatfallsmt.net

Tank Number	03	**Tank Age**	34	**Tank Installed Date**	04/22/1991	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	636	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Single Walled	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**	12/26/2018	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	05/16/2019	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	4172	**ATG Test Date**		**Line Tightness Test Date**	12/26/2018	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**	Veeder Root/TLS-450				
Tank Number	04	**Tank Age**	34	**Tank Installed Date**	04/22/1991	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	637	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Single Walled	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**	12/26/2018	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	05/16/2019	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No

Capacity	4172	**ATG Test Date**		**Line Tightness Test Date**	12/26/2018	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**	Veeder Root/TLS-450				
Tank Number	05	**Tank Age**	34	**Tank Installed Date**	04/22/1991	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	638	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Single Walled	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**	12/26/2018	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	05/16/2019	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	20000	**ATG Test Date**		**Line Tightness Test Date**	12/26/2018	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**	Veeder Root/TLS-450				

Facility Summary in Cascade County in the City of Great Falls

Location: GREAT FALLS INTERNATIONAL AIRPORT FUEL FARM 1
1931 Airport Ct
Great Falls, MT 59404-5599 Cascade

System Facility ID:07-10676

Facility Code: 18828
Last Inspected On: 09/01/2022
Operating Permit Renewal Date: 10/11/2019

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Great Falls International Airport

Operator Contact: Mike Cunningham;Rod Hall **(406) 727-3404;(406) 781-7242** **mikefra1@msn.com;rod@flygtf.com**

Owner/Operator: Great Falls International Airport

Mike Cunningham, UST Class A Operator	mikefra1@msn.com
Mike Cunningham, UST Class B Operator	mikefra1@msn.com
Rod Hall, UST Class A Operator	rod@flygtf.com
Rod Hall, UST Class A Operator	rod@flygtf.com
Rod Hall, UST Class B Operator	rod@flygtf.com
Rod Hall, UST Class B Operator	rod@flygtf.com

Tank Number	01	**Tank Age**	51	**Tank Installed Date**	04/03/1974	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	No Piping	**Overfill Types**	High Level Alarm
Tag Number	3740	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**	Lined Interior/Impressed Current	**Piping Construction**	None	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	U.S. Suction	**CP Met Types**	Impressed Current
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	09/04/2014	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Deferred	**Vapor Recovery**	No
Capacity	30550	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	02	**Tank Age**	51	**Tank Installed Date**	04/03/1974	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	No Piping	**Overfill Types**	High Level Alarm
Tag Number	3741	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**	Lined Interior/Impressed Current	**Piping Construction**	None	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	U.S. Suction	**CP Met Types**	Impressed Current
Product	Aviation Gas	**PLLD Test Date**		**Tank/Piping CP Test Date**	09/04/2014	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Deferred	**Vapor Recovery**	No

Capacity	30550	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	03	**Tank Age**	51	**Tank Installed Date**	04/03/1974	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	No Piping	**Overfill Types**	High Level Alarm
Tag Number	3742	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**	Lined Interior/Impressed Current	**Piping Construction**	None	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	U.S. Suction	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	09/04/2014	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Deferred	**Vapor Recovery**	No
Capacity	30550	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	04	**Tank Age**	51	**Tank Installed Date**	04/03/1974	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	No Piping	**Overfill Types**	High Level Alarm
Tag Number	3743	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**	Lined Interior/Impressed Current	**Piping Construction**	None	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	U.S. Suction	**CP Met Types**	Impressed Current
Product	Jet Fuel (Jet-A, Jet-A1, JP5)	**PLLD Test Date**		**Tank/Piping CP Test Date**	09/04/2014	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Deferred	**Vapor Recovery**	No
Capacity	30550	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	05	**Tank Age**	51	**Tank Installed Date**	04/03/1974	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	No Piping	**Overfill Types**	High Level Alarm
Tag Number	3744	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**	Lined Interior/Impressed Current	**Piping Construction**	None	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	U.S. Suction	**CP Met Types**	Impressed Current
Product	Jet Fuel (Jet-A, Jet-A1, JP5)	**PLLD Test Date**		**Tank/Piping CP Test Date**	09/04/2014	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Deferred	**Vapor Recovery**	No
Capacity	30550	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Tank Number	06	**Tank Age**	51	**Tank Installed Date**	04/03/1974	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	No Piping	**Overfill Types**	High Level Alarm
Tag Number	3745	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**	Lined Interior/Impressed Current	**Piping Construction**	None	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	U.S. Suction	**CP Met Types**	Impressed Current
Product	Jet Fuel (Jet-A, Jet-A1, JP5)	**PLLD Test Date**		**Tank/Piping CP Test Date**	09/04/2014	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Deferred	**Vapor Recovery**	No
Capacity	30000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	07	**Tank Age**	51	**Tank Installed Date**	04/03/1974	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	No Piping	**Overfill Types**	High Level Alarm
Tag Number	3746	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**	Lined Interior/Impressed Current	**Piping Construction**	None	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	U.S. Suction	**CP Met Types**	Impressed Current
Product	Jet Fuel (Jet-A, Jet-A1, JP5)	**PLLD Test Date**		**Tank/Piping CP Test Date**	09/04/2014	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Deferred	**Vapor Recovery**	No
Capacity	38000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	08	**Tank Age**	51	**Tank Installed Date**	04/03/1974	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	No Piping	**Overfill Types**	High Level Alarm
Tag Number	3747	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**	Lined Interior/Impressed Current	**Piping Construction**	None	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	U.S. Suction	**CP Met Types**	Impressed Current
Product	Jet Fuel (Jet-A, Jet-A1, JP5)	**PLLD Test Date**		**Tank/Piping CP Test Date**	09/04/2014	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Deferred	**Vapor Recovery**	No
Capacity	50000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	09	**Tank Age**	51	**Tank Installed Date**	04/03/1974	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	No Piping	**Overfill Types**	High Level Alarm
Tag Number	3748	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**	Lined Interior/Impressed Current	**Piping Construction**	None	**AST**	No

Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	U.S. Suction	**CP Met Types**	Impressed Current
Product	Jet Fuel (Jet-A, Jet-A1, JP5)	**PLLD Test Date**		**Tank/Piping CP Test Date**	09/04/2014	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Deferred	**Vapor Recovery**	No
Capacity	50000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	10	**Tank Age**	30	**Tank Installed Date**	11/01/1995	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	No Piping	**Overfill Types**	High Level Alarm
Tag Number	3749	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Not Listed	**CP Met Types**	Non-corrodible
Product	Jet Fuel (Jet-A, Jet-A1, JP5)	**PLLD Test Date**		**Tank/Piping CP Test Date**	08/31/2006	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	20000	**ATG Test Date**	09/01/2022	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	10/10/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	11	**Tank Age**	30	**Tank Installed Date**	11/01/1995	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	No Piping	**Overfill Types**	High Level Alarm
Tag Number	3750	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Not Listed	**CP Met Types**	Non-corrodible
Product	Aviation Gas	**PLLD Test Date**		**Tank/Piping CP Test Date**	08/31/2006	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	20000	**ATG Test Date**	09/01/2022	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	10/10/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Cascade County in the City of Great Falls

Location: GREAT FALLS SINCLAIR
620 57th St S
Great Falls, MT 59405-3940 Cascade

System Facility ID:07-02087

Facility Code: 18422
Last Inspected On: 03/31/2021
Operating Permit Renewal Date: 03/31/2024

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Set Five LLC Harlowtown	**(406) 632-4630**	**jwoodsoil@aol.com**
Operator Contact:	Derek Richardson;Greg Haines;William Raaen	**(406) 231-9465;(406) 590-2667;(406) 750-0090**	**setfive@hotmail.com;setfive01@outlook.com;wtraaen@gmail.com**

Derek Richardson, UST Class A Operator	setfive@hotmail.com
Derek Richardson, UST Class A Operator	setfive@hotmail.com
Derek Richardson, UST Class B Global Operator	setfive@hotmail.com
Derek Richardson, UST Class B Global Operator	setfive@hotmail.com
Greg Haines, UST Class A Operator	setfive01@outlook.com
Greg Haines, UST Class A Operator	setfive01@outlook.com
Greg Haines, UST Class B Operator	setfive01@outlook.com
Greg Haines, UST Class B Operator	setfive01@outlook.com
Mitzi McIntosh, UST Class B Operator	jstbnmitzi@yahoo.com
Mitzi McIntosh, UST Class B Operator	jstbnmitzi@yahoo.com
NayOmie Bean, UST Class B Global Operator	
NayOmie Bean, UST Class B Global Operator	
Norm Jensen, UST Class B Operator	maui2@bresnan.net
Norm Jensen, UST Class B Operator	maui2@bresnan.net
Roberta Gresham, UST Class B Operator	
Roberta Gresham, UST Class B Operator	
Thomas Ohagan, UST Class B Global Operator	ohagan@rock.com
Thomas Ohagan, UST Class B Global Operator	ohagan@rock.com
William Raaen, UST Class A Operator	wtraaen@gmail.com
William Raaen, UST Class A Operator	wtraaen@gmail.com
William Raaen, UST Class B Operator	wtraaen@gmail.com
William Raaen, UST Class B Operator	wtraaen@gmail.com

Tank Number	01	**Tank Age**	47	**Tank Installed Date**	04/04/1978	**Tank Material Construction**	Bare Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	1933	**Spill Test Date**	09/09/2020	**Piping Installed Date**	04/29/1998	**Tank Construction**		**Piping Construction**	None	**AST**	No

Status	**Permanently Out of Use**	**MLLD Test Date**	09/09/2020	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	09/09/2020	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	16000	**ATG Test Date**		**Line Tightness Test Date**	09/09/2020	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	09/09/2020			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	02	**Tank Age**	47	**Tank Installed Date**	04/04/1978	**Tank Material Construction**	Bare Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	1934	**Spill Test Date**	09/09/2020	**Piping Installed Date**	04/29/1998	**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**	09/09/2020	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	09/09/2020	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	16000	**ATG Test Date**		**Line Tightness Test Date**	09/09/2020	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	09/09/2020			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	03	**Tank Age**	47	**Tank Installed Date**	04/04/1978	**Tank Material Construction**	Bare Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	1935	**Spill Test Date**	09/09/2020	**Piping Installed Date**	04/29/1998	**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**	09/09/2020	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	09/09/2020	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	24000	**ATG Test Date**		**Line Tightness Test Date**	09/09/2020	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	09/09/2020			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Cascade County in the City of Great Falls

Location: GREAT FALLS TRANSIT DISTRICT
3905 N Star Blvd
Great Falls, MT 59405-1036 Cascade

System Facility ID:07-05346

Facility Code: 18560
Last Inspected On: 02/26/2025
Operating Permit Renewal Date: 06/02/2028

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Great Falls Transit District	**(406) 727-0386**	**nhanning@gftransit.com**
Operator Contact:	Nadine Hanning	**(406) 727-0382**	**nhanning@gftransit.com**

Owner/Operator: Great Falls Transit District (406) 727-0386 nhanning@gftransit.com

Nadine Hanning, UST Class A Operator nhanning@gftransit.com

Shawn Mahoney, UST Class B Operator nhanning@gftransit.com

Tank Number	01	**Tank Age**	40	**Tank Installed Date**	05/06/1985	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	1233	**Spill Test Date**	02/26/2025	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Diesel	**PLLD Test Date**	09/04/2024	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	12380	**ATG Test Date**	09/04/2024	**Line Tightness Test Date**	02/08/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	02/26/2025			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	02	**Tank Age**	40	**Tank Installed Date**	05/06/1985	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	
Tag Number	1234	**Spill Test Date**	02/09/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Gravity Feed	**CP Met Types**	
Product	Oil, Waste	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	3-Year Line Tightness Test	**Vapor Recovery**	No
Capacity	1000	**ATG Test Date**	02/26/2025	**Line Tightness Test Date**	02/26/2025	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Cascade County in the City of Great Falls

Location: H AND R #1
3200 10th Ave S
Great Falls, MT 59405 Cascade

System Facility ID:07-00092

Facility Code: 18331
Last Inspected On: 09/19/2022
Operating Permit Renewal Date: 11/20/2025

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Singh Inc	**(406) 868-2062**	**inder4030@yahoo.com**
Operator Contact:	Harinder Singh;Rajinder Singh	**(406) 761-4791;(406) 868-2062**	**hrkinc101@gmail.com;inder4030@yahoo.com**

Owner/Operator: Singh Inc (406) 868-2062 inder4030@yahoo.com

Frank Kruse, UST Class B Global Operator	wfkruse79@yahoo.com
Frank Kruse, UST Class B Global Operator	wfkruse79@yahoo.com
Frank Kruse, UST Class B Operator	wfkruse79@yahoo.com
Frank Kruse, UST Class B Operator	wfkruse79@yahoo.com
Harinder Singh, UST Class A Operator	inder4030@yahoo.com
Rajinder Singh, UST Class A Operator	hrkinc101@gmail.com

Tank Number	01	**Tank Age**	55	**Tank Installed Date**	12/31/1970	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	3839	**Spill Test Date**	08/17/2022	**Piping Installed Date**		**Tank Construction**	Lined Interior/Impressed Current	**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	11/02/2022	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**	03/13/2023	**Tank/Piping CP Test Date**	09/07/2022	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.1	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	03/03/2023	**Line Tightness Test Date**	11/02/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	10/19/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Number	02	**Tank Age**	55	**Tank Installed Date**	12/31/1970	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	3840	**Spill Test Date**	08/17/2022	**Piping Installed Date**		**Tank Construction**	Lined Interior/Impressed Current	**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	11/02/2022	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**	09/06/2018	**Tank/Piping CP Test Date**	09/07/2022	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.1	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No

Capacity	10000	**ATG Test Date**	03/03/2023	**Line Tightness Test Date**	11/02/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	09/19/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Number	03	**Tank Age**	55	**Tank Installed Date**	12/31/1970	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	4440	**Spill Test Date**	08/17/2022	**Piping Installed Date**		**Tank Construction**	Lined Interior/Impressed Current	**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	11/02/2022	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Diesel	**PLLD Test Date**	03/13/2023	**Tank/Piping CP Test Date**	09/07/2022	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.1	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	03/03/2023	**Line Tightness Test Date**	11/02/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	09/19/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				

Facility Summary in Cascade County in the City of Great Falls

Location: H AND R #2
1300 12th Ave S
Great Falls, MT 59405 Cascade

System Facility ID:07-00082

Facility Code: 18326
Last Inspected On: 02/21/2024
Operating Permit Renewal Date: 05/29/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Singh Inc	**(406) 868-2062**	**inder4030@yahoo.com**
Operator Contact:	Harinder Singh;Rajinder Singh	**(406) 761-4791;(406) 868-2062**	**hrkinc101@gmail.com;inder4030@yahoo.com**

Owner/Operator: Singh Inc (406) 868-2062 inder4030@yahoo.com

Frank Kruse, UST Class B Global Operator	wfkruse79@yahoo.com
Frank Kruse, UST Class B Global Operator	wfkruse79@yahoo.com
Frank Kruse, UST Class B Operator	wfkruse79@yahoo.com
Frank Kruse, UST Class B Operator	wfkruse79@yahoo.com
Harinder Singh, UST Class A Operator	inder4030@yahoo.com
Rajinder Singh, UST Class A Operator	hrkinc101@gmail.com

Tank Number	03	**Tank Age**	14	**Tank Installed Date**	11/01/2011	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve
Tag Number	5339	**Spill Test Date**	04/13/2024	**Piping Installed Date**	10/11/2011	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	02/21/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	09/06/2023	**Tank/Piping CP Test Date**	09/13/2010	**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	09/06/2023	**Line Tightness Test Date**	12/07/2020	**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	06/14/2024			**ATG Type**	Gilbarco/TLS-350;Gilbarco-Veeder Root/TLS-350				
Tank Number	04	**Tank Age**	14	**Tank Installed Date**	11/01/2011	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve
Tag Number	5340	**Spill Test Date**	02/21/2024	**Piping Installed Date**	10/11/2011	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	02/21/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	09/06/2023	**Tank/Piping CP Test Date**	09/13/2010	**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No

Capacity	10000	**ATG Test Date**	09/06/2023	**Line Tightness Test Date**	12/05/2020	**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	06/14/2024			**ATG Type**	Gilbarco/TLS-350;Gilbarco-Veeder Root/TLS-350				

Facility Summary in Cascade County in the City of Great Falls

Location: H AND R #4
5600 3rd Ave S
Great Falls, MT 59405-1726 Cascade

System Facility ID:07-00090

Facility Code: 18330
Last Inspected On: 02/28/2025
Operating Permit Renewal Date: 03/14/2023

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	H and R Inc		**inder4030@yahoo.com**
Operator Contact:	Harinder Singh;Rajinder Singh	**(406) 761-4791;(406) 868-2062**	**hrkinc101@gmail.com;inder4030@yahoo.com**

Owner/Operator: H and R Inc — inder4030@yahoo.com

Frank Kruse, UST Class B Global Operator	wfkruse79@yahoo.com
Frank Kruse, UST Class B Global Operator	wfkruse79@yahoo.com
Frank Kruse, UST Class B Operator	wfkruse79@yahoo.com
Frank Kruse, UST Class B Operator	wfkruse79@yahoo.com
Harinder Singh, UST Class A Operator	inder4030@yahoo.com
Rajinder Singh, UST Class A Operator	hrkinc101@gmail.com

Tank Number	03	**Tank Age**	55	**Tank Installed Date**	12/31/1970	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	3838	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**	Lined Interior/Impressed Current	**Piping Construction**	Double Walled	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	12/04/2019	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	20000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	01	**Tank Age**	55	**Tank Installed Date**	12/31/1970	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	4439	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**	Lined Interior/Impressed Current	**Piping Construction**	Double Walled	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	12/04/2019	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No

Capacity	20000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	04	**Tank Age**	4	**Tank Installed Date**	08/03/2021	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	6074	**Spill Test Date**	02/25/2025	**Piping Installed Date**	08/03/2021	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	02/25/2025	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**	03/26/2024	**Tank/Piping CP Test Date**	11/16/2021	**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	Yes
Capacity	12000	**ATG Test Date**	02/25/2025	**Line Tightness Test Date**	11/24/2021	**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	02/25/2025			**ATG Type**					
Tank Number	05	**Tank Age**	4	**Tank Installed Date**	08/03/2021	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	6075	**Spill Test Date**	02/25/2025	**Piping Installed Date**	08/03/2021	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	02/25/2025	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**	03/26/2024	**Tank/Piping CP Test Date**	11/16/2021	**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	7000	**ATG Test Date**	02/25/2025	**Line Tightness Test Date**	11/24/2021	**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	02/25/2025			**ATG Type**					
Tank Number	06	**Tank Age**	4	**Tank Installed Date**	08/03/2021	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	6076	**Spill Test Date**	02/25/2025	**Piping Installed Date**	08/03/2021	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	02/25/2025	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**	03/26/2024	**Tank/Piping CP Test Date**	11/16/2021	**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	Yes
Capacity	5000	**ATG Test Date**	02/25/2025	**Line Tightness Test Date**	11/24/2021	**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	02/25/2025			**ATG Type**					

Facility Summary in Cascade County in the City of Great Falls

Location: H AND R 3 ON YOUR WAY
1608 Fox Farm Rd
Great Falls, MT 59404-3339 Cascade

System Facility ID:07-04945

Facility Code: 18550
Last Inspected On: 05/24/2023
Operating Permit Renewal Date: 09/03/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: H and R Inc **inder4030@yahoo.com**

Operator Contact:

Owner/Operator: H and R Inc inder4030@yahoo.com

Tank Number	02	**Tank Age**	57	**Tank Installed Date**	01/01/1968	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	1972	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Single Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**		**Line Tightness Test Date**	07/17/2024	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	03	**Tank Age**	57	**Tank Installed Date**	01/01/1968	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	1973	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**		**Line Tightness Test Date**	07/17/2024	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	05	**Tank Age**	28	**Tank Installed Date**	11/03/1997	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm

Tag Number	1974	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Single Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**		**Line Tightness Test Date**	07/17/2024	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	06	**Tank Age**	28	**Tank Installed Date**	11/01/1997	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	1975	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**		**Line Tightness Test Date**	02/21/2020	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Cascade County in the City of Great Falls

Location: HALL TRANSIT CO
2620 Upper River Rd
Great Falls, MT 59405-7231 Cascade

System Facility ID:07-06402

Facility Code: 18626
Last Inspected On: 09/01/2023
Operating Permit Renewal Date: 08/06/2023

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Hall Transit Co;Lynn Hall;Hall Transit Co	**(406) 945-1363**	**lynn.l.hall66@gmail.com**
Operator Contact:	Lynn Hall;Hall Transit Co	**(406) 945-1363**	**lynn.l.hall66@gmail.com**

Owner/Operator: Hall Transit Co

Owner/Operator: Lynn Hall,Hall Transit Co

Lynn Hall, UST Class A Operator lynn.l.hall66@gmail.com
Lynn Hall, UST Class B Operator lynn.l.hall66@gmail.com

Tank Number	02	**Tank Age**	34	**Tank Installed Date**	11/01/1991	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	1268	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Temporarily Out of Use**	**MLLD Test Date**	07/14/2020	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	07/14/2020	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**		**Line Tightness Test Date**	07/14/2020	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Cascade County in the City of Great Falls

Location: KEITHS COUNTRY STORE
1621 10th Ave S
Great Falls, MT 59405 Cascade

System Facility ID:07-01418

Facility Code: 18394
Last Inspected On: 09/25/2023
Operating Permit Renewal Date: 12/02/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Keiths Country Store **(406) 727-7114**

Operator Contact: David Keith **(406) 862-2578** **terionline@123mail.org**

Owner/Operator: Keiths Country Store (406) 727-7114

Anna Dion, UST Class B Operator	amvd86@hotmail.com
Anna Dion, UST Class B Operator	amvd86@hotmail.com
David Keith, UST Class A Operator	terionline@123mail.org
David Keith, UST Class A Operator	terionline@123mail.org
David Keith, UST Class B Operator	terionline@123mail.org
David Keith, UST Class B Operator	terionline@123mail.org

Tank Number	03	**Tank Age**	26	**Tank Installed Date**	04/01/1999	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	3988	**Spill Test Date**	06/07/2021	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	06/07/2021	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.1;ELLD 0.2	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**	06/07/2021	**Line Tightness Test Date**	05/05/2020	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	06/07/2021			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	04	**Tank Age**	26	**Tank Installed Date**	04/01/1999	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	3989	**Spill Test Date**	06/07/2021	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	06/07/2021	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.1;ELLD 0.2	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	06/07/2021	**Line Tightness Test Date**	04/27/2020	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No

		Overfill Test Date	06/07/2021			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	05	**Tank Age**	26	**Tank Installed Date**	04/01/1999	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	3990	**Spill Test Date**	06/07/2021	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	06/07/2021	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.1;ELLD 0.2	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	06/07/2021	**Line Tightness Test Date**	05/21/2020	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	06/07/2021			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Cascade County in the City of Great Falls

Location: KERNAGHANS SERVICE 8TH AVE N
1507 8th Ave N
Great Falls, MT 59401-1749 Cascade

System Facility ID:07-04508

Facility Code: 18524
Last Inspected On: 09/06/2022
Operating Permit Renewal Date: 10/26/2025

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: James Kernaghan **(406) 452-9505**

Operator Contact: Jeff Rearden

Owner/Operator: James Kernaghan (406) 452-9505

Callie Rearden, UST Class B Operator
Jeff Rearden, UST Class A Operator

piknpump@gmail.com

Tank Number	03	**Tank Age**	36	**Tank Installed Date**	07/28/1989	**Tank Material Construction**	Steel Clad	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	1473	**Spill Test Date**	11/01/2021	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	01/29/2024	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	7500	**ATG Test Date**	01/29/2024	**Line Tightness Test Date**	04/17/2019	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	01/29/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	04	**Tank Age**	36	**Tank Installed Date**	07/28/1989	**Tank Material Construction**	Steel Clad	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	1474	**Spill Test Date**	11/01/2021	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	01/29/2024	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	5000	**ATG Test Date**	01/29/2024	**Line Tightness Test Date**	09/20/2018	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	01/29/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	05	**Tank Age**	36	**Tank Installed Date**	07/28/1989	**Tank Material Construction**	Steel Clad	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm

Tag Number	1475	**Spill Test Date**	12/07/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	01/29/2024	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	7500	**ATG Test Date**	01/29/2024	**Line Tightness Test Date**	07/15/2019	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	01/29/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	06	**Tank Age**	36	**Tank Installed Date**	07/28/1989	**Tank Material Construction**	Steel Clad	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	1476	**Spill Test Date**	11/01/2021	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	01/29/2024	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	01/29/2024	**Line Tightness Test Date**	04/12/2019	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	01/29/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	07	**Tank Age**	36	**Tank Installed Date**	07/28/1989	**Tank Material Construction**	Steel Clad	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	1477	**Spill Test Date**	11/01/2021	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	01/29/2024	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.1	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	01/29/2024	**Line Tightness Test Date**	05/14/2019	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	01/29/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	08	**Tank Age**	36	**Tank Installed Date**	07/28/1989	**Tank Material Construction**	Steel Clad	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	1478	**Spill Test Date**	11/01/2021	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	01/29/2024	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.1	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	01/29/2024	**Line Tightness Test Date**	04/17/2019	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No

		Overfill Test Date	01/29/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	09	**Tank Age**	43	**Tank Installed Date**	07/29/1982	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	1479	**Spill Test Date**	11/01/2021	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel, Dyed	**PLLD Test Date**	01/29/2024	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.1	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	2500	**ATG Test Date**	01/29/2024	**Line Tightness Test Date**	04/17/2019	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	01/29/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Cascade County in the City of Great Falls

Location: KERNAGHANS SERVICE 9TH AVE N
1504 9th Ave N
Great Falls, MT 59401-1301 Cascade

System Facility ID:07-04509

Facility Code: 18525
Last Inspected On: 09/01/2023
Operating Permit Renewal Date: 09/03/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: James Kernaghan **(406) 452-9505**

Operator Contact: Jeff Rearden

Owner/Operator: James Kernaghan (406) 452-9505

Callie Rearden, UST Class B Operator
Jeff Rearden, UST Class A Operator
piknpump@gmail.com

Tank Number	05	**Tank Age**	27	**Tank Installed Date**	05/23/1998	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	1480	**Spill Test Date**	10/18/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**	10/18/2022	**Tank/Piping CP Test Date**	08/05/2020	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	2000	**ATG Test Date**	10/18/2022	**Line Tightness Test Date**	11/09/2019	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	10/18/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	06	**Tank Age**	27	**Tank Installed Date**	05/23/1998	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	1481	**Spill Test Date**	12/06/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**	10/18/2022	**Tank/Piping CP Test Date**	08/05/2020	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	1000	**ATG Test Date**	10/18/2022	**Line Tightness Test Date**	11/09/2019	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	10/18/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	07	**Tank Age**	27	**Tank Installed Date**	05/23/1998	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm

Tag Number	1482	**Spill Test Date**	10/18/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**	10/18/2022	**Tank/Piping CP Test Date**	08/05/2020	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	2000	**ATG Test Date**	10/18/2022	**Line Tightness Test Date**	11/09/2019	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	10/18/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	08	**Tank Age**	27	**Tank Installed Date**	05/23/1998	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	1483	**Spill Test Date**	12/06/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**	10/18/2022	**Tank/Piping CP Test Date**	08/05/2020	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	3500	**ATG Test Date**	10/18/2022	**Line Tightness Test Date**	11/12/2019	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	10/18/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	09	**Tank Age**	27	**Tank Installed Date**	05/23/1998	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	1484	**Spill Test Date**	12/06/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**	10/18/2022	**Tank/Piping CP Test Date**	08/05/2020	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	1500	**ATG Test Date**	10/18/2022	**Line Tightness Test Date**	11/13/2019	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	10/18/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Cascade County in the City of Great Falls

Location: LITHIA BUICK GMC
26 9th St S
Great Falls, MT 59401-3757 Cascade

System Facility ID:07-10262

Facility Code: 18808
Last Inspected On: 03/31/2020
Operating Permit Renewal Date: 03/31/2023

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Lithia Real Estate Inc Great Falls **toberhoulser@lithia.com**

Operator Contact: Mark McCarthy

Dan Noland, UST Class B Operator
Dan Noland, UST Class B Operator
Mark McCarthy, UST Class A Operator
Mark McCarthy, UST Class B Global Operator

Tank Number	01	**Tank Age**	49	**Tank Installed Date**	01/27/1976	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	430	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Deferred	**Vapor Recovery**	No
Capacity	3996	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					

Facility Summary in Cascade County in the City of Great Falls

Location: LOVES TRAVEL STOP GREAT FALLS #789
3219 Airport Drive
Great Falls, MT 59404 Cascade

System Facility ID:60-15349

Facility Code: 32433
Last Inspected On: 03/28/2025
Operating Permit Renewal Date: 06/06/2028

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Loves Travel Stops and Country Stores Inc **environmental@loves.com**

Operator Contact: Eric Bennett;Loves Travel Stops and Country Stores Inc;Ted Lowery **(405) 779-3768** **environmental@loves.com;environmental@loves.com;environmental@loves.com**

Owner/Operator: Loves Travel Stops and Country Stores Inc environmental@loves.com

Eric Bennett, UST Class A Operator environmental@loves.com
Eric Bennett, UST Class B Operator environmental@loves.com
Ted Lowery, UST Class A Operator environmental@loves.com
Victor Valdez, UST Class B Operator Victor.Valdez@loves.com

Tank Number	1	**Tank Age**	4	**Tank Installed Date**	11/18/2021	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	6003	**Spill Test Date**	02/25/2025	**Piping Installed Date**	11/18/2021	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	11/02/2021	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	Yes
Capacity	20000	**ATG Test Date**	02/25/2025	**Line Tightness Test Date**	11/22/2021	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	Yes
		Overfill Test Date	02/25/2025			**ATG Type**					
Tank Number	2	**Tank Age**	4	**Tank Installed Date**	11/18/2021	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	6004	**Spill Test Date**	11/02/2021	**Piping Installed Date**	11/18/2021	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	11/02/2021	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	Yes
Capacity	12000	**ATG Test Date**	11/21/2021	**Line Tightness Test Date**	11/22/2021	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	Yes
		Overfill Test Date	11/30/2021			**ATG Type**					

Tank Number	3	**Tank Age**	4	**Tank Installed Date**	11/18/2021	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	6005	**Spill Test Date**	02/25/2025	**Piping Installed Date**	11/18/2021	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	11/02/2021	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	Yes
Capacity	8000	**ATG Test Date**	02/25/2025	**Line Tightness Test Date**	11/29/2021	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	Yes
		Overfill Test Date	02/25/2025			**ATG Type**					
Tank Number	4	**Tank Age**	4	**Tank Installed Date**	11/18/2021	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	6006	**Spill Test Date**	02/25/2025	**Piping Installed Date**	11/18/2021	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	11/02/2021	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	30000	**ATG Test Date**	02/25/2025	**Line Tightness Test Date**	11/22/2021	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	Yes
		Overfill Test Date	02/25/2025			**ATG Type**					
Tank Number	5	**Tank Age**	4	**Tank Installed Date**	11/18/2021	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	6007	**Spill Test Date**	02/25/2025	**Piping Installed Date**	11/18/2021	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	11/02/2021	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	30000	**ATG Test Date**	02/25/2025	**Line Tightness Test Date**	11/22/2021	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	Yes
		Overfill Test Date	02/25/2025			**ATG Type**					
Tank Number	6	**Tank Age**	4	**Tank Installed Date**	11/18/2021	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	
Tag Number	6008	**Spill Test Date**		**Piping Installed Date**	11/18/2021	**Tank Construction**		**Piping Construction**		**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**		**Piping Type**		**CP Met Types**	
Product	DEF (Not Regulated)	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**		**Vapor Recovery**	No

Capacity	20000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					

Facility Summary in Cascade County in the City of Great Falls

Location: MCLAUGHLIN RESEARCH INSTITUTE
1520 23rd St S
Great Falls, MT 59405-4900 Cascade

System Facility ID:07-12790

Facility Code: 19013
Last Inspected On: 03/19/2025
Operating Permit Renewal Date: 07/16/2028

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: McLaughlin Research Institute **(406) 452-6208**

Operator Contact: Leroy Bishop **(406) 899-1600** **lrbishop@mclaughlinresearch.org**

Owner/Operator: McLaughlin Research Institute (406) 452-6208

Leroy Bishop, UST Class A Operator lrbishop@mclaughlinresearch.org

Leroy Bishop, UST Class B Global Operator lrbishop@mclaughlinresearch.org

Tank Number	01	**Tank Age**	32	**Tank Installed Date**	05/23/1993	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	2977	**Spill Test Date**	06/20/2022	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Auto Dialer	**Piping Type**	U.S. Suction	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	3-Year Line Tightness Test	**Vapor Recovery**	No
Capacity	1000	**ATG Test Date**	09/03/2024	**Line Tightness Test Date**	06/20/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	06/20/2022			**ATG Type**	Gilbarco/EMC Basic				

Facility Summary in Cascade County in the City of Great Falls

Location: MDOT GREAT FALLS
200 Smelter Ave NE
Great Falls, MT 59404-1900 Cascade

System Facility ID:07-04047

Facility Code: 18498
Last Inspected On: 12/04/2023
Operating Permit Renewal Date: 03/25/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	MDOT Helena	**(406) 444-6163**	**mmurolo@mt.gov**
Operator Contact:	Joe Radonich;Montana Dept of Transportation;Mike Murolo;Montana Dept of Transportation;Tracy Deeds;MDOT Helena;Walt Kerttula;Montana Dept of Transportation	**(406) 444-6151;(406) 444-7632;(406) 444-6163;(406) 444-7632;(406) 444-9204;(406) 444-7632;(406) 461-0769;(406) 444-6163**	**jradonich@mt.gov;jradonich@mt.gov;mmurolo@mt.gov;jradonich@mt.gov;tdeeds@mt.gov;mmurolo@mt.gov;wkerttula@mt.gov;jradonich@mt.gov**

Owner/Operator: MDOT Helena (406) 444-6163 mmurolo@mt.gov

Joe Radonich, UST Class A Operator	jradonich@mt.gov
Joe Radonich, UST Class B Global Operator	jradonich@mt.gov
Kelly Holbrook, UST Class B Global Operator	kholbrook@mt.gov
Mike Murolo, UST Class A Operator	jradonich@mt.gov
Steven Rupnow, UST Class B Operator	vrupnow@mt.gov
Tracy Deeds, UST Class A Operator	mmurolo@mt.gov
Walt Kerttula, UST Class A Operator	jradonich@mt.gov

Tank Number	05	**Tank Age**	35	**Tank Installed Date**	11/01/1990	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	3704	**Spill Test Date**	12/04/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	12/04/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	12/04/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	12/04/2023			**ATG Type**	Gilbarco/EMC Basic				
Tank Number	06	**Tank Age**	33	**Tank Installed Date**	04/01/1992	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	3705	**Spill Test Date**	12/04/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	12/04/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**		**Vapor Recovery**	No

Capacity	12000	**ATG Test Date**	12/04/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	12/04/2023			**ATG Type**	Gilbarco/EMC Basic				

Facility Summary in Cascade County in the City of Great Falls

Location: MEADOWLARK COUNTRY CLUB
300 Country Club Blvd
Great Falls, MT 59404-3355 Cascade

System Facility ID:07-11234

Facility Code: 18876
Last Inspected On: 10/31/2024
Operating Permit Renewal Date: 03/01/2028

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Meadowlark Country Club **(406) 453-6531**

Operator Contact: Tim Furan **(406) 899-6846** **timfuran@hotmail.com**

Owner/Operator: Meadowlark Country Club (406) 453-6531

Tim Furan, UST Class A Operator timfuran@hotmail.com

Tim Furan, UST Class B Operator timfuran@hotmail.com

Tank Number	02	**Tank Age**	34	**Tank Installed Date**	05/23/1991	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	2317	**Spill Test Date**	10/31/2024	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	10/31/2024	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	1000	**ATG Test Date**	10/31/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	10/31/2024			**ATG Type**	OPW/EECO 1500				
Tank Number	03	**Tank Age**	34	**Tank Installed Date**	05/23/1991	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	2318	**Spill Test Date**	10/31/2024	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	10/31/2024	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	1000	**ATG Test Date**	10/31/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	10/31/2024			**ATG Type**	OPW/EECO 1500				

Facility Summary in Cascade County in the City of Great Falls

Location: MONTANA AIR NATIONAL GUARD UST
2800 Airport Ave B
Great Falls, MT 59404-5570 Cascade

System Facility ID:07-02294

Facility Code: 18433
Last Inspected On: 11/30/2022
Operating Permit Renewal Date: 03/11/2020

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Montana Air National Guard **(406) 791-0316**

Operator Contact: Clint Tyler;Joe Kerkes;Joseph Leggett;Mark Payton **(406) 231-0600** **joseph.leggett@us.af.mil**

Owner/Operator: Montana Air National Guard (406) 791-0316

Clint Tyler, UST Class A Operator
Clint Tyler, UST Class B Operator
Joe Kerkes, UST Class A Operator
Joe Kerkes, UST Class A Operator
Joseph Leggett, UST Class A Operator joseph.leggett@us.af.mil
Mark Payton, UST Class A Operator
Mark Payton, UST Class A Operator

Tank Number	26	**Tank Age**	31	**Tank Installed Date**	10/01/1994	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	No Piping	**Overfill Types**	
Tag Number		**Spill Test Date**		**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	None	**AST**	No
Status	**Other**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**		**Piping Type**	Gravity Feed	**CP Met Types**	
Product	Oil/Water Separator	**PLLD Test Date**		**Tank/Piping CP Test Date**	09/19/2007	**Primary Tank Leak Detection**	Continuous Interstitial Monitoring;Deferred	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	2110	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	3A	**Tank Age**	70	**Tank Installed Date**	01/01/1955	**Tank Material Construction**	Bare Steel	**Piping Material**	No Piping	**Overfill Types**	High Level Alarm
Tag Number	1662	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**	Lined Interior/Impressed Current	**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Gravity Feed	**CP Met Types**	Impressed Current
Product	Jet Fuel (Jet-A, Jet-A1, JP5)	**PLLD Test Date**		**Tank/Piping CP Test Date**	03/13/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**		**Vapor Recovery**	No

Capacity	25000	**ATG Test Date**	11/30/2022	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	11/30/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350				
Tank Number	3B	**Tank Age**	70	**Tank Installed Date**	01/01/1955	**Tank Material Construction**	Bare Steel	**Piping Material**	No Piping	**Overfill Types**	High Level Alarm
Tag Number	1663	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**	Lined Interior/Impressed Current	**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Gravity Feed	**CP Met Types**	Impressed Current
Product	Jet Fuel (Jet-A, Jet-A1, JP5)	**PLLD Test Date**		**Tank/Piping CP Test Date**	03/13/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	25000	**ATG Test Date**	11/30/2022	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	11/30/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350				
Tank Number	3C	**Tank Age**	70	**Tank Installed Date**	01/01/1955	**Tank Material Construction**	Bare Steel	**Piping Material**	No Piping	**Overfill Types**	High Level Alarm
Tag Number	1664	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**	Lined Interior/Impressed Current	**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Gravity Feed	**CP Met Types**	Impressed Current
Product	Jet Fuel (Jet-A, Jet-A1, JP5)	**PLLD Test Date**		**Tank/Piping CP Test Date**	03/13/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	25000	**ATG Test Date**	11/30/2022	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	11/30/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350				
Tank Number	3D	**Tank Age**	70	**Tank Installed Date**	01/01/1955	**Tank Material Construction**	Bare Steel	**Piping Material**	No Piping	**Overfill Types**	High Level Alarm
Tag Number	1665	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**	Lined Interior/Impressed Current	**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Gravity Feed	**CP Met Types**	Impressed Current
Product	Jet Fuel (Jet-A, Jet-A1, JP5)	**PLLD Test Date**		**Tank/Piping CP Test Date**	03/13/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	25000	**ATG Test Date**	11/30/2022	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	11/30/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350				
Tank Number	3F	**Tank Age**	70	**Tank Installed Date**	01/01/1955	**Tank Material Construction**	Bare Steel	**Piping Material**	No Piping	**Overfill Types**	High Level Alarm

Tag Number	1667	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**	Lined Interior/Impressed Current	**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Gravity Feed	**CP Met Types**	Impressed Current
Product	Jet Fuel (Jet-A, Jet-A1, JP5)	**PLLD Test Date**		**Tank/Piping CP Test Date**	03/13/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	25000	**ATG Test Date**	11/30/2022	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	11/30/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350				
Tank Number	3E	**Tank Age**	70	**Tank Installed Date**	01/01/1955	**Tank Material Construction**	Bare Steel	**Piping Material**	No Piping	**Overfill Types**	High Level Alarm
Tag Number	4783	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**	Lined Interior/Impressed Current	**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Gravity Feed	**CP Met Types**	Impressed Current
Product	Jet Fuel (Jet-A, Jet-A1, JP5)	**PLLD Test Date**		**Tank/Piping CP Test Date**	03/13/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	25000	**ATG Test Date**	11/30/2022	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	11/30/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Cascade County in the City of Great Falls

Location: ON YOUR WAY
3601 10th Ave S
Great Falls, MT 59405 Cascade

System Facility ID:07-03973

Facility Code: 18494
Last Inspected On: 12/05/2023
Operating Permit Renewal Date: 03/27/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	H and R Inc 5	**(406) 727-9830**	**inder4030@yahoo.com**
Operator Contact:	Harinder Singh;Rajinder Singh	**(406) 761-4791;(406) 868-2062**	**hrkinc101@gmail.com;inder4030@yahoo.com**

Owner/Operator: H and R Inc 5 (406) 727-9830 inder4030@yahoo.com

Frank Kruse, UST Class B Global Operator	wfkruse79@yahoo.com
Frank Kruse, UST Class B Global Operator	wfkruse79@yahoo.com
Frank Kruse, UST Class B Operator	wfkruse79@yahoo.com
Frank Kruse, UST Class B Operator	wfkruse79@yahoo.com
Harinder Singh, UST Class A Operator	inder4030@yahoo.com
Rajinder Singh, UST Class A Operator	hrkinc101@gmail.com

Tank Number	06	**Tank Age**	34	**Tank Installed Date**	06/01/1991	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	1248	**Spill Test Date**	12/05/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	12/05/2023	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	12/05/2023	**Line Tightness Test Date**	07/12/2020	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	12/05/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	07	**Tank Age**	34	**Tank Installed Date**	06/01/1991	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	1249	**Spill Test Date**	12/05/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	12/05/2023	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	12/05/2023	**Line Tightness Test Date**	08/13/2020	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No

		Overfill Test Date	12/05/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	08	**Tank Age**	34	**Tank Installed Date**	06/01/1991	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	1250	**Spill Test Date**	12/18/2024	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	12/05/2023	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	12/05/2023	**Line Tightness Test Date**	10/06/2020	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	12/05/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Cascade County in the City of Great Falls

Location: PHILLIPS 66 GREAT FALLS TERMINAL
1401 52nd St N
Great Falls, MT 59405-1073 Cascade

System Facility ID:07-01845

Facility Code: 18413
Last Inspected On: 01/21/2025
Operating Permit Renewal Date: 06/09/2028

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Phillips 66 Great Falls Terminal **(406) 255-5714**

Operator Contact: Brian Buckley;Russel Fox;Scott Cleveland **russel.fox@p66.com;sccleveland@pplweb.com**

Owner/Operator: Phillips 66 Great Falls Terminal (406) 255-5714

Brian Buckley, UST Class A Operator	
Brian Buckley, UST Class A Operator	
Brian Buckley, UST Class A Operator	
Brian Buckley, UST Class A Operator	
Brian Buckley, UST Class B Operator	
Brian Buckley, UST Class B Operator	
Brian Buckley, UST Class B Operator	
Brian Buckley, UST Class B Operator	
Russel Fox, UST Class A Operator	russel.fox@p66.com
Russel Fox, UST Class A Operator	russel.fox@p66.com
Russel Fox, UST Class B Operator	russel.fox@p66.com
Russel Fox, UST Class B Operator	russel.fox@p66.com
Scott Cleveland, UST Class A Operator	sccleveland@pplweb.com
Scott Cleveland, UST Class A Operator	sccleveland@pplweb.com
Scott Cleveland, UST Class A Operator	sccleveland@pplweb.com
Scott Cleveland, UST Class A Operator	sccleveland@pplweb.com
Scott Parker, UST Class B Operator	Scott.G.Parker@p66.com
Scott Parker, UST Class B Operator	Scott.G.Parker@p66.com
Scott Parker, UST Class B Operator	Scott.G.Parker@p66.com
Scott Parker, UST Class B Operator	Scott.G.Parker@p66.com

Tank Number	22	**Tank Age**	31	**Tank Installed Date**	02/01/1994	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Steel - Terminal Piping	**Overfill Types**	
Tag Number	4910	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	None	**AST**	No
Status	**Regulated by DOT**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Pressurized	**CP Met Types**	

Product	Mixture	**PLLD Test Date**		**Tank/Piping CP Test Date**	07/24/2009	**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**		**Line Tightness Test Date**	11/03/2009	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	S5	**Tank Age**	65	**Tank Installed Date**	01/01/1960	**Tank Material Construction**	Unknown	**Piping Material**	Steel - Terminal Piping	**Overfill Types**	
Tag Number	704	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	Yes
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	10/29/2024	**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Pressurized	**CP Met Types**	
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	05/29/2024	**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**	Terminal Piping Annual Line Test	**Vapor Recovery**	No
Capacity	2520000	**ATG Test Date**		**Line Tightness Test Date**	09/01/2021	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	S9	**Tank Age**	65	**Tank Installed Date**	01/01/1960	**Tank Material Construction**	Unknown	**Piping Material**	Steel - Terminal Piping	**Overfill Types**	
Tag Number	707	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	Yes
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Pressurized	**CP Met Types**	
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	05/29/2024	**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**	Terminal Piping Annual Line Test	**Vapor Recovery**	No
Capacity	1512000	**ATG Test Date**		**Line Tightness Test Date**	10/30/2024	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	S11	**Tank Age**	65	**Tank Installed Date**	01/01/1960	**Tank Material Construction**	Unknown	**Piping Material**	Steel - Terminal Piping	**Overfill Types**	
Tag Number	709	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	Yes
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Pressurized	**CP Met Types**	
Product	Kerosene	**PLLD Test Date**		**Tank/Piping CP Test Date**	05/29/2024	**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**	Terminal Piping Annual Line Test	**Vapor Recovery**	No
Capacity	1512000	**ATG Test Date**		**Line Tightness Test Date**	09/17/2024	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	S13	**Tank Age**	65	**Tank Installed Date**	01/01/1960	**Tank Material Construction**	Unknown	**Piping Material**	Steel - Terminal Piping	**Overfill Types**	
Tag Number	711	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	Yes

Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Pressurized	**CP Met Types**	
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	05/29/2024	**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**	Terminal Piping Annual Line Test	**Vapor Recovery**	No
Capacity	1050000	**ATG Test Date**		**Line Tightness Test Date**	09/17/2024	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	S15	**Tank Age**	65	**Tank Installed Date**	01/01/1960	**Tank Material Construction**	Unknown	**Piping Material**	Steel - Terminal Piping	**Overfill Types**	
Tag Number	713	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	Yes
Status	**Temporarily Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Pressurized	**CP Met Types**	
Product	Kerosene	**PLLD Test Date**		**Tank/Piping CP Test Date**	05/29/2024	**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**	Terminal Piping Annual Line Test	**Vapor Recovery**	No
Capacity	21000	**ATG Test Date**		**Line Tightness Test Date**	11/03/2009	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	S16	**Tank Age**	65	**Tank Installed Date**	01/01/1960	**Tank Material Construction**	Unknown	**Piping Material**	Steel - Terminal Piping	**Overfill Types**	
Tag Number	714	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	Yes
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Pressurized	**CP Met Types**	
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	05/29/2024	**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**	Terminal Piping Annual Line Test	**Vapor Recovery**	No
Capacity	1512000	**ATG Test Date**		**Line Tightness Test Date**	10/30/2024	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					

Facility Summary in Cascade County in the City of Great Falls

Location: RAINBOW SHOP
6700 Rainbow Dam Rd
Great Falls, MT 59404-6000 Cascade

System Facility ID:07-01189

Facility Code: 18379
Last Inspected On: 05/19/2025
Operating Permit Renewal Date: 09/30/2025

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Northwestern Energy Butte **(406) 655-2521** **beth.stimatz@northwestern.com**

Operator Contact: Brian Ranf **brian.ranf@northwestern.com**

Owner/Operator: Northwestern Energy Butte (406) 655-2521 beth.stimatz@northwestern.com

Brian Ranf, UST Class A Operator brian.ranf@northwestern.com

Matthew Lynn, UST Class B Operator matthew.lynn@northwestern.com

Tank Number	01	**Tank Age**	33	**Tank Installed Date**	08/01/1992	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	1674	**Spill Test Date**	09/21/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	05/16/2022	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	550	**ATG Test Date**	05/16/2022	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	02/15/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-300				
Tank Number	02	**Tank Age**	33	**Tank Installed Date**	08/01/1992	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	1675	**Spill Test Date**	09/21/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	05/16/2022	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	2000	**ATG Test Date**	05/16/2022	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	02/15/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-300				

Facility Summary in Cascade County in the City of Great Falls

Location: RENTAL CAR SERVICE BUILDING
2700 Airport Dr
Great Falls, MT 59404 Cascade

System Facility ID:07-12300

Facility Code: 18994
Last Inspected On: 05/11/2022
Operating Permit Renewal Date: 07/20/2025

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Great Falls International Airport

Operator Contact: Christopher Upchurch **(406) 799-3189** **chris@flygtf.com**

Owner/Operator: Great Falls International Airport

Christopher Upchurch, UST Class A Operator chris@flygtf.com
Christopher Upchurch, UST Class B Operator chris@flygtf.com
Tory Ewing, UST Class B Operator

Tank Number	01	**Tank Age**	35	**Tank Installed Date**	11/27/1990	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	2704	**Spill Test Date**	05/11/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	05/11/2022	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	05/11/2022			**ATG Type**	Veeder Root/TLS-300				

Facility Summary in Cascade County in the City of Great Falls

Location: SAMS CLUB 6379
401 Northwest Byp
Great Falls, MT 59404-4124 Cascade

System Facility ID:56-14065

Facility Code: 30718
Last Inspected On: 03/20/2023
Operating Permit Renewal Date: 04/16/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Sams West Inc	**(785) 550-8812**	**marie.brouhard@aptim.com**
Operator Contact:	Cheryl Shie;Dylan Oakden;Shaiyna Chinery	**(406) 217-2265;(760) 669-2468**	**clshie.s06379.us@samsclub.com;fatalangelshai@gmail.com;rdoakde.s06379.us@samsclub.com**

Owner/Operator: Sams West Inc (785) 550-8812 marie.brouhard@aptim.com

Cheryl Shie, UST Class A Operator	clshie.s06379.us@samsclub.com
Cheryl Shie, UST Class B Operator	clshie.s06379.us@samsclub.com
Dylan Oakden, UST Class A Operator	rdoakde.s06379.us@samsclub.com
Dylan Oakden, UST Class B Operator	rdoakde.s06379.us@samsclub.com
Johney Miller, UST Class B Global Operator	john.miller@7g-enviro.com
Shaiyna Chinery, UST Class A Operator	fatalangelshai@gmail.com
Shaiyna Chinery, UST Class B Global Operator	fatalangelshai@gmail.com

Tank Number	01	**Tank Age**	23	**Tank Installed Date**	08/05/2002	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	4702	**Spill Test Date**	02/15/2023	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	02/15/2023	**Sump Tightness Test Date**	04/26/2023	**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	20000	**ATG Test Date**	02/15/2023	**Line Tightness Test Date**	02/15/2023	**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	04/26/2023			**ATG Type**	Veeder Root/TLS-450				
Tank Number	02	**Tank Age**	23	**Tank Installed Date**	08/05/2002	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	4703	**Spill Test Date**	02/15/2023	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	02/15/2023	**Sump Tightness Test Date**	04/26/2023	**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No

Capacity	20000	**ATG Test Date**	02/15/2023	**Line Tightness Test Date**	02/15/2023	**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	04/26/2023			**ATG Type**	Veeder Root/TLS-450				
Tank Number	03	**Tank Age**	23	**Tank Installed Date**	08/05/2002	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	4704	**Spill Test Date**	02/15/2023	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	02/15/2023	**Sump Tightness Test Date**	04/26/2023	**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	20000	**ATG Test Date**	02/15/2023	**Line Tightness Test Date**	02/15/2023	**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	04/26/2023			**ATG Type**	Veeder Root/TLS-450				

Facility Summary in Cascade County in the City of Great Falls

Location: SCHULTES 38TH STREET STORE
3800 3rd Ave S
Great Falls, MT 59405 Cascade

System Facility ID:07-08480

Facility Code: 18691
Last Inspected On: 01/29/2024
Operating Permit Renewal Date: 03/24/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Great Falls Convenience Store	**(406) 453-3450**	**schultes38@bresnan.net**
Operator Contact:	Rory Schulte	**(406) 453-3450**	**schultes38@bresnan.net**

Owner/Operator: Great Falls Convenience Store (406) 453-3450 schultes38@bresnan.net

Rory Schulte, UST Class A Operator schultes38@bresnan.net

Rory Schulte, UST Class B Global Operator schultes38@bresnan.net

Tank Number	01	**Tank Age**	40	**Tank Installed Date**	12/07/1985	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	1906	**Spill Test Date**	01/22/2024	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	10/11/2023	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	03/11/2021	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	10/10/2023	**Line Tightness Test Date**	10/11/2023	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	01/22/2024			**ATG Type**	Veeder Root/TLS-350				
Tank Number	02	**Tank Age**	40	**Tank Installed Date**	12/07/1985	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	1907	**Spill Test Date**	01/22/2024	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	10/11/2023	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	03/11/2021	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	10/10/2023	**Line Tightness Test Date**	10/11/2023	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	01/22/2024			**ATG Type**	Veeder Root/TLS-350				
Tank Number	03	**Tank Age**	36	**Tank Installed Date**	12/07/1989	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	1908	**Spill Test Date**	01/22/2024	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No

Status	**Currently in Use**	**MLLD Test Date**	10/11/2023	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	02/22/2018	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	10/10/2023	**Line Tightness Test Date**	10/11/2023	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	01/22/2024			**ATG Type**	Veeder Root/TLS-350				

Facility Summary in Cascade County in the City of Great Falls

Location: SMITHS 166 FUEL CENTER
1601 Market Place Dr
Great Falls, MT 59401 Cascade

System Facility ID:60-15217

Facility Code: 30936
Last Inspected On: 01/07/2025
Operating Permit Renewal Date: 04/16/2028

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Smiths Food and Drug	**(801) 974-1400**	**roger.gough@sfdc.com**
Operator Contact:	Braxton Hill;James Dye	**(801) 560-0471**	**braxton.hill@sfdc.com;jim.dye@sfdc.com**

Owner/Operator: Smiths Food and Drug (801) 974-1400 roger.gough@sfdc.com

Braxton Hill, UST Class A Operator	braxton.hill@sfdc.com
Braxton Hill, UST Class B Operator	braxton.hill@sfdc.com
James Dye, UST Class A Operator	jim.dye@sfdc.com
James Dye, UST Class B Global Operator	jim.dye@sfdc.com
Todd Dotseth, UST Class B Operator	petrocompliance@gmail.com

Tank Number	01	**Tank Age**	13	**Tank Installed Date**	12/01/2012	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	5395	**Spill Test Date**	09/03/2024	**Piping Installed Date**	10/17/2012	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	09/05/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	09/03/2024	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	20000	**ATG Test Date**	09/03/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	10/23/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-450;Veeder Root/TLS-450				
Tank Number	02	**Tank Age**	13	**Tank Installed Date**	12/01/2012	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	5396	**Spill Test Date**	09/03/2024	**Piping Installed Date**	10/17/2012	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	09/05/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	09/03/2024	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No

Capacity	10000	**ATG Test Date**	09/03/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	09/03/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-450;Veeder Root/TLS-450				
Tank Number	03	**Tank Age**	13	**Tank Installed Date**	12/01/2012	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	5397	**Spill Test Date**	09/03/2024	**Piping Installed Date**	10/17/2012	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	09/05/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	09/03/2024	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	Yes
Capacity	8000	**ATG Test Date**	09/03/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	09/03/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-450;Veeder Root/TLS-450				

Facility Summary in Cascade County in the City of Great Falls

Location: SUCH GROUP INTERNATIONAL INC
2224 Vaughn Rd
Great Falls, MT 59404-2196 Cascade

System Facility ID:07-13632

Facility Code: 19051
Last Inspected On: 02/06/2024
Operating Permit Renewal Date: 02/13/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Such Group International Inc	**(406) 727-4144**	**todds@wwpgf.com**
Operator Contact:	Todd Such	**(406) 727-4114**	**todds@sgigf.com**

Owner/Operator: Such Group International Inc (406) 727-4144 todds@wwpgf.com
Todd Such, UST Class A Operator todds@sgigf.com
Todd Such, UST Class B Operator todds@sgigf.com

Tank Number	01	**Tank Age**	30	**Tank Installed Date**	08/01/1995	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	4389	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Temporarily Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Continuous Interstitial Monitoring	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.1;Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	02	**Tank Age**	30	**Tank Installed Date**	08/01/1995	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	4390	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Temporarily Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Continuous Interstitial Monitoring	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.1;Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No

		Overfill Test Date				**ATG Type**					

Facility Summary in Cascade County in the City of Great Falls

Location: TOLAN DISTRIBUTING INC
2201 Vaughn Rd
Great Falls, MT 59404-2197 Cascade

System Facility ID:07-04511

Facility Code: 18527
Last Inspected On: 08/11/2023
Operating Permit Renewal Date: 09/15/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Tolan Distributing Inc **tdimt@gmx.com**

Operator Contact:

Owner/Operator: Tolan Distributing Inc tdimt@gmx.com

Tank Number	06	**Tank Age**	26	**Tank Installed Date**	09/01/1999	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	4098	**Spill Test Date**	06/07/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	06/07/2023	**Sump Tightness Test Date**	09/26/2020	**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	06/07/2023	**Line Tightness Test Date**	06/07/2023	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	06/07/2023			**ATG Type**	EMCO Electronics/EECO 1500				
Tank Number	07	**Tank Age**	26	**Tank Installed Date**	01/01/1999	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	4099	**Spill Test Date**	06/07/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	06/07/2023	**Sump Tightness Test Date**	09/26/2018	**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	06/07/2023	**Line Tightness Test Date**	06/07/2023	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	06/07/2023			**ATG Type**	EMCO Electronics/EECO 1500				

Tank Number	08	**Tank Age**	26	**Tank Installed Date**	09/01/1999	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	4100	**Spill Test Date**	06/07/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	06/07/2023	**Sump Tightness Test Date**	09/26/2018	**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	06/07/2023	**Line Tightness Test Date**	06/07/2023	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	06/07/2023			**ATG Type**	EMCO Electronics/EECO 1500				
Tank Number	09	**Tank Age**	26	**Tank Installed Date**	09/01/1999	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	4101	**Spill Test Date**	06/07/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	06/07/2023	**Sump Tightness Test Date**	09/26/2018	**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	06/07/2023	**Line Tightness Test Date**	06/07/2023	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	06/07/2023			**ATG Type**	EMCO Electronics/EECO 1500				

Facility Summary in Cascade County in the City of Great Falls

Location: TOWN PUMP GREAT FALLS 6
3715 31st St SW
Great Falls, MT 59404-4700 Cascade

System Facility ID:56-14148

Facility Code: 30784
Last Inspected On: 03/26/2024
Operating Permit Renewal Date: 08/06/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Great Falls 6 Town Pump LLC **(406) 497-6700** **environmental@townpump.com**

Operator Contact: Trent Biggers **Trentb@townpump.com**

Owner/Operator: Great Falls 6 Town Pump LLC (406) 497-6700 environmental@townpump.com

Trent Biggers, UST Class A Operator Trentb@townpump.com

Trent Biggers, UST Class B Global Operator Trentb@townpump.com

Tank Number	01	**Tank Age**	20	**Tank Installed Date**	02/25/2005	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve;Flapper Valve
Tag Number	4956	**Spill Test Date**	01/12/2024	**Piping Installed Date**	02/25/2005	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	03/26/2024	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	20000	**ATG Test Date**	03/26/2024	**Line Tightness Test Date**	02/29/2016	**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	09/13/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350				
Tank Number	02	**Tank Age**	20	**Tank Installed Date**	02/25/2005	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve;Flapper Valve
Tag Number	4957	**Spill Test Date**	09/13/2023	**Piping Installed Date**	02/25/2005	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	03/26/2024	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	20000	**ATG Test Date**	03/26/2024	**Line Tightness Test Date**	02/24/2016	**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	09/13/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350				

Tank Number	03	**Tank Age**	20	**Tank Installed Date**	02/25/2005	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve;Flapper Valve
Tag Number	4958	**Spill Test Date**	09/13/2023	**Piping Installed Date**	02/25/2005	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	09/13/2023	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	20000	**ATG Test Date**	03/26/2024	**Line Tightness Test Date**	02/24/2016	**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	09/13/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350				
Tank Number	04	**Tank Age**	20	**Tank Installed Date**	02/25/2005	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve;Flapper Valve
Tag Number	4959	**Spill Test Date**	09/13/2023	**Piping Installed Date**	02/25/2005	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	03/26/2024	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	03/26/2024	**Line Tightness Test Date**	02/23/2016	**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	09/13/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350				
Tank Number	05	**Tank Age**	12	**Tank Installed Date**	05/01/2013	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	
Tag Number	5420	**Spill Test Date**		**Piping Installed Date**	05/05/2013	**Tank Construction**	Double-Walled	**Piping Construction**	None	**AST**	No
Status	**Other**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**		**Piping Type**	Pressurized	**CP Met Types**	
Product	DEF (Not Regulated)	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Deferred	**Primary Pipe Leak Detection**	Deferred	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Deferred;Not Listed	**Energy Act**	Yes
		Overfill Test Date				**ATG Type**					

Facility Summary in Cascade County in the City of Great Falls

Location: TOWN PUMP GREAT FALLS 7
1411 10th Ave S
Great Falls, MT 59405 Cascade

System Facility ID:60-15283

Facility Code: 30990
Last Inspected On: 03/26/2024
Operating Permit Renewal Date: 08/06/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Great Falls 7 Town Pump LLC **(406) 497-6700** **environmental@townpump.com**

Operator Contact: Trent Biggers;Town Pump **Trentb@townpump.com;environmental@townpump.com**

Owner/Operator: Great Falls 7 Town Pump LLC (406) 497-6700 environmental@townpump.com

Trent Biggers, UST Class A Operator environmental@townpump.com

Trent Biggers, UST Class B Global Operator environmental@townpump.com

Tank Number	01	**Tank Age**	8	**Tank Installed Date**	01/25/2017	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	High Density Polyethylene	**Overfill Types**	Flapper Valve
Tag Number	5665	**Spill Test Date**	09/12/2023	**Piping Installed Date**	07/01/2016	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	09/12/2023	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	03/26/2024	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**	03/26/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Statistical Inventory Reconciliation	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	Yes
		Overfill Test Date	01/15/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-450				
Tank Number	02	**Tank Age**	8	**Tank Installed Date**	01/25/2017	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	High Density Polyethylene	**Overfill Types**	Flapper Valve
Tag Number	5666	**Spill Test Date**	01/15/2024	**Piping Installed Date**	07/01/2016	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	09/12/2023	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	03/26/2024	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	15000	**ATG Test Date**	03/26/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Statistical Inventory Reconciliation	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	**Energy Act**	Yes

		Overfill Test Date	09/12/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-450				
Tank Number	03	**Tank Age**	8	**Tank Installed Date**	01/25/2017	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	High Density Polyethylene	**Overfill Types**	Flapper Valve
Tag Number	5667	**Spill Test Date**	09/12/2023	**Piping Installed Date**	07/01/2016	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	09/12/2023	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel, Dyed	**PLLD Test Date**	03/26/2024	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**	03/26/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Statistical Inventory Reconciliation	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	Yes
		Overfill Test Date	01/15/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-450				
Tank Number	04	**Tank Age**	8	**Tank Installed Date**	01/25/2017	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	High Density Polyethylene	**Overfill Types**	Flapper Valve
Tag Number	5668	**Spill Test Date**	09/12/2023	**Piping Installed Date**	07/01/2016	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	09/12/2023	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	03/26/2024	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	25000	**ATG Test Date**	03/26/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	Yes
		Overfill Test Date	01/15/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-450				
Tank Number	05	**Tank Age**	8	**Tank Installed Date**	01/25/2017	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	High Density Polyethylene	**Overfill Types**	Flapper Valve
Tag Number	5669	**Spill Test Date**	09/12/2023	**Piping Installed Date**	07/01/2016	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	09/12/2023	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	03/26/2024	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	15000	**ATG Test Date**	03/26/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Statistical Inventory Reconciliation	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	Yes
		Overfill Test Date	01/15/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-450				
Tank Number	06	**Tank Age**	8	**Tank Installed Date**	01/25/2017	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	High Density Polyethylene	**Overfill Types**	Flapper Valve
Tag Number	5670	**Spill Test Date**	01/15/2024	**Piping Installed Date**	07/01/2016	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No

Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	09/12/2023	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	03/26/2024	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**	03/26/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Statistical Inventory Reconciliation	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	Yes
		Overfill Test Date	01/15/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-450				

Facility Summary in Cascade County in the City of Great Falls

Location: TOWN PUMP INC GREAT FALLS 1
401 10th Ave S
Great Falls, MT 59405-4044 Cascade

System Facility ID:07-08700

Facility Code: 18695
Last Inspected On: 03/21/2024
Operating Permit Renewal Date: 08/06/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Great Falls 1 Town Pump LLC	**(406) 497-6700**	**environmental@townpump.com**
Operator Contact:	Trent Biggers		**Trentb@townpump.com**

Owner/Operator:	Great Falls 1 Town Pump LLC	(406) 497-6700	environmental@townpump.com
	Trent Biggers, UST Class A Operator		Trentb@townpump.com
	Trent Biggers, UST Class A Operator		Trentb@townpump.com
	Trent Biggers, UST Class B Global Operator		Trentb@townpump.com
	Trent Biggers, UST Class B Global Operator		Trentb@townpump.com

Tank Number	01	**Tank Age**	39	**Tank Installed Date**	01/01/1986	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve
Tag Number	2391	**Spill Test Date**	08/30/2023	**Piping Installed Date**	07/12/2013	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	08/30/2023	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**	03/21/2024	**Tank/Piping CP Test Date**	08/30/2023	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	03/21/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	No
		Overfill Test Date	08/30/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350				
Tank Number	02	**Tank Age**	39	**Tank Installed Date**	01/01/1986	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve
Tag Number	2392	**Spill Test Date**	08/30/2023	**Piping Installed Date**	07/12/2013	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	08/30/2023	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**	03/21/2024	**Tank/Piping CP Test Date**	03/21/2024	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	03/21/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	No
		Overfill Test Date	08/30/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350				

Tank Number	03	**Tank Age**	37	**Tank Installed Date**	08/18/1988	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve
Tag Number	2393	**Spill Test Date**	08/30/2023	**Piping Installed Date**	07/12/2013	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	08/30/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**	03/21/2024	**Tank/Piping CP Test Date**	03/21/2024	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	08/21/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	No
		Overfill Test Date	08/30/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350				
Tank Number	04	**Tank Age**	27	**Tank Installed Date**	05/01/1998	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve
Tag Number	2394	**Spill Test Date**	09/14/2023	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	08/30/2023	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	03/21/2024	**Tank/Piping CP Test Date**	03/16/2010	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	03/21/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	08/30/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350				
Tank Number	05	**Tank Age**	27	**Tank Installed Date**	05/01/1998	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	2395	**Spill Test Date**	08/30/2023	**Piping Installed Date**	07/12/2013	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	08/30/2023	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	03/21/2024	**Tank/Piping CP Test Date**	03/16/2010	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	03/21/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	No
		Overfill Test Date	08/30/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Cascade County in the City of Great Falls

Location: TOWN PUMP INC GREAT FALLS 2
1400 10th Ave S
Great Falls, MT 59405-2624 Cascade

System Facility ID:07-08701

Facility Code: 18696
Last Inspected On: 02/28/2024
Operating Permit Renewal Date: 06/24/2022

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Great Falls 2 Town Pump LLC **(406) 497-6700** **environmental@townpump.com**

Operator Contact: Trent Biggers **Trentb@townpump.com**

Owner/Operator: Great Falls 2 Town Pump LLC (406) 497-6700 environmental@townpump.com

Trent Biggers, UST Class A Operator Trentb@townpump.com

Trent Biggers, UST Class B Global Operator Trentb@townpump.com

Tank Number	04	**Tank Age**	35	**Tank Installed Date**	01/04/1990	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	2396	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Approved Remote Monitoring;Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Approved Remote Monitoring;Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	20000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	05	**Tank Age**	35	**Tank Installed Date**	01/04/1990	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	2397	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Approved Remote Monitoring;Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Approved Remote Monitoring;Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	24000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					

Tank Number	06	**Tank Age**	35	**Tank Installed Date**	01/04/1990	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	2398	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Approved Remote Monitoring;Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Approved Remote Monitoring;Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	24000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	07	**Tank Age**	35	**Tank Installed Date**	01/04/1990	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	2399	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Approved Remote Monitoring;Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Approved Remote Monitoring;Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	16000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	08	**Tank Age**	35	**Tank Installed Date**	01/04/1990	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	2400	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Approved Remote Monitoring;Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Approved Remote Monitoring;Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	11	**Tank Age**	5	**Tank Installed Date**	01/10/2020	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	5944	**Spill Test Date**	09/14/2023	**Piping Installed Date**	01/10/2020	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No

Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	09/14/2023	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	02/28/2024	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	Yes
Capacity	15000	**ATG Test Date**	02/28/2024	**Line Tightness Test Date**	09/14/2023	**Secondary Tank Leak Detection**	Statistical Inventory Reconciliation	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	Yes
		Overfill Test Date	09/14/2023			**ATG Type**					
Tank Number	12	**Tank Age**	5	**Tank Installed Date**	01/10/2020	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	5945	**Spill Test Date**	01/12/2024	**Piping Installed Date**	01/10/2020	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	09/14/2023	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	02/28/2024	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	Yes
Capacity	15000	**ATG Test Date**	02/28/2024	**Line Tightness Test Date**	09/14/2023	**Secondary Tank Leak Detection**	Statistical Inventory Reconciliation	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	Yes
		Overfill Test Date	09/14/2023			**ATG Type**					
Tank Number	13	**Tank Age**	5	**Tank Installed Date**	01/10/2020	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	5946	**Spill Test Date**	09/14/2023	**Piping Installed Date**	01/10/2020	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	09/14/2023	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	02/28/2024	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	20000	**ATG Test Date**	02/28/2024	**Line Tightness Test Date**	09/14/2023	**Secondary Tank Leak Detection**	Statistical Inventory Reconciliation	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	Yes
		Overfill Test Date	09/14/2023			**ATG Type**					

Facility Summary in Cascade County in the City of Great Falls

Location: TOWN PUMP INC GREAT FALLS 3
505 Northwest Byp
Great Falls, MT 59404-4102 Cascade

System Facility ID:56-14016

Facility Code: 30676
Last Inspected On: 03/25/2024
Operating Permit Renewal Date: 08/06/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Great Falls 3 Town Pump LLC **(406) 497-6700** **environmental@townpump.com**

Operator Contact: Trent Biggers **Trentb@townpump.com**

Owner/Operator: Great Falls 3 Town Pump LLC (406) 497-6700 environmental@townpump.com

Trent Biggers, UST Class A Operator Trentb@townpump.com

Trent Biggers, UST Class B Global Operator Trentb@townpump.com

Tank Number	01	**Tank Age**	24	**Tank Installed Date**	10/01/2001	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve
Tag Number	4453	**Spill Test Date**	09/13/2023	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	03/25/2024	**Tank/Piping CP Test Date**	11/30/2005	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	15000	**ATG Test Date**	03/25/2024	**Line Tightness Test Date**	10/12/2006	**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	09/13/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350				
Tank Number	02	**Tank Age**	24	**Tank Installed Date**	10/01/2001	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve
Tag Number	4454	**Spill Test Date**	09/13/2023	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	03/25/2024	**Tank/Piping CP Test Date**	11/30/2005	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	03/25/2024	**Line Tightness Test Date**	10/12/2006	**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	09/13/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350				

Tank Number	03	**Tank Age**	24	**Tank Installed Date**	10/01/2001	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve
Tag Number	4455	**Spill Test Date**	09/13/2023	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	03/25/2024	**Tank/Piping CP Test Date**	11/30/2005	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	5000	**ATG Test Date**	03/25/2024	**Line Tightness Test Date**	10/12/2006	**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	09/13/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350				
Tank Number	04	**Tank Age**	24	**Tank Installed Date**	10/01/2001	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve
Tag Number	4456	**Spill Test Date**	09/13/2023	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	03/25/2024	**Tank/Piping CP Test Date**	11/30/2005	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	03/25/2024	**Line Tightness Test Date**	10/12/2006	**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	09/13/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350				
Tank Number	05	**Tank Age**	24	**Tank Installed Date**	10/01/2001	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve
Tag Number	4457	**Spill Test Date**	09/13/2023	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	03/25/2024	**Tank/Piping CP Test Date**	11/30/2005	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	5000	**ATG Test Date**	03/25/2024	**Line Tightness Test Date**	10/12/2006	**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	09/13/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Cascade County in the City of Great Falls

Location: TOWN PUMP INC GREAT FALLS 4
700 10th Ave S
Great Falls, MT 59405-4051 Cascade

System Facility ID:07-03217

Facility Code: 18470
Last Inspected On: 03/27/2024
Operating Permit Renewal Date: 08/06/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Great Falls 4 Town Pump LLC	**(406) 497-6700**	**environmental@townpump.com**
Operator Contact:	Trent Biggers		**Trentb@townpump.com**

Owner/Operator: Great Falls 4 Town Pump LLC (406) 497-6700 environmental@townpump.com

Trent Biggers, UST Class A Operator — Trentb@townpump.com
Trent Biggers, UST Class A Operator — Trentb@townpump.com
Trent Biggers, UST Class B Global Operator — Trentb@townpump.com
Trent Biggers, UST Class B Global Operator — Trentb@townpump.com

Tank Number	08	**Tank Age**	23	**Tank Installed Date**	08/18/2002	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve
Tag Number	4708	**Spill Test Date**	01/09/2024	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	03/27/2024	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	03/27/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	09/14/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350				
Tank Number	09	**Tank Age**	23	**Tank Installed Date**	08/18/2002	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve
Tag Number	4709	**Spill Test Date**	09/14/2023	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel, Dyed	**PLLD Test Date**	03/27/2024	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	5000	**ATG Test Date**	03/27/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No

		Overfill Test Date	09/14/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350				
Tank Number	05	**Tank Age**	30	**Tank Installed Date**	08/01/1995	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve
Tag Number	4804	**Spill Test Date**	12/15/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	03/27/2024	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	2000	**ATG Test Date**	03/27/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	09/14/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350				
Tank Number	06	**Tank Age**	30	**Tank Installed Date**	08/01/1995	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve
Tag Number	4805	**Spill Test Date**	09/14/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	03/27/2024	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	03/27/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	09/14/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350				
Tank Number	07	**Tank Age**	30	**Tank Installed Date**	08/01/1995	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve
Tag Number	4806	**Spill Test Date**	12/15/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	03/27/2024	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	03/27/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	09/14/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Cascade County in the City of Great Falls

Location: TOWN PUMP INC GREAT FALLS 5
3700 31st St SW Ste 1
Great Falls, MT 59404-4734 Cascade

System Facility ID:07-03463

Facility Code: 18483
Last Inspected On: 03/27/2024
Operating Permit Renewal Date: 08/06/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Great Falls 5 Town Pump Inc **(406) 497-6000** **environmental@townpump.com**

Operator Contact: Trent Biggers **Trentb@townpump.com**

Owner/Operator: Great Falls 5 Town Pump Inc (406) 497-6000 environmental@townpump.com

Trent Biggers, UST Class A Operator Trentb@townpump.com
Trent Biggers, UST Class A Operator Trentb@townpump.com
Trent Biggers, UST Class B Global Operator Trentb@townpump.com
Trent Biggers, UST Class B Global Operator Trentb@townpump.com

Tank Number	04	**Tank Age**	36	**Tank Installed Date**	01/15/1989	**Tank Material Construction**	Steel Clad	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve
Tag Number	2223	**Spill Test Date**	12/15/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Diesel, Dyed	**PLLD Test Date**	03/27/2024	**Tank/Piping CP Test Date**	09/21/2023	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**	03/27/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	08/31/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350				
Tank Number	07	**Tank Age**	36	**Tank Installed Date**	01/15/1989	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve
Tag Number	2224	**Spill Test Date**	01/12/2024	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	08/02/2021	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**	03/27/2024	**Tank/Piping CP Test Date**	12/12/2023	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	14000	**ATG Test Date**	03/27/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No

		Overfill Test Date	08/31/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350				
Tank Number	08	**Tank Age**	32	**Tank Installed Date**	04/01/1993	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve
Tag Number	2225	**Spill Test Date**	08/31/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**	03/27/2024	**Tank/Piping CP Test Date**	09/21/2023	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	Yes
Capacity	10000	**ATG Test Date**	03/27/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	08/31/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350				
Tank Number	09	**Tank Age**	32	**Tank Installed Date**	04/01/1993	**Tank Material Construction**	Bare Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve
Tag Number	2226	**Spill Test Date**	12/15/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**	03/27/2024	**Tank/Piping CP Test Date**	12/12/2023	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**	03/27/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	08/31/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350				
Tank Number	10	**Tank Age**	32	**Tank Installed Date**	04/01/1993	**Tank Material Construction**	Bare Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve
Tag Number	2227	**Spill Test Date**	08/31/2023	**Piping Installed Date**	10/20/2019	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	09/03/2019	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**	03/27/2024	**Tank/Piping CP Test Date**	09/21/2023	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**	03/27/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	No
		Overfill Test Date	08/31/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350				
Tank Number	11	**Tank Age**	19	**Tank Installed Date**	04/25/2006	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve;Flapper Valve
Tag Number	5080	**Spill Test Date**	08/31/2023	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No

Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	03/27/2024	**Tank/Piping CP Test Date**	03/12/2010	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	30000	**ATG Test Date**	03/27/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	08/31/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350				
Tank Number	12	**Tank Age**	19	**Tank Installed Date**	04/26/2006	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve;Flapper Valve
Tag Number	5081	**Spill Test Date**	08/31/2023	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Continuous Interstitial Monitoring	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	03/27/2024	**Tank/Piping CP Test Date**	03/12/2010	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	30000	**ATG Test Date**	03/27/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	08/31/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350				
Tank Number	13	**Tank Age**	19	**Tank Installed Date**	04/25/2006	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	5082	**Spill Test Date**	08/31/2023	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	03/27/2024	**Tank/Piping CP Test Date**	03/12/2010	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	30000	**ATG Test Date**	03/27/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	08/31/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350				
Tank Number	14	**Tank Age**	0	**Tank Installed Date**		**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass	**Overfill Types**	High Level Alarm
Tag Number	5362	**Spill Test Date**		**Piping Installed Date**	04/12/2012	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Other**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Continuous Interstitial Monitoring	**Piping Type**	Not Listed	**CP Met Types**	

Product	DEF (Not Regulated)	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.1	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring;Not Listed	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Cascade County in the City of Great Falls

Location: WALMART SUPERCENTER #7199
5400 10th Ave S
Great Falls, MT 59405 Cascade

System Facility ID:60-15280

Facility Code: 30988
Last Inspected On: 03/21/2023
Operating Permit Renewal Date: 09/10/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Walmart Inc	**(877) 829-5505**	**walmartepmsupport@aptim.com**
Operator Contact:	Treavor Harpine	**(406) 770-6083**	**treavor12321@gmail.com**

Owner/Operator: Walmart Inc (877) 829-5505 walmartepmsupport@aptim.com

Treavor Harpine, UST Class A Operator treavor12321@gmail.com

Treavor Harpine, UST Class B Global Operator treavor12321@gmail.com

Tank Number	01	**Tank Age**	8	**Tank Installed Date**	03/01/2017	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	5646	**Spill Test Date**	02/05/2020	**Piping Installed Date**	03/01/2017	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	02/05/2020	**Sump Tightness Test Date**	10/17/2019	**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	Yes
Capacity	20000	**ATG Test Date**		**Line Tightness Test Date**	02/05/2020	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	MLLD Line Tightness Testing	**Energy Act**	Yes
		Overfill Test Date	02/05/2020			**ATG Type**	Gilbarco-Veeder Root/TLS-450				
Tank Number	02	**Tank Age**	8	**Tank Installed Date**	03/01/2017	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	5647	**Spill Test Date**	02/05/2020	**Piping Installed Date**	03/01/2017	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	02/05/2020	**Sump Tightness Test Date**	10/17/2019	**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	Yes
Capacity	12000	**ATG Test Date**		**Line Tightness Test Date**	02/05/2020	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	MLLD Line Tightness Testing	**Energy Act**	Yes
		Overfill Test Date	02/05/2020			**ATG Type**	Gilbarco-Veeder Root/TLS-450				
Tank Number	03	**Tank Age**	8	**Tank Installed Date**	03/01/2017	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve

Tag Number	5648	**Spill Test Date**	02/05/2020	**Piping Installed Date**	03/01/2017	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	02/05/2020	**Sump Tightness Test Date**	10/17/2019	**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**		**Line Tightness Test Date**	02/05/2020	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	MLLD Line Tightness Testing	**Energy Act**	Yes
		Overfill Test Date	02/05/2020			**ATG Type**	Gilbarco-Veeder Root/TLS-450				

Facility Summary in Cascade County in the City of Great Falls

Location: ZIP TRIP 45
625 1st Ave N
Great Falls, MT 59401-2510 Cascade

System Facility ID:07-01057

Facility Code: 18375
Last Inspected On: 03/18/2025
Operating Permit Renewal Date: 03/30/2028

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	CHS Inc Spokane Valley	**(509) 535-7701**	**Donald.Widdicombe@chsinc.com**
Operator Contact:	Jim Alford;Sean Hurley	**(509) 535-7701;(509) 536-7418**	**jim.alford@chsinc.com;sean.hurley@chsinc.com**

Owner/Operator: CHS Inc Spokane Valley (509) 535-7701 Donald.Widdicombe@chsinc.com

Jim Alford, UST Class A Operator	jim.alford@chsinc.com
Jim Alford, UST Class A Operator	jim.alford@chsinc.com
Jim Alford, UST Class B Operator	jim.alford@chsinc.com
Jim Alford, UST Class B Operator	jim.alford@chsinc.com
Luci Tuttle, UST Class B Operator	Lucinda.Tuttle@chsinc.com
Luci Tuttle, UST Class B Operator	Lucinda.Tuttle@chsinc.com
Sean Hurley, UST Class A Operator	sean.hurley@chsinc.com
Sean Hurley, UST Class A Operator	sean.hurley@chsinc.com
Travis Weber, UST Class B Operator	Donald.Widdicombe@chsinc.com
Travis Weber, UST Class B Operator	Donald.Widdicombe@chsinc.com

Tank Number	01	**Tank Age**	43	**Tank Installed Date**	04/27/1982	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	1610	**Spill Test Date**	06/29/2022	**Piping Installed Date**	03/14/2025	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	02/26/2025	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Diesel	**PLLD Test Date**	08/08/2024	**Tank/Piping CP Test Date**	03/18/2025	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	15000	**ATG Test Date**	08/08/2024	**Line Tightness Test Date**	09/20/2023	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	08/08/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	02	**Tank Age**	43	**Tank Installed Date**	04/27/1982	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	1611	**Spill Test Date**	06/29/2022	**Piping Installed Date**	03/14/2025	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No

Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	02/26/2025	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**	08/08/2024	**Tank/Piping CP Test Date**	03/18/2025	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	15000	**ATG Test Date**	08/08/2024	**Line Tightness Test Date**	06/21/2021	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	08/08/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	03	**Tank Age**	43	**Tank Installed Date**	04/27/1982	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	1612	**Spill Test Date**	06/29/2022	**Piping Installed Date**	03/14/2025	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	02/26/2025	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**	08/08/2024	**Tank/Piping CP Test Date**	03/18/2025	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	15000	**ATG Test Date**	08/08/2024	**Line Tightness Test Date**	06/16/2021	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	08/08/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Cascade County in the City of Malmstrom A F B

Location: MALMSTROM AFB BLDG 1480 1482
6705 Flightline Dr
Malmstrom A F B, MT 59402-7524 Cascade

System Facility ID:07-10733

Facility Code: 18844
Last Inspected On: 05/18/2024
Operating Permit Renewal Date: 09/22/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: 341 CES CEANQ **(406) 731-6188**

Operator Contact: Candace Ellsworth;Curtis Hester;William Smith **(406) 731-6239;(406) 731-7128** **candace.ellsworth@us.af.mil;william.smith@us.af.mil**

Owner/Operator: 341 CES CEANQ (406) 731-6188

Candace Ellsworth, UST Class A Operator	candace.ellsworth@us.af.mil
Candace Ellsworth, UST Class B Global Operator	candace.ellsworth@us.af.mil
Curtis Hester, UST Class A Operator	
Curtis Hester, UST Class B Global Operator	
Rodney Borger, UST Class B Global Operator	rodney.borger.ctr@malmstrom.af.mil
William Smith, UST Class A Operator	william.smith@us.af.mil
William Smith, UST Class B Global Operator	william.smith@us.af.mil

Tank Number	04	**Tank Age**	29	**Tank Installed Date**	08/01/1996	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Steel	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	4325	**Spill Test Date**	05/18/2024	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	03/31/2021	**Sump Tightness Test Date**	03/31/2021	**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Jet Fuel, JP8	**PLLD Test Date**		**Tank/Piping CP Test Date**	03/31/2021	**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	05/02/2024	**Line Tightness Test Date**	11/26/2012	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	05/02/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Cascade County in the City of Malmstrom A F B

Location: MALMSTROM AFB BLDG 500
21 77th St N
Malmstrom A F B, MT 59402-7538 Cascade

System Facility ID:07-08954

Facility Code: 18720
Last Inspected On: 05/18/2024
Operating Permit Renewal Date: 09/22/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: 341 CES CEANQ **(406) 731-6188**

Operator Contact: Candace Ellsworth;Curtis Hester;William Smith **(406) 731-6239;(406) 731-7128** **candace.ellsworth@us.af.mil;william.smith@us.af.mil**

Owner/Operator: 341 CES CEANQ (406) 731-6188

Candace Ellsworth, UST Class A Operator	candace.ellsworth@us.af.mil
Candace Ellsworth, UST Class B Global Operator	candace.ellsworth@us.af.mil
Curtis Hester, UST Class A Operator	
Curtis Hester, UST Class B Global Operator	
David Degolier, UST Class B Operator	david.degolier@us.af.mil
William Smith, UST Class A Operator	william.smith@us.af.mil
William Smith, UST Class B Global Operator	william.smith@us.af.mil

Tank Number	07	**Tank Age**	25	**Tank Installed Date**	11/22/2000	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	4227	**Spill Test Date**	05/18/2024	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	03/31/2021	**Catastrophic L.D. Type 3.0**	Auto Dialer	**Piping Type**	U.S. Suction	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	05/04/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	05/04/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				

Facility Summary in Cascade County in the City of Malmstrom A F B

Location: MILITARY VEHICLE REFUELING SITE BLDG 448
7832 Flightline Dr
Malmstrom A F B, MT 59402-7525 Cascade

System Facility ID:56-14116

Facility Code: 30757
Last Inspected On: 05/18/2024
Operating Permit Renewal Date: 09/22/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Malmstrom A F B **(406) 731-6167**

Operator Contact: Candace Ellsworth;Curtis Hester;William Smith **(406) 731-6239;(406) 731-7128** **candace.ellsworth@us.af.mil;william.smith@us.af.mil**

Owner/Operator: Malmstrom A F B (406) 731-6167

Candace Ellsworth, UST Class A Operator	candace.ellsworth@us.af.mil
Candace Ellsworth, UST Class B Global Operator	candace.ellsworth@us.af.mil
Curtis Hester, UST Class A Operator	
Curtis Hester, UST Class B Global Operator	
William Smith, UST Class A Operator	william.smith@us.af.mil
William Smith, UST Class B Global Operator	william.smith@us.af.mil

Tank Number	S1	**Tank Age**	20	**Tank Installed Date**	06/15/2005	**Tank Material Construction**	Concrete	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	4971	**Spill Test Date**		**Piping Installed Date**	07/29/2020	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	Yes
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	05/18/2024	**Catastrophic L.D. Type 3.0**	Auto Dialer	**Piping Type**	Pressurized	**CP Met Types**	
Product	Biodiesel, <=B20	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	60000	**ATG Test Date**		**Line Tightness Test Date**	07/29/2020	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	S2	**Tank Age**	20	**Tank Installed Date**	08/05/2005	**Tank Material Construction**	Concrete	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	4972	**Spill Test Date**		**Piping Installed Date**	07/29/2020	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	Yes
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	05/18/2024	**Catastrophic L.D. Type 3.0**	Auto Dialer	**Piping Type**	Pressurized	**CP Met Types**	
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	20000	**ATG Test Date**		**Line Tightness Test Date**	07/29/2020	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No

		Overfill Test Date				**ATG Type**					
Tank Number	S3	**Tank Age**	20	**Tank Installed Date**	08/05/2005	**Tank Material Construction**	Concrete	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	5037	**Spill Test Date**		**Piping Installed Date**	07/29/2020	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	Yes
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	05/18/2024	**Catastrophic L.D. Type 3.0**	Auto Dialer	**Piping Type**	Pressurized	**CP Met Types**	
Product	Gasoline, E85	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**		**Line Tightness Test Date**	07/29/2020	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					

Facility Summary in Cascade County in the City of Malmstrom AFB

Location: AAFES SHOPPING CENTER BLDG 1340
7200 Perimeter Rd
Malmstrom AFB, MT 59402 Cascade

System Facility ID:60-15199

Facility Code: 30920
Last Inspected On: 05/18/2024
Operating Permit Renewal Date: 09/22/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Malmstrom A F B	**(406) 731-6167**	
Operator Contact:	Ashley Collins;Candace Ellsworth;Famh Kosoff;Fatima Quintanilla;James Nau;Malmstrom A F B;Sonya Coker	**(406) 454-1301;(406) 731-6167;(406) 731-7128;(406) 761-8004**	**ashley.collins@7g-enviro.com;candace.ellsworth@us.af.mil;cokers@aafes.com;naujm@aafes.com;quintanillafm@aafes.com**

Owner/Operator: Malmstrom A F B (406) 731-6167

Ashley Collins, UST Class A Operator	ashley.collins@7g-enviro.com
Ashley Collins, UST Class B Global Operator	ashley.collins@7g-enviro.com
Candace Ellsworth, UST Class A Operator	candace.ellsworth@us.af.mil
Candace Ellsworth, UST Class B Global Operator	candace.ellsworth@us.af.mil
Famh Kosoff, UST Class A Operator	
Fatima Quintanilla, UST Class A Operator	quintanillafm@aafes.com
Fatima Quintanilla, UST Class B Operator	quintanillafm@aafes.com
James Nau, UST Class A Operator	naujm@aafes.com
James Nau, UST Class B Operator	naujm@aafes.com
Ken Chorpenning, UST Class B Global Operator	chorpenningk@aafes.com
Sonya Coker, UST Class A Operator	cokers@aafes.com
Sonya Coker, UST Class B Global Operator	cokers@aafes.com
Sonya Coker, UST Class B Operator	cokers@aafes.com

Tank Number	01	**Tank Age**	14	**Tank Installed Date**	09/01/2011	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	5329	**Spill Test Date**	05/18/2024	**Piping Installed Date**	08/31/2011	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	05/14/2018	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	05/28/2024	**Tank/Piping CP Test Date**	06/11/2012	**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	15000	**ATG Test Date**	05/28/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	05/28/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS;Veeder Root/TLS-450PLUS				

Tank Number	02	**Tank Age**	14	**Tank Installed Date**	09/01/2011	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	5330	**Spill Test Date**	05/18/2024	**Piping Installed Date**	08/31/2011	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	05/14/2018	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	05/28/2024	**Tank/Piping CP Test Date**	06/11/2012	**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	20000	**ATG Test Date**	05/28/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	05/28/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS;Veeder Root/TLS-450PLUS				

Facility Summary in Cascade County in the City of Monarch

Location: COUGAR CANYON LODGE and ESCAPE
5012 US Hwy 89 S
Monarch, MT 59463 Cascade

System Facility ID:07-01874

Facility Code: 18415
Last Inspected On: 09/29/2022
Operating Permit Renewal Date: 09/29/2025

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Mark Properties LLC	**(406) 236-5922**	**heatmechanical@gmail.com**
Operator Contact:	Richard Hatanpaa	**(406) 236-5922**	**cougarcanyonlodge@gmail.com**

Owner/Operator: Mark Properties LLC (406) 236-5922 heatmechanical@gmail.com
Richard Hatanpaa, UST Class A Operator cougarcanyonlodge@gmail.com
Richard Hatanpaa, UST Class B Operator cougarcanyonlodge@gmail.com

Tank Number	01	**Tank Age**	33	**Tank Installed Date**	09/01/1992	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	2979	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Temporarily Out of Use**	**MLLD Test Date**	05/16/2019	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	2000	**ATG Test Date**		**Line Tightness Test Date**	05/16/2019	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					

Facility Summary in Cascade County in the City of Monarch

Location: MALMSTROM AFB A 5
US Hwy 89
Monarch, MT 59463 Cascade

System Facility ID:07-08979

Facility Code: 18740
Last Inspected On: 06/14/2024
Operating Permit Renewal Date: 09/25/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: 341 CES CEANQ **(406) 731-6188**

Operator Contact: Candace Ellsworth;Curtis Hester;William Smith **(406) 731-6239;(406) 731-7128** **candace.ellsworth@us.af.mil;william.smith@us.af.mil**

Owner/Operator: 341 CES CEANQ (406) 731-6188

Candace Ellsworth, UST Class A Operator	candace.ellsworth@us.af.mil
Candace Ellsworth, UST Class B Global Operator	candace.ellsworth@us.af.mil
Curtis Hester, UST Class A Operator	
Curtis Hester, UST Class B Global Operator	
William Smith, UST Class A Operator	william.smith@us.af.mil
William Smith, UST Class B Global Operator	william.smith@us.af.mil

Tank Number	02	**Tank Age**	33	**Tank Installed Date**	06/01/1992	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	110	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	07/17/2020	**Catastrophic L.D. Type 3.0**	Auto Dialer	**Piping Type**	U.S. Suction	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	05/03/2022	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	05/03/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Cascade County in the City of Monarch

Location: MALMSTROM AFB A 6
US Hwy 89
Monarch, MT 59463 Cascade

System Facility ID:07-08980

Facility Code: 18741
Last Inspected On: 06/14/2024
Operating Permit Renewal Date: 09/25/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: 341 CES CEANQ **(406) 731-6188**

Operator Contact: Candace Ellsworth;Curtis Hester;William Smith **(406) 731-6239;(406) 731-7128** **candace.ellsworth@us.af.mil;william.smith@us.af.mil**

Owner/Operator: 341 CES CEANQ (406) 731-6188

Candace Ellsworth, UST Class A Operator	candace.ellsworth@us.af.mil
Candace Ellsworth, UST Class B Global Operator	candace.ellsworth@us.af.mil
Curtis Hester, UST Class A Operator	
Curtis Hester, UST Class B Global Operator	
William Smith, UST Class A Operator	william.smith@us.af.mil
William Smith, UST Class B Global Operator	william.smith@us.af.mil

Tank Number	02	**Tank Age**	33	**Tank Installed Date**	06/01/1992	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	111	**Spill Test Date**	07/17/2020	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	05/18/2020	**Catastrophic L.D. Type 3.0**	Auto Dialer	**Piping Type**	U.S. Suction	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	05/03/2022	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	05/03/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Cascade County in the City of Monarch

Location: MALMSTROM AFB A 7
US Hwy 89
Monarch, MT 59463 Cascade

System Facility ID:07-08981

Facility Code: 18742
Last Inspected On: 06/14/2024
Operating Permit Renewal Date: 10/07/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: 341 CES CEANQ **(406) 731-6188**

Operator Contact: Candace Ellsworth;Curtis Hester;William Smith **(406) 731-6239;(406) 731-7128** **candace.ellsworth@us.af.mil;william.smith@us.af.mil**

Owner/Operator: 341 CES CEANQ (406) 731-6188

Candace Ellsworth, UST Class A Operator	candace.ellsworth@us.af.mil
Candace Ellsworth, UST Class B Global Operator	candace.ellsworth@us.af.mil
Curtis Hester, UST Class A Operator	
Curtis Hester, UST Class B Global Operator	
William Smith, UST Class A Operator	william.smith@us.af.mil
William Smith, UST Class B Global Operator	william.smith@us.af.mil

Tank Number	02	**Tank Age**	33	**Tank Installed Date**	06/01/1992	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	112	**Spill Test Date**	05/05/2023	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	05/05/2023	**Catastrophic L.D. Type 3.0**	Auto Dialer	**Piping Type**	U.S. Suction	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	05/05/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	05/05/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Cascade County in the City of Monarch

Location: MALMSTROM AFB A 8
US Hwy 89
Monarch, MT 59463 Cascade

System Facility ID:07-08982

Facility Code: 18743
Last Inspected On: 06/14/2024
Operating Permit Renewal Date: 09/25/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: 341 CES CEANQ **(406) 731-6188**

Operator Contact: Candace Ellsworth;Curtis Hester;William Smith **(406) 731-6239;(406) 731-7128** **candace.ellsworth@us.af.mil;william.smith@us.af.mil**

Owner/Operator: 341 CES CEANQ (406) 731-6188

Candace Ellsworth, UST Class A Operator	candace.ellsworth@us.af.mil
Candace Ellsworth, UST Class B Global Operator	candace.ellsworth@us.af.mil
Curtis Hester, UST Class A Operator	
Curtis Hester, UST Class B Global Operator	
William Smith, UST Class A Operator	william.smith@us.af.mil
William Smith, UST Class B Global Operator	william.smith@us.af.mil

Tank Number	02	**Tank Age**	33	**Tank Installed Date**	06/01/1992	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	113	**Spill Test Date**	07/17/2020	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	05/18/2020	**Catastrophic L.D. Type 3.0**	Auto Dialer	**Piping Type**	U.S. Suction	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	05/03/2022	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	05/03/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Cascade County in the City of Neihart

Location: BOBS BAR UST
107 Main St
Neihart, MT 59465-0037 Cascade

System Facility ID:07-09274

Facility Code: 18768
Last Inspected On: 04/15/2021
Operating Permit Renewal Date: 05/16/2024

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Smith Bagheri LLC	**(406) 236-5955**	**jsmithbagheri@gmail.com**
Operator Contact:	Janice Smith-Bagheri	**(406) 236-5955**	**jsmithbagheri@gmail.com**

Janice Smith-Bagheri, UST Class A Operator	jsmithbagheri@gmail.com
Janice Smith-Bagheri, UST Class A Operator	jsmithbagheri@gmail.com
Janice Smith-Bagheri, UST Class B Operator	jsmithbagheri@gmail.com
Janice Smith-Bagheri, UST Class B Operator	jsmithbagheri@gmail.com

Tank Number	01	**Tank Age**	38	**Tank Installed Date**	02/16/1987	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	1455	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Single Walled	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	03/31/2021	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	3000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/				
Tank Number	02	**Tank Age**	38	**Tank Installed Date**	02/16/1987	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	1456	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Single Walled	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	03/31/2021	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	3000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/				

Facility Summary in Cascade County in the City of Sand Coulee

Location: CENTERVILLE ELEMENTARY SCHOOL
693 Stockett Rd
Sand Coulee, MT 59472-9757 Cascade

System Facility ID:07-11037

Facility Code: 18866
Last Inspected On: 02/17/2017
Operating Permit Renewal Date: 01/16/2019

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Centerville School **(406) 736-5123**

Operator Contact: Steve Beaumont **(406) 736-5123** **steveb@centerville.k12.mt.us**

Steve Beaumont, UST Class A Operator steveb@centerville.k12.mt.us
Steve Beaumont, UST Class B Operator steveb@centerville.k12.mt.us

Tank Number	S1	**Tank Age**	39	**Tank Installed Date**	04/30/1986	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	606	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Gravity Feed	**CP Met Types**	Galvanic
Product	Heating Oil	**PLLD Test Date**		**Tank/Piping CP Test Date**	03/28/2017	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	20000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date				**ATG Type**					

Facility Summary in Cascade County in the City of Simms

Location: CURTISS SERVICE CENTER
12742 MT Hwy 200
Simms, MT 59477 Cascade

System Facility ID:07-01612

Facility Code: 18399
Last Inspected On: 05/16/2023
Operating Permit Renewal Date: 07/30/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Robert Curtiss;Robert D Curtiss	**(406) 264-5640**	**bobnsheree@live.com**
Operator Contact:	Robert D Curtiss	**(406) 264-5640**	**bobnsheree@live.com**

Owner/Operator: Robert D Curtiss

Robert D Curtiss, UST Class A Operator	bobnsheree@live.com
Robert D Curtiss, UST Class A Operator	bobnsheree@live.com
Robert D Curtiss, UST Class B Operator	bobnsheree@live.com
Robert D Curtiss, UST Class B Operator	bobnsheree@live.com

Tank Number	06	**Tank Age**	26	**Tank Installed Date**	11/01/1999	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	4124	**Spill Test Date**	08/31/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	05/16/2023	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	05/16/2023	**Line Tightness Test Date**	05/16/2023	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	08/31/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	07	**Tank Age**	26	**Tank Installed Date**	11/01/1999	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	4125	**Spill Test Date**	08/31/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	05/16/2023	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	05/16/2023	**Line Tightness Test Date**	05/16/2023	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	08/31/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Tank Number	08	**Tank Age**	26	**Tank Installed Date**	11/01/1999	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	4126	**Spill Test Date**	08/31/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	05/16/2023	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	05/16/2023	**Line Tightness Test Date**	05/16/2023	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	08/31/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	09	**Tank Age**	26	**Tank Installed Date**	11/01/1999	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	4127	**Spill Test Date**	08/31/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	05/16/2023	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	05/16/2023	**Line Tightness Test Date**	05/16/2023	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	08/31/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Cascade County in the City of Simms

Location: MALMSTROM AFB G 1
MT Hwy 200
Simms, MT 59477 Cascade

System Facility ID:25-09041

Facility Code: 23811
Last Inspected On: 05/16/2024
Operating Permit Renewal Date: 09/22/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	341 CES CEANQ	**(406) 731-6188**	
Operator Contact:	Candace Ellsworth;Curtis Hester;William Smith	**(406) 731-6239;(406) 731-7128**	**candace.ellsworth@us.af.mil;william.smith@us.af.mil**

Owner/Operator: 341 CES CEANQ (406) 731-6188

Aaron Hill, UST Class B Operator	aaron.hill@malmstrom.af.mil
Allen Brooks, UST Class B Operator	allen.brooks@malmstrom.af.mil
Bethany Kent, UST Class B Operator	bethany.kent@malmstrom.af.mil
Brian Day, UST Class B Operator	brian.day@malmstrom.af.mil
Brian McVay, UST Class B Operator	
Brian Rayner, UST Class B Operator	brian.rayner@malmstrom.af.mil
Cameron Smith, UST Class B Operator	cameron.smith@malmstrom.af.mil
Candace Ellsworth, UST Class A Operator	candace.ellsworth@us.af.mil
Candace Ellsworth, UST Class B Global Operator	candace.ellsworth@us.af.mil
Chris Ploof, UST Class B Operator	chris.ploof@malmstrom.af.mil
Curtis Hester, UST Class A Operator	
Curtis Hester, UST Class B Global Operator	
Damon McCarty, UST Class B Operator	damon.mccarty@malmstrom.af.mil
David Cosner, UST Class B Operator	david.cosner@malmstrom.af.mil
David Degolier, UST Class B Operator	david.degolier@us.af.mil
Dustin Hemingway, UST Class B Operator	dustin.hemingway@malmstrom.af.mil
Glen Beck, UST Class B Operator	glen.beck@malmstrom.af.mil
Hudson English, UST Class B Operator	hudson.english@malmstrom.af.mil
Issac Price, UST Class B Operator	Issac.Price@malmstrom.af.mil
James Knudsen, UST Class B Operator	james.knudsen@malmstrom.af.mil
James Wooderchak, UST Class B Operator	jwooderchak@yahoo.com
Jason Vike, UST Class B Operator	jason.vike@malmstrom.af.mil
Jeff Laird, UST Class B Operator	jeffrey.laird@malmstrom.af.mil
Jeff Nelson, UST Class B Operator	jeffrey.nelson@malmstrom.af.mil
Jimmy Sonefelt, UST Class B Operator	jimmy.sonefelt@malmstrom.af.mil
John Corbett, UST Class B Operator	john.corbett.2@us.af.mil

Jonathan Buesch, UST Class B Operator	jonathan.buesch@malmstrom.af.mil
Kieth McIlwain, UST Class B Operator	keith.mcilwain@malmstrom.af.mil
Kyle Topp, UST Class B Operator	kyle.topp@us.af.mil
Michael Murieen, UST Class B Operator	michael.murieen@malmstrom.af.mil
Michael Stokes, UST Class B Operator	michael.stokes@malmstrom.af.mil
Patrick Ellis, UST Class B Operator	patrick.ellis@malmstrom.af.mil
Patrick Noppenberg, UST Class B Operator	patrick.noppenberg@malmstrom.af.mil
Paul Floyd, UST Class B Global Operator	paul.floyd@malmstrom.af.mil
Paul Floyd, UST Class B Operator	paul.floyd@malmstrom.af.mil
Paul Ziemba, UST Class B Operator	paul.ziemba@malmstrom.af.mil
Ricardo Andrillon, UST Class B Operator	ricardo.andrillon@malmstrom.af.mil
Ronald Miller, UST Class B Operator	ronald.miller@malmstrom.af.mil
Ryan Cox, UST Class B Operator	ryan.cox@malmstrom.af.mil
Ryan Kofoed, UST Class B Operator	ryan.kofoed@malmstrom.af.mil
Shane Hofstad, UST Class B Operator	shane.hofstad@malmstrom.af.mil
Shawn Ogrady, UST Class B Operator	shawn.ogrady@malmstrom.af.mil
William Hoffmeister, UST Class B Operator	william.hoffmeister@malmstrom.af.mil
William Smith, UST Class A Operator	william.smith@us.af.mil
William Smith, UST Class B Global Operator	william.smith@us.af.mil

Tank Number	01	**Tank Age**	63	**Tank Installed Date**	06/02/1962	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	250	**Spill Test Date**	05/16/2024	**Piping Installed Date**		**Tank Construction**	Lined Interior/Impressed Current	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	05/16/2024	**Catastrophic L.D. Type 3.0**	Auto Dialer	**Piping Type**	U.S. Suction	**CP Met Types**	Impressed Current
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	05/11/2021	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	12/10/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	12/10/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				

Facility Summary in Cascade County in the City of Simms

Location: MALMSTROM AFB G 11
MT Hwy 200
Simms, MT 59477 Cascade

System Facility ID:25-09051

Facility Code: 23817
Last Inspected On: 04/18/2024
Operating Permit Renewal Date: 09/22/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: 341 CES CEANQ **(406) 731-6188**

Operator Contact: Candace Ellsworth;Curtis Hester;William Smith **(406) 731-6239;(406) 731-7128** **candace.ellsworth@us.af.mil;william.smith@us.af.mil**

Owner/Operator: 341 CES CEANQ (406) 731-6188

Candace Ellsworth, UST Class A Operator	candace.ellsworth@us.af.mil
Candace Ellsworth, UST Class B Global Operator	candace.ellsworth@us.af.mil
Curtis Hester, UST Class A Operator	
Curtis Hester, UST Class B Global Operator	
William Smith, UST Class A Operator	william.smith@us.af.mil
William Smith, UST Class B Global Operator	william.smith@us.af.mil

Tank Number	02	**Tank Age**	36	**Tank Installed Date**	05/21/1989	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	256	**Spill Test Date**	04/04/2024	**Piping Installed Date**	08/18/2020	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	04/04/2024	**Catastrophic L.D. Type 3.0**	Auto Dialer	**Piping Type**	U.S. Suction	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	04/04/2024	**Line Tightness Test Date**	08/20/2020	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	04/04/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Cascade County in the City of Simms

Location: MALMSTROM AFB G 2
MT Hwy 200
Simms, MT 59477 Cascade

System Facility ID:07-09042

Facility Code: 18747
Last Inspected On: 04/18/2024
Operating Permit Renewal Date: 09/22/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: 341 CES CEANQ **(406) 731-6188**

Operator Contact: Candace Ellsworth;Curtis Hester;William Smith **(406) 731-6239;(406) 731-7128** **candace.ellsworth@us.af.mil;william.smith@us.af.mil**

Owner/Operator: 341 CES CEANQ (406) 731-6188

Candace Ellsworth, UST Class A Operator	candace.ellsworth@us.af.mil
Candace Ellsworth, UST Class B Global Operator	candace.ellsworth@us.af.mil
Curtis Hester, UST Class A Operator	
Curtis Hester, UST Class B Global Operator	
William Smith, UST Class A Operator	william.smith@us.af.mil
William Smith, UST Class B Global Operator	william.smith@us.af.mil

Tank Number	02	**Tank Age**	33	**Tank Installed Date**	06/01/1992	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	117	**Spill Test Date**	04/18/2024	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	04/18/2024	**Catastrophic L.D. Type 3.0**	Auto Dialer	**Piping Type**	U.S. Suction	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	04/18/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	04/18/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Cascade County in the City of Simms

Location: MALMSTROM AFB G 6
Road 287
Simms, MT 59477 Cascade

System Facility ID:25-09046

Facility Code: 23812
Last Inspected On: 04/17/2024
Operating Permit Renewal Date: 09/23/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: 341 CES CEANQ **(406) 731-6188**

Operator Contact: Candace Ellsworth;Curtis Hester;William Smith **(406) 731-6239;(406) 731-7128** **candace.ellsworth@us.af.mil;william.smith@us.af.mil**

Owner/Operator: 341 CES CEANQ (406) 731-6188

Candace Ellsworth, UST Class A Operator	candace.ellsworth@us.af.mil
Candace Ellsworth, UST Class B Global Operator	candace.ellsworth@us.af.mil
Curtis Hester, UST Class A Operator	
Curtis Hester, UST Class B Global Operator	
William Smith, UST Class A Operator	william.smith@us.af.mil
William Smith, UST Class B Global Operator	william.smith@us.af.mil

Tank Number	02	**Tank Age**	33	**Tank Installed Date**	05/01/1992	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	251	**Spill Test Date**	04/17/2024	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	04/17/2024	**Catastrophic L.D. Type 3.0**	Auto Dialer	**Piping Type**	U.S. Suction	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	04/17/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	04/17/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Cascade County in the City of Simms

Location: MALMSTROM AFB G 7
MT Hwy 200
Simms, MT 59477 Cascade

System Facility ID:25-09047

Facility Code: 23813
Last Inspected On: 04/17/2024
Operating Permit Renewal Date: 09/22/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: 341 CES CEANQ **(406) 731-6188**

Operator Contact: Candace Ellsworth;Curtis Hester;William Smith **(406) 731-6239;(406) 731-7128** **candace.ellsworth@us.af.mil;william.smith@us.af.mil**

Owner/Operator: 341 CES CEANQ (406) 731-6188

Candace Ellsworth, UST Class A Operator	candace.ellsworth@us.af.mil
Candace Ellsworth, UST Class B Global Operator	candace.ellsworth@us.af.mil
Curtis Hester, UST Class A Operator	
Curtis Hester, UST Class B Global Operator	
William Smith, UST Class A Operator	william.smith@us.af.mil
William Smith, UST Class B Global Operator	william.smith@us.af.mil

Tank Number	02	**Tank Age**	33	**Tank Installed Date**	05/01/1992	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	4271	**Spill Test Date**	05/24/2024	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	05/24/2024	**Catastrophic L.D. Type 3.0**	Auto Dialer	**Piping Type**	U.S. Suction	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	05/24/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	05/24/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Cascade County in the City of Simms

Location: MALMSTROM AFB G 8
MT Hwy 200
Simms, MT 59477 Cascade

System Facility ID:25-09048

Facility Code: 23814
Last Inspected On: 04/17/2024
Operating Permit Renewal Date: 09/22/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: 341 CES CEANQ **(406) 731-6188**

Operator Contact: Candace Ellsworth;Curtis Hester;William Smith **(406) 731-6239;(406) 731-7128** **candace.ellsworth@us.af.mil;william.smith@us.af.mil**

Owner/Operator: 341 CES CEANQ (406) 731-6188

Candace Ellsworth, UST Class A Operator	candace.ellsworth@us.af.mil
Candace Ellsworth, UST Class B Global Operator	candace.ellsworth@us.af.mil
Curtis Hester, UST Class A Operator	
Curtis Hester, UST Class B Global Operator	
William Smith, UST Class A Operator	william.smith@us.af.mil
William Smith, UST Class B Global Operator	william.smith@us.af.mil

Tank Number	02	**Tank Age**	33	**Tank Installed Date**	05/01/1992	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	253	**Spill Test Date**	04/17/2024	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	04/17/2024	**Catastrophic L.D. Type 3.0**	Auto Dialer	**Piping Type**	U.S. Suction	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	04/17/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	04/17/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Cascade County in the City of Simms

Location: MALMSTROM AFB H 7
MT Hwy 200
Simms, MT 59477 Cascade

System Facility ID:07-09058

Facility Code: 18754
Last Inspected On: 04/04/2024
Operating Permit Renewal Date: 09/22/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: 341 CES CEANQ **(406) 731-6188**

Operator Contact: Candace Ellsworth;Curtis Hester;William Smith **(406) 731-6239;(406) 731-7128** **candace.ellsworth@us.af.mil;william.smith@us.af.mil**

Owner/Operator: 341 CES CEANQ (406) 731-6188

Candace Ellsworth, UST Class A Operator	candace.ellsworth@us.af.mil
Candace Ellsworth, UST Class B Global Operator	candace.ellsworth@us.af.mil
Curtis Hester, UST Class A Operator	
Curtis Hester, UST Class B Global Operator	
William Smith, UST Class A Operator	william.smith@us.af.mil
William Smith, UST Class B Global Operator	william.smith@us.af.mil

Tank Number	02	**Tank Age**	34	**Tank Installed Date**	09/01/1991	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	124	**Spill Test Date**	04/04/2024	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	04/04/2024	**Catastrophic L.D. Type 3.0**	Auto Dialer	**Piping Type**	U.S. Suction	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	04/04/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	04/04/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Cascade County in the City of Simms

Location: MALMSTROM AFB H 8
MT Hwy 21
Simms, MT 59477 Cascade

System Facility ID:25-09059

Facility Code: 23818
Last Inspected On: 04/04/2024
Operating Permit Renewal Date: 09/22/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: 341 CES CEANQ **(406) 731-6188**

Operator Contact: Candace Ellsworth;Curtis Hester;William Smith **(406) 731-6239;(406) 731-7128** **candace.ellsworth@us.af.mil;william.smith@us.af.mil**

Owner/Operator: 341 CES CEANQ (406) 731-6188

Candace Ellsworth, UST Class A Operator	candace.ellsworth@us.af.mil
Candace Ellsworth, UST Class B Global Operator	candace.ellsworth@us.af.mil
Curtis Hester, UST Class A Operator	
Curtis Hester, UST Class B Global Operator	
William Smith, UST Class A Operator	william.smith@us.af.mil
William Smith, UST Class B Global Operator	william.smith@us.af.mil

Tank Number	02	**Tank Age**	34	**Tank Installed Date**	09/01/1991	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	257	**Spill Test Date**	04/04/2024	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	04/04/2024	**Catastrophic L.D. Type 3.0**	Auto Dialer	**Piping Type**	U.S. Suction	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	04/04/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	04/04/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Cascade County in the City of Stockett

Location: MALMSTROM AFB A 9
Road 227
Stockett, MT 59480 Cascade

System Facility ID:07-08983

Facility Code: 18744
Last Inspected On: 06/13/2024
Operating Permit Renewal Date: 09/25/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: 341 CES CEANQ **(406) 731-6188**

Operator Contact: Candace Ellsworth;Curtis Hester;William Smith **(406) 731-6239;(406) 731-7128** **candace.ellsworth@us.af.mil;william.smith@us.af.mil**

Owner/Operator: 341 CES CEANQ (406) 731-6188

Candace Ellsworth, UST Class A Operator	candace.ellsworth@us.af.mil
Candace Ellsworth, UST Class B Global Operator	candace.ellsworth@us.af.mil
Curtis Hester, UST Class A Operator	
Curtis Hester, UST Class B Global Operator	
William Smith, UST Class A Operator	william.smith@us.af.mil
William Smith, UST Class B Global Operator	william.smith@us.af.mil

Tank Number	02	**Tank Age**	33	**Tank Installed Date**	05/01/1992	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	114	**Spill Test Date**	07/17/2020	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	05/19/2020	**Catastrophic L.D. Type 3.0**	Auto Dialer	**Piping Type**	U.S. Suction	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	05/04/2022	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	05/04/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Cascade County in the City of Stockett

Location: MALMSTROM AFB I 2
Road 226
Stockett, MT 59480 Cascade

System Facility ID:07-09064

Facility Code: 18756
Last Inspected On: 04/22/2024
Operating Permit Renewal Date: 09/22/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: 341 CES CEANQ **(406) 731-6188**

Operator Contact: Candace Ellsworth;Curtis Hester;William Smith **(406) 731-6239;(406) 731-7128** **candace.ellsworth@us.af.mil;william.smith@us.af.mil**

Owner/Operator: 341 CES CEANQ (406) 731-6188

Candace Ellsworth, UST Class A Operator	candace.ellsworth@us.af.mil
Candace Ellsworth, UST Class B Global Operator	candace.ellsworth@us.af.mil
Curtis Hester, UST Class A Operator	
Curtis Hester, UST Class B Global Operator	
William Smith, UST Class A Operator	william.smith@us.af.mil
William Smith, UST Class B Global Operator	william.smith@us.af.mil

Tank Number	02	**Tank Age**	34	**Tank Installed Date**	10/01/1991	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	126	**Spill Test Date**	04/22/2024	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	04/22/2024	**Catastrophic L.D. Type 3.0**	Auto Dialer	**Piping Type**	U.S. Suction	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	04/22/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	04/22/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Cascade County in the City of Sun River

Location: MALMSTROM AFB H 4
US Hwy 89
Sun River, MT 59483 Cascade

System Facility ID:07-09055

Facility Code: 18751
Last Inspected On: 04/03/2024
Operating Permit Renewal Date: 09/22/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: 341 CES CEANQ **(406) 731-6188**

Operator Contact: Candace Ellsworth;Curtis Hester;William Smith **(406) 731-6239;(406) 731-7128** **candace.ellsworth@us.af.mil;william.smith@us.af.mil**

Owner/Operator: 341 CES CEANQ (406) 731-6188

Candace Ellsworth, UST Class A Operator	candace.ellsworth@us.af.mil
Candace Ellsworth, UST Class B Global Operator	candace.ellsworth@us.af.mil
Curtis Hester, UST Class A Operator	
Curtis Hester, UST Class B Global Operator	
William Smith, UST Class A Operator	william.smith@us.af.mil
William Smith, UST Class B Global Operator	william.smith@us.af.mil

Tank Number	02	**Tank Age**	34	**Tank Installed Date**	09/01/1991	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	121	**Spill Test Date**	04/03/2024	**Piping Installed Date**	04/20/2015	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	04/03/2024	**Catastrophic L.D. Type 3.0**	Auto Dialer	**Piping Type**	U.S. Suction	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	04/03/2024	**Line Tightness Test Date**	04/17/2015	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	04/03/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Cascade County in the City of Sun River

Location: MALMSTROM AFB H 5
US Hwy 89
Sun River, MT 59483 Cascade

System Facility ID:07-09056

Facility Code: 18752
Last Inspected On: 04/04/2024
Operating Permit Renewal Date: 09/22/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: 341 CES CEANQ **(406) 731-6188**

Operator Contact: Candace Ellsworth;Curtis Hester;William Smith **(406) 731-6239;(406) 731-7128** **candace.ellsworth@us.af.mil;william.smith@us.af.mil**

Owner/Operator: 341 CES CEANQ (406) 731-6188

Candace Ellsworth, UST Class A Operator	candace.ellsworth@us.af.mil
Candace Ellsworth, UST Class B Global Operator	candace.ellsworth@us.af.mil
Curtis Hester, UST Class A Operator	
Curtis Hester, UST Class B Global Operator	
William Smith, UST Class A Operator	william.smith@us.af.mil
William Smith, UST Class B Global Operator	william.smith@us.af.mil

Tank Number	02	**Tank Age**	34	**Tank Installed Date**	09/01/1991	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	122	**Spill Test Date**	04/04/2024	**Piping Installed Date**	05/18/2015	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	04/04/2024	**Catastrophic L.D. Type 3.0**	Auto Dialer	**Piping Type**	U.S. Suction	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	04/04/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	04/04/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Cascade County in the City of Ulm

Location: MALMSTROM AFB I 11
I-15
Ulm, MT 59485 Cascade

System Facility ID:07-09073

Facility Code: 18765
Last Inspected On: 04/22/2024
Operating Permit Renewal Date: 09/22/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: 341 CES CEANQ **(406) 731-6188**

Operator Contact: Candace Ellsworth;Curtis Hester;William Smith **(406) 731-6239;(406) 731-7128** **candace.ellsworth@us.af.mil;william.smith@us.af.mil**

Owner/Operator: 341 CES CEANQ (406) 731-6188

Candace Ellsworth, UST Class A Operator	candace.ellsworth@us.af.mil
Candace Ellsworth, UST Class B Global Operator	candace.ellsworth@us.af.mil
Curtis Hester, UST Class A Operator	
Curtis Hester, UST Class B Global Operator	
William Smith, UST Class A Operator	william.smith@us.af.mil
William Smith, UST Class B Global Operator	william.smith@us.af.mil

Tank Number	02	**Tank Age**	34	**Tank Installed Date**	10/01/1991	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	134	**Spill Test Date**	04/19/2024	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	04/19/2024	**Catastrophic L.D. Type 3.0**	Auto Dialer	**Piping Type**	U.S. Suction	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	04/19/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	04/19/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Cascade County in the City of Ulm

Location: MALMSTROM AFB I 7
I-15
Ulm, MT 59485 Cascade

System Facility ID:07-09069

Facility Code: 18761
Last Inspected On: 04/19/2024
Operating Permit Renewal Date: 09/22/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: 341 CES CEANQ **(406) 731-6188**

Operator Contact: Candace Ellsworth;Curtis Hester;William Smith **(406) 731-6239;(406) 731-7128** **candace.ellsworth@us.af.mil;william.smith@us.af.mil**

Owner/Operator: 341 CES CEANQ (406) 731-6188

Candace Ellsworth, UST Class A Operator	candace.ellsworth@us.af.mil
Candace Ellsworth, UST Class B Global Operator	candace.ellsworth@us.af.mil
Curtis Hester, UST Class A Operator	
Curtis Hester, UST Class B Global Operator	
William Smith, UST Class A Operator	william.smith@us.af.mil
William Smith, UST Class B Global Operator	william.smith@us.af.mil

Tank Number	02	**Tank Age**	33	**Tank Installed Date**	05/01/1992	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	131	**Spill Test Date**	04/19/2024	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	04/19/2024	**Catastrophic L.D. Type 3.0**	Auto Dialer	**Piping Type**	U.S. Suction	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	04/19/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	04/19/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Cascade County in the City of Ulm

Location: MOUNTAIN VIEW CO OP
2 Millegan Rd
Ulm, MT 59485 Cascade

System Facility ID:56-13797

Facility Code: 30484
Last Inspected On: 10/09/2023
Operating Permit Renewal Date: 11/14/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Mountain View Coop Black Eagle	**(406) 453-5900**	**ddouglas@mountainviewcoop.com**
Operator Contact:	Charles Niswanger;David Douglas;Robin Niswanger	**(406) 866-2030**	**ddouglas@mountainviewcoop.com**

Owner/Operator: Mountain View Coop Black Eagle (406) 453-5900 ddouglas@mountainviewcoop.com

Charles Niswanger, UST Class A Operator	
Charles Niswanger, UST Class B Operator	
David Douglas, UST Class A Operator	ddouglas@mountainviewcoop.com
Jasmin Nguyen, UST Class B Global Operator	jasmin_nguyen5@hotmail.com
Jasmin Nguyen, UST Class B Operator	jasmin_nguyen5@hotmail.com
John Malley, UST Class B Operator	jmalley@mountainviewcoop.com
Paul Obrien, UST Class B Operator	pobrien@moutainviewcoop.com
Robin Niswanger, UST Class A Operator	
Scott Bartlett, UST Class B Operator	sbartlett@mountianveiwcoop.com

Tank Number	01	**Tank Age**	28	**Tank Installed Date**	10/01/1997	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	4428	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	02/27/2023	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	04/26/2023	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**		**Line Tightness Test Date**	02/27/2023	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	02	**Tank Age**	28	**Tank Installed Date**	10/01/1997	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	4429	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	02/27/2023	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible

Product	Diesel	**PLLD Test Date**	04/26/2023	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**		**Line Tightness Test Date**	02/27/2023	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	03	**Tank Age**	28	**Tank Installed Date**	10/01/1997	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	4430	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	02/27/2023	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	04/26/2023	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**		**Line Tightness Test Date**	02/27/2023	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Cascade County in the City of Vaughn

Location: GAS N SHOP 3
133 US Highway 89
Vaughn, MT 59487 Cascade

System Facility ID:07-05008

Facility Code: 18552
Last Inspected On: 01/15/2024
Operating Permit Renewal Date: 06/30/2025

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Gas N Shop Inc	**(406) 660-9884**	**gasnshop133@gmail.com**
Operator Contact:	Gurinderbir Muhar	**(408) 660-9884**	**gasnshop133@gmail.com**

Owner/Operator: Gas N Shop Inc (406) 660-9884 gasnshop133@gmail.com
Gurinderbir Muhar, UST Class A Operator gasnshop133@gmail.com
Gurinderbir Muhar, UST Class B Global Operator gasnshop133@gmail.com
Sandeep Muhar, UST Class B Operator gasnshop133@gmail.com

Tank Number	05	**Tank Age**	28	**Tank Installed Date**	04/01/1997	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	2208	**Spill Test Date**	08/29/2023	**Piping Installed Date**	08/22/2023	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	08/22/2023	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	11/05/2024	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	11/05/2024	**Line Tightness Test Date**	04/23/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date	11/05/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Number	06	**Tank Age**	28	**Tank Installed Date**	04/01/1997	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	2209	**Spill Test Date**	08/29/2023	**Piping Installed Date**	08/22/2023	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	08/22/2023	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	11/05/2024	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	Yes
Capacity	4000	**ATG Test Date**	11/05/2024	**Line Tightness Test Date**	04/23/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No

		Overfill Test Date	11/05/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Number	07	**Tank Age**	28	**Tank Installed Date**	04/01/1997	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	2210	**Spill Test Date**	08/29/2023	**Piping Installed Date**	08/22/2023	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	08/22/2023	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel, Dyed	**PLLD Test Date**	03/01/2025	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	11/05/2024	**Line Tightness Test Date**	04/22/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date	11/05/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Number	08	**Tank Age**	2	**Tank Installed Date**	08/22/2023	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	6169	**Spill Test Date**	08/29/2023	**Piping Installed Date**	08/22/2023	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	08/22/2023	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	11/05/2024	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	Yes
Capacity	12000	**ATG Test Date**	11/05/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	11/05/2024			**ATG Type**					
Tank Number	09	**Tank Age**	2	**Tank Installed Date**	08/22/2023	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	6170	**Spill Test Date**	08/29/2023	**Piping Installed Date**	08/22/2023	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	08/22/2023	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	11/05/2024	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	Yes
Capacity	8000	**ATG Test Date**	11/05/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	11/05/2024			**ATG Type**					

Facility Summary in Cascade County in the City of Vaughn

Location: GLACIER GATEWAY
99 US Hwy 89
Vaughn, MT 59487 Cascade

System Facility ID:56-13783

Facility Code: 30471
Last Inspected On: 11/20/2023
Operating Permit Renewal Date: 04/09/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	NCI Tech Company LLC Vaughn;William Dean	**(406) 965-9014**	**bill@scheerswholesale.com**
Operator Contact:	Eric Bucher;Jake Neil;Kay Neil;Kevin Enochs;Kevin Francis	**(406) 799-6499;(406) 836-2087**	**jaken@nciengineering.com;jnkneil@gmail.com;woahmandude@hotmail.com**

Owner/Operator: NCI Tech Company LLC Vaughn (406) 965-9014

Owner/Operator: William Dean (406) 965-9014

Aaron McConnell, UST Class B Operator	
Allicia Wick, UST Class B Operator	a.r.zagar@live.com
Amy Evans, UST Class B Operator	fireyember@yahoo.com
Andrea Bowie, UST Class B Operator	
Barbara Matthews, UST Class B Operator	
Brenda Pischke, UST Class B Global Operator	
Bridget Bowen, UST Class B Operator	b_breezy34@yahoo.com
Christine Igel, UST Class B Operator	
Debbie Pengilly, UST Class B Operator	
Eric Bucher, UST Class A Operator	
Helen Taylor, UST Class B Global Operator	hannmadetattooz@yahoo.com
Jake Neil, UST Class A Operator	jaken@nciengineering.com
Jake Neil, UST Class B Operator	jaken@nciengineering.com
Janet Jensen, UST Class B Operator	b_breezy34@yahoo.com
Jenifer Colden, UST Class B Operator	
Jenna Blair, UST Class B Operator	
Josh Wick, UST Class B Operator	
Justin Vallier, UST Class B Operator	
Kay Neil, UST Class A Operator	jnkneil@gmail.com
Kay Neil, UST Class B Operator	jnkneil@gmail.com
Kevin Enochs, UST Class A Operator	
Kevin Francis, UST Class A Operator	woahmandude@hotmail.com
Leigh Wilson, UST Class B Operator	agfjk_1@msn.com
Marilyn Hutton, UST Class B Global Operator	
Matthew Schnittgen, UST Class B Operator	schnittgenm@hotmail.com

Roy Powell, UST Class B Operator	roypowell.d@gmail.com
Shalina Abrams, UST Class B Operator	shalina.johnson@yahoo.com
Vicki Ferda, UST Class B Operator	iluvdavidday@yahoo.com
Vicki Kriedeman, UST Class B Operator	vickikriedeman@yahoo.com

Tank Number	01	**Tank Age**	28	**Tank Installed Date**	06/01/1997	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	3444	**Spill Test Date**	11/17/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	11/17/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	11/16/2023			**ATG Type**	Veeder Root/TLS-300				
Tank Number	02	**Tank Age**	28	**Tank Installed Date**	06/01/1997	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	3445	**Spill Test Date**	02/01/2024	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	11/17/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	11/16/2023			**ATG Type**	Veeder Root/TLS-300				
Tank Number	03	**Tank Age**	28	**Tank Installed Date**	06/01/1997	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	3446	**Spill Test Date**	11/17/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**	11/17/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	11/17/2023			**ATG Type**	Veeder Root/TLS-300				
Tank Number	04	**Tank Age**	28	**Tank Installed Date**	06/01/1997	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	3447	**Spill Test Date**	11/17/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No

Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel, Dyed	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**	11/17/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	11/16/2023			**ATG Type**	Veeder Root/TLS-300				

Facility Summary in Cascade County in the City of Vaughn

Location: MALMSTROM AFB H 3
I-15
Vaughn, MT 59487 Cascade

System Facility ID:50-09054

Facility Code: 28887
Last Inspected On: 04/03/2024
Operating Permit Renewal Date: 09/23/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: 341 CES CEANQ **(406) 731-6188**

Operator Contact: Candace Ellsworth;Curtis Hester;William Smith **(406) 731-6239;(406) 731-7128** **candace.ellsworth@us.af.mil;william.smith@us.af.mil**

Owner/Operator: 341 CES CEANQ (406) 731-6188

Candace Ellsworth, UST Class A Operator	candace.ellsworth@us.af.mil
Candace Ellsworth, UST Class B Global Operator	candace.ellsworth@us.af.mil
Curtis Hester, UST Class A Operator	
Curtis Hester, UST Class B Global Operator	
William Smith, UST Class A Operator	william.smith@us.af.mil
William Smith, UST Class B Global Operator	william.smith@us.af.mil

Tank Number	02	**Tank Age**	34	**Tank Installed Date**	09/01/1991	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	313	**Spill Test Date**	04/03/2024	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	04/03/2024	**Catastrophic L.D. Type 3.0**	Auto Dialer	**Piping Type**	U.S. Suction	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	04/03/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	04/03/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Cascade County in the City of Vaughn

Location: MALMSTROM AFB I 10
I-15
Vaughn, MT 59487 Cascade

System Facility ID:07-09072

Facility Code: 18764
Last Inspected On: 04/22/2024
Operating Permit Renewal Date: 09/22/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: 341 CES CEANQ **(406) 731-6188**

Operator Contact: Candace Ellsworth;Curtis Hester;William Smith **(406) 731-6239;(406) 731-7128** **candace.ellsworth@us.af.mil;william.smith@us.af.mil**

Owner/Operator: 341 CES CEANQ (406) 731-6188

Candace Ellsworth, UST Class A Operator	candace.ellsworth@us.af.mil
Candace Ellsworth, UST Class B Global Operator	candace.ellsworth@us.af.mil
Curtis Hester, UST Class A Operator	
Curtis Hester, UST Class B Global Operator	
William Smith, UST Class A Operator	william.smith@us.af.mil
William Smith, UST Class B Global Operator	william.smith@us.af.mil

Tank Number	02	**Tank Age**	34	**Tank Installed Date**	08/01/1991	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	133	**Spill Test Date**	04/22/2024	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	04/22/2024	**Catastrophic L.D. Type 3.0**	Auto Dialer	**Piping Type**	U.S. Suction	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	04/22/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	04/22/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Cascade County in the City of Vaughn

Location: MALMSTROM AFB J 10
I-15
Vaughn, MT 59487 Cascade

System Facility ID:50-09083

Facility Code: 28893
Last Inspected On: 04/16/2024
Operating Permit Renewal Date: 09/22/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: 341 CES CEANQ **(406) 731-6188**

Operator Contact: Candace Ellsworth;Curtis Hester;William Smith **(406) 731-6239;(406) 731-7128** **candace.ellsworth@us.af.mil;william.smith@us.af.mil**

Owner/Operator: 341 CES CEANQ (406) 731-6188

Candace Ellsworth, UST Class A Operator	candace.ellsworth@us.af.mil
Candace Ellsworth, UST Class B Global Operator	candace.ellsworth@us.af.mil
Curtis Hester, UST Class A Operator	
Curtis Hester, UST Class B Global Operator	
William Smith, UST Class A Operator	william.smith@us.af.mil
William Smith, UST Class B Global Operator	william.smith@us.af.mil

Tank Number	02	**Tank Age**	34	**Tank Installed Date**	08/01/1991	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	319	**Spill Test Date**	04/16/2024	**Piping Installed Date**	06/02/2015	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	04/16/2024	**Catastrophic L.D. Type 3.0**	Auto Dialer	**Piping Type**	U.S. Suction	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	04/16/2024	**Line Tightness Test Date**	05/29/2015	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	04/16/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Cascade County in the City of Vaughn

Location: MALMSTROM AFB J 8
I-15
Vaughn, MT 59487 Cascade

System Facility ID:07-09081

Facility Code: 18766
Last Inspected On: 04/15/2024
Operating Permit Renewal Date: 09/22/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: 341 CES CEANQ **(406) 731-6188**

Operator Contact: Candace Ellsworth;Curtis Hester;William Smith **(406) 731-6239;(406) 731-7128** **candace.ellsworth@us.af.mil;william.smith@us.af.mil**

Owner/Operator: 341 CES CEANQ (406) 731-6188

Candace Ellsworth, UST Class A Operator	candace.ellsworth@us.af.mil
Candace Ellsworth, UST Class B Global Operator	candace.ellsworth@us.af.mil
Curtis Hester, UST Class A Operator	
Curtis Hester, UST Class B Global Operator	
William Smith, UST Class A Operator	william.smith@us.af.mil
William Smith, UST Class B Global Operator	william.smith@us.af.mil

Tank Number	02	**Tank Age**	34	**Tank Installed Date**	08/01/1991	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	135	**Spill Test Date**	04/15/2024	**Piping Installed Date**	08/11/2018	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	04/15/2024	**Catastrophic L.D. Type 3.0**	Auto Dialer	**Piping Type**	U.S. Suction	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	04/15/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	04/15/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Cascade County in the City of Vaughn

Location: MALMSTROM AFB J 9
I-15
Vaughn, MT 59487 Cascade

System Facility ID:07-09082

Facility Code: 18767
Last Inspected On: 04/15/2024
Operating Permit Renewal Date: 06/23/2020

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: 341 CES CEANQ **(406) 731-6188**

Operator Contact: Candace Ellsworth;Curtis Hester;William Smith **(406) 731-6239;(406) 731-7128** **candace.ellsworth@us.af.mil;william.smith@us.af.mil**

Owner/Operator: 341 CES CEANQ (406) 731-6188

Candace Ellsworth, UST Class A Operator	candace.ellsworth@us.af.mil
Candace Ellsworth, UST Class B Global Operator	candace.ellsworth@us.af.mil
Curtis Hester, UST Class A Operator	
Curtis Hester, UST Class B Global Operator	
William Smith, UST Class A Operator	william.smith@us.af.mil
William Smith, UST Class B Global Operator	william.smith@us.af.mil

Tank Number	02	**Tank Age**	34	**Tank Installed Date**	08/01/1991	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	136	**Spill Test Date**		**Piping Installed Date**	08/28/2018	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**	08/28/2018	**Catastrophic L.D. Type 3.0**	Auto Dialer	**Piping Type**	U.S. Suction	**CP Met Types**	
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	03	**Tank Age**	5	**Tank Installed Date**	05/20/2020	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	5925	**Spill Test Date**	04/15/2024	**Piping Installed Date**	08/28/2018	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	04/15/2024	**Catastrophic L.D. Type 3.0**	Auto Dialer	**Piping Type**	U.S. Suction	**CP Met Types**	Non-corrodible

Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	04/15/2024	**Line Tightness Test Date**	06/04/2020	**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**		**Energy Act**	Yes
		Overfill Test Date	04/15/2024			**ATG Type**					

Facility Summary in Chouteau County in the City of

Location: MALMSTROM AFB J 4
US Hwy 87 Rural Location
, MT Chouteau

System Facility ID:08-09077

Facility Code: 19299
Last Inspected On: 04/15/2024
Operating Permit Renewal Date: 09/22/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: 341 CES CEANQ **(406) 731-6188**

Operator Contact: Candace Ellsworth;Curtis Hester;William Smith **(406) 731-6239;(406) 731-7128** **candace.ellsworth@us.af.mil;william.smith@us.af.mil**

Owner/Operator: 341 CES CEANQ (406) 731-6188

Candace Ellsworth, UST Class A Operator	candace.ellsworth@us.af.mil
Candace Ellsworth, UST Class B Global Operator	candace.ellsworth@us.af.mil
Curtis Hester, UST Class A Operator	
Curtis Hester, UST Class B Global Operator	
William Smith, UST Class A Operator	william.smith@us.af.mil
William Smith, UST Class B Global Operator	william.smith@us.af.mil

Tank Number	02	**Tank Age**	34	**Tank Installed Date**	08/01/1991	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	158	**Spill Test Date**	04/15/2024	**Piping Installed Date**	06/19/2017	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	04/15/2024	**Catastrophic L.D. Type 3.0**	Auto Dialer	**Piping Type**	U.S. Suction	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	04/15/2024	**Line Tightness Test Date**	05/30/2017	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	04/15/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Chouteau County in the City of

Location: MALMSTROM AFB J 7
US Hwy 87 Rural Location
, MT Chouteau

System Facility ID:08-09080

Facility Code: 19302
Last Inspected On: 04/15/2024
Operating Permit Renewal Date: 09/22/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: 341 CES CEANQ **(406) 731-6188**

Operator Contact: Candace Ellsworth;Curtis Hester;William Smith **(406) 731-6239;(406) 731-7128** **candace.ellsworth@us.af.mil;william.smith@us.af.mil**

Owner/Operator: 341 CES CEANQ (406) 731-6188

Candace Ellsworth, UST Class A Operator	candace.ellsworth@us.af.mil
Candace Ellsworth, UST Class B Global Operator	candace.ellsworth@us.af.mil
Curtis Hester, UST Class A Operator	
Curtis Hester, UST Class B Global Operator	
William Smith, UST Class A Operator	william.smith@us.af.mil
William Smith, UST Class B Global Operator	william.smith@us.af.mil

Tank Number	02	**Tank Age**	34	**Tank Installed Date**	08/01/1991	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	161	**Spill Test Date**	04/15/2024	**Piping Installed Date**	08/08/2018	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	04/15/2024	**Catastrophic L.D. Type 3.0**	Auto Dialer	**Piping Type**	U.S. Suction	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	04/15/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	04/15/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Chouteau County in the City of Big Sandy

Location: EZZIES WHOLESALE BIG SANDY
418 Judith Landing Rd
Big Sandy, MT 59520-0395 Chouteau

System Facility ID:08-00855

Facility Code: 19100
Last Inspected On: 03/18/2025
Operating Permit Renewal Date: 07/09/2028

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Ezzies Wholesale Inc **bill@ezzies.com**

Operator Contact: Conor Moran;Ezzies Wholesale Inc **conor@ezzies.com;bill@ezzies.com**

Owner/Operator: Ezzies Wholesale Inc bill@ezzies.com

Conor Moran, UST Class A Operator bill@ezzies.com
Kenneth Martin, UST Class B Operator bigsandy@ezzies.com
Lindsay Boyce, UST Class B Operator lrboyce86@gmail.com

Tank Number	12	**Tank Age**	33	**Tank Installed Date**	06/01/1992	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	1841	**Spill Test Date**	05/23/2023	**Piping Installed Date**	02/27/2007	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	05/15/2024	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	05/15/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	05/23/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	10	**Tank Age**	35	**Tank Installed Date**	05/18/1990	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	1842	**Spill Test Date**	05/23/2023	**Piping Installed Date**	02/27/2007	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	05/15/2024	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	05/15/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No

		Overfill Test Date	05/23/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	09	**Tank Age**	35	**Tank Installed Date**	05/18/1990	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	1843	**Spill Test Date**	05/23/2023	**Piping Installed Date**	02/27/2007	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	05/15/2024	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	2000	**ATG Test Date**	05/15/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	05/23/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	13	**Tank Age**	33	**Tank Installed Date**	06/01/1992	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	1844	**Spill Test Date**	05/23/2023	**Piping Installed Date**	02/27/2007	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	05/15/2024	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	05/15/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	05/23/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	14	**Tank Age**	33	**Tank Installed Date**	06/01/1992	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	1845	**Spill Test Date**	05/23/2023	**Piping Installed Date**	02/27/2007	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	05/15/2024	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	05/15/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	05/23/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Chouteau County in the City of Big Sandy

Location: MOUNTAIN VIEW COOP BIG SANDY
79211 US Hwy 87
Big Sandy, MT 59520 Chouteau

System Facility ID:56-14150

Facility Code: 30786
Last Inspected On: 04/24/2023
Operating Permit Renewal Date: 05/27/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Mountain View Coop Black Eagle **(406) 453-5900** **ddouglas@mountainviewcoop.com**

Operator Contact: David Douglas **ddouglas@mountainviewcoop.com**

Owner/Operator: Mountain View Coop Black Eagle (406) 453-5900 ddouglas@mountainviewcoop.com

David Douglas, UST Class A Operator ddouglas@mountainviewcoop.com

David Douglas, UST Class B Global Operator ddouglas@mountainviewcoop.com

Tank Number	S1	**Tank Age**	20	**Tank Installed Date**	01/31/2005	**Tank Material Construction**	Bare Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	4965	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	Yes
Status	**Currently in Use**	**MLLD Test Date**	04/24/2023	**Sump Tightness Test Date**	04/15/2017	**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	5000	**ATG Test Date**	04/24/2023	**Line Tightness Test Date**	04/24/2023	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	04/24/2023			**ATG Type**					
Tank Number	S2	**Tank Age**	20	**Tank Installed Date**	01/31/2005	**Tank Material Construction**	Bare Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	4966	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	Yes
Status	**Currently in Use**	**MLLD Test Date**	04/24/2023	**Sump Tightness Test Date**	04/15/2017	**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	04/24/2023	**Primary Tank Leak Detection**	Deferred	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	5000	**ATG Test Date**		**Line Tightness Test Date**	04/24/2023	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	04/24/2023			**ATG Type**					
Tank Number	S3	**Tank Age**	0	**Tank Installed Date**		**Tank Material Construction**	Bare Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	

Tag Number	4967	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	Yes
Status	**Other**	**MLLD Test Date**		**Sump Tightness Test Date**	04/15/2013	**Catastrophic L.D. Type 3.0**		**Piping Type**	Pressurized	**CP Met Types**	
Product	Unknown	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	1	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	S4	**Tank Age**	0	**Tank Installed Date**		**Tank Material Construction**	Bare Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	
Tag Number	4968	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	Yes
Status	**Other**	**MLLD Test Date**		**Sump Tightness Test Date**	04/15/2013	**Catastrophic L.D. Type 3.0**		**Piping Type**	Not Listed	**CP Met Types**	
Product	Unknown	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	1	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					

Facility Summary in Chouteau County in the City of Carter

Location: MALMSTROM AFB J 3
US Hwy 87
Carter, MT 59420 Chouteau

System Facility ID:08-09076

Facility Code: 19298
Last Inspected On: 04/16/2024
Operating Permit Renewal Date: 09/22/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: 341 CES CEANQ **(406) 731-6188**

Operator Contact: Candace Ellsworth;Curtis Hester;William Smith **(406) 731-6239;(406) 731-7128** **candace.ellsworth@us.af.mil;william.smith@us.af.mil**

Owner/Operator: 341 CES CEANQ (406) 731-6188

Candace Ellsworth, UST Class A Operator	candace.ellsworth@us.af.mil
Candace Ellsworth, UST Class B Global Operator	candace.ellsworth@us.af.mil
Curtis Hester, UST Class A Operator	
Curtis Hester, UST Class B Global Operator	
William Smith, UST Class A Operator	william.smith@us.af.mil
William Smith, UST Class B Global Operator	william.smith@us.af.mil

Tank Number	02	**Tank Age**	34	**Tank Installed Date**	08/01/1991	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	157	**Spill Test Date**	04/16/2024	**Piping Installed Date**	05/23/2017	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	04/16/2024	**Catastrophic L.D. Type 3.0**	Auto Dialer	**Piping Type**	U.S. Suction	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	04/16/2024	**Line Tightness Test Date**	05/23/2017	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	04/16/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Chouteau County in the City of Carter

Location: MALMSTROM AFB J 5
US Hwy 87
Carter, MT 59420 Chouteau

System Facility ID:08-09078

Facility Code: 19300
Last Inspected On: 04/15/2024
Operating Permit Renewal Date: 09/22/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: 341 CES CEANQ **(406) 731-6188**

Operator Contact: Candace Ellsworth;Curtis Hester;William Smith **(406) 731-6239;(406) 731-7128** **candace.ellsworth@us.af.mil;william.smith@us.af.mil**

Owner/Operator: 341 CES CEANQ (406) 731-6188

Candace Ellsworth, UST Class A Operator	candace.ellsworth@us.af.mil
Candace Ellsworth, UST Class B Global Operator	candace.ellsworth@us.af.mil
Curtis Hester, UST Class A Operator	
Curtis Hester, UST Class B Global Operator	
William Smith, UST Class A Operator	william.smith@us.af.mil
William Smith, UST Class B Global Operator	william.smith@us.af.mil

Tank Number	02	**Tank Age**	34	**Tank Installed Date**	08/01/1991	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	159	**Spill Test Date**	04/15/2024	**Piping Installed Date**	06/19/2017	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	04/15/2024	**Catastrophic L.D. Type 3.0**	Auto Dialer	**Piping Type**	U.S. Suction	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	04/15/2024	**Line Tightness Test Date**	06/13/2017	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	04/15/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Chouteau County in the City of Carter

Location: SCHULER LANDS EAST FARM
17105 Dent Bridge Rd
Carter, MT 59420 Chouteau

System Facility ID:08-03976

Facility Code: 19168
Last Inspected On: 10/24/2024
Operating Permit Renewal Date: 11/21/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Dale Schuler;Schuler Lands Inc	**(406) 734-5404**	**mtgraingrower@gmail.com**
Operator Contact:	Dale Schuler	**(406) 734-5404**	**mtgraingrower@gmail.com**

Dale Schuler, UST Class A Operator mtgraingrower@gmail.com
Dale Schuler, UST Class B Operator mtgraingrower@gmail.com

Tank Number	01	**Tank Age**	43	**Tank Installed Date**	04/22/1982	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	No Piping	**Overfill Types**	Flapper Valve
Tag Number	4133	**Spill Test Date**	10/24/2024	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**		**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	18000	**ATG Test Date**	10/24/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	10/24/2024			**ATG Type**	Gilbarco/EMC Basic				

Facility Summary in Chouteau County in the City of Floweree

Location: MALMSTROM AFB J 6
17333 Bootlegger Trl
Floweree, MT 59440 Chouteau

System Facility ID:08-09079

Facility Code: 19301
Last Inspected On: 04/15/2024
Operating Permit Renewal Date: 09/22/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: 341 CES CEANQ **(406) 731-6188**

Operator Contact: Candace Ellsworth;Curtis Hester;William Smith **(406) 731-6239;(406) 731-7128** **candace.ellsworth@us.af.mil;william.smith@us.af.mil**

Owner/Operator: 341 CES CEANQ (406) 731-6188

Candace Ellsworth, UST Class A Operator	candace.ellsworth@us.af.mil
Candace Ellsworth, UST Class B Global Operator	candace.ellsworth@us.af.mil
Curtis Hester, UST Class A Operator	
Curtis Hester, UST Class B Global Operator	
William Smith, UST Class A Operator	william.smith@us.af.mil
William Smith, UST Class B Global Operator	william.smith@us.af.mil

Tank Number	03	**Tank Age**	10	**Tank Installed Date**	07/06/2015	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	5590	**Spill Test Date**	04/15/2024	**Piping Installed Date**	07/06/2015	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	04/15/2024	**Catastrophic L.D. Type 3.0**	Auto Dialer	**Piping Type**	U.S. Suction	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	04/15/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	Yes
		Overfill Test Date	04/15/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Chouteau County in the City of Fort Benton

Location: COUNTY COURTHOUSE and JAIL
1215 Washington St
Fort Benton, MT 59442 Chouteau

System Facility ID:08-05930

Facility Code: 19222
Last Inspected On: 08/18/2023
Operating Permit Renewal Date: 09/09/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Chouteau County	**(406) 622-3631**	
Operator Contact:	Bill Wallbillig;Robert Stevenson	**(406) 252-4661**	**billwallbillig@yahoo.com;bobcetera@bresnan.net**

Bill Wallbillig, UST Class A Operator	billwallbillig@yahoo.com
Bill Wallbillig, UST Class B Operator	billwallbillig@yahoo.com
Kelly Harding, UST Class B Operator	kharding@chouteaucosomt.com
Kelly Harding, UST Class B Operator	kharding@chouteaucosomt.com
Michael Hingiss, UST Class B Operator	michael.hingiss@gmail.com
Michael Hingiss, UST Class B Operator	michael.hingiss@gmail.com
Robert Stevenson, UST Class A Operator	bobcetera@bresnan.net
Robert Stevenson, UST Class A Operator	bobcetera@bresnan.net

Tank Number	01	**Tank Age**	37	**Tank Installed Date**	06/01/1988	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	4118	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**	09/13/2020	**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	U.S. Suction	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Manual Tank Gauging	**Primary Pipe Leak Detection**	Manual Interstitial Monitoring	**Vapor Recovery**	No
Capacity	550	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					

Facility Summary in Chouteau County in the City of Fort Benton

Location: JOYCE FUEL and FEEDS FORT BENTON
2118 Saint Charles St
Fort Benton, MT 59442 Chouteau

System Facility ID:56-13981

Facility Code: 30643
Last Inspected On: 11/29/2023
Operating Permit Renewal Date: 01/14/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Perry Joyce

Operator Contact: Perry Joyce

Owner/Operator: Perry Joyce

Owner/Operator: Perry W Joyce

Cody Joyce, UST Class B Global Operator cody24joyce@yahoo.com

Perry Joyce, UST Class A Operator

Tank Number	01	**Tank Age**	25	**Tank Installed Date**	07/27/2000	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	4210	**Spill Test Date**	02/21/2024	**Piping Installed Date**	07/27/2000	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	3000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco/EMC Basic				
Tank Number	02	**Tank Age**	25	**Tank Installed Date**	07/27/2000	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	4211	**Spill Test Date**	02/21/2024	**Piping Installed Date**	07/27/2000	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	3000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco/EMC Basic				

Tank Number	03	**Tank Age**	25	**Tank Installed Date**	07/27/2000	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	4212	**Spill Test Date**		**Piping Installed Date**	07/27/2000	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	3000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco/EMC Basic				

Facility Summary in Chouteau County in the City of Fort Benton

Location: JOYCO STORE
816 13th st
Fort Benton, MT 59442 Chouteau

System Facility ID:08-00093

Facility Code: 19071
Last Inspected On: 09/19/2022
Operating Permit Renewal Date: 11/20/2025

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: FORT PETROLEUM INC **(510) 714-5045**

Operator Contact: Jessica Graham **(406) 622-3381** **ftbentonjoyco@gmail.com**

Owner/Operator: FORT PETROLEUM INC (510) 714-5045

Jessica Graham, UST Class A Operator ftbentonjoyco@gmail.com
Jessica Graham, UST Class B Operator ftbentonjoyco@gmail.com

Tank Number	04	**Tank Age**	26	**Tank Installed Date**	06/01/1999	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve
Tag Number	4134	**Spill Test Date**	09/19/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	11/07/2019	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	09/19/2022	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	12/15/2022			**ATG Type**	Gilbarco/EMC Basic				
Tank Number	05	**Tank Age**	26	**Tank Installed Date**	06/01/1999	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve
Tag Number	4135	**Spill Test Date**	09/19/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	11/07/2019	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	09/19/2022	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	12/15/2022			**ATG Type**	Gilbarco/EMC Basic				
Tank Number	06	**Tank Age**	26	**Tank Installed Date**	06/01/1999	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve

Tag Number	4136	**Spill Test Date**	11/01/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	11/07/2019	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	09/19/2022	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	12/15/2022			**ATG Type**	Gilbarco/EMC Basic				

Facility Summary in Chouteau County in the City of Fort Benton

Location: MOUNTAIN VIEW COOP FORT BENTON
1820 Saint Charles St
Fort Benton, MT 59442 Chouteau

System Facility ID:08-00005

Facility Code: 19068
Last Inspected On: 05/23/2023
Operating Permit Renewal Date: 06/19/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Mountain View Coop Black Eagle	**(406) 453-5900**	**ddouglas@mountainviewcoop.com**
Operator Contact:	John Lindeman;Pat Trainor;Patricia Holskey	**(406) 622-5121;(406) 750-6802;(800) 823-3276**	**jclindeman@mountainviewcoop.com;pholskey@mountainviewcoop.com**

Owner/Operator: Mountain View Coop Black Eagle (406) 453-5900 ddouglas@mountainviewcoop.com

David Douglas, UST Class B Global Operator	ddouglas@mountainviewcoop.com
John Lindeman, UST Class A Operator	jclindeman@mountainviewcoop.com
John Lindeman, UST Class A Operator	jclindeman@mountainviewcoop.com
John Lindeman, UST Class B Operator	jclindeman@mountainviewcoop.com
John Lindeman, UST Class B Operator	jclindeman@mountainviewcoop.com
Pat Trainor, UST Class A Operator	
Pat Trainor, UST Class B Global Operator	
Patricia Holskey, UST Class A Operator	pholskey@mountainviewcoop.com
Patricia Holskey, UST Class A Operator	pholskey@mountainviewcoop.com
Patricia Holskey, UST Class B Operator	pholskey@mountainviewcoop.com
Patricia Holskey, UST Class B Operator	pholskey@mountainviewcoop.com

Tank Number	06	**Tank Age**	49	**Tank Installed Date**	12/11/1976	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	1021	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	05/18/2020	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**		**Line Tightness Test Date**	05/18/2020	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	12	**Tank Age**	34	**Tank Installed Date**	12/01/1991	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	1022	**Spill Test Date**	05/19/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No

Status	**Currently in Use**	**MLLD Test Date**	05/16/2023	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**	05/16/2023	**Line Tightness Test Date**	05/16/2023	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	05/15/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	13	**Tank Age**	34	**Tank Installed Date**	12/01/1991	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	1023	**Spill Test Date**	05/19/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	05/16/2023	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**	05/15/2023	**Line Tightness Test Date**	05/15/2023	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	05/15/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	14	**Tank Age**	34	**Tank Installed Date**	12/01/1991	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	1024	**Spill Test Date**	05/19/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	05/15/2023	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**	05/15/2023	**Line Tightness Test Date**	05/16/2023	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	05/15/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	15	**Tank Age**	34	**Tank Installed Date**	12/01/1991	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	1025	**Spill Test Date**	05/19/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	05/15/2023	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**	05/15/2023	**Line Tightness Test Date**	05/16/2023	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No

		Overfill Test Date	05/15/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	16	**Tank Age**	23	**Tank Installed Date**	03/28/2002	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	4628	**Spill Test Date**	05/15/2023	**Piping Installed Date**	06/03/2021	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	06/03/2021	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	05/14/2020	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	05/15/2023	**Line Tightness Test Date**	06/28/2021	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	05/15/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	17	**Tank Age**	23	**Tank Installed Date**	03/28/2002	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	4629	**Spill Test Date**	05/15/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	04/19/2020	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	05/14/2020	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	05/15/2023	**Line Tightness Test Date**	03/03/2008	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	05/15/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	18	**Tank Age**	23	**Tank Installed Date**	03/28/2002	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	4630	**Spill Test Date**	05/15/2023	**Piping Installed Date**	06/03/2021	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	06/03/2021	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	05/14/2020	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	05/15/2023	**Line Tightness Test Date**	06/28/2021	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	05/15/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	19	**Tank Age**	23	**Tank Installed Date**	03/28/2002	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm

Tag Number	4631	**Spill Test Date**	05/15/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	04/19/2020	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	05/14/2020	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	05/15/2023	**Line Tightness Test Date**	03/03/2008	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	05/15/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	20	**Tank Age**	23	**Tank Installed Date**	03/28/2002	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	4632	**Spill Test Date**	05/15/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	04/19/2020	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	05/14/2020	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	30000	**ATG Test Date**	05/15/2023	**Line Tightness Test Date**	03/03/2008	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	05/15/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	21	**Tank Age**	23	**Tank Installed Date**	03/28/2002	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	4633	**Spill Test Date**	05/15/2023	**Piping Installed Date**	06/03/2021	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	06/03/2021	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	05/14/2020	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	30000	**ATG Test Date**	05/15/2023	**Line Tightness Test Date**	06/28/2021	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	05/15/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Chouteau County in the City of Geraldine

Location: CENTRAL MONTANA COOP GERALDINE
28720 MT Hwy 80
Geraldine, MT 59446 Chouteau

System Facility ID:08-06615

Facility Code: 19239
Last Inspected On: 07/24/2024
Operating Permit Renewal Date: 07/24/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Central Montana Coop Geraldine **(406) 737-4480**

Operator Contact: Kirk Protsman **kirk.protsman@chsinc.com**

Owner/Operator: Central Montana Coop Geraldine (406) 737-4480

Jon Helberg, UST Class B Operator jon.helberg@chsinc.com
Kirk Protsman, UST Class A Operator kirk.protsman@chsinc.com

Tank Number	S1	**Tank Age**	51	**Tank Installed Date**	04/29/1974	**Tank Material Construction**	Bare Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	864	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	Yes
Status	**Temporarily Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	2000	**ATG Test Date**		**Line Tightness Test Date**	05/13/2013	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	S2	**Tank Age**	51	**Tank Installed Date**	04/29/1974	**Tank Material Construction**	Bare Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	865	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	Yes
Status	**Temporarily Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	2000	**ATG Test Date**		**Line Tightness Test Date**	05/13/2013	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					

Facility Summary in Chouteau County in the City of Highwood

Location: HIGHWOOD SERVICE CENTER UST
277 Broadway Ave W
Highwood, MT 59450 Chouteau

System Facility ID:08-12320

Facility Code: 19357
Last Inspected On: 10/22/2015
Operating Permit Renewal Date: 05/01/2019

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Keith Schott;Richard Schott	**(406) 667-2242;(406) 733-6072**	**1940@3rivers.net;schottk17@gmail.com**
Operator Contact:	Keith Schott	**(406) 667-2242**	**schottk17@gmail.com**

Keith Schott, UST Class A Operator	schottk17@gmail.com
Keith Schott, UST Class A Operator	schottk17@gmail.com
Keith Schott, UST Class B Operator	schottk17@gmail.com
Keith Schott, UST Class B Operator	schottk17@gmail.com

Tank Number	03	**Tank Age**	34	**Tank Installed Date**	09/01/1991	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	3112	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Deferred;Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	2000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	04	**Tank Age**	34	**Tank Installed Date**	09/01/1991	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	3113	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Deferred;Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	2000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					

Facility Summary in Chouteau County in the City of Loma

Location: PA'S MART
204 Broadway
Loma, MT 59460-0184 Chouteau

System Facility ID:08-01445

Facility Code: 19112
Last Inspected On: 03/14/2024
Operating Permit Renewal Date: 03/14/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Gregory Bouchard	**(406) 853-2139**	**maslomacafe@gmail.com**
Operator Contact:	Gregory Bouchard	**(406) 853-2139**	**maslomacafe@gmail.com**

Owner/Operator: Gregory Bouchard (406) 853-2139 maslomacafe@gmail.com

Gregory Bouchard, UST Class A Operator maslomacafe@gmail.com

Tank Number	03	**Tank Age**	39	**Tank Installed Date**	12/30/1986	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	3957	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Temporarily Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	07/22/2021	**Primary Tank Leak Detection**	Inventory Reconciliation;Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	04	**Tank Age**	39	**Tank Installed Date**	12/30/1986	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	3958	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Temporarily Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	07/22/2021	**Primary Tank Leak Detection**	Inventory Reconciliation;Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					

Facility Summary in Custer County in the City of Miles City

Location: CENEX ZIP TRIP 75
1815 S Haynes Ave
Miles City, MT 59301 Custer

System Facility ID:60-15272

Facility Code: 30983
Last Inspected On: 08/04/2022
Operating Permit Renewal Date: 01/06/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	CHS Inc dba Cenex Zip Trip #75		**sean.hurley@chsinc.com**
Operator Contact:	Jim Alford;Sean Hurley	**(509) 535-7701;(509) 536-7418**	**jim.alford@chsinc.com;sean.hurley@chsinc.com**

Owner/Operator: CHS Inc dba Cenex Zip Trip #75 sean.hurley@chsinc.com

Jim Alford, UST Class A Operator	jim.alford@chsinc.com
Jim Alford, UST Class B Operator	jim.alford@chsinc.com
Luci Tuttle, UST Class B Operator	Lucinda.Tuttle@chsinc.com
Nicholas Merritt, UST Class B Operator	nicholas.merritt@chsinc.com
Sean Hurley, UST Class A Operator	sean.hurley@chsinc.com

Tank Number	01	**Tank Age**	9	**Tank Installed Date**	08/15/2016	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	5630	**Spill Test Date**	07/25/2024	**Piping Installed Date**	08/15/2016	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	09/20/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	07/25/2024	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	25000	**ATG Test Date**	07/25/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	07/25/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-450;Veeder Root/TLS-450				
Tank Number	02	**Tank Age**	9	**Tank Installed Date**	08/15/2016	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	5631	**Spill Test Date**	07/25/2024	**Piping Installed Date**	08/15/2016	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	09/20/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	07/25/2024	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No

Capacity	25000	**ATG Test Date**	07/25/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	07/25/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-450;Veeder Root/TLS-450				
Tank Number	03	**Tank Age**	9	**Tank Installed Date**	08/15/2016	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	5632	**Spill Test Date**	07/25/2024	**Piping Installed Date**	08/15/2016	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	09/20/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	07/25/2024	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	25000	**ATG Test Date**	07/25/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	07/25/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-450;Veeder Root/TLS-450				
Tank Number	04	**Tank Age**	9	**Tank Installed Date**	08/15/2016	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	5633	**Spill Test Date**	07/25/2024	**Piping Installed Date**	08/15/2016	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	09/20/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	07/25/2024	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	25000	**ATG Test Date**	07/25/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	07/25/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-450;Veeder Root/TLS-450				
Tank Number	05	**Tank Age**	9	**Tank Installed Date**	08/15/2016	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	5634	**Spill Test Date**	07/25/2024	**Piping Installed Date**	08/15/2016	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	09/20/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	07/25/2024	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	07/25/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes

		Overfill Test Date	07/25/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-450;Veeder Root/TLS-450				
Tank Number	06	**Tank Age**	9	**Tank Installed Date**	08/15/2016	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	5635	**Spill Test Date**	07/25/2024	**Piping Installed Date**	08/15/2016	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	09/20/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	07/25/2024	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	07/25/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	07/25/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-450;Veeder Root/TLS-450				
Tank Number	07	**Tank Age**	9	**Tank Installed Date**	08/15/2016	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	5636	**Spill Test Date**	07/25/2024	**Piping Installed Date**	08/15/2016	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	09/20/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel, Dyed	**PLLD Test Date**	07/25/2024	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	07/25/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	07/25/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-450;Veeder Root/TLS-450				
Tank Number	08	**Tank Age**	10	**Tank Installed Date**	12/01/2015	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Not Listed	**Overfill Types**	
Tag Number	5722	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**		**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**		**Piping Type**	Pressurized	**CP Met Types**	
Product	DEF (Not Regulated)	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Not Listed	**Energy Act**	No
		Overfill Test Date				**ATG Type**					

Facility Summary in Custer County in the City of Miles City

Location: ENTERPRISE SYSTEMS SERVICE CENTER
114 S Haynes Ave
Miles City, MT 59301 Custer

System Facility ID:60-15140

Facility Code: 30884
Last Inspected On: 05/31/2022
Operating Permit Renewal Date: 09/18/2025

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: MT Dept of Administration ITSD **(406) 444-2700**

Operator Contact: Ed Sivils;John Salazar;Michael Krings **esivils@mt.gov;jksalazar@midrivers.com;mkrings@mt.gov**

Owner/Operator: MT Dept of Administration ITSD (406) 444-2700

Ed Sivils, UST Class A Operator	esivils@mt.gov
Ed Sivils, UST Class B Operator	esivils@mt.gov
John Salazar, UST Class A Operator	jksalazar@midrivers.com
John Salazar, UST Class B Operator	jksalazar@midrivers.com
Michael Krings, UST Class A Operator	mkrings@mt.gov
Mike Kennell, UST Class B Global Operator	mkennell2@mt.gov
Randy Anderson, UST Class B Global Operator	randerson3@mt.gov
Rennette Waldo, UST Class B Operator	shado@midrivers.com
Zane Rudolph, UST Class B Global Operator	zrudolph@mt.gov

Tank Number	S1	**Tank Age**	16	**Tank Installed Date**	07/21/2009	**Tank Material Construction**	Unknown	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	5215	**Spill Test Date**		**Piping Installed Date**	07/21/2009	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	Yes
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	06/05/2019	**Catastrophic L.D. Type 3.0**	Auto Dialer	**Piping Type**	Pressurized	**CP Met Types**	
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	05/31/2022	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	Yes
		Overfill Test Date				**ATG Type**					

Facility Summary in Custer County in the City of Miles City

Location: FRANKS QUICK STOP LLC
1308 S Haynes Ave
Miles City, MT 59301 Custer

System Facility ID:09-00624

Facility Code: 19399
Last Inspected On: 11/06/2023
Operating Permit Renewal Date: 11/06/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Franks Quick Stop LLC	**(406) 234-6661**	**frankango@midrivers.com**
Operator Contact:	Frank Ngo	**(406) 853-1991**	**frankango@midrivers.com**

Owner/Operator: Franks Quick Stop LLC (406) 234-6661 frankango@midrivers.com

Frank Ngo, UST Class A Operator	frankango@midrivers.com
Frank Ngo, UST Class A Operator	frankango@midrivers.com
Jason South, UST Class B Global Operator	jj95south@yahoo.com
Jason South, UST Class B Global Operator	jj95south@yahoo.com
Jeremy Thomas, UST Class B Global Operator	
Jeremy Thomas, UST Class B Global Operator	

Tank Number	08	**Tank Age**	35	**Tank Installed Date**	07/01/1990	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve;High Level Alarm
Tag Number	1788	**Spill Test Date**	10/11/2023	**Piping Installed Date**	09/27/2007	**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**	03/06/2023	**Tank/Piping CP Test Date**	10/11/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	11/20/2023	**Line Tightness Test Date**	06/28/2020	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.1	**Energy Act**	No
		Overfill Test Date	11/20/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	09	**Tank Age**	35	**Tank Installed Date**	07/01/1990	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve;High Level Alarm
Tag Number	1789	**Spill Test Date**	10/11/2023	**Piping Installed Date**	09/27/2007	**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**	03/06/2023	**Tank/Piping CP Test Date**	10/11/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	11/20/2023	**Line Tightness Test Date**	06/21/2020	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.1	**Energy Act**	No

		Overfill Test Date	11/20/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	10	**Tank Age**	35	**Tank Installed Date**	07/01/1990	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve;High Level Alarm
Tag Number	1790	**Spill Test Date**	10/11/2023	**Piping Installed Date**	09/27/2007	**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Diesel	**PLLD Test Date**	03/06/2023	**Tank/Piping CP Test Date**	10/11/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	11/20/2023	**Line Tightness Test Date**	06/20/2020	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.1	**Energy Act**	No
		Overfill Test Date	11/20/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Custer County in the City of Miles City

Location: FRANKS SHORT STOP II
305 Main St
Miles City, MT 59301 Custer

System Facility ID:09-07083

Facility Code: 19462
Last Inspected On: 03/06/2023
Operating Permit Renewal Date: 06/08/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Frank's Short Stop	**(406) 853-1991**	**frankango@midrivers.com**
Operator Contact:	Frank Ngo	**(406) 853-1991**	**frankango@midrivers.com**

Owner/Operator: Frank's Short Stop (406) 853-1991 frankango@midrivers.com

Frank Ngo, UST Class A Operator frankango@midrivers.com
Frank Ngo, UST Class A Operator frankango@midrivers.com
Frank Ngo, UST Class B Operator frankango@midrivers.com
Frank Ngo, UST Class B Operator frankango@midrivers.com

Tank Number	10	**Tank Age**	28	**Tank Installed Date**	10/01/1997	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	595	**Spill Test Date**	05/25/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	05/25/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	15000	**ATG Test Date**	03/06/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	06/03/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	11	**Tank Age**	28	**Tank Installed Date**	10/01/1997	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	596	**Spill Test Date**	03/06/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	01/30/2020	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	03/06/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No

		Overfill Test Date	03/06/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	12	**Tank Age**	28	**Tank Installed Date**	10/01/1997	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	597	**Spill Test Date**	03/06/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	01/30/2020	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**	03/06/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	03/06/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Yellowstone County in the City of Billings

Location: GM PETROLEUM DISTRIBUTORS
2100 1st Ave S
Billings, MT 59101 Yellowstone

System Facility ID:56-06962

Facility Code: 30147
Last Inspected On: 09/28/2023
Operating Permit Renewal Date: 03/14/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	City Service Valcon LLC DBA GM Petroleum Distributors		**jbrookie@gmpetroleum.com**
Operator Contact:	Jay Brookie;Laura Geffre;Margaret Flynn;Roger Schmechel	**(406) 208-3147;(406) 252-4661;(406) 294-0863**	**jayb@cityservicevalcon.com;margaretf@cityservicevalcon.com;rogers@cityservicevalcon.com**

Owner/Operator: City Service Valcon LLC DBA GM Petroleum Distributors — jbrookie@gmpetroleum.com

Jay Brookie, UST Class A Operator	jayb@cityservicevalcon.com
Jay Brookie, UST Class B Global Operator	jayb@cityservicevalcon.com
Laura Geffre, UST Class A Operator	
Laura Geffre, UST Class B Operator	
Margaret Flynn, UST Class A Operator	margaretf@cityservicevalcon.com
Margaret Flynn, UST Class B Operator	margaretf@cityservicevalcon.com
Roger Schmechel, UST Class A Operator	rogers@cityservicevalcon.com
Roger Schmechel, UST Class B Operator	rogers@cityservicevalcon.com

Tank Number	01	**Tank Age**	40	**Tank Installed Date**	06/01/1985	**Tank Material Construction**	Bare Steel	**Piping Material**	Steel	**Overfill Types**	High Level Alarm
Tag Number	1167	**Spill Test Date**	01/19/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Impressed Current
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	09/15/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**	01/19/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	01/19/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	02	**Tank Age**	40	**Tank Installed Date**	06/01/1985	**Tank Material Construction**	Bare Steel	**Piping Material**	Steel	**Overfill Types**	High Level Alarm
Tag Number	1168	**Spill Test Date**	01/19/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Impressed Current

Product	Diesel, Dyed	**PLLD Test Date**		**Tank/Piping CP Test Date**	09/15/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**	01/19/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	01/19/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	03	**Tank Age**	40	**Tank Installed Date**	06/01/1985	**Tank Material Construction**	Bare Steel	**Piping Material**	Steel	**Overfill Types**	High Level Alarm
Tag Number	1169	**Spill Test Date**	01/19/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Impressed Current
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	09/15/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**	01/19/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	01/19/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	04	**Tank Age**	40	**Tank Installed Date**	06/01/1985	**Tank Material Construction**	Bare Steel	**Piping Material**	Steel	**Overfill Types**	High Level Alarm
Tag Number	4626	**Spill Test Date**	01/19/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	09/15/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**	01/19/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	01/19/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	05	**Tank Age**	42	**Tank Installed Date**	05/07/1983	**Tank Material Construction**	Bare Steel	**Piping Material**	Steel	**Overfill Types**	High Level Alarm
Tag Number	4627	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Temporarily Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Gravity Feed	**CP Met Types**	Impressed Current
Product	Oil, Waste	**PLLD Test Date**		**Tank/Piping CP Test Date**	09/15/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	1000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Rosebud County in the City of Forsyth

Location: GM PETROLEUM DISTRIBUTORS
200 Main St
Forsyth, MT 59327 Rosebud

System Facility ID:44-10824

Facility Code: 27691
Last Inspected On: 09/06/2013
Operating Permit Renewal Date: 11/07/2016

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	City Service Valcon LLC DBA GM Petroleum Distributors		**jbrookie@gmpetroleum.com**
Operator Contact:	Bill Grunstead;Laura Geffre;Roger Schmechel	**(406) 208-3147**	**bgrunstead@gmpetroleum.com;rogers@cityservicevalcon.com**

Bill Grunstead, UST Class A Operator	bgrunstead@gmpetroleum.com
Bill Grunstead, UST Class A Operator	bgrunstead@gmpetroleum.com
Laura Geffre, UST Class A Operator	
Laura Geffre, UST Class A Operator	
Laura Geffre, UST Class B Operator	
Laura Geffre, UST Class B Operator	
Roger Schmechel, UST Class A Operator	rogers@cityservicevalcon.com
Roger Schmechel, UST Class A Operator	rogers@cityservicevalcon.com
Roger Schmechel, UST Class B Operator	rogers@cityservicevalcon.com
Roger Schmechel, UST Class B Operator	rogers@cityservicevalcon.com

Tank Number	07	**Tank Age**	0	**Tank Installed Date**		**Tank Material Construction**	Not Listed	**Piping Material**	Not Listed	**Overfill Types**	
Tag Number	5582	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**		**AST**	No
Status	**Other**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**		**Piping Type**	Not Listed	**CP Met Types**	
Product	Unknown	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Not Listed	**Primary Pipe Leak Detection**	Not Listed	**Vapor Recovery**	No
Capacity	1000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Not Listed	**Energy Act**	No
		Overfill Test Date				**ATG Type**					

Facility Summary in Custer County in the City of Miles City

Location: GM PETROLEUM DISTRIBUTORS
500 N 5th St
Miles City, MT 59301-2306 Custer

System Facility ID:09-05859

Facility Code: 19449
Last Inspected On: 08/10/2022
Operating Permit Renewal Date: 11/15/2025

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	City Service Valcon LLC		**tamara.noble@cityservicevalcon.com**
Operator Contact:	Bill Grunstead;Roger Schmechel	**(406) 208-3147**	**bgrunstead@gmpetroleum.com;rogers@cityservicevalcon.com**

Owner/Operator: City Service Valcon LLC tamara.noble@cityservicevalcon.com

Bill Grunstead, UST Class A Operator	bgrunstead@gmpetroleum.com
Bill Grunstead, UST Class A Operator	bgrunstead@gmpetroleum.com
Roger Schmechel, UST Class A Operator	rogers@cityservicevalcon.com
Roger Schmechel, UST Class A Operator	rogers@cityservicevalcon.com
Roger Schmechel, UST Class B Operator	rogers@cityservicevalcon.com
Roger Schmechel, UST Class B Operator	rogers@cityservicevalcon.com

Tank Number	S5	**Tank Age**	27	**Tank Installed Date**	11/01/1998	**Tank Material Construction**	Bare Steel	**Piping Material**	Steel	**Overfill Types**	
Tag Number	4009	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	Yes
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Gasoline	**PLLD Test Date**	06/06/2022	**Tank/Piping CP Test Date**	06/06/2022	**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	17335	**ATG Test Date**	06/06/2022	**Line Tightness Test Date**	07/12/2016	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	S6	**Tank Age**	27	**Tank Installed Date**	11/01/1998	**Tank Material Construction**	Bare Steel	**Piping Material**	Steel	**Overfill Types**	
Tag Number	4010	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	Yes
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Diesel	**PLLD Test Date**	06/06/2022	**Tank/Piping CP Test Date**	06/06/2022	**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	17335	**ATG Test Date**	06/06/2022	**Line Tightness Test Date**	07/12/2016	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	S7	**Tank Age**	27	**Tank Installed Date**	11/01/1998	**Tank Material Construction**	Bare Steel	**Piping Material**	Steel	**Overfill Types**	
Tag Number	4011	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	Yes

Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Diesel	**PLLD Test Date**	06/06/2022	**Tank/Piping CP Test Date**	06/06/2022	**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	17335	**ATG Test Date**	06/06/2022	**Line Tightness Test Date**	07/12/2016	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	S8	**Tank Age**	27	**Tank Installed Date**	11/01/1998	**Tank Material Construction**	Bare Steel	**Piping Material**	Steel	**Overfill Types**	
Tag Number	4012	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	Yes
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Gasoline	**PLLD Test Date**	06/06/2022	**Tank/Piping CP Test Date**	06/06/2022	**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	10123	**ATG Test Date**	06/06/2022	**Line Tightness Test Date**	07/12/2016	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					

Facility Summary in Custer County in the City of Miles City

Location: HOLY ROSARY HOSPITAL WILSON ST
2600 Wilson St
Miles City, MT 59301 Custer

System Facility ID:09-13574

Facility Code: 19513
Last Inspected On: 08/14/2024
Operating Permit Renewal Date: 02/10/2028

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Holy Rosary Hospital **(406) 233-2600**

Operator Contact: Al Miller;Holy Rosary Hospital;Dustin Leidholt;Scott Luedtke **(406) 233-2600;(406) 852-0342** **allan.miller@sclhealth.org;dustin.leidholt@sclhealth.org;scott.luedtke@sclhealth.org**

Owner/Operator: Holy Rosary Hospital (406) 233-2600

Al Miller, UST Class A Operator	allan.miller@sclhealth.org
Al Miller, UST Class B Operator	allan.miller@sclhealth.org
Dustin Leidholt, UST Class A Operator	dustin.leidholt@sclhealth.org
Dustin Leidholt, UST Class B Operator	dustin.leidholt@sclhealth.org
Scott Luedtke, UST Class A Operator	scott.luedtke@sclhealth.org
Scott Luedtke, UST Class B Global Operator	scott.luedtke@sclhealth.org

Tank Number	01	**Tank Age**	31	**Tank Installed Date**	08/01/1994	**Tank Material Construction**	Steel Clad	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	4284	**Spill Test Date**	03/15/2022	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	08/22/2024	**Catastrophic L.D. Type 3.0**	Auto Dialer	**Piping Type**	U.S. Suction	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	08/14/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	08/14/2024			**ATG Type**	Gilbarco-Veeder Root/ILS-350				

Facility Summary in Custer County in the City of Miles City

Location: M AND H GAS MILES CITY
1019 Main St
Miles City, MT 59301 Custer

System Facility ID:09-01058

Facility Code: 19402
Last Inspected On: 03/06/2024
Operating Permit Renewal Date: 06/23/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Miller and Holmes Inc

Operator Contact: Kevin Junker **kjj@mhstores.com**

Owner/Operator: Miller and Holmes Inc

Charles Kauffman, UST Class B Global Operator	charlesjkauffman@gmail.com
Charles Kauffman, UST Class B Global Operator	charlesjkauffman@gmail.com
Dave Lunder, UST Class B Operator	darterdave1569@yahoo.com
Dave Lunder, UST Class B Operator	darterdave1569@yahoo.com
Debra Agnew, UST Class B Global Operator	debra.agnew21@gmail.com
Debra Agnew, UST Class B Global Operator	debra.agnew21@gmail.com
Kevin Junker, UST Class A Operator	kjj@mhstores.com
Kevin Junker, UST Class A Operator	kjj@mhstores.com
Kevin Junker, UST Class B Operator	kjj@mhstores.com
Kevin Junker, UST Class B Operator	kjj@mhstores.com
Sandy Maine, UST Class B Operator	maine10@midrivers.com
Sandy Maine, UST Class B Operator	maine10@midrivers.com

Tank Number	04	**Tank Age**	31	**Tank Installed Date**	10/01/1994	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	1613	**Spill Test Date**	04/13/2023	**Piping Installed Date**	05/27/2008	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**	03/06/2024	**Tank/Piping CP Test Date**	03/06/2024	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	15000	**ATG Test Date**	03/06/2024	**Line Tightness Test Date**	02/03/2021	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	05/23/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	05	**Tank Age**	31	**Tank Installed Date**	10/01/1994	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm

Tag Number	1614	**Spill Test Date**	04/13/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**	03/06/2024	**Tank/Piping CP Test Date**	03/06/2024	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	15000	**ATG Test Date**	03/06/2024	**Line Tightness Test Date**	02/03/2021	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	05/23/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	06	**Tank Age**	31	**Tank Installed Date**	10/01/1994	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	1615	**Spill Test Date**	04/13/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**	03/06/2024	**Tank/Piping CP Test Date**	03/06/2024	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	7500	**ATG Test Date**	03/06/2024	**Line Tightness Test Date**	01/30/2021	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	05/23/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	07	**Tank Age**	31	**Tank Installed Date**	10/01/1994	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	1616	**Spill Test Date**	04/13/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**	03/06/2024	**Tank/Piping CP Test Date**	03/06/2024	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	7500	**ATG Test Date**	03/06/2024	**Line Tightness Test Date**	02/01/2021	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	05/23/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Custer County in the City of Miles City

Location: MILES CITY BULK PLANT
S 4th St & Pacific Ave
Miles City, MT 59301-1440 Custer

System Facility ID:09-03211

Facility Code: 19419
Last Inspected On: 03/07/2024
Operating Permit Renewal Date: 08/03/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Cenex Harvest States Sidney **(406) 234-1350**

Operator Contact: Parker Murnion;Randy Bickle **(406) 234-1350;(406) 234-2350** **parker.murnion@chsinc.com;randy.bickle@chsinc.com**

Owner/Operator: Cenex Harvest States Sidney (406) 234-1350

Parker Murnion, UST Class A Operator parker.murnion@chsinc.com
Randy Bickle, UST Class A Operator randy.bickle@chsinc.com
Randy Bickle, UST Class B Operator randy.bickle@chsinc.com

Tank Number	01	**Tank Age**	48	**Tank Installed Date**	03/26/1977	**Tank Material Construction**	Bare Steel	**Piping Material**	No Piping	**Overfill Types**	Flapper Valve
Tag Number	3586	**Spill Test Date**	04/30/2024	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	03/07/2024	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	11000	**ATG Test Date**	11/20/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	03/07/2024			**ATG Type**	Veeder Root/TLS-300				
Tank Number	02	**Tank Age**	48	**Tank Installed Date**	03/26/1977	**Tank Material Construction**	Bare Steel	**Piping Material**	No Piping	**Overfill Types**	Flapper Valve
Tag Number	3587	**Spill Test Date**	03/07/2024	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	03/07/2024	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	11000	**ATG Test Date**	11/20/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	03/07/2024			**ATG Type**	Veeder Root/TLS-300				
Tank Number	04	**Tank Age**	48	**Tank Installed Date**	03/26/1977	**Tank Material Construction**	Bare Steel	**Piping Material**	No Piping	**Overfill Types**	Flapper Valve

Tag Number	3588	**Spill Test Date**	03/07/2024	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	03/07/2024	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	11000	**ATG Test Date**	11/20/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	03/07/2024			**ATG Type**	Veeder Root/TLS-300				
Tank Number	05	**Tank Age**	48	**Tank Installed Date**	03/26/1977	**Tank Material Construction**	Bare Steel	**Piping Material**	No Piping	**Overfill Types**	Flapper Valve
Tag Number	3589	**Spill Test Date**	04/30/2024	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	03/07/2024	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	11000	**ATG Test Date**	11/20/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	03/07/2024			**ATG Type**	Veeder Root/TLS-300				
Tank Number	06	**Tank Age**	48	**Tank Installed Date**	03/26/1977	**Tank Material Construction**	Bare Steel	**Piping Material**	No Piping	**Overfill Types**	Flapper Valve
Tag Number	3590	**Spill Test Date**	04/30/2024	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	03/07/2024	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	11000	**ATG Test Date**	11/20/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	03/07/2024			**ATG Type**	Veeder Root/TLS-300				
Tank Number	03	**Tank Age**	48	**Tank Installed Date**	03/26/1977	**Tank Material Construction**	Bare Steel	**Piping Material**	No Piping	**Overfill Types**	Flapper Valve
Tag Number	3764	**Spill Test Date**	03/07/2024	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	03/07/2024	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	11000	**ATG Test Date**	11/20/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	03/07/2024			**ATG Type**	Veeder Root/TLS-300				

Facility Summary in Custer County in the City of Miles City

Location: QWEST MILES CITY CENTRAL OFFICE
811 Pleasant St
Miles City, MT 59301-3229 Custer

System Facility ID:09-08778

Facility Code: 19484
Last Inspected On: 09/07/2023
Operating Permit Renewal Date: 03/05/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Qwest Corporation/Century Link		**kevin.robison@centurylink.com**
Operator Contact:	Kevin Robison;Stephanie Miller;Thomas Pitts	**(206) 346-7532;(501) 680-8141;(801) 598-3020**	**kevin.robison@centurylink.com;Stephanie.miller@lumen.com**

Owner/Operator: Qwest Corporation/Century Link — kevin.robison@centurylink.com

Kevin Robison, UST Class A Operator	kevin.robison@centurylink.com
Kevin Robison, UST Class B Global Operator	kevin.robison@centurylink.com
Kevin Robison, UST Class B Operator	kevin.robison@centurylink.com
Stephanie Miller, UST Class A Operator	Stephanie.miller@lumen.com
Stephanie Miller, UST Class B Global Operator	Stephanie.miller@lumen.com
Thomas Pitts, UST Class A Operator	
Thomas Pitts, UST Class B Global Operator	
Thomas Pitts, UST Class B Operator	

Tank Number	01	**Tank Age**	32	**Tank Installed Date**	05/01/1993	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	1725	**Spill Test Date**	09/07/2023	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Auto Dialer	**Piping Type**	U.S. Suction	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	3-Year Line Tightness Test	**Vapor Recovery**	No
Capacity	553	**ATG Test Date**	09/07/2023	**Line Tightness Test Date**	07/25/2023	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	09/07/2023			**ATG Type**	Veeder Root/TLS-300				

Facility Summary in Custer County in the City of Miles City

Location: THE SHORT STOP STORE
16 N 7th St
Miles City, MT 59301-3110 Custer

System Facility ID:09-04443

Facility Code: 19431
Last Inspected On: 03/06/2023
Operating Permit Renewal Date: 06/19/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Frank Ngo;Teresa Newby	**(406) 234-6661;(406) 853-1991**	**frankango@midrivers.com**
Operator Contact:	Frank Ngo	**(406) 853-1991**	**frankango@midrivers.com**

Owner/Operator:	Frank Ngo	(406) 853-1991	frankango@midrivers.com
Owner/Operator:	Teresa Newby	(406) 853-1991	frankango@midrivers.com
	Frank Ngo, UST Class A Operator		frankango@midrivers.com
	Frank Ngo, UST Class B Operator		frankango@midrivers.com
	Frankie Meade, UST Class B Operator		tamara@midrivers.com
	Frankie Meade, UST Class B Operator		tamara@midrivers.com
	Frankie Meade, UST Class B Operator		tamara@midrivers.com
	Tony Russo, UST Class B Operator		sixguns45@hotmail.com
	Tony Russo, UST Class B Operator		sixguns45@hotmail.com
	Tony Russo, UST Class B Operator		sixguns45@hotmail.com

Tank Number	07	**Tank Age**	15	**Tank Installed Date**	12/17/2010	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	5284	**Spill Test Date**	03/06/2023	**Piping Installed Date**	11/29/2010	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	03/06/2023	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	03/06/2023	**Line Tightness Test Date**	10/09/2019	**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	03/06/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350;Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	08	**Tank Age**	15	**Tank Installed Date**	12/17/2010	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	5285	**Spill Test Date**	03/06/2023	**Piping Installed Date**	11/29/2010	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No

Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	03/06/2023	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	5000	**ATG Test Date**	03/06/2023	**Line Tightness Test Date**	10/08/2019	**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	03/06/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350;Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Custer County in the City of Miles City

Location: TOWN PUMP OF MILES CITY
1210 S Haynes Ave
Miles City, MT 59301 Custer

System Facility ID:09-07081

Facility Code: 19460
Last Inspected On: 03/12/2024
Operating Permit Renewal Date: 07/01/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Miles City 1 Town Pump LLC	**(406) 497-6700**	**environmental@townpump.com**
Operator Contact:	Trent Biggers		**Trentb@townpump.com**

Owner/Operator:	Miles City 1 Town Pump LLC	(406) 497-6700	environmental@townpump.com
	Trent Biggers, UST Class A Operator		Trentb@townpump.com
	Trent Biggers, UST Class A Operator		Trentb@townpump.com
	Trent Biggers, UST Class B Global Operator		Trentb@townpump.com
	Trent Biggers, UST Class B Global Operator		Trentb@townpump.com

Tank Number	10	**Tank Age**	31	**Tank Installed Date**	05/01/1994	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	2401	**Spill Test Date**	09/27/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Temporarily Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**	03/12/2024	**Tank/Piping CP Test Date**	06/16/2021	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	03/12/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	09/27/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350				
Tank Number	11	**Tank Age**	31	**Tank Installed Date**	05/01/1994	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	2402	**Spill Test Date**	09/27/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Temporarily Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**	03/12/2024	**Tank/Piping CP Test Date**	06/16/2021	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	5000	**ATG Test Date**	03/12/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No

		Overfill Test Date	09/27/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350				
Tank Number	12	**Tank Age**	31	**Tank Installed Date**	05/01/1994	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	2403	**Spill Test Date**	03/06/2024	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Temporarily Out of Use**	**MLLD Test Date**	03/03/2023	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**	03/12/2024	**Tank/Piping CP Test Date**	06/16/2021	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	5000	**ATG Test Date**	03/12/2024	**Line Tightness Test Date**	03/03/2023	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	03/06/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350				
Tank Number	13	**Tank Age**	30	**Tank Installed Date**	01/01/1995	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	2404	**Spill Test Date**	09/27/2023	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Temporarily Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	03/12/2024	**Tank/Piping CP Test Date**	12/17/2009	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	03/12/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	09/27/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350				
Tank Number	16	**Tank Age**	25	**Tank Installed Date**	11/01/2000	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve
Tag Number	4232	**Spill Test Date**	03/06/2024	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	03/12/2024	**Tank/Piping CP Test Date**	12/17/2009	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	15000	**ATG Test Date**	03/12/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	09/27/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350				
Tank Number	17	**Tank Age**	25	**Tank Installed Date**	11/01/2000	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve

Tag Number	4233	**Spill Test Date**	03/06/2024	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	03/12/2024	**Tank/Piping CP Test Date**	12/17/2009	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	15000	**ATG Test Date**	03/12/2024	**Line Tightness Test Date**	10/13/2022	**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	09/27/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350				
Tank Number	18	**Tank Age**	25	**Tank Installed Date**	11/01/2000	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve
Tag Number	4234	**Spill Test Date**	03/06/2024	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	06/16/2022	**Tank/Piping CP Test Date**	12/17/2009	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	15000	**ATG Test Date**	06/06/2022	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	06/16/2021			**ATG Type**	Gilbarco-Veeder Root/TLS-350				
Tank Number	19	**Tank Age**	25	**Tank Installed Date**	11/01/2000	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve
Tag Number	4235	**Spill Test Date**	09/27/2023	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	03/12/2024	**Tank/Piping CP Test Date**	12/17/2009	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	03/12/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	09/27/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350				
Tank Number	20	**Tank Age**	25	**Tank Installed Date**	11/01/2000	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve
Tag Number	4236	**Spill Test Date**	09/27/2023	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible

Product	Diesel, Dyed	**PLLD Test Date**	03/12/2024	**Tank/Piping CP Test Date**	12/17/2009	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	5000	**ATG Test Date**	03/12/2024	**Line Tightness Test Date**	12/11/2023	**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	09/27/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350				
Tank Number	14	**Tank Age**	30	**Tank Installed Date**	01/01/1995	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	4890	**Spill Test Date**	09/27/2023	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Temporarily Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	03/12/2024	**Tank/Piping CP Test Date**	12/17/2009	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	03/12/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	09/27/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350				
Tank Number	15	**Tank Age**	30	**Tank Installed Date**	01/01/1995	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	4891	**Spill Test Date**	09/27/2023	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Temporarily Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	03/12/2024	**Tank/Piping CP Test Date**	12/17/2009	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	03/12/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	09/27/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350				
Tank Number	21	**Tank Age**	0	**Tank Installed Date**		**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	5385	**Spill Test Date**		**Piping Installed Date**	08/14/2012	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Other**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	DEF (Not Regulated)	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.1;Continuous Interstitial Monitoring;Deferred	**Primary Pipe Leak Detection**	Approved Remote Monitoring;Deferred;Statistical Inventory Reconciliation	**Vapor Recovery**	No

Capacity	10000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring;Not Listed	**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	22	**Tank Age**	1	**Tank Installed Date**	12/12/2024	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	
Tag Number	6277	**Spill Test Date**	04/29/2025	**Piping Installed Date**	12/12/2024	**Tank Construction**		**Piping Construction**		**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	04/29/2025	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	Yes
Capacity	30000	**ATG Test Date**	04/29/2025	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	Yes
		Overfill Test Date	04/29/2025			**ATG Type**					
Tank Number	23	**Tank Age**	1	**Tank Installed Date**	12/12/2024	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	
Tag Number	6278	**Spill Test Date**	04/29/2025	**Piping Installed Date**	12/12/2024	**Tank Construction**		**Piping Construction**		**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	04/29/2025	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	30000	**ATG Test Date**	04/29/2025	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	Yes
		Overfill Test Date	04/29/2025			**ATG Type**					
Tank Number	24	**Tank Age**	1	**Tank Installed Date**	12/12/2024	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	
Tag Number	6279	**Spill Test Date**	04/29/2025	**Piping Installed Date**	12/12/2024	**Tank Construction**		**Piping Construction**		**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	04/29/2025	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Gasoline, E10	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	Yes
Capacity	20000	**ATG Test Date**	04/29/2025	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	Yes

		Overfill Test Date	04/29/2025			**ATG Type**					
Tank Number	25	**Tank Age**	1	**Tank Installed Date**	12/12/2024	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	
Tag Number	6280	**Spill Test Date**	04/29/2025	**Piping Installed Date**	12/12/2024	**Tank Construction**		**Piping Construction**		**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	04/29/2025	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	Yes
Capacity	10000	**ATG Test Date**	04/29/2025	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	Yes
		Overfill Test Date	04/29/2025			**ATG Type**					

Facility Summary in Custer County in the City of Miles City

Location: VA MEDICAL CENTER MILES CITY
210 S Winchester Ave
Miles City, MT 59301-4757 Custer

System Facility ID:09-07784

Facility Code: 19471
Last Inspected On: 04/29/2025
Operating Permit Renewal Date: 08/02/2025

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: VA Medical Center **(406) 874-5600**

Operator Contact: James Arneson;Joseph Dejong **(406) 232-3060;(406) 874-5880** **james.arneson@va.gov**

Owner/Operator: VA Medical Center (406) 874-5600

James Arneson, UST Class A Operator james.arneson@va.gov
James Arneson, UST Class B Global Operator james.arneson@va.gov
Joseph Dejong, UST Class A Operator

Tank Number	03	**Tank Age**	44	**Tank Installed Date**	04/22/1981	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Steel	**Overfill Types**	High Level Alarm
Tag Number	2191	**Spill Test Date**	05/13/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Continuous Interstitial Monitoring	**Piping Type**	U.S. Suction	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	3-Year Line Tightness Test	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	05/13/2022	**Line Tightness Test Date**	05/13/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	05/13/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	04	**Tank Age**	44	**Tank Installed Date**	04/22/1981	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Steel	**Overfill Types**	High Level Alarm
Tag Number	2192	**Spill Test Date**	07/27/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Continuous Interstitial Monitoring	**Piping Type**	U.S. Suction	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	3-Year Line Tightness Test	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	05/13/2022	**Line Tightness Test Date**	05/13/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No

		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	06	**Tank Age**	33	**Tank Installed Date**	04/20/1992	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Steel	**Overfill Types**	High Level Alarm
Tag Number	2193	**Spill Test Date**	05/13/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Continuous Interstitial Monitoring	**Piping Type**	U.S. Suction	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	3-Year Line Tightness Test	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	05/13/2022	**Line Tightness Test Date**	05/13/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	05/13/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	07	**Tank Age**	33	**Tank Installed Date**	11/17/1992	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Steel	**Overfill Types**	High Level Alarm
Tag Number	2194	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Temporarily Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Continuous Interstitial Monitoring	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	2000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					

Facility Summary in Custer County in the City of Miles City

Location: ZIP TRIP 59
1321 S Haynes Ave
Miles City, MT 59301-5733 Custer

System Facility ID:09-08212

Facility Code: 19475
Last Inspected On: 11/18/2024
Operating Permit Renewal Date: 03/25/2021

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	CHS Inc Spokane Valley	**(509) 535-7701**	**Donald.Widdicombe@chsinc.com**
Operator Contact:	Jim Alford;Sean Hurley	**(509) 535-7701;(509) 536-7418**	**jim.alford@chsinc.com;sean.hurley@chsinc.com**

Owner/Operator: CHS Inc Spokane Valley (509) 535-7701 Donald.Widdicombe@chsinc.com

Jim Alford, UST Class A Operator	jim.alford@chsinc.com
Jim Alford, UST Class A Operator	jim.alford@chsinc.com
Jim Alford, UST Class B Operator	jim.alford@chsinc.com
Jim Alford, UST Class B Operator	jim.alford@chsinc.com
Luci Tuttle, UST Class B Operator	Lucinda.Tuttle@chsinc.com
Nicholas Merritt, UST Class B Operator	nicholas.merritt@chsinc.com
Nicholas Merritt, UST Class B Operator	nicholas.merritt@chsinc.com
Sean Hurley, UST Class A Operator	sean.hurley@chsinc.com
Sean Hurley, UST Class A Operator	sean.hurley@chsinc.com

Tank Number	09	**Tank Age**	34	**Tank Installed Date**	05/03/1991	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Positive Shutoff
Tag Number	4347	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	08/04/2017	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.1;Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	20000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	10	**Tank Age**	34	**Tank Installed Date**	05/03/1991	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	4348	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No

Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	08/04/2017	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.1;Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	30000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	11	**Tank Age**	34	**Tank Installed Date**	05/03/1991	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	4349	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	08/04/2017	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.1;Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	30000	**ATG Test Date**		**Line Tightness Test Date**	09/29/2017	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD Line Tightness Testing	**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	08	**Tank Age**	34	**Tank Installed Date**	05/03/1991	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Positive Shutoff
Tag Number	547	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	08/04/2017	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.1;Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	20000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	12	**Tank Age**	34	**Tank Installed Date**	05/03/1991	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	551	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic

Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	08/04/2017	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.1;Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	20000	**ATG Test Date**		**Line Tightness Test Date**	09/07/2017	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD Line Tightness Testing	**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	13	**Tank Age**	34	**Tank Installed Date**	05/03/1991	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	552	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	08/04/2017	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.1;Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	20000	**ATG Test Date**		**Line Tightness Test Date**	09/28/2017	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD Line Tightness Testing	**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	14	**Tank Age**	2	**Tank Installed Date**	09/11/2023	**Tank Material Construction**	Steel Clad	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	6131	**Spill Test Date**	09/19/2023	**Piping Installed Date**	09/11/2023	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	09/19/2023	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	Yes
Capacity	10000	**ATG Test Date**	08/06/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	08/06/2024			**ATG Type**					
Tank Number	15	**Tank Age**	2	**Tank Installed Date**	09/11/2023	**Tank Material Construction**	Steel Clad	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	6132	**Spill Test Date**	09/19/2023	**Piping Installed Date**	09/11/2023	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	09/19/2023	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	Yes
Capacity	30000	**ATG Test Date**	08/06/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes

		Overfill Test Date	08/06/2024			**ATG Type**					
Tank Number	16	**Tank Age**	2	**Tank Installed Date**	09/11/2023	**Tank Material Construction**	Steel Clad	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	6133	**Spill Test Date**	09/19/2023	**Piping Installed Date**	09/11/2023	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	09/19/2023	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	08/06/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	08/06/2024			**ATG Type**					
Tank Number	17	**Tank Age**	2	**Tank Installed Date**	09/11/2023	**Tank Material Construction**	Steel Clad	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	6134	**Spill Test Date**	09/19/2023	**Piping Installed Date**	09/11/2023	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	09/19/2023	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	Yes
Capacity	10000	**ATG Test Date**	08/06/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	08/06/2024			**ATG Type**					
Tank Number	18	**Tank Age**	2	**Tank Installed Date**	09/11/2023	**Tank Material Construction**	Steel Clad	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	6135	**Spill Test Date**	09/19/2023	**Piping Installed Date**	09/11/2023	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	09/19/2023	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Diesel, Dyed	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	08/06/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	08/06/2024			**ATG Type**					
Tank Number	19	**Tank Age**	2	**Tank Installed Date**	09/11/2023	**Tank Material Construction**	Steel Clad	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	6137	**Spill Test Date**	09/19/2023	**Piping Installed Date**	09/11/2023	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	09/19/2023	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	

Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	30000	**ATG Test Date**	08/06/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	08/06/2024			**ATG Type**					

Facility Summary in Daniels County in the City of Flaxville

Location: PRO CO-OP 3
MT Hwy 5 & Main St
Flaxville, MT 59222 Daniels

System Facility ID:10-01331

Facility Code: 19535
Last Inspected On: 06/11/2024
Operating Permit Renewal Date: 09/28/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Pro Coop Scobey	**(406) 487-2741**	**bobcat@nemont.net**
Operator Contact:	Jason Nasby;Tanner Trower	**(406) 487-2741**	**bobcat@nemont.net;jnasby@procoopag.com**

Owner/Operator: Pro Coop Scobey (406) 487-2741 bobcat@nemont.net

Jason Nasby, UST Class A Operator	jnasby@procoopag.com
Kent Cromwell, UST Class B Operator	
Richard Carrier, UST Class B Operator	ggflaxville@nemont.net
Tanner Trower, UST Class A Operator	bobcat@nemont.net
Tanner Trower, UST Class B Global Operator	bobcat@nemont.net
Tanner Trower, UST Class B Operator	bobcat@nemont.net

Tank Number	04	**Tank Age**	34	**Tank Installed Date**	07/31/1991	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	1225	**Spill Test Date**	06/11/2024	**Piping Installed Date**	02/01/2013	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	06/11/2024	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	2000	**ATG Test Date**	06/11/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	06/11/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-300				
Tank Number	05	**Tank Age**	34	**Tank Installed Date**	07/31/1991	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	1226	**Spill Test Date**	06/11/2024	**Piping Installed Date**	02/01/2013	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	06/11/2024	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	2000	**ATG Test Date**	06/11/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No

		Overfill Test Date	06/11/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-300				
Tank Number	S6	**Tank Age**	12	**Tank Installed Date**	02/01/2013	**Tank Material Construction**	Bare Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	5408	**Spill Test Date**		**Piping Installed Date**	02/01/2013	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	Yes
Status	**Currently in Use**	**MLLD Test Date**	06/11/2024	**Sump Tightness Test Date**	06/11/2024	**Catastrophic L.D. Type 3.0**	Continuous Interstitial Monitoring;Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	11/19/2021	**Line Tightness Test Date**	11/19/2021	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	MLLD Line Tightness Testing	**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	S7	**Tank Age**	12	**Tank Installed Date**	02/01/2013	**Tank Material Construction**	Bare Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	5409	**Spill Test Date**		**Piping Installed Date**	02/01/2013	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	Yes
Status	**Currently in Use**	**MLLD Test Date**	06/11/2024	**Sump Tightness Test Date**	06/11/2024	**Catastrophic L.D. Type 3.0**	Continuous Interstitial Monitoring;Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	11/19/2021	**Line Tightness Test Date**	11/19/2021	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	MLLD Line Tightness Testing	**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	S8	**Tank Age**	12	**Tank Installed Date**	02/01/2013	**Tank Material Construction**	Bare Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	5453	**Spill Test Date**		**Piping Installed Date**	02/01/2013	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	Yes
Status	**Currently in Use**	**MLLD Test Date**	06/11/2024	**Sump Tightness Test Date**	06/11/2024	**Catastrophic L.D. Type 3.0**	Continuous Interstitial Monitoring;Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	11/19/2021	**Line Tightness Test Date**	11/19/2021	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	MLLD Line Tightness Testing	**Energy Act**	No

		Overfill Test Date				**ATG Type**					

Facility Summary in Daniels County in the City of Scobey

Location: CROMWELLS CONVENIENCE AND PETROLEUM
101 Railroad Ave W
Scobey, MT 59263 Daniels

System Facility ID:10-01223

Facility Code: 19533
Last Inspected On: 11/06/2024
Operating Permit Renewal Date: 03/09/2028

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Cromwells Convenience and Petroleum

Operator Contact: Shane Cromwell **(406) 487-2441** **shanec@nemont.net**

Owner/Operator: Cromwells Convenience and Petroleum

Shane Cromwell, UST Class A Operator	shanec@nemont.net
Shane Cromwell, UST Class A Operator	shanec@nemont.net
Shane Cromwell, UST Class B Global Operator	shanec@nemont.net
Shane Cromwell, UST Class B Global Operator	shanec@nemont.net

Tank Number	S4	**Tank Age**	29	**Tank Installed Date**	05/01/1996	**Tank Material Construction**	Aboveground Tank	**Piping Material**	Flexible Plastic	**Overfill Types**	
Tag Number	2176	**Spill Test Date**		**Piping Installed Date**	08/29/2022	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	Yes
Status	**Currently in Use**	**MLLD Test Date**	11/06/2024	**Sump Tightness Test Date**	11/06/2024	**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	5800	**ATG Test Date**		**Line Tightness Test Date**	09/21/2021	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	S5	**Tank Age**	29	**Tank Installed Date**	05/01/1996	**Tank Material Construction**	Aboveground Tank	**Piping Material**	Flexible Plastic	**Overfill Types**	
Tag Number	2177	**Spill Test Date**		**Piping Installed Date**	08/29/2022	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	Yes
Status	**Currently in Use**	**MLLD Test Date**	11/06/2024	**Sump Tightness Test Date**	11/06/2024	**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**		**Line Tightness Test Date**	09/21/2021	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					

Tank Number	S6	**Tank Age**	29	**Tank Installed Date**	05/01/1996	**Tank Material Construction**	Aboveground Tank	**Piping Material**	Flexible Plastic	**Overfill Types**	
Tag Number	2178	**Spill Test Date**		**Piping Installed Date**	08/29/2022	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	Yes
Status	**Currently in Use**	**MLLD Test Date**	11/06/2024	**Sump Tightness Test Date**	11/06/2024	**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Diesel, Dyed	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**		**Line Tightness Test Date**	09/21/2021	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	S7	**Tank Age**	29	**Tank Installed Date**	05/01/1996	**Tank Material Construction**	Aboveground Tank	**Piping Material**	Flexible Plastic	**Overfill Types**	
Tag Number	2179	**Spill Test Date**		**Piping Installed Date**	08/29/2022	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	Yes
Status	**Currently in Use**	**MLLD Test Date**	11/06/2024	**Sump Tightness Test Date**	11/06/2024	**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**		**Line Tightness Test Date**	09/21/2021	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					

Facility Summary in Daniels County in the City of Scobey

Location: NEMONT COMMUNICATIONS INC
61 Hwy 13 S
Scobey, MT 59263 Daniels

System Facility ID:10-13610

Facility Code: 19682
Last Inspected On: 09/07/2018
Operating Permit Renewal Date: 02/23/2022

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Nemont Communications Inc **(406) 783-5654**

Operator Contact:

Owner/Operator: Nemont Communications Inc (406) 783-5654

Tank Number	01	**Tank Age**	30	**Tank Installed Date**	04/01/1995	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	
Tag Number	3293	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Gravity Feed	**CP Met Types**	
Product	Oil, Waste	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Deferred	**Primary Pipe Leak Detection**	Deferred	**Vapor Recovery**	No
Capacity	100	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					

Facility Summary in Daniels County in the City of Scobey

Location: PRO CO-OP 1
3 Daniels St
Scobey, MT 59263 Daniels

System Facility ID:10-04159

Facility Code: 19572
Last Inspected On: 03/12/2024
Operating Permit Renewal Date: 06/20/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Pro Coop Scobey	**(406) 487-2741**	**bobcat@nemont.net**
Operator Contact:	Jason Nasby;Tanner Trower	**(406) 487-2741**	**bobcat@nemont.net;jnasby@procoopag.com**

Owner/Operator: Pro Coop Scobey (406) 487-2741 bobcat@nemont.net

Jason Nasby, UST Class A Operator	jnasby@procoopag.com
Jason Nasby, UST Class B Operator	jnasby@procoopag.com
Kent Cromwell, UST Class B Operator	
Kent Cromwell, UST Class B Operator	
Tanner Trower, UST Class A Operator	bobcat@nemont.net
Tanner Trower, UST Class A Operator	bobcat@nemont.net
Tanner Trower, UST Class B Global Operator	bobcat@nemont.net
Tanner Trower, UST Class B Global Operator	bobcat@nemont.net
Tanner Trower, UST Class B Operator	bobcat@nemont.net
Tanner Trower, UST Class B Operator	bobcat@nemont.net

Tank Number	S11	**Tank Age**	17	**Tank Installed Date**	10/10/2008	**Tank Material Construction**	Unknown	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	
Tag Number	5134	**Spill Test Date**		**Piping Installed Date**	06/19/2007	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	Yes
Status	**Currently in Use**	**MLLD Test Date**	06/29/2023	**Sump Tightness Test Date**	10/04/2021	**Catastrophic L.D. Type 3.0**	Continuous Interstitial Monitoring;Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	3000	**ATG Test Date**	06/29/2023	**Line Tightness Test Date**	06/29/2023	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	10/04/2021			**ATG Type**					
Tank Number	S10	**Tank Age**	17	**Tank Installed Date**	10/10/2008	**Tank Material Construction**	Unknown	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	

Tag Number	5699	**Spill Test Date**		**Piping Installed Date**	06/19/2007	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	Yes
Status	**Currently in Use**	**MLLD Test Date**	06/29/2023	**Sump Tightness Test Date**	10/04/2021	**Catastrophic L.D. Type 3.0**	Continuous Interstitial Monitoring;Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Gasohol/Ethanol	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	3000	**ATG Test Date**	06/29/2023	**Line Tightness Test Date**	06/29/2023	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	10/04/2021			**ATG Type**					

Facility Summary in Daniels County in the City of Scobey

Location: PRO CO-OP 2
108 1st St
Scobey, MT 59263 Daniels

System Facility ID:10-03710

Facility Code: 19562
Last Inspected On: 03/12/2024
Operating Permit Renewal Date: 06/20/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Pro Coop Scobey	**(406) 487-2741**	**bobcat@nemont.net**
Operator Contact:	Jason Nasby;Tanner Trower	**(406) 487-2741**	**bobcat@nemont.net;jnasby@procoopag.com**

Owner/Operator: Pro Coop Scobey (406) 487-2741 bobcat@nemont.net

Jason Nasby, UST Class A Operator	jnasby@procoopag.com
Jason Nasby, UST Class B Operator	jnasby@procoopag.com
Kent Cromwell, UST Class B Operator	
Tanner Trower, UST Class A Operator	bobcat@nemont.net
Tanner Trower, UST Class B Global Operator	bobcat@nemont.net
Tanner Trower, UST Class B Operator	bobcat@nemont.net

Tank Number	04	**Tank Age**	31	**Tank Installed Date**	10/01/1994	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve;High Level Alarm
Tag Number	1227	**Spill Test Date**	03/12/2024	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	06/19/2021	**Sump Tightness Test Date**	06/20/2021	**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**	06/28/2023	**Tank/Piping CP Test Date**	06/17/2021	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	06/28/2023	**Line Tightness Test Date**	06/19/2021	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring;ELLD 0.2	**Energy Act**	No
		Overfill Test Date	03/12/2024			**ATG Type**	Gilbarco/EMC Basic				
Tank Number	05	**Tank Age**	31	**Tank Installed Date**	10/01/1994	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve;High Level Alarm
Tag Number	1228	**Spill Test Date**	03/12/2024	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	06/19/2021	**Sump Tightness Test Date**	06/20/2021	**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**	06/28/2023	**Tank/Piping CP Test Date**	06/17/2021	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No

Capacity	12000	**ATG Test Date**	06/28/2023	**Line Tightness Test Date**	06/19/2021	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring;ELLD 0.2	**Energy Act**	No
		Overfill Test Date	03/12/2024			**ATG Type**	Gilbarco/EMC Basic				
Tank Number	06	**Tank Age**	31	**Tank Installed Date**	10/01/1994	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve;High Level Alarm
Tag Number	1229	**Spill Test Date**	03/12/2024	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	06/19/2021	**Sump Tightness Test Date**	06/20/2021	**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**	06/28/2023	**Tank/Piping CP Test Date**	06/17/2021	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	06/28/2023	**Line Tightness Test Date**	06/19/2021	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring;ELLD 0.2	**Energy Act**	No
		Overfill Test Date	03/12/2024			**ATG Type**	Gilbarco/EMC Basic				
Tank Number	07	**Tank Age**	31	**Tank Installed Date**	10/01/1994	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve;High Level Alarm
Tag Number	1230	**Spill Test Date**	03/12/2024	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	06/19/2021	**Sump Tightness Test Date**	06/20/2021	**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**	06/28/2023	**Tank/Piping CP Test Date**	06/17/2021	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	06/28/2023	**Line Tightness Test Date**	06/19/2021	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring;ELLD 0.2	**Energy Act**	No
		Overfill Test Date	03/12/2024			**ATG Type**	Gilbarco/EMC Basic				
Tank Number	08	**Tank Age**	31	**Tank Installed Date**	10/01/1994	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve
Tag Number	1231	**Spill Test Date**	03/12/2024	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	06/19/2021	**Sump Tightness Test Date**	06/20/2021	**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**	06/28/2023	**Tank/Piping CP Test Date**	06/17/2021	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	06/28/2023	**Line Tightness Test Date**	06/19/2021	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring;ELLD 0.2	**Energy Act**	No
		Overfill Test Date	03/12/2024			**ATG Type**	Gilbarco/EMC Basic				

Tank Number	09	**Tank Age**	31	**Tank Installed Date**	10/01/1994	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve;High Level Alarm
Tag Number	1232	**Spill Test Date**	03/12/2024	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	06/19/2021	**Sump Tightness Test Date**	06/20/2021	**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**	06/28/2023	**Tank/Piping CP Test Date**	06/17/2021	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2;MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	06/28/2023	**Line Tightness Test Date**	06/19/2021	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	03/12/2024			**ATG Type**	Gilbarco/EMC Basic				

Facility Summary in Dawson County in the City of Glendive

Location: BERGS TIRE INC
2111 W Towne St
Glendive, MT 59330-3214 Dawson

System Facility ID:11-03214

Facility Code: 19730
Last Inspected On: 04/30/2025
Operating Permit Renewal Date: 07/20/2028

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Berg Tire

Operator Contact: James Berg **bergtire@midrivers.com**

Owner/Operator: Berg Tire

James Berg, UST Class A Operator bergtire@midrivers.com
James Berg, UST Class B Operator bergtire@midrivers.com

Tank Number	06	**Tank Age**	38	**Tank Installed Date**	03/26/1987	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Steel	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	598	**Spill Test Date**	04/30/2025	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Diesel	**PLLD Test Date**	12/18/2024	**Tank/Piping CP Test Date**	12/18/2024	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	12/18/2024	**Line Tightness Test Date**	10/31/2018	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	12/18/2024			**ATG Type**	Veeder Root/TLS-450				
Tank Number	07	**Tank Age**	38	**Tank Installed Date**	03/26/1987	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Steel	**Overfill Types**	High Level Alarm
Tag Number	599	**Spill Test Date**	04/30/2025	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**	12/18/2024	**Tank/Piping CP Test Date**	12/18/2024	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	12/18/2024	**Line Tightness Test Date**	11/02/2018	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	12/18/2024			**ATG Type**	Veeder Root/TLS-450				
Tank Number	08	**Tank Age**	38	**Tank Installed Date**	03/26/1987	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Steel	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	600	**Spill Test Date**	04/30/2025	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No

Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Diesel, Dyed	**PLLD Test Date**	12/18/2024	**Tank/Piping CP Test Date**	12/18/2024	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**	12/18/2024	**Line Tightness Test Date**	11/08/2018	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	12/18/2024			**ATG Type**	Veeder Root/TLS-450				
Tank Number	09	**Tank Age**	38	**Tank Installed Date**	03/26/1987	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Steel	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	601	**Spill Test Date**	04/30/2025	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**	12/18/2024	**Tank/Piping CP Test Date**	12/18/2024	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**	12/18/2024	**Line Tightness Test Date**	10/29/2018	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	12/18/2024			**ATG Type**	Veeder Root/TLS-450				

Facility Summary in Dawson County in the City of Glendive

Location: BN GLENDIVE RAIL YARD
310 N Merrill Ave
Glendive, MT 59330-1728 Dawson

System Facility ID:11-09528

Facility Code: 19829
Last Inspected On: 09/25/2019
Operating Permit Renewal Date: 12/04/2022

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: BNSF Railway Company Fort Worth **(817) 333-2000**

Operator Contact: Tavita Masau **(773) 600-2860** **tmasau@icloud.com**

Tavita Masau, UST Class A Operator tmasau@icloud.com
Tavita Masau, UST Class A Operator tmasau@icloud.com
Tavita Masau, UST Class B Global Operator tmasau@icloud.com
Tavita Masau, UST Class B Global Operator tmasau@icloud.com

Tank Number	03	**Tank Age**	36	**Tank Installed Date**	12/28/1989	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	
Tag Number	504	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Continuous Interstitial Monitoring	**Piping Type**	Gravity Feed	**CP Met Types**	Galvanic
Product	Mixture	**PLLD Test Date**		**Tank/Piping CP Test Date**	09/04/2019	**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	32000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	SKC1	**Tank Age**	34	**Tank Installed Date**	09/01/1991	**Tank Material Construction**	Bare Steel	**Piping Material**	Steel	**Overfill Types**	
Tag Number	505	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	Yes
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Continuous Interstitial Monitoring	**Piping Type**	Gravity Feed	**CP Met Types**	
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	09/04/2019	**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	1360000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No

		Overfill Test Date				**ATG Type**					

Facility Summary in Dawson County in the City of Glendive

Location: BRAKE TIME 251715
322 E Barry St
Glendive, MT 59330-2306 Dawson

System Facility ID:11-05093

Facility Code: 19756
Last Inspected On: 07/19/2022
Operating Permit Renewal Date: 10/04/2025

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	GLENDIVE MT LLC	**(832) 539-8190**	**licensing@btcmstores.com**
Operator Contact:	Muhammad Akhtar	**(832) 539-8190**	**akhatarmuhammad65@gmail.com**

Owner/Operator: GLENDIVE MT LLC (832) 539-8190 licensing@btcmstores.com

Muhammad Akhtar, UST Class A Operator akhatarmuhammad65@gmail.com
Natalee Crumley, UST Class B Operator
Natalee Crumley, UST Class B Operator

Tank Number	04	**Tank Age**	29	**Tank Installed Date**	09/01/1996	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	1636	**Spill Test Date**	10/21/2020	**Piping Installed Date**	05/07/2012	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	05/24/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	07/19/2022	**Tank/Piping CP Test Date**	11/22/2011	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	07/19/2022	**Line Tightness Test Date**	05/24/2024	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date	10/21/2020			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	05	**Tank Age**	29	**Tank Installed Date**	09/01/1996	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	1637	**Spill Test Date**	10/21/2020	**Piping Installed Date**	05/07/2012	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	01/07/2021	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	07/19/2022	**Tank/Piping CP Test Date**	11/22/2011	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	07/19/2022	**Line Tightness Test Date**	07/19/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No

		Overfill Test Date	10/21/2020			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	06	**Tank Age**	29	**Tank Installed Date**	09/01/1996	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	1638	**Spill Test Date**	10/21/2020	**Piping Installed Date**	05/07/2012	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	05/24/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	07/19/2022	**Tank/Piping CP Test Date**	11/22/2011	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	07/19/2022	**Line Tightness Test Date**	05/24/2024	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date	10/21/2020			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Dawson County in the City of Glendive

Location: CIRCLE K STORE 2746271
701 N Merrill Ave
Glendive, MT 59330 Dawson

System Facility ID:11-08061

Facility Code: 19804
Last Inspected On: 01/02/2024
Operating Permit Renewal Date: 04/11/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Rocky Mountain Oil LLC	**(602) 728-8000**	**NT-ESS@Circlek.com**
Operator Contact:	Chuck Nyberg;Dean Townsend	**(952) 830-8722**	**dean.townsend@holidaycompanies.com**

Owner/Operator: Rocky Mountain Oil LLC (602) 728-8000 NT-ESS@Circlek.com

Brad Lee, UST Class B Global Operator	brad.lee@holidaycompanies.com
Brad Lee, UST Class B Global Operator	brad.lee@holidaycompanies.com
Chuck Nyberg, UST Class A Operator	
Dean Townsend, UST Class A Operator	dean.townsend@holidaycompanies.com
Dean Townsend, UST Class A Operator	dean.townsend@holidaycompanies.com
Greg Brewer, UST Class B Global Operator	greg.brewer@holidaycompanies.com
Greg Brewer, UST Class B Global Operator	greg.brewer@holidaycompanies.com
Kelly Jo Cooper, UST Class B Global Operator	kellyjcooper205@gmail.com
Kelly Jo Cooper, UST Class B Global Operator	kellyjcooper205@gmail.com
Travis Struckman, UST Class B Global Operator	travis.struckman@holidaycompanies.com
Travis Struckman, UST Class B Global Operator	travis.struckman@holidaycompanies.com

Tank Number	01	**Tank Age**	46	**Tank Installed Date**	10/01/1979	**Tank Material Construction**	Bare Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve
Tag Number	3001	**Spill Test Date**	07/11/2024	**Piping Installed Date**	06/03/2008	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**	03/21/2023	**Tank/Piping CP Test Date**	03/21/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	Yes
Capacity	12000	**ATG Test Date**	03/21/2024	**Line Tightness Test Date**	08/27/2020	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	03/21/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	02	**Tank Age**	46	**Tank Installed Date**	10/01/1979	**Tank Material Construction**	Bare Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve
Tag Number	3002	**Spill Test Date**	07/11/2024	**Piping Installed Date**	06/03/2008	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No

Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**	03/21/2024	**Tank/Piping CP Test Date**	03/21/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	Yes
Capacity	12000	**ATG Test Date**	03/21/2024	**Line Tightness Test Date**	08/19/2020	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	03/21/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	03	**Tank Age**	46	**Tank Installed Date**	10/01/1979	**Tank Material Construction**	Bare Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve
Tag Number	3003	**Spill Test Date**	07/11/2024	**Piping Installed Date**	06/03/2008	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**	03/21/2024	**Tank/Piping CP Test Date**	03/21/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	Yes
Capacity	8000	**ATG Test Date**	03/21/2024	**Line Tightness Test Date**	08/13/2020	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	03/21/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	04	**Tank Age**	46	**Tank Installed Date**	10/01/1979	**Tank Material Construction**	Bare Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve
Tag Number	3004	**Spill Test Date**	07/11/2024	**Piping Installed Date**	06/03/2008	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Diesel	**PLLD Test Date**	03/21/2024	**Tank/Piping CP Test Date**	03/21/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	03/21/2024	**Line Tightness Test Date**	08/23/2020	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	03/21/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Dawson County in the City of Glendive

Location: CROSSROADS CONOCO GLENDIVE
56 Hwy 16
Glendive, MT 59330-3609 Dawson

System Facility ID:56-13872

Facility Code: 30551
Last Inspected On: 09/27/2023
Operating Permit Renewal Date: 03/14/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Gregory Cross **gcross@crosspetroleumservice.com**

Operator Contact: Gregory Cross;R J Serpe;Timothy Fife **gcross@crosspetroleumservice.com;rlsrp@yahoo.com**

Owner/Operator: Greg Cross gcross@crosspetroleumservice.com

Greg Cross, UST Class A Operator	gcross@crosspetroleumservice.com
R J Serpe, UST Class A Operator	rlsrp@yahoo.com
R J Serpe, UST Class B Global Operator	rlsrp@yahoo.com
Ron Serpe, UST Class B Global Operator	cross@midrivers.com
Timothy Fife, UST Class A Operator	

Tank Number	01	**Tank Age**	26	**Tank Installed Date**	06/26/1999	**Tank Material Construction**	Steel Clad	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	4043	**Spill Test Date**	09/20/2020	**Piping Installed Date**	01/03/2013	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	08/11/2022	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	09/24/2023	**Line Tightness Test Date**	03/08/2012	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date	09/20/2020			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	02	**Tank Age**	26	**Tank Installed Date**	06/26/1999	**Tank Material Construction**	Steel Clad	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	4044	**Spill Test Date**	09/03/2020	**Piping Installed Date**	01/03/2013	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	08/11/2022	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	15000	**ATG Test Date**	09/24/2023	**Line Tightness Test Date**	03/08/2012	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No

		Overfill Test Date	09/03/2020			**ATG Type**	Gilbarco/EMC Basic				
Tank Number	03	**Tank Age**	26	**Tank Installed Date**	06/26/1999	**Tank Material Construction**	Steel Clad	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	4045	**Spill Test Date**	09/03/2020	**Piping Installed Date**	01/03/2013	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	08/11/2022	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	09/24/2023	**Line Tightness Test Date**	03/08/2012	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date	09/03/2020			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Dawson County in the City of Glendive

Location: DAWSON COMMUNITY AIRPORT
402 Dry Creek Rd
Glendive, MT 59330-9204 Dawson

System Facility ID:11-02455

Facility Code: 19717
Last Inspected On: 06/12/2023
Operating Permit Renewal Date: 11/24/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Dawson County		**airport@midrivers.com**
Operator Contact:	Craig Hostetler;Leon Baker	**(406) 377-4505;(406) 687-3372**	**airport@midrivers.com;craig@midrivers.com**

Owner/Operator: Dawson County — airport@midrivers.com

Bill Stebbins, UST Class B Operator	airport@midrivers.com
Craig Hostetler, UST Class A Operator	craig@midrivers.com
Craig Hostetler, UST Class B Operator	craig@midrivers.com
Leon Baker, UST Class A Operator	airport@midrivers.com
Leon Baker, UST Class B Global Operator	airport@midrivers.com
Leon Baker, UST Class B Operator	airport@midrivers.com

Tank Number	04	**Tank Age**	31	**Tank Installed Date**	11/21/1994	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Steel	**Overfill Types**	Flapper Valve
Tag Number	824	**Spill Test Date**	06/14/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Secondary Containment Chase	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	11/21/2022	**Sump Tightness Test Date**	07/29/2012	**Catastrophic L.D. Type 3.0**	Auto Dialer;Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Aviation Gas	**PLLD Test Date**		**Tank/Piping CP Test Date**	06/12/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	11/21/2022	**Line Tightness Test Date**	11/21/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	06/14/2022			**ATG Type**	EMCO Electronics/EECO 1500				
Tank Number	S5	**Tank Age**	51	**Tank Installed Date**	01/01/1974	**Tank Material Construction**	Unknown	**Piping Material**	Steel	**Overfill Types**	
Tag Number	825	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Single Walled	**AST**	Yes
Status	**Currently in Use**	**MLLD Test Date**	11/21/2022	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Auto Dialer;Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	

Product	Jet Fuel (Jet-A, Jet-A1, JP5)	**PLLD Test Date**		**Tank/Piping CP Test Date**	06/12/2023	**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**		**Line Tightness Test Date**	11/21/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					

Facility Summary in Dawson County in the City of Glendive

Location: EAST END CENEX
1803 Merrill Ave
Glendive, MT 59330 Dawson

System Facility ID:11-00033

Facility Code: 19684
Last Inspected On: 03/11/2024
Operating Permit Renewal Date: 07/21/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Cross Petroleum Services Glendive **cross@midrivers.com**

Operator Contact: Gregory Cross;R J Serpe;Timothy Fife **gcross@crosspetroleumservice.com;rlsrp@yahoo.com**

Owner/Operator: Cross Petroleum Services Glendive cross@midrivers.com

Greg Cross, UST Class A Operator	gcross@crosspetroleumservice.com
Greg Cross, UST Class A Operator	gcross@crosspetroleumservice.com
R J Serpe, UST Class A Operator	rlsrp@yahoo.com
R J Serpe, UST Class A Operator	rlsrp@yahoo.com
R J Serpe, UST Class B Global Operator	rlsrp@yahoo.com
R J Serpe, UST Class B Global Operator	rlsrp@yahoo.com
Ron Serpe, UST Class B Global Operator	cross@midrivers.com
Ron Serpe, UST Class B Global Operator	cross@midrivers.com
Timothy Fife, UST Class A Operator	
Timothy Fife, UST Class A Operator	

Tank Number	08	**Tank Age**	10	**Tank Installed Date**	02/09/2015	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	5535	**Spill Test Date**	03/11/2024	**Piping Installed Date**	02/09/2015	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	06/05/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	Yes
Capacity	12000	**ATG Test Date**	07/20/2023	**Line Tightness Test Date**	03/20/2015	**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	03/11/2024			**ATG Type**	Incon/TS-550 EVO				
Tank Number	09	**Tank Age**	10	**Tank Installed Date**	02/09/2015	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	5536	**Spill Test Date**	03/11/2024	**Piping Installed Date**	02/09/2015	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	06/05/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible

Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	07/20/2023	**Line Tightness Test Date**	03/20/2015	**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	03/11/2024			**ATG Type**	Incon/TS-550 EVO				
Tank Number	10	**Tank Age**	10	**Tank Installed Date**	02/09/2015	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	5537	**Spill Test Date**	03/11/2024	**Piping Installed Date**	02/09/2015	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	06/05/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	Yes
Capacity	8000	**ATG Test Date**	07/20/2023	**Line Tightness Test Date**	03/20/2015	**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	03/11/2024			**ATG Type**	Incon/TS-550 EVO				
Tank Number	11	**Tank Age**	10	**Tank Installed Date**	02/09/2015	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	5538	**Spill Test Date**	03/11/2024	**Piping Installed Date**	02/09/2015	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	06/05/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.1;Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	07/20/2023	**Line Tightness Test Date**	03/20/2015	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	03/11/2024			**ATG Type**	Incon/TS-550 EVO				

Facility Summary in Dawson County in the City of Glendive

Location: GLENDIVE COMBUSTION TURBINE
366 FAS 335
Glendive, MT 59330-9575 Dawson

System Facility ID:11-09400

Facility Code: 19827
Last Inspected On: 07/02/2024
Operating Permit Renewal Date: 11/17/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Montana Dakota Utilities Co Bismarck	**(701) 222-7865**	**mark.dihle@mdu.com**
Operator Contact:	Clay Olson;Evan Jones;Jim Shields;Kalle Kuether;Sean Cameron	**(307) 696-3597;(406) 939-5341;(970) 509-0698**	**clay.olson@mdu.com;evan.jones@mdu.com;jim.shields@MDU.com; kalle.kuether@mdu.com;sean.cameron@mdu.com**

Owner/Operator:	Montana Dakota Utilities Co Bismarck	(701) 222-7865	mark.dihle@mdu.com
	Chad Miller, UST Class B Operator		
	Clay Olson, UST Class A Operator		clay.olson@mdu.com
	Clay Olson, UST Class B Global Operator		clay.olson@mdu.com
	Evan Jones, UST Class A Operator		evan.jones@mdu.com
	Evan Jones, UST Class B Operator		evan.jones@mdu.com
	Jim Shields, UST Class A Operator		jim.shields@MDU.com
	Jim Shields, UST Class B Global Operator		jim.shields@MDU.com
	Jody Gustafson, UST Class B Global Operator		jody.gustafson@mdu.com
	Kalle Kuether, UST Class A Operator		kalle.kuether@mdu.com
	Sean Cameron, UST Class A Operator		sean.cameron@mdu.com
	Sean Cameron, UST Class B Operator		sean.cameron@mdu.com

Tank Number	S2	**Tank Age**	38	**Tank Installed Date**	07/01/1987	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Steel	**Overfill Types**	
Tag Number	1692	**Spill Test Date**		**Piping Installed Date**	07/13/2007	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	Yes
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	07/02/2024	**Catastrophic L.D. Type 3.0**	Auto Dialer	**Piping Type**	Pressurized	**CP Met Types**	
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Deferred	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	75000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					

Facility Summary in Dawson County in the City of Glendive

Location: GLENDIVE MEDICAL CENTER
202 Prospect Dr
Glendive, MT 59330-1943 Dawson

System Facility ID:11-09735

Facility Code: 19832
Last Inspected On: 09/18/2023
Operating Permit Renewal Date: 12/19/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Glendive Medical Center **(406) 345-3306**

Operator Contact: Mike Ryan;Sam Durham **durhams001@yahoo.com;miryan@gmc.org**

Owner/Operator: Glendive Medical Center (406) 345-3306

Craig Torno, UST Class B Operator ctorno@gmc.org
Mike Ryan, UST Class A Operator miryan@gmc.org
Sam Durham, UST Class A Operator durhams001@yahoo.com

Tank Number	03	**Tank Age**	30	**Tank Installed Date**	11/16/1995	**Tank Material Construction**	Steel Clad	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	1223	**Spill Test Date**	03/10/2022	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	08/12/2018	**Catastrophic L.D. Type 3.0**	Auto Dialer	**Piping Type**	U.S. Suction	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	3-Year Line Tightness Test	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	03/09/2023	**Line Tightness Test Date**	03/10/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	03/10/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-300				

Facility Summary in Dawson County in the City of Glendive

Location: JOYS GLENDIVE SERVICE INC
74 MT Hwy 16
Glendive, MT 59330-3609 Dawson

System Facility ID:11-07770

Facility Code: 19800
Last Inspected On: 02/06/2024
Operating Permit Renewal Date: 02/06/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: William Clemens **(608) 575-8642** **bcbeinc@yahoo.com**

Operator Contact: Glenn Lawres

Owner/Operator: William Clemens (608) 575-8642 bcbeinc@yahoo.com

Glenn Lawres, UST Class A Operator
Glenn Lawres, UST Class A Operator
Glenn Lawres, UST Class B Operator
Glenn Lawres, UST Class B Operator

Tank Number	06	**Tank Age**	27	**Tank Installed Date**	05/28/1998	**Tank Material Construction**	Steel Clad	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	1511	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Temporarily Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	06/14/2013	**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/ILS-350				
Tank Number	07	**Tank Age**	27	**Tank Installed Date**	05/28/1998	**Tank Material Construction**	Steel Clad	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	1512	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Temporarily Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	06/14/2013	**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/ILS-350				

Tank Number	08	**Tank Age**	27	**Tank Installed Date**	05/28/1998	**Tank Material Construction**	Steel Clad	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	1513	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Temporarily Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	06/14/2013	**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/ILS-350				
Tank Number	09	**Tank Age**	27	**Tank Installed Date**	05/28/1998	**Tank Material Construction**	Steel Clad	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	1514	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Temporarily Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	06/14/2013	**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	2000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/ILS-350				

Facility Summary in Dawson County in the City of Glendive

Location: QWEST GLENDIVE CENTRAL OFFICE
119 W Valentine St
Glendive, MT 59330-1638 Dawson

System Facility ID:11-06870

Facility Code: 19783
Last Inspected On: 09/07/2023
Operating Permit Renewal Date: 04/22/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Century Link Communication	**(501) 680-8141**	**Stephanie.miller@lumen.com**
Operator Contact:	Stephanie Miller	**(501) 680-8141**	**Stephanie.miller@lumen.com**

Owner/Operator: Century Link Communication (501) 680-8141 Stephanie.miller@lumen.com

Stephanie Miller, UST Class A Operator Stephanie.miller@lumen.com

Stephanie Miller, UST Class B Global Operator Stephanie.miller@lumen.com

Tank Number	01	**Tank Age**	32	**Tank Installed Date**	04/01/1993	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	1726	**Spill Test Date**	09/07/2023	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	U.S. Suction	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	3-Year Line Tightness Test	**Vapor Recovery**	No
Capacity	553	**ATG Test Date**	09/07/2023	**Line Tightness Test Date**	07/26/2023	**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	09/07/2023			**ATG Type**	Veeder Root/TLS-300				

Facility Summary in Dawson County in the City of Glendive

Location: SUPERPUMPER 58
1320 N Merrill Ave
Glendive, MT 59330-1958 Dawson

System Facility ID:11-04213

Facility Code: 19747
Last Inspected On: 04/16/2025
Operating Permit Renewal Date: 06/09/2028

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Superpumper Inc **(701) 852-1194**

Operator Contact: Vern Patterson;Parkland USA Corporation **(701) 720-6649;(701) 852-1194** **vern.patterson@parklandusa.com;Jake.thomas@parklandusa.com**

Owner/Operator: Superpumper Inc (701) 852-1194

Curtis McBride, UST Class B Operator Jake.thomas@parklandusa.com
Vern Patterson, UST Class A Operator Jake.thomas@parklandusa.com
Vern Patterson, UST Class B Operator Jake.thomas@parklandusa.com

Tank Number	01	**Tank Age**	41	**Tank Installed Date**	05/06/1984	**Tank Material Construction**	Bare Steel	**Piping Material**	Steel	**Overfill Types**	Flapper Valve
Tag Number	4308	**Spill Test Date**	04/16/2025	**Piping Installed Date**	05/09/2007	**Tank Construction**		**Piping Construction**	Single Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Diesel	**PLLD Test Date**	08/19/2024	**Tank/Piping CP Test Date**	04/16/2025	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	08/19/2024	**Line Tightness Test Date**	03/02/2025	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	04/16/2025			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	02	**Tank Age**	41	**Tank Installed Date**	05/06/1984	**Tank Material Construction**	Bare Steel	**Piping Material**	Steel	**Overfill Types**	Flapper Valve
Tag Number	4309	**Spill Test Date**	04/16/2025	**Piping Installed Date**	05/09/2007	**Tank Construction**		**Piping Construction**	Single Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**	08/19/2024	**Tank/Piping CP Test Date**	04/16/2025	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	08/19/2024	**Line Tightness Test Date**	02/28/2025	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	04/16/2025			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Tank Number	03	**Tank Age**	41	**Tank Installed Date**	05/06/1984	**Tank Material Construction**	Bare Steel	**Piping Material**	Steel	**Overfill Types**	Flapper Valve
Tag Number	4310	**Spill Test Date**	04/16/2025	**Piping Installed Date**	05/09/2007	**Tank Construction**		**Piping Construction**	Single Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**	08/19/2024	**Tank/Piping CP Test Date**	04/16/2025	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	08/19/2024	**Line Tightness Test Date**	02/02/2025	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	04/16/2025			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Dawson County in the City of Glendive

Location: TOWN PUMP GLENDIVE TRAVEL PLAZA
73 Hwy 16
Glendive, MT 59330 Dawson

System Facility ID:60-15289

Facility Code: 30996
Last Inspected On: 09/17/2024
Operating Permit Renewal Date: 07/21/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Glendive 1 Town Pump LLC **(406) 497-6700** **environmental@townpump.com**

Operator Contact: Trent Biggers;Town Pump **Trentb@townpump.com;environmental@townpump.com**

Owner/Operator: Glendive 1 Town Pump LLC (406) 497-6700 environmental@townpump.com

Trent Biggers, UST Class A Operator environmental@townpump.com

Trent Biggers, UST Class B Operator environmental@townpump.com

Tank Number	01	**Tank Age**	8	**Tank Installed Date**	07/10/2017	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	5686	**Spill Test Date**	01/24/2024	**Piping Installed Date**	07/10/2017	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	09/28/2023	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	02/06/2024	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	30000	**ATG Test Date**	02/06/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Statistical Inventory Reconciliation	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	Yes
		Overfill Test Date	09/28/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-450				
Tank Number	02	**Tank Age**	8	**Tank Installed Date**	07/10/2017	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	5687	**Spill Test Date**	09/28/2023	**Piping Installed Date**	07/10/2017	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	09/28/2023	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	02/06/2024	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	15000	**ATG Test Date**	02/06/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Statistical Inventory Reconciliation	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	**Energy Act**	Yes

		Overfill Test Date	09/28/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-450				
Tank Number	03	**Tank Age**	8	**Tank Installed Date**	07/10/2017	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	5688	**Spill Test Date**	09/28/2023	**Piping Installed Date**	07/10/2017	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	09/28/2023	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	02/06/2024	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	7000	**ATG Test Date**	02/06/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Statistical Inventory Reconciliation	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	Yes
		Overfill Test Date	09/28/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-450				
Tank Number	04	**Tank Age**	8	**Tank Installed Date**	07/10/2017	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	5689	**Spill Test Date**	01/24/2024	**Piping Installed Date**	07/10/2017	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	02/06/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	09/28/2023	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	30000	**ATG Test Date**	02/06/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Statistical Inventory Reconciliation	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	Yes
		Overfill Test Date	01/24/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-450				
Tank Number	05	**Tank Age**	8	**Tank Installed Date**	07/10/2017	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	5690	**Spill Test Date**	09/28/2023	**Piping Installed Date**	07/10/2017	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	09/28/2023	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	02/06/2024	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	02/06/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Statistical Inventory Reconciliation	**Secondary Pipe Leak Detection**		**Energy Act**	Yes
		Overfill Test Date	09/28/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-450				
Tank Number	06	**Tank Age**	8	**Tank Installed Date**	07/10/2017	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve

Tag Number	5691	**Spill Test Date**	01/24/2024	**Piping Installed Date**	07/10/2017	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	08/12/2020	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	06/14/2022	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	30000	**ATG Test Date**	06/14/2022	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Statistical Inventory Reconciliation	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	Yes
		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/TLS-450				
Tank Number	07	**Tank Age**	8	**Tank Installed Date**	07/10/2017	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	5692	**Spill Test Date**	09/28/2023	**Piping Installed Date**	07/10/2017	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	09/28/2023	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	02/06/2024	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	7000	**ATG Test Date**	02/06/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Statistical Inventory Reconciliation	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	Yes
		Overfill Test Date	09/28/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-450				
Tank Number	08	**Tank Age**	8	**Tank Installed Date**	07/10/2017	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	5719	**Spill Test Date**	09/28/2023	**Piping Installed Date**	07/10/2017	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	09/28/2023	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	02/06/2024	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	02/06/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Statistical Inventory Reconciliation	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	Yes
		Overfill Test Date	09/28/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-450				

Facility Summary in Dawson County in the City of Glendive

Location: TRAIL STAR CAR AND TRUCK STOP
11 MT Hwy 16
Glendive, MT 59330 Dawson

System Facility ID:11-05754

Facility Code: 19761
Last Inspected On: 12/04/2023
Operating Permit Renewal Date: 03/09/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Trailstar Truck Stop Inc

Operator Contact: Cheryl Haggerty **trailstar@midrivers.com**

Owner/Operator: Trailstar Truck Stop Inc

Cheryl Haggerty, UST Class A Operator	trailstar@midrivers.com
Cheryl Haggerty, UST Class A Operator	trailstar@midrivers.com
Cheryl Haggerty, UST Class B Operator	trailstar@midrivers.com
Cheryl Haggerty, UST Class B Operator	trailstar@midrivers.com

Tank Number	05	**Tank Age**	27	**Tank Installed Date**	11/30/1998	**Tank Material Construction**	Steel Clad	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	4274	**Spill Test Date**	10/25/2023	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	10/16/2020	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	10/24/2023	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	10/23/2023	**Line Tightness Test Date**	06/20/2020	**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	10/24/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	06	**Tank Age**	27	**Tank Installed Date**	11/30/1998	**Tank Material Construction**	Steel Clad	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	4275	**Spill Test Date**	10/25/2023	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	10/16/2020	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	10/24/2023	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	10/23/2023	**Line Tightness Test Date**	06/02/2020	**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No

		Overfill Test Date	10/24/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	07	**Tank Age**	27	**Tank Installed Date**	11/30/1998	**Tank Material Construction**	Steel Clad	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	4276	**Spill Test Date**	10/25/2023	**Piping Installed Date**	01/07/2011	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	10/16/2020	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	10/24/2023	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	10/23/2024	**Line Tightness Test Date**	08/20/2020	**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date	10/24/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	08	**Tank Age**	27	**Tank Installed Date**	11/30/1998	**Tank Material Construction**	Steel Clad	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	4277	**Spill Test Date**	10/25/2023	**Piping Installed Date**	08/17/2009	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	10/16/2020	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	10/24/2023	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	10/23/2023	**Line Tightness Test Date**	07/20/2020	**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	10/24/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	09	**Tank Age**	27	**Tank Installed Date**	11/30/1998	**Tank Material Construction**	Steel Clad	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	4278	**Spill Test Date**	10/25/2023	**Piping Installed Date**	08/17/2009	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	10/16/2020	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	10/24/2023	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	15000	**ATG Test Date**	10/23/2023	**Line Tightness Test Date**	07/20/2020	**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	10/24/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Dawson County in the City of Glendive

Location: WEST PARK CENEX
2200 W Towne St
Glendive, MT 59330 Dawson

System Facility ID:11-08908

Facility Code: 19822
Last Inspected On: 06/25/2024
Operating Permit Renewal Date: 10/09/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Cross Petroleum Services Glendive		**cross@midrivers.com**
Operator Contact:	Alvaro Garcia;Gregory Cross;R J Serpe	**(602) 373-8892**	**garc8651@gmail.com;gcross@crosspetroleumservice.com;rlsrp@yahoo.com**

Owner/Operator: Cross Petroleum Services Glendive cross@midrivers.com

Alvaro Garcia, UST Class A Operator	garc8651@gmail.com
Alvaro Garcia, UST Class A Operator	garc8651@gmail.com
Alvaro Garcia, UST Class B Global Operator	garc8651@gmail.com
Alvaro Garcia, UST Class B Global Operator	garc8651@gmail.com
Greg Cross, UST Class A Operator	gcross@crosspetroleumservice.com
Greg Cross, UST Class A Operator	gcross@crosspetroleumservice.com
R J Serpe, UST Class A Operator	rlsrp@yahoo.com
R J Serpe, UST Class A Operator	rlsrp@yahoo.com
R J Serpe, UST Class B Global Operator	rlsrp@yahoo.com
R J Serpe, UST Class B Global Operator	rlsrp@yahoo.com

Tank Number	S4	**Tank Age**	26	**Tank Installed Date**	09/01/1999	**Tank Material Construction**	Unknown	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	553	**Spill Test Date**		**Piping Installed Date**	09/21/2021	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	Yes
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	06/25/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Gasoline	**PLLD Test Date**	06/25/2024	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	06/25/2024	**Line Tightness Test Date**	03/11/2015	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	S5	**Tank Age**	26	**Tank Installed Date**	09/01/1999	**Tank Material Construction**	Unknown	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	554	**Spill Test Date**		**Piping Installed Date**	09/21/2021	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	Yes
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	06/25/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	

Product	Gasoline	**PLLD Test Date**	06/25/2024	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	06/25/2024	**Line Tightness Test Date**	02/05/2015	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	S6	**Tank Age**	26	**Tank Installed Date**	09/01/1999	**Tank Material Construction**	Unknown	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	555	**Spill Test Date**		**Piping Installed Date**	09/21/2021	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	Yes
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	06/25/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Diesel	**PLLD Test Date**	06/25/2024	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	06/25/2024	**Line Tightness Test Date**	02/07/2015	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date				**ATG Type**					

Facility Summary in Dawson County in the City of Glendive

Location: WESTGATE CENEX
56 MT Hwy 16
Glendive, MT 59330 Dawson

System Facility ID:11-08909

Facility Code: 19823
Last Inspected On: 06/25/2024
Operating Permit Renewal Date: 10/31/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Cross Petroleum Services Glendive **cross@midrivers.com**

Operator Contact: Gregory Cross;R J Serpe;Timothy Fife **gcross@crosspetroleumservice.com;rlsrp@yahoo.com**

Owner/Operator: Cross Petroleum Services Glendive cross@midrivers.com

Greg Cross, UST Class A Operator	gcross@crosspetroleumservice.com
Greg Cross, UST Class A Operator	gcross@crosspetroleumservice.com
R J Serpe, UST Class A Operator	rlsrp@yahoo.com
R J Serpe, UST Class A Operator	rlsrp@yahoo.com
R J Serpe, UST Class B Global Operator	rlsrp@yahoo.com
R J Serpe, UST Class B Global Operator	rlsrp@yahoo.com
Timothy Fife, UST Class A Operator	
Timothy Fife, UST Class A Operator	

Tank Number	01	**Tank Age**	64	**Tank Installed Date**	05/22/1961	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve;Flapper Valve
Tag Number	556	**Spill Test Date**	06/25/2024	**Piping Installed Date**	08/23/2007	**Tank Construction**	Lined Interior/Impressed Current	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	07/13/2012	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	06/25/2024	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	06/25/2024	**Line Tightness Test Date**	07/06/2012	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	06/25/2024			**ATG Type**	Incon/TS-550 EVO				
Tank Number	02	**Tank Age**	64	**Tank Installed Date**	05/22/1961	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	557	**Spill Test Date**	06/25/2024	**Piping Installed Date**	08/23/2007	**Tank Construction**	Lined Interior/Impressed Current	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	07/13/2012	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current

Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	06/25/2024	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	06/25/2024	**Line Tightness Test Date**	08/09/2011	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	06/25/2024			**ATG Type**	Incon/TS-550 EVO				
Tank Number	05	**Tank Age**	33	**Tank Installed Date**	02/07/1992	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	558	**Spill Test Date**	07/22/2024	**Piping Installed Date**	08/23/2007	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	07/13/2012	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	06/25/2024	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	06/25/2024	**Line Tightness Test Date**	07/04/2012	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	06/25/2024			**ATG Type**	Incon/TS-550 EVO				

Facility Summary in Dawson County in the City of Richey

Location: FARMERS ELEVATOR RICHEY
111 Railroad Ave
Richey, MT 59259 Dawson

System Facility ID:11-05898

Facility Code: 19762
Last Inspected On: 01/29/2025
Operating Permit Renewal Date: 02/02/2028

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: CHS Inc Richey **(406) 773-5758** **tim.buller@chsinc.com**

Operator Contact:

Owner/Operator: CHS Inc Richey (406) 773-5758 tim.buller@chsinc.com

Jana Olson, UST Class B Operator jana.olson@chsinc.com
Jana Olson, UST Class B Operator jana.olson@chsinc.com
Lance Schipman, UST Class B Operator lance.schipman@chsinc.com
Lance Schipman, UST Class B Operator lance.schipman@chsinc.com

Tank Number	05	**Tank Age**	24	**Tank Installed Date**	07/11/2001	**Tank Material Construction**	Steel Clad	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	4314	**Spill Test Date**	01/29/2025	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	10/29/2012	**Primary Tank Leak Detection**	Manual Interstitial Monitoring	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	01/29/2025	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	01/29/2025			**ATG Type**					
Tank Number	06	**Tank Age**	24	**Tank Installed Date**	07/11/2001	**Tank Material Construction**	Steel Clad	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	4315	**Spill Test Date**	01/29/2025	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	10/29/2012	**Primary Tank Leak Detection**	Manual Interstitial Monitoring	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	01/29/2025	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	01/29/2025			**ATG Type**					
Tank Number	07	**Tank Age**	24	**Tank Installed Date**	07/11/2001	**Tank Material Construction**	Steel Clad	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve

Tag Number	4316	**Spill Test Date**	01/29/2025	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	10/29/2012	**Primary Tank Leak Detection**	Manual Interstitial Monitoring	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	01/29/2025	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	01/29/2025			**ATG Type**					
Tank Number	08	**Tank Age**	10	**Tank Installed Date**	04/01/2015	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	5572	**Spill Test Date**	01/29/2025	**Piping Installed Date**	05/07/2015	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	01/29/2025	**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	01/29/2025	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	Yes
		Overfill Test Date	01/29/2025			**ATG Type**	Incon/TS-550 EVO				

Facility Summary in Deer Lodge County in the City of Anaconda

Location: FAIRMONT RV PARK AND CAMPGROUND LLC
1700 Fairmont Rd
Anaconda, MT 59711-9419 Deer Lodge

System Facility ID:56-13976

Facility Code: 30638
Last Inspected On: 09/07/2022
Operating Permit Renewal Date: 11/01/2025

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	SILVER BOW RESORTS INC DBA FAIRMONT RV RESORT	**(406) 979-3505**	**DANBRADSHAW27@ICLOUD.COM**
Operator Contact:	Dan Bashaw;Joe Bashaw	**(406) 593-0929;(406) 797-3505**	**danbashaw27@icloud.com;fairmontrvpark@aol.com**

Owner/Operator: SILVER BOW RESORTS INC DBA FAIRMONT RV RESORT (406) 979-3505 DANBRADSHAW27@ICLOUD.COM

Dan Bashaw, UST Class A Operator	fairmontrvpark@aol.com
Dan Bashaw, UST Class B Global Operator	fairmontrvpark@aol.com
Joe Bashaw, UST Class A Operator	danbashaw27@icloud.com
Joe Bashaw, UST Class B Global Operator	danbashaw27@icloud.com

Tank Number	02	**Tank Age**	25	**Tank Installed Date**	04/01/2000	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	4187	**Spill Test Date**	11/11/2021	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Manual Interstitial Monitoring	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	3000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	11/11/2021			**ATG Type**					
Tank Number	03	**Tank Age**	25	**Tank Installed Date**	04/01/2000	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	4188	**Spill Test Date**	11/11/2021	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Manual Interstitial Monitoring	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	3000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	11/11/2021			**ATG Type**					

Facility Summary in Deer Lodge County in the City of Anaconda

Location: MAIN GRANULATED SLAG PILE - ANACONDA SMELTER NPL SITE
6 mi west of I-90 on Hwy 1
Anaconda, MT 59711-9190 Deer Lodge

System Facility ID:12-10912

Facility Code: 19943
Last Inspected On: 09/06/2022
Operating Permit Renewal Date: 09/06/2025

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: ARCO Environmental Remediation LLC **(406) 782-9964**

Operator Contact:

Tank Number	S1	**Tank Age**	40	**Tank Installed Date**	04/16/1985	**Tank Material Construction**	Bare Steel	**Piping Material**	Steel	**Overfill Types**	
Tag Number	1836	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	Yes
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**	07/19/2019	**Catastrophic L.D. Type 3.0**	Continuous Interstitial Monitoring	**Piping Type**	Pressurized	**CP Met Types**	
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	25600	**ATG Test Date**		**Line Tightness Test Date**	07/19/2019	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	MLLD Line Tightness Testing	**Energy Act**	No
		Overfill Test Date				**ATG Type**					

Facility Summary in Deer Lodge County in the City of Anaconda

Location: THRIFTWAY SUPER STOP 3
1420 E Park Ave
Anaconda, MT 59711-2766 Deer Lodge

System Facility ID:12-07938

Facility Code: 19928
Last Inspected On: 01/31/2025
Operating Permit Renewal Date: 06/12/2028

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Sutey Oil Co Inc	**(406) 494-2305**	**ldsutey66@thriftwayss.com**
Operator Contact:	Linda Otonicar;Louis Sutey	**(406) 491-5808;(406) 494-2305**	**ldsutey66@thriftwayss.com;otonicarlinda@aol.com**

Owner/Operator: Sutey Oil Co Inc (406) 494-2305 ldsutey66@thriftwayss.com

Linda Otonicar, UST Class A Operator	otonicarlinda@aol.com
Louis Sutey, UST Class A Operator	ldsutey66@thriftwayss.com
Louis Sutey, UST Class B Global Operator	ldsutey66@thriftwayss.com
Patty Kline, UST Class B Operator	ldsutey66@thriftwayss.com
Theresa Weinman, UST Class B Operator	thriftway3@thriftwayss.com
Theresa Weinman, UST Class B Operator	thriftway3@thriftwayss.com

Tank Number	06	**Tank Age**	35	**Tank Installed Date**	09/01/1990	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	2048	**Spill Test Date**	01/30/2025	**Piping Installed Date**	10/04/2012	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	03/24/2022	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	04/08/2024	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	15000	**ATG Test Date**	04/08/2024	**Line Tightness Test Date**	02/10/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date	01/30/2025			**ATG Type**	Gilbarco-Veeder Root/TLS-450				
Tank Number	07	**Tank Age**	35	**Tank Installed Date**	09/01/1990	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	2049	**Spill Test Date**	01/30/2025	**Piping Installed Date**	10/04/2012	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	03/24/2022	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	04/08/2024	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	04/08/2024	**Line Tightness Test Date**	02/10/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No

		Overfill Test Date	01/30/2025			**ATG Type**	Gilbarco-Veeder Root/TLS-450				
Tank Number	08	**Tank Age**	35	**Tank Installed Date**	09/01/1990	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	2050	**Spill Test Date**	01/30/2025	**Piping Installed Date**	10/04/2012	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	03/24/2022	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	04/08/2024	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	04/08/2024	**Line Tightness Test Date**	02/10/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date	01/30/2025			**ATG Type**	Gilbarco-Veeder Root/TLS-450				
Tank Number	09	**Tank Age**	35	**Tank Installed Date**	09/01/1990	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	2051	**Spill Test Date**	01/30/2025	**Piping Installed Date**	10/04/2012	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	03/24/2022	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	04/08/2024	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**	04/08/2024	**Line Tightness Test Date**	02/10/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date	01/30/2025			**ATG Type**	Gilbarco-Veeder Root/TLS-450				
Tank Number	10	**Tank Age**	35	**Tank Installed Date**	09/01/1990	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	2052	**Spill Test Date**	01/30/2025	**Piping Installed Date**	10/04/2012	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	03/24/2022	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel, Dyed	**PLLD Test Date**	04/08/2024	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**	04/08/2024	**Line Tightness Test Date**	02/10/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date	01/30/2025			**ATG Type**	Gilbarco-Veeder Root/TLS-450				

Facility Summary in Deer Lodge County in the City of Anaconda

Location: THRIFTWAY SUPER STOP 7
2035 W Park Ave
Anaconda, MT 59711-1774 Deer Lodge

System Facility ID:12-00101

Facility Code: 19861
Last Inspected On: 10/29/2024
Operating Permit Renewal Date: 02/27/2028

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Sutey Oil Co Inc	**(406) 494-2305**	**ldsutey66@thriftwayss.com**
Operator Contact:	Brian Clemons;Jack Hook;Linda Otonicar;Louis Sutey;Theodore Weinman	**(406) 491-5808;(406) 494-2305;(406) 560-3928;(406) 563-2410**	**ldsutey66@thriftwayss.com;otonicarlinda@aol.com;tweinman62@gmail.com;wolfenmist@aol.com**

Owner/Operator: Sutey Oil Co Inc (406) 494-2305 ldsutey66@thriftwayss.com

Allyn Moses, UST Class B Operator	thriftway7@thriftwayss.com
Brian Clemons, UST Class A Operator	wolfenmist@aol.com
Jack Hook, UST Class A Operator	
Linda Otonicar, UST Class A Operator	otonicarlinda@aol.com
Louis Sutey, UST Class A Operator	ldsutey66@thriftwayss.com
Theodore Weinman, UST Class A Operator	tweinman62@gmail.com
Toni Clemons, UST Class B Operator	anacondacwolf59711@yahoo.com

Tank Number	02	**Tank Age**	32	**Tank Installed Date**	07/01/1993	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	2045	**Spill Test Date**	10/29/2024	**Piping Installed Date**		**Tank Construction**	Lined Interior/Impressed Current	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	04/09/2024	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	06/14/2022	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	04/09/2024	**Line Tightness Test Date**	04/09/2024	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	10/29/2024			**ATG Type**	Gilbarco/EMC Basic				
Tank Number	04	**Tank Age**	54	**Tank Installed Date**	12/31/1971	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	2046	**Spill Test Date**	10/29/2024	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	04/09/2024	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	06/14/2022	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No

Capacity	12000	**ATG Test Date**	04/09/2024	**Line Tightness Test Date**	04/09/2024	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	10/29/2024			**ATG Type**	Gilbarco/EMC Basic				
Tank Number	05	**Tank Age**	32	**Tank Installed Date**	07/01/1993	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	2047	**Spill Test Date**	10/29/2024	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	04/09/2024	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	06/14/2022	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	04/09/2024	**Line Tightness Test Date**	04/09/2024	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	10/29/2024			**ATG Type**	Gilbarco/EMC Basic				

Facility Summary in Deer Lodge County in the City of Anaconda

Location: TOWN PUMP INC ANACONDA 1
6940 MT Hwy 1 Ste A
Anaconda, MT 59711 Deer Lodge

System Facility ID:12-09326

Facility Code: 19935
Last Inspected On: 03/26/2025
Operating Permit Renewal Date: 08/29/2028

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Anaconda 1 Town Pump LLC **(406) 497-6700** **environmental@townpump.com**

Operator Contact: Trent Biggers **Trentb@townpump.com**

Owner/Operator: Anaconda 1 Town Pump LLC (406) 497-6700 environmental@townpump.com

Trent Biggers, UST Class A Operator Trentb@townpump.com
Trent Biggers, UST Class A Operator Trentb@townpump.com
Trent Biggers, UST Class B Global Operator Trentb@townpump.com
Trent Biggers, UST Class B Global Operator Trentb@townpump.com

Tank Number	05	**Tank Age**	34	**Tank Installed Date**	05/01/1991	**Tank Material Construction**	Bare Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	2411	**Spill Test Date**	04/10/2025	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Diesel	**PLLD Test Date**	03/26/2025	**Tank/Piping CP Test Date**	05/05/2021	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	03/26/2025	**Line Tightness Test Date**	09/01/2005	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	04/03/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Number	06	**Tank Age**	34	**Tank Installed Date**	05/01/1991	**Tank Material Construction**	Bare Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	2412	**Spill Test Date**	04/03/2024	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**	03/26/2025	**Tank/Piping CP Test Date**	05/05/2021	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No

Capacity	12000	**ATG Test Date**	03/26/2025	**Line Tightness Test Date**	09/01/2005	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	04/03/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Number	07	**Tank Age**	31	**Tank Installed Date**	12/01/1994	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	2413	**Spill Test Date**	10/01/2024	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	03/26/2025	**Tank/Piping CP Test Date**	06/24/2014	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	03/26/2025	**Line Tightness Test Date**	09/01/2005	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	04/03/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Number	08	**Tank Age**	31	**Tank Installed Date**	11/01/1994	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	2414	**Spill Test Date**	04/03/2024	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	03/26/2025	**Tank/Piping CP Test Date**	06/24/2014	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	03/26/2025	**Line Tightness Test Date**	09/01/2005	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	04/03/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Number	09	**Tank Age**	24	**Tank Installed Date**	07/01/2001	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	4574	**Spill Test Date**	10/16/2024	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel, Dyed	**PLLD Test Date**	03/26/2025	**Tank/Piping CP Test Date**	05/05/2012	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	03/26/2025	**Line Tightness Test Date**	09/01/2005	**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No

		Overfill Test Date	04/03/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Number	10	**Tank Age**	24	**Tank Installed Date**	07/01/2001	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve
Tag Number	4575	**Spill Test Date**	10/16/2024	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	03/26/2025	**Tank/Piping CP Test Date**	05/05/2012	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	5000	**ATG Test Date**	03/26/2025	**Line Tightness Test Date**	09/01/2005	**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	04/03/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				

Facility Summary in Deer Lodge County in the City of Anaconda

Location: TOWN PUMP INC ANACONDA 2
819 W Park Ave
Anaconda, MT 59711 Deer Lodge

System Facility ID:12-08668

Facility Code: 19933
Last Inspected On: 03/26/2025
Operating Permit Renewal Date: 03/26/2028

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Anaconda 2 Town Pump LLC **(406) 497-6700** **environmental@townpump.com**

Operator Contact: Trent Biggers **Trentb@townpump.com**

Owner/Operator: Anaconda 2 Town Pump LLC (406) 497-6700 environmental@townpump.com

Trent Biggers, UST Class A Operator Trentb@townpump.com

Trent Biggers, UST Class B Global Operator Trentb@townpump.com

Tank Number	03	**Tank Age**	34	**Tank Installed Date**	04/01/1991	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve;Flapper Valve
Tag Number	2407	**Spill Test Date**	09/17/2024	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Single Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	03/26/2025	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	03/26/2025	**Line Tightness Test Date**	10/31/2006	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	09/17/2024			**ATG Type**	/TLS-450PLUS;Gilbarco-Veeder Root/TLS-450PLUS				
Tank Number	04	**Tank Age**	34	**Tank Installed Date**	04/01/1991	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve;Flapper Valve
Tag Number	2408	**Spill Test Date**	09/17/2024	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Single Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	03/26/2025	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	03/26/2025	**Line Tightness Test Date**	10/31/2006	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No

		Overfill Test Date	09/17/2024			**ATG Type**	/TLS-450PLUS;Gilbarco-Veeder Root/TLS-450PLUS				
Tank Number	05	**Tank Age**	34	**Tank Installed Date**	04/01/1991	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve;Flapper Valve
Tag Number	2409	**Spill Test Date**	09/17/2024	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Single Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	03/26/2025	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	03/26/2025	**Line Tightness Test Date**	10/31/2006	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	09/17/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Number	06	**Tank Age**	34	**Tank Installed Date**	04/01/1991	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve;Flapper Valve
Tag Number	2410	**Spill Test Date**	09/17/2024	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Single Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	03/26/2025	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	03/26/2025	**Line Tightness Test Date**	10/31/2006	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	09/17/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				

Facility Summary in Deer Lodge County in the City of Warm Springs

Location: XANTHOPOULOS BLDG
2 C St
Warm Springs, MT 59756 Deer Lodge

System Facility ID:12-07585

Facility Code: 19926
Last Inspected On: 08/10/2023
Operating Permit Renewal Date: 11/26/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Montana Dept of Corrections	**(406) 444-6551**	**JCHRISTOFFERSON@MT.GOV**
Operator Contact:	Suzann Podruzny;Montana Dept of Corrections	**(406) 444-6551**	**sue.chvilicek@mt.gov;JCHRISTOFFERSON@MT.GOV**

Owner/Operator: Montana Dept of Corrections (406) 444-6551 JCHRISTOFFERSON@MT.GOV

Mark James, UST Class B Operator JCHRISTOFFERSON@MT.GOV

Suzann Podruzny, UST Class A Operator JCHRISTOFFERSON@MT.GOV

Tank Number	04	**Tank Age**	38	**Tank Installed Date**	01/01/1987	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	829	**Spill Test Date**	08/10/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	08/10/2023	**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	U.S. Suction	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.1	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	2000	**ATG Test Date**	05/22/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	08/10/2023			**ATG Type**	Veeder Root/TLS-300				

Facility Summary in Fallon County in the City of Baker

Location: BAKER FARMERS UNION OIL
303 W Montana Ave
Baker, MT 59313 Fallon

System Facility ID:13-09960

Facility Code: 20017
Last Inspected On: 01/17/2024
Operating Permit Renewal Date: 05/16/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Farmers Union Oil Co Baker **(406) 778-2519**

Operator Contact: Tonya England **(541) 643-4540** **cenexoffice@midrivers.com**

Owner/Operator: Farmers Union Oil Co Baker (406) 778-2519

Kelly Brookes, UST Class B Operator	
Kelly Brookes, UST Class B Operator	
Tonya England, UST Class A Operator	cenexoffice@midrivers.com
Tonya England, UST Class A Operator	cenexoffice@midrivers.com
Tonya England, UST Class B Global Operator	cenexoffice@midrivers.com
Tonya England, UST Class B Global Operator	cenexoffice@midrivers.com
Tonya England, UST Class B Operator	cenexoffice@midrivers.com
Tonya England, UST Class B Operator	cenexoffice@midrivers.com

Tank Number	12	**Tank Age**	8	**Tank Installed Date**	08/01/2017	**Tank Material Construction**	Steel Clad	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	5693	**Spill Test Date**	09/08/2022	**Piping Installed Date**	08/01/2017	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	10/04/2022	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	10/24/2023	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	Yes
Capacity	20000	**ATG Test Date**	04/15/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	09/08/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-450;Veeder Root/TLS-450				
Tank Number	13	**Tank Age**	8	**Tank Installed Date**	08/01/2017	**Tank Material Construction**	Steel Clad	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	5694	**Spill Test Date**	09/08/2022	**Piping Installed Date**	08/01/2017	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	10/04/2022	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible

Product	Diesel	**PLLD Test Date**	10/24/2023	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	14000	**ATG Test Date**	04/15/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	09/08/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-450;Veeder Root/TLS-450				
Tank Number	14	**Tank Age**	8	**Tank Installed Date**	08/01/2017	**Tank Material Construction**	Steel Clad	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	5695	**Spill Test Date**	09/08/2022	**Piping Installed Date**	08/01/2017	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	10/04/2022	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	10/24/2023	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**	10/24/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	09/08/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-450;Veeder Root/TLS-450				
Tank Number	15	**Tank Age**	8	**Tank Installed Date**	08/01/2017	**Tank Material Construction**	Steel Clad	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	5696	**Spill Test Date**	09/08/2022	**Piping Installed Date**	08/01/2017	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	10/04/2022	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	10/24/2023	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	Yes
Capacity	8000	**ATG Test Date**	04/15/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	09/08/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-450;Veeder Root/TLS-450				
Tank Number	16	**Tank Age**	8	**Tank Installed Date**	08/01/2017	**Tank Material Construction**	Steel Clad	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	5697	**Spill Test Date**	09/08/2022	**Piping Installed Date**	08/01/2017	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	10/04/2022	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	10/24/2023	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No

Capacity	6000	**ATG Test Date**	10/24/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	09/08/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-450;Veeder Root/TLS-450				
Tank Number	17	**Tank Age**	8	**Tank Installed Date**	08/01/2017	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Positive Shutoff
Tag Number	5702	**Spill Test Date**	09/08/2022	**Piping Installed Date**	08/01/2017	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Other**	**MLLD Test Date**		**Sump Tightness Test Date**	08/21/2017	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	DEF (Not Regulated)	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	ELLD 0.2;ELLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	2000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring;Not Listed	**Energy Act**	Yes
		Overfill Test Date	09/08/2022			**ATG Type**	Veeder Root/TLS-450				
Tank Number	06	**Tank Age**	30	**Tank Installed Date**	11/01/1995	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve
Tag Number	973	**Spill Test Date**	10/24/2023	**Piping Installed Date**	05/30/2012	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	10/04/2022	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Diesel, Dyed	**PLLD Test Date**	10/24/2023	**Tank/Piping CP Test Date**	08/28/2024	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	15000	**ATG Test Date**	10/24/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date	04/15/2024			**ATG Type**	Veeder Root/TLS-450				
Tank Number	07	**Tank Age**	30	**Tank Installed Date**	11/01/1995	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve
Tag Number	974	**Spill Test Date**	10/06/2022	**Piping Installed Date**	05/30/2012	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	10/04/2022	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**	10/24/2023	**Tank/Piping CP Test Date**	08/28/2024	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	5000	**ATG Test Date**	10/24/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No

		Overfill Test Date	04/15/2024			**ATG Type**	Veeder Root/TLS-450				
Tank Number	08	**Tank Age**	30	**Tank Installed Date**	11/01/1995	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve
Tag Number	975	**Spill Test Date**	04/15/2024	**Piping Installed Date**	05/30/2012	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	10/04/2022	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**	10/24/2023	**Tank/Piping CP Test Date**	08/28/2024	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	10/24/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date	04/15/2024			**ATG Type**	Veeder Root/TLS-450				
Tank Number	09	**Tank Age**	30	**Tank Installed Date**	11/01/1995	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve
Tag Number	976	**Spill Test Date**	10/06/2022	**Piping Installed Date**	05/30/2012	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	10/04/2022	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**	10/24/2023	**Tank/Piping CP Test Date**	08/28/2024	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	15000	**ATG Test Date**	10/24/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date	04/15/2024			**ATG Type**	Veeder Root/TLS-450				
Tank Number	10	**Tank Age**	30	**Tank Installed Date**	11/01/1995	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve
Tag Number	977	**Spill Test Date**	10/06/2022	**Piping Installed Date**	05/30/2012	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	10/04/2022	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**	10/24/2023	**Tank/Piping CP Test Date**	08/28/2024	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	5000	**ATG Test Date**	10/24/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date	04/15/2024			**ATG Type**	Veeder Root/TLS-450				
Tank Number	11	**Tank Age**	30	**Tank Installed Date**	11/01/1995	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve
Tag Number	978	**Spill Test Date**	10/06/2022	**Piping Installed Date**	05/30/2012	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No

Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	10/04/2022	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**	10/24/2023	**Tank/Piping CP Test Date**	08/28/2024	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	04/15/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date	04/15/2024			**ATG Type**	Veeder Root/TLS-450				

Facility Summary in Fallon County in the City of Baker

Location: FALLON COUNTY AIRPORT
Fallon County Airport
Baker, MT 59313 Fallon

System Facility ID:13-10696

Facility Code: 20018
Last Inspected On: 05/27/2021
Operating Permit Renewal Date: 06/21/2024

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Fallon County	**(406) 778-3508**	
Operator Contact:	Roger Meggers	**(406) 778-3508**	**bakerair@midrivers.com**

Roger Meggers, UST Class A Operator — bakerair@midrivers.com
Roger Meggers, UST Class B Operator — bakerair@midrivers.com

Tank Number	01	**Tank Age**	37	**Tank Installed Date**	01/01/1988	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	894	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Jet Fuel (Jet-A, Jet-A1, JP5)	**PLLD Test Date**		**Tank/Piping CP Test Date**	09/13/2012	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.1	**Vapor Recovery**	No
Capacity	20000	**ATG Test Date**		**Line Tightness Test Date**	05/27/2021	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**	OPW/EECO 1500				
Tank Number	02	**Tank Age**	37	**Tank Installed Date**	01/01/1988	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	895	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Aviation Gas	**PLLD Test Date**		**Tank/Piping CP Test Date**	09/13/2012	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.1	**Vapor Recovery**	No
Capacity	20000	**ATG Test Date**		**Line Tightness Test Date**	05/27/2021	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**	OPW/EECO 1500				

Facility Summary in Fallon County in the City of Baker

Location: FALLON COUNTY MEDICAL COMPLEX
225 S 3rd St W
Baker, MT 59313 Fallon

System Facility ID:60-15072

Facility Code: 30843
Last Inspected On: 06/06/2023
Operating Permit Renewal Date: 07/13/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Fallon Medical Complex Inc	**(406) 778-3331**	
Operator Contact:	Brad Kings;Tonna Hartman;Fallon Medical Complex Inc	**(406) 778-5419;(406) 778-3331;(406) 978-5220**	**bekings@fallonmedical.org;fmcmaintenance@fallonmedical.org**

Owner/Operator: Fallon Medical Complex Inc (406) 778-3331

Brad Kings, UST Class A Operator	bekings@fallonmedical.org
John Zook, UST Class B Global Operator	jzook894@yahoo.com
John Zook, UST Class B Operator	jzook894@yahoo.com
Tonna Hartman, UST Class A Operator	fmcmaintenance@fallonmedical.org
Tonna Hartman, UST Class B Global Operator	fmcmaintenance@fallonmedical.org

Tank Number	01	**Tank Age**	19	**Tank Installed Date**	01/02/2006	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	5125	**Spill Test Date**	08/22/2023	**Piping Installed Date**	04/25/2007	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	08/22/2023	**Catastrophic L.D. Type 3.0**	Auto Dialer	**Piping Type**	U.S. Suction	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	2500	**ATG Test Date**	06/06/2023	**Line Tightness Test Date**	06/24/2014	**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	08/22/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Fallon County in the City of Baker

Location: FALLON COUNTY RD DEPT
122 E Center Ave
Baker, MT 59313 Fallon

System Facility ID:13-01687

Facility Code: 19967
Last Inspected On: 04/01/2024
Operating Permit Renewal Date: 08/03/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Fallon County Road Dept **(406) 778-2019**

Operator Contact: Alba Higgins;Bobby Wiedmer **(406) 978-2015** **falcord@midrivers.com**

Owner/Operator: Fallon County Road Dept (406) 778-2019

Alba Higgins, UST Class A Operator	falcord@midrivers.com
Alba Higgins, UST Class A Operator	falcord@midrivers.com
Alba Higgins, UST Class B Operator	falcord@midrivers.com
Alba Higgins, UST Class B Operator	falcord@midrivers.com
Bobby Wiedmer, UST Class A Operator	falcord@midrivers.com
Bobby Wiedmer, UST Class A Operator	falcord@midrivers.com
Bobby Wiedmer, UST Class B Operator	falcord@midrivers.com
Bobby Wiedmer, UST Class B Operator	falcord@midrivers.com
Carl Overland, UST Class B Operator	blackycarlata1@gmail.com
Carl Overland, UST Class B Operator	blackycarlata1@gmail.com
Mitch Overn, UST Class B Operator	falcord@midrivers.com
Mitch Overn, UST Class B Operator	falcord@midrivers.com

Tank Number	05	**Tank Age**	32	**Tank Installed Date**	06/09/1993	**Tank Material Construction**	Steel Clad	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	896	**Spill Test Date**	03/05/2024	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	09/13/2012	**Primary Tank Leak Detection**	Manual Interstitial Monitoring	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	03/05/2024			**ATG Type**					
Tank Number	06	**Tank Age**	32	**Tank Installed Date**	06/01/1993	**Tank Material Construction**	Steel Clad	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	897	**Spill Test Date**	03/05/2024	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No

Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	09/13/2012	**Primary Tank Leak Detection**	Manual Interstitial Monitoring	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	03/05/2024			**ATG Type**					
Tank Number	07	**Tank Age**	32	**Tank Installed Date**	06/01/1993	**Tank Material Construction**	Steel Clad	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	898	**Spill Test Date**	03/05/2024	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	09/13/2012	**Primary Tank Leak Detection**	Manual Interstitial Monitoring	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	3000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	03/05/2024			**ATG Type**					

Facility Summary in Fallon County in the City of Baker

Location: GENERATIONAL PROPERTIES RENTAL
908 E Montana Ave
Baker, MT 59313-0000 Fallon

System Facility ID:13-08221

Facility Code: 20008
Last Inspected On: 07/01/2024
Operating Permit Renewal Date: 07/01/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	GENERATIONAL PROPERTIES LLC	**(406) 891-0979**	**generationalpropertiesmt@gmail.com**
Operator Contact:	Michael Miller;Promise Miller	**(406) 772-5828**	**flatlineincmg@gmail.com;promisemiller@hotmail.com**

Owner/Operator: GENERATIONAL PROPERTIES LLC (406) 891-0979 generationalpropertiesmt@gmail.com

Michael Miller, UST Class A Operator	flatlineincmg@gmail.com
Michael Miller, UST Class B Operator	flatlineincmg@gmail.com
Promise Miller, UST Class A Operator	promisemiller@hotmail.com
Promise Miller, UST Class B Operator	promisemiller@hotmail.com

Tank Number	04	**Tank Age**	26	**Tank Installed Date**	08/01/1999	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	4083	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Temporarily Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	10/15/2021	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco/EMC Basic				
Tank Number	05	**Tank Age**	26	**Tank Installed Date**	08/01/1999	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	4084	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Temporarily Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	10/15/2021	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco/EMC Basic				

Tank Number	S6	**Tank Age**	26	**Tank Installed Date**	08/01/1999	**Tank Material Construction**	Bare Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	
Tag Number	4085	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	Yes
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**	06/13/2018	**Catastrophic L.D. Type 3.0**	Continuous Interstitial Monitoring	**Piping Type**	Pressurized	**CP Met Types**	
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	06/12/2018	**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	5500	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					

Facility Summary in Fallon County in the City of Baker

Location: J and A MINI STORE
116 W Montana Ave
Baker, MT 59313 Fallon

System Facility ID:13-00685

Facility Code: 19958
Last Inspected On: 12/12/2023
Operating Permit Renewal Date: 12/16/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	ARMH Group LLC;Rose Heiser	**(406) 778-2411;(406) 891-0229**	**jandaministore@gmail.com;rosemorast98@hotmail.com**
Operator Contact:	Rose Heiser	**(406) 891-0229**	**rosemorast98@hotmail.com**
Owner/Operator:	ARMH Group LLC	(406) 778-2411	jandaministore@gmail.com
Owner/Operator:	Rose Heiser	(406) 778-2411	jandaministore@gmail.com
	Rose Heiser, UST Class A Operator		rosemorast98@hotmail.com
	Rose Heiser, UST Class B Global Operator		rosemorast98@hotmail.com

Tank Number	05	**Tank Age**	36	**Tank Installed Date**	05/24/1989	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	1447	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Temporarily Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	12/12/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	4042	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	06	**Tank Age**	36	**Tank Installed Date**	05/24/1989	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	1448	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Temporarily Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	12/12/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	9954	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Tank Number	07	**Tank Age**	36	**Tank Installed Date**	05/24/1989	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	1449	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Temporarily Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	12/12/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	10003	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Fallon County in the City of Baker

Location: MUFFYS
19 E Montana Ave
Baker, MT 59313 Fallon

System Facility ID:13-00227

Facility Code: 19954
Last Inspected On: 11/01/2024
Operating Permit Renewal Date: 11/13/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Monica Stark	**(406) 978-2643**	**muffysirish@gmail.com**
Operator Contact:	Monica Stark	**(406) 978-2643**	**muffysirish@gmail.com**

Owner/Operator: Monica Stark (406) 978-2643 muffysirish@gmail.com

Monica Stark, UST Class A Operator muffysirish@gmail.com
Monica Stark, UST Class B Operator muffysirish@gmail.com
Stacey Sterns, UST Class B Operator sternsstacey03@gmail.com
Stacey Sterns, UST Class B Operator sternsstacey03@gmail.com

Tank Number	05	**Tank Age**	36	**Tank Installed Date**	04/13/1989	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	3519	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Temporarily Out of Use**	**MLLD Test Date**	12/03/2018	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	11/01/2024	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**		**Line Tightness Test Date**	12/03/2018	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco/EMC Basic				
Tank Number	06	**Tank Age**	27	**Tank Installed Date**	10/01/1998	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	3520	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Temporarily Out of Use**	**MLLD Test Date**	12/03/2018	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	11/01/2024	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**		**Line Tightness Test Date**	12/03/2018	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco/EMC Basic				

Facility Summary in Fallon County in the City of Baker

Location: PRAIRIE FUELS
176 E Milwaukee Ave
Baker, MT 59313 Fallon

System Facility ID:13-07740

Facility Code: 20000
Last Inspected On: 07/01/2024
Operating Permit Renewal Date: 10/01/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Prairie Fuels **(406) 778-3245**

Operator Contact: Sharon Tronstad **merwininc@midrivers.com**

Owner/Operator: Prairie Fuels (406) 778-3245

Sharon Tronstad, UST Class A Operator merwininc@midrivers.com
Sharon Tronstad, UST Class B Operator merwininc@midrivers.com

Tank Number	S05	**Tank Age**	29	**Tank Installed Date**	09/01/1996	**Tank Material Construction**	Bare Steel	**Piping Material**	Fiberglass	**Overfill Types**	
Tag Number	3197	**Spill Test Date**		**Piping Installed Date**	12/12/2014	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	Yes
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	07/01/2024	**Catastrophic L.D. Type 3.0**	Auto Dialer	**Piping Type**	Pressurized	**CP Met Types**	
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	17000	**ATG Test Date**	07/01/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	S06	**Tank Age**	29	**Tank Installed Date**	09/01/1996	**Tank Material Construction**	Bare Steel	**Piping Material**	Fiberglass	**Overfill Types**	
Tag Number	3198	**Spill Test Date**		**Piping Installed Date**	07/20/2015	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	Yes
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	07/01/2024	**Catastrophic L.D. Type 3.0**	Auto Dialer	**Piping Type**	Pressurized	**CP Met Types**	
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	8500	**ATG Test Date**	07/01/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	S07	**Tank Age**	29	**Tank Installed Date**	09/01/1996	**Tank Material Construction**	Bare Steel	**Piping Material**	Fiberglass	**Overfill Types**	

Tag Number	3199	**Spill Test Date**		**Piping Installed Date**	12/12/2014	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	Yes
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	12/31/2024	**Catastrophic L.D. Type 3.0**	Auto Dialer	**Piping Type**	Pressurized	**CP Met Types**	
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	07/01/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	S08	**Tank Age**	29	**Tank Installed Date**	09/01/1996	**Tank Material Construction**	Bare Steel	**Piping Material**	Fiberglass	**Overfill Types**	
Tag Number	3200	**Spill Test Date**		**Piping Installed Date**	12/12/2014	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	Yes
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	12/31/2024	**Catastrophic L.D. Type 3.0**	Auto Dialer	**Piping Type**	Pressurized	**CP Met Types**	
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	S09	**Tank Age**	29	**Tank Installed Date**	09/01/1996	**Tank Material Construction**	Bare Steel	**Piping Material**	Fiberglass	**Overfill Types**	
Tag Number	3201	**Spill Test Date**		**Piping Installed Date**	12/12/2014	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	Yes
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**	11/18/2020	**Catastrophic L.D. Type 3.0**	Auto Dialer	**Piping Type**	Pressurized	**CP Met Types**	
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	S10	**Tank Age**	29	**Tank Installed Date**	09/01/1996	**Tank Material Construction**	Bare Steel	**Piping Material**	Fiberglass	**Overfill Types**	
Tag Number	3202	**Spill Test Date**		**Piping Installed Date**	12/12/2014	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	Yes
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**	11/18/2020	**Catastrophic L.D. Type 3.0**	Auto Dialer	**Piping Type**	Pressurized	**CP Met Types**	
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No

Capacity	4000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					

Facility Summary in Fergus County in the City of Denton

Location: MALMSTROM AFB D 1
Bear Springs Rd
Denton, MT 59430 Fergus

System Facility ID:14-09008

Facility Code: 20310
Last Inspected On: 06/05/2024
Operating Permit Renewal Date: 04/08/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: 341 CES CEANQ **(406) 731-6188**

Operator Contact: Candace Ellsworth;Curtis Hester;William Smith **(406) 731-6239;(406) 731-7128** **candace.ellsworth@us.af.mil;william.smith@us.af.mil**

Owner/Operator: 341 CES CEANQ (406) 731-6188

Candace Ellsworth, UST Class A Operator	candace.ellsworth@us.af.mil
Candace Ellsworth, UST Class A Operator	candace.ellsworth@us.af.mil
Candace Ellsworth, UST Class B Global Operator	candace.ellsworth@us.af.mil
Candace Ellsworth, UST Class B Global Operator	candace.ellsworth@us.af.mil
Curtis Hester, UST Class A Operator	
Curtis Hester, UST Class A Operator	
Curtis Hester, UST Class B Global Operator	
Curtis Hester, UST Class B Global Operator	
William Smith, UST Class A Operator	william.smith@us.af.mil
William Smith, UST Class A Operator	william.smith@us.af.mil
William Smith, UST Class B Global Operator	william.smith@us.af.mil
William Smith, UST Class B Global Operator	william.smith@us.af.mil

Tank Number	05	**Tank Age**	10	**Tank Installed Date**	09/07/2015	**Tank Material Construction**	Steel Clad	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	5591	**Spill Test Date**	03/31/2023	**Piping Installed Date**	09/07/2015	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	03/31/2023	**Catastrophic L.D. Type 3.0**	Auto Dialer	**Piping Type**	U.S. Suction	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	05/22/2022	**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	12/12/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**		**Energy Act**	Yes
		Overfill Test Date	12/12/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC;Gilbarco-Veeder Root/TLS-450PLUS				

Facility Summary in Fergus County in the City of Denton

Location: MALMSTROM AFB D 10
Bear Springs Road
Denton, MT 59430 Fergus

System Facility ID:14-09017

Facility Code: 20318
Last Inspected On: 06/06/2024
Operating Permit Renewal Date: 10/07/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: 341 CES CEANQ **(406) 731-6188**

Operator Contact: Candace Ellsworth;Curtis Hester;William Smith **(406) 731-6239;(406) 731-7128** **candace.ellsworth@us.af.mil;william.smith@us.af.mil**

Owner/Operator: 341 CES CEANQ (406) 731-6188

Candace Ellsworth, UST Class A Operator	candace.ellsworth@us.af.mil
Candace Ellsworth, UST Class B Global Operator	candace.ellsworth@us.af.mil
Curtis Hester, UST Class A Operator	
Curtis Hester, UST Class B Global Operator	
William Smith, UST Class A Operator	william.smith@us.af.mil
William Smith, UST Class B Global Operator	william.smith@us.af.mil

Tank Number	02	**Tank Age**	33	**Tank Installed Date**	08/01/1992	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	173	**Spill Test Date**	03/29/2023	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	03/29/2023	**Catastrophic L.D. Type 3.0**	Auto Dialer	**Piping Type**	U.S. Suction	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	03/29/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	03/29/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Fergus County in the City of Denton

Location: MALMSTROM AFB D 11
Bear Springs Road
Denton, MT 59430 Fergus

System Facility ID:14-09018

Facility Code: 20319
Last Inspected On: 06/05/2024
Operating Permit Renewal Date: 09/15/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: 341 CES CEANQ **(406) 731-6188**

Operator Contact: Candace Ellsworth;Curtis Hester;William Smith **(406) 731-6239;(406) 731-7128** **candace.ellsworth@us.af.mil;william.smith@us.af.mil**

Owner/Operator: 341 CES CEANQ (406) 731-6188

Candace Ellsworth, UST Class A Operator	candace.ellsworth@us.af.mil
Candace Ellsworth, UST Class B Global Operator	candace.ellsworth@us.af.mil
Curtis Hester, UST Class A Operator	
Curtis Hester, UST Class B Global Operator	
William Smith, UST Class A Operator	william.smith@us.af.mil
William Smith, UST Class B Global Operator	william.smith@us.af.mil

Tank Number	02	**Tank Age**	33	**Tank Installed Date**	08/01/1992	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	174	**Spill Test Date**	03/29/2023	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	03/29/2023	**Catastrophic L.D. Type 3.0**	Auto Dialer	**Piping Type**	U.S. Suction	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	03/29/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	03/29/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Fergus County in the City of Denton

Location: MALMSTROM AFB D 2
Bear Springs Road
Denton, MT 59430 Fergus

System Facility ID:14-09009

Facility Code: 20311
Last Inspected On: 06/05/2024
Operating Permit Renewal Date: 10/07/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: 341 CES CEANQ **(406) 731-6188**

Operator Contact: Candace Ellsworth;Curtis Hester;William Smith **(406) 731-6239;(406) 731-7128** **candace.ellsworth@us.af.mil;william.smith@us.af.mil**

Owner/Operator: 341 CES CEANQ (406) 731-6188

Candace Ellsworth, UST Class A Operator	candace.ellsworth@us.af.mil
Candace Ellsworth, UST Class B Global Operator	candace.ellsworth@us.af.mil
Curtis Hester, UST Class A Operator	
Curtis Hester, UST Class B Global Operator	
William Smith, UST Class A Operator	william.smith@us.af.mil
William Smith, UST Class B Global Operator	william.smith@us.af.mil

Tank Number	02	**Tank Age**	33	**Tank Installed Date**	08/01/1992	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	166	**Spill Test Date**	03/29/2023	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	03/29/2023	**Catastrophic L.D. Type 3.0**	Auto Dialer	**Piping Type**	U.S. Suction	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	03/29/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	03/29/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Fergus County in the City of Denton

Location: MALMSTROM AFB D 3
Bear Springs Road
Denton, MT 59430 Fergus

System Facility ID:14-09010

Facility Code: 20312
Last Inspected On: 06/05/2024
Operating Permit Renewal Date: 09/15/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: 341 CES CEANQ **(406) 731-6188**

Operator Contact: Candace Ellsworth;Curtis Hester;William Smith **(406) 731-6239;(406) 731-7128** **candace.ellsworth@us.af.mil;william.smith@us.af.mil**

Owner/Operator: 341 CES CEANQ (406) 731-6188

Candace Ellsworth, UST Class A Operator	candace.ellsworth@us.af.mil
Candace Ellsworth, UST Class B Global Operator	candace.ellsworth@us.af.mil
Curtis Hester, UST Class A Operator	
Curtis Hester, UST Class B Global Operator	
William Smith, UST Class A Operator	william.smith@us.af.mil
William Smith, UST Class B Global Operator	william.smith@us.af.mil

Tank Number	02	**Tank Age**	36	**Tank Installed Date**	06/21/1989	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	167	**Spill Test Date**	03/29/2023	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	03/29/2023	**Catastrophic L.D. Type 3.0**	Auto Dialer	**Piping Type**	U.S. Suction	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	03/29/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	03/29/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Fergus County in the City of Denton

Location: MALMSTROM AFB D 4
Bear Springs Road
Denton, MT 59430 Fergus

System Facility ID:14-10841

Facility Code: 20389
Last Inspected On: 06/05/2024
Operating Permit Renewal Date: 05/25/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: 341 CES CEANQ **(406) 731-6188**

Operator Contact: Candace Ellsworth;Curtis Hester;William Smith **(406) 731-6239;(406) 731-7128** **candace.ellsworth@us.af.mil;william.smith@us.af.mil**

Owner/Operator: 341 CES CEANQ (406) 731-6188

Candace Ellsworth, UST Class A Operator	candace.ellsworth@us.af.mil
Candace Ellsworth, UST Class A Operator	candace.ellsworth@us.af.mil
Candace Ellsworth, UST Class B Global Operator	candace.ellsworth@us.af.mil
Candace Ellsworth, UST Class B Global Operator	candace.ellsworth@us.af.mil
Curtis Hester, UST Class A Operator	
Curtis Hester, UST Class A Operator	
Curtis Hester, UST Class B Global Operator	
Curtis Hester, UST Class B Global Operator	
William Smith, UST Class A Operator	william.smith@us.af.mil
William Smith, UST Class A Operator	william.smith@us.af.mil
William Smith, UST Class B Global Operator	william.smith@us.af.mil
William Smith, UST Class B Global Operator	william.smith@us.af.mil

Tank Number	03	**Tank Age**	11	**Tank Installed Date**	10/01/2014	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	5544	**Spill Test Date**	01/30/2023	**Piping Installed Date**	11/03/2014	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	01/30/2023	**Catastrophic L.D. Type 3.0**	Auto Dialer	**Piping Type**	U.S. Suction	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	01/30/2023	**Line Tightness Test Date**	10/22/2014	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	Yes
		Overfill Test Date	01/30/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Fergus County in the City of Denton

Location: MALMSTROM AFB D 5
Bear Springs Road
Denton, MT 59430 Fergus

System Facility ID:14-09012

Facility Code: 20313
Last Inspected On: 06/05/2024
Operating Permit Renewal Date: 09/15/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: 341 CES CEANQ **(406) 731-6188**

Operator Contact: Candace Ellsworth;Curtis Hester;William Smith **(406) 731-6239;(406) 731-7128** **candace.ellsworth@us.af.mil;william.smith@us.af.mil**

Owner/Operator: 341 CES CEANQ (406) 731-6188

Candace Ellsworth, UST Class A Operator	candace.ellsworth@us.af.mil
Candace Ellsworth, UST Class B Global Operator	candace.ellsworth@us.af.mil
Curtis Hester, UST Class A Operator	
Curtis Hester, UST Class B Global Operator	
William Smith, UST Class A Operator	william.smith@us.af.mil
William Smith, UST Class B Global Operator	william.smith@us.af.mil

Tank Number	02	**Tank Age**	33	**Tank Installed Date**	08/01/1992	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	168	**Spill Test Date**	03/28/2023	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	03/28/2023	**Catastrophic L.D. Type 3.0**	Auto Dialer	**Piping Type**	U.S. Suction	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	03/28/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	03/28/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Fergus County in the City of Denton

Location: MALMSTROM AFB D 6
Bear Springs Road
Denton, MT 59430 Fergus

System Facility ID:14-09013

Facility Code: 20314
Last Inspected On: 06/06/2024
Operating Permit Renewal Date: 10/07/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: 341 CES CEANQ **(406) 731-6188**

Operator Contact: Candace Ellsworth;Curtis Hester;William Smith **(406) 731-6239;(406) 731-7128** **candace.ellsworth@us.af.mil;william.smith@us.af.mil**

Owner/Operator: 341 CES CEANQ (406) 731-6188

Candace Ellsworth, UST Class A Operator	candace.ellsworth@us.af.mil
Candace Ellsworth, UST Class B Global Operator	candace.ellsworth@us.af.mil
Curtis Hester, UST Class A Operator	
Curtis Hester, UST Class B Global Operator	
William Smith, UST Class A Operator	william.smith@us.af.mil
William Smith, UST Class B Global Operator	william.smith@us.af.mil

Tank Number	02	**Tank Age**	33	**Tank Installed Date**	08/01/1992	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	169	**Spill Test Date**	03/30/2023	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	03/30/2023	**Catastrophic L.D. Type 3.0**	Auto Dialer	**Piping Type**	U.S. Suction	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	03/30/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	03/30/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Fergus County in the City of Denton

Location: MALMSTROM AFB D 7
Bear Springs Road
Denton, MT 59430 Fergus

System Facility ID:14-09014

Facility Code: 20315
Last Inspected On: 06/06/2024
Operating Permit Renewal Date: 10/07/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: 341 CES CEANQ **(406) 731-6188**

Operator Contact: Candace Ellsworth;Curtis Hester;William Smith **(406) 731-6239;(406) 731-7128** **candace.ellsworth@us.af.mil;william.smith@us.af.mil**

Owner/Operator: 341 CES CEANQ (406) 731-6188

Candace Ellsworth, UST Class A Operator	candace.ellsworth@us.af.mil
Candace Ellsworth, UST Class B Global Operator	candace.ellsworth@us.af.mil
Curtis Hester, UST Class A Operator	
Curtis Hester, UST Class B Global Operator	
William Smith, UST Class A Operator	william.smith@us.af.mil
William Smith, UST Class B Global Operator	william.smith@us.af.mil

Tank Number	02	**Tank Age**	36	**Tank Installed Date**	06/21/1989	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	170	**Spill Test Date**	03/30/2023	**Piping Installed Date**	08/12/2020	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	03/30/2023	**Catastrophic L.D. Type 3.0**	Auto Dialer	**Piping Type**	U.S. Suction	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	03/30/2023	**Line Tightness Test Date**	08/12/2020	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	03/30/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Fergus County in the City of Denton

Location: MALMSTROM AFB D 8
Bear Springs Road
Denton, MT 59430 Fergus

System Facility ID:14-09015

Facility Code: 20316
Last Inspected On: 06/06/2024
Operating Permit Renewal Date: 10/07/2023

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: 341 CES CEANQ **(406) 731-6188**

Operator Contact: Candace Ellsworth;Curtis Hester;William Smith **(406) 731-6239;(406) 731-7128** **candace.ellsworth@us.af.mil;william.smith@us.af.mil**

Owner/Operator: 341 CES CEANQ (406) 731-6188

Candace Ellsworth, UST Class A Operator	candace.ellsworth@us.af.mil
Candace Ellsworth, UST Class B Global Operator	candace.ellsworth@us.af.mil
Curtis Hester, UST Class A Operator	
Curtis Hester, UST Class B Global Operator	
William Smith, UST Class A Operator	william.smith@us.af.mil
William Smith, UST Class B Global Operator	william.smith@us.af.mil

Tank Number	02	**Tank Age**	33	**Tank Installed Date**	08/12/1992	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	171	**Spill Test Date**	03/30/2023	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	03/30/2023	**Catastrophic L.D. Type 3.0**	Auto Dialer	**Piping Type**	U.S. Suction	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	03/30/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	03/30/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Fergus County in the City of Denton

Location: MALMSTROM AFB D 9
Bear Springs Road
Denton, MT 59430 Fergus

System Facility ID:14-09016

Facility Code: 20317
Last Inspected On: 06/13/2024
Operating Permit Renewal Date: 10/07/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: 341 CES CEANQ **(406) 731-6188**

Operator Contact: Candace Ellsworth;Curtis Hester;William Smith **(406) 731-6239;(406) 731-7128** **candace.ellsworth@us.af.mil;william.smith@us.af.mil**

Owner/Operator: 341 CES CEANQ (406) 731-6188

Candace Ellsworth, UST Class A Operator	candace.ellsworth@us.af.mil
Candace Ellsworth, UST Class B Global Operator	candace.ellsworth@us.af.mil
Curtis Hester, UST Class A Operator	
Curtis Hester, UST Class B Global Operator	
William Smith, UST Class A Operator	william.smith@us.af.mil
William Smith, UST Class B Global Operator	william.smith@us.af.mil

Tank Number	02	**Tank Age**	33	**Tank Installed Date**	08/01/1992	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	172	**Spill Test Date**	03/29/2023	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	03/29/2023	**Catastrophic L.D. Type 3.0**	Auto Dialer	**Piping Type**	U.S. Suction	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	03/29/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	03/29/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Fergus County in the City of Denton

Location: WOODHALL DISTRIBUTING DENTON CARDTROL
603 Broadway Ave
Denton, MT 59430-9405 Fergus

System Facility ID:14-06219

Facility Code: 20207
Last Inspected On: 03/29/2023
Operating Permit Renewal Date: 08/22/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: WOODHALL DISTRIBUTING LLC **woodhalldist@itstriangle.com**

Operator Contact: Greg Econom **(406) 567-2266** **woodhalldist2@itstriangle.com**

Owner/Operator: WOODHALL DISTRIBUTING LLC woodhalldist@itstriangle.com

Greg Econom, UST Class A Operator woodhalldist2@itstriangle.com
Greg Econom, UST Class A Operator woodhalldist2@itstriangle.com
Greg Econom, UST Class B Operator woodhalldist2@itstriangle.com
Greg Econom, UST Class B Operator woodhalldist2@itstriangle.com

Tank Number	10	**Tank Age**	28	**Tank Installed Date**	07/01/1997	**Tank Material Construction**	Steel Clad	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	4253	**Spill Test Date**	03/29/2026	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	04/19/2011	**Primary Tank Leak Detection**	Manual Interstitial Monitoring	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	2000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	03/29/2023			**ATG Type**					
Tank Number	11	**Tank Age**	28	**Tank Installed Date**	07/01/1997	**Tank Material Construction**	Steel Clad	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	4254	**Spill Test Date**	03/29/2023	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	04/19/2011	**Primary Tank Leak Detection**	Manual Interstitial Monitoring	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	2000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	03/29/2023			**ATG Type**					
Tank Number	12	**Tank Age**	28	**Tank Installed Date**	07/01/1997	**Tank Material Construction**	Steel Clad	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve

Tag Number	4255	**Spill Test Date**	03/29/2023	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	04/19/2011	**Primary Tank Leak Detection**	Manual Interstitial Monitoring	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	2000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	03/29/2023			**ATG Type**					

Facility Summary in Fergus County in the City of Denton

Location: WOODHALL DISTRIBUTING DENTON CHS
609 Broadway Ave
Denton, MT 59430-9405 Fergus

System Facility ID:14-01360

Facility Code: 20063
Last Inspected On: 09/04/2024
Operating Permit Renewal Date: 09/04/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	WOODHALL DISTRIBUTING LLC		**woodhalldist@itstriangle.com**
Operator Contact:	Greg Econom	**(406) 567-2266**	**woodhalldist2@itstriangle.com**

Owner/Operator: WOODHALL DISTRIBUTING LLC woodhalldist@itstriangle.com

Greg Econom, UST Class A Operator woodhalldist2@itstriangle.com
Greg Econom, UST Class A Operator woodhalldist2@itstriangle.com
Greg Econom, UST Class B Operator woodhalldist2@itstriangle.com
Greg Econom, UST Class B Operator woodhalldist2@itstriangle.com

Tank Number	01	**Tank Age**	35	**Tank Installed Date**	01/19/1990	**Tank Material Construction**	Steel Clad	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	903	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Temporarily Out of Use**	**MLLD Test Date**	09/13/2016	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	2000	**ATG Test Date**		**Line Tightness Test Date**	09/13/2016	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**	Veeder Root/TLS-250				
Tank Number	02	**Tank Age**	35	**Tank Installed Date**	01/19/1990	**Tank Material Construction**	Steel Clad	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	904	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Temporarily Out of Use**	**MLLD Test Date**	09/13/2016	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	2000	**ATG Test Date**		**Line Tightness Test Date**	09/13/2016	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**	Veeder Root/TLS-250				

Tank Number	03	**Tank Age**	35	**Tank Installed Date**	01/19/1990	**Tank Material Construction**	Steel Clad	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	905	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Temporarily Out of Use**	**MLLD Test Date**	09/13/2016	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	2000	**ATG Test Date**		**Line Tightness Test Date**	09/13/2016	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**	Veeder Root/TLS-250				

Facility Summary in Fergus County in the City of Forest Grove

Location: MALMSTROM AFB N 4
Road 238
Forest Grove, MT 59441 Fergus

System Facility ID:14-09121

Facility Code: 20346
Last Inspected On: 04/04/2025
Operating Permit Renewal Date: 08/14/2025

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: 341 CES CEANQ **(406) 731-6188**

Operator Contact: Candace Ellsworth;Curtis Hester;William Smith **(406) 731-6239;(406) 731-7128** **candace.ellsworth@us.af.mil;william.smith@us.af.mil**

Owner/Operator: 341 CES CEANQ (406) 731-6188

Candace Ellsworth, UST Class A Operator	candace.ellsworth@us.af.mil
Candace Ellsworth, UST Class B Global Operator	candace.ellsworth@us.af.mil
Curtis Hester, UST Class A Operator	
Curtis Hester, UST Class B Global Operator	
William Smith, UST Class A Operator	william.smith@us.af.mil
William Smith, UST Class B Global Operator	william.smith@us.af.mil

Tank Number	02	**Tank Age**	32	**Tank Installed Date**	08/01/1993	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	201	**Spill Test Date**	04/05/2022	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	04/05/2022	**Catastrophic L.D. Type 3.0**	Auto Dialer	**Piping Type**	U.S. Suction	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	04/05/2022	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	04/05/2022			**ATG Type**					

Facility Summary in Fergus County in the City of Forest Grove

Location: MALMSTROM AFB N 5
Road 238
Forest Grove, MT 59441 Fergus

System Facility ID:14-09122

Facility Code: 20347
Last Inspected On: 04/07/2025
Operating Permit Renewal Date: 08/14/2025

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: 341 CES CEANQ **(406) 731-6188**

Operator Contact: Candace Ellsworth;Curtis Hester;William Smith **(406) 731-6239;(406) 731-7128** **candace.ellsworth@us.af.mil;william.smith@us.af.mil**

Owner/Operator: 341 CES CEANQ (406) 731-6188

Candace Ellsworth, UST Class A Operator	candace.ellsworth@us.af.mil
Candace Ellsworth, UST Class B Global Operator	candace.ellsworth@us.af.mil
Curtis Hester, UST Class A Operator	
Curtis Hester, UST Class B Global Operator	
William Smith, UST Class A Operator	william.smith@us.af.mil
William Smith, UST Class B Global Operator	william.smith@us.af.mil

Tank Number	02	**Tank Age**	32	**Tank Installed Date**	08/01/1993	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	202	**Spill Test Date**	04/06/2022	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	04/06/2022	**Catastrophic L.D. Type 3.0**	Auto Dialer	**Piping Type**	U.S. Suction	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	04/06/2022	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	04/06/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Fergus County in the City of Forest Grove

Location: MALMSTROM AFB N 6
Road 238
Forest Grove, MT 59441 Fergus

System Facility ID:14-09123

Facility Code: 20348
Last Inspected On: 04/07/2025
Operating Permit Renewal Date: 08/14/2025

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: 341 CES CEANQ **(406) 731-6188**

Operator Contact: Candace Ellsworth;Curtis Hester;William Smith **(406) 731-6239;(406) 731-7128** **candace.ellsworth@us.af.mil;william.smith@us.af.mil**

Owner/Operator: 341 CES CEANQ (406) 731-6188

Candace Ellsworth, UST Class A Operator	candace.ellsworth@us.af.mil
Candace Ellsworth, UST Class B Global Operator	candace.ellsworth@us.af.mil
Curtis Hester, UST Class A Operator	
Curtis Hester, UST Class B Global Operator	
William Smith, UST Class A Operator	william.smith@us.af.mil
William Smith, UST Class B Global Operator	william.smith@us.af.mil

Tank Number	02	**Tank Age**	32	**Tank Installed Date**	08/13/1993	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	203	**Spill Test Date**	04/06/2022	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	04/06/2022	**Catastrophic L.D. Type 3.0**	Auto Dialer	**Piping Type**	U.S. Suction	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	04/06/2022	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	04/06/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Fergus County in the City of Garneill

Location: MALMSTROM AFB L 10
US Hwy 191
Garneill, MT 59453 Fergus

System Facility ID:14-09105

Facility Code: 20333
Last Inspected On: 03/27/2025
Operating Permit Renewal Date: 07/31/2028

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	341 CES CEANQ	**(406) 731-6188**	
Operator Contact:	Candace Ellsworth;Curtis Hester;William Smith	**(406) 731-6239;(406) 731-7128**	**candace.ellsworth@us.af.mil;william.smith@us.af.mil**

Owner/Operator: 341 CES CEANQ (406) 731-6188

Candace Ellsworth, UST Class A Operator	candace.ellsworth@us.af.mil
Candace Ellsworth, UST Class B Global Operator	candace.ellsworth@us.af.mil
Curtis Hester, UST Class A Operator	
Curtis Hester, UST Class B Global Operator	
William Smith, UST Class A Operator	william.smith@us.af.mil
William Smith, UST Class B Global Operator	william.smith@us.af.mil

Tank Number	02	**Tank Age**	32	**Tank Installed Date**	05/01/1993	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	188	**Spill Test Date**	03/27/2025	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	03/27/2025	**Catastrophic L.D. Type 3.0**	Auto Dialer	**Piping Type**	U.S. Suction	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	03/27/2025	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	03/27/2025			**ATG Type**	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Fergus County in the City of Grass Range

Location: LITTLE MONTANA TRUCK STOP
530 US Hwy 87 S
Grass Range, MT 59032 Fergus

System Facility ID:14-06338

Facility Code: 20208
Last Inspected On: 05/13/2022
Operating Permit Renewal Date: 09/06/2025

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Gary Smith;GS Oil Inc Roy;GS Oil Inc Roy	**(406) 464-2221;(406) 873-5526;(406) 464-2221**	**gsoil@midrivers.com;gsoil@midrivers.com;gsoil@midrivers.com**
Operator Contact:	Jolene Smith;GS Oil Inc Roy	**(406) 464-2391;(406) 464-2221**	**gsoil@midrivers.com;gsoil@midrivers.com**

Owner/Operator:	Gary Smith,GS Oil Inc Roy	(406) 873-5526	gsoil@midrivers.com
Owner/Operator:	GS Oil Inc Roy	(406) 873-5526	gsoil@midrivers.com
	Jolene Smith, UST Class A Operator		gsoil@midrivers.com
	PJ Klakken, UST Class B Operator		littleMTtruckstop@gmail.com

Tank Number	05	**Tank Age**	27	**Tank Installed Date**	09/01/1998	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	1138	**Spill Test Date**	05/13/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**	05/13/2022	**Tank/Piping CP Test Date**	05/13/2022	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	05/13/2022	**Line Tightness Test Date**	12/08/2021	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	05/13/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	06	**Tank Age**	27	**Tank Installed Date**	09/01/1998	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	1139	**Spill Test Date**	05/13/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**	05/13/2022	**Tank/Piping CP Test Date**	05/13/2022	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	05/13/2022	**Line Tightness Test Date**	12/06/2021	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	05/13/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Tank Number	07	**Tank Age**	27	**Tank Installed Date**	09/01/1998	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	1140	**Spill Test Date**	05/13/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**	05/13/2022	**Tank/Piping CP Test Date**	05/13/2022	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	05/13/2022	**Line Tightness Test Date**	12/06/2021	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	05/13/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	08	**Tank Age**	27	**Tank Installed Date**	09/01/1998	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	1141	**Spill Test Date**	05/13/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**	05/13/2022	**Tank/Piping CP Test Date**	05/13/2022	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**	05/13/2022	**Line Tightness Test Date**	12/26/2021	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	05/13/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	09	**Tank Age**	27	**Tank Installed Date**	09/01/1998	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	1142	**Spill Test Date**	05/13/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Diesel, Dyed	**PLLD Test Date**	05/13/2022	**Tank/Piping CP Test Date**	05/13/2022	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	05/13/2022	**Line Tightness Test Date**	12/26/2021	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	05/13/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Fergus County in the City of Grass Range

Location: MALMSTROM AFB N 1
US Hwy 87
Grass Range, MT 59032 Fergus

System Facility ID:14-09118

Facility Code: 20343
Last Inspected On: 04/04/2025
Operating Permit Renewal Date: 08/14/2025

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: 341 CES CEANQ **(406) 731-6188**

Operator Contact: Candace Ellsworth;Curtis Hester;William Smith **(406) 731-6239;(406) 731-7128** **candace.ellsworth@us.af.mil;william.smith@us.af.mil**

Owner/Operator: 341 CES CEANQ (406) 731-6188

Candace Ellsworth, UST Class A Operator	candace.ellsworth@us.af.mil
Candace Ellsworth, UST Class B Global Operator	candace.ellsworth@us.af.mil
Curtis Hester, UST Class A Operator	
Curtis Hester, UST Class B Global Operator	
William Smith, UST Class A Operator	william.smith@us.af.mil
William Smith, UST Class B Global Operator	william.smith@us.af.mil

Tank Number	01	**Tank Age**	63	**Tank Installed Date**	06/02/1962	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	198	**Spill Test Date**	04/06/2022	**Piping Installed Date**		**Tank Construction**	Lined Interior/Impressed Current	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	04/06/2022	**Catastrophic L.D. Type 3.0**	Auto Dialer	**Piping Type**	U.S. Suction	**CP Met Types**	Impressed Current
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	06/14/2021	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	11/13/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	11/13/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				

Facility Summary in Fergus County in the City of Grass Range

Location: MALMSTROM AFB N 2
US Hwy 87
Grass Range, MT 59032 Fergus

System Facility ID:14-09119

Facility Code: 20344
Last Inspected On: 04/04/2025
Operating Permit Renewal Date: 08/14/2025

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: 341 CES CEANQ **(406) 731-6188**

Operator Contact: Candace Ellsworth;Curtis Hester;William Smith **(406) 731-6239;(406) 731-7128** **candace.ellsworth@us.af.mil;william.smith@us.af.mil**

Owner/Operator: 341 CES CEANQ (406) 731-6188

Candace Ellsworth, UST Class A Operator	candace.ellsworth@us.af.mil
Candace Ellsworth, UST Class B Global Operator	candace.ellsworth@us.af.mil
Curtis Hester, UST Class A Operator	
Curtis Hester, UST Class B Global Operator	
William Smith, UST Class A Operator	william.smith@us.af.mil
William Smith, UST Class B Global Operator	william.smith@us.af.mil

Tank Number	02	**Tank Age**	32	**Tank Installed Date**	07/01/1993	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	199	**Spill Test Date**	04/07/2022	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	04/07/2022	**Catastrophic L.D. Type 3.0**	Auto Dialer	**Piping Type**	U.S. Suction	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	04/07/2022	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	04/07/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Fergus County in the City of Grass Range

Location: MALMSTROM AFB N 3
MT Hwy 19
Grass Range, MT 59032 Fergus

System Facility ID:14-09120

Facility Code: 20345
Last Inspected On: 04/03/2025
Operating Permit Renewal Date: 08/14/2025

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: 341 CES CEANQ **(406) 731-6188**

Operator Contact: Candace Ellsworth;Curtis Hester;William Smith **(406) 731-6239;(406) 731-7128** **candace.ellsworth@us.af.mil;william.smith@us.af.mil**

Owner/Operator: 341 CES CEANQ (406) 731-6188

Candace Ellsworth, UST Class A Operator	candace.ellsworth@us.af.mil
Candace Ellsworth, UST Class B Global Operator	candace.ellsworth@us.af.mil
Curtis Hester, UST Class A Operator	
Curtis Hester, UST Class B Global Operator	
William Smith, UST Class A Operator	william.smith@us.af.mil
William Smith, UST Class B Global Operator	william.smith@us.af.mil

Tank Number	02	**Tank Age**	35	**Tank Installed Date**	03/26/1990	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	200	**Spill Test Date**	04/07/2022	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	04/07/2022	**Catastrophic L.D. Type 3.0**	Auto Dialer	**Piping Type**	U.S. Suction	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	04/07/2022	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	04/07/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Fergus County in the City of Grass Range

Location: THE OLE' MERCANTILE
44151 US Hwy 87 S
Grass Range, MT 59032 Fergus

System Facility ID:60-15338

Facility Code: 32385
Last Inspected On: 02/13/2023
Operating Permit Renewal Date: 06/03/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Ezzies Wholesale Inc **bill@ezzies.com**

Operator Contact: Conor Moran;Ezzies Wholesale Inc **conor@ezzies.com;bill@ezzies.com**

Owner/Operator: Ezzies Wholesale Inc bill@ezzies.com

Conor Moran, UST Class A Operator bill@ezzies.com

Debra Degner, UST Class B Global Operator theolemercantile@gmail.com

Tank Number	01	**Tank Age**	6	**Tank Installed Date**	11/19/2019	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	5934	**Spill Test Date**	10/03/2022	**Piping Installed Date**	09/02/2019	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	10/03/2022	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	Yes
Capacity	10000	**ATG Test Date**	10/03/2022	**Line Tightness Test Date**	02/06/2023	**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	10/03/2022			**ATG Type**					
Tank Number	02	**Tank Age**	6	**Tank Installed Date**	11/19/2019	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	5935	**Spill Test Date**	10/03/2022	**Piping Installed Date**	09/02/2019	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	10/03/2022	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel, Dyed	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	Yes
Capacity	10000	**ATG Test Date**	10/03/2022	**Line Tightness Test Date**	02/07/2023	**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	10/03/2022			**ATG Type**					
Tank Number	03	**Tank Age**	6	**Tank Installed Date**	11/19/2019	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm

Tag Number	5936	**Spill Test Date**	10/03/2022	**Piping Installed Date**	09/02/2019	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	10/03/2022	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	10/03/2022	**Line Tightness Test Date**	02/07/2023	**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	10/03/2022			**ATG Type**					
Tank Number	04	**Tank Age**	6	**Tank Installed Date**	11/19/2019	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	5937	**Spill Test Date**	10/03/2022	**Piping Installed Date**	09/02/2019	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	10/03/2022	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	7000	**ATG Test Date**	10/03/2022	**Line Tightness Test Date**	02/08/2023	**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	10/03/2022			**ATG Type**					

Facility Summary in Fergus County in the City of Hilger

Location: MALMSTROM AFB E 6
County Road 236
Hilger, MT 59451 Fergus

System Facility ID:14-09024

Facility Code: 20325
Last Inspected On: 04/03/2023
Operating Permit Renewal Date: 09/15/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: 341 CES CEANQ **(406) 731-6188**

Operator Contact: Candace Ellsworth;Curtis Hester;William Smith **(406) 731-6239;(406) 731-7128** **candace.ellsworth@us.af.mil;william.smith@us.af.mil**

Owner/Operator: 341 CES CEANQ (406) 731-6188

Candace Ellsworth, UST Class A Operator	candace.ellsworth@us.af.mil
Candace Ellsworth, UST Class B Global Operator	candace.ellsworth@us.af.mil
Curtis Hester, UST Class A Operator	
Curtis Hester, UST Class B Global Operator	
William Smith, UST Class A Operator	william.smith@us.af.mil
William Smith, UST Class B Global Operator	william.smith@us.af.mil

Tank Number	02	**Tank Age**	33	**Tank Installed Date**	07/01/1992	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	180	**Spill Test Date**	03/28/2023	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	03/28/2023	**Catastrophic L.D. Type 3.0**	Auto Dialer	**Piping Type**	U.S. Suction	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	03/28/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	03/28/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Fergus County in the City of Hilger

Location: MALMSTROM AFB E 7
County Road 236
Hilger, MT 59451 Fergus

System Facility ID:14-09025

Facility Code: 20326
Last Inspected On: 06/04/2024
Operating Permit Renewal Date: 09/15/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: 341 CES CEANQ **(406) 731-6188**

Operator Contact: Candace Ellsworth;Curtis Hester;William Smith **(406) 731-6239;(406) 731-7128** **candace.ellsworth@us.af.mil;william.smith@us.af.mil**

Owner/Operator: 341 CES CEANQ (406) 731-6188

Candace Ellsworth, UST Class A Operator	candace.ellsworth@us.af.mil
Candace Ellsworth, UST Class B Global Operator	candace.ellsworth@us.af.mil
Curtis Hester, UST Class A Operator	
Curtis Hester, UST Class B Global Operator	
William Smith, UST Class A Operator	william.smith@us.af.mil
William Smith, UST Class B Global Operator	william.smith@us.af.mil

Tank Number	02	**Tank Age**	36	**Tank Installed Date**	08/01/1989	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	181	**Spill Test Date**	03/28/2023	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	03/28/2023	**Catastrophic L.D. Type 3.0**	Auto Dialer	**Piping Type**	U.S. Suction	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	03/28/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	09/28/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Fergus County in the City of Hilger

Location: MALMSTROM AFB E 8
MT Hwy 81
Hilger, MT 59451 Fergus

System Facility ID:14-09026

Facility Code: 20327
Last Inspected On: 06/04/2024
Operating Permit Renewal Date: 10/07/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: 341 CES CEANQ **(406) 731-6188**

Operator Contact: Candace Ellsworth;Curtis Hester;William Smith **(406) 731-6239;(406) 731-7128** **candace.ellsworth@us.af.mil;william.smith@us.af.mil**

Owner/Operator: 341 CES CEANQ (406) 731-6188

Candace Ellsworth, UST Class A Operator	candace.ellsworth@us.af.mil
Candace Ellsworth, UST Class B Global Operator	candace.ellsworth@us.af.mil
Curtis Hester, UST Class A Operator	
Curtis Hester, UST Class B Global Operator	
William Smith, UST Class A Operator	william.smith@us.af.mil
William Smith, UST Class B Global Operator	william.smith@us.af.mil

Tank Number	03	**Tank Age**	12	**Tank Installed Date**	12/01/2013	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	5465	**Spill Test Date**	03/28/2023	**Piping Installed Date**	11/25/2013	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	03/28/2023	**Catastrophic L.D. Type 3.0**	Auto Dialer	**Piping Type**	U.S. Suction	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	03/28/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	Yes
		Overfill Test Date	03/28/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Fergus County in the City of Hilger

Location: MALMSTROM AFB E 9
County Road 236
Hilger, MT 59451 Fergus

System Facility ID:14-09027

Facility Code: 20328
Last Inspected On: 06/04/2024
Operating Permit Renewal Date: 09/15/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: 341 CES CEANQ **(406) 731-6188**

Operator Contact: Candace Ellsworth;Curtis Hester;William Smith **(406) 731-6239;(406) 731-7128** **candace.ellsworth@us.af.mil;william.smith@us.af.mil**

Owner/Operator: 341 CES CEANQ (406) 731-6188

Candace Ellsworth, UST Class A Operator	candace.ellsworth@us.af.mil
Candace Ellsworth, UST Class B Global Operator	candace.ellsworth@us.af.mil
Curtis Hester, UST Class A Operator	
Curtis Hester, UST Class B Global Operator	
William Smith, UST Class A Operator	william.smith@us.af.mil
William Smith, UST Class B Global Operator	william.smith@us.af.mil

Tank Number	02	**Tank Age**	33	**Tank Installed Date**	07/01/1992	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	4270	**Spill Test Date**	03/28/2023	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	03/28/2023	**Catastrophic L.D. Type 3.0**	Auto Dialer	**Piping Type**	U.S. Suction	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	03/28/2023	**Line Tightness Test Date**	05/01/2013	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	03/28/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Fergus County in the City of Hilger

Location: MALMSTROM AFB M 2
MT Hwy 81
Hilger, MT 59451 Fergus

System Facility ID:14-09108

Facility Code: 20336
Last Inspected On: 04/01/2025
Operating Permit Renewal Date: 07/24/2028

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: 341 CES CEANQ **(406) 731-6188**

Operator Contact: Candace Ellsworth;Curtis Hester;William Smith **(406) 731-6239;(406) 731-7128** **candace.ellsworth@us.af.mil;william.smith@us.af.mil**

Owner/Operator: 341 CES CEANQ (406) 731-6188

Candace Ellsworth, UST Class A Operator	candace.ellsworth@us.af.mil
Candace Ellsworth, UST Class B Global Operator	candace.ellsworth@us.af.mil
Curtis Hester, UST Class A Operator	
Curtis Hester, UST Class B Global Operator	
William Smith, UST Class A Operator	william.smith@us.af.mil
William Smith, UST Class B Global Operator	william.smith@us.af.mil

Tank Number	02	**Tank Age**	32	**Tank Installed Date**	08/01/1993	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	191	**Spill Test Date**	04/01/2025	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	04/01/2025	**Catastrophic L.D. Type 3.0**	Auto Dialer	**Piping Type**	U.S. Suction	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	04/01/2025	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	04/01/2025			**ATG Type**	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Fergus County in the City of Hilger

Location: MALMSTROM AFB M 3
US Hwy 191
Hilger, MT 59451 Fergus

System Facility ID:14-09109

Facility Code: 20337
Last Inspected On: 04/01/2025
Operating Permit Renewal Date: 07/24/2028

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: 341 CES CEANQ **(406) 731-6188**

Operator Contact: Candace Ellsworth;Curtis Hester;William Smith **(406) 731-6239;(406) 731-7128** **candace.ellsworth@us.af.mil;william.smith@us.af.mil**

Owner/Operator: 341 CES CEANQ (406) 731-6188

Candace Ellsworth, UST Class A Operator	candace.ellsworth@us.af.mil
Candace Ellsworth, UST Class B Global Operator	candace.ellsworth@us.af.mil
Curtis Hester, UST Class A Operator	
Curtis Hester, UST Class B Global Operator	
William Smith, UST Class A Operator	william.smith@us.af.mil
William Smith, UST Class B Global Operator	william.smith@us.af.mil

Tank Number	02	**Tank Age**	32	**Tank Installed Date**	08/01/1993	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	192	**Spill Test Date**	04/01/2025	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	04/01/2025	**Catastrophic L.D. Type 3.0**	Auto Dialer	**Piping Type**	U.S. Suction	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	04/01/2025	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	04/01/2025			**ATG Type**	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Fergus County in the City of Hilger

Location: MALMSTROM AFB O 8
US Hwy 191
Hilger, MT 59451 Fergus

System Facility ID:14-09136

Facility Code: 20361
Last Inspected On: 04/01/2025
Operating Permit Renewal Date: 07/31/2028

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: 341 CES CEANQ **(406) 731-6188**

Operator Contact: Candace Ellsworth;Curtis Hester;William Smith **(406) 731-6239;(406) 731-7128** **candace.ellsworth@us.af.mil;william.smith@us.af.mil**

Owner/Operator: 341 CES CEANQ (406) 731-6188

Candace Ellsworth, UST Class A Operator	candace.ellsworth@us.af.mil
Candace Ellsworth, UST Class B Global Operator	candace.ellsworth@us.af.mil
Curtis Hester, UST Class A Operator	
Curtis Hester, UST Class B Global Operator	
William Smith, UST Class A Operator	william.smith@us.af.mil
William Smith, UST Class B Global Operator	william.smith@us.af.mil

Tank Number	02	**Tank Age**	32	**Tank Installed Date**	08/01/1993	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	216	**Spill Test Date**	04/01/2025	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	04/01/2025	**Catastrophic L.D. Type 3.0**	Auto Dialer	**Piping Type**	U.S. Suction	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	04/01/2025	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	04/01/2025			**ATG Type**	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Fergus County in the City of Hilger

Location: MALMSTROM AFB O 9
US Hwy 191
Hilger, MT 59451 Fergus

System Facility ID:14-09137

Facility Code: 20362
Last Inspected On: 04/01/2025
Operating Permit Renewal Date: 07/31/2028

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	341 CES CEANQ	**(406) 731-6188**	
Operator Contact:	Candace Ellsworth;Curtis Hester;Shannon Chouinard;Malmstrom A F B;William Smith	**(406) 731-6167;(406) 731-6239;(406) 731-7128**	**candace.ellsworth@us.af.mil;shannon.chouinard@us.af.mil;william.smith@us.af.mil**

Owner/Operator: 341 CES CEANQ (406) 731-6188

Candace Ellsworth, UST Class A Operator	candace.ellsworth@us.af.mil
Candace Ellsworth, UST Class B Global Operator	candace.ellsworth@us.af.mil
Curtis Hester, UST Class A Operator	
Curtis Hester, UST Class B Global Operator	
Shannon Chouinard, UST Class A Operator	shannon.chouinard@us.af.mil
Shannon Chouinard, UST Class B Operator	shannon.chouinard@us.af.mil
William Smith, UST Class A Operator	william.smith@us.af.mil
William Smith, UST Class B Global Operator	william.smith@us.af.mil

Tank Number	02	**Tank Age**	32	**Tank Installed Date**	08/01/1993	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	217	**Spill Test Date**	04/01/2025	**Piping Installed Date**	06/06/2016	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	04/01/2025	**Catastrophic L.D. Type 3.0**	Auto Dialer	**Piping Type**	U.S. Suction	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	04/01/2025	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	04/01/2025			**ATG Type**	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Fergus County in the City of Lewistown

Location: CENTRAL MONTANA MEDICAL CENTER
408 Wendell Ave
Lewistown, MT 59457-2261 Fergus

System Facility ID:14-01228

Facility Code: 20060
Last Inspected On: 11/07/2024
Operating Permit Renewal Date: 02/09/2028

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Central Montana Medical Center **(406) 538-6231**

Operator Contact: Brad Johnson;Gary Godbey;Ronald Baumann **(406) 535-6231;(406) 538-6231** **bjohnson@cmmccares.com;grg2444@yahoo.com**

Owner/Operator: Central Montana Medical Center (406) 538-6231

Brad Johnson, UST Class A Operator	bjohnson@cmmccares.com
Eric Wichman, UST Class B Operator	eric_wichman@yahoo.com
Gary Godbey, UST Class A Operator	grg2444@yahoo.com
Mary Curnyn, UST Class B Global Operator	m_curnyn@yahoo.com
Ronald Baumann, UST Class A Operator	

Tank Number	02	**Tank Age**	29	**Tank Installed Date**	07/01/1996	**Tank Material Construction**	Steel Clad	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	607	**Spill Test Date**	10/07/2024	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	11/05/2024	**Catastrophic L.D. Type 3.0**	Auto Dialer	**Piping Type**	U.S. Suction	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	10/08/2012	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	10/07/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	10/07/2024			**ATG Type**	Veeder Root/TLS-300				

Facility Summary in Fergus County in the City of Lewistown

Location: COUNTRY CORNER
102 W Main St
Lewistown, MT 59457-1715 Fergus

System Facility ID:14-01969

Facility Code: 20088
Last Inspected On: 10/13/2023
Operating Permit Renewal Date: 02/28/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Set Five LLC **(719) 244-6886** **wjwoods10@gmail.com**

Operator Contact: Chris Rindal **chrisrindal@hotmail.com**

Owner/Operator: Set Five LLC (719) 244-6886 wjwoods10@gmail.com

Chris Rindal, UST Class A Operator chrisrindal@hotmail.com
Kelsey Kramlich, UST Class B Operator countrycorner@midrivers.com
Tina Blair, UST Class B Operator

Tank Number	04	**Tank Age**	35	**Tank Installed Date**	05/06/1990	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	1501	**Spill Test Date**	10/10/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	10/13/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**	11/30/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	12/08/2022			**ATG Type**	Veeder Root/TLS-300				
Tank Number	05	**Tank Age**	35	**Tank Installed Date**	05/06/1990	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	1502	**Spill Test Date**	10/13/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	10/13/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**	11/30/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	12/08/2022			**ATG Type**	Veeder Root/TLS-300				
Tank Number	06	**Tank Age**	35	**Tank Installed Date**	05/06/1990	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm

Tag Number	1503	**Spill Test Date**	10/13/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	10/13/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	11/30/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	12/08/2022			**ATG Type**	Veeder Root/TLS-300				

Facility Summary in Fergus County in the City of Lewistown

Location: MALMSTROM AFB M 4
Road 505
Lewistown, MT 59457 Fergus

System Facility ID:14-09110

Facility Code: 20338
Last Inspected On: 04/01/2025
Operating Permit Renewal Date: 07/24/2028

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: 341 CES CEANQ **(406) 731-6188**

Operator Contact: Candace Ellsworth;Curtis Hester;William Smith **(406) 731-6239;(406) 731-7128** **candace.ellsworth@us.af.mil;william.smith@us.af.mil**

Owner/Operator: 341 CES CEANQ (406) 731-6188

Candace Ellsworth, UST Class A Operator	candace.ellsworth@us.af.mil
Candace Ellsworth, UST Class B Global Operator	candace.ellsworth@us.af.mil
Curtis Hester, UST Class A Operator	
Curtis Hester, UST Class B Global Operator	
William Smith, UST Class A Operator	william.smith@us.af.mil
William Smith, UST Class B Global Operator	william.smith@us.af.mil

Tank Number	02	**Tank Age**	32	**Tank Installed Date**	08/11/1993	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	193	**Spill Test Date**	04/01/2025	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	04/04/2022	**Catastrophic L.D. Type 3.0**	Auto Dialer	**Piping Type**	U.S. Suction	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	04/01/2025	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	04/01/2025	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	04/01/2025			**ATG Type**	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Fergus County in the City of Lewistown

Location: MALMSTROM AFB M 5
US Hwy 87
Lewistown, MT 59457 Fergus

System Facility ID:14-09111

Facility Code: 20339
Last Inspected On: 03/31/2025
Operating Permit Renewal Date: 07/24/2028

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: 341 CES CEANQ **(406) 731-6188**

Operator Contact: Candace Ellsworth;Curtis Hester;William Smith **(406) 731-6239;(406) 731-7128** **candace.ellsworth@us.af.mil;william.smith@us.af.mil**

Owner/Operator: 341 CES CEANQ (406) 731-6188

Candace Ellsworth, UST Class A Operator	candace.ellsworth@us.af.mil
Candace Ellsworth, UST Class B Global Operator	candace.ellsworth@us.af.mil
Curtis Hester, UST Class A Operator	
Curtis Hester, UST Class B Global Operator	
William Smith, UST Class A Operator	william.smith@us.af.mil
William Smith, UST Class B Global Operator	william.smith@us.af.mil

Tank Number	02	**Tank Age**	32	**Tank Installed Date**	05/01/1993	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	194	**Spill Test Date**	03/31/2025	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	03/31/2025	**Catastrophic L.D. Type 3.0**	Auto Dialer	**Piping Type**	U.S. Suction	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	03/31/2025	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	03/31/2025			**ATG Type**	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Fergus County in the City of Lewistown

Location: MALMSTROM AFB N 10
US Hwy 87
Lewistown, MT 59457 Fergus

System Facility ID:14-09127

Facility Code: 20352
Last Inspected On: 04/04/2025
Operating Permit Renewal Date: 08/14/2025

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: 341 CES CEANQ **(406) 731-6188**

Operator Contact: Candace Ellsworth;Curtis Hester;William Smith **(406) 731-6239;(406) 731-7128** **candace.ellsworth@us.af.mil;william.smith@us.af.mil**

Owner/Operator: 341 CES CEANQ (406) 731-6188

Candace Ellsworth, UST Class A Operator	candace.ellsworth@us.af.mil
Candace Ellsworth, UST Class B Global Operator	candace.ellsworth@us.af.mil
Curtis Hester, UST Class A Operator	
Curtis Hester, UST Class B Global Operator	
William Smith, UST Class A Operator	william.smith@us.af.mil
William Smith, UST Class B Global Operator	william.smith@us.af.mil

Tank Number	02	**Tank Age**	32	**Tank Installed Date**	08/01/1993	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	207	**Spill Test Date**	04/07/2022	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	04/07/2022	**Catastrophic L.D. Type 3.0**	Auto Dialer	**Piping Type**	U.S. Suction	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	04/07/2022	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	04/07/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Fergus County in the City of Lewistown

Location: MALMSTROM AFB N 11
US Hwy 87
Lewistown, MT 59457 Fergus

System Facility ID:14-09128

Facility Code: 20353
Last Inspected On: 04/04/2025
Operating Permit Renewal Date: 08/14/2025

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: 341 CES CEANQ **(406) 731-6188**

Operator Contact: Candace Ellsworth;Curtis Hester;William Smith **(406) 731-6239;(406) 731-7128** **candace.ellsworth@us.af.mil;william.smith@us.af.mil**

Owner/Operator: 341 CES CEANQ (406) 731-6188

Candace Ellsworth, UST Class A Operator	candace.ellsworth@us.af.mil
Candace Ellsworth, UST Class B Global Operator	candace.ellsworth@us.af.mil
Curtis Hester, UST Class A Operator	
Curtis Hester, UST Class B Global Operator	
William Smith, UST Class A Operator	william.smith@us.af.mil
William Smith, UST Class B Global Operator	william.smith@us.af.mil

Tank Number	02	**Tank Age**	32	**Tank Installed Date**	08/01/1993	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	208	**Spill Test Date**	05/28/2024	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	05/28/2024	**Catastrophic L.D. Type 3.0**	Auto Dialer	**Piping Type**	U.S. Suction	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	05/28/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	05/28/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Fergus County in the City of Lewistown

Location: MALMSTROM AFB N 7
Road 238
Lewistown, MT 59457 Fergus

System Facility ID:14-09124

Facility Code: 20349
Last Inspected On: 04/07/2025
Operating Permit Renewal Date: 08/14/2025

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: 341 CES CEANQ **(406) 731-6188**

Operator Contact: Candace Ellsworth;William Smith **(406) 731-6239;(406) 731-7128** **candace.ellsworth@us.af.mil;william.smith@us.af.mil**

Owner/Operator: 341 CES CEANQ (406) 731-6188

Candace Ellsworth, UST Class A Operator	candace.ellsworth@us.af.mil
Candace Ellsworth, UST Class B Global Operator	candace.ellsworth@us.af.mil
William Smith, UST Class A Operator	william.smith@us.af.mil
William Smith, UST Class B Global Operator	william.smith@us.af.mil

Tank Number	02	**Tank Age**	32	**Tank Installed Date**	08/01/1993	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	204	**Spill Test Date**	04/06/2022	**Piping Installed Date**	05/10/2017	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	04/06/2022	**Catastrophic L.D. Type 3.0**	Auto Dialer	**Piping Type**	U.S. Suction	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	04/06/2022	**Line Tightness Test Date**	05/09/2017	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	04/06/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Fergus County in the City of Lewistown

Location: MALMSTROM AFB N 8
US Hwy 87
Lewistown, MT 59457 Fergus

System Facility ID:14-09125

Facility Code: 20350
Last Inspected On: 05/29/2024
Operating Permit Renewal Date: 08/15/2025

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: 341 CES CEANQ **(406) 731-6188**

Operator Contact: Candace Ellsworth;Curtis Hester;William Smith **(406) 731-6239;(406) 731-7128** **candace.ellsworth@us.af.mil;william.smith@us.af.mil**

Owner/Operator: 341 CES CEANQ (406) 731-6188

Candace Ellsworth, UST Class A Operator	candace.ellsworth@us.af.mil
Candace Ellsworth, UST Class B Global Operator	candace.ellsworth@us.af.mil
Curtis Hester, UST Class A Operator	
Curtis Hester, UST Class B Global Operator	
William Smith, UST Class A Operator	william.smith@us.af.mil
William Smith, UST Class B Global Operator	william.smith@us.af.mil

Tank Number	02	**Tank Age**	32	**Tank Installed Date**	07/01/1993	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	205	**Spill Test Date**	04/06/2022	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	04/06/2022	**Catastrophic L.D. Type 3.0**	Auto Dialer	**Piping Type**	U.S. Suction	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	04/06/2022	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	04/06/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Fergus County in the City of Lewistown

Location: MALMSTROM AFB N 9
US Hwy 87
Lewistown, MT 59457 Fergus

System Facility ID:14-09126

Facility Code: 20351
Last Inspected On: 04/07/2025
Operating Permit Renewal Date: 08/14/2025

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: 341 CES CEANQ **(406) 731-6188**

Operator Contact: Candace Ellsworth;William Smith **(406) 731-6239;(406) 731-7128** **candace.ellsworth@us.af.mil;william.smith@us.af.mil**

Owner/Operator: 341 CES CEANQ (406) 731-6188

Candace Ellsworth, UST Class A Operator candace.ellsworth@us.af.mil
Candace Ellsworth, UST Class B Global Operator candace.ellsworth@us.af.mil
William Smith, UST Class A Operator william.smith@us.af.mil
William Smith, UST Class B Global Operator william.smith@us.af.mil

Tank Number	02	**Tank Age**	32	**Tank Installed Date**	07/01/1993	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	206	**Spill Test Date**	04/06/2022	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	04/06/2022	**Catastrophic L.D. Type 3.0**	Auto Dialer	**Piping Type**	U.S. Suction	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	04/06/2022	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	04/06/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Fergus County in the City of Lewistown

Location: MDOT LEWISTOWN
1620 Airport Rd
Lewistown, MT 59457 Fergus

System Facility ID:14-04062

Facility Code: 20143
Last Inspected On: 10/26/2022
Operating Permit Renewal Date: 11/06/2025

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	MDOT Helena	**(406) 444-6163**	**mmurolo@mt.gov**
Operator Contact:	Joe Radonich;Montana Dept of Transportation;Mike Murolo;Montana Dept of Transportation;Tracy Deeds;MDOT Helena;Walt Kerttula;Montana Dept of Transportation	**(406) 444-6151;(406) 444-7632;(406) 444-6163;(406) 444-7632;(406) 444-9204;(406) 444-7632;(406) 461-0769;(406) 444-6163**	**jradonich@mt.gov;jradonich@mt.gov;mmurolo@mt.gov;jradonich@mt.gov;tdeeds@mt.gov;mmurolo@mt.gov;wkerttula@mt.gov;jradonich@mt.gov**

Owner/Operator: MDOT Helena (406) 444-6163 mmurolo@mt.gov

Adam Lahr, UST Class B Global Operator	ahalr@mt.gov
Douglas Robbins, UST Class B Global Operator	jradonich@mt.gov
Gary Cecrle, UST Class B Operator	gcecrle@mt.gov
Joe Radonich, UST Class A Operator	jradonich@mt.gov
Mike Murolo, UST Class A Operator	jradonich@mt.gov
Tracy Deeds, UST Class A Operator	mmurolo@mt.gov
Walt Kerttula, UST Class A Operator	jradonich@mt.gov

Tank Number	05	**Tank Age**	32	**Tank Installed Date**	10/01/1993	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	4771	**Spill Test Date**	10/26/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	10/26/2022	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	10/26/2022	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	10/26/2022			**ATG Type**	Gilbarco/EMC Basic				
Tank Number	06	**Tank Age**	32	**Tank Installed Date**	10/01/1993	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	4772	**Spill Test Date**	10/26/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	10/26/2022	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**		**Vapor Recovery**	No

Capacity	10000	**ATG Test Date**	10/26/2022	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	10/26/2022			**ATG Type**	Gilbarco/EMC Basic				

Facility Summary in Fergus County in the City of Lewistown

Location: MONTANA MENTAL HEALTH NURSING CARE
800 Casino Creek Dr
Lewistown, MT 59457-3359 Fergus

System Facility ID:14-05032

Facility Code: 20171
Last Inspected On: 01/12/2023
Operating Permit Renewal Date: 01/12/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Montana Mental Health Nursing Care **(406) 538-7451**

Operator Contact: Henry Berry;Jason Fry;Mike Schenck **(406) 538-7451** **JFry@mt.gov;MSchenck@mt.gov**

Owner/Operator: Montana Mental Health Nursing Care (406) 538-7451

Charlie Craven, UST Class B Operator	ccraven@mt.gov
Don Taylor, UST Class B Operator	dtaylor@mt.gov
Henry Berry, UST Class A Operator	
Henry Berry, UST Class B Operator	
Jason Fry, UST Class A Operator	JFry@mt.gov
Jason Fry, UST Class B Operator	JFry@mt.gov
Mike Schenck, UST Class A Operator	MSchenck@mt.gov

Tank Number	02	**Tank Age**	18	**Tank Installed Date**	06/25/2007	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	5128	**Spill Test Date**		**Piping Installed Date**	05/04/2007	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Temporarily Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**	09/03/2014	**Catastrophic L.D. Type 3.0**	Auto Dialer	**Piping Type**	Pressurized	**CP Met Types**	
Product	Heating Oil	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	2500	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/TLS-300;Veeder Root/TLS-300				

Facility Summary in Fergus County in the City of Lewistown

Location: RINDAL OIL CO LEWISTOWN
1003 Joyland Rd
Lewistown, MT 59457 Fergus

System Facility ID:14-05108

Facility Code: 20172
Last Inspected On: 10/16/2024
Operating Permit Renewal Date: 02/04/2028

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Donald Rindal

Operator Contact: Chris Rindal **chrisrindal@hotmail.com**

Owner/Operator: Donald Rindal

Chris Rindal, UST Class A Operator chrisrindal@hotmail.com
Chris Rindal, UST Class B Global Operator chrisrindal@hotmail.com

Tank Number	S11	**Tank Age**	26	**Tank Installed Date**	01/01/1999	**Tank Material Construction**	Aboveground Tank	**Piping Material**	Flexible Plastic	**Overfill Types**	
Tag Number	3931	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	Yes
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	10/16/2024	**Catastrophic L.D. Type 3.0**	Continuous Interstitial Monitoring	**Piping Type**	Pressurized	**CP Met Types**	
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	1000	**ATG Test Date**	11/21/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	S12	**Tank Age**	26	**Tank Installed Date**	01/01/1999	**Tank Material Construction**	Aboveground Tank	**Piping Material**	Flexible Plastic	**Overfill Types**	
Tag Number	3932	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	Yes
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	10/16/2024	**Catastrophic L.D. Type 3.0**	Continuous Interstitial Monitoring	**Piping Type**	Pressurized	**CP Met Types**	
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	1000	**ATG Test Date**	11/21/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					

Tank Number	S13	**Tank Age**	26	**Tank Installed Date**	01/01/1999	**Tank Material Construction**	Aboveground Tank	**Piping Material**	Flexible Plastic	**Overfill Types**	
Tag Number	3933	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	Yes
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	10/16/2024	**Catastrophic L.D. Type 3.0**	Continuous Interstitial Monitoring	**Piping Type**	Pressurized	**CP Met Types**	
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	2000	**ATG Test Date**	11/21/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					

Facility Summary in Fergus County in the City of Lewistown

Location: RINDALS DEPOT
513 1st Ave N
Lewistown, MT 59457 Fergus

System Facility ID:14-12547

Facility Code: 20423
Last Inspected On: 01/06/2023
Operating Permit Renewal Date: 02/13/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Chris Rindal;Rindal Oil Co Lewistown **chrisrindal@hotmail.com**

Operator Contact: Chris Rindal **chrisrindal@hotmail.com**

Owner/Operator: Chris Rindal,Rindal Oil Co Lewistown chrisrindal@hotmail.com

Chris Rindal, UST Class A Operator chrisrindal@hotmail.com

Tank Number	01	**Tank Age**	34	**Tank Installed Date**	10/29/1991	**Tank Material Construction**	Bare Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	2721	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Temporarily Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	12/07/2022	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**		**Line Tightness Test Date**	02/10/2020	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	02	**Tank Age**	34	**Tank Installed Date**	10/29/1991	**Tank Material Construction**	Bare Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	2722	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Temporarily Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	12/07/2022	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**		**Line Tightness Test Date**	12/09/2019	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Tank Number	03	**Tank Age**	34	**Tank Installed Date**	10/29/1991	**Tank Material Construction**	Bare Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	2723	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Temporarily Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	12/07/2022	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**		**Line Tightness Test Date**	12/09/2019	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	04	**Tank Age**	31	**Tank Installed Date**	10/01/1994	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	2724	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Temporarily Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Not Listed	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	12/07/2022	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**		**Line Tightness Test Date**	02/10/2020	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	05	**Tank Age**	23	**Tank Installed Date**	03/18/2002	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	4617	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Temporarily Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Diesel, Dyed	**PLLD Test Date**		**Tank/Piping CP Test Date**	12/07/2022	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**		**Line Tightness Test Date**	02/10/2020	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	06	**Tank Age**	23	**Tank Installed Date**	03/18/2002	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	4618	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No

Status	**Temporarily Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Diesel, Dyed	**PLLD Test Date**		**Tank/Piping CP Test Date**	12/07/2022	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	3000	**ATG Test Date**		**Line Tightness Test Date**	02/10/2020	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	07	**Tank Age**	23	**Tank Installed Date**	03/18/2002	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	4619	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Temporarily Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	12/07/2022	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	3000	**ATG Test Date**		**Line Tightness Test Date**	02/10/2020	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	08	**Tank Age**	23	**Tank Installed Date**	05/15/2002	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	4659	**Spill Test Date**	01/26/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Single Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Gasoline	**PLLD Test Date**	12/07/2022	**Tank/Piping CP Test Date**	12/07/2022	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	12/07/2022	**Line Tightness Test Date**	10/13/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.1	**Energy Act**	No
		Overfill Test Date	12/07/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	09	**Tank Age**	23	**Tank Installed Date**	05/15/2002	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	4660	**Spill Test Date**	12/07/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Single Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Gasoline	**PLLD Test Date**	12/07/2022	**Tank/Piping CP Test Date**	12/07/2022	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**	12/07/2022	**Line Tightness Test Date**	10/16/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.1	**Energy Act**	No

		Overfill Test Date	12/07/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	10	**Tank Age**	23	**Tank Installed Date**	05/15/2002	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	4661	**Spill Test Date**	01/26/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Single Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Gasoline	**PLLD Test Date**	12/07/2022	**Tank/Piping CP Test Date**	12/07/2022	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	9000	**ATG Test Date**	12/07/2022	**Line Tightness Test Date**	10/16/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.1	**Energy Act**	No
		Overfill Test Date	12/07/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	11	**Tank Age**	23	**Tank Installed Date**	05/15/2002	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	4662	**Spill Test Date**	12/07/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Single Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Diesel	**PLLD Test Date**	12/07/2022	**Tank/Piping CP Test Date**	12/07/2022	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	3000	**ATG Test Date**	12/07/2022	**Line Tightness Test Date**	10/12/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.1	**Energy Act**	No
		Overfill Test Date	12/07/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Fergus County in the City of Lewistown

Location: RINDALS FORT LEWIS TRADING POST
1502 W Main St
Lewistown, MT 59457-2202 Fergus

System Facility ID:14-00095

Facility Code: 20027
Last Inspected On: 02/19/2024
Operating Permit Renewal Date: 06/16/2022

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Rindal Oil Co	**(406) 535-2753**	**Chris@rindals.com**
Operator Contact:	Chris Rindal		**chrisrindal@hotmail.com**

Owner/Operator:	Rindal Oil Co	(406) 535-2753	Chris@rindals.com
	Chris Rindal, UST Class A Operator		chrisrindal@hotmail.com
	Chris Rindal, UST Class B Global Operator		chrisrindal@hotmail.com
	Haley Bruseau, UST Class B Operator		fortlewis@rindals.com
	Joni Hartford, UST Class B Global Operator		jlschuff@yahoo.com
	Joni Hartford, UST Class B Global Operator		jlschuff@yahoo.com
	Joni Hartford, UST Class B Global Operator		jlschuff@yahoo.com
	Katie Metcalf, UST Class B Global Operator		katiemetcalf1970@gmail.com
	Katie Metcalf, UST Class B Global Operator		katiemetcalf1970@gmail.com
	Katie Metcalf, UST Class B Global Operator		katiemetcalf1970@gmail.com
	Kelly Davis, UST Class B Operator		fortlewis@midrivers.com
	Kelly Davis, UST Class B Operator		fortlewis@midrivers.com
	Kelly Davis, UST Class B Operator		fortlewis@midrivers.com
	Mito Allen, UST Class B Operator		punkmito@gmail.com
	Mito Allen, UST Class B Operator		punkmito@gmail.com
	Mito Allen, UST Class B Operator		punkmito@gmail.com
	Robert Heller, UST Class B Operator		fortlewis@midrivers.com
	Robert Heller, UST Class B Operator		fortlewis@midrivers.com
	Robert Heller, UST Class B Operator		fortlewis@midrivers.com

Tank Number	01	**Tank Age**	46	**Tank Installed Date**	06/01/1979	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Steel	**Overfill Types**	Flapper Valve
Tag Number	3923	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**	Lined Interior/Impressed Current	**Piping Construction**	None	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**	12/03/2018	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	12/03/2018	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No

Capacity	20000	**ATG Test Date**		**Line Tightness Test Date**	06/04/2015	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	02	**Tank Age**	47	**Tank Installed Date**	12/31/1978	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	3924	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**	Lined Interior/Impressed Current	**Piping Construction**	None	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**	12/03/2018	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	12/03/2018	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	20000	**ATG Test Date**		**Line Tightness Test Date**	06/04/2015	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	04	**Tank Age**	5	**Tank Installed Date**	12/10/2020	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	6034	**Spill Test Date**	02/21/2024	**Piping Installed Date**	12/10/2020	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	02/21/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	11/30/2023	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**	11/30/2023	**Line Tightness Test Date**	12/16/2020	**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	02/21/2024			**ATG Type**					
Tank Number	05	**Tank Age**	5	**Tank Installed Date**	12/10/2020	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	6035	**Spill Test Date**	02/21/2024	**Piping Installed Date**	12/10/2020	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	02/21/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel, Dyed	**PLLD Test Date**	11/30/2023	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**	11/30/2023	**Line Tightness Test Date**	12/16/2020	**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	02/21/2024			**ATG Type**					
Tank Number	06	**Tank Age**	5	**Tank Installed Date**	12/10/2020	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm

Tag Number	6036	**Spill Test Date**	02/21/2024	**Piping Installed Date**	12/10/2020	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	02/21/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	11/30/2023	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	Yes
Capacity	12000	**ATG Test Date**	11/30/2023	**Line Tightness Test Date**	12/16/2020	**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	02/21/2024			**ATG Type**					
Tank Number	07	**Tank Age**	5	**Tank Installed Date**	12/10/2020	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	6037	**Spill Test Date**	02/21/2024	**Piping Installed Date**	12/10/2020	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	02/21/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	11/30/2023	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	Yes
Capacity	4000	**ATG Test Date**	11/30/2023	**Line Tightness Test Date**	12/16/2020	**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	02/21/2024			**ATG Type**					

Facility Summary in Fergus County in the City of Lewistown

Location: RINDALS WEST END SERVICE
1015 Truck Byp
Lewistown, MT 59457 Fergus

System Facility ID:14-03118

Facility Code: 20128
Last Inspected On: 10/31/2022
Operating Permit Renewal Date: 12/31/2021

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Investment Properties Finance Group LLC **(406) 952-0520** **shannono.hmc@gmail.com**

Operator Contact:

Owner/Operator: Investment Properties Finance Group LLC (406) 952-0520 shannono.hmc@gmail.com

Tank Number	08	**Tank Age**	27	**Tank Installed Date**	11/01/1998	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	1838	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Temporarily Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	06/18/2013	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.1;Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2;MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	09	**Tank Age**	27	**Tank Installed Date**	11/01/1998	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	1839	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Temporarily Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	06/18/2013	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.1;Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2;MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	10	**Tank Age**	27	**Tank Installed Date**	11/01/1998	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm

Tag Number	1840	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Temporarily Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	06/18/2013	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.1;Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2;MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					

Facility Summary in Fergus County in the City of Lewistown

Location: SKYLINE AVIATION
410 Skyline Dr
Lewistown, MT 59457-9802 Fergus

System Facility ID:14-04561

Facility Code: 20161
Last Inspected On: 08/08/2024
Operating Permit Renewal Date: 10/10/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Skyline Aviation LLC	**(406) 538-8150**	**that@skylineav.com**
Operator Contact:	Thad Kucera;Skyline Aviation LLC	**(406) 366-9426;(406) 538-8150**	**THAD@SKYLINEAV.COM;that@skylineav.com**

Owner/Operator: Skyline Aviation LLC (406) 538-8150 that@skylineav.com

Thad Kucera, UST Class A Operator that@skylineav.com

Thad Kucera, UST Class B Operator that@skylineav.com

Tank Number	05	**Tank Age**	43	**Tank Installed Date**	04/13/1982	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	444	**Spill Test Date**	08/08/2024	**Piping Installed Date**		**Tank Construction**	Lined Interior/Impressed Current	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	08/08/2024	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	08/08/2024	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	08/08/2024	**Line Tightness Test Date**	08/08/2024	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	08/08/2024			**ATG Type**	Arizona Instrument/Soil Sentry Liquid 330				

Facility Summary in Fergus County in the City of Lewistown

Location: TOWN PUMP INC LEWISTOWN
520 NE Main St
Lewistown, MT 59457-2021 Fergus

System Facility ID:14-08711

Facility Code: 20301
Last Inspected On: 02/26/2024
Operating Permit Renewal Date: 08/06/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Lewistown 1 Town Pump LLC	**(406) 497-6700**	**environmental@townpump.com**
Operator Contact:	Trent Biggers		**Trentb@townpump.com**

Owner/Operator:	Lewistown 1 Town Pump LLC	(406) 497-6700	environmental@townpump.com
	Trent Biggers, UST Class A Operator		Trentb@townpump.com
	Trent Biggers, UST Class A Operator		Trentb@townpump.com
	Trent Biggers, UST Class B Global Operator		Trentb@townpump.com
	Trent Biggers, UST Class B Global Operator		Trentb@townpump.com

Tank Number	04	**Tank Age**	48	**Tank Installed Date**	04/14/1977	**Tank Material Construction**	Bare Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve;Flapper Valve
Tag Number	2418	**Spill Test Date**	08/28/2023	**Piping Installed Date**		**Tank Construction**	Lined Interior/Impressed Current	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	08/28/2023	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**	02/14/2024	**Tank/Piping CP Test Date**	08/28/2023	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	02/26/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	08/28/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-450				
Tank Number	05	**Tank Age**	34	**Tank Installed Date**	06/01/1991	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve;Flapper Valve
Tag Number	2419	**Spill Test Date**	01/14/2024	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	08/28/2023	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	02/26/2024	**Tank/Piping CP Test Date**	02/09/2006	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No

Capacity	6000	**ATG Test Date**	02/26/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	08/28/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-450				
Tank Number	06	**Tank Age**	24	**Tank Installed Date**	09/01/2001	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve
Tag Number	4521	**Spill Test Date**	01/14/2024	**Piping Installed Date**	09/01/2001	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	08/28/2023	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	02/26/2024	**Tank/Piping CP Test Date**	02/09/2006	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	02/26/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	08/28/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-450				
Tank Number	07	**Tank Age**	24	**Tank Installed Date**	09/01/2001	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve
Tag Number	4522	**Spill Test Date**	01/14/2024	**Piping Installed Date**	09/01/2001	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	08/28/2023	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	02/26/2024	**Tank/Piping CP Test Date**	02/09/2006	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	02/26/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	08/28/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-450				
Tank Number	08	**Tank Age**	24	**Tank Installed Date**	09/01/2001	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve
Tag Number	4523	**Spill Test Date**	04/12/2024	**Piping Installed Date**	09/01/2001	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	08/28/2023	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	02/26/2024	**Tank/Piping CP Test Date**	02/09/2006	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	5000	**ATG Test Date**	02/26/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	08/28/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-450				

Tank Number	09	**Tank Age**	24	**Tank Installed Date**	09/01/2001	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve
Tag Number	4524	**Spill Test Date**	08/28/2023	**Piping Installed Date**	09/01/2001	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	08/28/2023	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	02/26/2024	**Tank/Piping CP Test Date**	02/09/2006	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	5000	**ATG Test Date**	02/26/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	08/28/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-450				
Tank Number	15	**Tank Age**	24	**Tank Installed Date**	09/01/2001	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve
Tag Number	5418	**Spill Test Date**		**Piping Installed Date**	09/01/2001	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Other**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Continuous Interstitial Monitoring	**Piping Type**	Pressurized	**CP Met Types**	
Product	DEF (Not Regulated)	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.1;Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Not Listed	**Energy Act**	No
		Overfill Test Date				**ATG Type**	Veeder Root/TLS-450				
Tank Number	11	**Tank Age**	7	**Tank Installed Date**	05/01/2018	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	5748	**Spill Test Date**	01/14/2024	**Piping Installed Date**	05/01/2018	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	08/28/2023	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	02/26/2024	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	Yes
Capacity	24000	**ATG Test Date**	02/26/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Statistical Inventory Reconciliation	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	Yes
		Overfill Test Date	08/28/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-450				
Tank Number	12	**Tank Age**	7	**Tank Installed Date**	05/01/2018	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve

Tag Number	5749	**Spill Test Date**	08/28/2023	**Piping Installed Date**	05/01/2018	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	08/28/2023	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	02/26/2024	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	Yes
Capacity	6000	**ATG Test Date**	02/26/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Statistical Inventory Reconciliation	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	Yes
		Overfill Test Date	08/28/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-450				
Tank Number	13	**Tank Age**	7	**Tank Installed Date**	05/01/2018	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	5750	**Spill Test Date**	08/28/2023	**Piping Installed Date**	05/01/2018	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	08/28/2023	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	02/26/2024	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	15000	**ATG Test Date**	02/26/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Statistical Inventory Reconciliation	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	Yes
		Overfill Test Date	08/28/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-450				
Tank Number	14	**Tank Age**	7	**Tank Installed Date**	05/01/2018	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	5751	**Spill Test Date**	04/12/2024	**Piping Installed Date**	05/01/2018	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	08/28/2023	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	02/26/2024	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	Yes
Capacity	15000	**ATG Test Date**	02/26/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Statistical Inventory Reconciliation	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	Yes
		Overfill Test Date	08/28/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-450				

Facility Summary in Fergus County in the City of Moore

Location: EDDIES CORNER INC
65000 US Hwy 87
Moore, MT 59464 Fergus

System Facility ID:14-02832

Facility Code: 20120
Last Inspected On: 02/27/2023
Operating Permit Renewal Date: 05/08/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: KAMBOJ LLC **(510) 894-5533** **lakhbirkamboj@yahoo.com**

Operator Contact: Vicki Abel **Abel_vicki@yahoo.com**

Owner/Operator: KAMBOJ LLC (510) 894-5533 lakhbirkamboj@yahoo.com

Vicki Abel, UST Class A Operator Abel_vicki@yahoo.com

Vicki Abel, UST Class B Operator Abel_vicki@yahoo.com

Tank Number	06	**Tank Age**	35	**Tank Installed Date**	07/11/1990	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	852	**Spill Test Date**	06/29/2021	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	06/28/2022	**Sump Tightness Test Date**	05/31/2018	**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	02/27/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	06/28/2022	**Line Tightness Test Date**	06/28/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco/EMC Basic				
Tank Number	07	**Tank Age**	33	**Tank Installed Date**	04/17/1992	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	853	**Spill Test Date**	06/29/2021	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	06/28/2022	**Sump Tightness Test Date**	05/31/2018	**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	02/27/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**	06/28/2022	**Line Tightness Test Date**	06/28/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	06/27/2021			**ATG Type**	Gilbarco/EMC Basic				
Tank Number	08	**Tank Age**	33	**Tank Installed Date**	04/17/1992	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	854	**Spill Test Date**	06/29/2021	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No

Status	**Currently in Use**	**MLLD Test Date**	06/28/2022	**Sump Tightness Test Date**	05/31/2018	**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	02/27/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	06/28/2022	**Line Tightness Test Date**	06/28/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	06/27/2022			**ATG Type**	Gilbarco/EMC Basic				
Tank Number	09	**Tank Age**	33	**Tank Installed Date**	04/17/1992	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	855	**Spill Test Date**	06/29/2021	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	06/28/2022	**Sump Tightness Test Date**	05/31/2018	**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	02/27/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	06/28/2022	**Line Tightness Test Date**	06/28/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	06/27/2022			**ATG Type**	Gilbarco/EMC Basic				

Facility Summary in Fergus County in the City of Moore

Location: MALMSTROM AFB L 11
US Hwy 191
Moore, MT 59464 Fergus

System Facility ID:14-09106

Facility Code: 20334
Last Inspected On: 03/28/2025
Operating Permit Renewal Date: 08/06/2025

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: 341 CES CEANQ **(406) 731-6188**

Operator Contact: Candace Ellsworth;Curtis Hester;William Smith **(406) 731-6239;(406) 731-7128** **candace.ellsworth@us.af.mil;william.smith@us.af.mil**

Owner/Operator: 341 CES CEANQ (406) 731-6188

Candace Ellsworth, UST Class A Operator	candace.ellsworth@us.af.mil
Candace Ellsworth, UST Class B Global Operator	candace.ellsworth@us.af.mil
Curtis Hester, UST Class A Operator	
William Smith, UST Class A Operator	william.smith@us.af.mil
William Smith, UST Class B Global Operator	william.smith@us.af.mil

Tank Number	02	**Tank Age**	32	**Tank Installed Date**	06/01/1993	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	189	**Spill Test Date**	03/22/2022	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	03/22/2022	**Catastrophic L.D. Type 3.0**	Auto Dialer	**Piping Type**	U.S. Suction	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	03/22/2022	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	03/22/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Fergus County in the City of Moore

Location: MALMSTROM AFB L 2
US Hwy 87
Moore, MT 59464 Fergus

System Facility ID:14-09097

Facility Code: 20332
Last Inspected On: 03/28/2025
Operating Permit Renewal Date: 08/07/2025

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: 341 CES CEANQ **(406) 731-6188**

Operator Contact: Candace Ellsworth;Curtis Hester;William Smith **(406) 731-6239;(406) 731-7128** **candace.ellsworth@us.af.mil;william.smith@us.af.mil**

Owner/Operator: 341 CES CEANQ (406) 731-6188

Candace Ellsworth, UST Class A Operator	candace.ellsworth@us.af.mil
Candace Ellsworth, UST Class B Global Operator	candace.ellsworth@us.af.mil
Curtis Hester, UST Class A Operator	
Curtis Hester, UST Class B Global Operator	
William Smith, UST Class A Operator	william.smith@us.af.mil
William Smith, UST Class B Global Operator	william.smith@us.af.mil

Tank Number	02	**Tank Age**	32	**Tank Installed Date**	06/01/1993	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	187	**Spill Test Date**	03/22/2022	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	03/22/2022	**Catastrophic L.D. Type 3.0**	Auto Dialer	**Piping Type**	U.S. Suction	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	03/22/2022	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	03/22/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Fergus County in the City of Moore

Location: MALMSTROM AFB M 1
US Hwy 87
Moore, MT 59464 Fergus

System Facility ID:14-09107

Facility Code: 20335
Last Inspected On: 03/31/2025
Operating Permit Renewal Date: 07/24/2028

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: 341 CES CEANQ **(406) 731-6188**

Operator Contact: Candace Ellsworth;Curtis Hester;William Smith **(406) 731-6239;(406) 731-7128** **candace.ellsworth@us.af.mil;william.smith@us.af.mil**

Owner/Operator: 341 CES CEANQ (406) 731-6188

Candace Ellsworth, UST Class A Operator	candace.ellsworth@us.af.mil
Candace Ellsworth, UST Class B Global Operator	candace.ellsworth@us.af.mil
Curtis Hester, UST Class A Operator	
Curtis Hester, UST Class B Global Operator	
William Smith, UST Class A Operator	william.smith@us.af.mil
William Smith, UST Class B Global Operator	william.smith@us.af.mil

Tank Number	04	**Tank Age**	63	**Tank Installed Date**	05/02/1962	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	190	**Spill Test Date**	03/31/2025	**Piping Installed Date**		**Tank Construction**	Lined Interior/Impressed Current	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	03/31/2025	**Catastrophic L.D. Type 3.0**	Auto Dialer	**Piping Type**	U.S. Suction	**CP Met Types**	Impressed Current
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	06/04/2021	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	03/31/2025	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	03/31/2025			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				

Facility Summary in Fergus County in the City of Moore

Location: MALMSTROM AFB M 11
US Hwy 87
Moore, MT 59464 Fergus

System Facility ID:14-09117

Facility Code: 20342
Last Inspected On: 03/31/2025
Operating Permit Renewal Date: 07/31/2028

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: 341 CES CEANQ **(406) 731-6188**

Operator Contact: Candace Ellsworth;Curtis Hester;William Smith **(406) 731-6239;(406) 731-7128** **candace.ellsworth@us.af.mil;william.smith@us.af.mil**

Owner/Operator: 341 CES CEANQ (406) 731-6188

Candace Ellsworth, UST Class A Operator	candace.ellsworth@us.af.mil
Candace Ellsworth, UST Class B Global Operator	candace.ellsworth@us.af.mil
Curtis Hester, UST Class A Operator	
Curtis Hester, UST Class B Global Operator	
William Smith, UST Class A Operator	william.smith@us.af.mil
William Smith, UST Class B Global Operator	william.smith@us.af.mil

Tank Number	02	**Tank Age**	32	**Tank Installed Date**	05/01/1993	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	197	**Spill Test Date**	03/31/2025	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	03/31/2025	**Catastrophic L.D. Type 3.0**	Auto Dialer	**Piping Type**	U.S. Suction	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	03/31/2025	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	03/31/2025			**ATG Type**	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Fergus County in the City of Moore

Location: MALMSTROM AFB M 6
US Hwy 87
Moore, MT 59464 Fergus

System Facility ID:14-09112

Facility Code: 20340
Last Inspected On: 03/31/2025
Operating Permit Renewal Date: 07/24/2028

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: 341 CES CEANQ **(406) 731-6188**

Operator Contact: Candace Ellsworth;Curtis Hester;William Smith **(406) 731-6239;(406) 731-7128** **candace.ellsworth@us.af.mil;william.smith@us.af.mil**

Owner/Operator: 341 CES CEANQ (406) 731-6188

Candace Ellsworth, UST Class A Operator	candace.ellsworth@us.af.mil
Candace Ellsworth, UST Class B Global Operator	candace.ellsworth@us.af.mil
Curtis Hester, UST Class A Operator	
Curtis Hester, UST Class B Global Operator	
William Smith, UST Class A Operator	william.smith@us.af.mil
William Smith, UST Class B Global Operator	william.smith@us.af.mil

Tank Number	02	**Tank Age**	32	**Tank Installed Date**	05/01/1993	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	195	**Spill Test Date**	03/31/2025	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	03/31/2025	**Catastrophic L.D. Type 3.0**	Auto Dialer	**Piping Type**	U.S. Suction	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	03/31/2025	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	03/31/2025			**ATG Type**	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Fergus County in the City of Moore

Location: MALMSTROM AFB M 7
US Hwy 87
Moore, MT 59464 Fergus

System Facility ID:14-09113

Facility Code: 20341
Last Inspected On: 03/28/2025
Operating Permit Renewal Date: 07/24/2028

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: 341 CES CEANQ **(406) 731-6188**

Operator Contact: Candace Ellsworth;Curtis Hester;William Smith **(406) 731-6239;(406) 731-7128** **candace.ellsworth@us.af.mil;william.smith@us.af.mil**

Owner/Operator: 341 CES CEANQ (406) 731-6188

Candace Ellsworth, UST Class A Operator	candace.ellsworth@us.af.mil
Candace Ellsworth, UST Class B Global Operator	candace.ellsworth@us.af.mil
Curtis Hester, UST Class A Operator	
Curtis Hester, UST Class B Global Operator	
William Smith, UST Class A Operator	william.smith@us.af.mil
William Smith, UST Class B Global Operator	william.smith@us.af.mil

Tank Number	02	**Tank Age**	32	**Tank Installed Date**	05/01/1993	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	196	**Spill Test Date**	03/08/2025	**Piping Installed Date**	11/16/2016	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	03/08/2025	**Catastrophic L.D. Type 3.0**	Auto Dialer	**Piping Type**	U.S. Suction	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	03/08/2025	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	03/08/2025			**ATG Type**	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Fergus County in the City of Moore

Location: MOORE FARMERS OIL CO 5613901
113 Fergus Ave
Moore, MT 59464 Fergus

System Facility ID:56-13901

Facility Code: 30573
Last Inspected On: 12/01/2022
Operating Permit Renewal Date: 01/08/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Moore Farmers Oil Co

Operator Contact: Nick Burnham;Moore Farmers Oil Co;Shawn Auck **mfomang@mtintouch.net;mfostore@itstriangle.com**

Owner/Operator: Moore Farmers Oil Co

Nick Burnham, UST Class A Operator	mfostore@itstriangle.com
Nick Burnham, UST Class B Operator	mfostore@itstriangle.com
Shawn Auck, UST Class A Operator	mfomang@mtintouch.net

Tank Number	01	**Tank Age**	27	**Tank Installed Date**	10/01/1998	**Tank Material Construction**	Steel Clad	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	1693	**Spill Test Date**	12/29/2022	**Piping Installed Date**	09/28/2022	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	09/28/2022	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	01/15/2025	**Tank/Piping CP Test Date**	11/05/2010	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	01/15/2025	**Line Tightness Test Date**	10/10/2011	**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date	01/05/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	02	**Tank Age**	27	**Tank Installed Date**	10/01/1998	**Tank Material Construction**	Steel Clad	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	1694	**Spill Test Date**	12/29/2022	**Piping Installed Date**	09/28/2022	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	09/28/2022	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	01/15/2025	**Tank/Piping CP Test Date**	11/05/2010	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	01/15/2025	**Line Tightness Test Date**	10/10/2011	**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No

		Overfill Test Date	01/05/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	03	**Tank Age**	27	**Tank Installed Date**	10/01/1998	**Tank Material Construction**	Steel Clad	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	1695	**Spill Test Date**	12/29/2022	**Piping Installed Date**	09/28/2022	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	09/28/2022	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	01/15/2025	**Tank/Piping CP Test Date**	11/05/2010	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	01/15/2025	**Line Tightness Test Date**	10/10/2011	**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date	01/05/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	04	**Tank Age**	27	**Tank Installed Date**	10/01/1998	**Tank Material Construction**	Steel Clad	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	1696	**Spill Test Date**	12/29/2022	**Piping Installed Date**	09/28/2022	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	09/28/2022	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel, Dyed	**PLLD Test Date**	01/15/2025	**Tank/Piping CP Test Date**	11/05/2010	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	01/15/2025	**Line Tightness Test Date**	10/10/2011	**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date	01/05/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Fergus County in the City of Roy

Location: MALMSTROM AFB O 1
US Hwy 191
Roy, MT 59471 Fergus

System Facility ID:14-09129

Facility Code: 20354
Last Inspected On: 04/02/2025
Operating Permit Renewal Date: 07/31/2028

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: 341 CES CEANQ **(406) 731-6188**

Operator Contact: Candace Ellsworth;Curtis Hester;William Smith **(406) 731-6239;(406) 731-7128** **candace.ellsworth@us.af.mil;william.smith@us.af.mil**

Owner/Operator: 341 CES CEANQ (406) 731-6188

Candace Ellsworth, UST Class A Operator	candace.ellsworth@us.af.mil
Candace Ellsworth, UST Class B Global Operator	candace.ellsworth@us.af.mil
Curtis Hester, UST Class A Operator	
Curtis Hester, UST Class B Global Operator	
William Smith, UST Class A Operator	william.smith@us.af.mil
William Smith, UST Class B Global Operator	william.smith@us.af.mil

Tank Number	02	**Tank Age**	63	**Tank Installed Date**	06/02/1962	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	209	**Spill Test Date**	04/02/2025	**Piping Installed Date**		**Tank Construction**	Lined Interior/Impressed Current	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	04/02/2025	**Catastrophic L.D. Type 3.0**	Auto Dialer	**Piping Type**	U.S. Suction	**CP Met Types**	Impressed Current
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	01/15/2021	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	04/02/2025	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	04/02/2025			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				

Facility Summary in Fergus County in the City of Roy

Location: MALMSTROM AFB O 10
US Hwy 191
Roy, MT 59471 Fergus

System Facility ID:14-09138

Facility Code: 20363
Last Inspected On: 04/02/2025
Operating Permit Renewal Date: 08/14/2025

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: 341 CES CEANQ **(406) 731-6188**

Operator Contact: Candace Ellsworth;Curtis Hester;William Smith **(406) 731-6239;(406) 731-7128** **candace.ellsworth@us.af.mil;william.smith@us.af.mil**

Owner/Operator: 341 CES CEANQ (406) 731-6188

Aaron Hill, UST Class B Operator	aaron.hill@malmstrom.af.mil
Candace Ellsworth, UST Class A Operator	candace.ellsworth@us.af.mil
Candace Ellsworth, UST Class B Global Operator	candace.ellsworth@us.af.mil
Curtis Hester, UST Class A Operator	
Curtis Hester, UST Class B Global Operator	
William Smith, UST Class A Operator	william.smith@us.af.mil
William Smith, UST Class B Global Operator	william.smith@us.af.mil

Tank Number	02	**Tank Age**	32	**Tank Installed Date**	07/01/1993	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	218	**Spill Test Date**	04/05/2022	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	04/05/2022	**Catastrophic L.D. Type 3.0**	Auto Dialer	**Piping Type**	U.S. Suction	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	04/05/2022	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	04/05/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Fergus County in the City of Roy

Location: MALMSTROM AFB O 11
US Hwy 191
Roy, MT 59471 Fergus

System Facility ID:14-09139

Facility Code: 20364
Last Inspected On: 04/02/2025
Operating Permit Renewal Date: 08/14/2025

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: 341 CES CEANQ **(406) 731-6188**

Operator Contact: Candace Ellsworth;Curtis Hester;William Smith **(406) 731-6239;(406) 731-7128** **candace.ellsworth@us.af.mil;william.smith@us.af.mil**

Owner/Operator: 341 CES CEANQ (406) 731-6188

Brian McVay, UST Class B Operator	
Candace Ellsworth, UST Class A Operator	candace.ellsworth@us.af.mil
Candace Ellsworth, UST Class B Global Operator	candace.ellsworth@us.af.mil
Curtis Hester, UST Class A Operator	
Curtis Hester, UST Class B Global Operator	
William Hoffmeister, UST Class B Operator	william.hoffmeister@malmstrom.af.mil
William Smith, UST Class A Operator	william.smith@us.af.mil
William Smith, UST Class B Global Operator	william.smith@us.af.mil

Tank Number	02	**Tank Age**	32	**Tank Installed Date**	08/01/1993	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	219	**Spill Test Date**	04/04/2022	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	04/04/2022	**Catastrophic L.D. Type 3.0**	Auto Dialer	**Piping Type**	U.S. Suction	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	04/04/2022	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	04/04/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Fergus County in the City of Roy

Location: MALMSTROM AFB O 2
US Hwy 191
Roy, MT 59471 Fergus

System Facility ID:14-09130

Facility Code: 20355
Last Inspected On: 04/02/2025
Operating Permit Renewal Date: 07/31/2028

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: 341 CES CEANQ **(406) 731-6188**

Operator Contact: Candace Ellsworth;Curtis Hester;William Smith **(406) 731-6239;(406) 731-7128** **candace.ellsworth@us.af.mil;william.smith@us.af.mil**

Owner/Operator: 341 CES CEANQ (406) 731-6188

Candace Ellsworth, UST Class A Operator	candace.ellsworth@us.af.mil
Candace Ellsworth, UST Class B Global Operator	candace.ellsworth@us.af.mil
Curtis Hester, UST Class A Operator	
Curtis Hester, UST Class B Global Operator	
Dustin Hemingway, UST Class B Operator	dustin.hemingway@malmstrom.af.mil
William Smith, UST Class A Operator	william.smith@us.af.mil
William Smith, UST Class B Global Operator	william.smith@us.af.mil

Tank Number	02	**Tank Age**	32	**Tank Installed Date**	07/01/1993	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	210	**Spill Test Date**	04/02/2025	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	04/02/2025	**Catastrophic L.D. Type 3.0**	Auto Dialer	**Piping Type**	U.S. Suction	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	04/02/2025	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	04/02/2025			**ATG Type**	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Fergus County in the City of Roy

Location: MALMSTROM AFB O 3
US Hwy 191
Roy, MT 59471 Fergus

System Facility ID:14-09131

Facility Code: 20356
Last Inspected On: 04/03/2025
Operating Permit Renewal Date: 07/31/2028

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: 341 CES CEANQ **(406) 731-6188**

Operator Contact: Candace Ellsworth;Curtis Hester;William Smith **(406) 731-6239;(406) 731-7128** **candace.ellsworth@us.af.mil;william.smith@us.af.mil**

Owner/Operator: 341 CES CEANQ (406) 731-6188

Candace Ellsworth, UST Class A Operator	candace.ellsworth@us.af.mil
Candace Ellsworth, UST Class B Global Operator	candace.ellsworth@us.af.mil
Curtis Hester, UST Class A Operator	
Curtis Hester, UST Class B Global Operator	
William Smith, UST Class A Operator	william.smith@us.af.mil
William Smith, UST Class B Global Operator	william.smith@us.af.mil

Tank Number	02	**Tank Age**	32	**Tank Installed Date**	07/01/1993	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	211	**Spill Test Date**	04/03/2025	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	04/03/2025	**Catastrophic L.D. Type 3.0**	Auto Dialer	**Piping Type**	U.S. Suction	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	04/03/2025	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	04/03/2025			**ATG Type**	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Fergus County in the City of Roy

Location: MALMSTROM AFB O 4
MT Hwy 19
Roy, MT 59471 Fergus

System Facility ID:14-09132

Facility Code: 20357
Last Inspected On: 04/03/2025
Operating Permit Renewal Date: 07/31/2028

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: 341 CES CEANQ **(406) 731-6188**

Operator Contact: Candace Ellsworth;Curtis Hester;William Smith **(406) 731-6239;(406) 731-7128** **candace.ellsworth@us.af.mil;william.smith@us.af.mil**

Owner/Operator: 341 CES CEANQ (406) 731-6188

Candace Ellsworth, UST Class A Operator	candace.ellsworth@us.af.mil
Candace Ellsworth, UST Class B Global Operator	candace.ellsworth@us.af.mil
Curtis Hester, UST Class A Operator	
Curtis Hester, UST Class B Global Operator	
William Smith, UST Class A Operator	william.smith@us.af.mil
William Smith, UST Class B Global Operator	william.smith@us.af.mil

Tank Number	02	**Tank Age**	32	**Tank Installed Date**	07/01/1993	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	212	**Spill Test Date**	04/03/2025	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	04/03/2025	**Catastrophic L.D. Type 3.0**	Auto Dialer	**Piping Type**	U.S. Suction	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	04/03/2025	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	04/03/2025			**ATG Type**	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Fergus County in the City of Roy

Location: MALMSTROM AFB O 5
MT Hwy 19
Roy, MT 59471 Fergus

System Facility ID:14-09133

Facility Code: 20358
Last Inspected On: 04/03/2025
Operating Permit Renewal Date: 07/31/2028

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: 341 CES CEANQ **(406) 731-6188**

Operator Contact: Candace Ellsworth;Curtis Hester;William Smith **(406) 731-6239;(406) 731-7128** **candace.ellsworth@us.af.mil;william.smith@us.af.mil**

Owner/Operator: 341 CES CEANQ (406) 731-6188

Candace Ellsworth, UST Class A Operator	candace.ellsworth@us.af.mil
Candace Ellsworth, UST Class B Global Operator	candace.ellsworth@us.af.mil
Curtis Hester, UST Class A Operator	
Curtis Hester, UST Class B Global Operator	
William Smith, UST Class A Operator	william.smith@us.af.mil
William Smith, UST Class B Global Operator	william.smith@us.af.mil

Tank Number	02	**Tank Age**	32	**Tank Installed Date**	07/01/1993	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	213	**Spill Test Date**	04/03/2025	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	04/03/2025	**Catastrophic L.D. Type 3.0**	Auto Dialer	**Piping Type**	U.S. Suction	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	04/03/2025	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	04/03/2025			**ATG Type**	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Fergus County in the City of Roy

Location: MALMSTROM AFB O 6
MT Hwy 19
Roy, MT 59471 Fergus

System Facility ID:14-09134

Facility Code: 20359
Last Inspected On: 04/03/2025
Operating Permit Renewal Date: 07/31/2028

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	341 CES CEANQ	**(406) 731-6188**	
Operator Contact:	Candace Ellsworth;Curtis Hester;Shannon Chouinard;Malmstrom A F B;William Smith	**(406) 731-6167;(406) 731-6239;(406) 731-7128**	**candace.ellsworth@us.af.mil;shannon.chouinard@us.af.mil;william.smith@us.af.mil**

Owner/Operator: 341 CES CEANQ (406) 731-6188

Candace Ellsworth, UST Class A Operator	candace.ellsworth@us.af.mil
Candace Ellsworth, UST Class B Global Operator	candace.ellsworth@us.af.mil
Curtis Hester, UST Class A Operator	
Curtis Hester, UST Class B Global Operator	
Shannon Chouinard, UST Class A Operator	shannon.chouinard@us.af.mil
Shannon Chouinard, UST Class B Operator	shannon.chouinard@us.af.mil
William Smith, UST Class A Operator	william.smith@us.af.mil
William Smith, UST Class B Global Operator	william.smith@us.af.mil

Tank Number	02	**Tank Age**	32	**Tank Installed Date**	07/15/1993	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	214	**Spill Test Date**	04/03/2025	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	04/03/2025	**Catastrophic L.D. Type 3.0**	Auto Dialer	**Piping Type**	U.S. Suction	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	04/03/2025	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	04/03/2025			**ATG Type**	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Fergus County in the City of Roy

Location: MALMSTROM AFB O 7
US Hwy 191
Roy, MT 59471 Fergus

System Facility ID:14-09135

Facility Code: 20360
Last Inspected On: 04/02/2025
Operating Permit Renewal Date: 07/31/2028

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	341 CES CEANQ	**(406) 731-6188**	
Operator Contact:	Candace Ellsworth;Curtis Hester;Shannon Chouinard;Malmstrom A F B;William Smith	**(406) 731-6167;(406) 731-6239;(406) 731-7128**	**candace.ellsworth@us.af.mil;shannon.chouinard@us.af.mil;william.smith@us.af.mil**

Owner/Operator: 341 CES CEANQ (406) 731-6188

Candace Ellsworth, UST Class A Operator	candace.ellsworth@us.af.mil
Candace Ellsworth, UST Class B Global Operator	candace.ellsworth@us.af.mil
Curtis Hester, UST Class A Operator	
Curtis Hester, UST Class B Global Operator	
Shannon Chouinard, UST Class A Operator	shannon.chouinard@us.af.mil
Shannon Chouinard, UST Class B Operator	shannon.chouinard@us.af.mil
William Smith, UST Class A Operator	william.smith@us.af.mil
William Smith, UST Class B Global Operator	william.smith@us.af.mil

Tank Number	02	**Tank Age**	32	**Tank Installed Date**	07/01/1993	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	215	**Spill Test Date**	04/02/2025	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	04/02/2025	**Catastrophic L.D. Type 3.0**	Auto Dialer	**Piping Type**	U.S. Suction	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	04/02/2025	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	04/02/2025			**ATG Type**	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Fergus County in the City of Winifred

Location: CHS BIG SKY WINIFRED
108 Main St
Winifred, MT 59489 Fergus

System Facility ID:14-01292

Facility Code: 20062
Last Inspected On: 12/17/2024
Operating Permit Renewal Date: 01/24/2028

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: CHS Big Sky **(406) 462-5428**

Operator Contact: Brendon Jerke;Matthew Knox **(406) 462-5354;(406) 462-5428** **matt.knox@chsinc.com**

Owner/Operator: CHS Big Sky (406) 462-5428

Brendon Jerke, UST Class A Operator	
Brendon Jerke, UST Class A Operator	
Brian Foran, UST Class B Operator	brian.foran@chsinc.com
Brian Foran, UST Class B Operator	brian.foran@chsinc.com
Chris Schmitt, UST Class B Operator	chris.schmitt@chsinc.com
Chris Schmitt, UST Class B Operator	chris.schmitt@chsinc.com
Matthew Knox, UST Class A Operator	matt.knox@chsinc.com
Matthew Knox, UST Class A Operator	matt.knox@chsinc.com

Tank Number	09	**Tank Age**	29	**Tank Installed Date**	09/01/1996	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	2288	**Spill Test Date**	12/05/2024	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	12/05/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	03/02/2025	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	12/05/2024	**Line Tightness Test Date**	05/01/2013	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	12/05/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-450				
Tank Number	10	**Tank Age**	29	**Tank Installed Date**	09/01/1996	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	2289	**Spill Test Date**	12/05/2024	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	12/05/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	03/02/2025	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No

Capacity	4000	**ATG Test Date**	12/05/2024	**Line Tightness Test Date**	05/01/2013	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	12/05/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-450				
Tank Number	11	**Tank Age**	29	**Tank Installed Date**	09/01/1996	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	2290	**Spill Test Date**	12/05/2024	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	12/05/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	03/02/2025	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	12/05/2024	**Line Tightness Test Date**	05/01/2013	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	12/05/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-450				
Tank Number	12	**Tank Age**	29	**Tank Installed Date**	09/01/1996	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	2291	**Spill Test Date**	12/05/2024	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	12/05/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	03/02/2025	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	12/05/2024	**Line Tightness Test Date**	05/01/2013	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	12/05/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-450				
Tank Number	13	**Tank Age**	29	**Tank Installed Date**	09/01/1996	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	2292	**Spill Test Date**	12/05/2024	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	12/05/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	03/02/2025	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	12/05/2024	**Line Tightness Test Date**	05/01/2013	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	12/05/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-450				
Tank Number	14	**Tank Age**	29	**Tank Installed Date**	09/01/1996	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm

Tag Number	2293	**Spill Test Date**	12/05/2024	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	12/05/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	03/02/2025	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	12/05/2024	**Line Tightness Test Date**	05/01/2013	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	12/05/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-450				
Tank Number	15	**Tank Age**	29	**Tank Installed Date**	09/01/1996	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	2294	**Spill Test Date**	12/05/2024	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	12/05/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	03/02/2025	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	12/05/2024	**Line Tightness Test Date**	05/01/2013	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	12/05/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-450				

Facility Summary in Fergus County in the City of Winifred

Location: MALMSTROM AFB E 1
County Road 236
Winifred, MT 59489 Fergus

System Facility ID:14-09019

Facility Code: 20320
Last Inspected On: 06/03/2024
Operating Permit Renewal Date: 09/15/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: 341 CES CEANQ **(406) 731-6188**

Operator Contact: Candace Ellsworth;Curtis Hester;William Smith **(406) 731-6239;(406) 731-7128** **candace.ellsworth@us.af.mil;william.smith@us.af.mil**

Owner/Operator: 341 CES CEANQ (406) 731-6188

Candace Ellsworth, UST Class A Operator	candace.ellsworth@us.af.mil
Candace Ellsworth, UST Class B Global Operator	candace.ellsworth@us.af.mil
Curtis Hester, UST Class A Operator	
Curtis Hester, UST Class B Global Operator	
William Smith, UST Class A Operator	william.smith@us.af.mil
William Smith, UST Class B Global Operator	william.smith@us.af.mil

Tank Number	02	**Tank Age**	63	**Tank Installed Date**	05/02/1962	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	175	**Spill Test Date**	03/28/2023	**Piping Installed Date**		**Tank Construction**	Lined Interior/Impressed Current	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	03/28/2023	**Catastrophic L.D. Type 3.0**	Auto Dialer	**Piping Type**	U.S. Suction	**CP Met Types**	Impressed Current
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	04/01/2020	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	12/03/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	12/03/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				

Facility Summary in Fergus County in the City of Winifred

Location: MALMSTROM AFB E 10
County Road 236
Winifred, MT 59489 Fergus

System Facility ID:14-09028

Facility Code: 20329
Last Inspected On: 06/04/2024
Operating Permit Renewal Date: 09/15/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: 341 CES CEANQ **(406) 731-6188**

Operator Contact: Candace Ellsworth;Curtis Hester;William Smith **(406) 731-6239;(406) 731-7128** **candace.ellsworth@us.af.mil;william.smith@us.af.mil**

Owner/Operator: 341 CES CEANQ (406) 731-6188

Candace Ellsworth, UST Class A Operator	candace.ellsworth@us.af.mil
Candace Ellsworth, UST Class B Global Operator	candace.ellsworth@us.af.mil
Curtis Hester, UST Class A Operator	
Curtis Hester, UST Class B Global Operator	
William Smith, UST Class A Operator	william.smith@us.af.mil
William Smith, UST Class B Global Operator	william.smith@us.af.mil

Tank Number	02	**Tank Age**	33	**Tank Installed Date**	07/01/1992	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	184	**Spill Test Date**	03/27/2023	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	03/27/2023	**Catastrophic L.D. Type 3.0**	Auto Dialer	**Piping Type**	U.S. Suction	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	03/27/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	03/27/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Fergus County in the City of Winifred

Location: MALMSTROM AFB E 11
County Road 236
Winifred, MT 59489 Fergus

System Facility ID:14-09029

Facility Code: 20330
Last Inspected On: 06/03/2024
Operating Permit Renewal Date: 09/15/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: 341 CES CEANQ **(406) 731-6188**

Operator Contact: Candace Ellsworth;Curtis Hester;William Smith **(406) 731-6239;(406) 731-7128** **candace.ellsworth@us.af.mil;william.smith@us.af.mil**

Owner/Operator: 341 CES CEANQ (406) 731-6188

Candace Ellsworth, UST Class A Operator	candace.ellsworth@us.af.mil
Candace Ellsworth, UST Class B Global Operator	candace.ellsworth@us.af.mil
Curtis Hester, UST Class A Operator	
Curtis Hester, UST Class B Global Operator	
William Smith, UST Class A Operator	william.smith@us.af.mil
William Smith, UST Class B Global Operator	william.smith@us.af.mil

Tank Number	02	**Tank Age**	33	**Tank Installed Date**	07/01/1992	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	185	**Spill Test Date**	03/27/2023	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	03/27/2023	**Catastrophic L.D. Type 3.0**	Auto Dialer	**Piping Type**	U.S. Suction	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	03/27/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	03/27/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Fergus County in the City of Winifred

Location: MALMSTROM AFB E 2
County Road 236
Winifred, MT 59489 Fergus

System Facility ID:14-09020

Facility Code: 20321
Last Inspected On: 06/03/2024
Operating Permit Renewal Date: 09/15/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: 341 CES CEANQ **(406) 731-6188**

Operator Contact: Candace Ellsworth;Curtis Hester;William Smith **(406) 731-6239;(406) 731-7128** **candace.ellsworth@us.af.mil;william.smith@us.af.mil**

Owner/Operator: 341 CES CEANQ (406) 731-6188

Candace Ellsworth, UST Class A Operator	candace.ellsworth@us.af.mil
Candace Ellsworth, UST Class B Global Operator	candace.ellsworth@us.af.mil
Curtis Hester, UST Class A Operator	
Curtis Hester, UST Class B Global Operator	
William Smith, UST Class A Operator	william.smith@us.af.mil
William Smith, UST Class B Global Operator	william.smith@us.af.mil

Tank Number	02	**Tank Age**	33	**Tank Installed Date**	07/01/1992	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	176	**Spill Test Date**	03/27/2023	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	03/27/2023	**Catastrophic L.D. Type 3.0**	Auto Dialer	**Piping Type**	U.S. Suction	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	03/27/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	03/27/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Fergus County in the City of Winifred

Location: MALMSTROM AFB E 3
County Road 236
Winifred, MT 59489 Fergus

System Facility ID:14-09021

Facility Code: 20322
Last Inspected On: 06/03/2024
Operating Permit Renewal Date: 09/15/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: 341 CES CEANQ **(406) 731-6188**

Operator Contact: Candace Ellsworth;Curtis Hester;William Smith **(406) 731-6239;(406) 731-7128** **candace.ellsworth@us.af.mil;william.smith@us.af.mil**

Owner/Operator: 341 CES CEANQ (406) 731-6188

Candace Ellsworth, UST Class A Operator	candace.ellsworth@us.af.mil
Candace Ellsworth, UST Class B Global Operator	candace.ellsworth@us.af.mil
Curtis Hester, UST Class A Operator	
Curtis Hester, UST Class B Global Operator	
William Smith, UST Class A Operator	william.smith@us.af.mil
William Smith, UST Class B Global Operator	william.smith@us.af.mil

Tank Number	02	**Tank Age**	33	**Tank Installed Date**	07/01/1992	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	177	**Spill Test Date**	03/27/2023	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	03/27/2023	**Catastrophic L.D. Type 3.0**	Auto Dialer	**Piping Type**	U.S. Suction	**CP Met Types**	
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	03/27/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	03/27/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Fergus County in the City of Winifred

Location: MALMSTROM AFB E 4
County Road 236
Winifred, MT 59489 Fergus

System Facility ID:14-09022

Facility Code: 20323
Last Inspected On: 06/03/2024
Operating Permit Renewal Date: 09/15/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: 341 CES CEANQ **(406) 731-6188**

Operator Contact: Candace Ellsworth;Curtis Hester;William Smith **(406) 731-6239;(406) 731-7128** **candace.ellsworth@us.af.mil;william.smith@us.af.mil**

Owner/Operator: 341 CES CEANQ (406) 731-6188

Candace Ellsworth, UST Class A Operator	candace.ellsworth@us.af.mil
Candace Ellsworth, UST Class B Global Operator	candace.ellsworth@us.af.mil
Curtis Hester, UST Class A Operator	
Curtis Hester, UST Class B Global Operator	
William Smith, UST Class A Operator	william.smith@us.af.mil
William Smith, UST Class B Global Operator	william.smith@us.af.mil

Tank Number	02	**Tank Age**	33	**Tank Installed Date**	07/01/1992	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	4273	**Spill Test Date**	03/27/2023	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	03/27/2023	**Catastrophic L.D. Type 3.0**	Auto Dialer	**Piping Type**	U.S. Suction	**CP Met Types**	
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	03/27/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	03/27/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Fergus County in the City of Winifred

Location: MALMSTROM AFB E 5
County Road 236
Winifred, MT 59489 Fergus

System Facility ID:14-09023

Facility Code: 20324
Last Inspected On: 06/03/2024
Operating Permit Renewal Date: 09/15/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: 341 CES CEANQ **(406) 731-6188**

Operator Contact: Candace Ellsworth;Curtis Hester;William Smith **(406) 731-6239;(406) 731-7128** **candace.ellsworth@us.af.mil;william.smith@us.af.mil**

Owner/Operator: 341 CES CEANQ (406) 731-6188

Candace Ellsworth, UST Class A Operator	candace.ellsworth@us.af.mil
Candace Ellsworth, UST Class B Global Operator	candace.ellsworth@us.af.mil
Curtis Hester, UST Class A Operator	
Curtis Hester, UST Class B Global Operator	
William Smith, UST Class A Operator	william.smith@us.af.mil
William Smith, UST Class B Global Operator	william.smith@us.af.mil

Tank Number	02	**Tank Age**	33	**Tank Installed Date**	08/01/1992	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	4269	**Spill Test Date**	03/27/2023	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	03/27/2023	**Catastrophic L.D. Type 3.0**	Auto Dialer	**Piping Type**	U.S. Suction	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	03/27/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	03/27/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Flathead County in the City of Bigfork

Location: BIGFORK OUTDOOR RENTALS INC
110 Swan River Rd
Bigfork, MT 59911-6329 Flathead

System Facility ID:15-07361

Facility Code: 20728
Last Inspected On: 01/04/2024
Operating Permit Renewal Date: 01/03/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Bigfork Outdoor Rentals Inc;Dalen Whalen	**(406) 396-8185**	**dwhalen9@gmail.com**
Operator Contact:	Dale Whalen	**(406) 396-8185**	**dalewhalen@gmail.com**

Owner/Operator:	Bigfork Outdoor Rentals Inc	(406) 396-8185	dwhalen9@gmail.com
Owner/Operator:	Dalen Whalen	(406) 396-8185	dwhalen9@gmail.com
	Dale Whalen, UST Class A Operator		dalewhalen@gmail.com
	Dale Whalen, UST Class A Operator		dalewhalen@gmail.com
	Dale Whalen, UST Class B Global Operator		dalewhalen@gmail.com
	Dale Whalen, UST Class B Global Operator		dalewhalen@gmail.com
	Dale Whalen, UST Class B Operator		dalewhalen@gmail.com
	Dale Whalen, UST Class B Operator		dalewhalen@gmail.com

Tank Number	06	**Tank Age**	30	**Tank Installed Date**	11/01/1995	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	3498	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Single Walled	**AST**	No
Status	**Temporarily Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	01/03/2024	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.1;Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**	EMCO Electronics/EECO 1500				
Tank Number	07	**Tank Age**	30	**Tank Installed Date**	11/01/1995	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	3499	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Temporarily Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Galvanic

Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	01/03/2024	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.1;Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	3000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**	EMCO Electronics/EECO 1500				
Tank Number	08	**Tank Age**	30	**Tank Installed Date**	11/01/1995	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	3500	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Temporarily Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	01/03/2024	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.1;Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	3000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**	EMCO Electronics/EECO 1500				

Facility Summary in Flathead County in the City of Bigfork

Location: BIGFORK STAGE STOP INC
8263 MT Hwy 35
Bigfork, MT 59911-3518 Flathead

System Facility ID:56-13885

Facility Code: 30560
Last Inspected On: 10/05/2022
Operating Permit Renewal Date: 12/02/2025

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Bigfork Stage Stop Inc **(406) 837-5858**

Operator Contact: Vicky Miller;Bigfork Stage Stop Inc **(406) 837-1551;(406) 837-5858** **vicky@stage-stop.com**

Owner/Operator: Bigfork Stage Stop Inc (406) 837-5858

Vicky Miller, UST Class A Operator vicky@stage-stop.com
Vicky Miller, UST Class B Global Operator vicky@stage-stop.com

Tank Number	01	**Tank Age**	27	**Tank Installed Date**	10/01/1998	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	3531	**Spill Test Date**	04/07/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	10/05/2022	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	04/07/2022			**ATG Type**	Gilbarco/EMC Basic				
Tank Number	02	**Tank Age**	27	**Tank Installed Date**	10/01/1998	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	3532	**Spill Test Date**	04/07/2022	**Piping Installed Date**	11/24/2008	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	10/05/2022	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	04/07/2022			**ATG Type**	Gilbarco/EMC Basic				
Tank Number	03	**Tank Age**	27	**Tank Installed Date**	10/01/1998	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve

Tag Number	3533	**Spill Test Date**	04/07/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	5000	**ATG Test Date**	10/05/2022	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	04/07/2022			**ATG Type**	Gilbarco/EMC Basic				

Facility Summary in Flathead County in the City of Bigfork

Location: CALUMET CARDLOCK
8111 MT Hwy 35
Bigfork, MT 59911-3588 Flathead

System Facility ID:15-09801

Facility Code: 20806
Last Inspected On: 01/27/2025
Operating Permit Renewal Date: 03/18/2028

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Bigfork Properties LLC **(406) 837-4550**

Operator Contact: Marcus Balgos;Bigfork Properties LLC **(406) 837-5010;(406) 837-4550** **bhf_marcus@centurytel.net**

Owner/Operator: Bigfork Properties LLC (406) 837-4550

Marcus Balgos, UST Class A Operator bhf_marcus@centurytel.net
Marcus Balgos, UST Class B Operator bhf_marcus@centurytel.net

Tank Number	01	**Tank Age**	44	**Tank Installed Date**	05/01/1981	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	481	**Spill Test Date**	10/08/2024	**Piping Installed Date**	02/02/2022	**Tank Construction**	Lined Interior/Impressed Current	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	10/08/2024	**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	10/08/2024	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	10/08/2024	**Line Tightness Test Date**	02/02/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	10/08/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	02	**Tank Age**	44	**Tank Installed Date**	05/01/1981	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	482	**Spill Test Date**	11/14/2024	**Piping Installed Date**	02/02/2022	**Tank Construction**	Lined Interior/Impressed Current	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	02/02/2022	**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Impressed Current
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	10/08/2024	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	10/08/2024	**Line Tightness Test Date**	02/02/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	10/08/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Tank Number	03	**Tank Age**	32	**Tank Installed Date**	07/01/1993	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	483	**Spill Test Date**	10/08/2024	**Piping Installed Date**	02/02/2022	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	02/02/2022	**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	10/08/2024	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	10/08/2024	**Line Tightness Test Date**	02/02/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	10/08/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	04	**Tank Age**	30	**Tank Installed Date**	04/01/1995	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	484	**Spill Test Date**	11/14/2024	**Piping Installed Date**	02/02/2022	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	10/08/2024	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**	10/08/2024	**Line Tightness Test Date**	02/02/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	11/14/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	05	**Tank Age**	30	**Tank Installed Date**	04/01/1995	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	485	**Spill Test Date**	10/08/2024	**Piping Installed Date**	02/02/2022	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	02/02/2022	**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	10/08/2024	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	10/08/2024	**Line Tightness Test Date**	02/02/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	10/08/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Flathead County in the City of Bigfork

Location: EAGLE BEND YACHT HARBOR
371 Eagle Bend Dr
Bigfork, MT 59911-6210 Flathead

System Facility ID:15-13152

Facility Code: 21034
Last Inspected On: 05/28/2025
Operating Permit Renewal Date: 06/01/2028

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Eagle Bend Yacht Harbor Boat Slip Owners Association

Operator Contact: Dave Roberts **(406) 253-2840** **droberts@westernmountains.com**

Owner/Operator: Eagle Bend Yacht Harbor Boat Slip Owners Association

Dave Roberts, UST Class A Operator droberts@westernmountains.com

Dave Roberts, UST Class B Operator droberts@westernmountains.com

Tank Number	01	**Tank Age**	32	**Tank Installed Date**	07/01/1993	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve
Tag Number	4013	**Spill Test Date**	05/28/2025	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	05/20/2025	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	05/28/2025	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	5000	**ATG Test Date**	05/28/2025	**Line Tightness Test Date**	08/02/2010	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	05/28/2025			**ATG Type**	Gilbarco-Veeder Root/ILS-250				
Tank Number	02	**Tank Age**	32	**Tank Installed Date**	07/01/1993	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve
Tag Number	4014	**Spill Test Date**	05/28/2025	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	05/20/2025	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	05/28/2025	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	1000	**ATG Test Date**	05/28/2025	**Line Tightness Test Date**	08/02/2010	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	05/28/2025			**ATG Type**	Gilbarco-Veeder Root/ILS-250				

Facility Summary in Flathead County in the City of Bigfork

Location: FERNDALE MARKET
1845 MT Hwy 209
Bigfork, MT 59911-6540 Flathead

System Facility ID:15-07199

Facility Code: 20719
Last Inspected On: 04/27/2023
Operating Permit Renewal Date: 08/08/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Griggs Ferndale LLC	**(406) 837-5597**	**invoices@ferndalemarket.net**
Operator Contact:	Brian Truckey;Griggs Ferndale LLC;Robert Dileo;Ferndale Market	**(406) 407-0743;(406) 837-5597;(406) 837-5597**	**btruckey@gmail.com;invoices@ferndalemarket.net;dileorobert@gmail.com**

Owner/Operator: Griggs Ferndale LLC (406) 837-5597 invoices@ferndalemarket.net

Brian Truckey, UST Class A Operator	invoices@ferndalemarket.net
Brian Truckey, UST Class B Operator	invoices@ferndalemarket.net
Robert Dileo, UST Class A Operator	dileorobert@gmail.com
Robert Dileo, UST Class B Operator	dileorobert@gmail.com

Tank Number	01	**Tank Age**	49	**Tank Installed Date**	04/28/1976	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	3254	**Spill Test Date**	04/27/2023	**Piping Installed Date**		**Tank Construction**	Lined Interior/Impressed Current	**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	04/27/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	04/27/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	04/27/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	02	**Tank Age**	48	**Tank Installed Date**	04/28/1977	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	3255	**Spill Test Date**	04/27/2023	**Piping Installed Date**		**Tank Construction**	Lined Interior/Impressed Current	**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	04/27/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	04/27/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No

		Overfill Test Date	04/27/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	03	**Tank Age**	32	**Tank Installed Date**	06/01/1993	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	3256	**Spill Test Date**	09/12/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	04/27/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**	04/27/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	04/27/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	04	**Tank Age**	32	**Tank Installed Date**	06/01/1993	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	3257	**Spill Test Date**	09/12/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	04/27/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	04/27/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	04/27/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Flathead County in the City of Bigfork

Location: FLATHEAD LAKE LODGE
150 Flathead Lodge Rd
Bigfork, MT 59911-7419 Flathead

System Facility ID:15-04551

Facility Code: 20643
Last Inspected On: 02/05/2021
Operating Permit Renewal Date: 02/02/2024

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Flathead Lake Lodge

Operator Contact: Douglas Averill **(406) 837-4391** **info@flatheadlakelodge.com**

Douglas Averill, UST Class A Operator info@flatheadlakelodge.com
Douglas Averill, UST Class B Operator info@flatheadlakelodge.com

Tank Number	04	**Tank Age**	33	**Tank Installed Date**	05/14/1992	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	1826	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	01/10/2013	**Primary Tank Leak Detection**	Manual Tank Gauging;Tank Tightness Testing	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	2000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	05	**Tank Age**	31	**Tank Installed Date**	06/01/1994	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	1827	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	01/10/2013	**Primary Tank Leak Detection**	Manual Tank Gauging;Tank Tightness Testing	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	1200	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					

Facility Summary in Flathead County in the City of Bigfork

Location: MARINA CAY RESORT
180 Vista Lane
Bigfork, MT 59911-6162 Flathead

System Facility ID:15-03002

Facility Code: 20591
Last Inspected On: 09/12/2024
Operating Permit Renewal Date: 10/14/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Ken Wheeler;Marina Cay Resort	**(406) 837-5861**	**k.wheeler@frontlineag.com>**
Operator Contact:	David Roberts	**(406) 358-2422**	**droberts@westernmountains.com**

Owner/Operator: Ken Wheeler,Marina Cay Resort (406) 837-5861 k.wheeler@frontlineag.com>
David Roberts, UST Class A Operator droberts@westernmountains.com
David Roberts, UST Class B Operator droberts@westernmountains.com

Tank Number	02	**Tank Age**	26	**Tank Installed Date**	05/05/1999	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve
Tag Number	4067	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Temporarily Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Continuous Interstitial Monitoring	**Piping Type**	Pressurized	**CP Met Types**	
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	03	**Tank Age**	18	**Tank Installed Date**	07/25/2007	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve
Tag Number	5110	**Spill Test Date**	05/06/2025	**Piping Installed Date**	02/05/2006	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	05/06/2025	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	05/30/2025	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.1	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	05/30/2025	**Line Tightness Test Date**	10/21/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	05/06/2025			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				

Facility Summary in Flathead County in the City of Bigfork

Location: MEADOWLARK ENTERPRISES LLC
20221 MT Hwy 35
Bigfork, MT 59911-7254 Flathead

System Facility ID:56-14137

Facility Code: 30773
Last Inspected On: 04/19/2023
Operating Permit Renewal Date: 07/02/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Meadowlark Enterprises LLC	**(415) 225-2249**	**michael@baumer.us**
Operator Contact:	Michael Baumer;Stephen Baumer;Meadowlark Enterprises LLC	**(415) 225-2249**	**michael@baumer.us;stephen@baumer.us;michael@baumer.us**

Owner/Operator: Meadowlark Enterprises LLC (415) 225-2249 michael@baumer.us

Michael Baumer, UST Class A Operator	michael@baumer.us
Michael Baumer, UST Class B Operator	michael@baumer.us
Stephen Baumer, UST Class A Operator	michael@baumer.us
Stephen Baumer, UST Class B Operator	michael@baumer.us

Tank Number	01	**Tank Age**	20	**Tank Installed Date**	03/21/2005	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	5024	**Spill Test Date**	09/15/2021	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	11/12/2012	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	03/11/2011	**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	1000	**ATG Test Date**	04/19/2023	**Line Tightness Test Date**	06/30/2020	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	04/19/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Flathead County in the City of Bigfork

Location: MONTANA RANCH LLC
1463 Hwy 83
Bigfork, MT 59911 Flathead

System Facility ID:60-15198

Facility Code: 30919
Last Inspected On: 02/05/2024
Operating Permit Renewal Date: 03/23/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Montana Ranch LLC Bigfork	**(406) 755-0264**	**mattc@sabey.com**
Operator Contact:	Matt Cottle	**(406) 253-8403**	**mattc@sabey.com**

Owner/Operator: Montana Ranch LLC Bigfork (406) 755-0264 mattc@sabey.com

Matt Cottle, UST Class A Operator mattc@sabey.com

Matt Cottle, UST Class B Operator mattc@sabey.com

Tank Number	01	**Tank Age**	14	**Tank Installed Date**	08/29/2011	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Steel	**Overfill Types**	Flapper Valve
Tag Number	5327	**Spill Test Date**	02/05/2024	**Piping Installed Date**	08/29/2011	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	2500	**ATG Test Date**	02/05/2024	**Line Tightness Test Date**	10/06/2011	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	Yes
		Overfill Test Date	02/05/2024			**ATG Type**	Gilbarco-Veeder Root/EMC Basic				
Tank Number	02	**Tank Age**	14	**Tank Installed Date**	08/29/2011	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Steel	**Overfill Types**	Flapper Valve
Tag Number	5328	**Spill Test Date**	02/05/2024	**Piping Installed Date**	08/29/2011	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	2500	**ATG Test Date**	02/05/2024	**Line Tightness Test Date**	10/06/2011	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	Yes
		Overfill Test Date	02/05/2024			**ATG Type**	Gilbarco-Veeder Root/EMC Basic				

Facility Summary in Flathead County in the City of Bigfork

Location: O'CONNELLS QWICK STOP
21385 MT Hwy 83
Bigfork, MT 59911-7811 Flathead

System Facility ID:24-05644

Facility Code: 22977
Last Inspected On: 10/08/2023
Operating Permit Renewal Date: 11/26/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	PH and J Enterprises LLC;Preston O'Connell	**(406) 886-2300**	**froggitha@gmail.com**
Operator Contact:	Keith Broere	**(406) 360-4417**	**kbroere@aetmt.com**
Owner/Operator:	PH and J Enterprises LLC	(406) 886-2300	froggitha@gmail.com
Owner/Operator:	Preston O'Connell	(406) 886-2300	froggitha@gmail.com
	Keith Broere, UST Class A Operator		kbroere@aetmt.com
	Keith Broere, UST Class B Operator		kbroere@aetmt.com

Tank Number	04	**Tank Age**	39	**Tank Installed Date**	05/07/1986	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	3325	**Spill Test Date**	10/06/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Single Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	10/06/2023	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	10/06/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	10/06/2023	**Line Tightness Test Date**	10/06/2023	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	10/06/2023			**ATG Type**	Incon/TS-1000				
Tank Number	05	**Tank Age**	39	**Tank Installed Date**	05/07/1986	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	3326	**Spill Test Date**	10/06/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	10/06/2023	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	10/06/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	10/06/2023	**Line Tightness Test Date**	10/06/2023	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	10/06/2023			**ATG Type**	Incon/TS-1000				
Tank Number	06	**Tank Age**	29	**Tank Installed Date**	07/01/1996	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve

Tag Number	3327	**Spill Test Date**	10/06/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	10/06/2023	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	10/06/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**	10/06/2023	**Line Tightness Test Date**	10/06/2023	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	10/06/2023			**ATG Type**	Incon/TS-1000				
Tank Number	07	**Tank Age**	29	**Tank Installed Date**	07/01/1996	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	3328	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Temporarily Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	10/06/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.1;Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**		**Line Tightness Test Date**	03/08/2011	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**	Incon/TS-1000				

Facility Summary in Flathead County in the City of Bigfork

Location: PAPAS MARKET
14535 MT Hwy 35
Bigfork, MT 59911 Flathead

System Facility ID:24-06085

Facility Code: 22990
Last Inspected On: 09/06/2023
Operating Permit Renewal Date: 03/28/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: GEMBALA CORP **(406) 837-4884**

Operator Contact: Shawn Gembala **(406) 837-4884** **papasmarket.gembala@gmail.com**

Owner/Operator: GEMBALA CORP (406) 837-4884

Shawn Gembala, UST Class A Operator papasmarket.gembala@gmail.com
Shawn Gembala, UST Class B Operator papasmarket.gembala@gmail.com
Shawn Kneeland, UST Class B Global Operator

Tank Number	01	**Tank Age**	41	**Tank Installed Date**	01/30/1984	**Tank Material Construction**	Bare Steel	**Piping Material**	Steel	**Overfill Types**	Flapper Valve
Tag Number	1279	**Spill Test Date**	09/06/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	09/06/2023	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	09/06/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	11/30/2023	**Line Tightness Test Date**	09/06/2023	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	09/06/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-300				
Tank Number	02	**Tank Age**	41	**Tank Installed Date**	01/30/1984	**Tank Material Construction**	Bare Steel	**Piping Material**	Steel	**Overfill Types**	Flapper Valve
Tag Number	1280	**Spill Test Date**	09/06/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	09/06/2023	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	09/06/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**	11/30/2023	**Line Tightness Test Date**	09/06/2023	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	09/06/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-300				
Tank Number	03	**Tank Age**	31	**Tank Installed Date**	05/01/1994	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Steel	**Overfill Types**	Flapper Valve

Tag Number	1281	**Spill Test Date**	09/06/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	09/06/2023	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Impressed Current
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	09/06/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	11/30/2023	**Line Tightness Test Date**	05/13/2016	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	09/06/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-300				

Facility Summary in Flathead County in the City of Bigfork

Location: YOUR TURN CONVENIENCE STOP
7505 MT Hwy 35
Bigfork, MT 59911-6215 Flathead

System Facility ID:15-02482

Facility Code: 20582
Last Inspected On: 05/03/2023
Operating Permit Renewal Date: 08/08/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	White Enterprises	**(406) 837-6170**	**yourturnmercantile@hotmail.com**
Operator Contact:	Charity Neal;Your Turn Convenience Stop	**(406) 837-6170**	**ytm1993@yahoo.com**

Owner/Operator: White Enterprises (406) 837-6170 yourturnmercantile@hotmail.com
Charity Neal, UST Class A Operator ytm1993@yahoo.com
Charity Neal, UST Class B Operator ytm1993@yahoo.com

Tank Number	06	**Tank Age**	28	**Tank Installed Date**	01/10/1997	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve
Tag Number	3185	**Spill Test Date**	12/21/2021	**Piping Installed Date**	07/25/2013	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	03/23/2022	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	05/02/2023	**Line Tightness Test Date**	02/03/2011	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date	01/05/2022			**ATG Type**	Incon/TS-550 EVO				
Tank Number	07	**Tank Age**	28	**Tank Installed Date**	01/10/1997	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	3186	**Spill Test Date**	05/03/2023	**Piping Installed Date**	07/25/2013	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	03/23/2022	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	05/02/2023	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**		**Line Tightness Test Date**	02/03/2011	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date	05/03/2023			**ATG Type**	Incon/TS-550 EVO				
Tank Number	08	**Tank Age**	28	**Tank Installed Date**	01/10/1997	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve

Tag Number	3187	**Spill Test Date**	05/03/2023	**Piping Installed Date**	07/25/2013	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	03/23/2022	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	05/03/2023	**Line Tightness Test Date**	02/03/2011	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date	05/03/2023			**ATG Type**	Incon/TS-550 EVO				
Tank Number	09	**Tank Age**	28	**Tank Installed Date**	11/01/1997	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve
Tag Number	3188	**Spill Test Date**	12/22/2021	**Piping Installed Date**	07/25/2013	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	03/23/2022	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	05/02/2023	**Line Tightness Test Date**	02/03/2011	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date	01/05/2022			**ATG Type**	Incon/TS-550 EVO				

Facility Summary in Flathead County in the City of Columbia Falls

Location: CSV CARDLOCK NORTH
195 Truck Route Rd
Columbia Falls, MT 59912 Flathead

System Facility ID:15-12972

Facility Code: 21018
Last Inspected On: 08/22/2023
Operating Permit Renewal Date: 10/02/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: City Service Valcon LLC **tamara.noble@cityservicevalcon.com**

Operator Contact: Kary Tonjum **(406) 755-4321**

Owner/Operator: City Service Valcon LLC tamara.noble@cityservicevalcon.com

Kary Tonjum, UST Class A Operator

Kary Tonjum, UST Class B Global Operator

Tank Number	01	**Tank Age**	33	**Tank Installed Date**	12/15/1992	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	4404	**Spill Test Date**	05/03/2023	**Piping Installed Date**	10/02/2014	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	05/03/2023	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**	05/03/2023	**Tank/Piping CP Test Date**	05/03/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	15000	**ATG Test Date**	05/03/2023	**Line Tightness Test Date**	09/29/2014	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date	05/03/2023			**ATG Type**	Veeder Root/TLS-450				
Tank Number	04	**Tank Age**	33	**Tank Installed Date**	11/15/1992	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	4405	**Spill Test Date**	11/11/2021	**Piping Installed Date**	10/02/2014	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	04/07/2021	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	04/19/2017	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	5000	**ATG Test Date**		**Line Tightness Test Date**	09/29/2014	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date	11/29/2021			**ATG Type**	Veeder Root/TLS-450				
Tank Number	05	**Tank Age**	33	**Tank Installed Date**	11/15/1992	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve

Tag Number	4406	**Spill Test Date**	04/07/2021	**Piping Installed Date**	10/02/2014	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	04/07/2021	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	05/28/2020	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	5000	**ATG Test Date**		**Line Tightness Test Date**	09/29/2014	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date				**ATG Type**	Veeder Root/TLS-450				
Tank Number	03	**Tank Age**	33	**Tank Installed Date**	11/15/1992	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	4407	**Spill Test Date**	04/07/2021	**Piping Installed Date**	10/02/2014	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	04/07/2021	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	05/28/2020	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**		**Line Tightness Test Date**	09/29/2014	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date				**ATG Type**	Veeder Root/TLS-450				
Tank Number	02	**Tank Age**	33	**Tank Installed Date**	11/15/1992	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	4408	**Spill Test Date**	05/03/2023	**Piping Installed Date**	10/02/2014	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	05/03/2023	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**	05/03/2023	**Tank/Piping CP Test Date**	05/03/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	05/03/2023	**Line Tightness Test Date**	09/29/2014	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date	05/03/2023			**ATG Type**	Veeder Root/TLS-450				

Facility Summary in Flathead County in the City of Columbia Falls

Location: HI-STAR PROPERTIES LLC
7356 US Hwy 2 E
Columbia Falls, MT 59912-9107 Flathead

System Facility ID:15-11333

Facility Code: 20934
Last Inspected On: 07/28/2022
Operating Permit Renewal Date: 08/02/2025

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Hi-Star Properties LLC **histarms3@yahoo.com**

Operator Contact: Wade Lindsay **(406) 890-0968** **wade.w.lindsay@gmail.com**

Owner/Operator: Hi-Star Properties LLC histarms3@yahoo.com

Wade Lindsay, UST Class A Operator wade.w.lindsay@gmail.com

Wade Lindsay, UST Class B Global Operator wade.w.lindsay@gmail.com

Tank Number	01	**Tank Age**	35	**Tank Installed Date**	01/01/1990	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve;High Level Alarm
Tag Number	686	**Spill Test Date**	03/21/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	07/27/2022	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	04/26/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	07/27/2022	**Line Tightness Test Date**	07/27/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	03/22/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	02	**Tank Age**	35	**Tank Installed Date**	01/01/1990	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve;High Level Alarm
Tag Number	687	**Spill Test Date**	03/21/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	07/27/2022	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	07/27/2022	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	07/27/2022	**Line Tightness Test Date**	07/27/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	03/22/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	03	**Tank Age**	35	**Tank Installed Date**	01/01/1990	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve;High Level Alarm

Tag Number	688	**Spill Test Date**	03/21/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	07/27/2022	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	07/27/2022	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**	07/27/2022	**Line Tightness Test Date**	07/27/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	03/22/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	04	**Tank Age**	35	**Tank Installed Date**	01/01/1990	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve;High Level Alarm
Tag Number	689	**Spill Test Date**	03/21/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	07/27/2022	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	07/27/2022	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	07/27/2022	**Line Tightness Test Date**	07/27/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	03/22/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Flathead County in the City of Columbia Falls

Location: JUNCTION GAS
7322 US Hwy 2 E
Columbia Falls, MT 59912-9107 Flathead

System Facility ID:15-02820

Facility Code: 20587
Last Inspected On: 10/10/2022
Operating Permit Renewal Date: 12/24/2025

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Kalispell Properties LLC	**(509) 994-6599**	**histarms01@yahoo.com**
Operator Contact:	David Brotnov;Ramdeep Kaur	**(406) 892-2004;(803) 522-5352**	**ramdeeprokha@yahoo.com**

Owner/Operator: Kalispell Properties LLC (509) 994-6599 histarms01@yahoo.com

David M Brotnov, UST Class A Operator
Marlene Sevesind, UST Class B Global Operator
Ramdeep Kaur, UST Class A Operator ramdeeprokha@yahoo.com
Ramdeep Kaur, UST Class B Global Operator ramdeeprokha@yahoo.com
Ramdeep Kaur, UST Class B Operator ramdeeprokha@yahoo.com

Tank Number	01	**Tank Age**	48	**Tank Installed Date**	07/01/1977	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	496	**Spill Test Date**	09/22/2022	**Piping Installed Date**		**Tank Construction**	Lined Interior/Impressed Current	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	12/06/2016	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	09/22/2022	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	09/22/2022	**Line Tightness Test Date**	06/29/2010	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	09/22/2022			**ATG Type**	Gilbarco/EMC Basic				
Tank Number	02	**Tank Age**	48	**Tank Installed Date**	07/01/1977	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	497	**Spill Test Date**	09/22/2022	**Piping Installed Date**		**Tank Construction**	Lined Interior/Impressed Current	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	09/22/2022	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No

Capacity	10000	**ATG Test Date**	09/22/2022	**Line Tightness Test Date**	12/06/2016	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	09/22/2022			**ATG Type**	Gilbarco/EMC Basic				
Tank Number	03	**Tank Age**	48	**Tank Installed Date**	07/01/1977	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	498	**Spill Test Date**	09/22/2022	**Piping Installed Date**		**Tank Construction**	Lined Interior/Impressed Current	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	12/06/2016	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Diesel, Dyed	**PLLD Test Date**		**Tank/Piping CP Test Date**	09/22/2022	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**	09/22/2022	**Line Tightness Test Date**	06/29/2010	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	09/22/2022			**ATG Type**	Gilbarco/EMC Basic				
Tank Number	04	**Tank Age**	37	**Tank Installed Date**	11/17/1988	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	499	**Spill Test Date**	10/06/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	09/22/2022	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**	09/22/2022	**Line Tightness Test Date**	12/06/2016	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	09/22/2022			**ATG Type**	Gilbarco/EMC Basic				

Facility Summary in Flathead County in the City of Columbia Falls

Location: MIKES OF COLUMBIA FALLS
1645 9th St W
Columbia Falls, MT 59912 Flathead

System Facility ID:15-06839

Facility Code: 20716
Last Inspected On: 06/30/2023
Operating Permit Renewal Date: 07/31/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Dan Elder;KMR LLC;KMR LLC	**(253) 985-5039;(406) 892-2078;(406) 892-2078**	**dane@mikesconoco.com;dane@mikesconoco.com;dane@mikesconoco.com**
Operator Contact:	Ronda Heil;Shawn Damphier	**(406) 892-2078**	**schopper12345@gmail.com**

Owner/Operator:	Dan Elder,KMR LLC	(253) 985-5039	dane@mikesconoco.com
Owner/Operator:	KMR LLC	(253) 985-5039	dane@mikesconoco.com
	Ronda Heil, UST Class A Operator		
	Ronda Heil, UST Class A Operator		
	Shawn Damphier, UST Class A Operator		schopper12345@gmail.com
	Shawn Damphier, UST Class B Operator		schopper12345@gmail.com

Tank Number	06	**Tank Age**	29	**Tank Installed Date**	07/01/1996	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve
Tag Number	3366	**Spill Test Date**	11/30/2024	**Piping Installed Date**	03/30/2017	**Tank Construction**		**Piping Construction**	Secondary Containment Chase	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	11/30/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	01/22/2025	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	5000	**ATG Test Date**	01/22/2025	**Line Tightness Test Date**	02/25/2020	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date	06/29/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Tank Number	07	**Tank Age**	29	**Tank Installed Date**	07/01/1996	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve
Tag Number	3367	**Spill Test Date**	11/30/2024	**Piping Installed Date**	03/30/2017	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	11/30/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	01/22/2025	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No

Capacity	12000	**ATG Test Date**	01/22/2025	**Line Tightness Test Date**	02/26/2020	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date	06/29/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	08	**Tank Age**	29	**Tank Installed Date**	07/01/1996	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve
Tag Number	3368	**Spill Test Date**	06/29/2023	**Piping Installed Date**	03/30/2017	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	11/30/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	01/22/2025	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	15000	**ATG Test Date**	01/22/2025	**Line Tightness Test Date**	02/26/2020	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date	06/29/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	09	**Tank Age**	29	**Tank Installed Date**	07/01/1996	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve
Tag Number	3369	**Spill Test Date**	06/29/2023	**Piping Installed Date**	03/30/2017	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	11/30/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	01/22/2025	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	15000	**ATG Test Date**	01/22/2025	**Line Tightness Test Date**	02/25/2020	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date	06/29/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	05	**Tank Age**	29	**Tank Installed Date**	07/01/1996	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve
Tag Number	4466	**Spill Test Date**	06/28/2023	**Piping Installed Date**	03/30/2017	**Tank Construction**		**Piping Construction**	Secondary Containment Chase	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	06/28/2023	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	01/22/2025	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	01/22/2025	**Line Tightness Test Date**	02/25/2020	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date	06/29/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Flathead County in the City of Columbia Falls

Location: SMITHS #168 FUEL CENTER
150 Halfmoon Rd
Columbia Falls, MT 59912 Flathead

System Facility ID:60-15336

Facility Code: 32381
Last Inspected On: 05/17/2023
Operating Permit Renewal Date: 07/29/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Smiths Food and Drug	**(801) 974-1400**	**roger.gough@sfdc.com**
Operator Contact:	Braxton Hill;Kerry Busey	**(801) 977-1048**	**braxton.hill@sfdc.com;kerry.busey@sfdc.com**

Owner/Operator: Smiths Food and Drug (801) 974-1400 roger.gough@sfdc.com

Braxton Hill, UST Class A Operator braxton.hill@sfdc.com
Braxton Hill, UST Class B Operator braxton.hill@sfdc.com
Kerry Busey, UST Class A Operator kerry.busey@sfdc.com
Kerry Busey, UST Class B Global Operator kerry.busey@sfdc.com

Tank Number	01	**Tank Age**	5	**Tank Installed Date**	01/27/2020	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	5926	**Spill Test Date**	09/22/2022	**Piping Installed Date**	01/27/2020	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	09/22/2022	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	Yes
Capacity	20000	**ATG Test Date**	09/24/2024	**Line Tightness Test Date**	02/20/2020	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	11/20/2024			**ATG Type**					
Tank Number	02	**Tank Age**	5	**Tank Installed Date**	01/27/2020	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	5927	**Spill Test Date**	09/22/2022	**Piping Installed Date**	01/27/2020	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	09/22/2022	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	09/24/2024	**Line Tightness Test Date**	02/20/2020	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	11/20/2024			**ATG Type**					

Tank Number	03	**Tank Age**	5	**Tank Installed Date**	01/27/2020	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	5928	**Spill Test Date**	12/28/2022	**Piping Installed Date**	01/27/2020	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	09/22/2022	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	Yes
Capacity	8000	**ATG Test Date**	09/24/2024	**Line Tightness Test Date**	02/20/2020	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	11/20/2024			**ATG Type**					

Facility Summary in Flathead County in the City of Columbia Falls

Location: TOWN PUMP INC COLUMBIA FALLS 1
502 9th St W
Columbia Falls, MT 59912-3808 Flathead

System Facility ID:15-08690

Facility Code: 20763
Last Inspected On: 03/10/2023
Operating Permit Renewal Date: 08/28/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Columbia Falls 1 Town Pump LLC	**(406) 497-6700**	**environmental@townpump.com**
Operator Contact:	Trent Biggers		**Trentb@townpump.com**

Owner/Operator:	Columbia Falls 1 Town Pump LLC	(406) 497-6700	environmental@townpump.com
	Trent Biggers, UST Class A Operator		Trentb@townpump.com
	Trent Biggers, UST Class A Operator		Trentb@townpump.com
	Trent Biggers, UST Class B Global Operator		Trentb@townpump.com
	Trent Biggers, UST Class B Global Operator		Trentb@townpump.com

Tank Number	02	**Tank Age**	44	**Tank Installed Date**	07/14/1981	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	2420	**Spill Test Date**	03/12/2025	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	03/12/2025	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**	02/07/2022	**Tank/Piping CP Test Date**	09/19/2022	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	Yes
Capacity	12000	**ATG Test Date**	03/12/2025	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	09/19/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Number	07	**Tank Age**	36	**Tank Installed Date**	07/14/1989	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	2423	**Spill Test Date**	03/12/2025	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	03/12/2025	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Gasoline	**PLLD Test Date**	02/07/2022	**Tank/Piping CP Test Date**	02/07/2022	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	Yes
Capacity	12000	**ATG Test Date**	03/12/2025	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No

		Overfill Test Date	09/19/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Number	05	**Tank Age**	40	**Tank Installed Date**	10/01/1985	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	4380	**Spill Test Date**	03/12/2025	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	03/12/2025	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**	02/07/2022	**Tank/Piping CP Test Date**	09/19/2022	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	03/12/2025	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	09/19/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Number	06	**Tank Age**	36	**Tank Installed Date**	07/14/1989	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	4381	**Spill Test Date**	03/12/2025	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	03/12/2025	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Gasoline	**PLLD Test Date**	02/07/2022	**Tank/Piping CP Test Date**	02/07/2022	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	Yes
Capacity	12000	**ATG Test Date**	03/12/2025	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	09/19/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				

Facility Summary in Flathead County in the City of Columbia Falls

Location: TOWN PUMP INC COLUMBIA FALLS 2
6102 US Hwy 2 W
Columbia Falls, MT 59912-8927 Flathead

System Facility ID:56-13825

Facility Code: 30511
Last Inspected On: 03/10/2023
Operating Permit Renewal Date: 08/29/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Columbia Falls 2 Town Pump LLC **(406) 497-6700** **environmental@townpump.com**

Operator Contact: Trent Biggers **Trentb@townpump.com**

Owner/Operator: Columbia Falls 2 Town Pump LLC (406) 497-6700 environmental@townpump.com

Trent Biggers, UST Class A Operator Trentb@townpump.com
Trent Biggers, UST Class A Operator Trentb@townpump.com
Trent Biggers, UST Class B Global Operator Trentb@townpump.com
Trent Biggers, UST Class B Global Operator Trentb@townpump.com

Tank Number	01	**Tank Age**	28	**Tank Installed Date**	10/01/1997	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	2674	**Spill Test Date**	09/21/2022	**Piping Installed Date**	10/08/2013	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	09/21/2022	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	05/11/2021	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	Yes
Capacity	12000	**ATG Test Date**	03/09/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	No
		Overfill Test Date	09/21/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-450				
Tank Number	03	**Tank Age**	28	**Tank Installed Date**	10/01/1997	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	2676	**Spill Test Date**	09/21/2022	**Piping Installed Date**	10/08/2013	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	09/21/2022	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	05/11/2021	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	Yes
Capacity	10000	**ATG Test Date**	03/09/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	No
		Overfill Test Date	11/17/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-450				

Tank Number	04	**Tank Age**	28	**Tank Installed Date**	10/01/1997	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve
Tag Number	2677	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Approved Remote Monitoring;MLLD Line Tightness Testing;Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	20000	**ATG Test Date**		**Line Tightness Test Date**	11/12/2015	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	05	**Tank Age**	28	**Tank Installed Date**	10/01/1997	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve
Tag Number	2678	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Approved Remote Monitoring;MLLD Line Tightness Testing;Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**		**Line Tightness Test Date**	11/12/2015	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	06	**Tank Age**	28	**Tank Installed Date**	10/01/1997	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve
Tag Number	2679	**Spill Test Date**		**Piping Installed Date**	09/18/2014	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**	10/07/2014	**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Approved Remote Monitoring;MLLD Line Tightness Testing;Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**		**Line Tightness Test Date**	11/12/2015	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No

		Overfill Test Date				**ATG Type**					
Tank Number	07	**Tank Age**	25	**Tank Installed Date**	10/01/2000	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve
Tag Number	4249	**Spill Test Date**		**Piping Installed Date**	06/20/2012	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Pressurized	**CP Met Types**	
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Approved Remote Monitoring;Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	30000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	08	**Tank Age**	25	**Tank Installed Date**	10/01/2000	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve
Tag Number	4250	**Spill Test Date**		**Piping Installed Date**	06/20/2012	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Pressurized	**CP Met Types**	
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Approved Remote Monitoring;Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	30000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	02	**Tank Age**	28	**Tank Installed Date**	10/01/1997	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	4670	**Spill Test Date**	09/21/2022	**Piping Installed Date**	10/08/2013	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	09/21/2022	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	05/11/2021	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	03/09/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	No
		Overfill Test Date	11/17/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-450				

Tank Number	09	**Tank Age**	10	**Tank Installed Date**	10/02/2015	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	5600	**Spill Test Date**	09/21/2022	**Piping Installed Date**	10/07/2015	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	09/21/2022	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	05/11/2021	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	Yes
Capacity	15000	**ATG Test Date**	03/09/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Statistical Inventory Reconciliation	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	Yes
		Overfill Test Date	09/21/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-450				
Tank Number	10	**Tank Age**	10	**Tank Installed Date**	10/02/2015	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	5601	**Spill Test Date**	09/21/2022	**Piping Installed Date**	10/07/2015	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	09/21/2022	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	05/11/2021	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	Yes
Capacity	6000	**ATG Test Date**	03/09/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Statistical Inventory Reconciliation	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	Yes
		Overfill Test Date	09/21/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-450				
Tank Number	11	**Tank Age**	4	**Tank Installed Date**	01/18/2021	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	5995	**Spill Test Date**	09/21/2022	**Piping Installed Date**	01/18/2021	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	09/21/2022	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	05/11/2021	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	Yes
Capacity	6000	**ATG Test Date**	03/09/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Statistical Inventory Reconciliation	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	Yes
		Overfill Test Date	09/21/2022			**ATG Type**					
Tank Number	12	**Tank Age**	4	**Tank Installed Date**	01/18/2021	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	5996	**Spill Test Date**	09/21/2022	**Piping Installed Date**	01/18/2021	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No

Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	09/21/2022	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	05/11/2021	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	Yes
Capacity	8000	**ATG Test Date**	03/09/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Statistical Inventory Reconciliation	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	Yes
		Overfill Test Date	09/21/2022			**ATG Type**					
Tank Number	13	**Tank Age**	4	**Tank Installed Date**	01/18/2021	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	5997	**Spill Test Date**	09/21/2022	**Piping Installed Date**	01/18/2021	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	09/21/2022	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	05/11/2021	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	Yes
Capacity	6000	**ATG Test Date**	03/09/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Statistical Inventory Reconciliation	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	Yes
		Overfill Test Date	09/21/2022			**ATG Type**					
Tank Number	14	**Tank Age**	4	**Tank Installed Date**	01/18/2021	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	
Tag Number	5998	**Spill Test Date**	09/29/2020	**Piping Installed Date**		**Tank Construction**		**Piping Construction**		**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	09/29/2020	**Catastrophic L.D. Type 3.0**		**Piping Type**	Pressurized	**CP Met Types**	
Product	DEF (Not Regulated)	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	09/29/2020			**ATG Type**					
Tank Number	15	**Tank Age**	4	**Tank Installed Date**	01/18/2021	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	6009	**Spill Test Date**	09/21/2022	**Piping Installed Date**	01/18/2021	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	09/21/2022	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	05/11/2021	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	30000	**ATG Test Date**	03/09/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Statistical Inventory Reconciliation	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	Yes

		Overfill Test Date	09/21/2022			**ATG Type**					
Tank Number	16	**Tank Age**	4	**Tank Installed Date**	01/18/2021	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	6010	**Spill Test Date**	09/21/2022	**Piping Installed Date**	01/18/2021	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	09/21/2022	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	05/11/2021	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	03/09/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Statistical Inventory Reconciliation	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	Yes
		Overfill Test Date	09/21/2022			**ATG Type**					
Tank Number	17	**Tank Age**	4	**Tank Installed Date**	01/18/2021	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	6011	**Spill Test Date**	09/21/2022	**Piping Installed Date**	01/18/2021	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	09/21/2022	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel, Dyed	**PLLD Test Date**	05/11/2021	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	03/09/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Statistical Inventory Reconciliation	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	Yes
		Overfill Test Date	09/21/2022			**ATG Type**					

Facility Summary in Flathead County in the City of Coram

Location: GLACIER CENTER
10049 US Hwy 2 E
Coram, MT 59913 Flathead

System Facility ID:15-10895

Facility Code: 20898
Last Inspected On: 05/03/2023
Operating Permit Renewal Date: 06/03/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Kalispell Properties LLC	**(509) 994-6599**	**histarms01@yahoo.com**
Operator Contact:	Rhonda Andverson;Wade Lindsay;Kalispell Properties LLC	**(406) 38-75090;(406) 890-0968;(509) 994-6599**	**glaciercentergas@gmail.com;wade.w.lindsay@gmail.com;histarms01@yahoo.com**

Owner/Operator: Kalispell Properties LLC (509) 994-6599 histarms01@yahoo.com

Rhonda Andverson, UST Class A Operator	glaciercentergas@gmail.com
Wade Lindsay, UST Class A Operator	histarms01@yahoo.com
Wade Lindsay, UST Class A Operator	histarms01@yahoo.com
Wade Lindsay, UST Class B Operator	histarms01@yahoo.com
Wade Lindsay, UST Class B Operator	histarms01@yahoo.com

Tank Number	04	**Tank Age**	37	**Tank Installed Date**	04/17/1988	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve
Tag Number	1883	**Spill Test Date**	05/03/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	05/03/2023	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	05/03/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**	05/03/2023	**Line Tightness Test Date**	05/03/2023	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	05/03/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	05	**Tank Age**	30	**Tank Installed Date**	05/01/1995	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve
Tag Number	1884	**Spill Test Date**	05/03/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	05/03/2023	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	05/28/2014	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	05/03/2023	**Line Tightness Test Date**	05/03/2023	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No

		Overfill Test Date	05/03/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	06	**Tank Age**	30	**Tank Installed Date**	05/01/1995	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve
Tag Number	1885	**Spill Test Date**	05/03/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	05/03/2023	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	05/28/2014	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	05/03/2023	**Line Tightness Test Date**	05/03/2023	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	05/03/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	07	**Tank Age**	30	**Tank Installed Date**	05/01/1995	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve
Tag Number	1886	**Spill Test Date**	05/03/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	05/03/2023	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	05/28/2014	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	5000	**ATG Test Date**	05/03/2023	**Line Tightness Test Date**	05/03/2023	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	05/03/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Flathead County in the City of Hungry Horse

Location: BOBS SINCLAIR HUNGRY HORSE
8930 US Hwy 2 E
Hungry Horse, MT 59919 Flathead

System Facility ID:15-07506

Facility Code: 20733
Last Inspected On: 01/24/2024
Operating Permit Renewal Date: 03/24/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	SCR Investment LLC	**(406) 206-3676**	**snowman190202@gmail.com**
Operator Contact:	Jeff Johnson	**(406) 260-3676**	**snowman190202@gmail.com**

Owner/Operator:	SCR Investment LLC	(406) 206-3676	snowman190202@gmail.com
	Jeff Johnson, UST Class A Operator		snowman190202@gmail.com
	Jeff Johnson, UST Class A Operator		snowman190202@gmail.com
	Jeff Johnson, UST Class B Operator		snowman190202@gmail.com
	Jeff Johnson, UST Class B Operator		snowman190202@gmail.com

Tank Number	01	**Tank Age**	45	**Tank Installed Date**	09/01/1980	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve;Flapper Valve
Tag Number	4180	**Spill Test Date**	04/15/2021	**Piping Installed Date**	04/15/2021	**Tank Construction**	Lined Interior/Impressed Current	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	03/17/2021	**Sump Tightness Test Date**	04/15/2021	**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	04/28/2021	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	2000	**ATG Test Date**		**Line Tightness Test Date**	04/28/2021	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	MLLD Line Tightness Testing	**Energy Act**	No
		Overfill Test Date	04/15/2021			**ATG Type**	Gilbarco-Veeder Root/TLS-350				
Tank Number	02	**Tank Age**	45	**Tank Installed Date**	09/01/1980	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve;Flapper Valve
Tag Number	4181	**Spill Test Date**	04/15/2021	**Piping Installed Date**	04/15/2021	**Tank Construction**	Lined Interior/Impressed Current	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	04/15/2021	**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Safe Suction	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	04/28/2021	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**		**Line Tightness Test Date**	04/28/2021	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	MLLD Line Tightness Testing	**Energy Act**	No

		Overfill Test Date	04/15/2021			**ATG Type**	Gilbarco-Veeder Root/TLS-350				
Tank Number	03	**Tank Age**	45	**Tank Installed Date**	09/01/1980	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve;Flapper Valve
Tag Number	4182	**Spill Test Date**	04/15/2021	**Piping Installed Date**	04/15/2021	**Tank Construction**	Lined Interior/Impressed Current	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	03/17/2021	**Sump Tightness Test Date**	04/15/2021	**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	04/28/2021	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**		**Line Tightness Test Date**	04/28/2021	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	MLLD Line Tightness Testing	**Energy Act**	No
		Overfill Test Date	04/15/2021			**ATG Type**	Gilbarco-Veeder Root/TLS-350				
Tank Number	04	**Tank Age**	45	**Tank Installed Date**	09/01/1980	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve;Flapper Valve
Tag Number	4183	**Spill Test Date**	04/15/2021	**Piping Installed Date**	04/15/2021	**Tank Construction**	Lined Interior/Impressed Current	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	03/17/2021	**Sump Tightness Test Date**	04/15/2021	**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	04/28/2021	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**		**Line Tightness Test Date**	04/28/2021	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	MLLD Line Tightness Testing	**Energy Act**	No
		Overfill Test Date	04/15/2021			**ATG Type**	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Flathead County in the City of Hungry Horse

Location: CENEX ZIP TRIP 71
8840 US Hwy 2 E
Hungry Horse, MT 59919 Flathead

System Facility ID:15-09708

Facility Code: 20804
Last Inspected On: 11/07/2024
Operating Permit Renewal Date: 04/29/2028

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	CHS Inc Spokane Valley	**(509) 535-7701**	**Donald.Widdicombe@chsinc.com**
Operator Contact:	Jim Alford;Sean Hurley	**(509) 535-7701;(509) 536-7418**	**jim.alford@chsinc.com;sean.hurley@chsinc.com**

Owner/Operator: CHS Inc Spokane Valley (509) 535-7701 Donald.Widdicombe@chsinc.com

Jason Brenner, UST Class B Operator	jason.brenner@chsinc.com
Jim Alford, UST Class A Operator	jim.alford@chsinc.com
Jim Alford, UST Class A Operator	jim.alford@chsinc.com
Jim Alford, UST Class B Operator	jim.alford@chsinc.com
Jim Alford, UST Class B Operator	jim.alford@chsinc.com
Luci Tuttle, UST Class B Operator	Lucinda.Tuttle@chsinc.com
Sean Hurley, UST Class A Operator	sean.hurley@chsinc.com
Sean Hurley, UST Class A Operator	sean.hurley@chsinc.com

Tank Number	05	**Tank Age**	7	**Tank Installed Date**	10/23/2018	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	5855	**Spill Test Date**	11/07/2024	**Piping Installed Date**	10/23/2018	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	11/07/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	08/07/2024	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	20000	**ATG Test Date**	08/07/2024	**Line Tightness Test Date**	10/18/2018	**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	03/10/2025			**ATG Type**	Gilbarco-Veeder Root/TLS-450;Veeder Root/TLS-450				
Tank Number	06	**Tank Age**	7	**Tank Installed Date**	10/23/2018	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	5856	**Spill Test Date**	11/07/2024	**Piping Installed Date**	10/23/2018	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	11/07/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible

Product	Gasoline	**PLLD Test Date**	08/07/2024	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	08/07/2024	**Line Tightness Test Date**	10/18/2018	**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	03/10/2025			**ATG Type**	Gilbarco-Veeder Root/TLS-450;Veeder Root/TLS-450				
Tank Number	07	**Tank Age**	7	**Tank Installed Date**	10/23/2018	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	5857	**Spill Test Date**	11/07/2024	**Piping Installed Date**	10/23/2018	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	11/07/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	08/07/2024	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	08/07/2024	**Line Tightness Test Date**	10/18/2018	**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	03/10/2025			**ATG Type**	Gilbarco-Veeder Root/TLS-450;Veeder Root/TLS-450				
Tank Number	08	**Tank Age**	7	**Tank Installed Date**	10/23/2018	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	5858	**Spill Test Date**	11/07/2024	**Piping Installed Date**	10/23/2018	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	11/07/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	08/07/2024	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	08/07/2024	**Line Tightness Test Date**	10/18/2018	**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	03/10/2025			**ATG Type**	Gilbarco-Veeder Root/TLS-450;Veeder Root/TLS-450				
Tank Number	09	**Tank Age**	7	**Tank Installed Date**	10/23/2018	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	5859	**Spill Test Date**	11/07/2024	**Piping Installed Date**	10/23/2018	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	11/07/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	08/07/2024	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No

Capacity	10000	**ATG Test Date**	08/07/2024	**Line Tightness Test Date**	10/18/2018	**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	03/10/2025			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				

Facility Summary in Flathead County in the City of Kalispell

Location: APPLEWAY CONOCO
100 N Meridian Rd
Kalispell, MT 59901-3848 Flathead

System Facility ID:15-00113

Facility Code: 20517
Last Inspected On: 10/12/2023
Operating Permit Renewal Date: 01/12/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Appleway Conoco

Operator Contact: Linda Bertoli **(509) 315-9959** **lindabertoli@gmail.com**

Owner/Operator: Appleway Conoco

Linda Bertoli, UST Class A Operator lindabertoli@gmail.com
Linda Bertoli, UST Class B Operator lindabertoli@gmail.com

Tank Number	01	**Tank Age**	46	**Tank Installed Date**	12/31/1979	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	3141	**Spill Test Date**	03/10/2022	**Piping Installed Date**		**Tank Construction**	Lined Interior/Impressed Current	**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	08/31/2023	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	08/31/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	08/31/2023	**Line Tightness Test Date**	08/31/2023	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	03/10/2022			**ATG Type**	Gilbarco/EMC Basic				
Tank Number	02	**Tank Age**	46	**Tank Installed Date**	12/31/1979	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	3142	**Spill Test Date**	03/10/2022	**Piping Installed Date**		**Tank Construction**	Lined Interior/Impressed Current	**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	08/31/2023	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	08/31/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	08/31/2023	**Line Tightness Test Date**	08/31/2023	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	03/10/2022			**ATG Type**	Gilbarco/EMC Basic				
Tank Number	03	**Tank Age**	46	**Tank Installed Date**	12/31/1979	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve

Tag Number	3143	**Spill Test Date**	03/10/2022	**Piping Installed Date**		**Tank Construction**	Lined Interior/Impressed Current	**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	08/31/2023	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	08/31/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	08/31/2023	**Line Tightness Test Date**	08/31/2023	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	03/10/2022			**ATG Type**	Gilbarco/EMC Basic				

Facility Summary in Flathead County in the City of Kalispell

Location: BRAR FOOD STORE
1090 N Meridian Rd
Kalispell, MT 59901-3564 Flathead

System Facility ID:15-00110

Facility Code: 20514
Last Inspected On: 12/24/2024
Operating Permit Renewal Date: 03/23/2028

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	BRAR FOOD STORE INC	**(341) 345-8514**	**BFS.USA@YAHOO.COM**
Operator Contact:	Navneet Brar;BRAR FOOD STORE INC;Paramjit Singh;BRAR FOOD STORE INC	**(341) 345-8514**	**bfs.usa@xyz.com;BFS.USA@YAHOO.COM;brarnaman0@gmail.com; BFS.USA@YAHOO.COM**

Owner/Operator: BRAR FOOD STORE INC (341) 345-8514 BFS.USA@YAHOO.COM

Muskan Sohi, UST Class B Operator	4.sohi062@gmail.com
Navneet Brar, UST Class A Operator	BFS.USA@YAHOO.COM
Navneet Brar, UST Class B Operator	BFS.USA@YAHOO.COM
Paramjit Singh, UST Class A Operator	BFS.USA@YAHOO.COM
Paramjit Singh, UST Class B Operator	BFS.USA@YAHOO.COM

Tank Number	04	**Tank Age**	28	**Tank Installed Date**	11/01/1997	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	3171	**Spill Test Date**	01/15/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	12/09/2021	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	03/20/2025	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	12/09/2021	**Line Tightness Test Date**	12/09/2021	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	01/15/2022			**ATG Type**	Gilbarco/EMC Basic				
Tank Number	05	**Tank Age**	28	**Tank Installed Date**	11/01/1997	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	3172	**Spill Test Date**	11/23/2021	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	12/09/2021	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	03/20/2025	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	5000	**ATG Test Date**	12/09/2021	**Line Tightness Test Date**	12/09/2021	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	01/15/2022			**ATG Type**	Gilbarco/EMC Basic				

Tank Number	06	**Tank Age**	28	**Tank Installed Date**	11/01/1997	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	3173	**Spill Test Date**	01/15/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	12/09/2021	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	03/20/2025	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	5000	**ATG Test Date**	12/09/2021	**Line Tightness Test Date**	12/09/2021	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	01/15/2022			**ATG Type**	Gilbarco/EMC Basic				

Facility Summary in Flathead County in the City of Kalispell

Location: BRIANS C STORE
2075 US Hwy 2 E
Kalispell, MT 59901-2944 Flathead

System Facility ID:15-13730

Facility Code: 21091
Last Inspected On: 01/03/2024
Operating Permit Renewal Date: 01/14/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: DJL LLC **(406) 751-4623**

Operator Contact: Brian Kahler **(406) 360-6484** **muddsin1@yahoo.com**

Owner/Operator: DJL LLC (406) 751-4623

Brian Kahler, UST Class A Operator muddsin1@yahoo.com
Brian Kahler, UST Class B Global Operator muddsin1@yahoo.com

Tank Number	01	**Tank Age**	29	**Tank Installed Date**	06/01/1996	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve
Tag Number	3352	**Spill Test Date**	03/21/2024	**Piping Installed Date**	11/28/2023	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	11/20/2023	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	11/16/2023	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	20000	**ATG Test Date**	11/16/2023	**Line Tightness Test Date**	05/25/2021	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	03/21/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	02	**Tank Age**	29	**Tank Installed Date**	06/01/1996	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve
Tag Number	3353	**Spill Test Date**	03/21/2024	**Piping Installed Date**	11/28/2023	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	11/20/2023	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	11/16/2023	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	20000	**ATG Test Date**	11/16/2023	**Line Tightness Test Date**	08/07/2020	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	03/21/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Tank Number	03	**Tank Age**	29	**Tank Installed Date**	06/01/1996	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve
Tag Number	3354	**Spill Test Date**	11/16/2023	**Piping Installed Date**	11/28/2023	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	11/20/2023	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	11/16/2023	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	11/16/2023	**Line Tightness Test Date**	10/04/2020	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	03/21/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	04	**Tank Age**	29	**Tank Installed Date**	06/01/1996	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve
Tag Number	3355	**Spill Test Date**	11/16/2023	**Piping Installed Date**	11/28/2023	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	11/20/2023	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	11/16/2023	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	11/16/2023	**Line Tightness Test Date**	10/04/2020	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	11/16/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	05	**Tank Age**	29	**Tank Installed Date**	06/01/1996	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve
Tag Number	3356	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**		**Line Tightness Test Date**	05/28/2021	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	06	**Tank Age**	29	**Tank Installed Date**	06/01/1996	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve
Tag Number	3357	**Spill Test Date**	03/21/2024	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No

Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**		**Line Tightness Test Date**	04/28/2020	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	03/21/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Flathead County in the City of Kalispell

Location: BRIANS INC
1319 US Hwy 93 S
Kalispell, MT 59901-5765 Flathead

System Facility ID:15-09820

Facility Code: 20807
Last Inspected On: 05/18/2023
Operating Permit Renewal Date: 06/28/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Darryl Bjork;DJL LLC **(406) 751-4623;(406) 752-7339**

Operator Contact: Brian Kahler **(406) 360-6484** **muddsin1@yahoo.com**

Owner/Operator: Darryl Bjork (406) 752-7339

Owner/Operator: DJL LLC (406) 752-7339

Brian Kahler, UST Class A Operator muddsin1@yahoo.com
Brian Kahler, UST Class A Operator muddsin1@yahoo.com
Brian Kahler, UST Class B Global Operator muddsin1@yahoo.com
Brian Kahler, UST Class B Global Operator muddsin1@yahoo.com

Tank Number	05	**Tank Age**	30	**Tank Installed Date**	09/01/1995	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve;Flapper Valve
Tag Number	1847	**Spill Test Date**	05/17/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Single Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	05/17/2023	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	05/18/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	15000	**ATG Test Date**	05/17/2023	**Line Tightness Test Date**	05/17/2023	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	06/28/2023			**ATG Type**	Incon/TS-1000				
Tank Number	06	**Tank Age**	30	**Tank Installed Date**	09/01/1995	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve
Tag Number	1848	**Spill Test Date**	05/17/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	05/17/2023	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	05/18/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	15000	**ATG Test Date**	05/17/2023	**Line Tightness Test Date**	05/17/2023	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	05/17/2023			**ATG Type**	Incon/TS-1000				

Tank Number	07	**Tank Age**	30	**Tank Installed Date**	09/01/1995	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve;Flapper Valve
Tag Number	1849	**Spill Test Date**	06/27/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Single Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	05/17/2023	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	05/18/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	7500	**ATG Test Date**	05/17/2023	**Line Tightness Test Date**	05/17/2023	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	06/28/2023			**ATG Type**	Incon/TS-1000				
Tank Number	08	**Tank Age**	30	**Tank Installed Date**	09/01/1995	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve
Tag Number	1850	**Spill Test Date**	05/17/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	05/17/2023	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	05/18/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	7500	**ATG Test Date**	05/17/2023	**Line Tightness Test Date**	05/17/2023	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	05/17/2023			**ATG Type**	Incon/TS-1000				

Facility Summary in Flathead County in the City of Kalispell

Location: CHS - CENTRAL
55 4th Ave E N
Kalispell, MT 59901-4157 Flathead

System Facility ID:15-09705

Facility Code: 20802
Last Inspected On: 06/16/2020
Operating Permit Renewal Date: 06/16/2023

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Flathead County Economic Development Authority

Operator Contact: Bob Westin;Christy Dawson;Victor Hannam **victor.hannam@chsinc.com**

Bob Westin, UST Class A Operator	
Bob Westin, UST Class B Global Operator	
Christy Dawson, UST Class A Operator	
Christy Dawson, UST Class A Operator	
Christy Dawson, UST Class A Operator	
Christy Dawson, UST Class B Operator	
Christy Dawson, UST Class B Operator	
Christy Dawson, UST Class B Operator	
Victor Hannam, UST Class A Operator	victor.hannam@chsinc.com
Victor Hannam, UST Class A Operator	victor.hannam@chsinc.com
Victor Hannam, UST Class A Operator	victor.hannam@chsinc.com
Victor Hannam, UST Class A Operator	victor.hannam@chsinc.com
Victor Hannam, UST Class B Global Operator	victor.hannam@chsinc.com
Victor Hannam, UST Class B Global Operator	victor.hannam@chsinc.com
Victor Hannam, UST Class B Global Operator	victor.hannam@chsinc.com
Victor Hannam, UST Class B Global Operator	victor.hannam@chsinc.com

Tank Number	01	**Tank Age**	44	**Tank Installed Date**	03/26/1981	**Tank Material Construction**	Bare Steel	**Piping Material**	Steel	**Overfill Types**	Flapper Valve
Tag Number	3786	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	06/28/2017	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	40000	**ATG Test Date**		**Line Tightness Test Date**	07/06/2017	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD Line Tightness Testing	**Energy Act**	No

		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	02	**Tank Age**	44	**Tank Installed Date**	03/26/1981	**Tank Material Construction**	Bare Steel	**Piping Material**	Steel	**Overfill Types**	Flapper Valve
Tag Number	3787	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	06/28/2017	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	40000	**ATG Test Date**		**Line Tightness Test Date**	06/28/2017	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD Line Tightness Testing	**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	03	**Tank Age**	44	**Tank Installed Date**	03/26/1981	**Tank Material Construction**	Bare Steel	**Piping Material**	Steel	**Overfill Types**	Flapper Valve
Tag Number	3788	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	06/28/2017	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	40000	**ATG Test Date**		**Line Tightness Test Date**	06/28/2017	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD Line Tightness Testing	**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	08	**Tank Age**	26	**Tank Installed Date**	03/01/1999	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve
Tag Number	4075	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	16000	**ATG Test Date**		**Line Tightness Test Date**	06/28/2017	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD Line Tightness Testing	**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	09	**Tank Age**	26	**Tank Installed Date**	03/01/1999	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve
Tag Number	4076	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No

Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**		**Line Tightness Test Date**	08/04/2017	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Flathead County in the City of Kalispell

Location: CHS - WEST
120 W Idaho St
Kalispell, MT 59901 Flathead

System Facility ID:15-05069

Facility Code: 20654
Last Inspected On: 06/27/2017
Operating Permit Renewal Date: 06/30/2020

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: DOCO LLC

Operator Contact: Bob Westin

Bob Westin, UST Class A Operator

Bob Westin, UST Class B Global Operator

Tank Number	11	**Tank Age**	29	**Tank Installed Date**	03/01/1996	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	866	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	06/28/2017	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**		**Line Tightness Test Date**	03/16/2017	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring;ELLD Line Tightness Testing	**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	12	**Tank Age**	29	**Tank Installed Date**	03/01/1996	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	867	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	06/28/2017	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**		**Line Tightness Test Date**	03/16/2017	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring;ELLD Line Tightness Testing	**Energy Act**	No

		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	13	**Tank Age**	29	**Tank Installed Date**	03/01/1996	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	868	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	06/28/2017	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	30000	**ATG Test Date**		**Line Tightness Test Date**	03/16/2017	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring;ELLD Line Tightness Testing	**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Flathead County in the City of Kalispell

Location: CIRCLE K STORE 2746722
840 W Idaho St
Kalispell, MT 59901-3844 Flathead

System Facility ID:56-13985

Facility Code: 30646
Last Inspected On: 10/28/2021
Operating Permit Renewal Date: 03/30/2025

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Rocky Mountain Oil LLC	**(602) 728-8000**	**NT-ESS@Circlek.com**
Operator Contact:	Chuck Nyberg;Patrick Patnaude;Robert Deninno;Stephen Reckinger;Valeria Jeffries;Veronica Rivera	**(952) 830-8028;(952) 830-8721;(952) 830-8722**	**ESS-WestCoast@circlek.com;patrick.patnaude@holidaycompanies.com;steve.reckinger@holidaycompanies.com;valeria.jeffries@holidaycompanies.com**

Brad Lee, UST Class B Global Operator	brad.lee@holidaycompanies.com
Chuck Nyberg, UST Class A Operator	
Patrick Patnaude, UST Class A Operator	patrick.patnaude@holidaycompanies.com
Robert Deninno, UST Class A Operator	
Stephen Reckinger, UST Class A Operator	steve.reckinger@holidaycompanies.com
Todd White, UST Class B Global Operator	todd.white@holidaycompanies.com
Valeria Jeffries, UST Class A Operator	valeria.jeffries@holidaycompanies.com
Veronica Rivera, UST Class A Operator	ESS-WestCoast@circlek.com
Veronica Rivera, UST Class B Global Operator	ESS-WestCoast@circlek.com

Tank Number	01	**Tank Age**	25	**Tank Installed Date**	10/01/2000	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	4239	**Spill Test Date**	10/28/2021	**Piping Installed Date**	10/20/2000	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Gasoline	**PLLD Test Date**	10/28/2021	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	30000	**ATG Test Date**	10/28/2021	**Line Tightness Test Date**	07/24/2018	**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	10/28/2021			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	02	**Tank Age**	25	**Tank Installed Date**	10/01/2000	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	4240	**Spill Test Date**	10/28/2021	**Piping Installed Date**	10/20/2000	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No

Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	10/28/2021	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	20000	**ATG Test Date**	10/28/2021	**Line Tightness Test Date**	07/25/2018	**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	10/28/2021			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Flathead County in the City of Kalispell

Location: CITY SERVICE BULK PLANT
1841 3rd Ave E
Kalispell, MT 59901-5758 Flathead

System Facility ID:56-13824

Facility Code: 30510
Last Inspected On: 08/09/2022
Operating Permit Renewal Date: 12/24/2025

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: City Service Inc **(406) 755-4321**

Operator Contact: Drew Pike;Kary Tonjum;Margaret Flynn **(406) 294-0863;(406) 755-4321** **drewp@cityservicevalcon.com;margaretf@cityservicevalcon.com**

Owner/Operator: City Service Inc (406) 755-4321

Drew Pike, UST Class A Operator	drewp@cityservicevalcon.com
Drew Pike, UST Class B Global Operator	drewp@cityservicevalcon.com
Kary Tonjum, UST Class A Operator	
Kary Tonjum, UST Class B Global Operator	
Margaret Flynn, UST Class A Operator	margaretf@cityservicevalcon.com
Margaret Flynn, UST Class B Operator	margaretf@cityservicevalcon.com

Tank Number	01	**Tank Age**	28	**Tank Installed Date**	08/01/1997	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	681	**Spill Test Date**	04/15/2021	**Piping Installed Date**	09/28/2017	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	04/15/2021	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	05/13/2022	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	15000	**ATG Test Date**	05/13/2022	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date	05/13/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Tank Number	02	**Tank Age**	28	**Tank Installed Date**	08/01/1997	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	682	**Spill Test Date**	04/15/2021	**Piping Installed Date**	09/28/2017	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	04/15/2021	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	05/13/2022	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No

Capacity	15000	**ATG Test Date**	05/13/2022	**Line Tightness Test Date**	09/22/2016	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date	05/13/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	03	**Tank Age**	28	**Tank Installed Date**	08/01/1997	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	683	**Spill Test Date**	04/15/2021	**Piping Installed Date**	09/28/2017	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	04/15/2021	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	05/13/2022	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	20000	**ATG Test Date**	05/13/2022	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date	05/13/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	04	**Tank Age**	28	**Tank Installed Date**	08/01/1997	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	684	**Spill Test Date**	04/15/2021	**Piping Installed Date**	09/28/2017	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	04/15/2021	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel, Dyed	**PLLD Test Date**	05/13/2022	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	20000	**ATG Test Date**	05/13/2022	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date	05/13/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	05	**Tank Age**	28	**Tank Installed Date**	08/01/1997	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	685	**Spill Test Date**	04/15/2021	**Piping Installed Date**	09/28/2017	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	04/15/2021	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	05/13/2022	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	20000	**ATG Test Date**	05/13/2022	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date	05/13/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Flathead County in the City of Kalispell

Location: CITY SERVICE VALCON - EAGLE FUEL
3150 US Hwy 2
Kalispell, MT 59901 Flathead

System Facility ID:56-14014

Facility Code: 30674
Last Inspected On: 08/11/2022
Operating Permit Renewal Date: 12/31/2025

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: City Service Valcon LLC **tamara.noble@cityservicevalcon.com**

Operator Contact: Kary Tonjum **(406) 755-4321**

Owner/Operator: City Service Valcon LLC tamara.noble@cityservicevalcon.com

Kary Tonjum, UST Class A Operator
Kary Tonjum, UST Class B Global Operator

Tank Number	01	**Tank Age**	24	**Tank Installed Date**	07/01/2001	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	4605	**Spill Test Date**	02/02/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	04/15/2021	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	05/18/2022	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	05/18/2022	**Line Tightness Test Date**	12/13/2018	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	05/18/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	02	**Tank Age**	24	**Tank Installed Date**	07/01/2001	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	4606	**Spill Test Date**	02/02/2022	**Piping Installed Date**	12/20/2018	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	04/15/2021	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel, Dyed	**PLLD Test Date**	05/18/2022	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	05/18/2022	**Line Tightness Test Date**	12/13/2018	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date	05/18/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Tank Number	03	**Tank Age**	24	**Tank Installed Date**	07/01/2001	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	4607	**Spill Test Date**	04/15/2021	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	04/15/2021	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	05/18/2022	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	20000	**ATG Test Date**	05/18/2022	**Line Tightness Test Date**	12/13/2018	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	05/18/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	04	**Tank Age**	24	**Tank Installed Date**	07/01/2001	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	4608	**Spill Test Date**	02/02/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	04/15/2021	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	05/18/2022	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	05/18/2022	**Line Tightness Test Date**	12/13/2018	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	05/18/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Flathead County in the City of Kalispell

Location: CITY SERVICE VALCON LLC
52 5th Ave W N
Kalispell, MT 59901-3802 Flathead

System Facility ID:15-01680

Facility Code: 20552
Last Inspected On: 01/27/2025
Operating Permit Renewal Date: 05/01/2028

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	City Service Valcon LLC		**tamara.noble@cityservicevalcon.com**
Operator Contact:	Drew Pike;Jay Brookie;Kary Tonjum	**(406) 252-4661;(406) 755-4321**	**drewp@cityservicevalcon.com;jayb@cityservicevalcon.com**

Owner/Operator: City Service Valcon LLC — tamara.noble@cityservicevalcon.com

David Wines, UST Class B Global Operator	davidw@cityservicevalcon.com
Drew Pike, UST Class A Operator	drewp@cityservicevalcon.com
Drew Pike, UST Class B Global Operator	drewp@cityservicevalcon.com
Jay Brookie, UST Class A Operator	jayb@cityservicevalcon.com
Jay Brookie, UST Class B Global Operator	jayb@cityservicevalcon.com
Kary Tonjum, UST Class A Operator	
Kary Tonjum, UST Class B Operator	

Tank Number	09	**Tank Age**	27	**Tank Installed Date**	11/01/1998	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve
Tag Number	3689	**Spill Test Date**	05/01/2024	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	05/01/2024	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	25000	**ATG Test Date**	05/01/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	05/01/2024			**ATG Type**	Gilbarco/EMC				
Tank Number	10	**Tank Age**	27	**Tank Installed Date**	11/01/1998	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve
Tag Number	3690	**Spill Test Date**	05/01/2024	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	05/01/2024	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No

Capacity	25000	**ATG Test Date**	05/01/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	05/01/2024			**ATG Type**	Gilbarco/EMC				
Tank Number	11	**Tank Age**	27	**Tank Installed Date**	11/01/1998	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve
Tag Number	3691	**Spill Test Date**	05/01/2024	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	05/01/2024	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	20000	**ATG Test Date**	05/01/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	05/01/2024			**ATG Type**	Gilbarco/EMC				
Tank Number	12	**Tank Age**	27	**Tank Installed Date**	11/01/1998	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve
Tag Number	3692	**Spill Test Date**	05/01/2024	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	05/01/2024	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	15000	**ATG Test Date**	05/01/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	05/01/2024			**ATG Type**	Gilbarco/EMC				
Tank Number	13	**Tank Age**	27	**Tank Installed Date**	12/01/1998	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve
Tag Number	3693	**Spill Test Date**	05/01/2024	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Heating Oil	**PLLD Test Date**	05/01/2024	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	05/01/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	05/01/2024			**ATG Type**	Gilbarco/EMC				

Facility Summary in Flathead County in the City of Kalispell

Location: CONOCO CAR CARE CENTER
292 3rd Ave E N
Kalispell, MT 59901 Flathead

System Facility ID:15-01677

Facility Code: 20550
Last Inspected On: 11/22/2024
Operating Permit Renewal Date: 12/12/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Maurissa Spain	**(406) 609-8977**	**maurissaspain@gmail.com**
Operator Contact:	Dallas Herron;Maurissa Spain	**(406) 609-8977;(406) 751-4623**	**dallash@cityservicevalcon.com;maurissaspain@gmail.com**

Owner/Operator:	Maurissa Spain	(406) 609-8977	maurissaspain@gmail.com
	Dallas Herron, UST Class A Operator		dallash@cityservicevalcon.com
	Maurissa Spain, UST Class A Operator		maurissaspain@gmail.com
	Maurissa Spain, UST Class B Operator		maurissaspain@gmail.com

Tank Number	01	**Tank Age**	54	**Tank Installed Date**	04/24/1971	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	2199	**Spill Test Date**	11/30/2023	**Piping Installed Date**		**Tank Construction**	Lined Interior/Impressed Current	**Piping Construction**	Single Walled	**AST**	No
Status	**Temporarily Out of Use**	**MLLD Test Date**	11/30/2023	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	11/30/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	20000	**ATG Test Date**	11/30/2023	**Line Tightness Test Date**	11/30/2023	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	11/30/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	02	**Tank Age**	54	**Tank Installed Date**	04/24/1971	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	2200	**Spill Test Date**	08/05/2024	**Piping Installed Date**		**Tank Construction**	Lined Interior/Impressed Current	**Piping Construction**	None	**AST**	No
Status	**Temporarily Out of Use**	**MLLD Test Date**	11/30/2023	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	11/30/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	20000	**ATG Test Date**	11/30/2023	**Line Tightness Test Date**	11/30/2023	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No

		Overfill Test Date	11/30/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	03	**Tank Age**	49	**Tank Installed Date**	04/23/1976	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	2201	**Spill Test Date**	08/05/2024	**Piping Installed Date**		**Tank Construction**	Lined Interior/Impressed Current	**Piping Construction**	None	**AST**	No
Status	**Temporarily Out of Use**	**MLLD Test Date**	11/30/2023	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	11/30/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	11/30/2023	**Line Tightness Test Date**	11/30/2023	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	11/30/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	09	**Tank Age**	39	**Tank Installed Date**	04/23/1986	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	No Piping	**Overfill Types**	High Level Alarm
Tag Number	2202	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Temporarily Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Gravity Feed	**CP Met Types**	Galvanic
Product	Oil, Waste	**PLLD Test Date**		**Tank/Piping CP Test Date**	02/20/2020	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	3-Year Line Tightness Test	**Vapor Recovery**	No
Capacity	2000	**ATG Test Date**		**Line Tightness Test Date**	10/07/2020	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Flathead County in the City of Kalispell

Location: COSTCO WHOLESALE
2330 US Hwy 93 N
Kalispell, MT 59901-2547 Flathead

System Facility ID:60-15012

Facility Code: 30802
Last Inspected On: 12/07/2022
Operating Permit Renewal Date: 02/07/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Costco Wholesale **(425) 251-6222** **gaslicenses@costco.com**

Operator Contact: Zane Wilson;Costco Wholesale Corporation Missoula **w745gas@costco.com**

Owner/Operator: Costco Wholesale (425) 251-6222 gaslicenses@costco.com

Zane Wilson, UST Class A Operator w745gas@costco.com

Zane Wilson, UST Class B Operator w745gas@costco.com

Tank Number	01	**Tank Age**	20	**Tank Installed Date**	10/07/2005	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	5033	**Spill Test Date**	06/14/2023	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	11/15/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	07/07/2022	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	20000	**ATG Test Date**	07/07/2022	**Line Tightness Test Date**	07/07/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	07/14/2020			**ATG Type**	Gilbarco-Veeder Root/TLS-350				
Tank Number	02	**Tank Age**	20	**Tank Installed Date**	10/07/2005	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	5034	**Spill Test Date**	06/14/2023	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	11/15/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	07/07/2022	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	20000	**ATG Test Date**	07/07/2022	**Line Tightness Test Date**	07/07/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	07/14/2020			**ATG Type**	Gilbarco-Veeder Root/TLS-350				

Tank Number	03	**Tank Age**	20	**Tank Installed Date**	10/07/2005	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	5035	**Spill Test Date**	06/14/2023	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	06/14/2023	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	07/07/2022	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	20000	**ATG Test Date**	07/07/2022	**Line Tightness Test Date**	07/07/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	07/14/2020			**ATG Type**	Gilbarco-Veeder Root/TLS-350				
Tank Number	04	**Tank Age**	14	**Tank Installed Date**	04/19/2011	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	5280	**Spill Test Date**	06/02/2022	**Piping Installed Date**	10/25/2010	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	07/07/2022	**Sump Tightness Test Date**	06/02/2022	**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Hazardous Substance	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	1500	**ATG Test Date**	07/07/2022	**Line Tightness Test Date**	12/09/2019	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	MLLD Line Tightness Testing	**Energy Act**	Yes
		Overfill Test Date	07/07/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Flathead County in the City of Kalispell

Location: DIAMOND AIRE LLC LEASEE
1893 Airport Rd
Kalispell, MT 59901-7501 Flathead

System Facility ID:15-03172

Facility Code: 20598
Last Inspected On: 12/27/2022
Operating Permit Renewal Date: 12/20/2025

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	John Talmage;Montana Diamond Aire Inc	**(406) 752-5092**	**john@diamondaire.com;tia@flymissionmountain.com**
Operator Contact:	Tia Komberec;Montana Diamond Aire Inc	**(406) 250-8281**	**tia@flymissionmountain.com;tia@flymissionmountain.com**

Owner/Operator:	John Talmage	(406) 752-5092	john@diamondaire.com
Owner/Operator:	Montana Diamond Aire Inc	(406) 752-5092	john@diamondaire.com
	Tia Komberec, UST Class A Operator		tia@flymissionmountain.com
	Tia Komberec, UST Class B Operator		tia@flymissionmountain.com

Tank Number	07	**Tank Age**	30	**Tank Installed Date**	05/24/1995	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve
Tag Number	3285	**Spill Test Date**	04/01/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	12/27/2022	**Sump Tightness Test Date**	11/29/2016	**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Aviation Gas	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	12/27/2022	**Line Tightness Test Date**	12/27/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	12/27/2022			**ATG Type**	Gilbarco/TLS-350				
Tank Number	08	**Tank Age**	30	**Tank Installed Date**	05/24/1995	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve
Tag Number	3286	**Spill Test Date**	12/27/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	12/27/2022	**Sump Tightness Test Date**	11/29/2016	**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Jet Fuel (Jet-A, Jet-A1, JP5)	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	5000	**ATG Test Date**	12/27/2022	**Line Tightness Test Date**	12/27/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	12/27/2022			**ATG Type**	Gilbarco/TLS-350				

Facility Summary in Flathead County in the City of Kalispell

Location: EVERGREEN GAS and DELI
2100 US Hwy 2 E
Kalispell, MT 59901-2814 Flathead

System Facility ID:15-00108

Facility Code: 20512
Last Inspected On: 10/11/2023
Operating Permit Renewal Date: 12/02/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Aries Enterprises LLC;Kristi Ruggles	**(406) 890-5047**	**ramdeeprokha@yahoo.com**
Operator Contact:	Ramdeep Kaur	**(803) 522-5352**	**ramdeeprokha@yahoo.com**

Owner/Operator:	Aries Enterprises LLC	(406) 890-5047	ramdeeprokha@yahoo.com
Owner/Operator:	Kristi Lyn Ruggles	(406) 890-5047	ramdeeprokha@yahoo.com
	Ramdeep Kaur, UST Class A Operator		ramdeeprokha@yahoo.com
	Ramdeep Kaur, UST Class B Global Operator		ramdeeprokha@yahoo.com
	Ramdeep Kaur, UST Class B Operator		ramdeeprokha@yahoo.com

Tank Number	04	**Tank Age**	27	**Tank Installed Date**	06/01/1998	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve
Tag Number	3180	**Spill Test Date**	10/20/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	08/31/2023	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	08/31/2023	**Line Tightness Test Date**	08/31/2023	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	09/23/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	05	**Tank Age**	27	**Tank Installed Date**	06/01/1998	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve
Tag Number	3181	**Spill Test Date**	10/20/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	08/31/2023	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	08/31/2023	**Line Tightness Test Date**	08/31/2023	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No

		Overfill Test Date	09/23/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Flathead County in the City of Kalispell

Location: FLATHEAD COUNTY JUSTICE CENTER
920 S Main St
Kalispell, MT 59901 Flathead

System Facility ID:15-09279

Facility Code: 20774
Last Inspected On: 10/20/2022
Operating Permit Renewal Date: 03/16/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Flathead County Commissioners **(406) 758-5790**

Operator Contact: David Covill **(406) 758-5834** **dcovill@flathead.mt.gov**

Owner/Operator: Flathead County Commissioners (406) 758-5790

David Covill, UST Class A Operator dcovill@flathead.mt.gov
David Covill, UST Class B Operator dcovill@flathead.mt.gov

Tank Number	01	**Tank Age**	38	**Tank Installed Date**	03/11/1987	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Copper	**Overfill Types**	Flapper Valve
Tag Number	3810	**Spill Test Date**	10/20/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Secondary Containment Chase	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	12/06/2022	**Catastrophic L.D. Type 3.0**	Auto Dialer	**Piping Type**	U.S. Suction	**CP Met Types**	Galvanic
Product	Diesel, Dyed	**PLLD Test Date**		**Tank/Piping CP Test Date**	10/20/2022	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**	10/20/2022	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	10/20/2022			**ATG Type**	Gilbarco/EMC Basic				

Facility Summary in Flathead County in the City of Kalispell

Location: FLATHEAD COUNTY ROAD DEPT
1249 Willow Glen Dr
Kalispell, MT 59901-7541 Flathead

System Facility ID:15-06286

Facility Code: 20703
Last Inspected On: 01/22/2025
Operating Permit Renewal Date: 05/23/2028

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Flathead County Commissioners **(406) 758-5790**

Operator Contact: Corey Pilsch **(406) 752-4962**

Owner/Operator: Flathead County Commissioners (406) 758-5790

Corey Pilsch, UST Class A Operator
Corey Pilsch, UST Class A Operator
Corey Pilsch, UST Class B Operator
Corey Pilsch, UST Class B Operator

Tank Number	08	**Tank Age**	27	**Tank Installed Date**	05/01/1998	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	1088	**Spill Test Date**	06/13/2024	**Piping Installed Date**	11/19/2013	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	06/13/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	06/13/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date	06/13/2024			**ATG Type**	Gilbarco/EMC Basic				
Tank Number	09	**Tank Age**	27	**Tank Installed Date**	05/01/1998	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	1089	**Spill Test Date**	06/13/2024	**Piping Installed Date**	11/19/2013	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	06/13/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	3000	**ATG Test Date**	06/13/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date	06/13/2024			**ATG Type**	Gilbarco/EMC Basic				

Facility Summary in Flathead County in the City of Kalispell

Location: FLATHEAD COUNTY SOLID WASTE DIST
4098 US Hwy 93 N
Kalispell, MT 59901-6820 Flathead

System Facility ID:56-14041

Facility Code: 30696
Last Inspected On: 10/13/2022
Operating Permit Renewal Date: 12/26/2022

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Flathead County Commissioners **(406) 758-5790**

Operator Contact: James Chilton **jchilton@flathead.mt.gov**

Owner/Operator: Flathead County Commissioners (406) 758-5790

James Chilton, UST Class A Operator jchilton@flathead.mt.gov
James Chilton, UST Class B Operator jchilton@flathead.mt.gov

Tank Number	01	**Tank Age**	24	**Tank Installed Date**	11/26/2001	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	No Piping	**Overfill Types**	Ball Float Valve
Tag Number	4559	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	None	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**	08/24/2016	**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Not Listed	**CP Met Types**	Non-corrodible
Product	Oil, Waste	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	2000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	S2	**Tank Age**	22	**Tank Installed Date**	02/25/2003	**Tank Material Construction**	Concrete	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	4802	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	Yes
Status	**Currently in Use**	**MLLD Test Date**	02/15/2022	**Sump Tightness Test Date**	01/16/2020	**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	15000	**ATG Test Date**	02/15/2022	**Line Tightness Test Date**	02/15/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	S3	**Tank Age**	22	**Tank Installed Date**	02/25/2003	**Tank Material Construction**	Concrete	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm

Tag Number	4803	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	Yes
Status	**Currently in Use**	**MLLD Test Date**	02/15/2022	**Sump Tightness Test Date**	01/16/2020	**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	3000	**ATG Test Date**	02/15/2022	**Line Tightness Test Date**	02/15/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date				**ATG Type**					

Facility Summary in Flathead County in the City of Kalispell

Location: FLATHEAD ELECTRIC COOP KALISPELL
2510 US Hwy 2 E
Kalispell, MT 59901-2312 Flathead

System Facility ID:15-00044

Facility Code: 20508
Last Inspected On: 08/08/2023
Operating Permit Renewal Date: 08/08/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Flathead Electric Cooperative Inc	**(406) 751-4483**	
Operator Contact:	Christopher Anderson;Flathead Electric Cooperative Inc;Francisco Carbajal;Flathead Electric Cooperative Inc	**(406) 471-0554;(406) 751-4483;(406) 751-4483**	**c.anderson@flathead.coop;f.carbajal@flathead.coop**

Owner/Operator: Flathead Electric Cooperative Inc (406) 751-4483

Christopher Anderson, UST Class A Operator	c.anderson@flathead.coop
Christopher Anderson, UST Class B Operator	c.anderson@flathead.coop
Francisco Carbajal, UST Class A Operator	f.carbajal@flathead.coop
Francisco Carbajal, UST Class B Operator	f.carbajal@flathead.coop

Tank Number	04	**Tank Age**	27	**Tank Installed Date**	04/01/1998	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	1090	**Spill Test Date**	08/08/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	08/08/2023	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	08/08/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	08/08/2023			**ATG Type**	Veeder Root/TLS-450				
Tank Number	05	**Tank Age**	27	**Tank Installed Date**	04/01/1998	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	1091	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date				**ATG Type**	Veeder Root/TLS-450				

Tank Number	06	**Tank Age**	27	**Tank Installed Date**	04/01/1998	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	1092	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	5000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date				**ATG Type**	Veeder Root/TLS-450				

Facility Summary in Flathead County in the City of Kalispell

Location: GLACIER GAS N GO
1454 MT Hwy 35
Kalispell, MT 59901-2916 Flathead

System Facility ID:15-08357

Facility Code: 20756
Last Inspected On: 07/18/2023
Operating Permit Renewal Date: 08/20/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	HARJ93, LLC	**(206) 834-5349**	**sheragroupllc@gmail.com**
Operator Contact:	Rahul Kumar;Ranch Hand Inc	**(406) 296-2342**	**tharejallc@gmail.com**

Owner/Operator: HARJ93, LLC (206) 834-5349 sheragroupllc@gmail.com

Rahul Kumar, UST Class A Operator tharejallc@gmail.com

Rahul Kumar, UST Class B Operator tharejallc@gmail.com

Tank Number	01	**Tank Age**	43	**Tank Installed Date**	05/08/1982	**Tank Material Construction**	Bare Steel	**Piping Material**	Steel	**Overfill Types**	Flapper Valve
Tag Number	1420	**Spill Test Date**	05/08/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	05/08/2023	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	05/08/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	05/08/2023	**Line Tightness Test Date**	05/08/2023	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	05/08/2023			**ATG Type**	Veeder Root/TLS-300				
Tank Number	02	**Tank Age**	43	**Tank Installed Date**	05/08/1982	**Tank Material Construction**	Bare Steel	**Piping Material**	Steel	**Overfill Types**	Flapper Valve
Tag Number	1421	**Spill Test Date**	06/26/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	05/08/2023	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	05/09/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	05/08/2023	**Line Tightness Test Date**	05/08/2023	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	05/08/2023			**ATG Type**	Veeder Root/TLS-300				

Facility Summary in Flathead County in the City of Kalispell

Location: KELLY RAES INC
25 Batavia Ln
Kalispell, MT 59901-7280 Flathead

System Facility ID:15-06101

Facility Code: 20691
Last Inspected On: 12/07/2022
Operating Permit Renewal Date: 02/03/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Kalispell Properties LLC	**(509) 994-6599**	**histarms01@yahoo.com**
Operator Contact:	Lisa Myers	**(406) 752-5880**	**lisaloumyers@gmail.com**

Owner/Operator:	Kalispell Properties LLC	(509) 994-6599	histarms01@yahoo.com
	Lisa Myers, UST Class A Operator		lisaloumyers@gmail.com
	Lisa Myers, UST Class A Operator		lisaloumyers@gmail.com
	Lisa Myers, UST Class B Operator		lisaloumyers@gmail.com
	Lisa Myers, UST Class B Operator		lisaloumyers@gmail.com

Tank Number	03	**Tank Age**	31	**Tank Installed Date**	02/01/1994	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	4505	**Spill Test Date**	01/18/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Single Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	12/07/2022	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	01/18/2023	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**		**Line Tightness Test Date**	12/07/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	12/07/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Number	S5	**Tank Age**	60	**Tank Installed Date**	01/01/1965	**Tank Material Construction**	Bare Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	
Tag Number	4506	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	Yes
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	09/03/2013	**Primary Tank Leak Detection**	Deferred	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	20000	**ATG Test Date**		**Line Tightness Test Date**	08/16/2016	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					

Tank Number	S4	**Tank Age**	60	**Tank Installed Date**	01/01/1965	**Tank Material Construction**	Bare Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	
Tag Number	4507	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	Yes
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	09/03/2013	**Primary Tank Leak Detection**	Deferred	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	16000	**ATG Test Date**		**Line Tightness Test Date**	08/16/2016	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	S6	**Tank Age**	6	**Tank Installed Date**	01/10/2019	**Tank Material Construction**	Aboveground Tank	**Piping Material**	Flexible Plastic	**Overfill Types**	
Tag Number	5891	**Spill Test Date**		**Piping Installed Date**	01/10/2019	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	Yes
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	01/10/2019	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Diesel, Dyed	**PLLD Test Date**	12/07/2022	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	5000	**ATG Test Date**	12/07/2022	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	S7	**Tank Age**	6	**Tank Installed Date**	01/10/2019	**Tank Material Construction**	Aboveground Tank	**Piping Material**	Flexible Plastic	**Overfill Types**	
Tag Number	5892	**Spill Test Date**		**Piping Installed Date**	01/10/2019	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	Yes
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	01/10/2019	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Diesel	**PLLD Test Date**	12/07/2022	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	12/07/2022	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	S8	**Tank Age**	6	**Tank Installed Date**	01/10/2019	**Tank Material Construction**	Aboveground Tank	**Piping Material**	Flexible Plastic	**Overfill Types**	
Tag Number	5893	**Spill Test Date**		**Piping Installed Date**	01/10/2019	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	Yes
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	01/10/2019	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Gasoline	**PLLD Test Date**	12/07/2022	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No

Capacity	15000	**ATG Test Date**	12/07/2022	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	S9	**Tank Age**	6	**Tank Installed Date**	01/10/2019	**Tank Material Construction**	Aboveground Tank	**Piping Material**	Flexible Plastic	**Overfill Types**	
Tag Number	5894	**Spill Test Date**		**Piping Installed Date**	01/10/2019	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	Yes
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	01/10/2019	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Gasoline	**PLLD Test Date**	12/07/2022	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	5000	**ATG Test Date**	12/07/2022	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date				**ATG Type**					

Facility Summary in Flathead County in the City of Kalispell

Location: LOGAN HEALTH MEDICAL CENTER - ALERT
325 Claremont St
Kalispell, MT 59901-3576 Flathead

System Facility ID:15-00800

Facility Code: 20529
Last Inspected On: 12/02/2024
Operating Permit Renewal Date: 03/15/2028

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Northwest Healthcare	**(406) 756-3695**	
Operator Contact:	Kevin McCallum;Logan Health Whitefish;Kyle Hovey;Monti Arneson;Logan Health Whitefish	**(406) 212-8644;(406) 863-3533**	**got2fish62@gmail.com;jnewson@logan.org;khovey@krmc.org;kmccallum@logan.org;jnewson@logan.org**

Owner/Operator: Northwest Healthcare (406) 756-3695

Kevin McCallum, UST Class A Operator	jnewson@logan.org
Kevin McCallum, UST Class B Operator	jnewson@logan.org
Kyle Hovey, UST Class A Operator	khovey@krmc.org
Kyle Hovey, UST Class B Operator	khovey@krmc.org
Monti Arneson, UST Class A Operator	jnewson@logan.org
Monti Arneson, UST Class B Operator	jnewson@logan.org

Tank Number	02	**Tank Age**	35	**Tank Installed Date**	11/06/1990	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve
Tag Number	1465	**Spill Test Date**	06/18/2024	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	06/18/2024	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Jet Fuel (Jet-A, Jet-A1, JP5)	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**	06/18/2024	**Line Tightness Test Date**	06/18/2024	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	12/02/2024			**ATG Type**	Gilbarco/EMC Basic				

Facility Summary in Flathead County in the City of Kalispell

Location: LOGAN HEALTH MEDICAL CENTER - LOGAN NORTH
320 Sunnyview Ln
Kalispell, MT 59901-3177 Flathead

System Facility ID:56-14072

Facility Code: 30724
Last Inspected On: 07/06/2022
Operating Permit Renewal Date: 09/29/2025

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Flathead Hospital Development Co	**(406) 752-5111**	**mchitwood@krmc.org**
Operator Contact:	Alan Wallace;Kyle Hovey	**(406) 212-8644;(406) 871-5890**	**Alanwallace@logan.org;khovey@krmc.org**

Alan Wallace, UST Class A Operator	Alanwallace@logan.org
Alan Wallace, UST Class B Global Operator	Alanwallace@logan.org
Kyle Hovey, UST Class A Operator	khovey@krmc.org
Kyle Hovey, UST Class B Operator	khovey@krmc.org

Tank Number	S1	**Tank Age**	22	**Tank Installed Date**	12/16/2003	**Tank Material Construction**	Concrete	**Piping Material**	Flexible Plastic	**Overfill Types**	
Tag Number	4880	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	Yes
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**	07/06/2022	**Catastrophic L.D. Type 3.0**	Auto Dialer	**Piping Type**	U.S. Suction	**CP Met Types**	
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Deferred	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	07/06/2022	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					

Facility Summary in Flathead County in the City of Kalispell

Location: MATES 101
1645 US Hwy 93 S
Kalispell, MT 59901-5775 Flathead

System Facility ID:15-02014

Facility Code: 20564
Last Inspected On: 02/13/2025
Operating Permit Renewal Date: 02/13/2028

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	MATES 101 INC	**(929) 372-6087**	**101matesinc@gmail.com**
Operator Contact:	Tejas Sehgal;MATES 101 INC	**(929) 372-6087**	**101matesinc@gmail.com**

Owner/Operator: MATES 101 INC (929) 372-6087 101matesinc@gmail.com

Michael Apoka, UST Class B Operator 101matesinc@gmail.com

Tejas Sehgal, UST Class A Operator 101matesinc@gmail.com

Tank Number	11	**Tank Age**	28	**Tank Installed Date**	05/01/1997	**Tank Material Construction**	Steel Clad	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve
Tag Number	650	**Spill Test Date**	11/22/2021	**Piping Installed Date**	11/04/2013	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	11/22/2021	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	12/08/2021	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	12/08/2021	**Line Tightness Test Date**	09/07/2021	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date	11/22/2021			**ATG Type**	Gilbarco/EMC Basic				
Tank Number	12	**Tank Age**	28	**Tank Installed Date**	05/01/1997	**Tank Material Construction**	Steel Clad	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve
Tag Number	651	**Spill Test Date**	11/22/2021	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	12/08/2021	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	15000	**ATG Test Date**	12/08/2021	**Line Tightness Test Date**	12/14/2021	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	11/22/2021			**ATG Type**	Gilbarco/EMC Basic				
Tank Number	13	**Tank Age**	28	**Tank Installed Date**	05/01/1997	**Tank Material Construction**	Steel Clad	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve

Tag Number	652	**Spill Test Date**	11/22/2021	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	12/08/2021	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	12/08/2021	**Line Tightness Test Date**	08/26/2021	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	11/22/2021			**ATG Type**	Gilbarco/EMC Basic				
Tank Number	14	**Tank Age**	28	**Tank Installed Date**	05/01/1997	**Tank Material Construction**	Steel Clad	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve
Tag Number	653	**Spill Test Date**	11/22/2021	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	12/08/2021	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	15000	**ATG Test Date**	12/08/2021	**Line Tightness Test Date**	09/30/2021	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	11/22/2021			**ATG Type**	Gilbarco/EMC Basic				

Facility Summary in Flathead County in the City of Kalispell

Location: MDOT KALISPELL
85 5th Ave E N
Kalispell, MT 59901-4115 Flathead

System Facility ID:15-08733

Facility Code: 20766
Last Inspected On: 07/30/2024
Operating Permit Renewal Date: 11/01/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	MDOT Helena	**(406) 444-6163**	**mmurolo@mt.gov**
Operator Contact:	Joe Radonich;Montana Dept of Transportation;Mike Murolo;Montana Dept of Transportation;Tracy Deeds;MDOT Helena;Walt Kerttula;Montana Department of Transportation Helena	**(406) 444-6151;(406) 444-6163;(406) 444-7632;(406) 444-9204;(406) 444-7632;(406) 461-0769;(406) 444-6163**	**jradonich@mt.gov;jradonich@mt.gov;mmurolo@mt.gov;jradonich@mt.gov;tdeeds@mt.gov;mmurolo@mt.gov;wkerttula@mt.gov**

Owner/Operator: MDOT Helena (406) 444-6163 mmurolo@mt.gov

Joe Radonich, UST Class A Operator	jradonich@mt.gov
Joe Radonich, UST Class B Operator	jradonich@mt.gov
Mike Murolo, UST Class A Operator	jradonich@mt.gov
Nick Rosenbaum, UST Class B Operator	nrosenbaum@mt.gov
Tracy Deeds, UST Class A Operator	mmurolo@mt.gov
Walt Kerttula, UST Class A Operator	wkerttula@mt.gov

Tank Number	04	**Tank Age**	34	**Tank Installed Date**	12/01/1991	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	2892	**Spill Test Date**	07/30/2024	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	07/30/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	07/30/2024			**ATG Type**	Gilbarco/EMC Basic				
Tank Number	05	**Tank Age**	34	**Tank Installed Date**	12/01/1991	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	2893	**Spill Test Date**	07/30/2024	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	07/30/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No

		Overfill Test Date	07/30/2024			**ATG Type**	Gilbarco/EMC Basic				

Facility Summary in Flathead County in the City of Kalispell

Location: MICHAELS WEST FACILITY
1011 US Hwy 2 W
Kalispell, MT 59901-3800 Flathead

System Facility ID:15-02330

Facility Code: 20571
Last Inspected On: 12/17/2024
Operating Permit Renewal Date: 09/25/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	S AND M LLC	**(406) 253-2458**	**MAHAYES801@GMAIL.COM**
Operator Contact:	Christina Turner;Michael Hayes;Tiffany Howard	**(406) 755-4075**	**christinackt948@gmail.com;hayes6@centurytel.net;vwgirl_1117@yahoo.com**

Owner/Operator: S AND M LLC (406) 253-2458 MAHAYES801@GMAIL.COM

Alice Reeves, UST Class B Operator	
Alice Reeves, UST Class B Operator	
Christina Turner, UST Class A Operator	christinackt948@gmail.com
Michael Hayes, UST Class A Operator	hayes6@centurytel.net
Michael Hayes, UST Class A Operator	hayes6@centurytel.net
Tiffany Howard, UST Class A Operator	vwgirl_1117@yahoo.com
Tiffany Howard, UST Class A Operator	vwgirl_1117@yahoo.com
Tiffany Howard, UST Class B Global Operator	vwgirl_1117@yahoo.com
Tiffany Howard, UST Class B Global Operator	vwgirl_1117@yahoo.com
Tiffany Howard, UST Class B Operator	vwgirl_1117@yahoo.com
Tiffany Howard, UST Class B Operator	vwgirl_1117@yahoo.com

Tank Number	30	**Tank Age**	33	**Tank Installed Date**	12/01/1992	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	654	**Spill Test Date**	08/13/2024	**Piping Installed Date**	07/01/2024	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	08/13/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	Yes
Capacity	12000	**ATG Test Date**	12/11/2024	**Line Tightness Test Date**	08/09/2024	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date	08/13/2024			**ATG Type**	Franklin Fueling Systems/EVO 600				
Tank Number	31	**Tank Age**	33	**Tank Installed Date**	12/01/1992	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	655	**Spill Test Date**	08/13/2024	**Piping Installed Date**	07/01/2024	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No

Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	08/13/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	Yes
Capacity	12000	**ATG Test Date**	12/11/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date	08/13/2024			**ATG Type**	Franklin Fueling Systems/EVO 600				
Tank Number	32	**Tank Age**	33	**Tank Installed Date**	12/01/1992	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	656	**Spill Test Date**	08/13/2024	**Piping Installed Date**	07/01/2024	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	08/13/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	Yes
Capacity	12000	**ATG Test Date**	12/11/2024	**Line Tightness Test Date**	03/12/2015	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date	08/13/2024			**ATG Type**	Franklin Fueling Systems/EVO 600				
Tank Number	33	**Tank Age**	32	**Tank Installed Date**	04/01/1993	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	657	**Spill Test Date**	08/13/2024	**Piping Installed Date**	07/01/2024	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	08/13/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	12/11/2024	**Line Tightness Test Date**	08/09/2024	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date	08/13/2024			**ATG Type**	Franklin Fueling Systems/EVO 600				
Tank Number	34	**Tank Age**	32	**Tank Installed Date**	04/01/1993	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	658	**Spill Test Date**	08/13/2024	**Piping Installed Date**	07/01/2024	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	08/13/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel, Dyed	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	12/11/2024	**Line Tightness Test Date**	08/09/2024	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No

		Overfill Test Date	08/13/2024			**ATG Type**	Franklin Fueling Systems/EVO 600				
Tank Number	35	**Tank Age**	32	**Tank Installed Date**	04/01/1993	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	659	**Spill Test Date**	08/13/2024	**Piping Installed Date**	07/01/2024	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	08/13/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	12/11/2024	**Line Tightness Test Date**	08/09/2024	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date	08/13/2024			**ATG Type**	Franklin Fueling Systems/EVO 600				
Tank Number	36	**Tank Age**	32	**Tank Installed Date**	06/01/1993	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	660	**Spill Test Date**	08/13/2024	**Piping Installed Date**	07/01/2024	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	08/13/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	Yes
Capacity	4000	**ATG Test Date**	12/11/2024	**Line Tightness Test Date**	08/09/2024	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date	08/13/2024			**ATG Type**	Franklin Fueling Systems/EVO 600				

Facility Summary in Flathead County in the City of Kalispell

Location: MOUNTAIN WEST COOP KALISPELL
700 Rail Park Dr
Kalispell, MT 59901 Flathead

System Facility ID:60-15343

Facility Code: 32409
Last Inspected On: 08/30/2023
Operating Permit Renewal Date: 09/08/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Mountain West Cooperative	**(406) 543-8383**	
Operator Contact:	Banee Simonsen;Mountain West Coop;Dusty Smith;Mountain West Coop;Michael Gourley;CHS Inc Inver Grove Heights;Vanee Simonsen;Mountain West Cooperative	**(406) 370-3920;(651) 355-6343;(406) 543-8383;(406) 777-5441**	**banee.simonsen@chsinc.com;dusty.smith@chsinc.com;michael.gourley@chsinc.com;Kirsten.Tindall@chsinc.com;Vanee.Simonsen@chsinc.com**

Owner/Operator: Mountain West Cooperative (406) 543-8383

Banee Simonsen, UST Class A Operator	banee.simonsen@chsinc.com
Dusty Smith, UST Class A Operator	dusty.smith@chsinc.com
Dusty Smith, UST Class B Operator	dusty.smith@chsinc.com
Michael Gourley, UST Class A Operator	Kirsten.Tindall@chsinc.com
Vanee Simonsen, UST Class A Operator	Vanee.Simonsen@chsinc.com
Vanee Simonsen, UST Class B Operator	Vanee.Simonsen@chsinc.com

Tank Number	01	**Tank Age**	5	**Tank Installed Date**	03/09/2020	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	5963	**Spill Test Date**	08/30/2023	**Piping Installed Date**	03/09/2020	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	08/30/2023	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	08/30/2023	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	Yes
Capacity	4000	**ATG Test Date**	08/30/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	08/30/2023			**ATG Type**					
Tank Number	02	**Tank Age**	5	**Tank Installed Date**	03/09/2020	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	5964	**Spill Test Date**	08/30/2023	**Piping Installed Date**	03/09/2020	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	08/30/2023	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	08/30/2023	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No

Capacity	8000	**ATG Test Date**	08/30/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	08/30/2023			**ATG Type**					
Tank Number	03	**Tank Age**	5	**Tank Installed Date**	03/09/2020	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	5965	**Spill Test Date**	08/30/2023	**Piping Installed Date**	03/09/2020	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	08/30/2023	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	08/30/2023	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	08/30/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	08/30/2023			**ATG Type**					
Tank Number	04	**Tank Age**	5	**Tank Installed Date**	03/09/2020	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	5966	**Spill Test Date**	08/30/2023	**Piping Installed Date**	03/09/2020	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	08/30/2023	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	08/30/2023	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	Yes
Capacity	8000	**ATG Test Date**	08/30/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	08/30/2023			**ATG Type**					
Tank Number	05	**Tank Age**	5	**Tank Installed Date**	03/09/2020	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	5967	**Spill Test Date**	08/30/2023	**Piping Installed Date**	03/09/2020	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	08/30/2023	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel, Dyed	**PLLD Test Date**	08/30/2023	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	7000	**ATG Test Date**	08/30/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	08/30/2023			**ATG Type**					

Facility Summary in Flathead County in the City of Kalispell

Location: ON YOUR WAY 103
1278 US Hwy 2 E
Kalispell, MT 59901-3219 Flathead

System Facility ID:15-09707

Facility Code: 20803
Last Inspected On: 08/09/2023
Operating Permit Renewal Date: 09/04/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Indian Brothers LLC	**(406) 759-5538**	**chestersupermarket@gmail.com**
Operator Contact:	Tiffany Howard		**vwgirl_1117@yahoo.com**

Owner/Operator:	Indian Brothers LLC	(406) 759-5538	chestersupermarket@gmail.com
	Sharon Trickey, UST Class B Global Operator		trickeykid@gmail.com
	Sharon Trickey, UST Class B Global Operator		trickeykid@gmail.com
	Sharon Trickey, UST Class B Operator		trickeykid@gmail.com
	Sharon Trickey, UST Class B Operator		trickeykid@gmail.com
	Sherry Doyle, UST Class B Global Operator		sherryhabtech2@yahoo.com
	Sherry Doyle, UST Class B Global Operator		sherryhabtech2@yahoo.com
	Tiffany Howard, UST Class A Operator		vwgirl_1117@yahoo.com
	Tiffany Howard, UST Class A Operator		vwgirl_1117@yahoo.com
	Tiffany Howard, UST Class B Global Operator		vwgirl_1117@yahoo.com
	Tiffany Howard, UST Class B Global Operator		vwgirl_1117@yahoo.com
	Tiffany Howard, UST Class B Operator		vwgirl_1117@yahoo.com
	Tiffany Howard, UST Class B Operator		vwgirl_1117@yahoo.com

Tank Number	01	**Tank Age**	40	**Tank Installed Date**	06/01/1985	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Steel	**Overfill Types**	Ball Float Valve
Tag Number	3005	**Spill Test Date**	09/19/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Single Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**	08/07/2023	**Tank/Piping CP Test Date**	08/09/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	Yes
Capacity	12000	**ATG Test Date**	08/09/2023	**Line Tightness Test Date**	10/08/2020	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	08/09/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	02	**Tank Age**	40	**Tank Installed Date**	06/01/1985	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Steel	**Overfill Types**	Ball Float Valve

Tag Number	3006	**Spill Test Date**	09/19/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Single Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**	08/07/2023	**Tank/Piping CP Test Date**	08/09/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	Yes
Capacity	12000	**ATG Test Date**	08/09/2023	**Line Tightness Test Date**	10/08/2020	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	08/09/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	03	**Tank Age**	40	**Tank Installed Date**	06/01/1985	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Steel	**Overfill Types**	Ball Float Valve
Tag Number	3007	**Spill Test Date**	09/19/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Single Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**	08/07/2023	**Tank/Piping CP Test Date**	08/09/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	Yes
Capacity	10000	**ATG Test Date**	08/09/2023	**Line Tightness Test Date**	10/08/2020	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	08/09/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	04	**Tank Age**	40	**Tank Installed Date**	06/01/1985	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Steel	**Overfill Types**	Ball Float Valve
Tag Number	3008	**Spill Test Date**	08/07/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Single Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Diesel	**PLLD Test Date**	08/07/2023	**Tank/Piping CP Test Date**	08/09/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	08/09/2023	**Line Tightness Test Date**	10/08/2020	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	08/09/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Flathead County in the City of Kalispell

Location: RED EAGLE AVIATION INC
1880 US Hwy 93 S
Kalispell, MT 59901-5729 Flathead

System Facility ID:15-11166

Facility Code: 20921
Last Inspected On: 08/24/2023
Operating Permit Renewal Date: 09/14/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Red Eagle Aviation Inc

Operator Contact: Paige Pitz **paige@redeagleaviation.com**

Owner/Operator: Red Eagle Aviation Inc

Paige Pitz, UST Class A Operator paige@redeagleaviation.com
Paige Pitz, UST Class B Operator paige@redeagleaviation.com

Tank Number	03	**Tank Age**	44	**Tank Installed Date**	01/01/1981	**Tank Material Construction**	Bare Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	4144	**Spill Test Date**	09/30/2022	**Piping Installed Date**		**Tank Construction**	Lined Interior/Impressed Current	**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	08/24/2023	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Aviation Gas	**PLLD Test Date**		**Tank/Piping CP Test Date**	08/24/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	08/24/2023	**Line Tightness Test Date**	08/24/2023	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	08/24/2023			**ATG Type**	Incon/TS-1000				
Tank Number	04	**Tank Age**	44	**Tank Installed Date**	01/01/1981	**Tank Material Construction**	Bare Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	4173	**Spill Test Date**	09/30/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Jet Fuel (Jet-A, Jet-A1, JP5)	**PLLD Test Date**		**Tank/Piping CP Test Date**	08/24/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	08/24/2023	**Line Tightness Test Date**	11/28/2011	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	08/24/2023			**ATG Type**	Incon/TS-1000				

Facility Summary in Flathead County in the City of Kalispell

Location: RMC KALISPELL SHOP
2214 US Hwy 2 E
Kalispell, MT 59901-2816 Flathead

System Facility ID:15-04359

Facility Code: 20634
Last Inspected On: 05/05/2023
Operating Permit Renewal Date: 09/03/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Rocky Mountain Contractors Inc Kalispell **(406) 752-4280**

Operator Contact: Leona Prezeau **(406) 756-6012** **leona.prezeau@rmcontractors.com**

Owner/Operator: Rocky Mountain Contractors Inc Kalispell (406) 752-4280

Leona Prezeau, UST Class A Operator leona.prezeau@rmcontractors.com

Leona Prezeau, UST Class B Operator leona.prezeau@rmcontractors.com

Tank Number	03	**Tank Age**	31	**Tank Installed Date**	01/01/1994	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	1284	**Spill Test Date**	03/15/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Single Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	05/05/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	03/15/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-300				
Tank Number	04	**Tank Age**	31	**Tank Installed Date**	01/01/1994	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	1285	**Spill Test Date**	03/15/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	05/05/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	03/15/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-300				

Facility Summary in Flathead County in the City of Kalispell

Location: SMITHS FUEL CENTER 172
195 3rd Ave E N
Kalispell, MT 59901-4051 Flathead

System Facility ID:56-14062

Facility Code: 30715
Last Inspected On: 08/30/2023
Operating Permit Renewal Date: 11/04/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Smiths Food and Drug	**(801) 974-1400**	**roger.gough@sfdc.com**
Operator Contact:	Braxton Hill;David Harris;Gary Dotseth;James Dye;Kerry Busey;Michael Crumley;Ronnie Houtekamer;Steven Perkins;Todd Dotseth	**(406) 544-6677;(406) 788-2338;(801) 560-0471;(801) 974-1206;(801) 974-1317;(801) 977-1048;(801) 977-2012**	**braxton.hill@sfdc.com;david.harris@sfdc.com;jim.dye@sfdc.com;kerry.busey@sfdc.com;mike.crumley@kenecopetro.com;petrocompliance@gmail.com;ronnie.houtekamer@sfdc.com;steven.perkins@sfdc.com**

Owner/Operator:	Smiths Food and Drug	(801) 974-1400	roger.gough@sfdc.com
	Braxton Hill, UST Class A Operator		braxton.hill@sfdc.com
	Braxton Hill, UST Class B Operator		braxton.hill@sfdc.com
	David Harris, UST Class A Operator		david.harris@sfdc.com
	David Harris, UST Class B Global Operator		david.harris@sfdc.com
	Gary Dotseth, UST Class A Operator		petrocompliance@gmail.com
	Gary Dotseth, UST Class B Global Operator		petrocompliance@gmail.com
	James Dye, UST Class A Operator		jim.dye@sfdc.com
	James Dye, UST Class B Global Operator		jim.dye@sfdc.com
	Kerry Busey, UST Class A Operator		kerry.busey@sfdc.com
	Kerry Busey, UST Class B Global Operator		kerry.busey@sfdc.com
	Michael Crumley, UST Class A Operator		mike.crumley@kenecopetro.com
	Michael Crumley, UST Class B Global Operator		mike.crumley@kenecopetro.com
	Ronnie Houtekamer, UST Class A Operator		ronnie.houtekamer@sfdc.com
	Ronnie Houtekamer, UST Class B Global Operator		ronnie.houtekamer@sfdc.com
	Steven Perkins, UST Class A Operator		steven.perkins@sfdc.com
	Steven Perkins, UST Class B Global Operator		steven.perkins@sfdc.com
	Todd Dotseth, UST Class A Operator		petrocompliance@gmail.com
	Todd Dotseth, UST Class B Operator		petrocompliance@gmail.com

Tank Number	01	**Tank Age**	23	**Tank Installed Date**	08/23/2002	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve;Flapper Valve;High Level Alarm
Tag Number	4742	**Spill Test Date**	08/16/2023	**Piping Installed Date**	08/23/2002	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	08/24/2023	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible

Product	Gasoline	**PLLD Test Date**	08/24/2023	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	Yes
Capacity	20000	**ATG Test Date**	08/24/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	Yes
		Overfill Test Date	08/16/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350				
Tank Number	02	**Tank Age**	23	**Tank Installed Date**	08/23/2002	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve;Flapper Valve;High Level Alarm
Tag Number	4743	**Spill Test Date**	08/16/2023	**Piping Installed Date**	08/23/2002	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	08/24/2023	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	08/24/2023	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	Yes
Capacity	8000	**ATG Test Date**	08/24/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	Yes
		Overfill Test Date	08/16/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350				
Tank Number	03	**Tank Age**	23	**Tank Installed Date**	08/23/2002	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	4744	**Spill Test Date**	08/16/2023	**Piping Installed Date**	08/23/2002	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	08/24/2023	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	08/24/2023	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	08/24/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	Yes
		Overfill Test Date	08/16/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Flathead County in the City of Kalispell

Location: SWEET PEAKS ICE CREAM
343 S Main St
Kalispell, MT 59901-4847 Flathead

System Facility ID:15-04894

Facility Code: 20649
Last Inspected On: 06/13/2019
Operating Permit Renewal Date: 08/06/2022

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Gene Towle	**(714) 642-5001**	**upstreetnews@aol.com**
Operator Contact:	Keith Broere;Lisa Shriver	**(406) 360-4417**	**kbroere@aetmt.com;lshr461@ecy.wa.gov**

Keith Broere, UST Class A Operator	kbroere@aetmt.com
Keith Broere, UST Class A Operator	kbroere@aetmt.com
Keith Broere, UST Class A Operator	kbroere@aetmt.com
Keith Broere, UST Class B Global Operator	kbroere@aetmt.com
Keith Broere, UST Class B Global Operator	kbroere@aetmt.com
Keith Broere, UST Class B Global Operator	kbroere@aetmt.com
Lisa Shriver, UST Class A Operator	lshr461@ecy.wa.gov
Lisa Shriver, UST Class A Operator	lshr461@ecy.wa.gov
Lisa Shriver, UST Class A Operator	lshr461@ecy.wa.gov
Lisa Shriver, UST Class A Operator	lshr461@ecy.wa.gov
Lisa Shriver, UST Class B Global Operator	lshr461@ecy.wa.gov
Lisa Shriver, UST Class B Global Operator	lshr461@ecy.wa.gov
Lisa Shriver, UST Class B Global Operator	lshr461@ecy.wa.gov
Lisa Shriver, UST Class B Global Operator	lshr461@ecy.wa.gov
Lisa Shriver, UST Class B Operator	lshr461@ecy.wa.gov
Lisa Shriver, UST Class B Operator	lshr461@ecy.wa.gov
Lisa Shriver, UST Class B Operator	lshr461@ecy.wa.gov
Lisa Shriver, UST Class B Operator	lshr461@ecy.wa.gov

Tank Number	03	**Tank Age**	30	**Tank Installed Date**	09/14/1995	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve
Tag Number	438	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	05/17/2019	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No

Capacity	24000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**	Incon/TS-1000				
Tank Number	04	**Tank Age**	30	**Tank Installed Date**	09/14/1995	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve
Tag Number	439	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	05/17/2019	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**	Incon/TS-1000				

Facility Summary in Flathead County in the City of Kalispell

Location: TOWN PUMP INC KALISPELL 1
445 W Idaho St
Kalispell, MT 59901 Flathead

System Facility ID:15-08709

Facility Code: 20764
Last Inspected On: 03/10/2023
Operating Permit Renewal Date: 09/11/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Kalispell 1 Town Pump LLC	**(406) 497-6700**	**environmental@townpump.com**
Operator Contact:	Trent Biggers		**Trentb@townpump.com**

Owner/Operator:	Kalispell 1 Town Pump LLC	(406) 497-6700	environmental@townpump.com
	Trent Biggers, UST Class A Operator		Trentb@townpump.com
	Trent Biggers, UST Class A Operator		Trentb@townpump.com
	Trent Biggers, UST Class B Global Operator		Trentb@townpump.com
	Trent Biggers, UST Class B Global Operator		Trentb@townpump.com

Tank Number	02	**Tank Age**	43	**Tank Installed Date**	04/14/1982	**Tank Material Construction**	Bare Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	2425	**Spill Test Date**	09/15/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**	04/20/2021	**Tank/Piping CP Test Date**	09/15/2022	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	10/12/2023	**Line Tightness Test Date**	10/12/2023	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	09/15/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Number	06	**Tank Age**	28	**Tank Installed Date**	05/28/1997	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve
Tag Number	2426	**Spill Test Date**	09/15/2022	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Single Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	04/20/2021	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**	10/12/2023	**Line Tightness Test Date**	10/12/2023	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No

		Overfill Test Date	09/15/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Number	01	**Tank Age**	43	**Tank Installed Date**	04/14/1982	**Tank Material Construction**	Bare Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	4679	**Spill Test Date**	09/15/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Single Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**	04/20/2021	**Tank/Piping CP Test Date**	09/15/2022	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	10/10/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	09/15/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Number	07	**Tank Age**	28	**Tank Installed Date**	05/28/1997	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve
Tag Number	4680	**Spill Test Date**	09/15/2022	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	04/20/2021	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	10/12/2023	**Line Tightness Test Date**	10/12/2023	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	09/15/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Number	08	**Tank Age**	21	**Tank Installed Date**	08/18/2004	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve
Tag Number	4939	**Spill Test Date**	09/15/2022	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	04/20/2021	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	20000	**ATG Test Date**	10/12/2023	**Line Tightness Test Date**	10/12/2023	**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	09/15/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				

Facility Summary in Flathead County in the City of Kalispell

Location: TOWN PUMP INC KALISPELL 2
1100 E Idaho St
Kalispell, MT 59901 Flathead

System Facility ID:15-13764

Facility Code: 21094
Last Inspected On: 05/18/2023
Operating Permit Renewal Date: 09/12/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Kalispell 2 Town Pump LLC **(406) 497-6700** **environmental@townpump.com**

Operator Contact: Trent Biggers **Trentb@townpump.com**

Owner/Operator: Kalispell 2 Town Pump LLC (406) 497-6700 environmental@townpump.com

Trent Biggers, UST Class A Operator Trentb@townpump.com

Trent Biggers, UST Class B Global Operator Trentb@townpump.com

Tank Number	01	**Tank Age**	28	**Tank Installed Date**	04/01/1997	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	4814	**Spill Test Date**	12/01/2022	**Piping Installed Date**	07/12/2013	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	05/18/2023	**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	04/21/2021	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	05/18/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	No
		Overfill Test Date	12/01/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350				
Tank Number	02	**Tank Age**	28	**Tank Installed Date**	04/01/1997	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	4815	**Spill Test Date**	12/01/2022	**Piping Installed Date**	07/12/2013	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	05/18/2023	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	04/21/2021	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	05/18/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	No
		Overfill Test Date	12/01/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350				

Tank Number	03	**Tank Age**	28	**Tank Installed Date**	04/01/1997	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	4816	**Spill Test Date**	12/01/2022	**Piping Installed Date**	07/12/2013	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	05/18/2023	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	04/21/2021	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	05/18/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	No
		Overfill Test Date	12/01/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350				
Tank Number	04	**Tank Age**	28	**Tank Installed Date**	04/01/1997	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	4817	**Spill Test Date**	12/01/2022	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	05/18/2023	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	04/21/2021	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	05/18/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	12/01/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350				
Tank Number	05	**Tank Age**	28	**Tank Installed Date**	04/01/1997	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	4818	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	05/18/2023	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	04/21/2021	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	05/18/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Flathead County in the City of Kalispell

Location: TOWN PUMP INC KALISPELL 3
2605 US Hwy 2 E
Kalispell, MT 59901-2363 Flathead

System Facility ID:15-13732

Facility Code: 21092
Last Inspected On: 05/16/2023
Operating Permit Renewal Date: 09/13/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Kalispell 3 Town Pump **(406) 497-6700** **environmental@townpump.com**

Operator Contact: Trent Biggers **Trentb@townpump.com**

Owner/Operator: Kalispell 3 Town Pump (406) 497-6700 environmental@townpump.com

Trent Biggers, UST Class A Operator Trentb@townpump.com

Trent Biggers, UST Class B Global Operator Trentb@townpump.com

Tank Number	01	**Tank Age**	29	**Tank Installed Date**	07/01/1996	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	4766	**Spill Test Date**	09/13/2022	**Piping Installed Date**	12/02/2013	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	09/13/2022	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	Yes
Capacity	20000	**ATG Test Date**	05/16/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	No
		Overfill Test Date	09/13/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350				
Tank Number	02	**Tank Age**	29	**Tank Installed Date**	07/01/1996	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	4767	**Spill Test Date**	09/13/2022	**Piping Installed Date**	12/02/2013	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	09/13/2022	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	Yes
Capacity	15000	**ATG Test Date**	05/16/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	No
		Overfill Test Date	09/13/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350				
Tank Number	03	**Tank Age**	29	**Tank Installed Date**	07/01/1996	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve

Tag Number	4768	**Spill Test Date**	09/13/2022	**Piping Installed Date**	12/02/2013	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	09/13/2022	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	15000	**ATG Test Date**	05/16/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	No
		Overfill Test Date	09/13/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350				
Tank Number	04	**Tank Age**	29	**Tank Installed Date**	07/01/1996	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	4769	**Spill Test Date**	09/13/2022	**Piping Installed Date**	12/02/2013	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	09/13/2022	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	05/16/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	No
		Overfill Test Date	09/13/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350				
Tank Number	05	**Tank Age**	29	**Tank Installed Date**	07/01/1996	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	4770	**Spill Test Date**	09/13/2022	**Piping Installed Date**	12/02/2013	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	09/13/2022	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	05/16/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	No
		Overfill Test Date	09/13/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Flathead County in the City of Kalispell

Location: TOWN PUMP INC KALISPELL 5
2910 US Hwy 93 S
Kalispell, MT 59901-7901 Flathead

System Facility ID:15-13765

Facility Code: 21095
Last Inspected On: 05/17/2023
Operating Permit Renewal Date: 09/14/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Kalispell 5 Town Pump LLC **(406) 497-6700** **environmental@townpump.com**

Operator Contact: Trent Biggers **Trentb@townpump.com**

Owner/Operator: Kalispell 5 Town Pump LLC (406) 497-6700 environmental@townpump.com

Trent Biggers, UST Class A Operator Trentb@townpump.com

Trent Biggers, UST Class B Global Operator Trentb@townpump.com

Tank Number	01	**Tank Age**	29	**Tank Installed Date**	09/01/1996	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve
Tag Number	3430	**Spill Test Date**	08/25/2022	**Piping Installed Date**	04/20/2011	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	08/25/2023	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	05/17/2023	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	15000	**ATG Test Date**	05/17/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	No
		Overfill Test Date	08/25/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-450				
Tank Number	02	**Tank Age**	29	**Tank Installed Date**	09/01/1996	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve
Tag Number	3431	**Spill Test Date**	06/01/2022	**Piping Installed Date**	04/20/2011	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	05/04/2021	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	15000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/TLS-450				

Tank Number	03	**Tank Age**	29	**Tank Installed Date**	09/01/1996	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve;Positive Shutoff
Tag Number	3432	**Spill Test Date**	05/04/2021	**Piping Installed Date**	04/20/2011	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	05/04/2021	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	Yes
Capacity	20000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/TLS-450				
Tank Number	04	**Tank Age**	7	**Tank Installed Date**	12/05/2018	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	5793	**Spill Test Date**	05/04/2021	**Piping Installed Date**	12/05/2018	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	05/04/2021	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Statistical Inventory Reconciliation	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	Yes
		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/TLS-450				
Tank Number	05	**Tank Age**	7	**Tank Installed Date**	12/05/2018	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	5794	**Spill Test Date**	05/04/2021	**Piping Installed Date**	12/05/2018	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	05/04/2021	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	15000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Statistical Inventory Reconciliation	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	Yes
		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/TLS-450				
Tank Number	06	**Tank Age**	7	**Tank Installed Date**	12/05/2018	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	5795	**Spill Test Date**	05/04/2021	**Piping Installed Date**	12/05/2018	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No

Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	05/04/2021	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Statistical Inventory Reconciliation	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	Yes
		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/TLS-450				
Tank Number	07	**Tank Age**	7	**Tank Installed Date**	12/05/2018	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	5796	**Spill Test Date**	12/30/2024	**Piping Installed Date**	12/05/2018	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	05/04/2021	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	Yes
Capacity	6000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Statistical Inventory Reconciliation	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	Yes
		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/TLS-450				
Tank Number	08	**Tank Age**	7	**Tank Installed Date**	12/05/2018	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	5797	**Spill Test Date**	05/04/2021	**Piping Installed Date**	12/05/2018	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	05/04/2021	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	Yes
Capacity	15000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Statistical Inventory Reconciliation	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	Yes
		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/TLS-450				
Tank Number	09	**Tank Age**	7	**Tank Installed Date**	12/05/2018	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	
Tag Number	5798	**Spill Test Date**		**Piping Installed Date**	12/05/2018	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Continuous Interstitial Monitoring	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	DEF (Not Regulated)	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**		**Vapor Recovery**	No

Capacity	6000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	10	**Tank Age**	7	**Tank Installed Date**	12/05/2018	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	5799	**Spill Test Date**	05/04/2021	**Piping Installed Date**	12/05/2018	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	05/04/2021	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	Yes
Capacity	20000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Statistical Inventory Reconciliation	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	Yes
		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/TLS-450				

Facility Summary in Flathead County in the City of Kalispell

Location: TOWN PUMP KALISPELL 7
859 W Reserve St
Kalispell, MT 59901 Flathead

System Facility ID:60-15262

Facility Code: 30977
Last Inspected On: 05/16/2023
Operating Permit Renewal Date: 09/15/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Kalispell 7 Town Pump LLC **(406) 497-6700** **environmental@townpump.com**

Operator Contact: Trent Biggers **Trentb@townpump.com**

Owner/Operator: Kalispell 7 Town Pump LLC (406) 497-6700 environmental@townpump.com

Trent Biggers, UST Class A Operator Trentb@townpump.com

Trent Biggers, UST Class B Operator Trentb@townpump.com

Tank Number	01	**Tank Age**	10	**Tank Installed Date**	11/04/2015	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	5604	**Spill Test Date**	09/12/2022	**Piping Installed Date**	05/28/2016	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	09/12/2022	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	05/16/2023	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	Yes
Capacity	30000	**ATG Test Date**	05/16/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Statistical Inventory Reconciliation	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	Yes
		Overfill Test Date	09/12/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-450				
Tank Number	02	**Tank Age**	10	**Tank Installed Date**	11/04/2015	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	5605	**Spill Test Date**	09/12/2022	**Piping Installed Date**	05/28/2016	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	09/12/2023	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	05/16/2023	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	Yes
Capacity	6000	**ATG Test Date**	05/16/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Statistical Inventory Reconciliation	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	Yes
		Overfill Test Date	09/12/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-450				

Tank Number	03	**Tank Age**	10	**Tank Installed Date**	11/04/2015	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	5606	**Spill Test Date**	09/12/2022	**Piping Installed Date**	05/28/2016	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	09/12/2023	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	05/16/2023	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	Yes
Capacity	15000	**ATG Test Date**	05/16/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Statistical Inventory Reconciliation	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	Yes
		Overfill Test Date	09/12/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-450				
Tank Number	04	**Tank Age**	10	**Tank Installed Date**	11/04/2015	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	5607	**Spill Test Date**	04/15/2020	**Piping Installed Date**	05/28/2016	**Tank Construction**	Double-Walled	**Piping Construction**	None	**AST**	No
Status	**Other**	**MLLD Test Date**		**Sump Tightness Test Date**	12/03/2015	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	DEF (Not Regulated)	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Approved Remote Monitoring;Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	Yes
Capacity	6000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Approved Remote Monitoring;Continuous Interstitial Monitoring;Not Listed	**Energy Act**	Yes
		Overfill Test Date				**ATG Type**	Veeder Root/TLS-450				
Tank Number	05	**Tank Age**	10	**Tank Installed Date**	11/04/2015	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	5608	**Spill Test Date**	09/12/2022	**Piping Installed Date**	05/28/2016	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	09/12/2023	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	05/16/2023	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**	05/16/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Statistical Inventory Reconciliation	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	Yes
		Overfill Test Date	09/12/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-450				

Tank Number	06	**Tank Age**	10	**Tank Installed Date**	11/04/2015	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	5609	**Spill Test Date**	09/12/2022	**Piping Installed Date**	05/28/2016	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	09/12/2023	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	05/16/2023	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	15000	**ATG Test Date**	05/16/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Statistical Inventory Reconciliation	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	Yes
		Overfill Test Date	09/12/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-450				
Tank Number	07	**Tank Age**	10	**Tank Installed Date**	11/04/2015	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	5610	**Spill Test Date**	09/12/2023	**Piping Installed Date**	05/28/2016	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	09/12/2022	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	05/16/2023	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**	05/16/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Statistical Inventory Reconciliation	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	Yes
		Overfill Test Date	09/12/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-450				

Facility Summary in Flathead County in the City of Kalispell

Location: UNITED PARCEL SERVICES KALISPELL
1151 N Meridian Rd
Kalispell, MT 59901-3003 Flathead

System Facility ID:15-04535

Facility Code: 20640
Last Inspected On: 05/31/2019
Operating Permit Renewal Date: 10/11/2022

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	United Parcel Service Inc Seattle		**cdd6jxd@ups.com**
Operator Contact:	Dino Ostrow;Kaytee Villafrancaa;Russell Stott;Treair Smith	**(206) 621-6286;(206) 621-6380;(503) 329-7154;(503) 978-7678**	**dostrow@ups.com;jstott@ups.com;kvillafranca@ups.com;treairsmith@ups.com**

Dino Ostrow, UST Class A Operator	dostrow@ups.com
Dino Ostrow, UST Class A Operator	dostrow@ups.com
Dino Ostrow, UST Class B Operator	dostrow@ups.com
Dino Ostrow, UST Class B Operator	dostrow@ups.com
Kaytee Villafrancaa, UST Class A Operator	kvillafranca@ups.com
Kaytee Villafrancaa, UST Class A Operator	kvillafranca@ups.com
Kaytee Villafrancaa, UST Class B Global Operator	kvillafranca@ups.com
Kaytee Villafrancaa, UST Class B Global Operator	kvillafranca@ups.com
Russell Stott, UST Class A Operator	jstott@ups.com
Russell Stott, UST Class A Operator	jstott@ups.com
Russell Stott, UST Class B Operator	jstott@ups.com
Russell Stott, UST Class B Operator	jstott@ups.com
Treair Smith, UST Class A Operator	treairsmith@ups.com
Treair Smith, UST Class A Operator	treairsmith@ups.com
Treair Smith, UST Class B Global Operator	treairsmith@ups.com
Treair Smith, UST Class B Global Operator	treairsmith@ups.com

Tank Number	03	**Tank Age**	32	**Tank Installed Date**	08/01/1993	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	2180	**Spill Test Date**	04/05/2019	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**	04/05/2019	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	24000	**ATG Test Date**		**Line Tightness Test Date**	04/05/2019	**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No

		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Flathead County in the City of Kalispell

Location: WARDEN HUTTERIAN BRETHREN
295 Middle Rd
Kalispell, MT 59901-7700 Flathead

System Facility ID:15-05344

Facility Code: 20661
Last Inspected On: 11/04/2024
Operating Permit Renewal Date: 02/12/2028

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Warden Hutterian Brethren	**(406) 253-2276**	**pkwollman@gmail.com**
Operator Contact:	Steve Streich	**(406) 253-2276**	**spudtruck@montanasky.net**

Owner/Operator: Warden Hutterian Brethren (406) 253-2276 pkwollman@gmail.com
Steve Streich, UST Class A Operator spudtruck@montanasky.net
Steve Streich, UST Class B Global Operator spudtruck@montanasky.net

Tank Number	S3	**Tank Age**	30	**Tank Installed Date**	11/01/1995	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	869	**Spill Test Date**	11/04/2024	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Single Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	11/04/2024	**Primary Tank Leak Detection**	Manual Tank Gauging	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	1000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	01/23/2025			**ATG Type**					
Tank Number	S4	**Tank Age**	30	**Tank Installed Date**	11/01/1995	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	870	**Spill Test Date**	11/04/2024	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	11/04/2024	**Primary Tank Leak Detection**	Manual Tank Gauging	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	1000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	01/23/2025			**ATG Type**					

Facility Summary in Flathead County in the City of Kalispell

Location: WEST VALLEY SCHOOL DIST 1
2290 Farm To Market Rd
Kalispell, MT 59901-7108 Flathead

System Facility ID:15-10295

Facility Code: 20846
Last Inspected On: 08/23/2023
Operating Permit Renewal Date: 08/24/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	School Dist 1 West Valley	**(406) 755-7239**	**crisher@westvalleyschool.com**
Operator Contact:	Phillip Jackson	**(406) 755-7239**	**pjackson@westvalleyschool.com**

Owner/Operator: School Dist 1 West Valley (406) 755-7239 crisher@westvalleyschool.com

Phillip Jackson, UST Class A Operator pjackson@westvalleyschool.com

Phillip Jackson, UST Class B Operator pjackson@westvalleyschool.com

Tank Number	S2	**Tank Age**	30	**Tank Installed Date**	08/09/1995	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Copper	**Overfill Types**	Flapper Valve
Tag Number	2249	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Secondary Containment Chase	**AST**	No
Status	**Temporarily Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**	07/23/2015	**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	U.S. Suction	**CP Met Types**	Non-corrodible
Product	Heating Oil	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Manual Tank Gauging	**Primary Pipe Leak Detection**	3-Year Line Tightness Test	**Vapor Recovery**	No
Capacity	1000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					

Facility Summary in Flathead County in the City of Kalispell

Location: WHITE OAK SUPER STOP
4810 US Hwy 93 S
Kalispell, MT 59901-7985 Flathead

System Facility ID:15-13287

Facility Code: 21043
Last Inspected On: 09/13/2023
Operating Permit Renewal Date: 10/17/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Greg Tabish;Tabish Brothers Distributors Inc	**(406) 543-7621;(406) 728-2575**	**lss@gwpetrol.com;zootown@gwpetrol.com**
Operator Contact:	Amber Terrell;Karly Shafer;Kristy Stevenson	**(406) 396-2206;(406) 857-2344;(406) 871-8400**	**ambert2007@gmail.com;karly@gwpetrol.com;kristyinmontana@gmail.com**

Owner/Operator:	Greg Tabish	(406) 728-2575	zootown@gwpetrol.com
Owner/Operator:	Tabish Brothers Distributors Inc	(406) 728-2575	zootown@gwpetrol.com
	Amber Terrell, UST Class A Operator		ambert2007@gmail.com
	Amber Terrell, UST Class B Operator		ambert2007@gmail.com
	Karly Shafer, UST Class A Operator		karly@gwpetrol.com
	Karly Shafer, UST Class B Global Operator		karly@gwpetrol.com
	Kristy Stevenson, UST Class A Operator		kristyinmontana@gmail.com

Tank Number	01	**Tank Age**	42	**Tank Installed Date**	10/01/1983	**Tank Material Construction**	Bare Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	4481	**Spill Test Date**		**Piping Installed Date**	09/01/2017	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	10/04/2017	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	11/18/2017	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**		**Line Tightness Test Date**	10/09/2019	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date	09/12/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Number	02	**Tank Age**	42	**Tank Installed Date**	11/01/1983	**Tank Material Construction**	Bare Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	4482	**Spill Test Date**		**Piping Installed Date**	09/01/2017	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	10/04/2017	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	11/18/2017	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No

Capacity	10000	**ATG Test Date**		**Line Tightness Test Date**	10/09/2019	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/TLS-450				
Tank Number	03	**Tank Age**	42	**Tank Installed Date**	11/01/1983	**Tank Material Construction**	Bare Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	4483	**Spill Test Date**		**Piping Installed Date**	09/01/2017	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	10/04/2017	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	11/18/2017	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**		**Line Tightness Test Date**	10/09/2019	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date				**ATG Type**	Veeder Root/TLS-450				
Tank Number	04	**Tank Age**	8	**Tank Installed Date**	09/01/2017	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	5781	**Spill Test Date**	09/12/2023	**Piping Installed Date**	09/01/2017	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	10/04/2017	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	20000	**ATG Test Date**		**Line Tightness Test Date**	10/09/2019	**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS;Veeder Root/TLS-450PLUS				

Facility Summary in Flathead County in the City of Kalispell

Location: WOODLAND QUIKSTOP
81 Woodland Park Dr
Kalispell, MT 59901-4665 Flathead

System Facility ID:15-00115

Facility Code: 20518
Last Inspected On: 03/11/2025
Operating Permit Renewal Date: 06/11/2028

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Kalispell Properties LLC **(509) 994-6599** **histarms01@yahoo.com**

Operator Contact: Semere Kentiba **sammyimagination@gmail.com**

Owner/Operator: Kalispell Properties LLC (509) 994-6599 histarms01@yahoo.com

Semere Kentiba, UST Class A Operator sammyimagination@gmail.com

Semere Kentiba, UST Class B Global Operator sammyimagination@gmail.com

Tank Number	03	**Tank Age**	27	**Tank Installed Date**	07/23/1998	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve
Tag Number	3524	**Spill Test Date**	03/11/2025	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	02/02/2022	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	03/11/2025	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	03/11/2025			**ATG Type**	Gilbarco/EMC Basic				
Tank Number	04	**Tank Age**	27	**Tank Installed Date**	07/23/1998	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve
Tag Number	3525	**Spill Test Date**	02/11/2025	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	02/02/2022	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	03/11/2025	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	03/11/2025			**ATG Type**	Gilbarco/EMC Basic				

Facility Summary in Flathead County in the City of Kalispell

Location: WOODYS COUNTRY STORE INC
3333 MT Hwy 35
Kalispell, MT 59901-7724 Flathead

System Facility ID:15-05801

Facility Code: 20677
Last Inspected On: 11/06/2023
Operating Permit Renewal Date: 03/17/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Woodys Country Store Inc **(406) 755-5544**

Operator Contact: Charles Weiss **(406) 253-2818** **charlesalanweis@gmail.com**

Owner/Operator: Woodys Country Store Inc (406) 755-5544

Charles Weiss, UST Class A Operator charlesalanweis@gmail.com
Charles Weiss, UST Class B Operator charlesalanweis@gmail.com

Tank Number	01	**Tank Age**	41	**Tank Installed Date**	12/05/1984	**Tank Material Construction**	Bare Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	2243	**Spill Test Date**	10/18/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	10/18/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	02/10/2025	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	10/18/2023			**ATG Type**	Franklin Fueling Systems/EVO 600				
Tank Number	02	**Tank Age**	41	**Tank Installed Date**	12/05/1984	**Tank Material Construction**	Bare Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	2244	**Spill Test Date**	10/18/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	10/18/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	02/10/2025	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	10/18/2023			**ATG Type**	Franklin Fueling Systems/EVO 600				
Tank Number	03	**Tank Age**	41	**Tank Installed Date**	12/05/1984	**Tank Material Construction**	Bare Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	2245	**Spill Test Date**	10/18/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No

Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	10/18/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	02/10/2025	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	10/18/2023			**ATG Type**	Franklin Fueling Systems/EVO 600				

Facility Summary in Flathead County in the City of Kalispell

Location: ZIP TRIP 39
305 E Idaho St
Kalispell, MT 59901-4134 Flathead

System Facility ID:15-03915

Facility Code: 20624
Last Inspected On: 08/14/2024
Operating Permit Renewal Date: 01/24/2024

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	CHS Inc Spokane Valley	**(509) 535-7701**	**Donald.Widdicombe@chsinc.com**
Operator Contact:	Jim Alford	**(509) 536-7418**	**jim.alford@chsinc.com**

Owner/Operator: CHS Inc Spokane Valley (509) 535-7701 Donald.Widdicombe@chsinc.com

Andrew Duffie, UST Class B Operator	duffstars@yahoo.com
Andrew Duffie, UST Class B Operator	duffstars@yahoo.com
Ian Johnstone, UST Class B Global Operator	ianj@ziptrip.net
Ian Johnstone, UST Class B Global Operator	ianj@ziptrip.net
Jim Alford, UST Class A Operator	jim.alford@chsinc.com
Jim Alford, UST Class A Operator	jim.alford@chsinc.com
Jim Alford, UST Class B Global Operator	jim.alford@chsinc.com
Jim Alford, UST Class B Global Operator	jim.alford@chsinc.com
Justin Mace, UST Class B Operator	minuzle@gmail.com
Justin Mace, UST Class B Operator	minuzle@gmail.com
Wesley Bentley, UST Class B Operator	wesley.bentley@chsinc.com

Tank Number	04	**Tank Age**	27	**Tank Installed Date**	10/01/1998	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	1306	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	24000	**ATG Test Date**	06/30/2020	**Line Tightness Test Date**	06/30/2020	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco/EMC Basic				
Tank Number	05	**Tank Age**	27	**Tank Installed Date**	10/01/1998	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	1307	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No

Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	24000	**ATG Test Date**	06/30/2020	**Line Tightness Test Date**	06/30/2020	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco/EMC Basic				
Tank Number	06	**Tank Age**	27	**Tank Installed Date**	10/01/1998	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	1308	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	06/30/2020	**Line Tightness Test Date**	06/30/2020	**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco/EMC Basic				
Tank Number	07	**Tank Age**	27	**Tank Installed Date**	10/01/1998	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	1309	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	06/30/2020	**Line Tightness Test Date**	06/30/2020	**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco/EMC Basic				
Tank Number	08	**Tank Age**	2	**Tank Installed Date**	09/06/2023	**Tank Material Construction**	Steel Clad	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	6196	**Spill Test Date**	01/09/2024	**Piping Installed Date**	09/06/2023	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	01/09/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	Yes
Capacity	14000	**ATG Test Date**	01/17/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes

		Overfill Test Date	01/09/2024			**ATG Type**					
Tank Number	09	**Tank Age**	2	**Tank Installed Date**	09/06/2023	**Tank Material Construction**	Steel Clad	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	6197	**Spill Test Date**	01/09/2024	**Piping Installed Date**	09/06/2023	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	01/09/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	Yes
Capacity	6000	**ATG Test Date**	01/17/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	01/09/2024			**ATG Type**					
Tank Number	10	**Tank Age**	2	**Tank Installed Date**	09/06/2023	**Tank Material Construction**	Steel Clad	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	6198	**Spill Test Date**	01/09/2024	**Piping Installed Date**	09/06/2023	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	01/09/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	14000	**ATG Test Date**	01/17/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	01/09/2024			**ATG Type**					
Tank Number	11	**Tank Age**	2	**Tank Installed Date**	09/06/2023	**Tank Material Construction**	Steel Clad	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	6199	**Spill Test Date**	01/09/2024	**Piping Installed Date**	09/06/2023	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	Yes
Capacity	6000	**ATG Test Date**	01/17/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	01/09/2024			**ATG Type**					

Facility Summary in Flathead County in the City of Kalispell

Location: ZIP TRIP 40
1420 1st Ave E
Kalispell, MT 59901 Flathead

System Facility ID:15-02331

Facility Code: 20572
Last Inspected On: 09/15/2022
Operating Permit Renewal Date: 03/14/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	CHS Inc Spokane Valley	**(509) 535-7701**	**Donald.Widdicombe@chsinc.com**
Operator Contact:	Jim Alford;Sean Hurley	**(509) 535-7701;(509) 536-7418**	**jim.alford@chsinc.com;sean.hurley@chsinc.com**

Owner/Operator: CHS Inc Spokane Valley (509) 535-7701 Donald.Widdicombe@chsinc.com

Jason Brenner, UST Class B Operator	jason.brenner@chsinc.com
Jim Alford, UST Class A Operator	jim.alford@chsinc.com
Jim Alford, UST Class A Operator	jim.alford@chsinc.com
Jim Alford, UST Class B Operator	jim.alford@chsinc.com
Jim Alford, UST Class B Operator	jim.alford@chsinc.com
Luci Tuttle, UST Class B Operator	Lucinda.Tuttle@chsinc.com
Sean Hurley, UST Class A Operator	sean.hurley@chsinc.com
Sean Hurley, UST Class A Operator	sean.hurley@chsinc.com

Tank Number	01	**Tank Age**	43	**Tank Installed Date**	04/30/1982	**Tank Material Construction**	Bare Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve;Flapper Valve
Tag Number	1303	**Spill Test Date**	09/17/2021	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**	07/26/2022	**Tank/Piping CP Test Date**	07/01/2020	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	07/26/2022	**Line Tightness Test Date**	07/26/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	07/26/2022			**ATG Type**	Gilbarco/EMC Basic				
Tank Number	02	**Tank Age**	43	**Tank Installed Date**	04/30/1982	**Tank Material Construction**	Bare Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve;Flapper Valve
Tag Number	1304	**Spill Test Date**	09/17/2021	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Diesel	**PLLD Test Date**	07/26/2022	**Tank/Piping CP Test Date**	07/01/2020	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No

Capacity	8000	**ATG Test Date**	07/26/2022	**Line Tightness Test Date**	07/26/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	07/26/2022			**ATG Type**	Gilbarco/EMC Basic				
Tank Number	03	**Tank Age**	43	**Tank Installed Date**	04/30/1982	**Tank Material Construction**	Bare Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve;Flapper Valve
Tag Number	1305	**Spill Test Date**	09/17/2021	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**	07/26/2022	**Tank/Piping CP Test Date**	07/01/2020	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	07/26/2022	**Line Tightness Test Date**	07/26/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	07/26/2022			**ATG Type**	Gilbarco/EMC Basic				

Facility Summary in Flathead County in the City of Kalispell

Location: ZIP TRIP 41
2490 US Hwy 93 N
Kalispell, MT 59901-2148 Flathead

System Facility ID:15-07432

Facility Code: 20730
Last Inspected On: 07/05/2022
Operating Permit Renewal Date: 11/09/2025

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	CHS Inc Spokane Valley	**(509) 535-7701**	**Donald.Widdicombe@chsinc.com**
Operator Contact:	Jim Alford;Sean Hurley	**(509) 535-7701;(509) 536-7418**	**jim.alford@chsinc.com;sean.hurley@chsinc.com**

Owner/Operator: CHS Inc Spokane Valley (509) 535-7701 Donald.Widdicombe@chsinc.com

Jason Brenner, UST Class B Operator	jason.brenner@chsinc.com
Jim Alford, UST Class A Operator	jim.alford@chsinc.com
Jim Alford, UST Class B Operator	jim.alford@chsinc.com
Luci Tuttle, UST Class B Operator	Lucinda.Tuttle@chsinc.com
Sean Hurley, UST Class A Operator	sean.hurley@chsinc.com

Tank Number	01	**Tank Age**	40	**Tank Installed Date**	04/23/1985	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve;Flapper Valve
Tag Number	382	**Spill Test Date**	09/16/2021	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	06/27/2022	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	06/29/2021	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	06/27/2022	**Line Tightness Test Date**	06/27/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	09/16/2021			**ATG Type**	Veeder Root/TLS-300				
Tank Number	02	**Tank Age**	40	**Tank Installed Date**	04/23/1985	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve;Flapper Valve
Tag Number	383	**Spill Test Date**	09/16/2021	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	09/26/2018	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	06/29/2021	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	06/27/2022	**Line Tightness Test Date**	09/26/2018	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	09/16/2021			**ATG Type**	Veeder Root/TLS-300				

Tank Number	03	**Tank Age**	23	**Tank Installed Date**	06/21/2002	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve;Flapper Valve
Tag Number	4685	**Spill Test Date**	09/16/2021	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	06/27/2022	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	06/29/2015	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	06/27/2022	**Line Tightness Test Date**	06/27/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	09/16/2021			**ATG Type**	Veeder Root/TLS-300				

Facility Summary in Flathead County in the City of Lakeside

Location: ARIES GAS AND GROCERY
7254 US Hwy 93
Lakeside, MT 59922 Flathead

System Facility ID:15-13487

Facility Code: 21062
Last Inspected On: 10/20/2022
Operating Permit Renewal Date: 12/06/2025

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	RKR LLC	**(406) 890-5047**	**ramdeeprokha@hotmail.com**
Operator Contact:	Asham Singh;Janet Heinze;Ramdeep Kaur;Rod Phillips;Steven Heinze	**(406) 844-0336;(406) 871-7278;(406) 890-5047;(803) 522-5352**	**ashamjeet_singh@yahoo.com;backinblack_07@hotmail.com;ramdeeprokha@yahoo.com;sjdheinze@hotmail.com**

Owner/Operator: RKR LLC (406) 890-5047 ramdeeprokha@hotmail.com

Asham Singh, UST Class A Operator	ashamjeet_singh@yahoo.com
Asham Singh, UST Class A Operator	ashamjeet_singh@yahoo.com
Asham Singh, UST Class B Operator	ashamjeet_singh@yahoo.com
Asham Singh, UST Class B Operator	ashamjeet_singh@yahoo.com
Janet Heinze, UST Class A Operator	sjdheinze@hotmail.com
Janet Heinze, UST Class A Operator	sjdheinze@hotmail.com
Janet Heinze, UST Class B Operator	sjdheinze@hotmail.com
Janet Heinze, UST Class B Operator	sjdheinze@hotmail.com
Ramdeep Kaur, UST Class A Operator	ramdeeprokha@yahoo.com
Ramdeep Kaur, UST Class A Operator	ramdeeprokha@yahoo.com
Rod Phillips, UST Class A Operator	backinblack_07@hotmail.com
Rod Phillips, UST Class A Operator	backinblack_07@hotmail.com
Rod Phillips, UST Class B Operator	backinblack_07@hotmail.com
Rod Phillips, UST Class B Operator	backinblack_07@hotmail.com
Steven Heinze, UST Class A Operator	sjdheinze@hotmail.com
Steven Heinze, UST Class A Operator	sjdheinze@hotmail.com

Tank Number	01	**Tank Age**	31	**Tank Installed Date**	08/01/1994	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve;Flapper Valve
Tag Number	666	**Spill Test Date**	09/21/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	09/21/2022	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	03/19/2024	**Line Tightness Test Date**	09/21/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No

		Overfill Test Date	10/19/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Number	02	**Tank Age**	31	**Tank Installed Date**	08/01/1994	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve;Flapper Valve
Tag Number	667	**Spill Test Date**	09/21/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	09/21/2022	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	03/19/2024	**Line Tightness Test Date**	09/21/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	10/19/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Number	03	**Tank Age**	31	**Tank Installed Date**	08/01/1994	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve;Flapper Valve
Tag Number	668	**Spill Test Date**	09/21/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	09/21/2022	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	7000	**ATG Test Date**	03/19/2024	**Line Tightness Test Date**	09/21/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	10/19/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Number	04	**Tank Age**	31	**Tank Installed Date**	08/01/1994	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	669	**Spill Test Date**	09/21/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	09/21/2022	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel, Dyed	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	5000	**ATG Test Date**	03/19/2024	**Line Tightness Test Date**	09/21/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	10/19/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				

Facility Summary in Flathead County in the City of Lakeside

Location: ARSR GATR BLDG
Blacktail Mountain Rd
Lakeside, MT 59922 Flathead

System Facility ID:15-03618

Facility Code: 20613
Last Inspected On: 02/14/2024
Operating Permit Renewal Date: 02/19/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Federal Aviation Admin Renton **(206) 227-2367**

Operator Contact: Rob Jodsaas **rob.jodsaas@faa.gov**

Owner/Operator: Federal Aviation Admin Renton (206) 227-2367

Rob Jodsaas, UST Class A Operator rob.jodsaas@faa.gov

Rob Jodsaas, UST Class B Operator rob.jodsaas@faa.gov

Tank Number	S5	**Tank Age**	29	**Tank Installed Date**	09/25/1996	**Tank Material Construction**	Unknown	**Piping Material**	Flexible Plastic	**Overfill Types**	
Tag Number	4565	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	Yes
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	02/14/2024	**Catastrophic L.D. Type 3.0**	Auto Dialer	**Piping Type**	Pressurized	**CP Met Types**	
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	2000	**ATG Test Date**	02/14/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					

Facility Summary in Flathead County in the City of Lakeside

Location: JOE BLOGZ
7170 US Hwy 93 S
Lakeside, MT 59922-9728 Flathead

System Facility ID:15-10513

Facility Code: 20867
Last Inspected On: 11/20/2024
Operating Permit Renewal Date: 02/20/2028

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	FH Properties LLC	**(509) 833-6629**	**JoeBlogz@gmail.com**
Operator Contact:	Atinderpal Chana;FH Properties LLC	**(509) 833-6629**	**Joeblogzcasino@gmail.com;JoeBlogz@gmail.com**

Owner/Operator: FH Properties LLC (509) 833-6629 JoeBlogz@gmail.com

Atinderpal Chana, UST Class A Operator JoeBlogz@gmail.com

Atinderpal Chana, UST Class B Operator JoeBlogz@gmail.com

Tank Number	01	**Tank Age**	40	**Tank Installed Date**	03/07/1985	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	3798	**Spill Test Date**	11/20/2024	**Piping Installed Date**	04/01/1999	**Tank Construction**	Lined Interior/Impressed Current	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	11/20/2024	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	11/20/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	11/20/2024			**ATG Type**	Gilbarco/EMC Basic				
Tank Number	02	**Tank Age**	40	**Tank Installed Date**	03/07/1985	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	3799	**Spill Test Date**	11/20/2024	**Piping Installed Date**	04/01/1999	**Tank Construction**	Lined Interior/Impressed Current	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	11/20/2024	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	11/20/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	11/20/2024			**ATG Type**	Gilbarco/EMC Basic				

Facility Summary in Flathead County in the City of Lakeside

Location: MOCCASIN LODGE LLC
616 Lutheran Camp Rd
Lakeside, MT 59922 Flathead

System Facility ID:56-14069

Facility Code: 30721
Last Inspected On: 11/15/2023
Operating Permit Renewal Date: 02/19/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Moccasin Lodge LLC	**(406) 844-3569**	**kgnelson@centurytel.net**
Operator Contact:	Kathleen Nelson	**(406) 253-1021**	**kgnelson@centurytel.net**

Owner/Operator: Moccasin Lodge LLC (406) 844-3569 kgnelson@centurytel.net

Kathleen Nelson, UST Class A Operator kgnelson@centurytel.net

Kathleen Nelson, UST Class B Operator kgnelson@centurytel.net

Tank Number	S1	**Tank Age**	23	**Tank Installed Date**	12/30/2002	**Tank Material Construction**	Steel Clad	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	4781	**Spill Test Date**	11/15/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Temporarily Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**	11/15/2023	**Catastrophic L.D. Type 3.0**	Auto Dialer	**Piping Type**	U.S. Suction	**CP Met Types**	Non-corrodible
Product	Heating Oil	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Manual Tank Gauging	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	1600	**ATG Test Date**	11/15/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	11/15/2023			**ATG Type**					

Facility Summary in Flathead County in the City of Marion

Location: CABIN CREEK LANDING LLC
166 Wright Way
Marion, MT 59925-9874 Flathead

System Facility ID:56-14102

Facility Code: 30745
Last Inspected On: 01/26/2023
Operating Permit Renewal Date: 04/04/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Cabin Creek Landing LLC Dillon **randy@dillonflyingservice.com**

Operator Contact: J. Peter Gross **(406) 270-0910** **petegrossbackcountryflyingservice@cabincreek.com**

Owner/Operator: Cabin Creek Landing LLC Dillon randy@dillonflyingservice.com

J. Peter Gross, UST Class A Operator petegrossbackcountryflyingservice@cabincreek.com

J. Peter Gross, UST Class B Operator petegrossbackcountryflyingservice@cabincreek.com

Tank Number	01	**Tank Age**	21	**Tank Installed Date**	02/09/2004	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve
Tag Number	4883	**Spill Test Date**	09/08/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	09/08/2022	**Sump Tightness Test Date**	09/08/2022	**Catastrophic L.D. Type 3.0**	Continuous Interstitial Monitoring;Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Aviation Gas	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**	09/08/2022	**Line Tightness Test Date**	09/08/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	09/08/2022			**ATG Type**	Gilbarco-Veeder Root/EMC Basic				

Facility Summary in Flathead County in the City of Marion

Location: CANI INC
8205 US Hwy 2 W
Marion, MT 59925-9740 Flathead

System Facility ID:56-13803

Facility Code: 30490
Last Inspected On: 09/08/2022
Operating Permit Renewal Date: 11/06/2025

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: CANI Inc **(406) 854-2992** **caniincstore@gmail.com**

Operator Contact: Tonia Gardner **tonia159@hotmail.com**

Owner/Operator: CANI Inc (406) 854-2992 caniincstore@gmail.com

Tonia Gardner, UST Class A Operator tonia159@hotmail.com

Tonia Gardner, UST Class B Operator tonia159@hotmail.com

Tank Number	01	**Tank Age**	28	**Tank Installed Date**	08/01/1997	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	834	**Spill Test Date**	09/06/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	09/07/2022	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	09/07/2022	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	5000	**ATG Test Date**	09/07/2022	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	09/06/2022			**ATG Type**	EMCO Electronics/EECO 1500				
Tank Number	02	**Tank Age**	28	**Tank Installed Date**	08/01/1997	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	835	**Spill Test Date**	10/27/2022	**Piping Installed Date**	02/20/2015	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	09/07/2022	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	09/07/2022	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	5000	**ATG Test Date**	09/07/2022	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date	10/27/2022			**ATG Type**	EMCO Electronics/EECO 1500				

Tank Number	03	**Tank Age**	28	**Tank Installed Date**	08/01/1997	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	836	**Spill Test Date**	10/27/2022	**Piping Installed Date**	02/20/2015	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	09/07/2022	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	09/07/2022	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	5000	**ATG Test Date**	09/07/2022	**Line Tightness Test Date**	02/12/2015	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date	10/27/2022			**ATG Type**	EMCO Electronics/EECO 1500				

Facility Summary in Flathead County in the City of Marion

Location: MOOSE CROSSING INC
8405 US Hwy 2 W
Marion, MT 59925-9701 Flathead

System Facility ID:15-10015

Facility Code: 20822
Last Inspected On: 09/28/2021
Operating Permit Renewal Date: 10/12/2024

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Vern Taber Moose Crossing Inc;Virginia Guderjahn **(406) 854-2070;(406) 854-2292**

Operator Contact: Rebecca Taber;Vernon Taber **(406) 854-2070** **founds@live.com;moosecrossing406@gmail.com**

Rebecca Taber, UST Class A Operator	founds@live.com
Rebecca Taber, UST Class B Operator	founds@live.com
Vernon Taber, UST Class A Operator	moosecrossing406@gmail.com

Tank Number	S3	**Tank Age**	28	**Tank Installed Date**	09/25/1997	**Tank Material Construction**	Unknown	**Piping Material**	Flexible Plastic	**Overfill Types**	
Tag Number	1245	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	Yes
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**	09/28/2021	**Catastrophic L.D. Type 3.0**	Continuous Interstitial Monitoring	**Piping Type**	Gravity Feed	**CP Met Types**	
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	03/09/2022	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	S4	**Tank Age**	28	**Tank Installed Date**	09/25/1997	**Tank Material Construction**	Unknown	**Piping Material**	Flexible Plastic	**Overfill Types**	
Tag Number	1246	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	Yes
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**	09/28/2021	**Catastrophic L.D. Type 3.0**	Continuous Interstitial Monitoring	**Piping Type**	Pressurized	**CP Met Types**	
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**	03/09/2022	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					

Tank Number	S5	**Tank Age**	28	**Tank Installed Date**	09/25/1997	**Tank Material Construction**	Unknown	**Piping Material**	Flexible Plastic	**Overfill Types**	
Tag Number	1247	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	Yes
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**	09/28/2021	**Catastrophic L.D. Type 3.0**	Continuous Interstitial Monitoring	**Piping Type**	Pressurized	**CP Met Types**	
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	2000	**ATG Test Date**	03/09/2022	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					

Facility Summary in Flathead County in the City of Olney

Location: GLACIER GOLD LLC
255 Good Creek Rd
Olney, MT 59927 Flathead

System Facility ID:15-02973

Facility Code: 20589
Last Inspected On: 01/23/2024
Operating Permit Renewal Date: 01/23/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Glacier Gold LLC **(406) 881-3030**

Operator Contact: Joe Warner **(406) 881-3030** **glaciergold@centurytel.net**

Owner/Operator: Glacier Gold LLC (406) 881-3030

Joe Warner, UST Class A Operator glaciergold@centurytel.net
Joe Warner, UST Class B Operator glaciergold@centurytel.net

Tank Number	03	**Tank Age**	37	**Tank Installed Date**	03/29/1988	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	No Piping	**Overfill Types**	Flapper Valve
Tag Number	3583	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Temporarily Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**		**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	01/23/2024	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	9000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.1	**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					

Facility Summary in Flathead County in the City of Olney

Location: OLNEY STORE
105 Olney Loop Rd
Olney, MT 59927 Flathead

System Facility ID:56-13849

Facility Code: 30531
Last Inspected On: 07/28/2022
Operating Permit Renewal Date: 07/28/2025

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Jon Lemburg	**(406) 471-5557**	**lastbestplace@gmail.com**
Operator Contact:	Fred Peters;Jon Lemburg;Briggs Mercantile	**(406) 471-5557;(406) 881-2100;(406) 881-4010**	**birddog@blackfoot.net;lastbestplace@gmail.com**

Owner/Operator: Jon Lemburg (406) 471-5557 lastbestplace@gmail.com

Fred Peters, UST Class A Operator birddog@blackfoot.net
Fred Peters, UST Class B Operator birddog@blackfoot.net
Jon Lemburg, UST Class A Operator lastbestplace@gmail.com

Tank Number	03	**Tank Age**	27	**Tank Installed Date**	06/01/1998	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	3504	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Temporarily Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	07/28/2022	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	1000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**	EMCO Electronics/EECO 1500				
Tank Number	04	**Tank Age**	27	**Tank Installed Date**	06/01/1998	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	3505	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Temporarily Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	07/28/2022	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	500	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**	EMCO Electronics/EECO 1500				

Tank Number	05	**Tank Age**	27	**Tank Installed Date**	06/01/1998	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	3506	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Temporarily Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	07/28/2022	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	500	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**	EMCO Electronics/EECO 1500				

Facility Summary in Flathead County in the City of West Glacier

Location: GLACIER HIGHLAND RESORT
12555 US Hwy 2 E
West Glacier, MT 59936 Flathead

System Facility ID:15-10685

Facility Code: 20877
Last Inspected On: 09/14/2023
Operating Permit Renewal Date: 09/17/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Glacier Highland Resort;Joseph Hoff **(406) 888-5427** **glacierhighland@gmail.com**

Operator Contact: Joseph Hoff **bubba284@icloud.com**

Owner/Operator: Glacier Highland Resort (406) 888-5427 glacierhighland@gmail.com

Owner/Operator: Joseph B Hoff (406) 888-5427 glacierhighland@gmail.com

Joseph Hoff, UST Class A Operator bubba284@icloud.com

Joseph Hoff, UST Class B Global Operator bubba284@icloud.com

Tank Number	03	**Tank Age**	27	**Tank Installed Date**	10/01/1998	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	3214	**Spill Test Date**	09/13/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Single Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	09/13/2023	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	09/14/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	09/13/2023	**Line Tightness Test Date**	09/13/2023	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	09/13/2023			**ATG Type**	EMCO Electronics/EECO 1500				
Tank Number	04	**Tank Age**	27	**Tank Installed Date**	10/01/1998	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	3215	**Spill Test Date**	09/13/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Single Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	09/13/2023	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	09/14/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**	09/13/2023	**Line Tightness Test Date**	09/13/2023	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	09/13/2023			**ATG Type**	EMCO Electronics/EECO 1500				

Facility Summary in Flathead County in the City of West Glacier

Location: GLACIER PARK HDQTRS GAS PUMPS
64 Grinnell Dr
West Glacier, MT 59936-0128 Flathead

System Facility ID:15-09491

Facility Code: 20794
Last Inspected On: 06/24/2023
Operating Permit Renewal Date: 08/02/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Glacier National Park	**(406) 732-7718**	**john_lucke@nps.gov**
Operator Contact:	Franklin Thompson;Lori King;Patrick Glynn	**(406) 888-7967**	**frank_thompson@nps.gov;patrick_glynn@nps.gov**

Owner/Operator: Glacier National Park (406) 732-7718 john_lucke@nps.gov

Franklin Thompson, UST Class A Operator — frank_thompson@nps.gov
Franklin Thompson, UST Class B Operator — frank_thompson@nps.gov
Lori King, UST Class A Operator
Lori King, UST Class B Operator
Patrick Glynn, UST Class A Operator — patrick_glynn@nps.gov
Patrick Glynn, UST Class B Operator — patrick_glynn@nps.gov

Tank Number	06	**Tank Age**	35	**Tank Installed Date**	11/01/1990	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve
Tag Number	1219	**Spill Test Date**	06/21/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	06/21/2023	**Sump Tightness Test Date**	06/21/2023	**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	06/21/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	5000	**ATG Test Date**	06/21/2023	**Line Tightness Test Date**	06/21/2023	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	06/21/2023			**ATG Type**	Veeder Root/TLS-300				
Tank Number	07	**Tank Age**	35	**Tank Installed Date**	11/01/1990	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve
Tag Number	1220	**Spill Test Date**	06/21/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	06/21/2023	**Sump Tightness Test Date**	06/21/2023	**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	06/21/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	06/21/2023	**Line Tightness Test Date**	07/07/2020	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No

		Overfill Test Date	06/21/2023			**ATG Type**	Veeder Root/TLS-300				

Facility Summary in Flathead County in the City of West Glacier

Location: MRC GAS STATION
200 Going To The Sun Rd
West Glacier, MT 59936 Flathead

System Facility ID:15-03288

Facility Code: 20602
Last Inspected On: 08/15/2023
Operating Permit Renewal Date: 12/02/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Glacier Park Inc	**(406) 892-6708**	**lwyrick@pursuitcollection.com**
Operator Contact:	Charles Krasselt	**(406) 270-8013**	**ckrasselt@glacierparkinc.com**

Owner/Operator:	Glacier Park Inc	(406) 892-6708	lwyrick@pursuitcollection.com
	Charles Krasselt, UST Class A Operator		ckrasselt@glacierparkinc.com
	Charles Krasselt, UST Class A Operator		ckrasselt@glacierparkinc.com
	Charles Krasselt, UST Class B Global Operator		ckrasselt@glacierparkinc.com
	Charles Krasselt, UST Class B Global Operator		ckrasselt@glacierparkinc.com

Tank Number	04	**Tank Age**	36	**Tank Installed Date**	10/23/1989	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve
Tag Number	2246	**Spill Test Date**	04/28/2022	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Single Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	04/06/2023	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	05/09/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	04/06/2023	**Line Tightness Test Date**	04/06/2023	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	04/28/2022			**ATG Type**	Veeder Root/TLS-300				
Tank Number	05	**Tank Age**	36	**Tank Installed Date**	10/23/1989	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	No Piping	**Overfill Types**	Ball Float Valve
Tag Number	2247	**Spill Test Date**	04/28/2022	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	03/16/2022	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	05/09/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	04/06/2023	**Line Tightness Test Date**	03/16/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	04/28/2022			**ATG Type**	Veeder Root/TLS-300				

Tank Number	06	**Tank Age**	36	**Tank Installed Date**	10/23/1989	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve
Tag Number	2248	**Spill Test Date**	04/28/2022	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	04/06/2023	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	05/09/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**	04/06/2023	**Line Tightness Test Date**	04/06/2023	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	04/28/2022			**ATG Type**	Veeder Root/TLS-300				

Facility Summary in Flathead County in the City of Whitefish

Location: ALPINE VILLAGE MARKET
721 Wisconsin Ave
Whitefish, MT 59937-2131 Flathead

System Facility ID:15-10944

Facility Code: 20900
Last Inspected On: 09/20/2023
Operating Permit Renewal Date: 12/31/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Super Grocer Corp **(406) 862-5025**

Operator Contact: Alan Reisch;Brent Silcox **(406) 862-5025** **alpine1@aboutmontana.net**

Owner/Operator: Super Grocer Corp (406) 862-5025

Alan Reisch, UST Class A Operator	alpine1@aboutmontana.net
Alan Reisch, UST Class B Operator	alpine1@aboutmontana.net
Brent Silcox, UST Class A Operator	alpine1@aboutmontana.net
Brent Silcox, UST Class B Operator	alpine1@aboutmontana.net

Tank Number	01	**Tank Age**	44	**Tank Installed Date**	04/21/1981	**Tank Material Construction**	Bare Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	4692	**Spill Test Date**	12/21/2023	**Piping Installed Date**	09/13/2002	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**	09/19/2023	**Tank/Piping CP Test Date**	09/19/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	09/19/2023	**Line Tightness Test Date**	09/10/2014	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	09/19/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	02	**Tank Age**	44	**Tank Installed Date**	04/21/1981	**Tank Material Construction**	Bare Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	4693	**Spill Test Date**	12/21/2023	**Piping Installed Date**	09/13/2002	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**	09/19/2023	**Tank/Piping CP Test Date**	09/19/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	09/19/2023	**Line Tightness Test Date**	08/15/2014	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No

		Overfill Test Date	09/19/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	03	**Tank Age**	34	**Tank Installed Date**	10/01/1991	**Tank Material Construction**	Bare Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	4694	**Spill Test Date**	12/21/2023	**Piping Installed Date**	09/13/2002	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Diesel	**PLLD Test Date**	09/19/2023	**Tank/Piping CP Test Date**	09/19/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	5000	**ATG Test Date**	09/19/2023	**Line Tightness Test Date**	09/09/2017	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	12/21/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Flathead County in the City of Whitefish

Location: BIG MOUNTAIN SKI RESORT SHOP
3910 Big Mountain Rd
Whitefish, MT 59937 Flathead

System Facility ID:15-05579

Facility Code: 20672
Last Inspected On: 09/06/2022
Operating Permit Renewal Date: 10/22/2025

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Winter Sports Inc **(406) 862-2987**

Operator Contact: Gardner Beougher **(406) 862-2987** **gardnerb@skiwhhitefish.com**

Owner/Operator: Winter Sports Inc (406) 862-2987

Gardner Beougher, UST Class A Operator gardnerb@skiwhhitefish.com
Gardner Beougher, UST Class B Operator gardnerb@skiwhhitefish.com

Tank Number	08	**Tank Age**	33	**Tank Installed Date**	09/01/1992	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve
Tag Number	2295	**Spill Test Date**	07/13/2022	**Piping Installed Date**	07/20/2007	**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	07/14/2022	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	07/13/2022	**Line Tightness Test Date**	07/14/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	07/13/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-450				
Tank Number	09	**Tank Age**	27	**Tank Installed Date**	07/14/1998	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	2296	**Spill Test Date**	07/13/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	07/13/2022	**Line Tightness Test Date**	11/01/2006	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	07/13/2022			**ATG Type**	Gilbarco-Veeder Root/Other				
Tank Number	10	**Tank Age**	27	**Tank Installed Date**	07/14/1998	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	2297	**Spill Test Date**	09/01/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No

Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	2000	**ATG Test Date**	07/13/2022	**Line Tightness Test Date**	11/01/2006	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	07/13/2022			**ATG Type**	Gilbarco-Veeder Root/Other				

Facility Summary in Flathead County in the City of Whitefish

Location: CENEX ZIP TRIP #69
6585 US Hwy 93 S
Whitefish, MT 59937 Flathead

System Facility ID:15-04903

Facility Code: 20650
Last Inspected On: 10/28/2022
Operating Permit Renewal Date: 12/27/2025

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	CHS Inc Spokane Valley	**(509) 535-7701**	**Donald.Widdicombe@chsinc.com**
Operator Contact:	Jim Alford;Sean Hurley	**(509) 535-7701;(509) 536-7418**	**jim.alford@chsinc.com;sean.hurley@chsinc.com**

Owner/Operator: CHS Inc Spokane Valley (509) 535-7701 Donald.Widdicombe@chsinc.com

Jason Brenner, UST Class B Operator	jim.alford@chsinc.com
Jim Alford, UST Class A Operator	jim.alford@chsinc.com
Jim Alford, UST Class B Operator	jim.alford@chsinc.com
Luci Tuttle, UST Class B Operator	Lucinda.Tuttle@chsinc.com
Sean Hurley, UST Class A Operator	sean.hurley@chsinc.com

Tank Number	07	**Tank Age**	34	**Tank Installed Date**	11/04/1991	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	2956	**Spill Test Date**	01/21/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	11/02/2018	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	06/30/2021	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	08/25/2022	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	01/21/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	08	**Tank Age**	34	**Tank Installed Date**	11/04/1991	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	2957	**Spill Test Date**	01/21/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	11/02/2018	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	06/30/2021	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	08/25/2022	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No

		Overfill Test Date	01/21/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	09	**Tank Age**	34	**Tank Installed Date**	11/04/1991	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	2958	**Spill Test Date**	01/21/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	11/02/2018	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Diesel, Dyed	**PLLD Test Date**		**Tank/Piping CP Test Date**	06/30/2021	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	08/25/2022	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	01/21/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	10	**Tank Age**	34	**Tank Installed Date**	11/04/1991	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	2959	**Spill Test Date**	01/21/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	11/02/2018	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	06/30/2021	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	08/25/2022	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	01/21/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Flathead County in the City of Whitefish

Location: LOGAN HEALTH WHITEFISH
1600 Hospital Way
Whitefish, MT 59937-2990 Flathead

System Facility ID:60-15034

Facility Code: 30816
Last Inspected On: 03/12/2025
Operating Permit Renewal Date: 03/13/2028

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Logan Health Whitefish	**(406) 863-3533**	**jnewson@logan.org**
Operator Contact:	Jeff Greene;Logan Health Whitefish;Matthew Moody;Logan Health Whitefish;Steven Reasner;Logan Health Whitefish	**(406) 471-2116;(406) 863-3533;(406) 863-3533**	**jeffgreene@logan.org;jnewson@logan.org;moodster10@hotmail.com;jnewson@logan.org;sreasner@logan.org;jnewson@logan.org**

Owner/Operator: Logan Health Whitefish (406) 863-3533 jnewson@logan.org

Jeff Greene, UST Class A Operator	jnewson@logan.org
Jeff Greene, UST Class B Operator	jnewson@logan.org
Matthew Moody, UST Class A Operator	jnewson@logan.org
Matthew Moody, UST Class B Operator	jnewson@logan.org
Steven Reasner, UST Class A Operator	jnewson@logan.org
Steven Reasner, UST Class B Operator	jnewson@logan.org

Tank Number	S1	**Tank Age**	18	**Tank Installed Date**	01/17/2007	**Tank Material Construction**	Aboveground Tank	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	5123	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	Yes
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	03/12/2025	**Catastrophic L.D. Type 3.0**	Auto Dialer	**Piping Type**	Pressurized	**CP Met Types**	
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	03/12/2025	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	Yes
		Overfill Test Date				**ATG Type**					

Facility Summary in Flathead County in the City of Whitefish

Location: MIDWAY MINI MART
4899 US Hwy 93 S
Whitefish, MT 59937-8520 Flathead

System Facility ID:15-07766

Facility Code: 20742
Last Inspected On: 05/10/2023
Operating Permit Renewal Date: 08/07/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Midway MM Inc **(406) 862-6365** **victorsmarket@outlook.com**

Operator Contact: Riley Workman **riley.a.workman@gmail.com**

Owner/Operator: Midway MM Inc (406) 862-6365 victorsmarket@outlook.com

Riley Workman, UST Class A Operator riley.a.workman@gmail.com

Riley Workman, UST Class B Operator riley.a.workman@gmail.com

Tank Number	04	**Tank Age**	29	**Tank Installed Date**	04/01/1996	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	3384	**Spill Test Date**	05/10/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	05/10/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	05/10/2023	**Line Tightness Test Date**	06/04/2020	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	05/10/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	05	**Tank Age**	29	**Tank Installed Date**	04/01/1996	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	3385	**Spill Test Date**	05/10/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	05/10/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	7000	**ATG Test Date**	05/10/2023	**Line Tightness Test Date**	06/04/2020	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	05/10/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	06	**Tank Age**	29	**Tank Installed Date**	04/01/1996	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve

Tag Number	3386	**Spill Test Date**	05/10/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	05/10/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	5000	**ATG Test Date**	05/10/2023	**Line Tightness Test Date**	06/04/2020	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	05/10/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Flathead County in the City of Whitefish

Location: SAFEWAY FUEL STATION #2106
110 W 13th St
Whitefish, MT 59937 Flathead

System Facility ID:60-15151

Facility Code: 30892
Last Inspected On: 07/25/2022
Operating Permit Renewal Date: 12/28/2025

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Safeway #2106	**(623) 869-3573**	**liz.alwine@safeway.com**
Operator Contact:	Jesse Wees;Page Rost	**(208) 412-2233;(208) 412-7561**	**jesse.wees@albertsons.com;page.rost@albertsons.com**

Owner/Operator: Safeway #2106 (623) 869-3573 liz.alwine@safeway.com

A Beagle, UST Class B Global Operator	
A Beagle, UST Class B Global Operator	
Allen Long, UST Class B Global Operator	
Allen Long, UST Class B Global Operator	
Jesse Wees, UST Class A Operator	jesse.wees@albertsons.com
Jesse Wees, UST Class A Operator	jesse.wees@albertsons.com
Page Rost, UST Class A Operator	page.rost@albertsons.com
Page Rost, UST Class A Operator	page.rost@albertsons.com
Page Rost, UST Class B Global Operator	page.rost@albertsons.com
Page Rost, UST Class B Global Operator	page.rost@albertsons.com

Tank Number	01	**Tank Age**	15	**Tank Installed Date**	04/28/2010	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	5233	**Spill Test Date**	05/13/2020	**Piping Installed Date**	04/08/2010	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	05/13/2020	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	07/25/2022	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	20000	**ATG Test Date**	07/25/2022	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	08/12/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350;Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	02	**Tank Age**	15	**Tank Installed Date**	04/28/2010	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm

Tag Number	5234	**Spill Test Date**	05/13/2020	**Piping Installed Date**	04/08/2010	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	05/13/2020	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	07/25/2022	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	07/25/2022	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	08/12/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350;Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	03	**Tank Age**	15	**Tank Installed Date**	04/28/2010	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	5235	**Spill Test Date**	05/13/2020	**Piping Installed Date**	04/08/2010	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	05/13/2020	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	07/25/2022	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	07/25/2022	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	08/12/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350;Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Flathead County in the City of Whitefish

Location: TOMS SUPER SERVICE
722 Clearwater Drive
Whitefish, MT 59937 Flathead

System Facility ID:37-06114

Facility Code: 26416
Last Inspected On: 04/17/2019
Operating Permit Renewal Date: 07/20/2022

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Ben Taylor Inc		**bti@3rivers.net**
Operator Contact:	Tom Fetters	**(406) 278-5213**	**bti@3rivers.net**

Gail Mullennax, UST Class B Operator
Gail Mullennax, UST Class B Operator
Gail Mullennax, UST Class B Operator
Tom Fetters, UST Class A Operator bti@3rivers.net
Tom Fetters, UST Class A Operator bti@3rivers.net
Tom Fetters, UST Class A Operator bti@3rivers.net
Tom Fetters, UST Class B Operator bti@3rivers.net
Tom Fetters, UST Class B Operator bti@3rivers.net
Tom Fetters, UST Class B Operator bti@3rivers.net

Tank Number	03	**Tank Age**	32	**Tank Installed Date**	05/12/1993	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve
Tag Number	423	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	None	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**	04/17/2019	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**		**Line Tightness Test Date**	04/17/2019	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/ILS-250				
Tank Number	04	**Tank Age**	32	**Tank Installed Date**	05/12/1993	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve
Tag Number	424	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	None	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**	04/17/2019	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible

Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	16000	**ATG Test Date**		**Line Tightness Test Date**	04/17/2019	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/ILS-250				
Tank Number	05	**Tank Age**	32	**Tank Installed Date**	05/12/1993	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve
Tag Number	425	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	None	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**	04/17/2019	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**		**Line Tightness Test Date**	04/17/2019	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					

Facility Summary in Flathead County in the City of Whitefish

Location: TOWN PUMP INC WHITEFISH 1
6600 US Hwy 93 S
Whitefish, MT 59937 Flathead

System Facility ID:15-10105

Facility Code: 20827
Last Inspected On: 05/24/2023
Operating Permit Renewal Date: 08/31/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Whitefish 1 Town Pump LLC	**(406) 497-6700**	**environmental@townpump.com**
Operator Contact:	Trent Biggers		**Trentb@townpump.com**

Owner/Operator:	Whitefish 1 Town Pump LLC	(406) 497-6700	environmental@townpump.com
	Trent Biggers, UST Class A Operator		Trentb@townpump.com
	Trent Biggers, UST Class A Operator		Trentb@townpump.com
	Trent Biggers, UST Class B Global Operator		Trentb@townpump.com
	Trent Biggers, UST Class B Global Operator		Trentb@townpump.com

Tank Number	01	**Tank Age**	35	**Tank Installed Date**	01/17/1990	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	2428	**Spill Test Date**	10/22/2024	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	10/22/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Diesel	**PLLD Test Date**	04/28/2021	**Tank/Piping CP Test Date**	11/18/2021	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	05/24/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	09/22/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Number	03	**Tank Age**	35	**Tank Installed Date**	01/17/1990	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	2430	**Spill Test Date**	11/16/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Gasoline	**PLLD Test Date**	04/28/2021	**Tank/Piping CP Test Date**	11/18/2021	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	05/24/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No

		Overfill Test Date	09/22/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Number	04	**Tank Age**	35	**Tank Installed Date**	01/17/1990	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	2431	**Spill Test Date**	10/22/2024	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Gasoline	**PLLD Test Date**	04/28/2021	**Tank/Piping CP Test Date**	11/18/2021	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	05/24/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	09/22/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Number	02	**Tank Age**	35	**Tank Installed Date**	01/17/1990	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	4306	**Spill Test Date**	11/16/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Gasoline	**PLLD Test Date**	04/28/2021	**Tank/Piping CP Test Date**	11/18/2021	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	05/24/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	09/22/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Number	05	**Tank Age**	21	**Tank Installed Date**	10/01/2004	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve
Tag Number	4941	**Spill Test Date**	10/22/2024	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Gasoline	**PLLD Test Date**	04/28/2021	**Tank/Piping CP Test Date**	11/18/2021	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	20000	**ATG Test Date**	05/24/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	09/22/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				

Facility Summary in Flathead County in the City of Whitefish

Location: TOWN PUMP WHITEFISH 2
4825 US Hwy 40
Whitefish, MT 59937 Flathead

System Facility ID:60-15355

Facility Code: 32453
Last Inspected On: 05/29/2023
Operating Permit Renewal Date: 05/29/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Whitefish #2 Town Pump LLC **(406) 497-6900** **environmental@townpump.com**

Operator Contact: Trent Biggers;Town Pump **Trentb@townpump.com;environmental@townpump.com**

Owner/Operator: Whitefish #2 Town Pump LLC (406) 497-6900 environmental@townpump.com

Trent Biggers, UST Class A Operator environmental@townpump.com

Trent Biggers, UST Class B Global Operator environmental@townpump.com

Tank Number	01	**Tank Age**	4	**Tank Installed Date**	11/26/2021	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	6044	**Spill Test Date**	09/27/2022	**Piping Installed Date**	11/26/2021	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	10/24/2021	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	Yes
Capacity	30000	**ATG Test Date**	05/24/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Statistical Inventory Reconciliation	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	Yes
		Overfill Test Date	09/27/2022			**ATG Type**					
Tank Number	02	**Tank Age**	4	**Tank Installed Date**	11/26/2021	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	6045	**Spill Test Date**	09/27/2022	**Piping Installed Date**	11/26/2021	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	10/24/2021	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	Yes
Capacity	6000	**ATG Test Date**	05/24/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Statistical Inventory Reconciliation	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	Yes
		Overfill Test Date	09/27/2022			**ATG Type**					

Tank Number	03	**Tank Age**	4	**Tank Installed Date**	11/26/2021	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	6046	**Spill Test Date**	09/27/2022	**Piping Installed Date**	11/26/2021	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	10/24/2021	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	Yes
Capacity	15000	**ATG Test Date**	05/24/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Statistical Inventory Reconciliation	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	Yes
		Overfill Test Date	09/27/2022			**ATG Type**					
Tank Number	04	**Tank Age**	4	**Tank Installed Date**	11/26/2021	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	6047	**Spill Test Date**	09/27/2022	**Piping Installed Date**	11/26/2021	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**	05/24/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Statistical Inventory Reconciliation	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	Yes
		Overfill Test Date	09/27/2022			**ATG Type**					
Tank Number	05	**Tank Age**	4	**Tank Installed Date**	11/26/2021	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	6048	**Spill Test Date**	09/27/2022	**Piping Installed Date**	11/26/2021	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	10/24/2021	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel, Dyed	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	7000	**ATG Test Date**	05/24/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Statistical Inventory Reconciliation	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	Yes
		Overfill Test Date	09/27/2022			**ATG Type**					
Tank Number	06	**Tank Age**	4	**Tank Installed Date**	11/26/2021	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	6049	**Spill Test Date**	09/27/2022	**Piping Installed Date**	11/26/2021	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No

Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	10/24/2021	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	20000	**ATG Test Date**	05/24/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Statistical Inventory Reconciliation	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	Yes
		Overfill Test Date	09/27/2022			**ATG Type**					

Facility Summary in Flathead County in the City of Whitefish

Location: WHITEFISH LAKE LODGE
1380 Wisconsin Ave
Whitefish, MT 59937-3338 Flathead

System Facility ID:15-12719

Facility Code: 21003
Last Inspected On: 08/29/2023
Operating Permit Renewal Date: 04/30/2019

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Whitefish Lake Lodge

Operator Contact: Chris Gulick;Dave Wood;Heath Howell **(406) 863-4000;(406) 863-4049;(615) 426-3939** **chrisgulick@lodgeatwhitefishlake.com;marina@lodgeatwhitefishlake.com**

Owner/Operator: Whitefish Lake Lodge

Chris Gulick, UST Class A Operator	chrisgulick@lodgeatwhitefishlake.com
Chris Gulick, UST Class B Operator	chrisgulick@lodgeatwhitefishlake.com
Dave Wood, UST Class A Operator	marina@lodgeatwhitefishlake.com
Dave Wood, UST Class B Operator	marina@lodgeatwhitefishlake.com
Heath Howell, UST Class A Operator	
Heath Howell, UST Class B Operator	

Tank Number	01	**Tank Age**	33	**Tank Installed Date**	04/01/1992	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	
Tag Number		**Spill Test Date**		**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Other**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**		**Piping Type**	Pressurized	**CP Met Types**	
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring;MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	02	**Tank Age**	33	**Tank Installed Date**	04/01/1992	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve
Tag Number	4898	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	08/22/2017	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No

Capacity	4000	**ATG Test Date**		**Line Tightness Test Date**	07/22/2014	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Flathead County in the City of Whitefish

Location: WHITEFISH WESTSIDE MARKET
145 2nd St W
Whitefish, MT 59937 Flathead

System Facility ID:15-00112

Facility Code: 20516
Last Inspected On: 08/22/2024
Operating Permit Renewal Date: 09/06/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	West 2nd Property Group LLC	**(406) 862-4535**	**westsidemarket406@gmail.com**
Operator Contact:	Bill Kahle;Whitefish Westside Market LLC	**(406) 862-4535**	**westsidemarket406@gmail.com;westsidemarket406@gmail.com**

Owner/Operator: West 2nd Property Group LLC (406) 862-4535 westsidemarket406@gmail.com

Bill Kahle, UST Class A Operator westsidemarket406@gmail.com

Bill Kahle, UST Class B Operator westsidemarket406@gmail.com

Tank Number	03	**Tank Age**	29	**Tank Installed Date**	11/01/1996	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	3421	**Spill Test Date**	10/17/2024	**Piping Installed Date**	05/08/2018	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	08/22/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	08/22/2024	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	08/22/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date	08/22/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-300				
Tank Number	04	**Tank Age**	29	**Tank Installed Date**	11/01/1996	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	3422	**Spill Test Date**		**Piping Installed Date**	05/08/2018	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	05/07/2018	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	02/27/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/TLS-300				

Facility Summary in Gallatin County in the City of Belgrade

Location: BELGRADE CARD LOCK
163 Thunder Rd
Belgrade, MT 59714-8939 Gallatin

System Facility ID:56-14162

Facility Code: 30793
Last Inspected On: 11/27/2023
Operating Permit Renewal Date: 03/16/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Parkland USA Corporation **(701) 852-1194** **Jake.thomas@parklandusa.com**

Operator Contact: Calvin Wilson;Jason Shanley

Owner/Operator: Parkland USA Corporation (701) 852-1194 Jake.thomas@parklandusa.com

Caleb Jensen, UST Class B Operator calebj@storydist.com
Calvin Wilson, UST Class A Operator
Calvin Wilson, UST Class B Global Operator
Jason Shanley, UST Class A Operator
Jason Shanley, UST Class B Global Operator
Kelly Shutes, UST Class B Global Operator

Tank Number	01	**Tank Age**	20	**Tank Installed Date**	09/05/2005	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	4999	**Spill Test Date**	11/27/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	07/19/2023	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	07/19/2023	**Line Tightness Test Date**	11/29/2017	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	11/27/2023			**ATG Type**	Gilbarco/EMC Basic				
Tank Number	02	**Tank Age**	20	**Tank Installed Date**	09/05/2005	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	5000	**Spill Test Date**	11/27/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	07/19/2023	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	20000	**ATG Test Date**	07/19/2023	**Line Tightness Test Date**	09/20/2020	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No

		Overfill Test Date	11/27/2023			**ATG Type**	Gilbarco/EMC Basic				
Tank Number	03	**Tank Age**	20	**Tank Installed Date**	09/05/2005	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	5001	**Spill Test Date**	11/27/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	07/19/2023	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	07/19/2023	**Line Tightness Test Date**	10/07/2020	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	11/27/2023			**ATG Type**	Gilbarco/EMC Basic				
Tank Number	04	**Tank Age**	20	**Tank Installed Date**	09/05/2005	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	5002	**Spill Test Date**	11/27/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	07/19/2023	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	07/19/2023	**Line Tightness Test Date**	09/20/2020	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	11/27/2023			**ATG Type**	Gilbarco/EMC Basic				
Tank Number	05	**Tank Age**	20	**Tank Installed Date**	09/16/2005	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	5003	**Spill Test Date**	11/27/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	07/19/2023	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	15000	**ATG Test Date**	07/19/2023	**Line Tightness Test Date**	09/18/2020	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	11/27/2023			**ATG Type**	Gilbarco/EMC Basic				
Tank Number	06	**Tank Age**	20	**Tank Installed Date**	09/05/2005	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	5004	**Spill Test Date**	11/27/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No

Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	07/19/2023	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**	07/19/2023	**Line Tightness Test Date**	09/22/2020	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	11/27/2023			**ATG Type**	Gilbarco/EMC Basic				
Tank Number	07	**Tank Age**	20	**Tank Installed Date**	09/05/2005	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	5063	**Spill Test Date**	11/27/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	07/19/2023	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	20000	**ATG Test Date**	07/19/2023	**Line Tightness Test Date**	09/26/2020	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	11/27/2023			**ATG Type**	Gilbarco/EMC Basic				

Facility Summary in Gallatin County in the City of Belgrade

Location: CENTRAL COPTERS
395 Jetway Dr
Belgrade, MT 59714 Gallatin

System Facility ID:60-15232

Facility Code: 30949
Last Inspected On: 05/06/2025
Operating Permit Renewal Date: 08/24/2028

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Central Copters	**(406) 586-9185**	**mark@centralcopters.com**
Operator Contact:	Brian Geary;Mark Duffy	**(406) 586-9185**	**brian@centralcopters.com;mark@centralcopters.com**

Owner/Operator: Central Copters (406) 586-9185 mark@centralcopters.com

Brian Geary, UST Class A Operator	brian@centralcopters.com
Brian Geary, UST Class B Operator	brian@centralcopters.com
Mark Duffy, UST Class A Operator	mark@centralcopters.com
Mark Duffy, UST Class B Operator	mark@centralcopters.com

Tank Number	01	**Tank Age**	9	**Tank Installed Date**	03/01/2016	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	5547	**Spill Test Date**	05/06/2025	**Piping Installed Date**	10/14/2015	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	05/06/2025	**Sump Tightness Test Date**	05/06/2025	**Catastrophic L.D. Type 3.0**	Auto Dialer;Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Jet Fuel (Jet-A, Jet-A1, JP5)	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	05/06/2025	**Line Tightness Test Date**	02/28/2020	**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**		**Energy Act**	Yes
		Overfill Test Date	05/06/2025			**ATG Type**	Gilbarco-Veeder Root/TLS-300;Veeder Root/TLS-300				

Facility Summary in Gallatin County in the City of Belgrade

Location: CIRCLE K STORE 2746506
402 Belgrade BLVD
Belgrade, MT 59714 Gallatin

System Facility ID:60-15351

Facility Code: 32437
Last Inspected On: 04/08/2024
Operating Permit Renewal Date: 08/01/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Rocky Mountain Oil LLC **(602) 728-8000** **NT-ESS@Circlek.com**

Operator Contact: Veronica Rivera **ESS-WestCoast@circlek.com**

Owner/Operator: Rocky Mountain Oil LLC (602) 728-8000 NT-ESS@Circlek.com

Kenneth Sheehan, UST Class B Global Operator kennethjordansheehan@gmail.com

Veronica Rivera, UST Class A Operator ESS-WestCoast@circlek.com

Tank Number	1	**Tank Age**	4	**Tank Installed Date**	01/23/2021	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	6016	**Spill Test Date**	04/08/2024	**Piping Installed Date**	01/23/2021	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	04/08/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	Yes
Capacity	20000	**ATG Test Date**	11/13/2023	**Line Tightness Test Date**	02/24/2021	**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	11/13/2023			**ATG Type**					
Tank Number	2	**Tank Age**	4	**Tank Installed Date**	01/23/2021	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	6017	**Spill Test Date**	04/08/2024	**Piping Installed Date**	01/23/2021	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	04/08/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	Yes
Capacity	12000	**ATG Test Date**	11/13/2023	**Line Tightness Test Date**	02/24/2021	**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	11/13/2023			**ATG Type**					
Tank Number	3	**Tank Age**	4	**Tank Installed Date**	01/23/2021	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve

Tag Number	6018	**Spill Test Date**	04/08/2024	**Piping Installed Date**	01/23/2021	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	04/08/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	Yes
Capacity	8000	**ATG Test Date**	11/13/2023	**Line Tightness Test Date**	02/23/2021	**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	11/13/2023			**ATG Type**					
Tank Number	4	**Tank Age**	4	**Tank Installed Date**	01/23/2021	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	6019	**Spill Test Date**	04/08/2024	**Piping Installed Date**	01/23/2021	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	04/08/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	11/13/2023	**Line Tightness Test Date**	02/23/2021	**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	11/13/2023			**ATG Type**					

Facility Summary in Gallatin County in the City of Belgrade

Location: FORMER FLYING J INC BELGRADE
6505 Jackrabbit Ln
Belgrade, MT 59714-8990 Gallatin

System Facility ID:16-05753

Facility Code: 21368
Last Inspected On: 12/07/2023
Operating Permit Renewal Date: 12/14/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Belgrade 5 RE2 LLC	**(406) 497-6700**	**environmental@townpump.com**
Operator Contact:	Trent Biggers;Town Pump		**Trentb@townpump.com;environmental@townpump.com**

Trent Biggers, UST Class A Operator	environmental@townpump.com
Trent Biggers, UST Class A Operator	environmental@townpump.com
Trent Biggers, UST Class B Operator	environmental@townpump.com
Trent Biggers, UST Class B Operator	environmental@townpump.com

Tank Number	01	**Tank Age**	49	**Tank Installed Date**	04/26/1976	**Tank Material Construction**	Bare Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	3793	**Spill Test Date**		**Piping Installed Date**	08/31/2011	**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**	10/05/2020	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	09/06/2018	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	56000	**ATG Test Date**		**Line Tightness Test Date**	10/05/2020	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	02	**Tank Age**	49	**Tank Installed Date**	04/26/1976	**Tank Material Construction**	Bare Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	3794	**Spill Test Date**	01/15/2021	**Piping Installed Date**	12/08/2021	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**	10/05/2020	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	09/06/2018	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	56000	**ATG Test Date**		**Line Tightness Test Date**	08/09/2020	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No

		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	03	**Tank Age**	49	**Tank Installed Date**	04/26/1976	**Tank Material Construction**	Bare Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	3795	**Spill Test Date**	02/01/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**	12/07/2022	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	09/06/2018	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	20000	**ATG Test Date**		**Line Tightness Test Date**	12/07/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	05	**Tank Age**	49	**Tank Installed Date**	04/01/1976	**Tank Material Construction**	Bare Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	3796	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**	10/05/2020	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	09/06/2018	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	20000	**ATG Test Date**		**Line Tightness Test Date**	10/05/2020	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	04	**Tank Age**	49	**Tank Installed Date**	04/26/1976	**Tank Material Construction**	Bare Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	3797	**Spill Test Date**		**Piping Installed Date**	12/08/2021	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**	10/05/2020	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	09/06/2018	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	56000	**ATG Test Date**		**Line Tightness Test Date**	07/28/2020	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring;ELLD 0.2	**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Gallatin County in the City of Belgrade

Location: GALLATIN FIELD AIRPORT
633 Gallatin Field Rd
Belgrade, MT 59714 Gallatin

System Facility ID:60-15152

Facility Code: 30893
Last Inspected On: 03/25/2025
Operating Permit Renewal Date: 07/03/2028

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Parkland USA Corporation	**(701) 852-1194**	**Jake.thomas@parklandusa.com**
Operator Contact:	Vern Patterson;Parkland USA Corporation	**(701) 720-6649;(701) 852-1194**	**vern.patterson@parklandusa.com;Jake.thomas@parklandusa.com**

Owner/Operator: Parkland USA Corporation (701) 852-1194 Jake.thomas@parklandusa.com

Vern Patterson, UST Class A Operator Jake.thomas@parklandusa.com

Vern Patterson, UST Class B Operator Jake.thomas@parklandusa.com

Tank Number	01	**Tank Age**	15	**Tank Installed Date**	04/13/2010	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	5236	**Spill Test Date**	03/26/2025	**Piping Installed Date**	04/08/2010	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	07/24/2024	**Sump Tightness Test Date**	03/26/2025	**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	07/24/2024	**Line Tightness Test Date**	07/01/2022	**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	MLLD Line Tightness Testing	**Energy Act**	Yes
		Overfill Test Date	03/26/2025			**ATG Type**	Gilbarco-Veeder Root/TLS-300;Veeder Root/TLS-300				

Facility Summary in Gallatin County in the City of Belgrade

Location: GALLATIN FIELD MAINTENANCE SHOP
311 Wings Way
Belgrade, MT 59714 Gallatin

System Facility ID:16-12952

Facility Code: 21806
Last Inspected On: 04/18/2019
Operating Permit Renewal Date: 07/22/2022

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Gallatin Field Airport	**paul.schneider@bozemanairport.com**
Operator Contact:	Calvin Wilson;Gary Scales;Jason Shanley	**garys@storydist.com**

Caleb Jensen, UST Class B Operator	calebj@storydist.com
Calvin Wilson, UST Class A Operator	
Calvin Wilson, UST Class B Global Operator	
Gary Scales, UST Class A Operator	garys@storydist.com
Gary Scales, UST Class B Global Operator	garys@storydist.com
Jason Shanley, UST Class A Operator	
Jason Shanley, UST Class B Operator	
Kelly Shutes, UST Class B Global Operator	

Tank Number	S1	**Tank Age**	33	**Tank Installed Date**	11/01/1992	**Tank Material Construction**	Bare Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	
Tag Number	2032	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	Yes
Status	**Permanently Out of Use**	**MLLD Test Date**	07/26/2018	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**		**Line Tightness Test Date**	07/26/2018	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					

Facility Summary in Gallatin County in the City of Belgrade

Location: QWEST COMMUNICATIONS
95 N Broadway
Belgrade, MT 59714-3702 Gallatin

System Facility ID:56-13996

Facility Code: 30657
Last Inspected On: 09/19/2023
Operating Permit Renewal Date: 03/14/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Qwest Corporation/Century Link **kevin.robison@centurylink.com**

Operator Contact: Stephanie Miller **(501) 680-8141** **Stephanie.miller@lumen.com**

Owner/Operator: Qwest Corporation/Century Link kevin.robison@centurylink.com

Stephanie Miller, UST Class A Operator Stephanie.miller@lumen.com

Stephanie Miller, UST Class B Global Operator Stephanie.miller@lumen.com

Tank Number	01	**Tank Age**	24	**Tank Installed Date**	11/01/2001	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	4266	**Spill Test Date**	09/19/2023	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Auto Dialer	**Piping Type**	U.S. Suction	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	3-Year Line Tightness Test	**Vapor Recovery**	No
Capacity	1000	**ATG Test Date**	12/18/2024	**Line Tightness Test Date**	09/19/2023	**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	12/18/2024			**ATG Type**	Veeder Root/TLS-4I, B, C				

Facility Summary in Gallatin County in the City of Belgrade

Location: ROCKY MOUNTAIN SUPPLY INC BELGRADE
350 Jackrabbit Ln
Belgrade, MT 59714-3035 Gallatin

System Facility ID:16-12101

Facility Code: 21757
Last Inspected On: 11/27/2023
Operating Permit Renewal Date: 02/26/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Rocky Mountain Supply Inc	**(406) 388-4009**	**billballiet@rmsi.coop**
Operator Contact:	Jason Rorabaugh	**(406) 388-6116**	**jasonrorabaugh@rmsi.coop**

Owner/Operator: Rocky Mountain Supply Inc (406) 388-4009 billballiet@rmsi.coop

Jason Rorabaugh, UST Class A Operator jasonrorabaugh@rmsi.coop

Jason Rorabaugh, UST Class B Operator jasonrorabaugh@rmsi.coop

Tank Number	01	**Tank Age**	35	**Tank Installed Date**	09/20/1990	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	1189	**Spill Test Date**	05/18/2022	**Piping Installed Date**	04/01/2019	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	05/17/2022	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**	06/24/2020	**Tank/Piping CP Test Date**	05/18/2022	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	03/14/2024	**Line Tightness Test Date**	12/14/2020	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date	04/25/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-450				
Tank Number	02	**Tank Age**	35	**Tank Installed Date**	09/20/1990	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	1190	**Spill Test Date**	05/18/2022	**Piping Installed Date**	04/01/2019	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	05/17/2022	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**	06/24/2020	**Tank/Piping CP Test Date**	05/18/2022	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	20000	**ATG Test Date**	04/25/2024	**Line Tightness Test Date**	12/13/2020	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date	04/25/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-450				
Tank Number	03	**Tank Age**	35	**Tank Installed Date**	09/20/1990	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm

Tag Number	1191	**Spill Test Date**	05/18/2022	**Piping Installed Date**	04/01/2019	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	05/17/2022	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**	06/24/2020	**Tank/Piping CP Test Date**	05/18/2022	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	03/14/2024	**Line Tightness Test Date**	11/11/2020	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date	05/18/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-450				
Tank Number	04	**Tank Age**	35	**Tank Installed Date**	09/20/1990	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	1192	**Spill Test Date**	05/18/2022	**Piping Installed Date**	04/01/2019	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	05/17/2022	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**	06/24/2020	**Tank/Piping CP Test Date**	05/18/2022	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	20000	**ATG Test Date**	03/14/2024	**Line Tightness Test Date**	11/20/2020	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date	05/18/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-450				
Tank Number	05	**Tank Age**	22	**Tank Installed Date**	10/24/2003	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	4867	**Spill Test Date**	05/18/2022	**Piping Installed Date**	04/01/2019	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	05/17/2022	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	06/24/2020	**Tank/Piping CP Test Date**	05/18/2022	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	03/14/2024	**Line Tightness Test Date**	11/11/2020	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date	05/18/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-450				
Tank Number	06	**Tank Age**	6	**Tank Installed Date**	04/01/2019	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm;Positive Shutoff
Tag Number	5896	**Spill Test Date**	05/18/2022	**Piping Installed Date**	04/01/2019	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	05/17/2022	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	06/24/2020	**Tank/Piping CP Test Date**	05/18/2022	**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	Yes

Capacity	6000	**ATG Test Date**	03/14/2024	**Line Tightness Test Date**	12/15/2020	**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	05/25/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-450;Veeder Root/TLS-450				
Tank Number	07	**Tank Age**	6	**Tank Installed Date**	04/01/2019	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm;Positive Shutoff
Tag Number	5897	**Spill Test Date**	05/18/2022	**Piping Installed Date**	04/01/2019	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	05/17/2022	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	06/24/2020	**Tank/Piping CP Test Date**	05/18/2022	**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**	03/14/2024	**Line Tightness Test Date**	11/14/2020	**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	04/25/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-450;Veeder Root/TLS-450				
Tank Number	08	**Tank Age**	6	**Tank Installed Date**	04/01/2019	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm;Positive Shutoff
Tag Number	5898	**Spill Test Date**		**Piping Installed Date**	04/01/2019	**Tank Construction**	Double-Walled	**Piping Construction**	Single Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	DEF (Not Regulated)	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	ELLD 0.2;ELLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring;Not Listed	**Energy Act**	No
		Overfill Test Date				**ATG Type**	Veeder Root/TLS-450				

Facility Summary in Gallatin County in the City of Belgrade

Location: TOWN PUMP INC BELGRADE 1
206 W Jefferson Ave
Belgrade, MT 59714-4406 Gallatin

System Facility ID:16-13625

Facility Code: 21840
Last Inspected On: 06/11/2025
Operating Permit Renewal Date: 09/16/2025

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Belgrade 1 Town Pump LLC **(406) 497-6700** **environmental@townpump.com**

Operator Contact: Trent Biggers **Trentb@townpump.com**

Owner/Operator: Belgrade 1 Town Pump LLC (406) 497-6700 environmental@townpump.com

Trent Biggers, UST Class A Operator Trentb@townpump.com

Trent Biggers, UST Class B Global Operator Trentb@townpump.com

Tank Number	01	**Tank Age**	30	**Tank Installed Date**	05/01/1995	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	2454	**Spill Test Date**	09/14/2023	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	04/21/2021	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	07/26/2022	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	07/26/2022	**Line Tightness Test Date**	06/30/2015	**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	09/14/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350				
Tank Number	02	**Tank Age**	30	**Tank Installed Date**	05/01/1995	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve;Flapper Valve
Tag Number	2455	**Spill Test Date**	09/14/2023	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	04/21/2021	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	07/26/2022	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	Yes
Capacity	10000	**ATG Test Date**	07/26/2022	**Line Tightness Test Date**	06/30/2015	**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	09/14/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350				

Tank Number	03	**Tank Age**	30	**Tank Installed Date**	05/01/1995	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve;Flapper Valve
Tag Number	2456	**Spill Test Date**	09/14/2023	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	04/21/2021	**Catastrophic L.D. Type 3.0**	Continuous Interstitial Monitoring	**Piping Type**	Safe Suction	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	Yes
Capacity	10000	**ATG Test Date**	07/26/2022	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	09/14/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350				
Tank Number	05	**Tank Age**	30	**Tank Installed Date**	05/01/1995	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve;Flapper Valve
Tag Number	2458	**Spill Test Date**	09/14/2023	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	04/21/2021	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	07/26/2022	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	07/26/2022	**Line Tightness Test Date**	06/30/2015	**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	09/14/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350				
Tank Number	04	**Tank Age**	30	**Tank Installed Date**	05/01/1995	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve;Flapper Valve
Tag Number	4371	**Spill Test Date**	09/14/2023	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	04/21/2021	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	07/26/2022	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	Yes
Capacity	12000	**ATG Test Date**	07/26/2022	**Line Tightness Test Date**	06/30/2015	**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	09/14/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Gallatin County in the City of Belgrade

Location: TOWN PUMP INC BELGRADE 2
691 Jackrabbit Ln
Belgrade, MT 59714-3034 Gallatin

System Facility ID:60-15008

Facility Code: 30798
Last Inspected On: 03/28/2025
Operating Permit Renewal Date: 09/16/2028

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Belgrade 2 Town Pump LLC **(406) 497-6700** **environmental@townpump.com**

Operator Contact: Trent Biggers **Trentb@townpump.com**

Owner/Operator: Belgrade 2 Town Pump LLC (406) 497-6700 environmental@townpump.com

Trent Biggers, UST Class A Operator Trentb@townpump.com

Trent Biggers, UST Class B Global Operator Trentb@townpump.com

Tank Number	01	**Tank Age**	20	**Tank Installed Date**	09/20/2005	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve;Flapper Valve
Tag Number	5019	**Spill Test Date**	06/11/2024	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	04/28/2021	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	03/28/2025	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	Yes
Capacity	25000	**ATG Test Date**	03/28/2025	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	06/11/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Number	02	**Tank Age**	20	**Tank Installed Date**	09/20/2005	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve
Tag Number	5020	**Spill Test Date**	06/11/2024	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	04/28/2021	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	03/28/2025	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	03/28/2025	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No

		Overfill Test Date	06/11/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Number	03	**Tank Age**	20	**Tank Installed Date**	09/20/2005	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve
Tag Number	5021	**Spill Test Date**	06/11/2024	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	04/28/2021	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel, Dyed	**PLLD Test Date**	03/28/2025	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	03/28/2025	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	06/11/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Number	04	**Tank Age**	20	**Tank Installed Date**	09/20/2005	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve;Flapper Valve
Tag Number	5022	**Spill Test Date**	10/23/2024	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	04/28/2021	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	03/28/2025	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	15000	**ATG Test Date**	03/28/2025	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	06/11/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Number	05	**Tank Age**	20	**Tank Installed Date**	09/20/2005	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve
Tag Number	5023	**Spill Test Date**	06/11/2024	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	04/28/2021	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	03/28/2025	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	15000	**ATG Test Date**	03/28/2025	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	06/11/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				

Facility Summary in Gallatin County in the City of Belgrade

Location: TOWN PUMP INC BELGRADE 3
305 E Main St
Belgrade, MT 59714-3850 Gallatin

System Facility ID:16-07788

Facility Code: 21453
Last Inspected On: 04/29/2025
Operating Permit Renewal Date: 10/19/2028

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Belgrade 3 Town Pump LLC **(406) 497-6700** **environmental@townpump.com**

Operator Contact: Trent Biggers **Trentb@townpump.com**

Owner/Operator: Belgrade 3 Town Pump LLC (406) 497-6700 environmental@townpump.com

Trent Biggers, UST Class A Operator Trentb@townpump.com

Trent Biggers, UST Class B Global Operator Trentb@townpump.com

Tank Number	07	**Tank Age**	20	**Tank Installed Date**	08/29/2005	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve
Tag Number	5016	**Spill Test Date**	06/11/2024	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	04/29/2021	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	04/29/2025	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	04/29/2025	**Line Tightness Test Date**	09/11/2005	**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	Yes
		Overfill Test Date	06/11/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Number	08	**Tank Age**	20	**Tank Installed Date**	08/29/2005	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve
Tag Number	5017	**Spill Test Date**	06/11/2024	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	04/29/2021	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	04/29/2025	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	04/29/2025	**Line Tightness Test Date**	09/11/2005	**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	Yes
		Overfill Test Date	06/11/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350				

Tank Number	09	**Tank Age**	20	**Tank Installed Date**	08/29/2005	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve
Tag Number	5026	**Spill Test Date**	06/11/2024	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	04/29/2021	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	04/29/2025	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	20000	**ATG Test Date**	04/29/2025	**Line Tightness Test Date**	09/11/2005	**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	Yes
		Overfill Test Date	06/11/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				

Facility Summary in Gallatin County in the City of Belgrade

Location: TOWN PUMP INC BELGRADE 4
561 Business Hub Dr
Belgrade, MT 59714 Gallatin

System Facility ID:60-15245

Facility Code: 30962
Last Inspected On: 03/13/2025
Operating Permit Renewal Date: 07/22/2028

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Belgrade 4 Town Pump LLC **(406) 497-6700** **environmental@townpump.com**

Operator Contact: Trent Biggers **Trentb@townpump.com**

Owner/Operator: Belgrade 4 Town Pump LLC (406) 497-6700 environmental@townpump.com

Trent Biggers, UST Class A Operator Trentb@townpump.com

Trent Biggers, UST Class B Global Operator Trentb@townpump.com

Tank Number	01	**Tank Age**	11	**Tank Installed Date**	04/14/2014	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	5484	**Spill Test Date**	07/16/2024	**Piping Installed Date**	03/27/2014	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	07/16/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	03/13/2025	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	30000	**ATG Test Date**	03/13/2025	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Statistical Inventory Reconciliation	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	Yes
		Overfill Test Date	07/16/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Number	02	**Tank Age**	11	**Tank Installed Date**	04/14/2014	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	5485	**Spill Test Date**	07/16/2024	**Piping Installed Date**	03/27/2014	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	07/16/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	03/13/2025	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	30000	**ATG Test Date**	03/13/2025	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Statistical Inventory Reconciliation	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	Yes

		Overfill Test Date	07/16/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Number	03	**Tank Age**	11	**Tank Installed Date**	04/14/2014	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	5486	**Spill Test Date**	07/16/2024	**Piping Installed Date**	03/27/2014	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	07/16/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	03/13/2025	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	30000	**ATG Test Date**	03/13/2025	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Statistical Inventory Reconciliation	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	Yes
		Overfill Test Date	07/16/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Number	04	**Tank Age**	11	**Tank Installed Date**	04/14/2014	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	5487	**Spill Test Date**	10/22/2024	**Piping Installed Date**	03/27/2014	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	07/16/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	03/13/2025	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	Yes
Capacity	30000	**ATG Test Date**	03/11/2025	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Statistical Inventory Reconciliation	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	Yes
		Overfill Test Date	07/16/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Number	05	**Tank Age**	11	**Tank Installed Date**	04/14/2014	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	5488	**Spill Test Date**	10/22/2024	**Piping Installed Date**	03/27/2014	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	07/16/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	03/13/2025	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	Yes
Capacity	20000	**ATG Test Date**	03/13/2025	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Statistical Inventory Reconciliation	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	Yes
		Overfill Test Date	07/16/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				

Tank Number	06	**Tank Age**	11	**Tank Installed Date**	04/14/2014	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	5489	**Spill Test Date**	07/16/2024	**Piping Installed Date**	03/27/2014	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	07/16/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	03/13/2025	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	03/13/2025	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Statistical Inventory Reconciliation	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	Yes
		Overfill Test Date	07/16/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Number	07	**Tank Age**	11	**Tank Installed Date**	04/14/2014	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	5490	**Spill Test Date**	07/16/2024	**Piping Installed Date**	03/27/2014	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	07/16/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel, Dyed	**PLLD Test Date**	03/13/2025	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	20000	**ATG Test Date**	03/13/2025	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Statistical Inventory Reconciliation	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	Yes
		Overfill Test Date	07/16/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Number	08	**Tank Age**	11	**Tank Installed Date**	04/14/2014	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Positive Shutoff
Tag Number	5491	**Spill Test Date**		**Piping Installed Date**	03/27/2014	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Other**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**		**Piping Type**	Pressurized	**CP Met Types**	
Product	DEF (Not Regulated)	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	04/24/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Not Listed	**Energy Act**	Yes
		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				

Facility Summary in Gallatin County in the City of Belgrade

Location: YELLOWSTONE JET CENTER LLC
456 Wings Way
Belgrade, MT 59714-8544 Gallatin

System Facility ID:16-04440

Facility Code: 21287
Last Inspected On: 10/17/2023
Operating Permit Renewal Date: 08/04/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Gallatin Airport Authority	**(406) 388-8321**	**brian.sprenger@bozemanairport.com**
Operator Contact:	Al Sandvold;Michael Russell	**(406) 388-3821**	**michael.russell@signatureflight.com**

Al Sandvold, UST Class A Operator
Al Sandvold, UST Class A Operator
Michael Russell, UST Class A Operator michael.russell@signatureflight.com
Michael Russell, UST Class A Operator michael.russell@signatureflight.com
Robert Lemon, UST Class B Operator
Robert Lemon, UST Class B Operator

Tank Number	01	**Tank Age**	48	**Tank Installed Date**	04/11/1977	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Steel	**Overfill Types**	High Level Alarm
Tag Number	2036	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Impressed Current
Product	Aviation Gas	**PLLD Test Date**		**Tank/Piping CP Test Date**	04/20/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	24000	**ATG Test Date**	10/17/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	10/17/2023			**ATG Type**	Veeder Root/TLS-450				
Tank Number	02	**Tank Age**	48	**Tank Installed Date**	04/11/1977	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Steel	**Overfill Types**	High Level Alarm
Tag Number	2037	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Impressed Current
Product	Jet Fuel (Jet-A, Jet-A1, JP5)	**PLLD Test Date**		**Tank/Piping CP Test Date**	04/20/2024	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	24000	**ATG Test Date**	10/17/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No

		Overfill Test Date	10/17/2023			**ATG Type**	Veeder Root/TLS-450				
Tank Number	03	**Tank Age**	48	**Tank Installed Date**	04/11/1977	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Steel	**Overfill Types**	High Level Alarm
Tag Number	2038	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**	Lined Interior/Impressed Current	**Piping Construction**	None	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Impressed Current
Product	Jet Fuel (Jet-A, Jet-A1, JP5)	**PLLD Test Date**		**Tank/Piping CP Test Date**	04/20/2024	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	24000	**ATG Test Date**	10/17/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	10/17/2023			**ATG Type**	Veeder Root/TLS-450				
Tank Number	04	**Tank Age**	50	**Tank Installed Date**	04/12/1975	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Steel	**Overfill Types**	High Level Alarm
Tag Number	2039	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**	Lined Interior/Impressed Current	**Piping Construction**	None	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Impressed Current
Product	Jet Fuel (Jet-A, Jet-A1, JP5)	**PLLD Test Date**		**Tank/Piping CP Test Date**	04/20/2024	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	24000	**ATG Test Date**	10/17/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	10/17/2023			**ATG Type**	Veeder Root/TLS-450				
Tank Number	05	**Tank Age**	50	**Tank Installed Date**	04/12/1975	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Steel	**Overfill Types**	High Level Alarm
Tag Number	2040	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**	Lined Interior/Impressed Current	**Piping Construction**	None	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Jet Fuel (Jet-A, Jet-A1, JP5)	**PLLD Test Date**		**Tank/Piping CP Test Date**	04/20/2024	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	24000	**ATG Test Date**	10/17/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	10/17/2023			**ATG Type**	Veeder Root/TLS-450				
Tank Number	06	**Tank Age**	50	**Tank Installed Date**	04/12/1975	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Steel	**Overfill Types**	High Level Alarm
Tag Number	2041	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No

Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Impressed Current
Product	Jet Fuel (Jet-A, Jet-A1, JP5)	**PLLD Test Date**		**Tank/Piping CP Test Date**	04/20/2024	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	24000	**ATG Test Date**	10/17/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	10/17/2023			**ATG Type**	Veeder Root/TLS-450				
Tank Number	07	**Tank Age**	50	**Tank Installed Date**	04/12/1975	**Tank Material Construction**	Bare Steel	**Piping Material**	Steel	**Overfill Types**	High Level Alarm
Tag Number	2042	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Impressed Current
Product	Jet Fuel (Jet-A, Jet-A1, JP5)	**PLLD Test Date**		**Tank/Piping CP Test Date**	04/20/2024	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	24000	**ATG Test Date**	10/17/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	10/17/2023			**ATG Type**	Veeder Root/TLS-450				

Facility Summary in Gallatin County in the City of Big Sky

Location: BIG SKY CONOCO
90 Lone Mountain Trl
Big Sky, MT 59716 Gallatin

System Facility ID:16-03801

Facility Code: 21263
Last Inspected On: 04/05/2023
Operating Permit Renewal Date: 10/24/2025

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Nevermore Inc **bsconoco@gmail.com**

Operator Contact: Renae Schumacher;Steve Schumacher **(406) 581-1357;(406) 995-4275** **bsconoco@ gmail.com or menatwork@3rivers.net;bsconoco@gmail.com**

Owner/Operator: Nevermore Inc bsconoco@gmail.com

Renae Schumacher, UST Class A Operator bsconoco@ gmail.com or menatwork@3rivers.net
Steve Schumacher, UST Class A Operator bsconoco@gmail.com
Steve Schumacher, UST Class B Operator bsconoco@gmail.com

Tank Number	06	**Tank Age**	28	**Tank Installed Date**	05/01/1997	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	3155	**Spill Test Date**	06/29/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	06/29/2022	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	24000	**ATG Test Date**	06/29/2022	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.1	**Energy Act**	No
		Overfill Test Date	06/29/2022			**ATG Type**	Veeder Root/TLS-350				
Tank Number	07	**Tank Age**	28	**Tank Installed Date**	05/01/1997	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	3156	**Spill Test Date**	06/29/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	06/29/2022	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	24000	**ATG Test Date**	06/29/2022	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.1	**Energy Act**	No
		Overfill Test Date	06/29/2022			**ATG Type**	Veeder Root/TLS-350				
Tank Number	S8	**Tank Age**	28	**Tank Installed Date**	05/01/1997	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve

Tag Number	3157	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	U.S. Suction	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	06/29/2022	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	2000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**	Veeder Root/TLS-350				
Tank Number	09	**Tank Age**	24	**Tank Installed Date**	06/01/2001	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve
Tag Number	4488	**Spill Test Date**	06/29/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	07/05/2016	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	5000	**ATG Test Date**	06/29/2022	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.1	**Energy Act**	No
		Overfill Test Date	06/29/2022			**ATG Type**	Veeder Root/TLS-350				
Tank Number	10	**Tank Age**	3	**Tank Installed Date**	12/01/2022	**Tank Material Construction**	Steel Clad	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	6127	**Spill Test Date**	12/13/2022	**Piping Installed Date**	12/01/2022	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	12/13/2022	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	Yes
Capacity	20000	**ATG Test Date**	12/13/2022	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	12/13/2022			**ATG Type**					
Tank Number	11	**Tank Age**	3	**Tank Installed Date**	12/01/2022	**Tank Material Construction**	Steel Clad	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	6128	**Spill Test Date**	12/13/2022	**Piping Installed Date**	12/01/2022	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	12/13/2022	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	12/13/2022	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes

		Overfill Test Date	12/13/2022			**ATG Type**					
Tank Number	12	**Tank Age**	3	**Tank Installed Date**	12/01/2022	**Tank Material Construction**	Steel Clad	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	6129	**Spill Test Date**	12/13/2022	**Piping Installed Date**	12/01/2022	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	12/13/2022	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	Yes
Capacity	8000	**ATG Test Date**	12/13/2022	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	12/13/2022			**ATG Type**					
Tank Number	13	**Tank Age**	3	**Tank Installed Date**	12/01/2022	**Tank Material Construction**	Steel Clad	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	6130	**Spill Test Date**	12/13/2022	**Piping Installed Date**	12/01/2022	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	12/13/2022	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Diesel, Dyed	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	12/13/2022	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	12/13/2022			**ATG Type**					

Facility Summary in Gallatin County in the City of Big Sky

Location: KUNES MONTANA PROPERTY LLC
2300 N Fork Rd
Big Sky, MT 59716 Gallatin

System Facility ID:16-13672

Facility Code: 21844
Last Inspected On: 07/13/2022
Operating Permit Renewal Date: 12/06/2025

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Gregg Kunes	**(262) 749-3014**	**gk@genevaonline.com**
Operator Contact:	Jay Reader		**jreader@wtgerrard.com**

Owner/Operator: Gregg Kunes (262) 749-3014 gk@genevaonline.com

Dennis Franks, UST Class B Global Operator dennis@ajminc.net
Jay Reader, UST Class A Operator jreader@wtgerrard.com
Jay Reader, UST Class B Global Operator jreader@wtgerrard.com

Tank Number	02	**Tank Age**	27	**Tank Installed Date**	10/01/1998	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	3726	**Spill Test Date**	05/23/2022	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	1000	**ATG Test Date**	05/23/2022	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	05/23/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-300				
Tank Number	01	**Tank Age**	30	**Tank Installed Date**	09/01/1995	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	3936	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	05/23/2022	**Sump Tightness Test Date**	05/23/2022	**Catastrophic L.D. Type 3.0**	Auto Dialer;Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	1000	**ATG Test Date**	05/23/2022	**Line Tightness Test Date**	12/02/2019	**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**		**Energy Act**	No

		Overfill Test Date	05/23/2022			**ATG Type**	Veeder Root/TLS-300				

Facility Summary in Gallatin County in the City of Big Sky

Location: SPANISH PEAKS LODGE
995 Settlement Trail
Big Sky, MT 59716 Gallatin

System Facility ID:60-15334

Facility Code: 32347
Last Inspected On: 03/30/2022
Operating Permit Renewal Date: 11/09/2025

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	SP Hotel Owner, LLP	**(406) 995-5140**	**jdonovan@lonemountainland.com**
Operator Contact:	Cory Moran;John Douglas;Stephen Mickulas		**cory@cobbmechanical.com;john.douglas@montage.com;stephen.mickulas@montage.com**

Owner/Operator: SP Hotel Owner, LLP (406) 995-5140 jdonovan@lonemountainland.com

Cory Moran, UST Class A Operator	cory@cobbmechanical.com
Cory Moran, UST Class B Operator	cory@cobbmechanical.com
John Douglas, UST Class A Operator	john.douglas@montage.com
John Douglas, UST Class B Global Operator	john.douglas@montage.com
Stephen Mickulas, UST Class A Operator	stephen.mickulas@montage.com
Stephen Mickulas, UST Class B Global Operator	stephen.mickulas@montage.com

Tank Number	1	**Tank Age**	4	**Tank Installed Date**	08/19/2021	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	5915	**Spill Test Date**	09/12/2022	**Piping Installed Date**	08/19/2021	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	07/13/2021	**Catastrophic L.D. Type 3.0**	Auto Dialer;Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	03/30/2022	**Line Tightness Test Date**	09/12/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	Yes
		Overfill Test Date	03/30/2022			**ATG Type**					

Facility Summary in Gallatin County in the City of Big Sky

Location: WATERMARK HOME
341 Andesite Ridge Rd
Big Sky, MT 59716 Gallatin

System Facility ID:60-15032

Facility Code: 30815
Last Inspected On: 11/09/2022
Operating Permit Renewal Date: 01/11/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Watermark Services	**(406) 209-1400**	**michaelh@pivotalenterprises.com**
Operator Contact:	Michael Hart	**(406) 640-7507**	**michaelh@pivotalenterprises.com**

Owner/Operator: Watermark Services (406) 209-1400 michaelh@pivotalenterprises.com

Michael Hart, UST Class A Operator michaelh@pivotalenterprises.com

Michael Hart, UST Class B Global Operator michaelh@pivotalenterprises.com

Tank Number	01	**Tank Age**	19	**Tank Installed Date**	10/24/2006	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	5133	**Spill Test Date**	11/09/2022	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	12/09/2019	**Catastrophic L.D. Type 3.0**	Auto Dialer	**Piping Type**	U.S. Suction	**CP Met Types**	Non-corrodible
Product	Diesel, Dyed	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	3-Year Line Tightness Test	**Vapor Recovery**	No
Capacity	3000	**ATG Test Date**	10/18/2023	**Line Tightness Test Date**	11/09/2022	**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	11/09/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-300;Veeder Root/TLS-300				

Facility Summary in Gallatin County in the City of Bozeman

Location: 223 EAST MAIN ST
223 E Main St
Bozeman, MT 59715 Gallatin

System Facility ID:60-15322

Facility Code: 31019
Last Inspected On:
Operating Permit Renewal Date: 12/01/2018

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: 223 E Main LLC **(406) 579-3519** **resflyfish@gmail.com**

Operator Contact:

Tank Number	01	**Tank Age**	0	**Tank Installed Date**		**Tank Material Construction**	Bare Steel	**Piping Material**	Steel	**Overfill Types**	
Tag Number	5840	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**		**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**		**Piping Type**	Not Listed	**CP Met Types**	
Product	Heating Oil, No. 1 - 2	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Not Listed	**Primary Pipe Leak Detection**	Not Listed	**Vapor Recovery**	No
Capacity	600	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Not Listed	**Energy Act**	No
		Overfill Test Date				**ATG Type**					

Facility Summary in Gallatin County in the City of Bozeman

Location: BLUE BASKET # 4
1035 Reeves Rd
Bozeman, MT 59718-7731 Gallatin

System Facility ID:16-13115

Facility Code: 21812
Last Inspected On: 02/24/2025
Operating Permit Renewal Date: 06/30/2028

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Blue Basket Markets Billings **(406) 252-0166**

Operator Contact: Brit Miller **(406) 252-0166** **bluebasketmarkets@gmail.com**

Owner/Operator: Blue Basket Markets Billings (406) 252-0166

Brit Miller, UST Class A Operator bluebasketmarkets@gmail.com
Susie Breen, UST Class B Operator bluebasketmarkets@gmail.com
Susie Breen, UST Class B Operator bluebasketmarkets@gmail.com

Tank Number	01	**Tank Age**	32	**Tank Installed Date**	04/01/1993	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	456	**Spill Test Date**	02/24/2025	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**	10/21/2024	**Tank/Piping CP Test Date**	02/24/2025	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	10/21/2024	**Line Tightness Test Date**	11/08/2018	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	10/21/2024			**ATG Type**	Gilbarco/EMC Basic				
Tank Number	02	**Tank Age**	32	**Tank Installed Date**	04/01/1993	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	457	**Spill Test Date**	02/24/2025	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**	10/21/2024	**Tank/Piping CP Test Date**	02/24/2025	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	10/21/2024	**Line Tightness Test Date**	11/07/2018	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	10/21/2024			**ATG Type**	Gilbarco/EMC Basic				
Tank Number	03	**Tank Age**	32	**Tank Installed Date**	04/01/1993	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm

Tag Number	458	**Spill Test Date**	02/24/2025	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**	10/21/2024	**Tank/Piping CP Test Date**	02/24/2025	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	10/21/2024	**Line Tightness Test Date**	11/06/2018	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	10/21/2024			**ATG Type**	Gilbarco/EMC Basic				

Facility Summary in Gallatin County in the City of Bozeman

Location: BOZEMAN DEACONESS HOSPITAL
915 Highland Blvd
Bozeman, MT 59715-6902 Gallatin

System Facility ID:16-09771

Facility Code: 21534
Last Inspected On: 12/01/2022
Operating Permit Renewal Date: 04/05/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Bozeman Deaconess Hospital	**(406) 414-1091**	**bbuhl@bozemanhealth.org**
Operator Contact:	Jason Cocke;William Buhl	**(406) 595-1488**	**bbuhl@bozemanhealth.org;jcoc461@ecy.wa.gov**

Owner/Operator: Bozeman Deaconess Hospital (406) 414-1091 bbuhl@bozemanhealth.org

Jason Cocke, UST Class A Operator	jcoc461@ecy.wa.gov
Jason Cocke, UST Class B Global Operator	jcoc461@ecy.wa.gov
Jason Cocke, UST Class B Operator	jcoc461@ecy.wa.gov
Michael Dawson, UST Class B Operator	dineen.dawson@gmail.com
William Buhl, UST Class A Operator	bbuhl@bozemanhealth.org
William Buhl, UST Class B Operator	bbuhl@bozemanhealth.org

Tank Number	S3	**Tank Age**	21	**Tank Installed Date**	07/15/2004	**Tank Material Construction**	Concrete	**Piping Material**	Flexible Plastic	**Overfill Types**	
Tag Number	4940	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	Yes
Status	**Other**	**MLLD Test Date**		**Sump Tightness Test Date**	11/28/2022	**Catastrophic L.D. Type 3.0**		**Piping Type**	U.S. Suction	**CP Met Types**	
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	04	**Tank Age**	5	**Tank Installed Date**	09/29/2020	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	5932	**Spill Test Date**	09/21/2022	**Piping Installed Date**	09/29/2020	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	11/28/2022	**Catastrophic L.D. Type 3.0**	Auto Dialer	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	09/21/2022	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	22000	**ATG Test Date**	09/21/2022	**Line Tightness Test Date**	09/29/2020	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes

		Overfill Test Date	09/21/2022			**ATG Type**					
Tank Number	05	**Tank Age**	5	**Tank Installed Date**	09/29/2020	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	5933	**Spill Test Date**	09/21/2022	**Piping Installed Date**	09/29/2020	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	11/28/2022	**Catastrophic L.D. Type 3.0**	Auto Dialer	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	09/21/2022	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	09/21/2022	**Line Tightness Test Date**	09/29/2020	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	09/21/2022			**ATG Type**					

Facility Summary in Gallatin County in the City of Bozeman

Location: BOZEMAN KARDLOCK
300 E Griffin Dr
Bozeman, MT 59715 Gallatin

System Facility ID:16-08191

Facility Code: 21485
Last Inspected On: 11/17/2022
Operating Permit Renewal Date: 01/15/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Parkland USA Corporation **(701) 852-1194** **Jake.thomas@parklandusa.com**

Operator Contact: Calvin Wilson

Owner/Operator: Parkland USA Corporation (701) 852-1194 Jake.thomas@parklandusa.com

Calvin Wilson, UST Class A Operator

Calvin Wilson, UST Class B Global Operator

Tank Number	01	**Tank Age**	47	**Tank Installed Date**	05/02/1978	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	3864	**Spill Test Date**	07/14/2021	**Piping Installed Date**		**Tank Construction**	Lined Interior/Impressed Current	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	11/09/2022	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	07/19/2022	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	01/11/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	02	**Tank Age**	47	**Tank Installed Date**	05/02/1978	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	3865	**Spill Test Date**	07/14/2021	**Piping Installed Date**	12/22/2010	**Tank Construction**	Lined Interior/Impressed Current	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	03/22/2021	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	11/09/2022	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	07/19/2022	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No

		Overfill Test Date	01/11/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	03	**Tank Age**	47	**Tank Installed Date**	05/02/1978	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	3866	**Spill Test Date**	07/14/2021	**Piping Installed Date**		**Tank Construction**	Lined Interior/Impressed Current	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Diesel, Dyed	**PLLD Test Date**		**Tank/Piping CP Test Date**	11/09/2022	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	07/19/2022	**Line Tightness Test Date**	11/16/2010	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	07/14/2021			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	04	**Tank Age**	39	**Tank Installed Date**	01/01/1986	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	3867	**Spill Test Date**	07/14/2021	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	11/09/2022	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	07/19/2022	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	01/11/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	05	**Tank Age**	39	**Tank Installed Date**	01/01/1986	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	3868	**Spill Test Date**	07/14/2021	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	11/09/2022	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	07/19/2022	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	07/14/2021			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Gallatin County in the City of Bozeman

Location: BRAKE TIME 253718
717 W College St
Bozeman, MT 59715 Gallatin

System Facility ID:16-05778

Facility Code: 21369
Last Inspected On: 11/11/2024
Operating Permit Renewal Date: 03/02/2028

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	COLLEGE BOZEMAN MT LLC	**(406) 586-8012**	**licensing@btcmstores.com**
Operator Contact:	Omair Bashir	**(832) 539-8190**	**licensing@btcmstores.com**

Owner/Operator: COLLEGE BOZEMAN MT LLC (406) 586-8012 licensing@btcmstores.com

Natalee Crumley, UST Class B Global Operator
Natalee Crumley, UST Class B Global Operator
Omair Bashir, UST Class A Operator licensing@btcmstores.com
Theodore Bezel, UST Class B Global Operator
Theodore Bezel, UST Class B Global Operator

Tank Number	01	**Tank Age**	44	**Tank Installed Date**	04/25/1981	**Tank Material Construction**	Bare Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	3641	**Spill Test Date**	11/08/2024	**Piping Installed Date**	12/26/2014	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	09/16/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**	08/31/2024	**Tank/Piping CP Test Date**	05/10/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**	11/08/2024	**Line Tightness Test Date**	12/18/2014	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date	11/08/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	02	**Tank Age**	44	**Tank Installed Date**	04/25/1981	**Tank Material Construction**	Bare Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	3642	**Spill Test Date**	11/08/2024	**Piping Installed Date**	12/26/2014	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	09/16/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Diesel	**PLLD Test Date**	08/31/2024	**Tank/Piping CP Test Date**	05/10/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	08/31/2024	**Line Tightness Test Date**	12/18/2014	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No

		Overfill Test Date	11/08/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	03	**Tank Age**	44	**Tank Installed Date**	04/25/1981	**Tank Material Construction**	Bare Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	3643	**Spill Test Date**	11/08/2024	**Piping Installed Date**	12/26/2014	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	09/16/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**	07/31/2024	**Tank/Piping CP Test Date**	05/10/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**	08/31/2024	**Line Tightness Test Date**	12/18/2014	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date	11/08/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Gallatin County in the City of Bozeman

Location: BRAKE TIME 253723
1910 W Main St
Bozeman, MT 59718-3906 Gallatin

System Facility ID:16-03913

Facility Code: 21271
Last Inspected On: 02/28/2025
Operating Permit Renewal Date: 06/14/2028

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	MAIN ST BOZEMAN MT LLC	**(832) 539-8190**	**akhatarmuhammad65@gmail.com**
Operator Contact:	John Sumowski;Randal Liebnow;Theodore Bezel;Mini Mart Inc dba Loaf 'N Jug Pueblo	**(513) 964-1568**	**eglegaldept@eg-america.com;randy.liebnow@loafnjug.com**

Owner/Operator:	MAIN ST BOZEMAN MT LLC	(832) 539-8190	akhatarmuhammad65@gmail.com
	Hiede Richardson, UST Class B Global Operator		hiede.richardson@yahoo.com
	Jennifer Coleman, UST Class B Global Operator		
	Jody Hale, UST Class B Operator		jkeasj@gmail.com
	Jody Hale, UST Class B Operator		jkeasj@gmail.com
	John Sumowski, UST Class A Operator		
	John Sumowski, UST Class A Operator		
	Randal Liebnow, UST Class A Operator		randy.liebnow@loafnjug.com
	Randal Liebnow, UST Class B Global Operator		randy.liebnow@loafnjug.com
	Scott Huether, UST Class B Global Operator		mtscorpion1963@msn.com
	Scott Huether, UST Class B Operator		mtscorpion1963@msn.com
	Stevie Ulstad, UST Class B Operator		crazyfroggie2003@yahoo.com
	Theodore Bezel, UST Class A Operator		eglegaldept@eg-america.com
	Theodore Bezel, UST Class A Operator		eglegaldept@eg-america.com
	Theodore Bezel, UST Class B Global Operator		
	Theodore Bezel, UST Class B Global Operator		
	Theodore Bezel, UST Class B Operator		
	Theodore Bezel, UST Class B Operator		
	Timothy Osterman, UST Class B Global Operator		bigoproductions@msn.com
	Timothy Osterman, UST Class B Operator		bigoproductions@msn.com
	Toni Mullen, UST Class B Global Operator		

Tank Number	13	**Tank Age**	40	**Tank Installed Date**	11/01/1985	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	1639	**Spill Test Date**	07/30/2024	**Piping Installed Date**	05/03/2018	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	09/18/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic

Product	Gasoline	**PLLD Test Date**	07/30/2024	**Tank/Piping CP Test Date**	07/30/2024	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	03/14/2025	**Line Tightness Test Date**	10/01/2018	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date	01/30/2025			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	14	**Tank Age**	40	**Tank Installed Date**	11/01/1985	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	1640	**Spill Test Date**	07/30/2024	**Piping Installed Date**	05/03/2018	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	09/18/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**	07/30/2024	**Tank/Piping CP Test Date**	07/30/2024	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	03/14/2025	**Line Tightness Test Date**	10/01/2018	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date	01/30/2025			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	31	**Tank Age**	40	**Tank Installed Date**	11/01/1985	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	1641	**Spill Test Date**	07/30/2024	**Piping Installed Date**	05/03/2018	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	09/18/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**	07/30/2024	**Tank/Piping CP Test Date**	07/30/2024	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	03/14/2025	**Line Tightness Test Date**	10/01/2018	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date	01/30/2025			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	32	**Tank Age**	40	**Tank Installed Date**	11/01/1985	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	1642	**Spill Test Date**	07/30/2024	**Piping Installed Date**	05/03/2018	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	09/18/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**	07/30/2024	**Tank/Piping CP Test Date**	07/30/2024	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	03/14/2025	**Line Tightness Test Date**	10/01/2018	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No

		Overfill Test Date	01/30/2025			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Gallatin County in the City of Bozeman

Location: BRIDGER BOWL INC
15795 Bridger Canyon Rd
Bozeman, MT 59715-8282 Gallatin

System Facility ID:16-01793

Facility Code: 21177
Last Inspected On: 04/26/2024
Operating Permit Renewal Date: 10/01/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Bridger Bowl Inc **(406) 587-2111**

Operator Contact: David Rosengen;Dillan Smith;Robert Allen **(406) 587-2111** **rosngrn@gmail.com;vehicles@bridgerbowl.com**

Owner/Operator: Bridger Bowl Inc (406) 587-2111

David Rosengen, UST Class A Operator rosngrn@gmail.com
David Rosengen, UST Class B Operator rosngrn@gmail.com
Dillan Smith, UST Class A Operator vehicles@bridgerbowl.com
Robert Allen, UST Class A Operator

Tank Number	S7	**Tank Age**	29	**Tank Installed Date**	11/01/1996	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	No Piping	**Overfill Types**	
Tag Number		**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Other**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Gravity Feed	**CP Met Types**	Galvanic
Product	Other	**PLLD Test Date**		**Tank/Piping CP Test Date**	05/28/2009	**Primary Tank Leak Detection**	Deferred	**Primary Pipe Leak Detection**	Deferred	**Vapor Recovery**	No
Capacity	500	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	08	**Tank Age**	27	**Tank Installed Date**	10/30/1998	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	492	**Spill Test Date**	04/26/2024	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	04/26/2024	**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	04/26/2024	**Primary Tank Leak Detection**	Manual Interstitial Monitoring	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	2000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	04/26/2024			**ATG Type**					
Tank Number	09	**Tank Age**	27	**Tank Installed Date**	10/30/1998	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve

Tag Number	493	**Spill Test Date**	04/26/2024	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	04/26/2024	**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	04/26/2024	**Primary Tank Leak Detection**	Manual Interstitial Monitoring	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	1000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	04/26/2024			**ATG Type**					

Facility Summary in Gallatin County in the City of Bozeman

Location: BRIDGER MARKET
2020 N 7th Ave
Bozeman, MT 59715-2516 Gallatin

System Facility ID:16-00758

Facility Code: 21119
Last Inspected On: 08/02/2023
Operating Permit Renewal Date: 11/06/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	BRIDGER MARKET INC	**(406) 922-9577**	**bridgermarket@gmail.com**
Operator Contact:	Natalie Doyle;Williams Pump and Pak Inc	**(406) 922-9577;(406) 922-9577**	**bridgermarket@gmail.com;nataliedoyle101@att.net**

Owner/Operator: BRIDGER MARKET INC (406) 922-9577 bridgermarket@gmail.com

Natalie Doyle, UST Class A Operator nataliedoyle101@att.net

Natalie Doyle, UST Class B Operator nataliedoyle101@att.net

Tank Number	04	**Tank Age**	28	**Tank Installed Date**	06/01/1997	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	2275	**Spill Test Date**	03/20/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	09/17/2020	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	03/20/2023			**ATG Type**	Veeder Root/TLS-300				
Tank Number	05	**Tank Age**	28	**Tank Installed Date**	06/01/1997	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	2276	**Spill Test Date**	10/02/2020	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	10/02/2020	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	09/17/2020	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**		**Line Tightness Test Date**	01/25/2023	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date				**ATG Type**	Veeder Root/TLS-300				

Facility Summary in Gallatin County in the City of Bozeman

Location: CASEYS CORNER 1
81855 Gallatin Rd
Bozeman, MT 59718-8110 Gallatin

System Facility ID:16-06922

Facility Code: 21409
Last Inspected On: 04/13/2022
Operating Permit Renewal Date: 07/22/2025

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Superpumper Inc **(701) 852-1194**

Operator Contact: Vern Patterson;Parkland USA Corporation **(701) 720-6649;(701) 852-1194** **vern.patterson@parklandusa.com;Jake.thomas@parklandusa.com**

Owner/Operator: Superpumper Inc (701) 852-1194

Scott Trullinger, UST Class B Operator Jake.thomas@parklandusa.com
Vern Patterson, UST Class A Operator Jake.thomas@parklandusa.com
Vern Patterson, UST Class B Operator Jake.thomas@parklandusa.com

Tank Number	04	**Tank Age**	34	**Tank Installed Date**	04/10/1991	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	2018	**Spill Test Date**	08/10/2021	**Piping Installed Date**	11/22/2017	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	08/10/2021	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**	08/10/2021	**Tank/Piping CP Test Date**	04/13/2022	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	08/10/2021	**Line Tightness Test Date**	02/26/2019	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date	08/10/2021			**ATG Type**	Veeder Root/TLS-450				
Tank Number	05	**Tank Age**	34	**Tank Installed Date**	04/10/1991	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	2019	**Spill Test Date**	08/10/2021	**Piping Installed Date**	11/22/2017	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	08/10/2021	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**	08/10/2021	**Tank/Piping CP Test Date**	04/13/2022	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	08/10/2021	**Line Tightness Test Date**	02/26/2019	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date	08/10/2021			**ATG Type**	Veeder Root/TLS-450				

Tank Number	06	**Tank Age**	34	**Tank Installed Date**	04/10/1991	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	2020	**Spill Test Date**	08/10/2021	**Piping Installed Date**	11/22/2017	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	08/10/2021	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**	08/10/2021	**Tank/Piping CP Test Date**	04/13/2022	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	08/10/2021	**Line Tightness Test Date**	02/23/2019	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date	01/20/2023			**ATG Type**	Veeder Root/TLS-450				
Tank Number	07	**Tank Age**	29	**Tank Installed Date**	05/01/1996	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	2021	**Spill Test Date**	08/10/2021	**Piping Installed Date**	11/22/2017	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	08/10/2021	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**	08/10/2021	**Tank/Piping CP Test Date**	04/13/2022	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	2000	**ATG Test Date**	08/10/2021	**Line Tightness Test Date**	02/22/2019	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date	01/20/2023			**ATG Type**	Veeder Root/TLS-450				
Tank Number	08	**Tank Age**	29	**Tank Installed Date**	05/01/1996	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	2022	**Spill Test Date**	08/10/2021	**Piping Installed Date**	11/22/2017	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	08/10/2021	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Diesel, Dyed	**PLLD Test Date**	08/10/2021	**Tank/Piping CP Test Date**	04/13/2022	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**	08/10/2021	**Line Tightness Test Date**	02/22/2019	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date	01/20/2023			**ATG Type**	Veeder Root/TLS-450				
Tank Number	09	**Tank Age**	29	**Tank Installed Date**	05/01/1996	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	2023	**Spill Test Date**	08/10/2021	**Piping Installed Date**	11/22/2017	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	08/10/2021	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic

Product	Diesel	**PLLD Test Date**	08/10/2021	**Tank/Piping CP Test Date**	04/13/2022	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	08/10/2021	**Line Tightness Test Date**	02/22/2019	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date	08/10/2021			**ATG Type**	Veeder Root/TLS-450				
Tank Number	10	**Tank Age**	29	**Tank Installed Date**	05/01/1996	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	2024	**Spill Test Date**	08/10/2021	**Piping Installed Date**	11/22/2017	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	08/10/2021	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Diesel, Dyed	**PLLD Test Date**	08/10/2021	**Tank/Piping CP Test Date**	04/13/2022	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	08/10/2021	**Line Tightness Test Date**	02/22/2019	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date	01/20/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-450				
Tank Number	11	**Tank Age**	8	**Tank Installed Date**	09/17/2017	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**		**Overfill Types**	Positive Shutoff
Tag Number	5769	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**		**AST**	No
Status	**Other**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**		**Piping Type**		**CP Met Types**	
Product	DEF (Not Regulated)	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**	Veeder Root/TLS-450				

Facility Summary in Gallatin County in the City of Bozeman

Location: CASEYS CORNER 2
1211 E Main St
Bozeman, MT 59715 Gallatin

System Facility ID:16-08188

Facility Code: 21482
Last Inspected On: 08/15/2022
Operating Permit Renewal Date: 12/31/2025

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Superpumper Inc **(701) 852-1194**

Operator Contact: Vern Patterson;Parkland USA Corporation **(701) 720-6649;(701) 852-1194** **vern.patterson@parklandusa.com;Jake.thomas@parklandusa.com**

Owner/Operator: Superpumper Inc (701) 852-1194

Scott Trullinger, UST Class B Operator Jake.thomas@parklandusa.com
Vern Patterson, UST Class A Operator Jake.thomas@parklandusa.com
Vern Patterson, UST Class B Operator Jake.thomas@parklandusa.com

Tank Number	06	**Tank Age**	27	**Tank Installed Date**	04/01/1998	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	2030	**Spill Test Date**	09/21/2021	**Piping Installed Date**	07/31/2018	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	09/21/2021	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**	09/29/2022	**Tank/Piping CP Test Date**	08/15/2022	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	09/29/2022	**Line Tightness Test Date**	06/10/2019	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date	01/20/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	07	**Tank Age**	27	**Tank Installed Date**	04/01/1998	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	2031	**Spill Test Date**	09/21/2021	**Piping Installed Date**	07/31/2018	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	09/21/2021	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**	09/29/2022	**Tank/Piping CP Test Date**	08/15/2022	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	09/29/2022	**Line Tightness Test Date**	06/10/2019	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No

		Overfill Test Date	01/20/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	04	**Tank Age**	27	**Tank Installed Date**	04/01/1998	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	4576	**Spill Test Date**	01/20/2022	**Piping Installed Date**	07/31/2018	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	09/21/2021	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**	09/29/2022	**Tank/Piping CP Test Date**	08/15/2022	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	09/29/2022	**Line Tightness Test Date**	06/16/2019	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date	01/20/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	05	**Tank Age**	27	**Tank Installed Date**	04/01/1998	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	4577	**Spill Test Date**	01/20/2022	**Piping Installed Date**	07/31/2018	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	09/21/2021	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**	09/29/2022	**Tank/Piping CP Test Date**	08/15/2022	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	09/29/2022	**Line Tightness Test Date**	06/10/2019	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date	01/20/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Gallatin County in the City of Bozeman

Location: CASEYS CORNER 3
1420 N 7th Ave
Bozeman, MT 59715 Gallatin

System Facility ID:16-08190

Facility Code: 21484
Last Inspected On: 08/15/2022
Operating Permit Renewal Date: 12/31/2025

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Superpumper Inc **(701) 852-1194**

Operator Contact: Vern Patterson;Parkland USA Corporation **(701) 720-6649;(701) 852-1194** **vern.patterson@parklandusa.com;Jake.thomas@parklandusa.com**

Owner/Operator: Superpumper Inc (701) 852-1194

Scott Trullinger, UST Class B Operator Jake.thomas@parklandusa.com
Vern Patterson, UST Class A Operator Jake.thomas@parklandusa.com
Vern Patterson, UST Class B Operator Jake.thomas@parklandusa.com

Tank Number	06	**Tank Age**	27	**Tank Installed Date**	12/01/1998	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	3687	**Spill Test Date**	10/10/2024	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**	09/29/2022	**Tank/Piping CP Test Date**	08/15/2022	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	09/29/2022	**Line Tightness Test Date**	01/22/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	08/15/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	07	**Tank Age**	27	**Tank Installed Date**	12/01/1998	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	3688	**Spill Test Date**	08/31/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**	09/29/2022	**Tank/Piping CP Test Date**	08/15/2022	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	14000	**ATG Test Date**	09/29/2022	**Line Tightness Test Date**	10/15/2021	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No

		Overfill Test Date	08/15/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	08	**Tank Age**	20	**Tank Installed Date**	12/28/2005	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve;Flapper Valve
Tag Number	5054	**Spill Test Date**	08/15/2022	**Piping Installed Date**	11/16/2015	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	03/22/2022	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	09/29/2022	**Tank/Piping CP Test Date**	10/07/2010	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	09/29/2022	**Line Tightness Test Date**	10/15/2021	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date	08/15/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Gallatin County in the City of Bozeman

Location: CASEYS CORNER 5
4135 Valley Commons Dr
Bozeman, MT 59718-6427 Gallatin

System Facility ID:16-13775

Facility Code: 21847
Last Inspected On: 12/05/2022
Operating Permit Renewal Date: 02/19/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Superpumper Inc **(701) 852-1194**

Operator Contact: Vern Patterson;Parkland USA Corporation **(701) 720-6649;(701) 852-1194** **vern.patterson@parklandusa.com;Jake.thomas@parklandusa.com**

Owner/Operator: Superpumper Inc (701) 852-1194

Scott Trullinger, UST Class B Operator Jake.thomas@parklandusa.com
Vern Patterson, UST Class A Operator Jake.thomas@parklandusa.com
Vern Patterson, UST Class B Operator Jake.thomas@parklandusa.com

Tank Number	01	**Tank Age**	27	**Tank Installed Date**	03/01/1998	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve
Tag Number	3407	**Spill Test Date**	08/16/2022	**Piping Installed Date**	06/08/2015	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	06/08/2015	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	09/29/2022	**Line Tightness Test Date**	01/18/2024	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date	08/30/2022			**ATG Type**	Gilbarco/EMC Basic				
Tank Number	02	**Tank Age**	27	**Tank Installed Date**	03/01/1998	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve;Flapper Valve
Tag Number	3408	**Spill Test Date**	08/30/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	09/29/2022	**Line Tightness Test Date**	01/18/2024	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	08/30/2022			**ATG Type**	Gilbarco/EMC Basic				

Tank Number	03	**Tank Age**	27	**Tank Installed Date**	03/01/1998	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve;Flapper Valve
Tag Number	3409	**Spill Test Date**	08/16/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	01/18/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	09/29/2022	**Line Tightness Test Date**	08/07/2013	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	08/16/2022			**ATG Type**	Gilbarco/EMC Basic				

Facility Summary in Gallatin County in the City of Bozeman

Location: CIRCLE K STORE 2746305
1951 Durston Rd
Bozeman, MT 59718-2738 Gallatin

System Facility ID:56-13937

Facility Code: 30607
Last Inspected On: 08/15/2022
Operating Permit Renewal Date: 12/20/2025

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Rocky Mountain Oil LLC	**(602) 728-8000**	**NT-ESS@Circlek.com**
Operator Contact:	Chuck Nyberg;Patrick Patnaude;Stephen Reckinger;Valeria Jeffries;Veronica Rivera	**(952) 830-8028;(952) 830-8721;(952) 830-8722**	**ESS-WestCoast@circlek.com;patrick.patnaude@holidaycompanies.com;steve.reckinger@holidaycompanies.com;valeria.jeffries@holidaycompanies.com**

Owner/Operator:	Rocky Mountain Oil LLC	(602) 728-8000	NT-ESS@Circlek.com
	Brad Lee, UST Class B Global Operator		brad.lee@holidaycompanies.com
	Chuck Nyberg, UST Class A Operator		
	Jeff Reed, UST Class B Global Operator		jeff.reed@holidaycompanies.com
	Jeff Reed, UST Class B Global Operator		jeff.reed@holidaycompanies.com
	Patrick Patnaude, UST Class A Operator		patrick.patnaude@holidaycompanies.com
	Patrick Patnaude, UST Class A Operator		patrick.patnaude@holidaycompanies.com
	Stephen Reckinger, UST Class A Operator		steve.reckinger@holidaycompanies.com
	Steve Ulery, UST Class B Operator		steveulery@msn.com
	Steve Ulery, UST Class B Operator		steveulery@msn.com
	Todd White, UST Class B Global Operator		todd.white@holidaycompanies.com
	Todd White, UST Class B Global Operator		todd.white@holidaycompanies.com
	Valeria Jeffries, UST Class A Operator		valeria.jeffries@holidaycompanies.com
	Veronica Rivera, UST Class A Operator		ESS-WestCoast@circlek.com
	Veronica Rivera, UST Class A Operator		ESS-WestCoast@circlek.com
	Veronica Rivera, UST Class B Operator		ESS-WestCoast@circlek.com
	Veronica Rivera, UST Class B Operator		ESS-WestCoast@circlek.com

Tank Number	01	**Tank Age**	26	**Tank Installed Date**	06/01/1999	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	4047	**Spill Test Date**	06/21/2021	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	06/30/2022	**Tank/Piping CP Test Date**	10/02/2007	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	Yes
Capacity	8000	**ATG Test Date**	06/30/2022	**Line Tightness Test Date**	03/12/2019	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No

		Overfill Test Date	06/30/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	02	**Tank Age**	26	**Tank Installed Date**	06/01/1999	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	4048	**Spill Test Date**	01/04/2022	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	06/30/2022	**Tank/Piping CP Test Date**	10/02/2007	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	Yes
Capacity	8000	**ATG Test Date**	06/30/2022	**Line Tightness Test Date**	03/12/2019	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	06/30/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	05	**Tank Age**	26	**Tank Installed Date**	06/01/1999	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	4051	**Spill Test Date**	06/21/2021	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	06/30/2022	**Tank/Piping CP Test Date**	10/02/2007	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	06/30/2022	**Line Tightness Test Date**	03/05/2019	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	06/30/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	03	**Tank Age**	26	**Tank Installed Date**	06/01/1999	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	4566	**Spill Test Date**	01/04/2022	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	06/30/2022	**Tank/Piping CP Test Date**	10/02/2007	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	Yes
Capacity	8000	**ATG Test Date**	06/30/2022	**Line Tightness Test Date**	03/10/2019	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	06/30/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	04	**Tank Age**	26	**Tank Installed Date**	06/01/1999	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve

Tag Number	4567	**Spill Test Date**	06/21/2021	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	06/30/2022	**Tank/Piping CP Test Date**	10/02/2007	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	Yes
Capacity	8000	**ATG Test Date**	06/30/2022	**Line Tightness Test Date**	03/07/2019	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	06/30/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Gallatin County in the City of Bozeman

Location: COLLEGE EXXON SERVICE STATION
723 S 8th Ave
Bozeman, MT 59715-4414 Gallatin

System Facility ID:16-00472

Facility Code: 21108
Last Inspected On: 04/15/2024
Operating Permit Renewal Date: 08/20/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: College Chevron of Bozeman Inc **(406) 587-4453**

Operator Contact: David Lapinski **dalapski@yahoo.com**

Owner/Operator: College Chevron of Bozeman Inc (406) 587-4453

David Lapinski, UST Class A Operator	dalapski@yahoo.com
David Lapinski, UST Class A Operator	dalapski@yahoo.com
David Lapinski, UST Class B Operator	dalapski@yahoo.com
David Lapinski, UST Class B Operator	dalapski@yahoo.com

Tank Number	06	**Tank Age**	27	**Tank Installed Date**	04/01/1998	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	694	**Spill Test Date**	06/03/2021	**Piping Installed Date**	11/14/2024	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	11/14/2024	**Sump Tightness Test Date**	11/14/2024	**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	06/03/2021	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**	06/03/2021	**Line Tightness Test Date**	11/15/2024	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	MLLD Line Tightness Testing	**Energy Act**	No
		Overfill Test Date	06/03/2021			**ATG Type**	Veeder Root/TLS-300				
Tank Number	07	**Tank Age**	27	**Tank Installed Date**	04/01/1998	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	695	**Spill Test Date**	06/03/2021	**Piping Installed Date**	11/14/2024	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	11/14/2024	**Sump Tightness Test Date**	11/14/2024	**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	06/03/2021	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	06/03/2021	**Line Tightness Test Date**	11/15/2024	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	MLLD Line Tightness Testing	**Energy Act**	No
		Overfill Test Date	06/03/2021			**ATG Type**	Veeder Root/TLS-300				

Facility Summary in Gallatin County in the City of Bozeman

Location: COSTCO WHOLESALE GASOLINE BOZEMAN
2505 Catron St
Bozeman, MT 59718 Gallatin

System Facility ID:60-15075

Facility Code: 30846
Last Inspected On: 05/12/2025
Operating Permit Renewal Date: 08/22/2025

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Costco Wholesale	**(425) 251-6222**	**gaslicenses@costco.com**
Operator Contact:	Charlie Brown;Herbert Burnell;Pamela Williams		**w096gas@costco.com**

Owner/Operator: Costco Wholesale (425) 251-6222 gaslicenses@costco.com

Charlie Brown, UST Class A Operator	w096gas@costco.com
Charlie Brown, UST Class B Operator	w096gas@costco.com
Herbert Burnell, UST Class A Operator	w096gas@costco.com
Herbert Burnell, UST Class B Operator	w096gas@costco.com
Pamela Williams, UST Class A Operator	w096gas@costco.com
Pamela Williams, UST Class B Operator	w096gas@costco.com

Tank Number	01	**Tank Age**	18	**Tank Installed Date**	10/24/2007	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	5130	**Spill Test Date**	02/03/2020	**Piping Installed Date**	08/23/2007	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	01/13/2020	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	09/15/2021	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	30000	**ATG Test Date**	09/15/2021	**Line Tightness Test Date**	09/15/2021	**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	06/28/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350				
Tank Number	02	**Tank Age**	18	**Tank Installed Date**	10/24/2007	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	5131	**Spill Test Date**	02/03/2020	**Piping Installed Date**	08/23/2007	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	01/13/2020	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	09/15/2021	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No

Capacity	30000	**ATG Test Date**	09/15/2021	**Line Tightness Test Date**	09/15/2021	**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	06/28/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350				
Tank Number	03	**Tank Age**	18	**Tank Installed Date**	10/24/2007	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	5132	**Spill Test Date**	02/03/2020	**Piping Installed Date**	08/23/2007	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	01/13/2020	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	09/15/2021	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	30000	**ATG Test Date**	09/15/2021	**Line Tightness Test Date**	09/15/2021	**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	06/28/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350				
Tank Number	04	**Tank Age**	14	**Tank Installed Date**	03/25/2011	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	5282	**Spill Test Date**	02/03/2020	**Piping Installed Date**	10/27/2010	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	09/15/2021	**Sump Tightness Test Date**	01/13/2020	**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Hazardous Substance	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	1500	**ATG Test Date**	09/15/2021	**Line Tightness Test Date**	09/15/2021	**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	MLLD Line Tightness Testing	**Energy Act**	Yes
		Overfill Test Date	06/28/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Gallatin County in the City of Bozeman

Location: GRANTREE CONOCO
1417 N 7th Ave
Bozeman, MT 59715-2513 Gallatin

System Facility ID:16-01254

Facility Code: 21148
Last Inspected On: 08/15/2022
Operating Permit Renewal Date: 12/24/2025

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	TWC BOZEMAN GAS LLC	**(646) 560-1750**	**AKANDERS@THREEWALLCAPITAL.COM**
Operator Contact:	Miki Marshall;Grantree Conoco	**(406) 587-0651;(406) 587-5261**	**grantreeconoco@gmail.com**

Owner/Operator: TWC BOZEMAN GAS LLC (646) 560-1750 AKANDERS@THREEWALLCAPITAL.COM

Miki Marshall, UST Class A Operator grantreeconoco@gmail.com

Miki Marshall, UST Class B Operator grantreeconoco@gmail.com

Tank Number	05	**Tank Age**	30	**Tank Installed Date**	09/01/1995	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	3299	**Spill Test Date**	08/15/2022	**Piping Installed Date**	04/14/2016	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	11/04/2022	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	11/17/2022	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	11/17/2022	**Line Tightness Test Date**	04/23/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date	08/17/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	06	**Tank Age**	30	**Tank Installed Date**	09/01/1995	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	3300	**Spill Test Date**	08/15/2022	**Piping Installed Date**	04/14/2016	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	11/04/2022	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	11/17/2022	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	11/17/2022	**Line Tightness Test Date**	05/07/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date	08/17/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Tank Number	07	**Tank Age**	30	**Tank Installed Date**	09/01/1995	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	3301	**Spill Test Date**	08/15/2022	**Piping Installed Date**	04/14/2016	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	08/16/2022	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	11/17/2022	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	11/17/2022	**Line Tightness Test Date**	04/25/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date	08/17/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	08	**Tank Age**	30	**Tank Installed Date**	09/01/1995	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	3302	**Spill Test Date**	08/15/2022	**Piping Installed Date**	04/14/2016	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	11/04/2022	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel, Dyed	**PLLD Test Date**	11/17/2022	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	11/17/2022	**Line Tightness Test Date**	06/04/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date	08/17/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Gallatin County in the City of Bozeman

Location: KAGY KORNER INC
1809 S Tracy Ave
Bozeman, MT 59715-5736 Gallatin

System Facility ID:16-09672

Facility Code: 21532
Last Inspected On: 03/20/2023
Operating Permit Renewal Date: 07/15/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Kagy Korner Store Inc **(406) 586-1079**

Operator Contact: Amber Wilkinson **ambershock@hotmail.com**

Owner/Operator: Kagy Korner Store Inc (406) 586-1079

Amber Wilkinson, UST Class A Operator ambershock@hotmail.com
Ellyse Tullar, UST Class B Operator kagykorner@gmail.com

Tank Number	01	**Tank Age**	38	**Tank Installed Date**	11/15/1987	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	1462	**Spill Test Date**	03/20/2023	**Piping Installed Date**	06/29/2017	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	03/20/2023	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	03/20/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	03/20/2023	**Line Tightness Test Date**	03/13/2017	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date	03/20/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350				
Tank Number	02	**Tank Age**	38	**Tank Installed Date**	11/15/1987	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	1463	**Spill Test Date**	06/01/2023	**Piping Installed Date**	06/29/2017	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	03/20/2023	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	03/20/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	03/20/2023	**Line Tightness Test Date**	03/13/2017	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date	06/01/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350				
Tank Number	03	**Tank Age**	38	**Tank Installed Date**	11/15/1987	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm

Tag Number	1464	**Spill Test Date**	03/20/2023	**Piping Installed Date**	06/29/2017	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	03/20/2023	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	03/20/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	03/20/2023	**Line Tightness Test Date**	03/13/2017	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date	03/20/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Gallatin County in the City of Bozeman

Location: PAR MONTANA BOZEMAN PRODUCTS TERMINAL
220 W Griffin Dr
Bozeman, MT 59715-2254 Gallatin

System Facility ID:16-08730

Facility Code: 21508
Last Inspected On: 05/21/2024
Operating Permit Renewal Date: 09/28/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	PAR MONTANA	**(281) 899-4847**	**bmcfarland@parpacific.com**
Operator Contact:	Bry Joaillier Allen;Christopher Martin;Clinton Robbins;James Vokral;Janie Lee;Jason Martin;Michael Bailey;Michael James;Robert Ochsenbein	**(406) 223-6901;(406) 586-6927;(406) 657-5404;(435) 764-7049;(832) 624-7774;(832) 624-7876**	**clinton.m.robbins@exxonmobil.com;colt_ochsenbein@hotmail.com;jason.m.martin@exxonmobil.com**

Owner/Operator:	PAR MONTANA	(281) 899-4847	bmcfarland@parpacific.com
	Bry Joaillier Allen, UST Class A Operator		
	Bry Joaillier Allen, UST Class A Operator		
	Bry Joaillier Allen, UST Class A Operator		
	Bry Joaillier Allen, UST Class B Global Operator		
	Bry Joaillier Allen, UST Class B Global Operator		
	Bry Joaillier Allen, UST Class B Global Operator		
	Christopher Martin, UST Class A Operator		
	Christopher Martin, UST Class A Operator		
	Christopher Martin, UST Class A Operator		
	Christopher Martin, UST Class B Operator		
	Christopher Martin, UST Class B Operator		
	Christopher Martin, UST Class B Operator		
	Clinton Robbins, UST Class A Operator		clinton.m.robbins@exxonmobil.com
	Clinton Robbins, UST Class A Operator		clinton.m.robbins@exxonmobil.com
	Clinton Robbins, UST Class B Global Operator		clinton.m.robbins@exxonmobil.com
	Clinton Robbins, UST Class B Global Operator		clinton.m.robbins@exxonmobil.com
	James Vokral, UST Class A Operator		
	James Vokral, UST Class A Operator		
	James Vokral, UST Class A Operator		
	James Vokral, UST Class B Global Operator		
	James Vokral, UST Class B Global Operator		
	James Vokral, UST Class B Global Operator		
	Janie Lee, UST Class A Operator		
	Janie Lee, UST Class A Operator		
	Janie Lee, UST Class A Operator		
	Janie Lee, UST Class B Global Operator		

Janie Lee, UST Class B Global Operator	
Janie Lee, UST Class B Global Operator	
M Martin, UST Class A Operator	jason.m.martin@exxonmobil.com
M Martin, UST Class A Operator	jason.m.martin@exxonmobil.com
M Martin, UST Class A Operator	jason.m.martin@exxonmobil.com
M Martin, UST Class B Global Operator	jason.m.martin@exxonmobil.com
M Martin, UST Class B Global Operator	jason.m.martin@exxonmobil.com
M Martin, UST Class B Global Operator	jason.m.martin@exxonmobil.com
Michael Bailey, UST Class A Operator	
Michael Bailey, UST Class A Operator	
Michael Bailey, UST Class A Operator	
Michael Bailey, UST Class B Global Operator	
Michael Bailey, UST Class B Global Operator	
Michael Bailey, UST Class B Global Operator	
Michael James, UST Class A Operator	
Michael James, UST Class A Operator	
Michael James, UST Class A Operator	
Michael James, UST Class B Global Operator	
Michael James, UST Class B Global Operator	
Michael James, UST Class B Global Operator	
Robert Ochsenbein, UST Class A Operator	colt_ochsenbein@hotmail.com
Robert Ochsenbein, UST Class A Operator	colt_ochsenbein@hotmail.com
Robert Ochsenbein, UST Class A Operator	colt_ochsenbein@hotmail.com
Robert Ochsenbein, UST Class B Global Operator	colt_ochsenbein@hotmail.com
Robert Ochsenbein, UST Class B Global Operator	colt_ochsenbein@hotmail.com
Robert Ochsenbein, UST Class B Global Operator	colt_ochsenbein@hotmail.com

Tank Number	32	**Tank Age**	44	**Tank Installed Date**	12/01/1981	**Tank Material Construction**	Bare Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	
Tag Number		**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Other**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Gravity Feed	**CP Met Types**	Impressed Current
Product	Oil/Water Separator	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Deferred	**Primary Pipe Leak Detection**	Deferred	**Vapor Recovery**	No
Capacity	15000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	S1	**Tank Age**	71	**Tank Installed Date**	06/01/1954	**Tank Material Construction**	Bare Steel	**Piping Material**	Steel - Terminal Piping	**Overfill Types**	
Tag Number	2805	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	Yes

Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Pressurized	**CP Met Types**	
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	06/22/2021	**Primary Tank Leak Detection**	Deferred	**Primary Pipe Leak Detection**	Terminal Piping Annual Line Test	**Vapor Recovery**	No
Capacity	630000	**ATG Test Date**		**Line Tightness Test Date**	09/30/2020	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	S5	**Tank Age**	71	**Tank Installed Date**	06/01/1954	**Tank Material Construction**	Bare Steel	**Piping Material**	Steel - Terminal Piping	**Overfill Types**	
Tag Number	2809	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	Yes
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Pressurized	**CP Met Types**	
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	06/22/2021	**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**	Terminal Piping Annual Line Test	**Vapor Recovery**	No
Capacity	420000	**ATG Test Date**		**Line Tightness Test Date**	09/30/2020	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	S7	**Tank Age**	71	**Tank Installed Date**	06/01/1954	**Tank Material Construction**	Bare Steel	**Piping Material**	Steel - Terminal Piping	**Overfill Types**	
Tag Number	2811	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	Yes
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Pressurized	**CP Met Types**	
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	06/22/2021	**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**	Terminal Piping Annual Line Test	**Vapor Recovery**	No
Capacity	630000	**ATG Test Date**		**Line Tightness Test Date**	09/30/2020	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	S9	**Tank Age**	71	**Tank Installed Date**	06/01/1954	**Tank Material Construction**	Bare Steel	**Piping Material**	Steel - Terminal Piping	**Overfill Types**	
Tag Number	2813	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	Yes
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Pressurized	**CP Met Types**	
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	06/22/2021	**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**	Terminal Piping Annual Line Test	**Vapor Recovery**	No
Capacity	420000	**ATG Test Date**		**Line Tightness Test Date**	09/30/2020	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	S11	**Tank Age**	71	**Tank Installed Date**	06/01/1954	**Tank Material Construction**	Bare Steel	**Piping Material**	Steel	**Overfill Types**	

Tag Number	2815	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	Yes
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Pressurized	**CP Met Types**	
Product	Other	**PLLD Test Date**		**Tank/Piping CP Test Date**	06/22/2021	**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**	Terminal Piping Annual Line Test	**Vapor Recovery**	No
Capacity	420000	**ATG Test Date**		**Line Tightness Test Date**	09/30/2020	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	S12	**Tank Age**	71	**Tank Installed Date**	06/01/1954	**Tank Material Construction**	Bare Steel	**Piping Material**	Steel	**Overfill Types**	
Tag Number	2816	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	Yes
Status	**Other**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	08/24/2011	**Primary Tank Leak Detection**	Deferred	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	420000	**ATG Test Date**		**Line Tightness Test Date**	10/25/2012	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	S22	**Tank Age**	71	**Tank Installed Date**	01/01/1954	**Tank Material Construction**	Bare Steel	**Piping Material**	Steel	**Overfill Types**	
Tag Number	2817	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	Yes
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Pressurized	**CP Met Types**	
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	06/22/2021	**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**	Terminal Piping Annual Line Test	**Vapor Recovery**	No
Capacity	110	**ATG Test Date**		**Line Tightness Test Date**	09/30/2020	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	S24	**Tank Age**	71	**Tank Installed Date**	01/01/1954	**Tank Material Construction**	Bare Steel	**Piping Material**	Steel	**Overfill Types**	
Tag Number	2819	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	Yes
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Pressurized	**CP Met Types**	
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	06/22/2021	**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**	Terminal Piping Annual Line Test	**Vapor Recovery**	No
Capacity	110	**ATG Test Date**		**Line Tightness Test Date**	09/30/2020	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					

Tank Number	S36	**Tank Age**	34	**Tank Installed Date**	04/01/1991	**Tank Material Construction**	Bare Steel	**Piping Material**	Steel	**Overfill Types**	
Tag Number	2824	**Spill Test Date**		**Piping Installed Date**	12/29/2016	**Tank Construction**		**Piping Construction**	Secondary Containment Chase	**AST**	Yes
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	09/23/2021	**Catastrophic L.D. Type 3.0**	Continuous Interstitial Monitoring	**Piping Type**	Pressurized	**CP Met Types**	
Product	Hazardous Substance	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	S37	**Tank Age**	38	**Tank Installed Date**	09/01/1987	**Tank Material Construction**	Bare Steel	**Piping Material**	Steel	**Overfill Types**	
Tag Number	2825	**Spill Test Date**		**Piping Installed Date**	12/29/2016	**Tank Construction**		**Piping Construction**	Secondary Containment Chase	**AST**	Yes
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	09/23/2021	**Catastrophic L.D. Type 3.0**	Continuous Interstitial Monitoring	**Piping Type**	Pressurized	**CP Met Types**	
Product	Hazardous Substance	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	3000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	S40	**Tank Age**	31	**Tank Installed Date**	05/01/1994	**Tank Material Construction**	Bare Steel	**Piping Material**	Steel	**Overfill Types**	
Tag Number	2828	**Spill Test Date**		**Piping Installed Date**	12/29/2016	**Tank Construction**		**Piping Construction**	Secondary Containment Chase	**AST**	Yes
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	09/23/2021	**Catastrophic L.D. Type 3.0**	Continuous Interstitial Monitoring	**Piping Type**	Pressurized	**CP Met Types**	
Product	Hazardous Substance	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	1000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	21	**Tank Age**	37	**Tank Installed Date**	06/01/1988	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Steel	**Overfill Types**	High Level Alarm

Tag Number	3702	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Gravity Feed	**CP Met Types**	
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	06/22/2021	**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Terminal Piping Annual Line Test	**Vapor Recovery**	No
Capacity	2000	**ATG Test Date**		**Line Tightness Test Date**	09/30/2020	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	S3	**Tank Age**	71	**Tank Installed Date**	06/01/1954	**Tank Material Construction**	Bare Steel	**Piping Material**	Steel - Terminal Piping	**Overfill Types**	
Tag Number	4851	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	Yes
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Pressurized	**CP Met Types**	
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	06/22/2021	**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**	Terminal Piping Annual Line Test	**Vapor Recovery**	No
Capacity	1260000	**ATG Test Date**		**Line Tightness Test Date**	09/30/2020	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					

Facility Summary in Gallatin County in the City of Bozeman

Location: PHILLIPS 66 BOZEMAN TERMINAL
318 W Griffin Dr
Bozeman, MT 59715 Gallatin

System Facility ID:16-01844

Facility Code: 21181
Last Inspected On: 06/28/2023
Operating Permit Renewal Date: 10/31/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Phillips 66 Pipeline LLC **(406) 255-5714**

Operator Contact: Chase Keith;Joshua Brown **(406) 223-9892;(406) 855-6044** **chase.keith@p66.com;joshua.b.brown@p66.com**

Owner/Operator: Phillips 66 Pipeline LLC (406) 255-5714

Chase Keith, UST Class A Operator	chase.keith@p66.com
Chase Keith, UST Class A Operator	chase.keith@p66.com
Chase Keith, UST Class B Global Operator	chase.keith@p66.com
Chase Keith, UST Class B Global Operator	chase.keith@p66.com
Joshua Brown, UST Class A Operator	joshua.b.brown@p66.com
Joshua Brown, UST Class A Operator	joshua.b.brown@p66.com
Joshua Brown, UST Class B Operator	joshua.b.brown@p66.com
Joshua Brown, UST Class B Operator	joshua.b.brown@p66.com

Tank Number	23	**Tank Age**	25	**Tank Installed Date**	01/01/2000	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	4698	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	06/24/2014	**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Gravity Feed	**CP Met Types**	
Product	Mixture	**PLLD Test Date**		**Tank/Piping CP Test Date**	05/01/2020	**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	3-Year Line Tightness Test	**Vapor Recovery**	No
Capacity	1500	**ATG Test Date**		**Line Tightness Test Date**	07/14/2020	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**	Other/Other				
Tank Number	S6	**Tank Age**	70	**Tank Installed Date**	01/01/1955	**Tank Material Construction**	Unknown	**Piping Material**	Steel - Terminal Piping	**Overfill Types**	
Tag Number	715	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	Yes
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Pressurized	**CP Met Types**	
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	05/01/2020	**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**	3-Year Line Tightness Test	**Vapor Recovery**	No

Capacity	840000	**ATG Test Date**		**Line Tightness Test Date**	07/14/2020	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	S10	**Tank Age**	70	**Tank Installed Date**	01/01/1955	**Tank Material Construction**	Unknown	**Piping Material**	Steel - Terminal Piping	**Overfill Types**	
Tag Number	716	**Spill Test Date**		**Piping Installed Date**	07/02/2013	**Tank Construction**		**Piping Construction**	None	**AST**	Yes
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Pressurized	**CP Met Types**	
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	05/01/2020	**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**	3-Year Line Tightness Test	**Vapor Recovery**	No
Capacity	840000	**ATG Test Date**		**Line Tightness Test Date**	07/14/2020	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	S8	**Tank Age**	70	**Tank Installed Date**	01/01/1955	**Tank Material Construction**	Unknown	**Piping Material**	Steel - Terminal Piping	**Overfill Types**	
Tag Number	717	**Spill Test Date**		**Piping Installed Date**	07/02/2013	**Tank Construction**		**Piping Construction**	None	**AST**	Yes
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Pressurized	**CP Met Types**	
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	05/01/2020	**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**	3-Year Line Tightness Test	**Vapor Recovery**	No
Capacity	840000	**ATG Test Date**		**Line Tightness Test Date**	07/14/2020	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	S12	**Tank Age**	70	**Tank Installed Date**	01/01/1955	**Tank Material Construction**	Unknown	**Piping Material**	Steel - Terminal Piping	**Overfill Types**	
Tag Number	720	**Spill Test Date**		**Piping Installed Date**	07/02/2013	**Tank Construction**		**Piping Construction**	None	**AST**	Yes
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Pressurized	**CP Met Types**	
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	05/01/2020	**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**	3-Year Line Tightness Test	**Vapor Recovery**	No
Capacity	840000	**ATG Test Date**		**Line Tightness Test Date**	07/14/2020	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	S14	**Tank Age**	59	**Tank Installed Date**	01/01/1966	**Tank Material Construction**	Unknown	**Piping Material**	Steel - Terminal Piping	**Overfill Types**	
Tag Number	722	**Spill Test Date**		**Piping Installed Date**	04/10/2015	**Tank Construction**		**Piping Construction**	None	**AST**	Yes
Status	**Temporarily Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Pressurized	**CP Met Types**	

Product	Mixture	**PLLD Test Date**		**Tank/Piping CP Test Date**	05/01/2020	**Primary Tank Leak Detection**	Deferred	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	1680000	**ATG Test Date**		**Line Tightness Test Date**	05/13/2011	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					

Facility Summary in Gallatin County in the City of Bozeman

Location: RESSLER MOTOR COMPANY
8474 Huffine Ln
Bozeman, MT 59718-9421 Gallatin

System Facility ID:60-15102

Facility Code: 30861
Last Inspected On: 04/12/2024
Operating Permit Renewal Date: 08/18/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Ressler Motors Company	**(406) 587-5501**	**rfthomas@resslermotors.com**
Operator Contact:	Chad Karch;Tracy Mullins	**(509) 217-2694**	**ckarch@resslermotors.com;pcmstore.ta256@tatravelcenters.com**

Owner/Operator: Ressler Motors Company (406) 587-5501 rfthomas@resslermotors.com

Chad Karch, UST Class A Operator ckarch@resslermotors.com
Chad Karch, UST Class B Operator ckarch@resslermotors.com
Tracy Mullins, UST Class A Operator pcmstore.ta256@tatravelcenters.com
Tracy Mullins, UST Class B Global Operator pcmstore.ta256@tatravelcenters.com

Tank Number	S1	**Tank Age**	17	**Tank Installed Date**	07/08/2008	**Tank Material Construction**	Unknown	**Piping Material**	Flexible Plastic	**Overfill Types**	
Tag Number	5178	**Spill Test Date**		**Piping Installed Date**	03/10/2008	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	Yes
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	07/07/2021	**Catastrophic L.D. Type 3.0**	Auto Dialer	**Piping Type**	Pressurized	**CP Met Types**	
Product	Oil, Waste	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	1100	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	Yes
		Overfill Test Date				**ATG Type**					
Tank Number	S2	**Tank Age**	17	**Tank Installed Date**	07/08/2008	**Tank Material Construction**	Unknown	**Piping Material**	Flexible Plastic	**Overfill Types**	
Tag Number	5179	**Spill Test Date**		**Piping Installed Date**	03/10/2008	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	Yes
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	07/07/2021	**Catastrophic L.D. Type 3.0**	Auto Dialer	**Piping Type**	Pressurized	**CP Met Types**	
Product	Oil, Waste	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	1100	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	Yes
		Overfill Test Date				**ATG Type**					

Facility Summary in Gallatin County in the City of Bozeman

Location: SAFEWAY FUEL 2999
1801 W Main St
Bozeman, MT 59715-4015 Gallatin

System Facility ID:16-05474

Facility Code: 21348
Last Inspected On: 09/14/2022
Operating Permit Renewal Date: 12/10/2025

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Albertsons Inc Boise	**(208) 421-7561**	**jesse.wees@albertsons.com**
Operator Contact:	Jesse Wees;Steven Hernandez	**(208) 412-7561**	**brassikevin@gmail.com;jesse.wees@albertsons.com**

Owner/Operator: Albertsons Inc Boise (208) 421-7561 jesse.wees@albertsons.com

Jesse Wees, UST Class A Operator	jesse.wees@albertsons.com
Jesse Wees, UST Class A Operator	jesse.wees@albertsons.com
Jesse Wees, UST Class A Operator	jesse.wees@albertsons.com
Kenneth Matheys, UST Class B Global Operator	klm.trader22@gmail.com
Kenneth Matheys, UST Class B Global Operator	klm.trader22@gmail.com
Kenneth Matheys, UST Class B Global Operator	klm.trader22@gmail.com
Steven Hernandez, UST Class A Operator	brassikevin@gmail.com
Steven Hernandez, UST Class B Global Operator	brassikevin@gmail.com

Tank Number	05	**Tank Age**	6	**Tank Installed Date**	06/05/2019	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	5870	**Spill Test Date**	06/09/2021	**Piping Installed Date**	06/05/2019	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	12/10/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	09/14/2022	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	20000	**ATG Test Date**	09/14/2022	**Line Tightness Test Date**	12/10/2024	**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date	10/13/2021			**ATG Type**					
Tank Number	06	**Tank Age**	6	**Tank Installed Date**	06/05/2019	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	5871	**Spill Test Date**	06/09/2021	**Piping Installed Date**	06/05/2019	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	06/09/2021	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible

Product	Gasoline	**PLLD Test Date**	09/14/2022	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	09/14/2022	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date	10/13/2021			**ATG Type**					
Tank Number	07	**Tank Age**	6	**Tank Installed Date**	06/05/2019	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	5872	**Spill Test Date**	06/09/2021	**Piping Installed Date**	06/05/2019	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	06/09/2021	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	09/14/2022	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	15000	**ATG Test Date**	09/14/2022	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date	10/13/2021			**ATG Type**					
Tank Number	08	**Tank Age**	6	**Tank Installed Date**	06/05/2019	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	5873	**Spill Test Date**	06/09/2021	**Piping Installed Date**	06/05/2019	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	06/09/2021	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	09/14/2022	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	09/14/2022	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date	10/13/2021			**ATG Type**					

Facility Summary in Gallatin County in the City of Bozeman

Location: SIME CONSTRUCTION
190 Ramshorn Dr
Bozeman, MT 59718 Gallatin

System Facility ID:56-13960

Facility Code: 30627
Last Inspected On: 05/01/2025
Operating Permit Renewal Date: 06/29/2028

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Sime Construction **(406) 582-9841** **shop@simeconst.com**

Operator Contact: Shawn Sime

Owner/Operator: Sime Construction (406) 582-9841 shop@simeconst.com

Matthew Wilmeth, UST Class B Global Operator

Shawn Sime, UST Class A Operator

Tank Number	01	**Tank Age**	25	**Tank Installed Date**	01/01/2000	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	4487	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	03/22/2022	**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	U.S. Suction	**CP Met Types**	Galvanic
Product	Oil, Waste	**PLLD Test Date**		**Tank/Piping CP Test Date**	03/22/2022	**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	2000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**	Pneumercator/Other				

Facility Summary in Gallatin County in the City of Bozeman

Location: SMITHS #170 FUEL CENTER
1735 W Oak St
Bozeman, MT 59715 Gallatin

System Facility ID:60-15234

Facility Code: 30951
Last Inspected On: 04/05/2023
Operating Permit Renewal Date: 06/16/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Smiths Food and Drug	**(801) 974-1400**	**roger.gough@sfdc.com**
Operator Contact:	James Dye	**(801) 560-0471**	**jim.dye@sfdc.com**

Owner/Operator: Smiths Food and Drug (801) 974-1400 roger.gough@sfdc.com

Braxton Hill, UST Class B Operator braxton.hill@sfdc.com

James Dye, UST Class A Operator jim.dye@sfdc.com

Tank Number	01	**Tank Age**	12	**Tank Installed Date**	11/01/2013	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	5443	**Spill Test Date**	06/18/2024	**Piping Installed Date**	11/04/2013	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	10/13/2021	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	08/16/2022	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	20000	**ATG Test Date**	01/05/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	06/18/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-450				
Tank Number	02	**Tank Age**	12	**Tank Installed Date**	11/01/2013	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	5444	**Spill Test Date**	06/18/2024	**Piping Installed Date**	11/04/2013	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	10/13/2021	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	01/05/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	06/18/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-450				
Tank Number	03	**Tank Age**	12	**Tank Installed Date**	11/01/2013	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm

Tag Number	5445	**Spill Test Date**	06/18/2024	**Piping Installed Date**	11/04/2013	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	10/13/2023	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	08/16/2022	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	01/05/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	06/18/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-450				

Facility Summary in Gallatin County in the City of Bozeman

Location: STRAIGHTAWAY MOTORS
5 E Mendenhall St
Bozeman, MT 59715-3666 Gallatin

System Facility ID:16-07197

Facility Code: 21423
Last Inspected On: 02/15/2018
Operating Permit Renewal Date: 05/04/2021

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Straightaway Bozeman Investors LLC	**(406) 404-1788**	**lauren@hbpartners.com**
Operator Contact:	Eric Colvin;Peter Colvin	**(406) 586-2569**	

Eric Colvin, UST Class A Operator
Eric Colvin, UST Class A Operator
Peter H Colvin, UST Class A Operator
Peter H Colvin, UST Class A Operator
Peter H Colvin, UST Class B Global Operator
Peter H Colvin, UST Class B Global Operator

Tank Number	05	**Tank Age**	33	**Tank Installed Date**	07/01/1992	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	
Tag Number	1387	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	None	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Gravity Feed	**CP Met Types**	Galvanic
Product	Oil, Waste	**PLLD Test Date**		**Tank/Piping CP Test Date**	02/15/2018	**Primary Tank Leak Detection**	Manual Interstitial Monitoring	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**		**Line Tightness Test Date**	02/15/2018	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					

Facility Summary in Gallatin County in the City of Bozeman

Location: THRIFTWAY SUPER STOP 10
919 W College St
Bozeman, MT 59715-5062 Gallatin

System Facility ID:16-03432

Facility Code: 21243
Last Inspected On: 05/05/2025
Operating Permit Renewal Date: 06/12/2028

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Sutey Oil Co Inc	**(406) 494-2305**	**ldsutey66@thriftwayss.com**
Operator Contact:	Bryan Kelsey;Louis Sutey	**(406) 491-5808**	**bkelsey66@thriftwayss.com;ldsutey66@thriftwayss.com**

Owner/Operator: Sutey Oil Co Inc (406) 494-2305 ldsutey66@thriftwayss.com

Bryan Kelsey, UST Class A Operator	bkelsey66@thriftwayss.com
Bryan Kelsey, UST Class B Operator	bkelsey66@thriftwayss.com
Dan Franti, UST Class B Operator	thriftway10@thriftwayss.com
Louis Sutey, UST Class A Operator	ldsutey66@thriftwayss.com
Louis Sutey, UST Class B Global Operator	ldsutey66@thriftwayss.com

Tank Number	02	**Tank Age**	42	**Tank Installed Date**	07/01/1983	**Tank Material Construction**	Bare Steel	**Piping Material**	Steel	**Overfill Types**	Flapper Valve
Tag Number	4434	**Spill Test Date**	04/23/2025	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Single Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	04/23/2025	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	06/01/2022	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	04/23/2025	**Line Tightness Test Date**	04/23/2025	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	04/23/2025			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	01	**Tank Age**	42	**Tank Installed Date**	07/01/1983	**Tank Material Construction**	Bare Steel	**Piping Material**	Steel	**Overfill Types**	Flapper Valve
Tag Number	812	**Spill Test Date**	04/23/2025	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Single Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	04/23/2025	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	06/01/2022	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	04/23/2025	**Line Tightness Test Date**	04/23/2025	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No

		Overfill Test Date	04/23/2025			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	03	**Tank Age**	42	**Tank Installed Date**	07/01/1983	**Tank Material Construction**	Bare Steel	**Piping Material**	Steel	**Overfill Types**	Flapper Valve
Tag Number	814	**Spill Test Date**	04/23/2025	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Single Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	04/23/2025	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	06/01/2022	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	04/23/2025	**Line Tightness Test Date**	04/23/2025	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	04/23/2025			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Gallatin County in the City of Bozeman

Location: THRIFTWAY SUPER STOP 11
621 W Main St
Bozeman, MT 59715-3468 Gallatin

System Facility ID:16-03800

Facility Code: 21262
Last Inspected On: 05/03/2025
Operating Permit Renewal Date: 06/12/2028

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Sutey Oil Co Inc	**(406) 494-2305**	**ldsutey66@thriftwayss.com**
Operator Contact:	Bryan Kelsey;Louis Sutey	**(406) 491-5808**	**bkelsey66@thriftwayss.com;ldsutey66@thriftwayss.com**

Owner/Operator: Sutey Oil Co Inc (406) 494-2305 ldsutey66@thriftwayss.com

Brandon Blonigen, UST Class B Operator	ldsutey66@thriftwayss.com
Bryan Kelsey, UST Class A Operator	bkelsey66@thriftwayss.com
Bryan Kelsey, UST Class A Operator	bkelsey66@thriftwayss.com
Bryan Kelsey, UST Class B Operator	bkelsey66@thriftwayss.com
Bryan Kelsey, UST Class B Operator	bkelsey66@thriftwayss.com
Louis Sutey, UST Class A Operator	ldsutey66@thriftwayss.com
Louis Sutey, UST Class B Global Operator	ldsutey66@thriftwayss.com

Tank Number	06	**Tank Age**	35	**Tank Installed Date**	05/01/1990	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	815	**Spill Test Date**	04/24/2025	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Single Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	04/24/2025	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	04/12/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	04/24/2025	**Line Tightness Test Date**	04/24/2025	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	04/24/2025			**ATG Type**	Gilbarco-Veeder Root/EMC Basic				
Tank Number	07	**Tank Age**	35	**Tank Installed Date**	05/01/1990	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	816	**Spill Test Date**	04/24/2025	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Single Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	04/24/2025	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	04/12/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	04/24/2025	**Line Tightness Test Date**	04/24/2025	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No

		Overfill Test Date	04/24/2025			**ATG Type**	Gilbarco-Veeder Root/EMC Basic				
Tank Number	08	**Tank Age**	35	**Tank Installed Date**	05/01/1990	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	817	**Spill Test Date**	04/24/2025	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Single Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	04/24/2025	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	04/12/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	04/24/2025	**Line Tightness Test Date**	04/24/2025	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	04/24/2025			**ATG Type**	Gilbarco-Veeder Root/EMC Basic				

Facility Summary in Gallatin County in the City of Bozeman

Location: THRIFTWAY SUPER STOP 8
8192 Huffine Ln
Bozeman, MT 59718-9420 Gallatin

System Facility ID:16-05064

Facility Code: 21319
Last Inspected On: 12/03/2024
Operating Permit Renewal Date: 05/06/2028

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Sutey Oil Co Inc	**(406) 494-2305**	**ldsutey66@thriftwayss.com**
Operator Contact:	Bryan Kelsey;Louis Sutey	**(406) 491-5808**	**bkelsey66@thriftwayss.com;ldsutey66@thriftwayss.com**

Owner/Operator: Sutey Oil Co Inc (406) 494-2305 ldsutey66@thriftwayss.com

Bryan Kelsey, UST Class A Operator	bkelsey66@thriftwayss.com
Bryan Kelsey, UST Class A Operator	bkelsey66@thriftwayss.com
Bryan Kelsey, UST Class B Operator	bkelsey66@thriftwayss.com
Bryan Kelsey, UST Class B Operator	bkelsey66@thriftwayss.com
Dave Stine, UST Class B Operator	bkelsey66@thriftwayss.com
Dave Stine, UST Class B Operator	bkelsey66@thriftwayss.com
Louis Sutey, UST Class A Operator	ldsutey66@thriftwayss.com
Louis Sutey, UST Class B Global Operator	ldsutey66@thriftwayss.com
Matthew Nichols, UST Class B Global Operator	matthew.nichols90@yahoo.com

Tank Number	05	**Tank Age**	27	**Tank Installed Date**	08/01/1998	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	2053	**Spill Test Date**	04/04/2025	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	04/08/2024	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	Yes
Capacity	15000	**ATG Test Date**	04/08/2024	**Line Tightness Test Date**	09/05/2021	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	12/03/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	06	**Tank Age**	27	**Tank Installed Date**	08/01/1998	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	2054	**Spill Test Date**	12/03/2024	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible

Product	Gasoline	**PLLD Test Date**	04/08/2024	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	Yes
Capacity	15000	**ATG Test Date**	04/08/2024	**Line Tightness Test Date**	09/05/2021	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	12/03/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	07	**Tank Age**	27	**Tank Installed Date**	08/01/1998	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	2055	**Spill Test Date**	12/03/2024	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	01/16/2023	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	04/08/2024	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**	04/08/2024	**Line Tightness Test Date**	09/05/2021	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	12/03/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Gallatin County in the City of Bozeman

Location: TOWN PUMP INC BOZEMAN 1
803 E Main St
Bozeman, MT 59715-3842 Gallatin

System Facility ID:16-08674

Facility Code: 21505
Last Inspected On: 03/28/2025
Operating Permit Renewal Date: 10/21/2028

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Bozeman 1 Town Pump LLC	**(406) 497-6700**	**environmental@townpump.com**
Operator Contact:	Trent Biggers		**Trentb@townpump.com**

Owner/Operator:	Bozeman 1 Town Pump LLC	(406) 497-6700	environmental@townpump.com
	Trent Biggers, UST Class A Operator		Trentb@townpump.com
	Trent Biggers, UST Class A Operator		Trentb@townpump.com
	Trent Biggers, UST Class B Global Operator		Trentb@townpump.com
	Trent Biggers, UST Class B Global Operator		Trentb@townpump.com

Tank Number	09	**Tank Age**	10	**Tank Installed Date**	04/01/2015	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	5520	**Spill Test Date**	10/24/2024	**Piping Installed Date**	10/24/2014	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	07/09/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	03/28/2025	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	20000	**ATG Test Date**	03/28/2025	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Statistical Inventory Reconciliation	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	Yes
		Overfill Test Date	03/31/2025			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Number	10	**Tank Age**	10	**Tank Installed Date**	04/01/2015	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	5521	**Spill Test Date**	10/24/2024	**Piping Installed Date**	10/24/2014	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	07/09/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	03/28/2025	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No

Capacity	10000	**ATG Test Date**	03/28/2025	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Statistical Inventory Reconciliation	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	Yes
		Overfill Test Date	03/31/2025			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Number	11	**Tank Age**	10	**Tank Installed Date**	04/01/2015	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	5522	**Spill Test Date**	07/09/2024	**Piping Installed Date**	10/24/2014	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	07/09/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	03/28/2025	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	03/28/2025	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Statistical Inventory Reconciliation	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	Yes
		Overfill Test Date	03/31/2025			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Number	12	**Tank Age**	10	**Tank Installed Date**	04/01/2015	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	5523	**Spill Test Date**	07/09/2024	**Piping Installed Date**	10/24/2014	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	07/09/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel, Dyed	**PLLD Test Date**	03/28/2025	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**	03/28/2025	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Statistical Inventory Reconciliation	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	Yes
		Overfill Test Date	03/31/2025			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Number	13	**Tank Age**	10	**Tank Installed Date**	04/01/2015	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	5524	**Spill Test Date**	07/09/2025	**Piping Installed Date**	10/24/2014	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	07/09/2025	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	03/28/2025	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**	03/28/2025	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Statistical Inventory Reconciliation	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	Yes

		Overfill Test Date	03/31/2025			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				

Facility Summary in Gallatin County in the City of Bozeman

Location: TOWN PUMP INC BOZEMAN 10
77 East Valley Center Road
Bozeman, MT 59715 Gallatin

System Facility ID:60-15346

Facility Code: 32426
Last Inspected On: 03/25/2025
Operating Permit Renewal Date: 07/25/2028

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Bozeman 10 Town Pump LLC **(406) 497-6700** **environmental@townpump.com**

Operator Contact: Trent Biggers **Trentb@townpump.com**

Owner/Operator: Bozeman 10 Town Pump LLC (406) 497-6700 environmental@townpump.com

Trent Biggers, UST Class A Operator Trentb@townpump.com

Trent Biggers, UST Class B Global Operator Trentb@townpump.com

Tank Number	01	**Tank Age**	5	**Tank Installed Date**	12/14/2020	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	5985	**Spill Test Date**	08/01/2024	**Piping Installed Date**	12/14/2020	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	08/01/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	03/19/2025	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	Yes
Capacity	30000	**ATG Test Date**	03/19/2025	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Statistical Inventory Reconciliation	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	Yes
		Overfill Test Date	08/01/2024			**ATG Type**					
Tank Number	02	**Tank Age**	5	**Tank Installed Date**	12/14/2020	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	5986	**Spill Test Date**	08/01/2024	**Piping Installed Date**	12/14/2020	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	08/01/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	03/19/2025	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	Yes
Capacity	7000	**ATG Test Date**	03/19/2025	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Statistical Inventory Reconciliation	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	Yes
		Overfill Test Date	08/01/2024			**ATG Type**					

Tank Number	03	**Tank Age**	5	**Tank Installed Date**	12/14/2020	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	5987	**Spill Test Date**	08/01/2024	**Piping Installed Date**	12/14/2020	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	08/01/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	03/19/2025	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	Yes
Capacity	15000	**ATG Test Date**	03/19/2025	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Statistical Inventory Reconciliation	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	Yes
		Overfill Test Date	08/01/2024			**ATG Type**					
Tank Number	04	**Tank Age**	5	**Tank Installed Date**	12/14/2020	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	5988	**Spill Test Date**	08/01/2024	**Piping Installed Date**	12/14/2020	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	08/01/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel, Dyed	**PLLD Test Date**	03/19/2025	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	7000	**ATG Test Date**	03/19/2025	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Statistical Inventory Reconciliation	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	Yes
		Overfill Test Date	08/01/2024			**ATG Type**					
Tank Number	05	**Tank Age**	5	**Tank Installed Date**	12/14/2020	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	5989	**Spill Test Date**	08/01/2024	**Piping Installed Date**	12/14/2020	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	08/01/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	03/19/2025	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	7000	**ATG Test Date**	03/19/2025	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Statistical Inventory Reconciliation	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	Yes
		Overfill Test Date	08/01/2024			**ATG Type**					
Tank Number	06	**Tank Age**	5	**Tank Installed Date**	12/14/2020	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	5990	**Spill Test Date**	08/01/2024	**Piping Installed Date**	12/14/2020	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No

Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	08/01/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	03/19/2025	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	20000	**ATG Test Date**	03/19/2025	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Statistical Inventory Reconciliation	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	Yes
		Overfill Test Date	08/01/2024			**ATG Type**					
Tank Number	07	**Tank Age**	5	**Tank Installed Date**	12/14/2020	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	5991	**Spill Test Date**	08/01/2024	**Piping Installed Date**	12/14/2020	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	08/01/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	03/19/2025	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	7000	**ATG Test Date**	03/19/2025	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Statistical Inventory Reconciliation	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	Yes
		Overfill Test Date	08/01/2024			**ATG Type**					
Tank Number	08	**Tank Age**	5	**Tank Installed Date**	12/14/2020	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	5992	**Spill Test Date**	08/01/2024	**Piping Installed Date**	12/14/2020	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	08/01/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	03/19/2025	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	15000	**ATG Test Date**	03/19/2025	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Statistical Inventory Reconciliation	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	Yes
		Overfill Test Date	08/01/2024			**ATG Type**					
Tank Number	09	**Tank Age**	5	**Tank Installed Date**	12/14/2020	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	5993	**Spill Test Date**	08/01/2024	**Piping Installed Date**	12/14/2020	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	08/01/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel, Dyed	**PLLD Test Date**	03/19/2025	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No

Capacity	7000	**ATG Test Date**	03/19/2025	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Statistical Inventory Reconciliation	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	Yes
		Overfill Test Date	08/01/2024			**ATG Type**					
Tank Number	10	**Tank Age**	5	**Tank Installed Date**	12/14/2020	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	5994	**Spill Test Date**	09/01/2020	**Piping Installed Date**	12/14/2020	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	09/01/2020	**Catastrophic L.D. Type 3.0**		**Piping Type**	Pressurized	**CP Met Types**	
Product	DEF (Not Regulated)	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	7000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	12/11/2020			**ATG Type**					

Facility Summary in Gallatin County in the City of Bozeman

Location: TOWN PUMP INC BOZEMAN 2
2607 W Main St
Bozeman, MT 59718-3942 Gallatin

System Facility ID:16-08675

Facility Code: 21506
Last Inspected On: 08/17/2022
Operating Permit Renewal Date: 09/01/2025

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Bozeman 2 Town Pump LLC	**(406) 497-6700**	**environmental@townpump.com**
Operator Contact:	Trent Biggers		**Trentb@townpump.com**

Trent Biggers, UST Class A Operator	Trentb@townpump.com
Trent Biggers, UST Class A Operator	Trentb@townpump.com
Trent Biggers, UST Class B Global Operator	Trentb@townpump.com
Trent Biggers, UST Class B Global Operator	Trentb@townpump.com

Tank Number	01	**Tank Age**	41	**Tank Installed Date**	04/11/1984	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve
Tag Number	2441	**Spill Test Date**	07/08/2021	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**	08/12/2022	**Tank/Piping CP Test Date**	06/06/2023	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	40000	**ATG Test Date**	08/12/2022	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	02/22/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350				
Tank Number	02	**Tank Age**	41	**Tank Installed Date**	04/11/1984	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	2442	**Spill Test Date**	10/28/2024	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**	08/12/2022	**Tank/Piping CP Test Date**	06/06/2023	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	40000	**ATG Test Date**	08/12/2022	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	07/08/2021			**ATG Type**	Gilbarco-Veeder Root/TLS-350				

Tank Number	03	**Tank Age**	41	**Tank Installed Date**	04/11/1984	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve
Tag Number	2443	**Spill Test Date**	10/28/2024	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Diesel	**PLLD Test Date**	08/12/2022	**Tank/Piping CP Test Date**	06/06/2023	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	40000	**ATG Test Date**	08/12/2022	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	02/22/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350				
Tank Number	04	**Tank Age**	36	**Tank Installed Date**	04/01/1989	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve
Tag Number	2444	**Spill Test Date**	10/28/2024	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Single Walled	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	08/12/2022	**Tank/Piping CP Test Date**	02/01/2018	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	48000	**ATG Test Date**	08/12/2022	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	05/03/2021			**ATG Type**	Gilbarco-Veeder Root/TLS-350				
Tank Number	01	**Tank Age**	1	**Tank Installed Date**	05/02/2024	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	6219	**Spill Test Date**	08/22/2024	**Piping Installed Date**	05/02/2024	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	06/24/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	22000	**ATG Test Date**	12/11/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Statistical Inventory Reconciliation	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	Yes
		Overfill Test Date	08/22/2024			**ATG Type**					
Tank Number	02	**Tank Age**	1	**Tank Installed Date**	05/02/2024	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	
Tag Number	6220	**Spill Test Date**		**Piping Installed Date**	05/02/2024	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**		**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible

Product	DEF (Not Regulated)	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	Yes
		Overfill Test Date				**ATG Type**					
Tank Number	03	**Tank Age**	1	**Tank Installed Date**	05/02/2024	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	6221	**Spill Test Date**	08/22/2024	**Piping Installed Date**	05/02/2024	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	06/24/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	Yes
Capacity	7000	**ATG Test Date**	12/11/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Statistical Inventory Reconciliation	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	Yes
		Overfill Test Date	08/22/2024			**ATG Type**					
Tank Number	04	**Tank Age**	1	**Tank Installed Date**	05/02/2024	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	6222	**Spill Test Date**	08/22/2024	**Piping Installed Date**	05/02/2024	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	06/24/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	Yes
Capacity	15000	**ATG Test Date**	12/11/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Statistical Inventory Reconciliation	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	Yes
		Overfill Test Date	08/22/2024			**ATG Type**					
Tank Number	05	**Tank Age**	1	**Tank Installed Date**	05/02/2024	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	6223	**Spill Test Date**	08/22/2024	**Piping Installed Date**	05/02/2024	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	06/24/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel, Dyed	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	12/11/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Statistical Inventory Reconciliation	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	Yes
		Overfill Test Date	08/22/2024			**ATG Type**					

Tank Number	06	**Tank Age**	1	**Tank Installed Date**	05/02/2024	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	6224	**Spill Test Date**	08/22/2024	**Piping Installed Date**	05/02/2024	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	06/24/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	Yes
Capacity	24000	**ATG Test Date**	12/11/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Statistical Inventory Reconciliation	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	Yes
		Overfill Test Date	08/22/2024			**ATG Type**					
Tank Number	07	**Tank Age**	1	**Tank Installed Date**	05/02/2024	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	6225	**Spill Test Date**	08/22/2024	**Piping Installed Date**	05/02/2024	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	06/24/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**	12/11/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Statistical Inventory Reconciliation	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	Yes
		Overfill Test Date	08/22/2024			**ATG Type**					

Facility Summary in Gallatin County in the City of Bozeman

Location: TOWN PUMP INC BOZEMAN 5
29001 Norris Rd
Bozeman, MT 59718-8161 Gallatin

System Facility ID:60-15119

Facility Code: 30866
Last Inspected On: 03/13/2025
Operating Permit Renewal Date: 07/14/2028

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Bozeman 5 Town Pump LLC **(406) 497-6700** **environmental@townpump.com**

Operator Contact: Trent Biggers **Trentb@townpump.com**

Owner/Operator: Bozeman 5 Town Pump LLC (406) 497-6700 environmental@townpump.com

Trent Biggers, UST Class A Operator Trentb@townpump.com

Trent Biggers, UST Class B Global Operator Trentb@townpump.com

Tank Number	01	**Tank Age**	17	**Tank Installed Date**	12/08/2008	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	5191	**Spill Test Date**	07/11/2024	**Piping Installed Date**	06/09/2017	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	07/11/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	03/13/2025	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	14000	**ATG Test Date**	03/13/2025	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	No
		Overfill Test Date	07/11/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Number	02	**Tank Age**	17	**Tank Installed Date**	12/08/2008	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	5192	**Spill Test Date**	07/11/2024	**Piping Installed Date**	06/25/2008	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	07/11/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel, Dyed	**PLLD Test Date**	03/13/2025	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**	03/13/2025	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No

		Overfill Test Date	07/11/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Number	03	**Tank Age**	17	**Tank Installed Date**	12/08/2008	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	5193	**Spill Test Date**	07/11/2024	**Piping Installed Date**	06/09/2017	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	07/11/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	03/13/2025	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	14000	**ATG Test Date**	03/13/2025	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	No
		Overfill Test Date	07/11/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Number	04	**Tank Age**	17	**Tank Installed Date**	12/08/2008	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	5194	**Spill Test Date**	07/11/2024	**Piping Installed Date**	06/25/2008	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	07/11/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	03/13/2025	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**	03/13/2025	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	07/11/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Number	05	**Tank Age**	17	**Tank Installed Date**	12/08/2008	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	5195	**Spill Test Date**	07/11/2024	**Piping Installed Date**	06/09/2017	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	07/11/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	03/13/2025	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	Yes
Capacity	20000	**ATG Test Date**	03/13/2025	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	No
		Overfill Test Date	07/11/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				

Tank Number	06	**Tank Age**	8	**Tank Installed Date**	06/06/2017	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	5736	**Spill Test Date**	10/21/2024	**Piping Installed Date**	06/09/2017	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	07/11/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	03/13/2025	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	Yes
Capacity	6000	**ATG Test Date**	03/13/2025	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Statistical Inventory Reconciliation	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	Yes
		Overfill Test Date	07/11/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				

Facility Summary in Gallatin County in the City of Bozeman

Location: TOWN PUMP INC BOZEMAN 6
2525 N 19th Ave
Bozeman, MT 59715 Gallatin

System Facility ID:60-15339

Facility Code: 32386
Last Inspected On: 04/29/2025
Operating Permit Renewal Date: 09/19/2028

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Bozeman 6 Town Pump LLC **(406) 497-6700** **environmental@townpump.com**

Operator Contact: Trent Biggers **Trentb@townpump.com**

Owner/Operator: Bozeman 6 Town Pump LLC (406) 497-6700 environmental@townpump.com

Trent Biggers, UST Class A Operator Trentb@townpump.com

Trent Biggers, UST Class B Operator Trentb@townpump.com

Tank Number	01	**Tank Age**	5	**Tank Installed Date**	11/23/2020	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	5938	**Spill Test Date**	07/09/2024	**Piping Installed Date**	11/23/2020	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	07/09/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	Yes
Capacity	30000	**ATG Test Date**	04/29/2025	**Line Tightness Test Date**	12/12/2020	**Secondary Tank Leak Detection**	Statistical Inventory Reconciliation	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	Yes
		Overfill Test Date	07/09/2024			**ATG Type**					
Tank Number	02	**Tank Age**	5	**Tank Installed Date**	11/23/2020	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	5939	**Spill Test Date**	07/09/2024	**Piping Installed Date**	11/23/2020	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	07/09/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	Yes
Capacity	15000	**ATG Test Date**	04/29/2025	**Line Tightness Test Date**	12/12/2020	**Secondary Tank Leak Detection**	Statistical Inventory Reconciliation	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	Yes
		Overfill Test Date	07/09/2024			**ATG Type**					

Tank Number	03	**Tank Age**	5	**Tank Installed Date**	11/23/2020	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	5940	**Spill Test Date**	07/09/2024	**Piping Installed Date**	11/23/2020	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	07/09/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	15000	**ATG Test Date**	04/29/2025	**Line Tightness Test Date**	12/12/2020	**Secondary Tank Leak Detection**	Statistical Inventory Reconciliation	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	Yes
		Overfill Test Date	07/09/2024			**ATG Type**					
Tank Number	04	**Tank Age**	5	**Tank Installed Date**	11/23/2020	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	5941	**Spill Test Date**	07/09/2024	**Piping Installed Date**	11/23/2020	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	07/09/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	Yes
Capacity	7000	**ATG Test Date**	04/29/2025	**Line Tightness Test Date**	12/12/2020	**Secondary Tank Leak Detection**	Statistical Inventory Reconciliation	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	Yes
		Overfill Test Date	07/09/2024			**ATG Type**					
Tank Number	05	**Tank Age**	5	**Tank Installed Date**	11/23/2020	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	5942	**Spill Test Date**	07/09/2024	**Piping Installed Date**	11/23/2020	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	07/09/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	7000	**ATG Test Date**	04/29/2025	**Line Tightness Test Date**	12/12/2020	**Secondary Tank Leak Detection**	Statistical Inventory Reconciliation	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	Yes
		Overfill Test Date	07/09/2024			**ATG Type**					
Tank Number	06	**Tank Age**	5	**Tank Installed Date**	11/23/2020	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	5943	**Spill Test Date**	07/09/2024	**Piping Installed Date**	11/23/2020	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No

Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	07/09/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel, Dyed	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	7000	**ATG Test Date**	04/29/2025	**Line Tightness Test Date**	12/12/2020	**Secondary Tank Leak Detection**	Statistical Inventory Reconciliation	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	Yes
		Overfill Test Date	07/09/2024			**ATG Type**					

Facility Summary in Gallatin County in the City of Bozeman

Location: TOWN PUMP INC BOZEMAN 7
1871 Baxter Ln
Bozeman, MT 59715 Gallatin

System Facility ID:60-15205

Facility Code: 30925
Last Inspected On: 04/29/2025
Operating Permit Renewal Date: 09/01/2028

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Bozeman 7 Town Pump LLC **(406) 497-6700** **environmental@townpump.com**

Operator Contact: Trent Biggers **Trentb@townpump.com**

Owner/Operator: Bozeman 7 Town Pump LLC (406) 497-6700 environmental@townpump.com

Trent Biggers, UST Class A Operator Trentb@townpump.com

Trent Biggers, UST Class B Global Operator Trentb@townpump.com

Tank Number	02	**Tank Age**	13	**Tank Installed Date**	12/01/2012	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	5348	**Spill Test Date**	11/12/2024	**Piping Installed Date**	12/01/2012	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	07/31/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	04/29/2025	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	Yes
Capacity	20000	**ATG Test Date**	04/29/2025	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Statistical Inventory Reconciliation	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	Yes
		Overfill Test Date	07/31/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Number	03	**Tank Age**	13	**Tank Installed Date**	12/01/2012	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	5349	**Spill Test Date**	11/12/2024	**Piping Installed Date**	12/01/2012	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	07/31/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	04/29/2025	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	15000	**ATG Test Date**	04/29/2025	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Statistical Inventory Reconciliation	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	Yes

		Overfill Test Date	07/31/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Number	04	**Tank Age**	13	**Tank Installed Date**	12/01/2012	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	5350	**Spill Test Date**	07/31/2024	**Piping Installed Date**	12/01/2012	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	07/31/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	04/29/2025	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**	04/29/2025	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Statistical Inventory Reconciliation	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	Yes
		Overfill Test Date	07/31/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Number	05	**Tank Age**	13	**Tank Installed Date**	12/01/2012	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	5351	**Spill Test Date**	11/12/2024	**Piping Installed Date**	12/01/2012	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	07/31/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	04/29/2025	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	15000	**ATG Test Date**	04/29/2025	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Statistical Inventory Reconciliation	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	Yes
		Overfill Test Date	07/31/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Number	06	**Tank Age**	13	**Tank Installed Date**	12/01/2012	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	5352	**Spill Test Date**	07/31/2024	**Piping Installed Date**	12/01/2012	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	07/31/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel, Dyed	**PLLD Test Date**	04/29/2025	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**	04/29/2025	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Statistical Inventory Reconciliation	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	Yes
		Overfill Test Date	07/31/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				

Facility Summary in Gallatin County in the City of Bozeman

Location: TOWN PUMP INC BOZEMAN 8
5200 S Cottonwood Rd
Bozeman, MT 59718 Gallatin

System Facility ID:60-15244

Facility Code: 30961
Last Inspected On: 06/09/2025
Operating Permit Renewal Date: 12/03/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Bozeman 8 Town Pump LLC **(406) 497-6700** **environmental@townpump.com**

Operator Contact: Trent Biggers **Trentb@townpump.com**

Owner/Operator: Bozeman 8 Town Pump LLC (406) 497-6700 environmental@townpump.com

Trent Biggers, UST Class A Operator Trentb@townpump.com

Trent Biggers, UST Class B Operator Trentb@townpump.com

Tank Number	01	**Tank Age**	11	**Tank Installed Date**	08/01/2014	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	5479	**Spill Test Date**	05/13/2021	**Piping Installed Date**	06/28/2014	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	05/13/2021	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	08/09/2022	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	Yes
Capacity	20000	**ATG Test Date**	07/31/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Statistical Inventory Reconciliation	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	Yes
		Overfill Test Date	05/13/2021			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Number	02	**Tank Age**	11	**Tank Installed Date**	08/14/2014	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	5480	**Spill Test Date**	05/13/2021	**Piping Installed Date**	06/28/2014	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	05/13/2021	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	08/09/2022	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	Yes
Capacity	15000	**ATG Test Date**	07/31/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Statistical Inventory Reconciliation	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	Yes

		Overfill Test Date	05/13/2021			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Number	03	**Tank Age**	11	**Tank Installed Date**	08/14/2014	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	5481	**Spill Test Date**	05/13/2021	**Piping Installed Date**	06/28/2014	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	05/13/2021	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	08/09/2022	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**	07/31/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Statistical Inventory Reconciliation	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	Yes
		Overfill Test Date	05/13/2021			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Number	04	**Tank Age**	11	**Tank Installed Date**	08/14/2014	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	5482	**Spill Test Date**	05/13/2021	**Piping Installed Date**	06/28/2014	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	05/13/2021	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	08/09/2022	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	15000	**ATG Test Date**	07/31/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Statistical Inventory Reconciliation	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	Yes
		Overfill Test Date	05/13/2021			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Number	05	**Tank Age**	11	**Tank Installed Date**	08/14/2014	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	5483	**Spill Test Date**	05/13/2021	**Piping Installed Date**	06/28/2014	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	05/13/2021	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel, Dyed	**PLLD Test Date**	08/09/2022	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**	07/31/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Statistical Inventory Reconciliation	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	Yes
		Overfill Test Date	05/13/2021			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				

Tank Number	06	**Tank Age**	2	**Tank Installed Date**	12/01/2023	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	6145	**Spill Test Date**	07/17/2024	**Piping Installed Date**	12/01/2023	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	07/17/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	Yes
Capacity	15000	**ATG Test Date**	07/17/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Statistical Inventory Reconciliation	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	Yes
		Overfill Test Date	07/17/2024			**ATG Type**					
Tank Number	07	**Tank Age**	2	**Tank Installed Date**	12/01/2023	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	6146	**Spill Test Date**	07/17/2024	**Piping Installed Date**	12/01/2023	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	07/17/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	Yes
Capacity	8000	**ATG Test Date**	07/17/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Statistical Inventory Reconciliation	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	Yes
		Overfill Test Date	07/17/2024			**ATG Type**					
Tank Number	08	**Tank Age**	2	**Tank Installed Date**	12/01/2023	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	6147	**Spill Test Date**	07/17/2024	**Piping Installed Date**	12/01/2023	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	07/17/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	15000	**ATG Test Date**	07/17/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Statistical Inventory Reconciliation	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	Yes
		Overfill Test Date	07/17/2024			**ATG Type**					
Tank Number	09	**Tank Age**	2	**Tank Installed Date**	12/01/2023	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	
Tag Number	6148	**Spill Test Date**	07/17/2024	**Piping Installed Date**	12/01/2023	**Tank Construction**		**Piping Construction**		**AST**	No

Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	07/17/2024	**Catastrophic L.D. Type 3.0**		**Piping Type**	Pressurized	**CP Met Types**	
Product	DEF (Not Regulated)	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	07/17/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	Yes
		Overfill Test Date	07/17/2024			**ATG Type**					

Facility Summary in Gallatin County in the City of Bozeman

Location: TOWN PUMP INC BOZEMAN 9
8439 Huffine Lane
Bozeman, MT 59718 Gallatin

System Facility ID:00-32527

Facility Code: 32527
Last Inspected On: 06/05/2025
Operating Permit Renewal Date: 11/21/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Bozeman 9 RE2 LLC **arnoldo@townpump.com**

Operator Contact:

Owner/Operator: Bozeman 9 RE2 LLC arnoldo@townpump.com

Tank Number	01	**Tank Age**	2	**Tank Installed Date**	08/18/2023	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	6171	**Spill Test Date**	11/12/2023	**Piping Installed Date**	08/18/2023	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	10/19/2023	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	Yes
Capacity	30000	**ATG Test Date**	07/18/2024	**Line Tightness Test Date**	10/20/2023	**Secondary Tank Leak Detection**	Statistical Inventory Reconciliation	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	Yes
		Overfill Test Date	07/18/2024			**ATG Type**					
Tank Number	02	**Tank Age**	2	**Tank Installed Date**	08/18/2023	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	6172	**Spill Test Date**	11/12/2023	**Piping Installed Date**	08/18/2023	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	10/19/2023	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	30000	**ATG Test Date**	07/18/2024	**Line Tightness Test Date**	10/20/2023	**Secondary Tank Leak Detection**	Statistical Inventory Reconciliation	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	Yes
		Overfill Test Date	07/18/2024			**ATG Type**					
Tank Number	03	**Tank Age**	2	**Tank Installed Date**	08/18/2023	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve

Tag Number	6173	**Spill Test Date**	11/12/2023	**Piping Installed Date**	08/18/2023	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	10/19/2023	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	Yes
Capacity	20000	**ATG Test Date**	07/18/2024	**Line Tightness Test Date**	10/20/2023	**Secondary Tank Leak Detection**	Statistical Inventory Reconciliation	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	Yes
		Overfill Test Date	07/18/2024			**ATG Type**					
Tank Number	04	**Tank Age**	2	**Tank Installed Date**	08/18/2023	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	6174	**Spill Test Date**	11/12/2023	**Piping Installed Date**	08/18/2023	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	10/19/2023	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	Yes
Capacity	10000	**ATG Test Date**	07/18/2024	**Line Tightness Test Date**	10/20/2023	**Secondary Tank Leak Detection**	Statistical Inventory Reconciliation	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	Yes
		Overfill Test Date	07/18/2024			**ATG Type**					
Tank Number	05	**Tank Age**	2	**Tank Installed Date**	08/18/2023	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	6175	**Spill Test Date**	11/12/2023	**Piping Installed Date**	08/18/2023	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	10/19/2023	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	30000	**ATG Test Date**	07/18/2024	**Line Tightness Test Date**	10/20/2023	**Secondary Tank Leak Detection**	Statistical Inventory Reconciliation	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	Yes
		Overfill Test Date	07/18/2024			**ATG Type**					
Tank Number	06	**Tank Age**	2	**Tank Installed Date**	08/18/2023	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	6176	**Spill Test Date**	11/12/2023	**Piping Installed Date**	08/18/2023	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	10/20/2023	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible

Product	Diesel, Dyed	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	07/18/2024	**Line Tightness Test Date**	10/20/2023	**Secondary Tank Leak Detection**	Statistical Inventory Reconciliation	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	Yes
		Overfill Test Date	07/18/2024			**ATG Type**					
Tank Number	07	**Tank Age**	2	**Tank Installed Date**	08/18/2023	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	6177	**Spill Test Date**	11/12/2023	**Piping Installed Date**	08/18/2023	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	10/20/2023	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	07/18/2024	**Line Tightness Test Date**	10/20/2023	**Secondary Tank Leak Detection**	Statistical Inventory Reconciliation	**Secondary Pipe Leak Detection**	Not Listed	**Energy Act**	Yes
		Overfill Test Date	07/18/2024			**ATG Type**					
Tank Number	08	**Tank Age**	2	**Tank Installed Date**	08/18/2023	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	
Tag Number	6178	**Spill Test Date**		**Piping Installed Date**	08/18/2023	**Tank Construction**		**Piping Construction**		**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**		**Piping Type**	Pressurized	**CP Met Types**	
Product	DEF (Not Regulated)	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	Yes
		Overfill Test Date				**ATG Type**					
Tank Number	09	**Tank Age**	2	**Tank Installed Date**	08/18/2023	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	6251	**Spill Test Date**	11/12/2023	**Piping Installed Date**	08/18/2023	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	10/19/2023	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel, Dyed	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	07/18/2024	**Line Tightness Test Date**	10/20/2023	**Secondary Tank Leak Detection**	Statistical Inventory Reconciliation	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	Yes
		Overfill Test Date	07/18/2024			**ATG Type**					

Facility Summary in Gallatin County in the City of Bozeman

Location: ZEKES LITTLE STORE INC
621 Bridger Dr
Bozeman, MT 59715-2205 Gallatin

System Facility ID:16-10193

Facility Code: 21568
Last Inspected On: 05/02/2023
Operating Permit Renewal Date: 07/31/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Zeke's Little Store, Inc	**(406) 539-0576**	**zekeslittlestore@gmail.com**
Operator Contact:	David Huntley;Panda Harston;Stacy Huntley;William Harston	**(406) 579-8371;(406) 587-6280**	**dirtdetail@hotmail.com;panda_bill@yahoo.com;zekeslittlestore@gmail.com**

Owner/Operator: Zeke's Little Store, Inc (406) 539-0576 zekeslittlestore@gmail.com

David Huntley, UST Class A Operator	dirtdetail@hotmail.com
David Huntley, UST Class B Operator	dirtdetail@hotmail.com
Panda Harston, UST Class A Operator	
Panda Harston, UST Class B Operator	
Stacy Huntley, UST Class A Operator	zekeslittlestore@gmail.com
Stacy Huntley, UST Class B Operator	zekeslittlestore@gmail.com
William P Harston, UST Class A Operator	panda_bill@yahoo.com
William P Harston, UST Class B Operator	panda_bill@yahoo.com

Tank Number	01	**Tank Age**	35	**Tank Installed Date**	01/05/1990	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	3067	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**	Veeder Root/TLS-300				
Tank Number	02	**Tank Age**	35	**Tank Installed Date**	01/05/1990	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	3068	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**		**Vapor Recovery**	No

Capacity	6000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**	Veeder Root/TLS-300				
Tank Number	03	**Tank Age**	35	**Tank Installed Date**	01/05/1990	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	4542	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**	Veeder Root/TLS-300				

Facility Summary in Gallatin County in the City of Bozeman

Location: ZIP TRIP 46
1210 E Main St
Bozeman, MT 59715 Gallatin

System Facility ID:16-06596

Facility Code: 21399
Last Inspected On: 01/30/2025
Operating Permit Renewal Date: 05/26/2028

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	CHS Inc Spokane Valley	**(509) 535-7701**	**Donald.Widdicombe@chsinc.com**
Operator Contact:	Jim Alford;Sean Hurley	**(509) 535-7701;(509) 536-7418**	**jim.alford@chsinc.com;sean.hurley@chsinc.com**

Owner/Operator:	CHS Inc Spokane Valley	(509) 535-7701	Donald.Widdicombe@chsinc.com
	Jim Alford, UST Class A Operator		jim.alford@chsinc.com
	Jim Alford, UST Class A Operator		jim.alford@chsinc.com
	Jim Alford, UST Class B Operator		jim.alford@chsinc.com
	Jim Alford, UST Class B Operator		jim.alford@chsinc.com
	Luci Tuttle, UST Class B Operator		Lucinda.Tuttle@chsinc.com
	Sean Hurley, UST Class A Operator		sean.hurley@chsinc.com
	Sean Hurley, UST Class A Operator		sean.hurley@chsinc.com
	Travis Weber, UST Class B Operator		Donald.Widdicombe@chsinc.com

Tank Number	01	**Tank Age**	40	**Tank Installed Date**	04/03/1985	**Tank Material Construction**	Bare Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	2105	**Spill Test Date**	01/30/2025	**Piping Installed Date**	06/18/2019	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	01/30/2025	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**	07/24/2024	**Tank/Piping CP Test Date**	06/28/2022	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	07/24/2024	**Line Tightness Test Date**	05/18/2021	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date	01/30/2025			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	02	**Tank Age**	40	**Tank Installed Date**	04/03/1985	**Tank Material Construction**	Bare Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	2106	**Spill Test Date**	01/30/2025	**Piping Installed Date**	06/18/2019	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	01/30/2025	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current

Product	Gasoline	**PLLD Test Date**	07/24/2024	**Tank/Piping CP Test Date**	06/28/2022	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	07/24/2024	**Line Tightness Test Date**	05/18/2021	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date	01/30/2025			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	03	**Tank Age**	40	**Tank Installed Date**	04/03/1985	**Tank Material Construction**	Bare Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	2107	**Spill Test Date**	01/30/2025	**Piping Installed Date**	06/18/2019	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	01/30/2025	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Diesel	**PLLD Test Date**	07/24/2024	**Tank/Piping CP Test Date**	06/28/2022	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	07/24/2024	**Line Tightness Test Date**	05/18/2021	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date	01/30/2025			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Gallatin County in the City of Gallatin Gateway

Location: CASEYS CORNER 6
47650 Gallatin Rd
Gallatin Gateway, MT 59730 Gallatin

System Facility ID:16-06923

Facility Code: 21410
Last Inspected On: 05/08/2023
Operating Permit Renewal Date: 09/10/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Superpumper Inc **(701) 852-1194**

Operator Contact: Vern Patterson;Parkland USA Corporation **(701) 720-6649;(701) 852-1194** **vern.patterson@parklandusa.com;Jake.thomas@parklandusa.com**

Owner/Operator: Superpumper Inc (701) 852-1194

Scott Trullinger, UST Class B Operator Jake.thomas@parklandusa.com
Vern Patterson, UST Class A Operator Jake.thomas@parklandusa.com
Vern Patterson, UST Class B Operator Jake.thomas@parklandusa.com

Tank Number	01	**Tank Age**	40	**Tank Installed Date**	09/01/1985	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	4556	**Spill Test Date**	05/08/2023	**Piping Installed Date**	12/20/2016	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	05/28/2020	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**	04/03/2023	**Tank/Piping CP Test Date**	05/08/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	04/03/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date	03/21/2023			**ATG Type**	Veeder Root/TLS-450PLUS				
Tank Number	02	**Tank Age**	40	**Tank Installed Date**	09/01/1985	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	4557	**Spill Test Date**	05/28/2020	**Piping Installed Date**	12/20/2016	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	05/28/2020	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**	04/03/2023	**Tank/Piping CP Test Date**	03/09/2020	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	04/03/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date	05/28/2020			**ATG Type**	Veeder Root/TLS-450PLUS				

Tank Number	03	**Tank Age**	40	**Tank Installed Date**	09/01/1985	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	4558	**Spill Test Date**	05/28/2020	**Piping Installed Date**	12/20/2016	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	05/28/2020	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Diesel	**PLLD Test Date**	04/03/2023	**Tank/Piping CP Test Date**	03/09/2020	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	04/03/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date	05/28/2020			**ATG Type**	Veeder Root/TLS-450PLUS				

Facility Summary in Gallatin County in the City of Gallatin Gateway

Location: CASEYS CORNER 9
76250 Gallatin Rd
Gallatin Gateway, MT 59730 Gallatin

System Facility ID:16-09998

Facility Code: 21546
Last Inspected On: 10/10/2023
Operating Permit Renewal Date: 02/20/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Superpumper Inc **(701) 852-1194**

Operator Contact: Vern Patterson;Parkland USA Corporation **(701) 720-6649;(701) 852-1194** **vern.patterson@parklandusa.com;Jake.thomas@parklandusa.com**

Owner/Operator: Superpumper Inc (701) 852-1194

Scott Trullinger, UST Class B Operator Jake.thomas@parklandusa.com
Vern Patterson, UST Class A Operator Jake.thomas@parklandusa.com
Vern Patterson, UST Class B Operator Jake.thomas@parklandusa.com

Tank Number	05	**Tank Age**	32	**Tank Installed Date**	11/19/1993	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve
Tag Number	4492	**Spill Test Date**	10/10/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	03/20/2023	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	03/20/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	03/20/2023	**Line Tightness Test Date**	03/09/2020	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	10/10/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	06	**Tank Age**	32	**Tank Installed Date**	11/19/1993	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve
Tag Number	4493	**Spill Test Date**	10/10/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	03/20/2023	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	03/20/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**	03/20/2023	**Line Tightness Test Date**	03/09/2020	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	10/10/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Tank Number	07	**Tank Age**	32	**Tank Installed Date**	11/19/1993	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve
Tag Number	4494	**Spill Test Date**	10/10/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	03/20/2023	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	03/20/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	03/20/2023	**Line Tightness Test Date**	03/09/2020	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	10/10/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	08	**Tank Age**	32	**Tank Installed Date**	11/19/1993	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve
Tag Number	4495	**Spill Test Date**	10/10/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	03/20/2023	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	03/20/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	03/20/2023	**Line Tightness Test Date**	03/09/2020	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	10/10/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	09	**Tank Age**	32	**Tank Installed Date**	11/19/1993	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve
Tag Number	4496	**Spill Test Date**	10/10/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	03/20/2023	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	03/20/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	03/20/2023	**Line Tightness Test Date**	03/09/2020	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	10/10/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Gallatin County in the City of Manhattan

Location: DANHOF CHEVROLET INC
6605 Amsterdam Rd
Manhattan, MT 59741-8315 Gallatin

System Facility ID:16-01367

Facility Code: 21153
Last Inspected On: 11/27/2023
Operating Permit Renewal Date: 04/16/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Danhof Chevrolet Inc **(406) 282-7231**

Operator Contact: Jason Rorabaugh;Rocky Mountain Supply Inc Belgrade **(406) 388-6116** **jasonrorabaugh@rmsi.coop**

Owner/Operator: Danhof Chevrolet Inc (406) 282-7231

Dennis Franks, UST Class B Global Operator	dennis@ajminc.net
Jason Rorabaugh, UST Class A Operator	jasonrorabaugh@rmsi.coop
Jason Rorabaugh, UST Class B Operator	jasonrorabaugh@rmsi.coop

Tank Number	12	**Tank Age**	27	**Tank Installed Date**	12/01/1998	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	3592	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	04/14/2015	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	16000	**ATG Test Date**		**Line Tightness Test Date**	08/10/2017	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date				**ATG Type**	Veeder Root/TLS-300				
Tank Number	13	**Tank Age**	27	**Tank Installed Date**	12/01/1998	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	3593	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	04/14/2015	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**		**Line Tightness Test Date**	08/10/2017	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date				**ATG Type**	Veeder Root/TLS-300				

Tank Number	09	**Tank Age**	39	**Tank Installed Date**	06/13/1986	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	800	**Spill Test Date**	11/27/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	11/27/2023	**Sump Tightness Test Date**	04/12/2021	**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	11/27/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	11/27/2023	**Line Tightness Test Date**	08/10/2017	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	MLLD Line Tightness Testing	**Energy Act**	No
		Overfill Test Date	11/27/2023			**ATG Type**	Veeder Root/TLS-450PLUS				
Tank Number	10	**Tank Age**	39	**Tank Installed Date**	06/13/1986	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	801	**Spill Test Date**	11/27/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	11/27/2023	**Sump Tightness Test Date**	04/12/2021	**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	11/27/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	11/27/2023	**Line Tightness Test Date**	08/10/2017	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	MLLD Line Tightness Testing	**Energy Act**	No
		Overfill Test Date	11/27/2023			**ATG Type**	Veeder Root/TLS-450PLUS				
Tank Number	11	**Tank Age**	39	**Tank Installed Date**	06/13/1986	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	802	**Spill Test Date**	11/27/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	11/27/2023	**Sump Tightness Test Date**	04/12/2021	**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	11/27/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	11/27/2023	**Line Tightness Test Date**	08/10/2017	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	MLLD Line Tightness Testing	**Energy Act**	No
		Overfill Test Date	11/27/2023			**ATG Type**	Veeder Root/TLS-450PLUS				

Facility Summary in Gallatin County in the City of Manhattan

Location: HARLOWS SCHOOL BUS SVC
1085 Yadon Rd
Manhattan, MT 59741 Gallatin

System Facility ID:56-13969

Facility Code: 30631
Last Inspected On: 10/14/2022
Operating Permit Renewal Date: 10/14/2025

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: HJJ Properties LLC **(701) 224-1767** **jeremy.hageness@goharlows.com**

Operator Contact:

Owner/Operator: HJJ Properties LLC (701) 224-1767 jeremy.hageness@goharlows.com

Tank Number	01	**Tank Age**	26	**Tank Installed Date**	12/30/1999	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	4142	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Temporarily Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	10/14/2022	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Not Listed	**Vapor Recovery**	No
Capacity	1000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.1	**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	02	**Tank Age**	26	**Tank Installed Date**	12/30/1999	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	4143	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Temporarily Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	10/14/2022	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Not Listed	**Vapor Recovery**	No
Capacity	500	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.1	**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					

Facility Summary in Gallatin County in the City of Manhattan

Location: SCHUTTER SEED FARM, INC
3627 Wooden Shoe Rd
Manhattan, MT 59741-8108 Gallatin

System Facility ID:16-10184

Facility Code: 21567
Last Inspected On: 09/04/2023
Operating Permit Renewal Date: 03/26/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Sid Schutter Farm Inc **sidschutter@gmail.com**

Operator Contact: Sid Schutter **(406) 284-6478** **sidschutter@gmail.com**

Owner/Operator: Sid Schutter Farm Inc sidschutter@gmail.com

Sid Schutter, UST Class A Operator sidschutter@gmail.com

Sid Schutter, UST Class B Operator sidschutter@gmail.com

Tank Number	S3	**Tank Age**	50	**Tank Installed Date**	01/31/1975	**Tank Material Construction**	Bare Steel	**Piping Material**	Steel	**Overfill Types**	
Tag Number		**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**		**AST**	No
Status	**Deregulated under SB386**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**		**Piping Type**	Not Listed	**CP Met Types**	
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Not Listed	**Primary Pipe Leak Detection**	Not Listed	**Vapor Recovery**	No
Capacity	3000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	07	**Tank Age**	31	**Tank Installed Date**	01/01/1994	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Steel	**Overfill Types**	Flapper Valve
Tag Number	1909	**Spill Test Date**	09/04/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	08/09/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	2000	**ATG Test Date**	09/04/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	09/04/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	08	**Tank Age**	31	**Tank Installed Date**	01/01/1994	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Steel	**Overfill Types**	Flapper Valve

Tag Number	1910	**Spill Test Date**	09/04/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	08/09/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	09/04/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	09/04/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Gallatin County in the City of Manhattan

Location: THRIFTWAY SUPER STOP 12
404 S Broadway St
Manhattan, MT 59741 Gallatin

System Facility ID:16-03431

Facility Code: 21242
Last Inspected On: 01/21/2025
Operating Permit Renewal Date: 06/12/2028

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Sutey Oil Co Inc	**(406) 494-2305**	**ldsutey66@thriftwayss.com**
Operator Contact:	Bryan Kelsey;Louis Sutey	**(406) 491-5808**	**bkelsey66@thriftwayss.com;ldsutey66@thriftwayss.com**

Owner/Operator: Sutey Oil Co Inc (406) 494-2305 ldsutey66@thriftwayss.com

Bryan Kelsey, UST Class A Operator	bkelsey66@thriftwayss.com
Bryan Kelsey, UST Class A Operator	bkelsey66@thriftwayss.com
Bryan Kelsey, UST Class B Operator	bkelsey66@thriftwayss.com
Bryan Kelsey, UST Class B Operator	bkelsey66@thriftwayss.com
Louis Sutey, UST Class A Operator	ldsutey66@thriftwayss.com
Louis Sutey, UST Class B Global Operator	ldsutey66@thriftwayss.com
Tanya West, UST Class B Operator	twest050@gmail.com

Tank Number	07	**Tank Age**	18	**Tank Installed Date**	12/04/2007	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	5124	**Spill Test Date**	04/27/2022	**Piping Installed Date**	04/09/2007	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	04/27/2022	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	Yes
Capacity	15000	**ATG Test Date**	04/27/2022	**Line Tightness Test Date**	03/09/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	04/27/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	04	**Tank Age**	28	**Tank Installed Date**	05/01/1997	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	809	**Spill Test Date**	04/27/2022	**Piping Installed Date**	04/09/2007	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	04/27/2022	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	Yes

Capacity	12000	**ATG Test Date**	04/27/2022	**Line Tightness Test Date**	03/03/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	04/27/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	05	**Tank Age**	28	**Tank Installed Date**	05/01/1997	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	810	**Spill Test Date**	04/27/2022	**Piping Installed Date**	05/26/2016	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	07/20/2022	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	04/27/2022	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	04/27/2022	**Line Tightness Test Date**	03/02/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date	04/27/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	06	**Tank Age**	28	**Tank Installed Date**	05/01/1997	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	811	**Spill Test Date**	04/27/2022	**Piping Installed Date**	04/09/2007	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel, Dyed	**PLLD Test Date**	04/27/2022	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	5000	**ATG Test Date**	04/27/2022	**Line Tightness Test Date**	03/06/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	04/27/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Gallatin County in the City of Three Forks

Location: THRIFTWAY CONOCO 15
5 S Main St
Three Forks, MT 59752 Gallatin

System Facility ID:16-00987

Facility Code: 21128
Last Inspected On: 06/09/2025
Operating Permit Renewal Date: 06/14/2028

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	David Sutey;Sutey Oil Co Inc	**(406) 494-2305**	**ldsutey66@thriftwayss.com**
Operator Contact:	Bryan Kelsey;Louis Sutey	**(406) 491-5808**	**bkelsey66@thriftwayss.com;ldsutey66@thriftwayss.com**

Owner/Operator: David Sutey (406) 494-2305

Owner/Operator: Sutey Oil Co Inc (406) 494-2305

Bryan Kelsey, UST Class A Operator	bkelsey66@thriftwayss.com
Bryan Kelsey, UST Class A Operator	bkelsey66@thriftwayss.com
Bryan Kelsey, UST Class B Operator	bkelsey66@thriftwayss.com
Bryan Kelsey, UST Class B Operator	bkelsey66@thriftwayss.com
Dave Stine, UST Class B Operator	bkelsey66@thriftwayss.com
Dave Stine, UST Class B Operator	bkelsey66@thriftwayss.com
Gayle Ross, UST Class B Operator	thriftway15@thriftwayss.com
Gayle Ross, UST Class B Operator	thriftway15@thriftwayss.com
Louis Sutey, UST Class A Operator	ldsutey66@thriftwayss.com
Louis Sutey, UST Class B Global Operator	ldsutey66@thriftwayss.com

Tank Number	07	**Tank Age**	31	**Tank Installed Date**	04/01/1994	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	520	**Spill Test Date**	04/29/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	02/01/2022	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	04/10/2019	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	Yes
Capacity	12000	**ATG Test Date**	02/01/2022	**Line Tightness Test Date**	02/01/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	02/01/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-450				
Tank Number	08	**Tank Age**	31	**Tank Installed Date**	04/01/1994	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	521	**Spill Test Date**	04/29/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No

Status	**Currently in Use**	**MLLD Test Date**	02/01/2022	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	04/10/2019	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	Yes
Capacity	3000	**ATG Test Date**	02/01/2022	**Line Tightness Test Date**	02/01/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	02/01/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-450				
Tank Number	09	**Tank Age**	31	**Tank Installed Date**	04/01/1994	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	522	**Spill Test Date**	04/29/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	02/01/2022	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	04/10/2019	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	3000	**ATG Test Date**	02/01/2022	**Line Tightness Test Date**	02/01/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	02/01/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-450				
Tank Number	10	**Tank Age**	31	**Tank Installed Date**	04/01/1994	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	523	**Spill Test Date**	04/29/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	02/01/2022	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	04/10/2019	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	02/01/2022	**Line Tightness Test Date**	02/01/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	02/01/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-450				
Tank Number	11	**Tank Age**	31	**Tank Installed Date**	04/01/1994	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	524	**Spill Test Date**	04/29/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	02/01/2022	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	04/10/2019	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	02/01/2022	**Line Tightness Test Date**	02/01/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	02/01/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-450				
Tank Number	12	**Tank Age**	31	**Tank Installed Date**	04/01/1994	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve

Tag Number	525	**Spill Test Date**	04/29/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	02/01/2022	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	04/10/2019	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	02/01/2022	**Line Tightness Test Date**	02/01/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	02/01/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-450				
Tank Number	13	**Tank Age**	31	**Tank Installed Date**	04/01/1994	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	526	**Spill Test Date**	04/29/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	02/01/2022	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	04/10/2019	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	02/01/2022	**Line Tightness Test Date**	02/01/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	02/01/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-450				

Facility Summary in Gallatin County in the City of Three Forks

Location: TOWN PUMP INC THREE FORKS
10800 US Hwy 287
Three Forks, MT 59752 Gallatin

System Facility ID:16-08721

Facility Code: 21507
Last Inspected On: 04/30/2025
Operating Permit Renewal Date: 02/09/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Three Forks 1 Town Pump LLC **(406) 497-6700** **environmental@townpump.com**

Operator Contact: Trent Biggers **Trentb@townpump.com**

Owner/Operator: Three Forks 1 Town Pump LLC (406) 497-6700 environmental@townpump.com

Trent Biggers, UST Class A Operator Trentb@townpump.com
Trent Biggers, UST Class A Operator Trentb@townpump.com
Trent Biggers, UST Class B Global Operator Trentb@townpump.com
Trent Biggers, UST Class B Global Operator Trentb@townpump.com

Tank Number	08	**Tank Age**	45	**Tank Installed Date**	04/14/1980	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve;Flapper Valve
Tag Number	2450	**Spill Test Date**	12/17/2024	**Piping Installed Date**	08/15/2019	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	06/25/2021	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Diesel	**PLLD Test Date**	05/24/2022	**Tank/Piping CP Test Date**	06/25/2021	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	05/24/2022	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	No
		Overfill Test Date	06/25/2021			**ATG Type**	Gilbarco-Veeder Root/TLS-450				
Tank Number	11	**Tank Age**	36	**Tank Installed Date**	01/01/1989	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve;Flapper Valve
Tag Number	2452	**Spill Test Date**	09/03/2021	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	05/24/2022	**Tank/Piping CP Test Date**	07/08/2014	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	05/24/2022	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No

		Overfill Test Date	09/03/2021			**ATG Type**	Gilbarco-Veeder Root/TLS-450				
Tank Number	03	**Tank Age**	51	**Tank Installed Date**	04/14/1974	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve
Tag Number	4543	**Spill Test Date**	12/17/2024	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Diesel	**PLLD Test Date**	05/24/2022	**Tank/Piping CP Test Date**	06/25/2021	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	05/24/2022	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	06/25/2021			**ATG Type**	Gilbarco-Veeder Root/TLS-450				
Tank Number	05	**Tank Age**	51	**Tank Installed Date**	04/14/1974	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve
Tag Number	4544	**Spill Test Date**	06/25/2021	**Piping Installed Date**	08/15/2019	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	06/25/2021	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**	05/24/2022	**Tank/Piping CP Test Date**	06/25/2021	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	05/24/2022	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	No
		Overfill Test Date	06/25/2021			**ATG Type**	Gilbarco-Veeder Root/TLS-450				
Tank Number	06	**Tank Age**	45	**Tank Installed Date**	04/14/1980	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve;Positive Shutoff
Tag Number	4545	**Spill Test Date**	01/02/2024	**Piping Installed Date**	08/15/2019	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	06/25/2021	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**	05/24/2022	**Tank/Piping CP Test Date**	06/25/2021	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	05/24/2022	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	No
		Overfill Test Date	06/25/2021			**ATG Type**	Gilbarco-Veeder Root/TLS-450				
Tank Number	07	**Tank Age**	45	**Tank Installed Date**	04/14/1980	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve
Tag Number	4546	**Spill Test Date**	06/25/2021	**Piping Installed Date**	08/15/2019	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No

Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	06/25/2021	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**	05/24/2022	**Tank/Piping CP Test Date**	06/25/2021	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	05/24/2022	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	No
		Overfill Test Date	06/25/2021			**ATG Type**	Gilbarco-Veeder Root/TLS-450				
Tank Number	04	**Tank Age**	51	**Tank Installed Date**	04/14/1974	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve;Flapper Valve
Tag Number	4681	**Spill Test Date**	12/17/2024	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Diesel, Dyed	**PLLD Test Date**	05/24/2022	**Tank/Piping CP Test Date**	06/25/2021	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	05/24/2022	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	09/03/2021			**ATG Type**	Gilbarco-Veeder Root/TLS-450				
Tank Number	12	**Tank Age**	36	**Tank Installed Date**	01/01/1989	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve
Tag Number	4882	**Spill Test Date**	12/17/2024	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	05/24/2022	**Tank/Piping CP Test Date**	07/08/2014	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	05/24/2022	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	06/25/2021			**ATG Type**	Gilbarco-Veeder Root/TLS-450				
Tank Number	10	**Tank Age**	36	**Tank Installed Date**	01/01/1989	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve
Tag Number	4886	**Spill Test Date**	09/03/2021	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	06/25/2021	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	05/24/2022	**Tank/Piping CP Test Date**	07/08/2014	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No

Capacity	12000	**ATG Test Date**	05/24/2022	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	No
		Overfill Test Date	06/25/2021			**ATG Type**	Gilbarco-Veeder Root/TLS-450				
Tank Number	13	**Tank Age**	20	**Tank Installed Date**	02/02/2005	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	4931	**Spill Test Date**	09/03/2021	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	05/24/2022	**Tank/Piping CP Test Date**	07/08/2014	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	30000	**ATG Test Date**	05/24/2022	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	09/03/2021			**ATG Type**	Gilbarco-Veeder Root/TLS-450				
Tank Number	14	**Tank Age**	13	**Tank Installed Date**	07/20/2012	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass	**Overfill Types**	Ball Float Valve
Tag Number	5355	**Spill Test Date**		**Piping Installed Date**	04/19/2012	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Other**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	DEF (Not Regulated)	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/TLS-450				
Tank Number	09	**Tank Age**	6	**Tank Installed Date**	08/15/2019	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	5924	**Spill Test Date**	06/25/2021	**Piping Installed Date**	08/15/2019	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	06/25/2021	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	05/24/2022	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	Yes
Capacity	8000	**ATG Test Date**	05/24/2022	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Statistical Inventory Reconciliation	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	Yes
		Overfill Test Date	06/25/2021			**ATG Type**					

Facility Summary in Gallatin County in the City of Three Forks

Location: WHEAT MONTANA FARMS INC
10778 US Hwy 287
Three Forks, MT 59752-9518 Gallatin

System Facility ID:56-14009

Facility Code: 30669
Last Inspected On: 06/02/2025
Operating Permit Renewal Date: 07/07/2028

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Wheat Montana Bakery Inc **apclerk@wheatmontana.com**

Operator Contact: Wayne Fuller;Wayner Fuller;Wheat Montana Bakery Inc **(406) 582-4575** **waynef@wheatmontana.com;waynef@wheatmontana.com;apclerk@wheatmontana.com**

Owner/Operator: Wheat Montana Bakery Inc apclerk@wheatmontana.com

Jim Malott, UST Class B Operator jmalott0239@msn.com
Wayne Fuller, UST Class A Operator waynef@wheatmontana.com
Wayner Fuller, UST Class A Operator apclerk@wheatmontana.com

Tank Number	01	**Tank Age**	24	**Tank Installed Date**	06/01/2001	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve;High Level Alarm
Tag Number	4384	**Spill Test Date**	05/29/2025	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	07/03/2019	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	05/29/2025	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	05/29/2025	**Line Tightness Test Date**	02/08/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	05/29/2025			**ATG Type**	Gilbarco-Veeder Root/TLS-350				
Tank Number	02	**Tank Age**	24	**Tank Installed Date**	06/01/2001	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve;High Level Alarm
Tag Number	4385	**Spill Test Date**	05/29/2025	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	07/03/2019	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	05/29/2025	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	05/29/2025	**Line Tightness Test Date**	02/12/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	05/29/2025			**ATG Type**	Gilbarco/TLS-350				
Tank Number	03	**Tank Age**	24	**Tank Installed Date**	06/01/2001	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve;High Level Alarm

Tag Number	4386	**Spill Test Date**	05/29/2025	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	01/23/2024	**Sump Tightness Test Date**	07/03/2019	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	05/29/2025	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	5000	**ATG Test Date**	05/29/2025	**Line Tightness Test Date**	01/23/2024	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.1	**Energy Act**	No
		Overfill Test Date	05/29/2025			**ATG Type**	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Gallatin County in the City of West Yellowstone

Location: CORNER CENEX
136 N Canyon St
West Yellowstone, MT 59758 Gallatin

System Facility ID:16-00055

Facility Code: 21097
Last Inspected On: 05/09/2023
Operating Permit Renewal Date: 09/05/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Jerrys Enterprises Inc	**(406) 646-7735**	**wysupersave@yahoo.com**
Operator Contact:	Brad Schmier		**bschmier@msn.com**

Owner/Operator: Jerrys Enterprises Inc (406) 646-7735 wysupersave@yahoo.com

Brad Schmier, UST Class A Operator bschmier@msn.com
Brad Schmier, UST Class A Operator bschmier@msn.com
Brad Schmier, UST Class B Operator bschmier@msn.com
Brad Schmier, UST Class B Operator bschmier@msn.com

Tank Number	10	**Tank Age**	34	**Tank Installed Date**	10/01/1991	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	2263	**Spill Test Date**	05/09/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	05/04/2020	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	10/10/2022	**Line Tightness Test Date**	05/16/2017	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	05/09/2023			**ATG Type**	Gilbarco/EMC Basic				
Tank Number	11	**Tank Age**	34	**Tank Installed Date**	10/01/1991	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	2264	**Spill Test Date**	05/09/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	05/04/2020	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	10/10/2022	**Line Tightness Test Date**	05/16/2017	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	05/09/2023			**ATG Type**	Gilbarco/EMC Basic				

Tank Number	12	**Tank Age**	34	**Tank Installed Date**	10/01/1991	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	2265	**Spill Test Date**	05/09/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	05/04/2020	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**	05/09/2023	**Line Tightness Test Date**	05/16/2017	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	05/09/2023			**ATG Type**	Gilbarco/EMC Basic				
Tank Number	13	**Tank Age**	34	**Tank Installed Date**	10/01/1991	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	2266	**Spill Test Date**	05/09/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	05/04/2020	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	10/10/2022	**Line Tightness Test Date**	05/16/2017	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	05/09/2023			**ATG Type**	Gilbarco/EMC Basic				

Facility Summary in Gallatin County in the City of West Yellowstone

Location: DELAWARE NORTH PARKS SERVICES AT YELLOWSTONE LLC
251 Echo Canyon Rd
West Yellowstone, MT 59758 Gallatin

System Facility ID:16-06367

Facility Code: 21389
Last Inspected On: 06/29/2022
Operating Permit Renewal Date: 10/01/2025

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Delaware North Companies Inc **(716) 858-5000** **jcook@delawarenorth.com**

Operator Contact: Jesse Spears;Karmon Bryant **(406) 548-2709** **JSpears@delawarenorth.com;kbryant@delawarenorth.com**

Owner/Operator: Delaware North Companies Inc (716) 858-5000 jcook@delawarenorth.com

Jesse Spears, UST Class A Operator JSpears@delawarenorth.com
Jesse Spears, UST Class B Global Operator JSpears@delawarenorth.com
Karmon Bryant, UST Class A Operator kbryant@delawarenorth.com
Karmon Bryant, UST Class B Global Operator kbryant@delawarenorth.com

Tank Number	S4	**Tank Age**	44	**Tank Installed Date**	05/01/1981	**Tank Material Construction**	Bare Steel	**Piping Material**	Steel	**Overfill Types**	
Tag Number		**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**		**AST**	No
Status	**Deregulated under SB386**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**		**Piping Type**	Not Listed	**CP Met Types**	
Product	Heating Oil	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Inventory Reconciliation;Tank Tightness Testing	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	1000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	05	**Tank Age**	32	**Tank Installed Date**	06/01/1993	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	1277	**Spill Test Date**	05/18/2021	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	05/25/2022	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	06/29/2022	**Primary Tank Leak Detection**	Manual Interstitial Monitoring	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**		**Line Tightness Test Date**	05/25/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	05/18/2021			**ATG Type**					

Tank Number	06	**Tank Age**	32	**Tank Installed Date**	06/01/1993	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	1278	**Spill Test Date**	05/18/2021	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	05/25/2022	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	06/29/2022	**Primary Tank Leak Detection**	Manual Interstitial Monitoring	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	2000	**ATG Test Date**		**Line Tightness Test Date**	05/25/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	05/18/2021			**ATG Type**					

Facility Summary in Gallatin County in the City of West Yellowstone

Location: DNC PARKS AND RESORTS AT YELLOWSTONE ADVENTURES
415 Yellowstone Ave
West Yellowstone, MT 59758 Gallatin

System Facility ID:16-11619

Facility Code: 21712
Last Inspected On: 06/21/2024
Operating Permit Renewal Date: 10/19/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Delaware North Companies Inc	**(716) 858-5000**	**jcook@delawarenorth.com**
Operator Contact:	David Singleton;Erik Dawkins;Holly Loomans;Kennedy Brown;Ron Wilkes	**(406) 548-8440;(406) 599-5991**	**dsingleton@xanterra.com;edawkins@delawarenorth.com;HLOOMANS@delawarenorth.com;rentit@twotopsnowmobile.com;rwilkes@dncinc.com**

Owner/Operator: Delaware North Companies Inc (716) 858-5000 jcook@delawarenorth.com

Alexandra Chipouras, UST Class B Operator	achipouras@delawarenorth.com
David Singleton, UST Class A Operator	dsingleton@xanterra.com
David Singleton, UST Class B Global Operator	dsingleton@xanterra.com
Erik Dawkins, UST Class A Operator	edawkins@delawarenorth.com
Erik Dawkins, UST Class B Global Operator	edawkins@delawarenorth.com
Erik Dawkins, UST Class B Operator	edawkins@delawarenorth.com
Holly Loomans, UST Class A Operator	HLOOMANS@delawarenorth.com
Holly Loomans, UST Class B Operator	HLOOMANS@delawarenorth.com
Kennedy Brown, UST Class A Operator	rentit@twotopsnowmobile.com
Kennedy Brown, UST Class B Operator	rentit@twotopsnowmobile.com
Ron Wilkes, UST Class A Operator	rwilkes@dncinc.com

Tank Number	02	**Tank Age**	32	**Tank Installed Date**	10/01/1993	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Steel	**Overfill Types**	Flapper Valve
Tag Number	2350	**Spill Test Date**	06/17/2024	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	06/17/2024	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	06/17/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	06/17/2024			**ATG Type**	Veeder Root/TLS-300				

Facility Summary in Gallatin County in the City of West Yellowstone

Location: DNC PARKS AND RESORTS OF WEST YELLOWSTONE
315 Yellowstone Ave
West Yellowstone, MT 59758-9527 Gallatin

System Facility ID:16-13528

Facility Code: 21831
Last Inspected On: 10/02/2023
Operating Permit Renewal Date: 05/17/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Delaware North Companies Inc	**(716) 858-5000**	**jcook@delawarenorth.com**
Operator Contact:	Cedar Shannon;DNC Parks & Resorts of West Yellowstone Inc;Jason Fatouros;Karmon Bryant	**(406) 220-0463;(406) 223-0843;(716) 858-5055;(406) 548-2709**	**cshannon@dncinc.com;bsalansk@delawarenorth.com;jfatouros@delawarenorth.com;kbryant@delawarenorth.com**

Owner/Operator: Delaware North Companies Inc (716) 858-5000 jcook@delawarenorth.com

Cedar Shannon, UST Class A Operator	bsalansk@delawarenorth.com
Cedar Shannon, UST Class B Operator	bsalansk@delawarenorth.com
Jason Fatouros, UST Class A Operator	jfatouros@delawarenorth.com
Jason Fatouros, UST Class B Global Operator	jfatouros@delawarenorth.com
Jerry Rutan, UST Class B Operator	bsalansk@delawarenorth.com
Karmon Bryant, UST Class A Operator	kbryant@delawarenorth.com
Karmon Bryant, UST Class B Global Operator	kbryant@delawarenorth.com

Tank Number	01	**Tank Age**	31	**Tank Installed Date**	09/10/1994	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	2306	**Spill Test Date**	10/02/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	10/02/2023	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	10/02/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	10/02/2023	**Line Tightness Test Date**	08/08/2023	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	10/02/2023			**ATG Type**	Veeder Root/TLS-300				

Facility Summary in Gallatin County in the City of West Yellowstone

Location: EAGLE CHEVRON 1
3 Canyon St
West Yellowstone, MT 59758-9515 Gallatin

System Facility ID:16-08570

Facility Code: 21495
Last Inspected On: 05/08/2023
Operating Permit Renewal Date: 10/08/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Eagle Store Holding Company LLC	**(786) 486-4370**	**joycooholdings@gmail.com**
Operator Contact:	Moshe Korleicar	**(954) 881-1418**	**kormoshe@gmail.com**

Owner/Operator: Eagle Store Holding Company LLC (786) 486-4370 joycooholdings@gmail.com

Doreena Ford, UST Class B Operator
Moshe Korleicar, UST Class A Operator kormoshe@gmail.com
Moshe Korleicar, UST Class B Operator kormoshe@gmail.com

Tank Number	06	**Tank Age**	36	**Tank Installed Date**	04/28/1989	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	3986	**Spill Test Date**	05/06/2020	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	10/08/2019	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	10/06/2021	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	10/11/2022	**Line Tightness Test Date**	10/08/2019	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	05/06/2020			**ATG Type**	Veeder Root/TLS-300				
Tank Number	07	**Tank Age**	36	**Tank Installed Date**	04/28/1989	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	3987	**Spill Test Date**	05/06/2020	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	10/08/2019	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	10/06/2021	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**		**Line Tightness Test Date**	10/08/2019	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	05/06/2020			**ATG Type**	Veeder Root/TLS-300				
Tank Number	08	**Tank Age**	28	**Tank Installed Date**	10/20/1997	**Tank Material Construction**	Steel Clad	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve

Tag Number	843	**Spill Test Date**	05/06/2020	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	10/08/2019	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**		**Line Tightness Test Date**	10/08/2019	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	05/06/2020			**ATG Type**	Veeder Root/TLS-300				

Facility Summary in Gallatin County in the City of West Yellowstone

Location: EAGLE CHEVRON 2
17 Canyon St
West Yellowstone, MT 59758 Gallatin

System Facility ID:16-08571

Facility Code: 21496
Last Inspected On: 05/09/2023
Operating Permit Renewal Date: 10/08/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Eagle Store Holding Company LLC	**(786) 486-4370**	**joycooholdings@gmail.com**
Operator Contact:	Eva Eagle;Moshe Korleicar	**(954) 881-1418**	**eva.eagle@mac.com;kormoshe@gmail.com**

Owner/Operator: Eagle Store Holding Company LLC (786) 486-4370 joycooholdings@gmail.com

Eva Eagle, UST Class A Operator eva.eagle@mac.com
Moshe Korleicar, UST Class A Operator kormoshe@gmail.com
Moshe Korleicar, UST Class B Operator kormoshe@gmail.com

Tank Number	07	**Tank Age**	26	**Tank Installed Date**	06/01/1999	**Tank Material Construction**	Steel Clad	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	4018	**Spill Test Date**	05/06/2020	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	10/08/2019	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	10/06/2021	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**		**Line Tightness Test Date**	10/08/2019	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**	Veeder Root/TLS-300				
Tank Number	08	**Tank Age**	26	**Tank Installed Date**	06/01/1999	**Tank Material Construction**	Steel Clad	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	4019	**Spill Test Date**	05/06/2020	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	10/08/2019	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	10/06/2021	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**		**Line Tightness Test Date**	10/08/2019	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	11/07/2023			**ATG Type**	Veeder Root/TLS-300				
Tank Number	05	**Tank Age**	35	**Tank Installed Date**	10/05/1990	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve

Tag Number	844	**Spill Test Date**	05/06/2020	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	10/08/2019	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	10/06/2021	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**		**Line Tightness Test Date**	10/08/2019	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**	Veeder Root/TLS-300				
Tank Number	06	**Tank Age**	35	**Tank Installed Date**	10/05/1990	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	845	**Spill Test Date**	05/06/2020	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	10/08/2019	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	10/06/2021	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**		**Line Tightness Test Date**	10/08/2019	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**	Veeder Root/TLS-300				

Facility Summary in Gallatin County in the City of West Yellowstone

Location: ECONO MART
307 Firehole Ave
West Yellowstone, MT 59758-9516 Gallatin

System Facility ID:16-10356

Facility Code: 21581
Last Inspected On: 10/04/2023
Operating Permit Renewal Date: 03/03/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Econo Clyde G Seely;Firehole Holdings LLC **(406) 646-7887** **economart@yahoo.com**

Operator Contact: Merrick Young **merrick_young@yahoo.com**

Owner/Operator: Econo Clyde G Seely

Owner/Operator: Firehole Holdings LLC

Merrick Young, UST Class A Operator	merrick_young@yahoo.com
Merrick Young, UST Class A Operator	merrick_young@yahoo.com
Merrick Young, UST Class B Global Operator	merrick_young@yahoo.com
Merrick Young, UST Class B Global Operator	merrick_young@yahoo.com

Tank Number	06	**Tank Age**	24	**Tank Installed Date**	10/01/2001	**Tank Material Construction**	Steel Clad	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	4438	**Spill Test Date**	10/04/2023	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	10/04/2023	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	10/05/2021	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	2000	**ATG Test Date**	10/04/2023	**Line Tightness Test Date**	10/06/2020	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	10/04/2023			**ATG Type**	Veeder Root/TLS-300				
Tank Number	01	**Tank Age**	50	**Tank Installed Date**	02/11/1975	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	847	**Spill Test Date**	10/04/2023	**Piping Installed Date**		**Tank Construction**	Lined Interior/Impressed Current	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	10/04/2023	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	10/05/2021	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No

Capacity	10000	**ATG Test Date**	10/04/2023	**Line Tightness Test Date**	10/06/2020	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	10/04/2023			**ATG Type**	Veeder Root/TLS-300				
Tank Number	02	**Tank Age**	50	**Tank Installed Date**	02/11/1975	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	848	**Spill Test Date**	10/04/2023	**Piping Installed Date**		**Tank Construction**	Lined Interior/Impressed Current	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	10/04/2023	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	10/05/2021	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	10/04/2023	**Line Tightness Test Date**	10/06/2020	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	10/04/2023			**ATG Type**	Veeder Root/TLS-300				
Tank Number	04	**Tank Age**	50	**Tank Installed Date**	02/11/1975	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	850	**Spill Test Date**	10/04/2023	**Piping Installed Date**		**Tank Construction**	Lined Interior/Impressed Current	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	10/04/2023	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	10/05/2021	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	2000	**ATG Test Date**	10/04/2023	**Line Tightness Test Date**	10/06/2020	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	10/04/2023			**ATG Type**	Veeder Root/TLS-300				
Tank Number	05	**Tank Age**	50	**Tank Installed Date**	02/11/1975	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	851	**Spill Test Date**	10/04/2023	**Piping Installed Date**	05/16/2013	**Tank Construction**	Lined Interior/Impressed Current	**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	10/04/2023	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	10/05/2021	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	5000	**ATG Test Date**	10/04/2023	**Line Tightness Test Date**	10/06/2020	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	MLLD Line Tightness Testing	**Energy Act**	No
		Overfill Test Date	10/04/2023			**ATG Type**	Veeder Root/TLS-300				

Facility Summary in Gallatin County in the City of West Yellowstone

Location: KIRKWOOD RANCH MOTEL TRAILER PARK
35 Kirkwood Creek Rd
West Yellowstone, MT 59758-9770 Gallatin

System Facility ID:16-10793

Facility Code: 21623
Last Inspected On: 04/27/2023
Operating Permit Renewal Date: 05/25/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	E I Holdings LLC	**(801) 916-6605**	**sac6807@gmail.com**
Operator Contact:	Chris Swenson;Kyle Burden	**(406) 490-1927**	**cwswenson01@gmail.com;info@kirkwoodresort.com**

Owner/Operator: E I Holdings LLC (801) 916-6605 sac6807@gmail.com

Chris Swenson, UST Class A Operator	cwswenson01@gmail.com
Chris Swenson, UST Class B Global Operator	cwswenson01@gmail.com
Kyle Burden, UST Class A Operator	info@kirkwoodresort.com
Kyle Burden, UST Class B Operator	info@kirkwoodresort.com

Tank Number	05	**Tank Age**	25	**Tank Installed Date**	08/01/2000	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	4237	**Spill Test Date**	04/27/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	04/27/2023	**Sump Tightness Test Date**	04/24/2020	**Catastrophic L.D. Type 3.0**	Continuous Interstitial Monitoring;Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	04/27/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.1	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**	04/27/2023	**Line Tightness Test Date**	04/27/2023	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	04/27/2023			**ATG Type**	Veeder Root/TLS-300				
Tank Number	06	**Tank Age**	25	**Tank Installed Date**	08/01/2000	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	4580	**Spill Test Date**	04/27/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	04/27/2023	**Sump Tightness Test Date**	04/24/2020	**Catastrophic L.D. Type 3.0**	Continuous Interstitial Monitoring;Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	04/27/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.1	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No

Capacity	2000	**ATG Test Date**	04/27/2023	**Line Tightness Test Date**	04/27/2023	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	04/27/2023			**ATG Type**	Veeder Root/TLS-300				

Facility Summary in Gallatin County in the City of West Yellowstone

Location: MDOT DUCK CREEK (WEST YELLOWSTONE)
8060 Gallatin Rd
West Yellowstone, MT 59758 Gallatin

System Facility ID:16-04057

Facility Code: 21275
Last Inspected On: 10/07/2020
Operating Permit Renewal Date: 03/25/2024

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	MDOT Helena	**(406) 444-6163**	**mmurolo@mt.gov**
Operator Contact:	Jeff Gleason;Joe Radonich;Mike Murolo;Walt Kerttula	**(406) 444-6151;(406) 444-6163;(406) 444-9204**	**jradonich@mt.gov;mmurolo@mt.gov;wkerttula@mt.gov**

Greg Johnson, UST Class B Global Operator	grjohnson@mt.gov
Jacob Holthues, UST Class B Operator	jholthues@mt.gov
Jeff Gleason, UST Class A Operator	
Joe Radonich, UST Class A Operator	jradonich@mt.gov
Joe Radonich, UST Class B Global Operator	jradonich@mt.gov
Ken Whitaker, UST Class B Global Operator	kwhitaker@mt.gov
Mike Murolo, UST Class A Operator	mmurolo@mt.gov
Walt Kerttula, UST Class A Operator	wkerttula@mt.gov

Tank Number	06	**Tank Age**	33	**Tank Installed Date**	07/01/1992	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	4323	**Spill Test Date**	10/07/2020	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	None	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	10/07/2020	**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	10/07/2020			**ATG Type**	Gilbarco-Veeder Root/ILS-350				
Tank Number	07	**Tank Age**	33	**Tank Installed Date**	07/01/1992	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	4324	**Spill Test Date**	10/07/2020	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	None	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Galvanic

Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	10/07/2020	**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	10/07/2020			**ATG Type**	Gilbarco-Veeder Root/ILS-350				

Facility Summary in Gallatin County in the City of West Yellowstone

Location: MOUNTAINSIDE KOA
1545 Targhee Pass Hwy
West Yellowstone, MT 59758-9626 Gallatin

System Facility ID:16-12923

Facility Code: 21802
Last Inspected On: 05/07/2024
Operating Permit Renewal Date: 05/07/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Fred Stott;KAMPGROUNDS OF AMERICA INC	**(408) 310-8556;(406) 248-7444**	**fstott@koa.net;YELLOWSTONEMOUNTAINSIDE@KOA.COM**
Operator Contact:	Fred Stott	**(408) 310-8556**	**fstott@koa.net**

Owner/Operator: Fred Stott,KAMPGROUNDS OF AMERICA INC (408) 310-8556 fstott@koa.net

Fred Stott, UST Class A Operator fstott@koa.net

Fred Stott, UST Class B Operator fstott@koa.net

Tank Number	02	**Tank Age**	33	**Tank Installed Date**	11/01/1992	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Steel	**Overfill Types**	Flapper Valve
Tag Number	3391	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Temporarily Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	05/03/2024	**Primary Tank Leak Detection**	Vapor Monitoring	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					

Facility Summary in Gallatin County in the City of West Yellowstone

Location: RIVERSIDE STATION
215 N Canyon St
West Yellowstone, MT 59758 Gallatin

System Facility ID:16-04500

Facility Code: 21290
Last Inspected On: 05/09/2023
Operating Permit Renewal Date: 08/02/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Jerrys Enterprises Inc **(406) 646-7735** **wysupersave@yahoo.com**

Operator Contact: Brad Schmier **bschmier@msn.com**

Owner/Operator: Jerrys Enterprises Inc (406) 646-7735 wysupersave@yahoo.com

Brad Schmier, UST Class A Operator bschmier@msn.com

Brad Schmier, UST Class B Operator bschmier@msn.com

Tank Number	05	**Tank Age**	26	**Tank Installed Date**	01/01/1999	**Tank Material Construction**	Steel Clad	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	3684	**Spill Test Date**	05/09/2023	**Piping Installed Date**	09/12/2013	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	10/10/2022	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	10/10/2022	**Line Tightness Test Date**	11/17/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date	05/09/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	06	**Tank Age**	26	**Tank Installed Date**	01/01/1999	**Tank Material Construction**	Steel Clad	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	3685	**Spill Test Date**	05/09/2023	**Piping Installed Date**	09/12/2013	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	10/10/2022	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	10/10/2022	**Line Tightness Test Date**	05/08/2023	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date	05/09/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Tank Number	07	**Tank Age**	26	**Tank Installed Date**	01/01/1999	**Tank Material Construction**	Steel Clad	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	3686	**Spill Test Date**	05/09/2023	**Piping Installed Date**	09/12/2013	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	10/10/2022	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	10/10/2022	**Line Tightness Test Date**	05/08/2023	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date	05/09/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Gallatin County in the City of West Yellowstone

Location: SUPER SAVE CONOCO
138 Firehole Ln
West Yellowstone, MT 59758-9609 Gallatin

System Facility ID:16-04501

Facility Code: 21291
Last Inspected On: 05/09/2023
Operating Permit Renewal Date: 08/02/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Jerrys Enterprises Inc **(406) 646-7735** **wysupersave@yahoo.com**

Operator Contact: Brad Schmier **bschmier@msn.com**

Owner/Operator: Jerrys Enterprises Inc (406) 646-7735 wysupersave@yahoo.com

Brad Schmier, UST Class A Operator bschmier@msn.com

Brad Schmier, UST Class B Operator bschmier@msn.com

Tank Number	05	**Tank Age**	36	**Tank Installed Date**	12/11/1989	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	1414	**Spill Test Date**	05/09/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	10/11/2022	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	05/09/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	10/11/2022	**Line Tightness Test Date**	10/11/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	05/09/2023			**ATG Type**	Veeder Root/TLS-300				
Tank Number	07	**Tank Age**	36	**Tank Installed Date**	12/11/1989	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	1416	**Spill Test Date**	05/09/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	10/11/2022	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	05/09/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**	10/11/2022	**Line Tightness Test Date**	10/11/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	05/09/2023			**ATG Type**	Veeder Root/TLS-300				
Tank Number	08	**Tank Age**	31	**Tank Installed Date**	06/01/1994	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	1417	**Spill Test Date**	05/09/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No

Status	**Currently in Use**	**MLLD Test Date**	10/11/2022	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	05/09/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**	10/11/2022	**Line Tightness Test Date**	10/11/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	05/09/2023			**ATG Type**	Veeder Root/TLS-300				
Tank Number	06	**Tank Age**	36	**Tank Installed Date**	12/11/1989	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	4302	**Spill Test Date**	05/09/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	10/11/2022	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	05/09/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	10/11/2022	**Line Tightness Test Date**	10/11/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	05/09/2023			**ATG Type**	Veeder Root/TLS-300				

Facility Summary in Gallatin County in the City of West Yellowstone

Location: THREE BEAR LODGE INC
217 Yellowstone Ave
West Yellowstone, MT 59758 Gallatin

System Facility ID:16-10357

Facility Code: 21582
Last Inspected On: 05/10/2023
Operating Permit Renewal Date: 07/03/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Clyde Seely **clyde@threebearlodge.com**

Operator Contact: Merrick Young **merrick_young@yahoo.com**

Owner/Operator: Clyde Seely clyde@threebearlodge.com

Merrick Young, UST Class A Operator merrick_young@yahoo.com
Merrick Young, UST Class A Operator merrick_young@yahoo.com
Merrick Young, UST Class B Global Operator merrick_young@yahoo.com
Merrick Young, UST Class B Global Operator merrick_young@yahoo.com

Tank Number	02	**Tank Age**	32	**Tank Installed Date**	10/01/1993	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Steel	**Overfill Types**	Flapper Valve
Tag Number	2114	**Spill Test Date**	05/10/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	10/12/2022	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	05/10/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**	10/12/2022	**Line Tightness Test Date**	10/11/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	05/10/2023			**ATG Type**	Veeder Root/TLS-300				

Facility Summary in Gallatin County in the City of West Yellowstone

Location: TRAVELERS SERVICE CENTER
36 Electric St
West Yellowstone, MT 59758 Gallatin

System Facility ID:16-09852

Facility Code: 21535
Last Inspected On: 05/09/2023
Operating Permit Renewal Date: 08/05/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	WEST CORNER INC	**(406) 646-7597**	**westcornerstation@gmail.com**
Operator Contact:	Bradley Loomis	**(406) 646-7773**	**bradpolaris@gmail.com**

Owner/Operator: WEST CORNER INC (406) 646-7597 westcornerstation@gmail.com

Bradley Loomis, UST Class A Operator bradpolaris@gmail.com

Bradley Loomis, UST Class B Operator bradpolaris@gmail.com

Tank Number	04	**Tank Age**	27	**Tank Installed Date**	04/21/1998	**Tank Material Construction**	Steel Clad	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	1555	**Spill Test Date**	05/09/2023	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	10/10/2022	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	02/03/2024	**Line Tightness Test Date**	10/10/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	05/09/2023			**ATG Type**	Franklin Fueling Systems/EVO 600				
Tank Number	05	**Tank Age**	27	**Tank Installed Date**	04/21/1998	**Tank Material Construction**	Steel Clad	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	1556	**Spill Test Date**	05/09/2023	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	10/10/2022	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	02/03/2024	**Line Tightness Test Date**	10/10/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	05/09/2023			**ATG Type**	Franklin Fueling Systems/EVO 600				
Tank Number	06	**Tank Age**	27	**Tank Installed Date**	04/21/1998	**Tank Material Construction**	Steel Clad	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve

Tag Number	1557	**Spill Test Date**	05/09/2023	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	10/10/2022	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**	02/03/2024	**Line Tightness Test Date**	10/10/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	05/09/2023			**ATG Type**	Franklin Fueling Systems/EVO 600				

Facility Summary in Gallatin County in the City of West Yellowstone

Location: TWO TOP SNOWMOBILE RENTAL
645 Gibbon Ave
West Yellowstone, MT 59758 Gallatin

System Facility ID:16-04445

Facility Code: 21289
Last Inspected On: 09/29/2023
Operating Permit Renewal Date: 02/27/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	DNC Parks & Resorts Yellowstone Adventures Inc.	**(406) 586-7593**	**jfatouros@delawarenorth.com**
Operator Contact:	Jennie Allen;Kennedy Brown		**jallen4@delawarenorth.com;rentit@twotopsnowmobile.com**

Owner/Operator:	DNC Parks & Resorts Yellowstone Adventures Inc.	(406) 586-7593	jfatouros@delawarenorth.com
	Jennie Allen, UST Class A Operator		jallen4@delawarenorth.com
	Jennie Allen, UST Class B Operator		jallen4@delawarenorth.com
	Kennedy Brown, UST Class A Operator		rentit@twotopsnowmobile.com
	Kennedy Brown, UST Class B Operator		rentit@twotopsnowmobile.com

Tank Number	01	**Tank Age**	33	**Tank Installed Date**	09/01/1992	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Steel	**Overfill Types**	Flapper Valve
Tag Number	1598	**Spill Test Date**	10/19/2021	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	10/02/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	10/02/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	10/02/2023			**ATG Type**	Veeder Root/TLS-300				

Facility Summary in Gallatin County in the City of West Yellowstone

Location: WEST ENTRANCE BLDG 458
W Entrance Bldg 458
West Yellowstone, MT 59758 Gallatin

System Facility ID:16-08870

Facility Code: 21515
Last Inspected On: 07/13/2022
Operating Permit Renewal Date: 09/13/2025

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	National Park Service Mammoth	**(307) 344-2333**	
Operator Contact:	Claude Long;Harry Laney;Jason Ogle;Joel Browning;National Park Service Mammoth;Nathan Munson	**(304) 344-2333;(307) 344-2333;(307) 344-2333;(406) 581-9206;(406) 595-0840**	**claude_long@nps.gov;harry_laney@nps.gov;jason_ogle@nps.gov;joel_browning@nps.gov;nathan_munson@nps.gov**

Owner/Operator: National Park Service Mammoth (307) 344-2333

Claude Long, UST Class A Operator	claude_long@nps.gov
Harry Laney, UST Class A Operator	harry_laney@nps.gov
Harry Laney, UST Class B Operator	harry_laney@nps.gov
Jason Ogle, UST Class A Operator	jason_ogle@nps.gov
Joel Browning, UST Class A Operator	joel_browning@nps.gov
Nathan Munson, UST Class A Operator	nathan_munson@nps.gov

Tank Number	01	**Tank Age**	37	**Tank Installed Date**	08/24/1988	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Steel	**Overfill Types**	Flapper Valve
Tag Number	1739	**Spill Test Date**	08/05/2024	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	PVC	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	05/14/2022	**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	08/23/2021	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	08/05/2024			**ATG Type**	EBW/Auto Stik JR				
Tank Number	02	**Tank Age**	37	**Tank Installed Date**	08/24/1988	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Steel	**Overfill Types**	Flapper Valve
Tag Number	1740	**Spill Test Date**	08/05/2024	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	PVC	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	05/14/2022	**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	08/23/2021	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No

		Overfill Test Date	08/05/2024			**ATG Type**	EBW/Auto Stik JR				

Facility Summary in Gallatin County in the City of West Yellowstone

Location: WESTGATE STATION
11 Yellowstone Ave
West Yellowstone, MT 59758-9510 Gallatin

System Facility ID:16-03734

Facility Code: 21256
Last Inspected On: 10/03/2023
Operating Permit Renewal Date: 10/03/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Westgate Station West Yellowstone **(406) 646-7651**

Operator Contact: Cole Parker **(406) 646-7651** **cole_parker@hotmail.com**

Owner/Operator: Westgate Station West Yellowstone (406) 646-7651

Cole Parker, UST Class A Operator cole_parker@hotmail.com
Cole Parker, UST Class A Operator cole_parker@hotmail.com
Cole Parker, UST Class B Operator cole_parker@hotmail.com
Cole Parker, UST Class B Operator cole_parker@hotmail.com

Tank Number	09	**Tank Age**	27	**Tank Installed Date**	10/01/1998	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve;High Level Alarm
Tag Number	3108	**Spill Test Date**	10/19/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Single Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	10/05/2023	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	10/19/2023	**Line Tightness Test Date**	10/07/2020	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	10/19/2023			**ATG Type**	Franklin Fueling Systems/EVO 600				
Tank Number	10	**Tank Age**	27	**Tank Installed Date**	10/01/1998	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve;High Level Alarm
Tag Number	3109	**Spill Test Date**	10/19/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	10/05/2023	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	10/19/2023	**Line Tightness Test Date**	10/07/2020	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	10/19/2023			**ATG Type**	Franklin Fueling Systems/EVO 600				

Tank Number	11	**Tank Age**	27	**Tank Installed Date**	10/01/1998	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve;High Level Alarm
Tag Number	3110	**Spill Test Date**	10/19/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	10/07/2020	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**	10/19/2023	**Line Tightness Test Date**	10/07/2020	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	10/19/2023			**ATG Type**	Franklin Fueling Systems/EVO 600				
Tank Number	12	**Tank Age**	27	**Tank Installed Date**	10/01/1998	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve;High Level Alarm
Tag Number	3111	**Spill Test Date**	10/19/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	10/05/2023	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	5000	**ATG Test Date**	10/19/2023	**Line Tightness Test Date**	10/07/2020	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	10/19/2023			**ATG Type**	Franklin Fueling Systems/EVO 600				

Facility Summary in Gallatin County in the City of West Yellowstone

Location: YELLOWSTONE ARCTIC YAMAHA ELECTRIC ST
208 Electric St
West Yellowstone, MT 59758 Gallatin

System Facility ID:16-10358

Facility Code: 21583
Last Inspected On: 08/29/2024
Operating Permit Renewal Date: 10/14/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Firehole Holdings LLC **(406) 646-7887** **economart@yahoo.com**

Operator Contact: Merrick Young **merrick_young@yahoo.com**

Owner/Operator: Firehole Holdings LLC (406) 646-7887 economart@yahoo.com

Merrick Young, UST Class A Operator merrick_young@yahoo.com

Merrick Young, UST Class B Operator merrick_young@yahoo.com

Tank Number	02	**Tank Age**	33	**Tank Installed Date**	09/01/1992	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Steel	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	2305	**Spill Test Date**	10/04/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	09/30/2024	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**	10/04/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	10/04/2023			**ATG Type**	Veeder Root/TLS-300				

Facility Summary in Gallatin County in the City of West Yellowstone

Location: YELLOWSTONE HOLIDAY RESORT
16990 Hebgen Lake Rd
West Yellowstone, MT 59758 Gallatin

System Facility ID:16-11066

Facility Code: 21649
Last Inspected On: 10/02/2024
Operating Permit Renewal Date: 03/09/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Grayling Partners LC — **ellen@wsmgt.com**

Operator Contact: Bradley Campbell;Todd Barta — **(406) 539-2394;(406) 570-1364** — **redcreek3@gmail.com;tvbarta@aol.com**

Owner/Operator: Grayling Partners LC — ellen@wsmgt.com

Bradley Campbell, UST Class A Operator	redcreek3@gmail.com
Bradley Campbell, UST Class A Operator	redcreek3@gmail.com
James Hynes, UST Class B Operator	info@yellowstoneholiday.com
James Hynes, UST Class B Operator	info@yellowstoneholiday.com
Todd Barta, UST Class A Operator	tvbarta@aol.com
Todd Barta, UST Class A Operator	tvbarta@aol.com
Vickie Barta, UST Class B Operator	vickie@yhrv.net
Vickie Barta, UST Class B Operator	vickie@yhrv.net

Tank Number	S6	**Tank Age**	26	**Tank Installed Date**	10/01/1999	**Tank Material Construction**	Concrete	**Piping Material**	Fiberglass	**Overfill Types**	
Tag Number	4132	**Spill Test Date**		**Piping Installed Date**	05/03/2013	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	Yes
Status	**Currently in Use**	**MLLD Test Date**	10/02/2024	**Sump Tightness Test Date**	10/02/2024	**Catastrophic L.D. Type 3.0**	Continuous Interstitial Monitoring;Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Deferred	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring;MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	1500	**ATG Test Date**	10/02/2024	**Line Tightness Test Date**	04/27/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					

Facility Summary in Garfield County in the City of Jordan

Location: FARMERS UNION OIL CO JORDAN
201 Jordan Ave
Jordan, MT 59337 Garfield

System Facility ID:17-05702

Facility Code: 21878
Last Inspected On: 02/17/2023
Operating Permit Renewal Date: 08/19/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Farmers Union Oil Co Jordan	**(406) 557-2215**	**cenexjor@midrivers.com**
Operator Contact:	Robert Wilson	**(406) 557-2218**	**cenexjor@midrivers.com**

Owner/Operator: Farmers Union Oil Co Jordan (406) 557-2215 cenexjor@midrivers.com

Loren Edwards, UST Class B Global Operator edwards_loren@yahoo.com

Robert Wilson, UST Class A Operator cenexjor@midrivers.com

Tank Number	06	**Tank Age**	27	**Tank Installed Date**	12/01/1998	**Tank Material Construction**	Steel Clad	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	941	**Spill Test Date**	02/17/2023	**Piping Installed Date**	09/18/2024	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	09/23/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	01/30/2008	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**		**Line Tightness Test Date**	09/18/2024	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date	02/17/2023			**ATG Type**	Franklin Fueling Systems/				
Tank Number	07	**Tank Age**	27	**Tank Installed Date**	12/01/1998	**Tank Material Construction**	Steel Clad	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	942	**Spill Test Date**	02/17/2023	**Piping Installed Date**	10/02/2014	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	04/11/2022	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	01/30/2008	**Primary Tank Leak Detection**	Manual Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	4100	**ATG Test Date**		**Line Tightness Test Date**	06/26/2017	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date	02/17/2023			**ATG Type**					
Tank Number	08	**Tank Age**	27	**Tank Installed Date**	12/01/1998	**Tank Material Construction**	Steel Clad	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve

Tag Number	943	**Spill Test Date**	02/17/2023	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	04/11/2022	**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Not Listed	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	01/30/2008	**Primary Tank Leak Detection**	Manual Interstitial Monitoring	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	4100	**ATG Test Date**		**Line Tightness Test Date**	06/26/2017	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	02/17/2023			**ATG Type**					
Tank Number	09	**Tank Age**	27	**Tank Installed Date**	12/01/1998	**Tank Material Construction**	Steel Clad	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	944	**Spill Test Date**	02/17/2023	**Piping Installed Date**	10/02/2014	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	04/11/2022	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	01/30/2008	**Primary Tank Leak Detection**	Manual Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	3760	**ATG Test Date**		**Line Tightness Test Date**	06/26/2017	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date	02/17/2023			**ATG Type**					
Tank Number	10	**Tank Age**	27	**Tank Installed Date**	12/01/1998	**Tank Material Construction**	Steel Clad	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	945	**Spill Test Date**	02/17/2023	**Piping Installed Date**	06/03/2011	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	04/11/2022	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	01/30/2008	**Primary Tank Leak Detection**	Manual Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	7900	**ATG Test Date**		**Line Tightness Test Date**	06/26/2017	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date	02/17/2023			**ATG Type**					
Tank Number	11	**Tank Age**	27	**Tank Installed Date**	12/01/1998	**Tank Material Construction**	Steel Clad	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	946	**Spill Test Date**	02/17/2023	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	04/11/2022	**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Not Listed	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	01/30/2008	**Primary Tank Leak Detection**	Manual Interstitial Monitoring	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	4100	**ATG Test Date**		**Line Tightness Test Date**	06/26/2017	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No

		Overfill Test Date	02/17/2023			**ATG Type**					

Facility Summary in Garfield County in the City of Jordan

Location: FARMERS UNION OIL CO JORDAN 2
40 Brusett Rd
Jordan, MT 59337 Garfield

System Facility ID:60-15243

Facility Code: 30960
Last Inspected On: 02/17/2023
Operating Permit Renewal Date: 07/05/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Farmers Union Oil Co Jordan **(406) 557-2215** **cenexjor@midrivers.com**

Operator Contact: Robert Wilson **(406) 557-2218** **cenexjor@midrivers.com**

Owner/Operator: Farmers Union Oil Co Jordan (406) 557-2215 cenexjor@midrivers.com

Loren Edwards, UST Class B Global Operator edwards_loren@yahoo.com

Robert Wilson, UST Class A Operator cenexjor@midrivers.com

Tank Number	S1	**Tank Age**	11	**Tank Installed Date**	10/28/2014	**Tank Material Construction**	Aboveground Tank	**Piping Material**	Flexible Plastic	**Overfill Types**	
Tag Number	5498	**Spill Test Date**		**Piping Installed Date**	10/28/2014	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	Yes
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	05/02/2022	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	15000	**ATG Test Date**		**Line Tightness Test Date**	06/26/2017	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date				**ATG Type**					
Tank Number	S2	**Tank Age**	11	**Tank Installed Date**	10/28/2014	**Tank Material Construction**	Aboveground Tank	**Piping Material**	Flexible Plastic	**Overfill Types**	
Tag Number	5499	**Spill Test Date**		**Piping Installed Date**	10/28/2014	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	Yes
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	05/02/2022	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	15000	**ATG Test Date**		**Line Tightness Test Date**	06/26/2017	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date				**ATG Type**					
Tank Number	S3	**Tank Age**	11	**Tank Installed Date**	10/28/2014	**Tank Material Construction**	Aboveground Tank	**Piping Material**	Flexible Plastic	**Overfill Types**	

Tag Number	5500	**Spill Test Date**		**Piping Installed Date**	10/28/2014	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	Yes
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	05/02/2022	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	15000	**ATG Test Date**		**Line Tightness Test Date**	06/26/2017	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date				**ATG Type**					

Facility Summary in Garfield County in the City of Jordan

Location: JAKES PLACE
618 Jordan Ave
Jordan, MT 59337 Garfield

System Facility ID:17-10707

Facility Code: 21895
Last Inspected On: 08/07/2023
Operating Permit Renewal Date: 11/16/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Jakes Property Investments LLC	**(406) 853-1732**	**skylarharbaugh@hotmail.com**
Operator Contact:	Kenneth Ellington;Rex Phipps;Skylar Harbaugh	**(406) 557-2201;(406) 853-1732**	**kellington@midrivers.com;rex@garfieldcountybank.com;skylarharbaugh@hotmail.com**

Owner/Operator:	Jakes Property Investments LLC	(406) 853-1732	skylarharbaugh@hotmail.com
	Kenneth Ellington, UST Class A Operator		kellington@midrivers.com
	Kenneth Ellington, UST Class A Operator		kellington@midrivers.com
	Kenneth Ellington, UST Class B Operator		kellington@midrivers.com
	Kenneth Ellington, UST Class B Operator		kellington@midrivers.com
	Rex Phipps, UST Class A Operator		rex@garfieldcountybank.com
	Rex Phipps, UST Class A Operator		rex@garfieldcountybank.com
	Rex Phipps, UST Class B Operator		rex@garfieldcountybank.com
	Rex Phipps, UST Class B Operator		rex@garfieldcountybank.com
	Skylar Harbaugh, UST Class A Operator		skylarharbaugh@hotmail.com
	Skylar Harbaugh, UST Class A Operator		skylarharbaugh@hotmail.com
	Skylar Harbaugh, UST Class B Global Operator		skylarharbaugh@hotmail.com
	Skylar Harbaugh, UST Class B Global Operator		skylarharbaugh@hotmail.com

Tank Number	05	**Tank Age**	24	**Tank Installed Date**	06/01/2001	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	4311	**Spill Test Date**	08/07/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	10/17/2013	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	08/07/2023	**Line Tightness Test Date**	08/24/2020	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	08/07/2023			**ATG Type**	Incon/TS-550 EVO				
Tank Number	06	**Tank Age**	24	**Tank Installed Date**	06/01/2001	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm

Tag Number	4312	**Spill Test Date**	08/07/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	10/17/2013	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	08/07/2023	**Line Tightness Test Date**	08/27/2020	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	08/07/2023			**ATG Type**	Incon/TS-550 EVO				
Tank Number	07	**Tank Age**	24	**Tank Installed Date**	06/01/2001	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	4313	**Spill Test Date**	08/07/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	10/17/2013	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	08/07/2023	**Line Tightness Test Date**	08/23/2020	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	08/07/2023			**ATG Type**	Incon/TS-550 EVO				

Facility Summary in Glacier County in the City of Babb

Location: THRONSONS STORE
US Hwy 89
Babb, MT 59411 Glacier

System Facility ID:18-03871

Facility Code: 21949
Last Inspected On: 06/02/2023
Operating Permit Renewal Date: 09/03/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Thronsons Store **(406) 732-5530**

Operator Contact: Michael Thronson **(406) 732-5530** **mikethronson@hotmail.com**

Owner/Operator: Thronsons Store (406) 732-5530

Michael Thronson, UST Class A Operator mikethronson@hotmail.com

Michael Thronson, UST Class B Global Operator mikethronson@hotmail.com

Tank Number	07	**Tank Age**	36	**Tank Installed Date**	12/31/1989	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve
Tag Number	4401	**Spill Test Date**	06/30/2021	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	None	**AST**	No
Status	**Temporarily Out of Use**	**MLLD Test Date**	05/26/2020	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	06/01/2023	**Primary Tank Leak Detection**	Manual Interstitial Monitoring	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	7000	**ATG Test Date**		**Line Tightness Test Date**	05/26/2020	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	09/09/2023			**ATG Type**					
Tank Number	08	**Tank Age**	36	**Tank Installed Date**	12/31/1989	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve
Tag Number	4402	**Spill Test Date**	05/22/2025	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Single Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	05/22/2025	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	06/01/2023	**Primary Tank Leak Detection**	Manual Interstitial Monitoring	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	3000	**ATG Test Date**		**Line Tightness Test Date**	05/22/2025	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	09/09/2021			**ATG Type**					
Tank Number	06	**Tank Age**	36	**Tank Installed Date**	12/31/1989	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve
Tag Number	4403	**Spill Test Date**	05/22/2025	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	None	**AST**	No

Status	**Currently in Use**	**MLLD Test Date**	05/22/2025	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	06/01/2023	**Primary Tank Leak Detection**	Manual Interstitial Monitoring	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**		**Line Tightness Test Date**	05/22/2025	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	09/09/2021			**ATG Type**					

Facility Summary in Powder River County in the City of Broadus

Location: CORNER STORE
106 W Holt St
Broadus, MT 59317 Powder River

System Facility ID:38-00126

Facility Code: 26529
Last Inspected On: 11/06/2023
Operating Permit Renewal Date: 11/06/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Amsden, LLC	**(406) 580-4698**	**amsden@becklawyers.com**
Operator Contact:	Julie Riley	**(406) 853-3971**	**jriley@rangeweb.net**

Owner/Operator: Amsden, LLC (406) 580-4698 amsden@becklawyers.com

Julie Riley, UST Class A Operator jriley@rangeweb.net

Julie Riley, UST Class B Operator jriley@rangeweb.net

Tank Number	06	**Tank Age**	33	**Tank Installed Date**	12/04/1992	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	933	**Spill Test Date**	05/30/2024	**Piping Installed Date**	03/22/2013	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**	11/06/2023	**Tank/Piping CP Test Date**	11/06/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**	11/06/2023	**Line Tightness Test Date**	10/10/2020	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date	05/30/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	07	**Tank Age**	33	**Tank Installed Date**	12/04/1992	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	934	**Spill Test Date**	11/06/2023	**Piping Installed Date**	04/28/2020	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**	11/06/2023	**Tank/Piping CP Test Date**	11/06/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**	11/06/2023	**Line Tightness Test Date**	09/25/2020	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date	05/30/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Tank Number	08	**Tank Age**	33	**Tank Installed Date**	12/04/1992	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	935	**Spill Test Date**	11/06/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**	11/06/2023	**Tank/Piping CP Test Date**	11/06/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	5000	**ATG Test Date**	11/06/2023	**Line Tightness Test Date**	09/22/2020	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	05/30/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	09	**Tank Age**	33	**Tank Installed Date**	12/04/1992	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	936	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Temporarily Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	11/06/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.1	**Vapor Recovery**	No
Capacity	5000	**ATG Test Date**		**Line Tightness Test Date**	01/07/2017	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Glacier County in the City of Browning

Location: CORNER STORE
330 W Central Ave
Browning, MT 59417 Glacier

System Facility ID:18-05813

Facility Code: 21980
Last Inspected On: 11/09/2023
Operating Permit Renewal Date: 03/13/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: CORNER STORE **(406) 338-2575** **JAMIE.ALICE@HOTMAIL.COM**

Operator Contact:

Owner/Operator: CORNER STORE (406) 338-2575 JAMIE.ALICE@HOTMAIL.COM

Tank Number	04	**Tank Age**	28	**Tank Installed Date**	01/03/1997	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve

Tag Number	4441	**Spill Test Date**	09/19/2023	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	09/19/2023	**Tank/Piping CP Test Date**	09/19/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	20000	**ATG Test Date**	09/19/2023	**Line Tightness Test Date**	12/10/2008	**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	09/19/2023			**ATG Type**	Gilbarco/EMC Basic				
Tank Number	05	**Tank Age**	28	**Tank Installed Date**	01/03/1997	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	4442	**Spill Test Date**	05/21/2024	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	09/19/2023	**Tank/Piping CP Test Date**	09/19/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	09/19/2023	**Line Tightness Test Date**	05/25/2017	**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	05/21/2024			**ATG Type**	Gilbarco/EMC Basic				
Tank Number	06	**Tank Age**	28	**Tank Installed Date**	01/03/1997	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	4443	**Spill Test Date**	09/19/2023	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	09/19/2023	**Tank/Piping CP Test Date**	09/19/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	09/19/2023	**Line Tightness Test Date**	05/25/2017	**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	09/19/2023			**ATG Type**	Gilbarco/EMC Basic				

Facility Summary in Glacier County in the City of Browning

Location: GLACIER FAMILY FOODS
601 SE Boundary St
Browning, MT 59417 Glacier

System Facility ID:60-15286

Facility Code: 30993
Last Inspected On: 05/28/2025
Operating Permit Renewal Date: 10/14/2025

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Siyeh Development Corporation **TArmstrong@glaciercash.com**

Operator Contact: Dori Johnson;Siyeh Development Corporation;Mark Magee **dori.johnson@siyehdevelopment.com;TArmstrong@glaciercash.com;mmagee@glaciercash.com**

Owner/Operator: Siyeh Development Corporation TArmstrong@glaciercash.com

Dori Johnson, UST Class A Operator TArmstrong@glaciercash.com
Dori Johnson, UST Class B Operator dori.johnson@siyehdevelopment.com
Mark Magee, UST Class A Operator mmagee@glaciercash.com
Mark Magee, UST Class B Operator mmagee@glaciercash.com

Tank Number	01	**Tank Age**	10	**Tank Installed Date**	10/01/2015	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	5673	**Spill Test Date**	03/25/2022	**Piping Installed Date**	10/01/2015	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	09/14/2021	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	04/17/2019	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	07/26/2022	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	09/14/2021			**ATG Type**	Incon/TS-550 EVO				
Tank Number	02	**Tank Age**	10	**Tank Installed Date**	10/01/2015	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	5674	**Spill Test Date**	09/14/2021	**Piping Installed Date**	10/01/2015	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	09/14/2021	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel, Dyed	**PLLD Test Date**	04/17/2019	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	07/26/2022	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	09/14/2021			**ATG Type**	Incon/TS-550 EVO				

Tank Number	03	**Tank Age**	10	**Tank Installed Date**	10/01/2015	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	5675	**Spill Test Date**	09/14/2021	**Piping Installed Date**	10/01/2015	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	09/14/2021	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	04/17/2019	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	Yes
Capacity	20000	**ATG Test Date**	07/26/2022	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	09/14/2021			**ATG Type**	Incon/TS-550 EVO				
Tank Number	04	**Tank Age**	10	**Tank Installed Date**	10/01/2015	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	5676	**Spill Test Date**	09/14/2021	**Piping Installed Date**	10/01/2015	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	09/14/2021	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	04/17/2019	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	Yes
Capacity	8000	**ATG Test Date**	07/26/2022	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	09/14/2021			**ATG Type**	Incon/TS-550 EVO				

Facility Summary in Glacier County in the City of Browning

Location: GLACIER WAY CONVENIENCE STORE
200 MT Hwy 464
Browning, MT 59417 Glacier

System Facility ID:18-13768

Facility Code: 22049
Last Inspected On: 12/21/2023
Operating Permit Renewal Date: 12/20/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Pat Schildt	**(406) 338-4464**	**pschildt2@yahoo.com**
Operator Contact:	Charles Lafley;Harold Schildt;Stacey Keller	**(406) 338-4464;(406) 338-7568;(775) 560-2318**	**s_keller21@yahoo.com**

Owner/Operator: Pat Schildt (406) 338-4464 pschildt2@yahoo.com

Charles Lafley, UST Class A Operator
Charles Lafley, UST Class B Global Operator
Harold Schildt, UST Class A Operator
Harold Schildt, UST Class B Global Operator
Stacey Keller, UST Class A Operator s_keller21@yahoo.com
Stacey Keller, UST Class B Global Operator s_keller21@yahoo.com

Tank Number	01	**Tank Age**	29	**Tank Installed Date**	09/25/1996	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve
Tag Number	3425	**Spill Test Date**	12/12/2023	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	07/17/2023	**Sump Tightness Test Date**	04/20/2018	**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	07/09/2008	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	20000	**ATG Test Date**	07/17/2023	**Line Tightness Test Date**	07/17/2023	**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	07/17/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	02	**Tank Age**	29	**Tank Installed Date**	09/25/1996	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve
Tag Number	3426	**Spill Test Date**	12/12/2023	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	07/17/2023	**Sump Tightness Test Date**	04/20/2018	**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	07/09/2008	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No

Capacity	15000	**ATG Test Date**	07/17/2023	**Line Tightness Test Date**	07/17/2023	**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	12/12/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	03	**Tank Age**	29	**Tank Installed Date**	09/25/1996	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve
Tag Number	3427	**Spill Test Date**	07/17/2023	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	07/17/2023	**Sump Tightness Test Date**	04/20/2018	**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	07/09/2008	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	07/17/2023	**Line Tightness Test Date**	07/17/2023	**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	07/17/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Glacier County in the City of Browning

Location: PARK CAFE AND GROCERY
3147 US Hwy 89 W
Browning, MT 59417-9701 Glacier

System Facility ID:18-06436

Facility Code: 21989
Last Inspected On: 04/04/2023
Operating Permit Renewal Date: 10/30/2025

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Hilton Family Corporation	**(406) 250-1193**	**hhh.electric@yahoo.com**
Operator Contact:	Keith Hilton	**(406) 250-1193**	**hhh.electric@yahoo.com**

Owner/Operator: Hilton Family Corporation (406) 250-1193 hhh.electric@yahoo.com

Keith Hilton, UST Class A Operator hhh.electric@yahoo.com

Keith Hilton, UST Class B Operator hhh.electric@yahoo.com

Tank Number	05	**Tank Age**	34	**Tank Installed Date**	11/01/1991	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve
Tag Number	1380	**Spill Test Date**	05/05/2025	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Single Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	05/05/2025	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	24000	**ATG Test Date**	05/05/2025	**Line Tightness Test Date**	05/05/2025	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	05/05/2025			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	06	**Tank Age**	34	**Tank Installed Date**	11/01/1991	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve
Tag Number	1381	**Spill Test Date**	05/05/2025	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Single Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	05/05/2025	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	05/05/2025	**Line Tightness Test Date**	05/05/2025	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	05/05/2025			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	07	**Tank Age**	34	**Tank Installed Date**	11/01/1991	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve

Tag Number	1382	**Spill Test Date**	05/05/2025	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Single Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	05/05/2025	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	05/05/2025	**Line Tightness Test Date**	05/05/2025	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	05/05/2025			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Glacier County in the City of Browning

Location: SCHOOL DIST 9 MAINTENANCE COMPLEX
105 E Boundary St
Browning, MT 59417 Glacier

System Facility ID:18-03868

Facility Code: 21947
Last Inspected On: 02/25/2025
Operating Permit Renewal Date: 03/22/2028

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: School Dist 9 Browning

Operator Contact: Reid Reagan **(406) 338-2490** **reidr@bps.k12.mt.gov**

Owner/Operator: School Dist 9 Browning

Reid Reagan, UST Class A Operator reidr@bps.k12.mt.gov
Reid Reagan, UST Class B Operator reidr@bps.k12.mt.gov

Tank Number	02	**Tank Age**	39	**Tank Installed Date**	11/29/1986	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Steel	**Overfill Types**	Flapper Valve
Tag Number	4130	**Spill Test Date**	04/05/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Single Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	03/02/2022	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	03/12/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	03/12/2024			**ATG Type**	Gilbarco/TLS-350				
Tank Number	03	**Tank Age**	36	**Tank Installed Date**	11/28/1989	**Tank Material Construction**	Steel Clad	**Piping Material**	Steel	**Overfill Types**	Flapper Valve
Tag Number	4131	**Spill Test Date**	04/05/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Single Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	03/02/2022	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	03/12/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	03/12/2024			**ATG Type**	Gilbarco/TLS-350				

Facility Summary in Glacier County in the City of Browning

Location: SCHOOL DIST 9 TRANSPORTATION DEPT
829 SW Boundary St
Browning, MT 59417 Glacier

System Facility ID:18-12747

Facility Code: 22038
Last Inspected On: 02/25/2025
Operating Permit Renewal Date: 03/22/2028

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: School Dist 9 Browning

Operator Contact: Wayne Bullcalf;School Dist 9 Browning **francisb@bps.k12.mt.us**

Owner/Operator: School Dist 9 Browning

Wayne Bullcalf, UST Class A Operator francisb@bps.k12.mt.us
Wayne Bullcalf, UST Class B Global Operator francisb@bps.k12.mt.us

Tank Number	01	**Tank Age**	33	**Tank Installed Date**	07/01/1992	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	1898	**Spill Test Date**	03/02/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Single Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**	03/12/2024	**Tank/Piping CP Test Date**	03/02/2022	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	03/12/2024	**Line Tightness Test Date**	03/12/2024	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	03/12/2024			**ATG Type**	Gilbarco/TLS-350				
Tank Number	02	**Tank Age**	33	**Tank Installed Date**	07/01/1992	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	1899	**Spill Test Date**	03/23/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Diesel	**PLLD Test Date**	03/12/2024	**Tank/Piping CP Test Date**	03/02/2022	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	03/12/2024	**Line Tightness Test Date**	03/12/2024	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	03/12/2024			**ATG Type**	Gilbarco/TLS-350				
Tank Number	03	**Tank Age**	33	**Tank Installed Date**	07/01/1992	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	1900	**Spill Test Date**	03/02/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No

Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	03/24/2022	**Catastrophic L.D. Type 3.0**	Continuous Interstitial Monitoring	**Piping Type**	U.S. Suction	**CP Met Types**	Impressed Current
Product	Oil, Waste	**PLLD Test Date**		**Tank/Piping CP Test Date**	03/02/2022	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	1000	**ATG Test Date**	03/02/2022	**Line Tightness Test Date**	09/08/2009	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	03/22/2022			**ATG Type**	Gilbarco/TLS-350				

Facility Summary in Glacier County in the City of Browning

Location: TOWN PUMP INC BROWNING 2
304 SE Boundary St
Browning, MT 59417 Glacier

System Facility ID:18-08677

Facility Code: 22011
Last Inspected On: 03/15/2024
Operating Permit Renewal Date: 08/06/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Town Pump Inc Browning 2

Operator Contact: Trent Biggers **Trentb@townpump.com**

Owner/Operator: Town Pump Inc Browning 2

Trent Biggers, UST Class A Operator Trentb@townpump.com

Trent Biggers, UST Class B Global Operator Trentb@townpump.com

Tank Number	09	**Tank Age**	30	**Tank Installed Date**	06/01/1995	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve;Flapper Valve
Tag Number	2463	**Spill Test Date**	07/07/2023	**Piping Installed Date**	07/11/2013	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	02/03/2020	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	03/15/2024	**Tank/Piping CP Test Date**	11/26/2012	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	Yes
Capacity	12000	**ATG Test Date**	03/15/2024	**Line Tightness Test Date**	12/01/2006	**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	No
		Overfill Test Date	07/07/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350				
Tank Number	11	**Tank Age**	30	**Tank Installed Date**	06/01/1995	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve;Flapper Valve
Tag Number	2465	**Spill Test Date**	07/07/2023	**Piping Installed Date**	07/11/2013	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	02/03/2020	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	07/26/2022	**Tank/Piping CP Test Date**	11/26/2012	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	Yes
Capacity	12000	**ATG Test Date**	03/15/2024	**Line Tightness Test Date**	11/30/2006	**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	No
		Overfill Test Date	07/07/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350				

Tank Number	12	**Tank Age**	30	**Tank Installed Date**	06/01/1995	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve
Tag Number	2466	**Spill Test Date**	08/29/2023	**Piping Installed Date**	07/11/2013	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	02/03/2020	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	03/15/2024	**Tank/Piping CP Test Date**	12/04/2009	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	03/15/2024	**Line Tightness Test Date**	11/30/2006	**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	No
		Overfill Test Date	08/29/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350				
Tank Number	13	**Tank Age**	30	**Tank Installed Date**	06/01/1995	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve
Tag Number	2467	**Spill Test Date**	07/07/2023	**Piping Installed Date**	07/11/2013	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	02/03/2020	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	07/26/2022	**Tank/Piping CP Test Date**	11/26/2012	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	03/15/2024	**Line Tightness Test Date**	11/30/2006	**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	No
		Overfill Test Date	07/07/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350				
Tank Number	14	**Tank Age**	22	**Tank Installed Date**	08/14/2003	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve
Tag Number	4859	**Spill Test Date**	07/07/2023	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	02/03/2020	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	03/15/2024	**Tank/Piping CP Test Date**	12/04/2009	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	03/15/2024	**Line Tightness Test Date**	12/01/2006	**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	07/07/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350				
Tank Number	15	**Tank Age**	22	**Tank Installed Date**	08/14/2003	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve
Tag Number	4860	**Spill Test Date**	08/29/2023	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No

Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	02/03/2020	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	03/15/2024	**Tank/Piping CP Test Date**	11/26/2012	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	5000	**ATG Test Date**	03/15/2024	**Line Tightness Test Date**	12/01/2006	**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	08/29/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350				
Tank Number	10	**Tank Age**	30	**Tank Installed Date**	06/01/1995	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve;Flapper Valve
Tag Number	4888	**Spill Test Date**	07/07/2023	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	02/03/2020	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	03/15/2024	**Tank/Piping CP Test Date**	11/26/2012	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	Yes
Capacity	12000	**ATG Test Date**	03/15/2024	**Line Tightness Test Date**	11/30/2006	**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	07/07/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Glacier County in the City of Cut Bank

Location: BEN TAYLOR INC - CUT BANK BULK PLANT
201 BN Industrial Site
Cut Bank, MT 59427-2936 Glacier

System Facility ID:18-04137

Facility Code: 21958
Last Inspected On: 05/29/2025
Operating Permit Renewal Date: 11/17/2025

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Ben Taylor Inc — **bti@3rivers.net**

Operator Contact: Scott Curry;Shannon Gabbard — **(406) 873-2812** — **scott.curry@btimontana.com;shannong@bentaylorinc.com**

Owner/Operator: Ben Taylor Inc — bti@3rivers.net

Scott Curry, UST Class A Operator	scott.curry@btimontana.com
Shannon Gabbard, UST Class A Operator	shannong@bentaylorinc.com
Shannon Gabbard, UST Class A Operator	shannong@bentaylorinc.com
Shannon Gabbard, UST Class B Operator	shannong@bentaylorinc.com
Shannon Gabbard, UST Class B Operator	shannong@bentaylorinc.com

Tank Number	S16	**Tank Age**	25	**Tank Installed Date**	10/29/2000	**Tank Material Construction**	Unknown	**Piping Material**	Flexible Plastic	**Overfill Types**	
Tag Number	4241	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	Yes
Status	**Currently in Use**	**MLLD Test Date**	08/02/2022	**Sump Tightness Test Date**	08/02/2022	**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	34000	**ATG Test Date**		**Line Tightness Test Date**	08/02/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	S17	**Tank Age**	25	**Tank Installed Date**	10/29/2000	**Tank Material Construction**	Unknown	**Piping Material**	Flexible Plastic	**Overfill Types**	
Tag Number	4242	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	Yes
Status	**Currently in Use**	**MLLD Test Date**	08/02/2022	**Sump Tightness Test Date**	08/02/2022	**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	11700	**ATG Test Date**		**Line Tightness Test Date**	08/02/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No

		Overfill Test Date				**ATG Type**					
Tank Number	S18	**Tank Age**	25	**Tank Installed Date**	10/29/2000	**Tank Material Construction**	Unknown	**Piping Material**	Flexible Plastic	**Overfill Types**	
Tag Number	4243	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	Yes
Status	**Currently in Use**	**MLLD Test Date**	08/02/2022	**Sump Tightness Test Date**	08/02/2022	**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	12500	**ATG Test Date**		**Line Tightness Test Date**	08/02/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	S19	**Tank Age**	25	**Tank Installed Date**	10/29/2000	**Tank Material Construction**	Unknown	**Piping Material**	Flexible Plastic	**Overfill Types**	
Tag Number	4244	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	Yes
Status	**Currently in Use**	**MLLD Test Date**	08/02/2022	**Sump Tightness Test Date**	08/02/2022	**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Diesel, Dyed	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	34000	**ATG Test Date**		**Line Tightness Test Date**	08/02/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	S20	**Tank Age**	25	**Tank Installed Date**	10/29/2000	**Tank Material Construction**	Unknown	**Piping Material**	Flexible Plastic	**Overfill Types**	
Tag Number	4245	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	Yes
Status	**Currently in Use**	**MLLD Test Date**	08/02/2022	**Sump Tightness Test Date**	08/02/2022	**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Diesel, Dyed	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	12500	**ATG Test Date**		**Line Tightness Test Date**	08/02/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	S21	**Tank Age**	25	**Tank Installed Date**	10/29/2000	**Tank Material Construction**	Unknown	**Piping Material**	Flexible Plastic	**Overfill Types**	
Tag Number	4246	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	Yes
Status	**Currently in Use**	**MLLD Test Date**	08/02/2022	**Sump Tightness Test Date**	08/02/2022	**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	

Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	11700	**ATG Test Date**		**Line Tightness Test Date**	08/02/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date				**ATG Type**					

Facility Summary in Glacier County in the City of Cut Bank

Location: BTI 813 E RAILROAD CARDLOCK
813 E Railroad St
Cut Bank, MT 59427 Glacier

System Facility ID:56-13775

Facility Code: 30464
Last Inspected On: 03/08/2023
Operating Permit Renewal Date: 07/30/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Ben Taylor Inc		**bti@3rivers.net**
Operator Contact:	Scott Curry;Steve Nelson	**(406) 873-4612**	**ditchrider61@yahoo.com;scott.curry@btimontana.com**

Owner/Operator: Ben Taylor Inc — bti@3rivers.net

Joseph Pehan, UST Class B Operator	simonspt@3rivers.net
Joseph Pehan, UST Class B Operator	simonspt@3rivers.net
Justin Aikins, UST Class B Operator	justinleeaikins@gmail.com
Justin Aikins, UST Class B Operator	justinleeaikins@gmail.com
Scott Curry, UST Class A Operator	scott.curry@btimontana.com
Steve Nelson, UST Class A Operator	ditchrider61@yahoo.com
Steve Nelson, UST Class A Operator	ditchrider61@yahoo.com
Steve Nelson, UST Class B Operator	ditchrider61@yahoo.com
Steve Nelson, UST Class B Operator	ditchrider61@yahoo.com

Tank Number	S1	**Tank Age**	28	**Tank Installed Date**	10/31/1997	**Tank Material Construction**	Bare Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	
Tag Number	1928	**Spill Test Date**		**Piping Installed Date**	01/03/2012	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	Yes
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	03/08/2023	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**		**Line Tightness Test Date**	02/26/2020	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	S2	**Tank Age**	28	**Tank Installed Date**	10/31/1997	**Tank Material Construction**	Bare Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	
Tag Number	1929	**Spill Test Date**		**Piping Installed Date**	01/03/2012	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	Yes
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	03/08/2023	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	

Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**		**Line Tightness Test Date**	02/26/2020	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	03	**Tank Age**	13	**Tank Installed Date**	03/01/2012	**Tank Material Construction**	Unknown	**Piping Material**	Flexible Plastic	**Overfill Types**	
Tag Number	5494	**Spill Test Date**		**Piping Installed Date**	03/01/2012	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	Yes
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	03/08/2023	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	11800	**ATG Test Date**		**Line Tightness Test Date**	02/26/2020	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date				**ATG Type**					

Facility Summary in Glacier County in the City of Cut Bank

Location: CUT BANK MUNICIPAL AIRPORT
2705 Valier Hwy
Cut Bank, MT 59427 Glacier

System Facility ID:18-00137

Facility Code: 21903
Last Inspected On: 09/28/2022
Operating Permit Renewal Date: 01/31/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Cut Bank Airport Authority **(406) 873-8683**

Operator Contact: Ronald Hermanet;Roy Nollkamper;Tom Redfield **(406) 873-8683** **cbaa_mt@yahoo.com;nollkamper47@hotmail.com**

Owner/Operator: Cut Bank Airport Authority (406) 873-8683

Ronald Hermanet, UST Class A Operator	cbaa_mt@yahoo.com
Ronald Hermanet, UST Class A Operator	cbaa_mt@yahoo.com
Roy Nollkamper, UST Class A Operator	nollkamper47@hotmail.com
Roy Nollkamper, UST Class A Operator	nollkamper47@hotmail.com
Roy Nollkamper, UST Class B Operator	nollkamper47@hotmail.com
Roy Nollkamper, UST Class B Operator	nollkamper47@hotmail.com
Tom Redfield, UST Class A Operator	cbaa_mt@yahoo.com
Tom Redfield, UST Class B Global Operator	cbaa_mt@yahoo.com

Tank Number	08	**Tank Age**	28	**Tank Installed Date**	11/01/1997	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	793	**Spill Test Date**	07/12/2021	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	04/06/2022	**Sump Tightness Test Date**	09/28/2022	**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Jet Fuel (Jet-A, Jet-A1, JP5)	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	04/06/2022	**Line Tightness Test Date**	04/06/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	07/25/2022			**ATG Type**	Gilbarco-Veeder Root/EMC Basic				
Tank Number	09	**Tank Age**	28	**Tank Installed Date**	11/01/1997	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	794	**Spill Test Date**	07/12/2021	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	04/06/2022	**Sump Tightness Test Date**	09/28/2022	**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Aviation Gas	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No

Capacity	12000	**ATG Test Date**	04/06/2022	**Line Tightness Test Date**	04/06/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	07/25/2022			**ATG Type**	Gilbarco-Veeder Root/EMC Basic				

Facility Summary in Glacier County in the City of Cut Bank

Location: KENNYS SUPER SERVICE
401 E Main St
Cut Bank, MT 59427-3014 Glacier

System Facility ID:18-00321

Facility Code: 21907
Last Inspected On: 09/28/2021
Operating Permit Renewal Date: 09/28/2024

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Kennys Super Service;Randy Fetters **(406) 873-2432**

Operator Contact: Randall Fetters **(406) 873-2432**

Randy Fetters, UST Class A Operator
Randy Fetters, UST Class A Operator
Randy Fetters, UST Class A Operator
Randy Fetters, UST Class B Operator
Randy Fetters, UST Class B Operator
Randy Fetters, UST Class B Operator

Tank Number	01	**Tank Age**	40	**Tank Installed Date**	06/13/1985	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	1471	**Spill Test Date**		**Piping Installed Date**	07/20/2007	**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	09/20/2020	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**	EMCO Electronics/EECO 1500				
Tank Number	02	**Tank Age**	40	**Tank Installed Date**	06/13/1985	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	1472	**Spill Test Date**		**Piping Installed Date**	07/20/2007	**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	09/20/2020	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No

		Overfill Test Date				**ATG Type**	EMCO Electronics/EECO 1500				

Facility Summary in Glacier County in the City of Cut Bank

Location: TOWN PUMP INC CUT BANK 2
510 W Main St
Cut Bank, MT 59427-2808 Glacier

System Facility ID:18-03417

Facility Code: 21942
Last Inspected On: 03/13/2024
Operating Permit Renewal Date: 08/06/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Cut Bank 2 Town Pump LLC **(406) 497-6700** **environmental@townpump.com**

Operator Contact: Trent Biggers **Trentb@townpump.com**

Owner/Operator: Cut Bank 2 Town Pump LLC (406) 497-6700 environmental@townpump.com

Trent Biggers, UST Class A Operator Trentb@townpump.com

Trent Biggers, UST Class B Global Operator Trentb@townpump.com

Tank Number	01	**Tank Age**	32	**Tank Installed Date**	03/01/1993	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve
Tag Number	2459	**Spill Test Date**	07/19/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	07/19/2023	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	03/13/2024	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	03/13/2024	**Line Tightness Test Date**	12/02/2009	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	07/19/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350				
Tank Number	02	**Tank Age**	32	**Tank Installed Date**	03/01/1993	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve;Flapper Valve
Tag Number	2460	**Spill Test Date**	07/19/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	03/13/2024	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	03/13/2024	**Line Tightness Test Date**	12/02/2009	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	07/19/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350				

Tank Number	03	**Tank Age**	32	**Tank Installed Date**	03/01/1993	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	2461	**Spill Test Date**	07/19/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	03/13/2024	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	03/13/2024	**Line Tightness Test Date**	12/02/2009	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	07/19/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350				
Tank Number	04	**Tank Age**	32	**Tank Installed Date**	03/01/1993	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve
Tag Number	2462	**Spill Test Date**	07/19/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	03/13/2024	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	03/13/2024	**Line Tightness Test Date**	12/02/2009	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	07/19/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350				
Tank Number	07	**Tank Age**	25	**Tank Installed Date**	05/01/2000	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve
Tag Number	4185	**Spill Test Date**	07/19/2023	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	03/13/2024	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	03/13/2024	**Line Tightness Test Date**	12/02/2009	**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	07/19/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350				
Tank Number	08	**Tank Age**	25	**Tank Installed Date**	05/01/2000	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve
Tag Number	4186	**Spill Test Date**	07/19/2023	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible

Product	Diesel	**PLLD Test Date**	03/13/2024	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	5000	**ATG Test Date**	03/13/2024	**Line Tightness Test Date**	12/02/2009	**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	07/19/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Glacier County in the City of Cut Bank

Location: TOWN PUMP OF CUT BANK 1
1119 E Main St
Cut Bank, MT 59427 Glacier

System Facility ID:60-15144

Facility Code: 30888
Last Inspected On: 03/13/2024
Operating Permit Renewal Date: 08/06/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Cut Bank 1 Town Pump LLC **(406) 497-6700** **environmental@townpump.com**

Operator Contact: Trent Biggers **Trentb@townpump.com**

Owner/Operator: Cut Bank 1 Town Pump LLC (406) 497-6700 environmental@townpump.com

Trent Biggers, UST Class A Operator Trentb@townpump.com

Trent Biggers, UST Class B Global Operator Trentb@townpump.com

Tank Number	01	**Tank Age**	15	**Tank Installed Date**	07/03/2010	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve
Tag Number	5227	**Spill Test Date**	07/26/2023	**Piping Installed Date**	07/03/2010	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	07/26/2023	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	03/13/2024	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	20000	**ATG Test Date**	03/13/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Statistical Inventory Reconciliation	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	Yes
		Overfill Test Date	07/26/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350				
Tank Number	02	**Tank Age**	15	**Tank Installed Date**	07/03/2010	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve
Tag Number	5228	**Spill Test Date**	07/06/2023	**Piping Installed Date**	07/03/2010	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	07/06/2023	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	03/13/2024	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	03/13/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Statistical Inventory Reconciliation	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	Yes
		Overfill Test Date	07/06/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350				

Tank Number	03	**Tank Age**	15	**Tank Installed Date**	07/03/2010	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve
Tag Number	5229	**Spill Test Date**	07/06/2023	**Piping Installed Date**	07/03/2010	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	07/06/2023	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	03/13/2024	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	03/13/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Statistical Inventory Reconciliation	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	Yes
		Overfill Test Date	07/06/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Glacier County in the City of East Glacier Park

Location: BEAR TRACK TRAVEL CENTER
20958 US Hwy 2
East Glacier Park, MT 59434 Glacier

System Facility ID:56-13933

Facility Code: 30603
Last Inspected On: 07/18/2024
Operating Permit Renewal Date: 11/23/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Blackfeet Tribe

Operator Contact: Mark Magee;Tahnee Armstrong;Siyeh Development Corporation;Thomas Bearchild **(406) 338-5669** **mmagee@glaciercash.com;tarmstrong96@yahoo.com;TArmstrong@glaciercash.com;tbearchild@glaciercash.com**

Owner/Operator: Blackfeet Tribe

Mark Magee, UST Class A Operator	mmagee@glaciercash.com
Mark Magee, UST Class B Operator	mmagee@glaciercash.com
Tahnee Armstrong, UST Class A Operator	TArmstrong@glaciercash.com
Tahnee Armstrong, UST Class B Operator	TArmstrong@glaciercash.com
Thomas Bearchild, UST Class A Operator	tbearchild@glaciercash.com
Thomas Bearchild, UST Class B Operator	tbearchild@glaciercash.com

Tank Number	S1	**Tank Age**	26	**Tank Installed Date**	06/01/1999	**Tank Material Construction**	Unknown	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	4068	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	Yes
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	10/02/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	07/18/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Manual Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	07/18/2024			**ATG Type**					
Tank Number	S2	**Tank Age**	26	**Tank Installed Date**	06/01/1999	**Tank Material Construction**	Unknown	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	4069	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	Yes
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	10/02/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	5000	**ATG Test Date**	07/18/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Manual Interstitial Monitoring	**Energy Act**	No

		Overfill Test Date	07/18/2024			**ATG Type**					
Tank Number	S3	**Tank Age**	18	**Tank Installed Date**	09/14/2007	**Tank Material Construction**	Concrete	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	5126	**Spill Test Date**		**Piping Installed Date**	04/23/2007	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	Yes
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	10/02/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	07/18/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Manual Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	07/18/2024			**ATG Type**					

Facility Summary in Glacier County in the City of East Glacier Park

Location: SEARS MOTEL and GIFT SHOP
1023 Hwy 49 N
East Glacier Park, MT 59434 Glacier

System Facility ID:18-03870

Facility Code: 21948
Last Inspected On: 02/05/2021
Operating Permit Renewal Date: 02/05/2024

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Judy Jones;William Stewart	**(239) 694-0279;(406) 250-7525**	**EGlacier@aol.com;Sundaysun.bs@gmail.com**

Operator Contact:	Judy Jones	**(239) 694-0279**	**EGlacier@aol.com**

Owner/Operator:	Judy Jones	(239) 694-0279	EGlacier@aol.com
Owner/Operator:	William Stewart	(239) 694-0279	EGlacier@aol.com
	Judy Jones, UST Class A Operator		EGlacier@aol.com
	Judy Jones, UST Class B Operator		EGlacier@aol.com

Tank Number	03	**Tank Age**	35	**Tank Installed Date**	09/28/1990	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	1453	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Single Walled	**AST**	No
Status	**Temporarily Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	2000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco/EMC Basic				
Tank Number	04	**Tank Age**	35	**Tank Installed Date**	09/01/1990	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	1454	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Temporarily Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	2000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco/EMC Basic				

Facility Summary in Glacier County in the City of Saint Mary

Location: SAINT MARY RANGER STATION
73 Hudson Bay Rd
Saint Mary, MT 59411 Glacier

System Facility ID:18-02745

Facility Code: 21939
Last Inspected On: 12/23/2024
Operating Permit Renewal Date: 04/04/2028

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	National Park Service Browning	**(406) 732-7724**	**mark_hickcox@nps.gov**
Operator Contact:	Patrick Glynn	**(406) 888-7967**	**patrick_glynn@nps.gov**

Owner/Operator: National Park Service Browning (406) 732-7724 mark_hickcox@nps.gov

Patrick Glynn, UST Class A Operator patrick_glynn@nps.gov

Patrick Glynn, UST Class B Global Operator patrick_glynn@nps.gov

Tank Number	04	**Tank Age**	38	**Tank Installed Date**	07/01/1987	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	1221	**Spill Test Date**	09/02/2024	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	09/02/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**	09/02/2024	**Tank/Piping CP Test Date**	11/10/2024	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	09/02/2024	**Line Tightness Test Date**	11/03/2015	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	09/02/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	06	**Tank Age**	10	**Tank Installed Date**	10/01/2015	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	5620	**Spill Test Date**	09/02/2024	**Piping Installed Date**	10/28/2015	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	09/02/2024	**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	09/02/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**		**Energy Act**	Yes

		Overfill Test Date	09/02/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350;Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Glacier County in the City of Saint Mary

Location: ST MARY LODGE
3 Going To The Sun Rd
Saint Mary, MT 59411 Glacier

System Facility ID:18-01907

Facility Code: 21924
Last Inspected On: 06/01/2023
Operating Permit Renewal Date: 10/20/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Glacier Park Inc;Sally Welder	**(406) 892-6708**	**lwyrick@pursuitcollection.com**
Operator Contact:	Jon Noe;Lisa Wyrick	**(406) 226-5675;(406) 732-4431**	**lwyrick@pursuitcollection.com**

Owner/Operator:	Glacier Park Inc	(406) 892-6708	lwyrick@pursuitcollection.com
Owner/Operator:	Sally Black Welder	(406) 892-6708	lwyrick@pursuitcollection.com
	Bob Hines, UST Class B Operator		bhines@glacierparkinc.com
	Bob Hines, UST Class B Operator		bhines@glacierparkinc.com
	Jon Noe, UST Class A Operator		
	Jon Noe, UST Class A Operator		
	Lisa Wyrick, UST Class A Operator		lwyrick@pursuitcollection.com
	Lisa Wyrick, UST Class A Operator		lwyrick@pursuitcollection.com
	Lisa Wyrick, UST Class B Operator		lwyrick@pursuitcollection.com
	Lisa Wyrick, UST Class B Operator		lwyrick@pursuitcollection.com

Tank Number	01	**Tank Age**	35	**Tank Installed Date**	06/01/1990	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve
Tag Number	451	**Spill Test Date**	04/07/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**	06/18/2024	**Tank/Piping CP Test Date**	05/27/2020	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	15000	**ATG Test Date**	06/18/2024	**Line Tightness Test Date**	10/17/2007	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	04/07/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	02	**Tank Age**	35	**Tank Installed Date**	06/01/1990	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve
Tag Number	452	**Spill Test Date**	04/07/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Secondary Containment Chase	**AST**	No

Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**	06/18/2024	**Tank/Piping CP Test Date**	05/27/2020	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	15000	**ATG Test Date**	06/18/2024	**Line Tightness Test Date**	10/17/2007	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	04/07/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	03	**Tank Age**	35	**Tank Installed Date**	06/01/1990	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve
Tag Number	453	**Spill Test Date**	04/07/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Secondary Containment Chase	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**	06/18/2024	**Tank/Piping CP Test Date**	05/27/2020	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	7000	**ATG Test Date**	06/18/2024	**Line Tightness Test Date**	10/17/2007	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	04/07/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	04	**Tank Age**	35	**Tank Installed Date**	06/01/1990	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve
Tag Number	454	**Spill Test Date**	04/07/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Secondary Containment Chase	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**	06/18/2024	**Tank/Piping CP Test Date**	05/27/2020	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	3000	**ATG Test Date**	06/18/2024	**Line Tightness Test Date**	10/17/2011	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	04/07/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Golden Valley County in the City of Lavina

Location: FARMERS OASIS LLC
4666 MT Hwy 3
Lavina, MT 59046-7156 Golden Valley

System Facility ID:19-13681

Facility Code: 22075
Last Inspected On: 07/14/2022
Operating Permit Renewal Date: 10/24/2025

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Mike Bury;FARMERS OASIS LLC	**(406) 632-4329;(561) 693-8795**	**mike@raysoasis.com;MIKE@RAYOASIS.COM**
Operator Contact:	Jeff Parker	**(503) 298-3965**	**jjp7850@gmail.com**

Owner/Operator: Mike Bury,FARMERS OASIS LLC (406) 632-4329 mike@raysoasis.com
Jeff Parker, UST Class A Operator jjp7850@gmail.com
Jeff Parker, UST Class B Operator jjp7850@gmail.com

Tank Number	S1	**Tank Age**	29	**Tank Installed Date**	03/01/1996	**Tank Material Construction**	Unknown	**Piping Material**	Flexible Plastic	**Overfill Types**	
Tag Number	3381	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	Yes
Status	**Currently in Use**	**MLLD Test Date**	10/21/2022	**Sump Tightness Test Date**	10/21/2016	**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Deferred	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	07/14/2022	**Line Tightness Test Date**	07/14/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	S2	**Tank Age**	29	**Tank Installed Date**	03/01/1996	**Tank Material Construction**	Unknown	**Piping Material**	Flexible Plastic	**Overfill Types**	
Tag Number	3382	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	Yes
Status	**Currently in Use**	**MLLD Test Date**	07/14/2022	**Sump Tightness Test Date**	10/21/2016	**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Deferred	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	07/14/2022	**Line Tightness Test Date**	07/14/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					

Facility Summary in Golden Valley County in the City of Ryegate

Location: RYEGATE PUBLIC SCHOOLS DIST 1
207 2nd Ave W
Ryegate, MT 59074-0129 Golden Valley

System Facility ID:19-07975

Facility Code: 22067
Last Inspected On: 08/01/2024
Operating Permit Renewal Date: 11/01/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: School Dist 1 Ryegate **(406) 568-2211**

Operator Contact: Penny Stradtman **pstradtman@ryegate.k12.mt.us**

Owner/Operator: School Dist 1 Ryegate (406) 568-2211

Penny Stradtman, UST Class A Operator pstradtman@ryegate.k12.mt.us
Penny Stradtman, UST Class B Operator pstradtman@ryegate.k12.mt.us

Tank Number	S2	**Tank Age**	29	**Tank Installed Date**	08/01/1996	**Tank Material Construction**	Bare Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	1870	**Spill Test Date**		**Piping Installed Date**	07/30/2014	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	Yes
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	08/01/2024	**Catastrophic L.D. Type 3.0**	Auto Dialer	**Piping Type**	U.S. Suction	**CP Met Types**	
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	5000	**ATG Test Date**		**Line Tightness Test Date**	07/31/2014	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					

Facility Summary in Golden Valley County in the City of Ryegate

Location: SUPER D GROCERY
203 E Railway Ave
Ryegate, MT 59074 Golden Valley

System Facility ID:19-13735

Facility Code: 22076
Last Inspected On: 09/26/2024
Operating Permit Renewal Date: 12/10/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Clifford Sutton;Super D Grocery Inc	**(406) 568-2378**	**superd@midrivers.com**
Operator Contact:	Peggy Sutton	**(406) 568-2378**	**superd@midrivers.com**

Owner/Operator: Clifford Sutton (406) 568-2378

Owner/Operator: Super D Grocery Inc (406) 568-2378

Peggy Sutton, UST Class A Operator superd@midrivers.com

Peggy Sutton, UST Class B Operator superd@midrivers.com

Tank Number	S1	**Tank Age**	29	**Tank Installed Date**	04/08/1996	**Tank Material Construction**	Unknown	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	3462	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	Yes
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	10/02/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Deferred	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	5000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	S2	**Tank Age**	27	**Tank Installed Date**	12/01/1998	**Tank Material Construction**	Unknown	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	3727	**Spill Test Date**		**Piping Installed Date**	08/20/2008	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	Yes
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	10/02/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Deferred	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date				**ATG Type**					

Tank Number	S3	**Tank Age**	27	**Tank Installed Date**	12/01/1998	**Tank Material Construction**	Unknown	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	3728	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	Yes
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	09/25/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Deferred	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date				**ATG Type**					

Facility Summary in Granite County in the City of Drummond

Location: FICS KWIK SIX
410 E Front St
Drummond, MT 59832-9648 Granite

System Facility ID:20-03192

Facility Code: 22104
Last Inspected On: 09/20/2022
Operating Permit Renewal Date: 10/14/2025

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Fickler Oil Co Inc Deer Lodge	**(406) 846-3970**	**tfickler@montana.com**
Operator Contact:	Judy Rasmussen;Kayla Brown;Fics Kwik Six		**fics@blackfoot.net;kayla.i.hannawalt@gmail.com**

Owner/Operator:	Fickler Oil Co Inc Deer Lodge	(406) 846-3970	tfickler@montana.com
	Dolly Brewer, UST Class B Global Operator		barrelgirl11@hotmail.com
	Dolly Brewer, UST Class B Global Operator		barrelgirl11@hotmail.com
	Judy Rasmussen, UST Class A Operator		fics@blackfoot.net
	Judy Rasmussen, UST Class A Operator		fics@blackfoot.net
	Judy Rasmussen, UST Class B Operator		fics@blackfoot.net
	Judy Rasmussen, UST Class B Operator		fics@blackfoot.net
	Kayla Brown, UST Class A Operator		kayla.i.hannawalt@gmail.com
	Kayla Brown, UST Class B Operator		kayla.i.hannawalt@gmail.com
	Todd Fickler, UST Class B Operator		vclose@bresnan.net

Tank Number	10	**Tank Age**	15	**Tank Installed Date**	07/01/2010	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	5264	**Spill Test Date**	10/14/2024	**Piping Installed Date**	03/31/2010	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	12/22/2020	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	12/01/2021	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	12/01/2021	**Line Tightness Test Date**	11/18/2009	**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	09/20/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350;Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	11	**Tank Age**	15	**Tank Installed Date**	07/01/2010	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	5265	**Spill Test Date**	10/14/2024	**Piping Installed Date**	03/31/2010	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No

Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	12/22/2020	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	12/01/2021	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	5000	**ATG Test Date**	12/01/2021	**Line Tightness Test Date**	11/18/2009	**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	09/20/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350;Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	12	**Tank Age**	15	**Tank Installed Date**	07/01/2010	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	5266	**Spill Test Date**	10/14/2024	**Piping Installed Date**	03/31/2010	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	12/22/2020	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	12/01/2021	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	12/01/2021	**Line Tightness Test Date**	11/18/2009	**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	09/20/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350;Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	13	**Tank Age**	15	**Tank Installed Date**	07/01/2010	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	5267	**Spill Test Date**	10/14/2024	**Piping Installed Date**	03/31/2010	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	12/22/2020	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel, Dyed	**PLLD Test Date**	12/01/2021	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	5000	**ATG Test Date**	12/01/2021	**Line Tightness Test Date**	11/18/2009	**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	09/20/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350;Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Granite County in the City of Drummond

Location: MOUNTAIN WEST CO OP
350 E Front St
Drummond, MT 59832 Granite

System Facility ID:20-03611

Facility Code: 22107
Last Inspected On: 09/24/2024
Operating Permit Renewal Date: 01/25/2028

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Mountain West Coop Drummond **(406) 288-3219**

Operator Contact: Dusty Smith;Michael Gourley;CHS Inc Inver Grove Heights;Robin McCurdy **(406) 370-3920;(651) 355-6343;(406) 546-4885** **dusty.smith@chsinc.com;michael.gourley@chsinc.com;Kirsten.Tindall@chsinc.com;robin.mccurdy@chsinc.com**

Owner/Operator: Mountain West Coop Drummond (406) 288-3219

Dusty Smith, UST Class A Operator	dusty.smith@chsinc.com
Michael Gourley, UST Class A Operator	Kirsten.Tindall@chsinc.com
Robin McCurdy, UST Class A Operator	robin.mccurdy@chsinc.com
Robin McCurdy, UST Class B Operator	robin.mccurdy@chsinc.com

Tank Number	06	**Tank Age**	65	**Tank Installed Date**	06/15/1960	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	1458	**Spill Test Date**	09/24/2024	**Piping Installed Date**		**Tank Construction**	Lined Interior/Impressed Current	**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	09/24/2024	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	09/24/2024	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	09/24/2024	**Line Tightness Test Date**	09/24/2024	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	09/24/2024			**ATG Type**	Gilbarco/TLS-350				
Tank Number	07	**Tank Age**	54	**Tank Installed Date**	06/16/1971	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	1459	**Spill Test Date**	09/24/2024	**Piping Installed Date**		**Tank Construction**	Lined Interior/Impressed Current	**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	09/24/2024	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	09/24/2024	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	09/24/2024	**Line Tightness Test Date**	09/24/2024	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	09/24/2024			**ATG Type**	Gilbarco/TLS-350				

Tank Number	08	**Tank Age**	34	**Tank Installed Date**	05/13/1991	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	1460	**Spill Test Date**	09/24/2024	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	09/24/2024	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	09/24/2024	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**	09/24/2024	**Line Tightness Test Date**	09/24/2024	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	09/24/2024			**ATG Type**	Gilbarco/TLS-350				
Tank Number	09	**Tank Age**	34	**Tank Installed Date**	05/13/1991	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	1461	**Spill Test Date**	09/24/2024	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	09/24/2024	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	09/24/2024	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**	09/24/2024	**Line Tightness Test Date**	09/24/2024	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	09/24/2024			**ATG Type**	Gilbarco/TLS-350				
Tank Number	05	**Tank Age**	65	**Tank Installed Date**	06/15/1960	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	4461	**Spill Test Date**	09/24/2024	**Piping Installed Date**		**Tank Construction**	Lined Interior/Impressed Current	**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	09/24/2024	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	09/24/2024	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	2000	**ATG Test Date**	09/24/2024	**Line Tightness Test Date**	09/24/2024	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	09/24/2024			**ATG Type**	Gilbarco/TLS-350				

Facility Summary in Granite County in the City of Philipsburg

Location: PINTLER PETROLEUM INC
906 W Broadway Rd
Philipsburg, MT 59858 Granite

System Facility ID:56-13983

Facility Code: 30645
Last Inspected On: 09/07/2023
Operating Permit Renewal Date: 10/07/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Bill Antonioli;William Antonioli	**(406) 859-3164**	**phl3727@gmail.com**
Operator Contact:	William Antonioli	**(406) 859-3164**	**phl3727@gmail.com**

Owner/Operator: Bill Antonioli (406) 859-3164

Owner/Operator: William Antonioli (406) 859-3164

William Antonioli, UST Class A Operator phl3727@gmail.com

William Antonioli, UST Class B Operator phl3727@gmail.com

Tank Number	S1	**Tank Age**	25	**Tank Installed Date**	09/01/2000	**Tank Material Construction**	Unknown	**Piping Material**	Flexible Plastic	**Overfill Types**	
Tag Number	4215	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	Yes
Status	**Currently in Use**	**MLLD Test Date**	09/07/2023	**Sump Tightness Test Date**	09/30/2020	**Catastrophic L.D. Type 3.0**	Continuous Interstitial Monitoring;Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	09/07/2023	**Line Tightness Test Date**	05/04/2021	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	S2	**Tank Age**	25	**Tank Installed Date**	09/01/2000	**Tank Material Construction**	Unknown	**Piping Material**	Flexible Plastic	**Overfill Types**	
Tag Number	4216	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	Yes
Status	**Currently in Use**	**MLLD Test Date**	09/07/2023	**Sump Tightness Test Date**	09/30/2020	**Catastrophic L.D. Type 3.0**	Continuous Interstitial Monitoring;Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No

Capacity	12000	**ATG Test Date**	09/07/2023	**Line Tightness Test Date**	09/07/2023	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	S3	**Tank Age**	25	**Tank Installed Date**	09/01/2000	**Tank Material Construction**	Unknown	**Piping Material**	Flexible Plastic	**Overfill Types**	
Tag Number	4217	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	Yes
Status	**Currently in Use**	**MLLD Test Date**	09/07/2023	**Sump Tightness Test Date**	09/30/2020	**Catastrophic L.D. Type 3.0**	Continuous Interstitial Monitoring;Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	20000	**ATG Test Date**	09/07/2023	**Line Tightness Test Date**	09/07/2023	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	S4	**Tank Age**	25	**Tank Installed Date**	09/01/2000	**Tank Material Construction**	Unknown	**Piping Material**	Flexible Plastic	**Overfill Types**	
Tag Number	4218	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	Yes
Status	**Currently in Use**	**MLLD Test Date**	09/07/2023	**Sump Tightness Test Date**	09/30/2020	**Catastrophic L.D. Type 3.0**	Continuous Interstitial Monitoring;Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	24000	**ATG Test Date**	09/07/2023	**Line Tightness Test Date**	09/07/2023	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					

Facility Summary in Granite County in the City of Philipsburg

Location: SUNSHINE STATION 417
3830 MT Hwy 1
Philipsburg, MT 59858-9748 Granite

System Facility ID:20-05771

Facility Code: 22120
Last Inspected On: 10/17/2023
Operating Permit Renewal Date: 10/17/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: JTCD ENTERPRISES, INC **(406) 544-4676**

Operator Contact: Aaron Bay;John Monahan;Randy Livingston **(406) 396-7578;(406) 544-4676** **aaron.bay@askallegiance.com;jmonahan@hi-noon.com**

Owner/Operator: JTCD ENTERPRISES, INC (406) 544-4676

Aaron Bay, UST Class A Operator	aaron.bay@askallegiance.com
Aaron Bay, UST Class B Global Operator	aaron.bay@askallegiance.com
Aaron Bay, UST Class B Operator	aaron.bay@askallegiance.com
Bill Dirkes, UST Class B Global Operator	
John Monahan, UST Class A Operator	jmonahan@hi-noon.com
John Monahan, UST Class B Global Operator	jmonahan@hi-noon.com
Randy Livingston, UST Class A Operator	
Randy Livingston, UST Class B Global Operator	

Tank Number	01	**Tank Age**	42	**Tank Installed Date**	04/27/1983	**Tank Material Construction**	Bare Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	1313	**Spill Test Date**	04/10/2024	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	06/04/2024	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	10/17/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	12/15/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	02	**Tank Age**	42	**Tank Installed Date**	04/27/1983	**Tank Material Construction**	Bare Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	4516	**Spill Test Date**	12/01/2021	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current

Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	12/15/2022	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	10/17/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	12/15/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	03	**Tank Age**	26	**Tank Installed Date**	09/20/1999	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	4517	**Spill Test Date**	04/10/2024	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	06/04/2024	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	10/17/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	12/15/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Hill County in the City of Havre

Location: BN HAVRE RAIL YARD
235 Main St
Havre, MT 59501-3523 Hill

System Facility ID:21-09548

Facility Code: 22426
Last Inspected On: 05/26/2023
Operating Permit Renewal Date: 08/26/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: BNSF Railway Company Fort Worth **(817) 333-2000**

Operator Contact: Robert Mantle;BNSF Railway Havre;Tavita Masau;Tim Christianson **(406) 265-0483;(406) 939-4254;(773) 600-2860** **bobmantle@hotmail.com;tmasau@icloud.com**

Owner/Operator: BNSF Railway Company Fort Worth (817) 333-2000

Doran Loftus, UST Class B Global Operator	doran.loftus@aecom.com
Doran Loftus, UST Class B Global Operator	doran.loftus@aecom.com
Dwayne Whitaker, UST Class B Operator	
Ed Hill, UST Class B Operator	edward.hill@bnsf.com
Ed Hill, UST Class B Operator	edward.hill@bnsf.com
Robert Mantle, UST Class A Operator	bobmantle@hotmail.com
Tavita Masau, UST Class A Operator	tmasau@icloud.com
Tavita Masau, UST Class A Operator	tmasau@icloud.com
Tavita Masau, UST Class B Global Operator	tmasau@icloud.com
Tavita Masau, UST Class B Global Operator	tmasau@icloud.com
Tim Christianson, UST Class A Operator	
Tom Swinney, UST Class B Operator	thomas.swinney@bnsf.com
Tom Swinney, UST Class B Operator	thomas.swinney@bnsf.com

Tank Number	S23	**Tank Age**	21	**Tank Installed Date**	01/22/2004	**Tank Material Construction**	Concrete	**Piping Material**	Steel - Terminal Piping	**Overfill Types**	
Tag Number	4877	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	Yes
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Pressurized	**CP Met Types**	
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	11/02/2023	**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**	Terminal Piping Annual Line Test	**Vapor Recovery**	No
Capacity	640000	**ATG Test Date**	05/23/2023	**Line Tightness Test Date**	08/02/2019	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	S24	**Tank Age**	21	**Tank Installed Date**	01/22/2004	**Tank Material Construction**	Concrete	**Piping Material**	Steel - Terminal Piping	**Overfill Types**	

Tag Number	4878	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	Yes
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Pressurized	**CP Met Types**	
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	11/02/2023	**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**	Terminal Piping Annual Line Test	**Vapor Recovery**	No
Capacity	640000	**ATG Test Date**	05/23/2023	**Line Tightness Test Date**	08/02/2019	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	22	**Tank Age**	32	**Tank Installed Date**	06/21/1993	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	No Piping	**Overfill Types**	High Level Alarm
Tag Number	506	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Not Listed	**CP Met Types**	Impressed Current
Product	Oil, Waste	**PLLD Test Date**		**Tank/Piping CP Test Date**	11/02/2023	**Primary Tank Leak Detection**	Manual Interstitial Monitoring	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	20000	**ATG Test Date**	05/05/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					

Facility Summary in Hill County in the City of Havre

Location: CIRCLE K STORE 2746272
200 1st St W
Havre, MT 59501 Hill

System Facility ID:21-08068

Facility Code: 22350
Last Inspected On: 05/23/2023
Operating Permit Renewal Date: 12/04/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Rocky Mountain Oil LLC	**(602) 728-8000**	**NT-ESS@Circlek.com**
Operator Contact:	Veronica Rivera		**ESS-WestCoast@circlek.com**

Owner/Operator:	Rocky Mountain Oil LLC	(602) 728-8000	NT-ESS@Circlek.com
	Brad Lee, UST Class B Global Operator		brad.lee@holidaycompanies.com
	Brad Lee, UST Class B Global Operator		brad.lee@holidaycompanies.com
	Jeff Reed, UST Class B Global Operator		jeff.reed@holidaycompanies.com
	Jeff Reed, UST Class B Global Operator		jeff.reed@holidaycompanies.com
	Veronica Rivera, UST Class A Operator		ESS-WestCoast@circlek.com
	Veronica Rivera, UST Class A Operator		ESS-WestCoast@circlek.com

Tank Number	01	**Tank Age**	0	**Tank Installed Date**		**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	3013	**Spill Test Date**		**Piping Installed Date**	11/24/2020	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	05/23/2023	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**	09/09/2020	**Tank/Piping CP Test Date**	09/06/2022	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	Yes
Capacity	12000	**ATG Test Date**	05/23/2023	**Line Tightness Test Date**	11/12/2020	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date	09/07/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	02	**Tank Age**	40	**Tank Installed Date**	10/01/1985	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	3014	**Spill Test Date**		**Piping Installed Date**	11/24/2020	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	09/07/2022	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**	09/09/2020	**Tank/Piping CP Test Date**	09/06/2022	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	Yes

Capacity	12000	**ATG Test Date**	05/23/2023	**Line Tightness Test Date**	11/17/2020	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date	09/08/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	03	**Tank Age**	40	**Tank Installed Date**	10/01/1985	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	3015	**Spill Test Date**		**Piping Installed Date**	11/24/2020	**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	05/23/2023	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**	09/09/2020	**Tank/Piping CP Test Date**	09/06/2022	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	Yes
Capacity	10000	**ATG Test Date**	05/23/2023	**Line Tightness Test Date**	11/10/2020	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date	09/07/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	04	**Tank Age**	40	**Tank Installed Date**	10/01/1985	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	3016	**Spill Test Date**		**Piping Installed Date**	11/24/2020	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	05/23/2023	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Diesel	**PLLD Test Date**	09/09/2020	**Tank/Piping CP Test Date**	09/06/2022	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	05/23/2023	**Line Tightness Test Date**	11/11/2020	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date	09/07/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Hill County in the City of Havre

Location: EMPORIUM FOOD AND FUEL
1415 1st St
Havre, MT 59501 Hill

System Facility ID:21-12763

Facility Code: 22461
Last Inspected On: 03/18/2025
Operating Permit Renewal Date: 06/30/2028

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Duck Inn Inc		**duckinninc@gmail.com**
Operator Contact:	Joseph Hopf;Marie Hawkins;Duck Inn Inc	**(406) 344-2966**	**gpgekk1@yahoo.com;duckinninc@gmail.com;jhopf2016@gmail.com**

Owner/Operator: Duck Inn Inc — duckinninc@gmail.com

Cindy Lee, UST Class B Operator	emporiumstationhavre@gmail.com
Dustin Rolfe, UST Class B Operator	dustinrolfe81@gmail.com
Joseph Hopf, UST Class A Operator	jhopf2016@gmail.com
Joseph Hopf, UST Class B Operator	jhopf2016@gmail.com
Marie Hawkins, UST Class A Operator	duckinninc@gmail.com
Marie Hawkins, UST Class B Operator	duckinninc@gmail.com

Tank Number	01	**Tank Age**	33	**Tank Installed Date**	08/01/1992	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	2971	**Spill Test Date**	03/15/2025	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	05/12/2021	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	05/15/2024	**Line Tightness Test Date**	01/06/2025	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	05/15/2024			**ATG Type**	Franklin Fueling Systems/EVO 600				
Tank Number	02	**Tank Age**	33	**Tank Installed Date**	08/01/1992	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	2972	**Spill Test Date**	03/15/2025	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	05/12/2021	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	05/15/2024	**Line Tightness Test Date**	03/21/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No

		Overfill Test Date	05/15/2024			**ATG Type**	Franklin Fueling Systems/EVO 600				
Tank Number	03	**Tank Age**	33	**Tank Installed Date**	08/01/1992	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	2973	**Spill Test Date**	03/15/2025	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	05/12/2021	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**	05/15/2024	**Line Tightness Test Date**	01/03/2025	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	05/15/2024			**ATG Type**	Franklin Fueling Systems/EVO 600				
Tank Number	04	**Tank Age**	33	**Tank Installed Date**	08/01/1992	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	2974	**Spill Test Date**	03/15/2025	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	05/12/2021	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**	05/15/2024	**Line Tightness Test Date**	01/09/2025	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	05/15/2024			**ATG Type**	Franklin Fueling Systems/EVO 600				

Facility Summary in Hill County in the City of Havre

Location: EZZIES CENEX CARDTROL
33 1st St
Havre, MT 59501 Hill

System Facility ID:21-07467

Facility Code: 22339
Last Inspected On: 09/05/2023
Operating Permit Renewal Date: 09/05/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Ezzies Wholesale Inc **bill@ezzies.com**

Operator Contact: Conor Moran;Ezzies Wholesale Inc **conor@ezzies.com;bill@ezzies.com**

Owner/Operator: Ezzies Wholesale Inc bill@ezzies.com

Conor Moran, UST Class A Operator bill@ezzies.com
Jimmy Kimberling, UST Class B Operator havre@ezzies.com
Jimmy Kimberling, UST Class B Operator havre@ezzies.com

Tank Number	08	**Tank Age**	28	**Tank Installed Date**	06/01/1997	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	538	**Spill Test Date**	05/23/2023	**Piping Installed Date**	08/27/2008	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	05/12/2020	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	05/23/2023	**Line Tightness Test Date**	05/23/2023	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	05/23/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	09	**Tank Age**	28	**Tank Installed Date**	06/01/1997	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	539	**Spill Test Date**	05/23/2023	**Piping Installed Date**	08/27/2008	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	05/12/2020	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	05/23/2023	**Line Tightness Test Date**	05/23/2023	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No

		Overfill Test Date	05/23/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	10	**Tank Age**	28	**Tank Installed Date**	06/01/1997	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	540	**Spill Test Date**	05/23/2023	**Piping Installed Date**	08/27/2008	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	05/12/2020	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	05/23/2023	**Line Tightness Test Date**	05/23/2023	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	05/23/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	11	**Tank Age**	28	**Tank Installed Date**	06/28/1997	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	541	**Spill Test Date**	05/23/2023	**Piping Installed Date**	08/27/2008	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	05/12/2020	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**	05/23/2023	**Line Tightness Test Date**	05/23/2023	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	05/23/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	12	**Tank Age**	28	**Tank Installed Date**	06/28/1997	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	542	**Spill Test Date**	05/23/2023	**Piping Installed Date**	08/27/2008	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	05/12/2020	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**	05/23/2023	**Line Tightness Test Date**	05/23/2023	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	05/23/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	13	**Tank Age**	28	**Tank Installed Date**	06/01/1997	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm

Tag Number	543	**Spill Test Date**	05/23/2023	**Piping Installed Date**	08/27/2008	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	05/12/2020	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	05/23/2023	**Line Tightness Test Date**	05/23/2023	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	05/23/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Hill County in the City of Havre

Location: EZZIES WHOLESALE HAVRE
726 1st St W
Havre, MT 59501-3418 Hill

System Facility ID:21-12751

Facility Code: 22460
Last Inspected On: 03/18/2025
Operating Permit Renewal Date: 07/09/2028

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Ezzies Wholesale Inc **bill@ezzies.com**

Operator Contact: Conor Moran;Ezzies Wholesale Inc **conor@ezzies.com;bill@ezzies.com**

Owner/Operator: Ezzies Wholesale Inc bill@ezzies.com

Conor Moran, UST Class A Operator bill@ezzies.com

Jimmy Kimberling, UST Class B Operator havre@ezzies.com

Tank Number	01	**Tank Age**	33	**Tank Installed Date**	07/01/1992	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	878	**Spill Test Date**	05/12/2021	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Single Walled	**AST**	No
Status	**Temporarily Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Solvents	**PLLD Test Date**		**Tank/Piping CP Test Date**	03/18/2025	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	05/12/2021	**Line Tightness Test Date**	03/21/2013	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	05/12/2021			**ATG Type**	Gilbarco/EMC				
Tank Number	02	**Tank Age**	33	**Tank Installed Date**	07/01/1992	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	879	**Spill Test Date**	05/15/2024	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Single Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**	05/15/2024	**Tank/Piping CP Test Date**	03/18/2025	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	05/15/2024	**Line Tightness Test Date**	08/29/2007	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	05/15/2024			**ATG Type**	Gilbarco/EMC				
Tank Number	03	**Tank Age**	33	**Tank Installed Date**	07/01/1992	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	880	**Spill Test Date**	05/15/2024	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Single Walled	**AST**	No

Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**	05/15/2024	**Tank/Piping CP Test Date**	03/18/2025	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	05/15/2024	**Line Tightness Test Date**	08/29/2007	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	05/15/2024			**ATG Type**	Gilbarco/EMC				
Tank Number	04	**Tank Age**	33	**Tank Installed Date**	07/01/1992	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	881	**Spill Test Date**	05/15/2024	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Single Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**	05/15/2024	**Tank/Piping CP Test Date**	03/18/2025	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	05/15/2024	**Line Tightness Test Date**	08/29/2007	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	05/15/2024			**ATG Type**	Gilbarco/EMC				
Tank Number	05	**Tank Age**	33	**Tank Installed Date**	07/01/1992	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	882	**Spill Test Date**	05/15/2024	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Single Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**	05/15/2024	**Tank/Piping CP Test Date**	03/18/2025	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	05/15/2024	**Line Tightness Test Date**	08/29/2007	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	05/15/2024			**ATG Type**	Gilbarco/EMC				
Tank Number	06	**Tank Age**	33	**Tank Installed Date**	07/01/1992	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	883	**Spill Test Date**	05/15/2024	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Single Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**	05/15/2024	**Tank/Piping CP Test Date**	03/18/2025	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	05/15/2024	**Line Tightness Test Date**	08/29/2007	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	05/15/2024			**ATG Type**	Gilbarco/EMC				
Tank Number	07	**Tank Age**	33	**Tank Installed Date**	07/01/1992	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm

Tag Number	884	**Spill Test Date**	05/15/2024	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Single Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**	05/15/2024	**Tank/Piping CP Test Date**	03/18/2025	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	05/15/2024	**Line Tightness Test Date**	08/29/2007	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	05/15/2024			**ATG Type**	Gilbarco/EMC				
Tank Number	08	**Tank Age**	33	**Tank Installed Date**	07/01/1992	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	885	**Spill Test Date**	05/15/2024	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Single Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**	05/15/2024	**Tank/Piping CP Test Date**	03/18/2025	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	05/15/2024	**Line Tightness Test Date**	08/29/2007	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	05/15/2024			**ATG Type**	Gilbarco/EMC				

Facility Summary in Hill County in the City of Havre

Location: HILL COUNTY JUSTICE CENTER
1450 2nd St W
Havre, MT 59501-3497 Hill

System Facility ID:56-13886

Facility Code: 30561
Last Inspected On: 09/04/2024
Operating Permit Renewal Date: 11/05/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Hill County Commissioners **(406) 265-5481**

Operator Contact: Daryl Anez;Joseph Smith;Richard Ricci **(406) 262-3467;(406) 945-1497** **anezd@hillcounty.us;ricci@co.hill.mt.us**

Owner/Operator: Hill County Commissioners (406) 265-5481

Daryl Anez, UST Class A Operator	anezd@hillcounty.us
Daryl Anez, UST Class B Global Operator	anezd@hillcounty.us
Daryl Anez, UST Class B Operator	anezd@hillcounty.us
Joseph Smith, UST Class A Operator	
Joseph Smith, UST Class B Operator	
Mike Winchell, UST Class B Global Operator	mike@lodestarlandandhome.com
Richard Ricci, UST Class A Operator	ricci@co.hill.mt.us
Richard Ricci, UST Class B Global Operator	ricci@co.hill.mt.us

Tank Number	S1	**Tank Age**	27	**Tank Installed Date**	07/20/1998	**Tank Material Construction**	Concrete	**Piping Material**	Steel	**Overfill Types**	
Tag Number	1377	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Secondary Containment Chase	**AST**	Yes
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Auto Dialer	**Piping Type**	U.S. Suction	**CP Met Types**	
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**	3-Year Line Tightness Test	**Vapor Recovery**	No
Capacity	2000	**ATG Test Date**		**Line Tightness Test Date**	09/04/2024	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date				**ATG Type**					

Facility Summary in Hill County in the City of Havre

Location: STROMBERGS SINCLAIR
1200 1st St
Havre, MT 59501-3802 Hill

System Facility ID:21-02166

Facility Code: 22209
Last Inspected On: 10/21/2022
Operating Permit Renewal Date: 12/12/2025

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Stromberg Sinclair	**(406) 265-3441**	**tolearly75@icloud.com**
Operator Contact:	Todd O'Leary	**(406) 262-3441**	**toleary75@icloud.com**

Owner/Operator:	Stromberg Sinclair	(406) 265-3441	tolearly75@icloud.com
	Todd O'Leary, UST Class A Operator		toleary75@icloud.com
	Todd O'Leary, UST Class A Operator		toleary75@icloud.com
	Todd O'Leary, UST Class B Operator		toleary75@icloud.com
	Todd O'Leary, UST Class B Operator		toleary75@icloud.com

Tank Number	08	**Tank Age**	26	**Tank Installed Date**	03/01/1999	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve
Tag Number	3965	**Spill Test Date**	10/17/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	04/30/2020	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	10/09/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date	10/17/2022			**ATG Type**	Gilbarco/EMC Basic				
Tank Number	09	**Tank Age**	26	**Tank Installed Date**	03/01/1999	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve
Tag Number	3966	**Spill Test Date**	10/17/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	04/30/2020	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	10/09/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date	10/17/2022			**ATG Type**	Gilbarco/EMC Basic				

Tank Number	10	**Tank Age**	26	**Tank Installed Date**	03/01/1999	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve
Tag Number	3967	**Spill Test Date**	10/17/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	04/30/2020	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	10/09/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date	10/17/2022			**ATG Type**	Gilbarco/EMC Basic				

Facility Summary in Hill County in the City of Havre

Location: TOWN PUMP HAVRE
136 1st St W
Havre, MT 59501 Hill

System Facility ID:21-08705

Facility Code: 22359
Last Inspected On: 02/27/2024
Operating Permit Renewal Date: 09/19/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Havre 1 Town Pump LLC	**(406) 497-6700**	**environmental@townpump.com**
Operator Contact:	Daniel Sampson;Trent Biggers		**andrew02@directv.net;Trentb@townpump.com**

Owner/Operator: Havre 1 Town Pump LLC (406) 497-6700 environmental@townpump.com

Daniel Sampson, UST Class A Operator	andrew02@directv.net
Daniel Sampson, UST Class A Operator	andrew02@directv.net
Daniel Sampson, UST Class B Global Operator	andrew02@directv.net
Daniel Sampson, UST Class B Global Operator	andrew02@directv.net
Trent Biggers, UST Class A Operator	Trentb@townpump.com
Trent Biggers, UST Class A Operator	Trentb@townpump.com
Trent Biggers, UST Class B Global Operator	Trentb@townpump.com
Trent Biggers, UST Class B Global Operator	Trentb@townpump.com

Tank Number	03	**Tank Age**	36	**Tank Installed Date**	11/15/1989	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	2472	**Spill Test Date**	07/26/2023	**Piping Installed Date**	07/25/2014	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	07/26/2023	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	02/27/2024	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	02/27/2024	**Line Tightness Test Date**	01/29/2015	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	07/26/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350				
Tank Number	04	**Tank Age**	36	**Tank Installed Date**	11/15/1989	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	2473	**Spill Test Date**	07/26/2023	**Piping Installed Date**	07/25/2014	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	07/26/2023	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible

Product	Gasoline	**PLLD Test Date**	02/27/2024	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	02/27/2024	**Line Tightness Test Date**	01/29/2015	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	07/26/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350				
Tank Number	05	**Tank Age**	36	**Tank Installed Date**	11/15/1989	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	2474	**Spill Test Date**	07/26/2023	**Piping Installed Date**	07/25/2014	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	07/26/2023	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	02/27/2024	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	02/27/2024	**Line Tightness Test Date**	01/29/2015	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	07/26/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350				
Tank Number	06	**Tank Age**	36	**Tank Installed Date**	11/15/1989	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	2475	**Spill Test Date**	07/26/2023	**Piping Installed Date**	07/25/2014	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	07/26/2023	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	02/27/2024	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	02/27/2024	**Line Tightness Test Date**	01/29/2015	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	07/26/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350				
Tank Number	07	**Tank Age**	11	**Tank Installed Date**	08/01/2014	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	5510	**Spill Test Date**	07/26/2023	**Piping Installed Date**	07/25/2014	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	07/26/2023	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	02/27/2024	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No

Capacity	6000	**ATG Test Date**	02/27/2024	**Line Tightness Test Date**	01/29/2015	**Secondary Tank Leak Detection**	Statistical Inventory Reconciliation	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	Yes
		Overfill Test Date	07/26/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350				
Tank Number	08	**Tank Age**	11	**Tank Installed Date**	08/01/2014	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	5514	**Spill Test Date**	07/26/2023	**Piping Installed Date**	07/25/2014	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	07/26/2023	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel, Dyed	**PLLD Test Date**	02/27/2024	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	15000	**ATG Test Date**	02/27/2024	**Line Tightness Test Date**	01/29/2015	**Secondary Tank Leak Detection**	Statistical Inventory Reconciliation	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	Yes
		Overfill Test Date	08/07/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350				
Tank Number	09	**Tank Age**	11	**Tank Installed Date**	08/01/2014	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	5515	**Spill Test Date**		**Piping Installed Date**	07/25/2014	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Other**	**MLLD Test Date**		**Sump Tightness Test Date**	02/04/2015	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	DEF (Not Regulated)	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date				**ATG Type**					

Facility Summary in Hill County in the City of Havre

Location: ZIP TRIP 48
911 11th St W
Havre, MT 59501 Hill

System Facility ID:21-00089

Facility Code: 22169
Last Inspected On: 06/24/2024
Operating Permit Renewal Date: 06/27/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	CHS Inc Spokane Valley	**(509) 535-7701**	**Donald.Widdicombe@chsinc.com**
Operator Contact:	Jim Alford;Sean Hurley	**(509) 535-7701;(509) 536-7418**	**jim.alford@chsinc.com;sean.hurley@chsinc.com**

Owner/Operator: CHS Inc Spokane Valley (509) 535-7701 Donald.Widdicombe@chsinc.com

Jim Alford, UST Class A Operator	jim.alford@chsinc.com
Jim Alford, UST Class B Operator	jim.alford@chsinc.com
Luci Tuttle, UST Class B Operator	Lucinda.Tuttle@chsinc.com
Sean Hurley, UST Class A Operator	sean.hurley@chsinc.com
Travis Weber, UST Class B Operator	travis.weber3@chsinc.com

Tank Number	03	**Tank Age**	14	**Tank Installed Date**	10/01/2011	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve
Tag Number	5341	**Spill Test Date**	08/08/2024	**Piping Installed Date**	10/11/2011	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	06/24/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	06/24/2024	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	15000	**ATG Test Date**	06/24/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	08/08/2024			**ATG Type**	Gilbarco/EMC Basic;Gilbarco-Veeder Root/EMC Basic				
Tank Number	04	**Tank Age**	14	**Tank Installed Date**	10/01/2011	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve
Tag Number	5342	**Spill Test Date**	06/24/2024	**Piping Installed Date**	10/11/2011	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	06/24/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	06/24/2024	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No

Capacity	10000	**ATG Test Date**	06/24/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	08/08/2024			**ATG Type**	Gilbarco/EMC Basic;Gilbarco-Veeder Root/EMC Basic				
Tank Number	05	**Tank Age**	14	**Tank Installed Date**	10/01/2011	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve
Tag Number	5343	**Spill Test Date**	06/24/2024	**Piping Installed Date**	10/11/2011	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	06/24/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	06/24/2024	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**	06/24/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	08/08/2024			**ATG Type**	Gilbarco/EMC Basic;Gilbarco-Veeder Root/EMC Basic				

Facility Summary in Hill County in the City of Havre

Location: ZIP TRIP 49
1004 1st St
Havre, MT 59501 Hill

System Facility ID:21-00103

Facility Code: 22170
Last Inspected On: 11/03/2022
Operating Permit Renewal Date: 12/04/2025

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	CHS Inc Spokane Valley	**(509) 535-7701**	**Donald.Widdicombe@chsinc.com**
Operator Contact:	Jim Alford;Sean Hurley	**(509) 535-7701;(509) 536-7418**	**jim.alford@chsinc.com;sean.hurley@chsinc.com**

Owner/Operator:	CHS Inc Spokane Valley	(509) 535-7701	Donald.Widdicombe@chsinc.com
	Jim Alford, UST Class A Operator		jim.alford@chsinc.com
	Jim Alford, UST Class A Operator		jim.alford@chsinc.com
	Jim Alford, UST Class B Operator		jim.alford@chsinc.com
	Jim Alford, UST Class B Operator		jim.alford@chsinc.com
	Luci Tuttle, UST Class B Operator		Lucinda.Tuttle@chsinc.com
	Sean Hurley, UST Class A Operator		sean.hurley@chsinc.com
	Sean Hurley, UST Class A Operator		sean.hurley@chsinc.com
	Travis Weber, UST Class B Operator		Donald.Widdicombe@chsinc.com

Tank Number	04	**Tank Age**	12	**Tank Installed Date**	05/01/2013	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	5405	**Spill Test Date**	01/05/2023	**Piping Installed Date**	11/27/2012	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	07/06/2020	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	07/28/2022	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	07/28/2022	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	01/05/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350;Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	05	**Tank Age**	12	**Tank Installed Date**	05/01/2013	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	5406	**Spill Test Date**	07/06/2020	**Piping Installed Date**	11/27/2012	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	07/06/2020	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible

Product	Gasoline	**PLLD Test Date**	07/28/2022	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**	07/28/2022	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	11/03/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350;Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	06	**Tank Age**	12	**Tank Installed Date**	05/01/2013	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	5407	**Spill Test Date**	01/05/2023	**Piping Installed Date**	11/27/2012	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	07/06/2020	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	07/28/2022	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	07/28/2022	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	01/05/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350;Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Hill County in the City of Hingham

Location: HINGHAM MOTORS LLC
Central Ave & 1st St N
Hingham, MT 59528 Hill

System Facility ID:21-00783

Facility Code: 22185
Last Inspected On: 03/31/2017
Operating Permit Renewal Date: 05/14/2020

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: D's Automotive & Company **(406) 468-5457**

Operator Contact: Robert Spicher **(406) 390-3171**

Owner/Operator: D's Automotive & Company (406) 468-5457

Robert Spicher, UST Class A Operator

Robert Spicher, UST Class B Global Operator

Tank Number	S06	**Tank Age**	30	**Tank Installed Date**	07/25/1995	**Tank Material Construction**	Unknown	**Piping Material**	Flexible Plastic	**Overfill Types**	
Tag Number	1383	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	Yes
Status	**Temporarily Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**	05/13/2014	**Catastrophic L.D. Type 3.0**	Continuous Interstitial Monitoring	**Piping Type**	Pressurized	**CP Met Types**	
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Deferred	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	S07	**Tank Age**	27	**Tank Installed Date**	10/01/1998	**Tank Material Construction**	Unknown	**Piping Material**	Flexible Plastic	**Overfill Types**	
Tag Number	1384	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	Yes
Status	**Temporarily Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**	05/13/2014	**Catastrophic L.D. Type 3.0**	Continuous Interstitial Monitoring	**Piping Type**	Pressurized	**CP Met Types**	
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Deferred	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					

Tank Number	S08	**Tank Age**	27	**Tank Installed Date**	10/01/1998	**Tank Material Construction**	Unknown	**Piping Material**	Flexible Plastic	**Overfill Types**	
Tag Number	1385	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	Yes
Status	**Temporarily Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**	05/13/2014	**Catastrophic L.D. Type 3.0**	Continuous Interstitial Monitoring	**Piping Type**	Pressurized	**CP Met Types**	
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Deferred	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	S09	**Tank Age**	27	**Tank Installed Date**	10/01/1998	**Tank Material Construction**	Unknown	**Piping Material**	Flexible Plastic	**Overfill Types**	
Tag Number	1386	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	Yes
Status	**Temporarily Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**	05/13/2014	**Catastrophic L.D. Type 3.0**	Continuous Interstitial Monitoring	**Piping Type**	Pressurized	**CP Met Types**	
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Deferred	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					

Facility Summary in Hill County in the City of Inverness

Location: FRASER OIL INC INVERNESS
125 Main St
Inverness, MT 59530 Hill

System Facility ID:21-07327

Facility Code: 22337
Last Inspected On: 11/16/2023
Operating Permit Renewal Date: 03/27/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Fraser Oil Inc

Operator Contact: Cory Fraser **frasfuel@yahoo.com**

Owner/Operator: Fraser Oil Inc

Cory Fraser, UST Class A Operator frasfuel@yahoo.com
Cory Fraser, UST Class B Operator frasfuel@yahoo.com

Tank Number	04	**Tank Age**	33	**Tank Installed Date**	10/15/1992	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	1120	**Spill Test Date**	11/16/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	11/14/2022	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	1000	**ATG Test Date**	11/16/2023	**Line Tightness Test Date**	12/11/2008	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	11/16/2022			**ATG Type**	Gilbarco/EMC Basic				
Tank Number	05	**Tank Age**	33	**Tank Installed Date**	10/15/1992	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	1121	**Spill Test Date**	11/16/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	11/14/2022	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	1000	**ATG Test Date**	11/16/2023	**Line Tightness Test Date**	12/11/2008	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	11/16/2022			**ATG Type**	Gilbarco/EMC Basic				
Tank Number	06	**Tank Age**	33	**Tank Installed Date**	10/15/1992	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	1122	**Spill Test Date**	11/16/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No

Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	11/14/2022	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	1000	**ATG Test Date**	11/16/2023	**Line Tightness Test Date**	12/11/2008	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	11/16/2022			**ATG Type**	Gilbarco/EMC Basic				

Facility Summary in Hill County in the City of Rudyard

Location: C & H Tires Inc
103 Main St
Rudyard, MT 59540 Hill

System Facility ID:21-02475

Facility Code: 22212
Last Inspected On: 03/30/2022
Operating Permit Renewal Date: 09/24/2025

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	C & H Tires Inc		**dunlop_12345@yahoo.com**
Operator Contact:	Rick Pester;Robert Toner	**(406) 355-4131**	**toners@itstriangle.com;toners@mtintouch.net**

Owner/Operator: C & H Tires Inc — dunlop_12345@yahoo.com

Rick Pester, UST Class A Operator	toners@mtintouch.net
Rick Pester, UST Class A Operator	toners@mtintouch.net
Rick Pester, UST Class B Operator	toners@mtintouch.net
Rick Pester, UST Class B Operator	toners@mtintouch.net
Robert Toner, UST Class A Operator	toners@itstriangle.com
Robert Toner, UST Class A Operator	toners@itstriangle.com

Tank Number	05	**Tank Age**	28	**Tank Installed Date**	11/01/1997	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	2108	**Spill Test Date**	03/30/2021	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	04/14/2016	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.1	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	2000	**ATG Test Date**	03/30/2022	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	05/11/2022			**ATG Type**	Franklin Fueling Systems/EVO 600				
Tank Number	06	**Tank Age**	28	**Tank Installed Date**	11/01/1997	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	2109	**Spill Test Date**	03/30/2021	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	04/14/2016	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.1	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	2000	**ATG Test Date**	03/30/2022	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No

		Overfill Test Date	05/11/2022			**ATG Type**	Franklin Fueling Systems/EVO 600				

Facility Summary in Hill County in the City of Rudyard

Location: FARMERS UNION OIL CO RUDYARD
1 Main St
Rudyard, MT 59540 Hill

System Facility ID:21-03509

Facility Code: 22239
Last Inspected On: 09/07/2022
Operating Permit Renewal Date: 09/28/2025

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Farmers Union Oil Co Rudyard	**(406) 355-4543**	**farmersunionoilrudyard@yahoo.com**
Operator Contact:	Cory Tollefson;Farmers Union Oil Co Rudyard	**(406) 443-0382;(406) 355-4543**	**farmersunionoilrudyard@yahoo.com;farmersunionoilrudyard@yahoo.com**

Owner/Operator: Farmers Union Oil Co Rudyard (406) 355-4543 farmersunionoilrudyard@yahoo.com

Cory Tollefson, UST Class A Operator farmersunionoilrudyard@yahoo.com

Cory Tollefson, UST Class B Global Operator farmersunionoilrudyard@yahoo.com

Tank Number	S4	**Tank Age**	59	**Tank Installed Date**	04/23/1966	**Tank Material Construction**	Bare Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	
Tag Number	947	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	Yes
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	01/10/2023	**Catastrophic L.D. Type 3.0**	Continuous Interstitial Monitoring	**Piping Type**	Pressurized	**CP Met Types**	
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	2000	**ATG Test Date**	09/07/2022	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	S5	**Tank Age**	59	**Tank Installed Date**	04/23/1966	**Tank Material Construction**	Bare Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	
Tag Number	948	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	Yes
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	01/10/2023	**Catastrophic L.D. Type 3.0**	Continuous Interstitial Monitoring	**Piping Type**	Pressurized	**CP Met Types**	
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	09/07/2022	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					

Tank Number	S6	**Tank Age**	59	**Tank Installed Date**	04/23/1966	**Tank Material Construction**	Bare Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	
Tag Number	949	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	Yes
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	01/10/2023	**Catastrophic L.D. Type 3.0**	Continuous Interstitial Monitoring	**Piping Type**	Pressurized	**CP Met Types**	
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	5000	**ATG Test Date**	09/07/2022	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					

Facility Summary in Jefferson County in the City of Boulder

Location: HARLOWS SCHOOL BUS SERVICE INC BOULDER
101 Main St
Boulder, MT 59632 Jefferson

System Facility ID:22-12378

Facility Code: 22635
Last Inspected On: 02/03/2023
Operating Permit Renewal Date: 02/03/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	HJJ Properties LLC	**(701) 224-1767**	**jeremy.hageness@goharlows.com**
Operator Contact:	Hugh Taylor;Sandra Hays;Wesley Tangen	**(406) 225-3344;(406) 239-8845;(406) 293-8845**	**busservice@frontier.com;fireater71@hotmail.com;sandra.hays@goharlows.com**

Owner/Operator:	HJJ Properties LLC	(701) 224-1767	jeremy.hageness@goharlows.com
	Hugh Taylor, UST Class A Operator		fireater71@hotmail.com
	Hugh Taylor, UST Class A Operator		fireater71@hotmail.com
	Hugh Taylor, UST Class B Operator		fireater71@hotmail.com
	Hugh Taylor, UST Class B Operator		fireater71@hotmail.com
	Sandra Hays, UST Class A Operator		sandra.hays@goharlows.com
	Sandra Hays, UST Class A Operator		sandra.hays@goharlows.com
	Sandra Hays, UST Class B Operator		sandra.hays@goharlows.com
	Sandra Hays, UST Class B Operator		sandra.hays@goharlows.com
	Wesley Tangen, UST Class A Operator		busservice@frontier.com
	Wesley Tangen, UST Class A Operator		busservice@frontier.com
	Wesley Tangen, UST Class B Operator		busservice@frontier.com
	Wesley Tangen, UST Class B Operator		busservice@frontier.com

Tank Number	06	**Tank Age**	34	**Tank Installed Date**	10/01/1991	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	2710	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Temporarily Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	02/03/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.1;Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Not Listed	**Vapor Recovery**	No
Capacity	2000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	07	**Tank Age**	34	**Tank Installed Date**	10/01/1991	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm

Tag Number	2711	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Temporarily Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	02/03/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.1;Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Not Listed	**Vapor Recovery**	No
Capacity	2000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					

Facility Summary in Jefferson County in the City of Boulder

Location: TOWN PUMP INC BOULDER
703 N Main
Boulder, MT 59632 Jefferson

System Facility ID:22-08673

Facility Code: 22598
Last Inspected On: 04/30/2025
Operating Permit Renewal Date: 05/26/2024

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Boulder 1 Town Pump LLC	**(406) 497-6700**	**environmental@townpump.com**
Operator Contact:	Trent Biggers		**Trentb@townpump.com**

Owner/Operator:	Boulder 1 Town Pump LLC	(406) 497-6700	environmental@townpump.com
	Trent Biggers, UST Class A Operator		Trentb@townpump.com
	Trent Biggers, UST Class A Operator		Trentb@townpump.com
	Trent Biggers, UST Class B Global Operator		Trentb@townpump.com
	Trent Biggers, UST Class B Global Operator		Trentb@townpump.com

Tank Number	01	**Tank Age**	48	**Tank Installed Date**	05/10/1977	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve
Tag Number	2485	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**	05/24/2021	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**	05/24/2021	**Tank/Piping CP Test Date**	05/24/2021	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	24000	**ATG Test Date**		**Line Tightness Test Date**	09/26/2006	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/TLS-350				
Tank Number	02	**Tank Age**	48	**Tank Installed Date**	05/10/1977	**Tank Material Construction**	Bare Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve
Tag Number	2486	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**	05/24/2021	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Diesel	**PLLD Test Date**	05/24/2021	**Tank/Piping CP Test Date**	05/24/2021	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**		**Line Tightness Test Date**	09/26/2006	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No

		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/TLS-350				
Tank Number	03	**Tank Age**	48	**Tank Installed Date**	05/10/1977	**Tank Material Construction**	Bare Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve
Tag Number	2487	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**	05/24/2021	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**	05/24/2021	**Tank/Piping CP Test Date**	05/24/2021	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**		**Line Tightness Test Date**	09/26/2006	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/TLS-350				
Tank Number	04	**Tank Age**	36	**Tank Installed Date**	01/01/1989	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve
Tag Number	4477	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**	05/24/2021	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Diesel	**PLLD Test Date**	05/24/2021	**Tank/Piping CP Test Date**	05/24/2021	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	24000	**ATG Test Date**		**Line Tightness Test Date**	09/26/2006	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/TLS-350				
Tank Number	05	**Tank Age**	36	**Tank Installed Date**	05/10/1989	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve
Tag Number	4478	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**	05/24/2021	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Diesel	**PLLD Test Date**	05/24/2021	**Tank/Piping CP Test Date**	05/24/2021	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	18000	**ATG Test Date**		**Line Tightness Test Date**	09/26/2006	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/TLS-350				
Tank Number	06	**Tank Age**	24	**Tank Installed Date**	04/01/2001	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve

Tag Number	4479	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**	05/24/2021	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	05/24/2021	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	20000	**ATG Test Date**		**Line Tightness Test Date**	09/26/2006	**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/TLS-350				
Tank Number	07	**Tank Age**	24	**Tank Installed Date**	04/01/2001	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve
Tag Number	4480	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**	05/24/2021	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	05/24/2021	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**		**Line Tightness Test Date**	09/26/2006	**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/TLS-350				
Tank Number	08	**Tank Age**	3	**Tank Installed Date**	05/25/2022	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	6058	**Spill Test Date**	06/11/2024	**Piping Installed Date**	05/25/2022	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	06/11/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	04/30/2025	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	30000	**ATG Test Date**	04/30/2025	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Statistical Inventory Reconciliation	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	Yes
		Overfill Test Date	06/11/2024			**ATG Type**					
Tank Number	09	**Tank Age**	3	**Tank Installed Date**	05/25/2022	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	6059	**Spill Test Date**	06/11/2024	**Piping Installed Date**	05/25/2022	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	06/11/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible

Product	Diesel	**PLLD Test Date**	04/30/2025	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	04/30/2025	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Statistical Inventory Reconciliation	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	Yes
		Overfill Test Date	06/11/2024			**ATG Type**					
Tank Number	10	**Tank Age**	3	**Tank Installed Date**	05/25/2022	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	6060	**Spill Test Date**	06/11/2024	**Piping Installed Date**	05/25/2022	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	06/11/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel, Dyed	**PLLD Test Date**	04/30/2025	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	04/30/2025	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Statistical Inventory Reconciliation	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	Yes
		Overfill Test Date	06/11/2024			**ATG Type**					
Tank Number	11	**Tank Age**	3	**Tank Installed Date**	05/25/2022	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	6061	**Spill Test Date**	06/11/2024	**Piping Installed Date**	05/25/2022	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	06/11/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	DEF (Not Regulated)	**PLLD Test Date**	04/30/2025	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	04/30/2025	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	06/11/2024			**ATG Type**					
Tank Number	12	**Tank Age**	0	**Tank Installed Date**		**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	6062	**Spill Test Date**	06/11/2024	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	06/11/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	04/30/2025	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	15000	**ATG Test Date**	04/30/2025	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Statistical Inventory Reconciliation	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	Yes

		Overfill Test Date	06/11/2024			**ATG Type**					
Tank Number	13	**Tank Age**	0	**Tank Installed Date**		**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	6063	**Spill Test Date**	06/11/2024	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	06/11/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline, E10	**PLLD Test Date**	04/30/2025	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	Yes
Capacity	15000	**ATG Test Date**	04/30/2025	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Statistical Inventory Reconciliation	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	Yes
		Overfill Test Date	06/11/2024			**ATG Type**					
Tank Number	14	**Tank Age**	0	**Tank Installed Date**		**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	6064	**Spill Test Date**	06/11/2024	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	06/11/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	04/30/2025	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	Yes
Capacity	24000	**ATG Test Date**	04/30/2025	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Statistical Inventory Reconciliation	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	Yes
		Overfill Test Date	06/11/2024			**ATG Type**					
Tank Number	15	**Tank Age**	0	**Tank Installed Date**		**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	6065	**Spill Test Date**	06/11/2024	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	06/11/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	Yes
Capacity	6000	**ATG Test Date**	04/30/2025	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Statistical Inventory Reconciliation	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	Yes
		Overfill Test Date	06/11/2024			**ATG Type**					

Facility Summary in Jefferson County in the City of Cardwell

Location: CARDWELL GENERAL STORE and CAMPGROUND
770 MT Hwy 2 E
Cardwell, MT 59721-9615 Jefferson

System Facility ID:22-13424

Facility Code: 22656
Last Inspected On: 06/01/2023
Operating Permit Renewal Date: 09/03/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: CARDWELL CAMPGROUND LLC **(510) 754-8233**

Operator Contact: Curtis Perry **(406) 581-1526** **cardwellgeneralstore@gmail.com**

Owner/Operator: CARDWELL CAMPGROUND LLC (510) 754-8233

Curtis Perry, UST Class A Operator	cardwellgeneralstore@gmail.com
Curtis Perry, UST Class A Operator	cardwellgeneralstore@gmail.com
Curtis Perry, UST Class A Operator	cardwellgeneralstore@gmail.com
Curtis Perry, UST Class B Operator	cardwellgeneralstore@gmail.com
Curtis Perry, UST Class B Operator	cardwellgeneralstore@gmail.com
Curtis Perry, UST Class B Operator	cardwellgeneralstore@gmail.com

Tank Number	01	**Tank Age**	31	**Tank Installed Date**	04/01/1994	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	3193	**Spill Test Date**	06/01/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Single Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	03/13/2025	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	06/01/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	9000	**ATG Test Date**	03/13/2025	**Line Tightness Test Date**	03/13/2025	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	06/01/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	02	**Tank Age**	31	**Tank Installed Date**	04/01/1994	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	3194	**Spill Test Date**	06/01/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Single Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	03/13/2025	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	06/01/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	3000	**ATG Test Date**	03/13/2025	**Line Tightness Test Date**	03/13/2025	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No

		Overfill Test Date	06/01/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	03	**Tank Age**	31	**Tank Installed Date**	04/01/1994	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	3195	**Spill Test Date**	06/01/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Single Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	03/13/2025	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	06/01/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**	03/13/2025	**Line Tightness Test Date**	03/13/2025	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	06/01/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	04	**Tank Age**	31	**Tank Installed Date**	04/01/1994	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	3196	**Spill Test Date**	06/01/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Single Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	03/13/2025	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	06/01/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**	03/13/2025	**Line Tightness Test Date**	03/13/2025	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	06/01/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Jefferson County in the City of Clancy

Location: CLANCY STORE
10 E Clancy St
Clancy, MT 59634-9560 Jefferson

System Facility ID:22-02898

Facility Code: 22515
Last Inspected On: 08/05/2019
Operating Permit Renewal Date: 08/05/2022

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Clancy Store LLC **(406) 465-0540**

Operator Contact:

Owner/Operator: Clancy Store LLC (406) 465-0540

Tank Number	02	**Tank Age**	41	**Tank Installed Date**	04/26/1984	**Tank Material Construction**	Bare Steel	**Piping Material**	Steel	**Overfill Types**	High Level Alarm
Tag Number	3534	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Temporarily Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	08/05/2019	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	2000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	03	**Tank Age**	32	**Tank Installed Date**	04/10/1993	**Tank Material Construction**	Bare Steel	**Piping Material**	Steel	**Overfill Types**	High Level Alarm
Tag Number	4647	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Temporarily Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	08/05/2019	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	1000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					

Facility Summary in Jefferson County in the City of Montana City

Location: MONTANA CITY STORE LLC
1 Jackson Creek Rd
Montana City, MT 59634-9714 Jefferson

System Facility ID:22-01822

Facility Code: 22494
Last Inspected On: 05/09/2025
Operating Permit Renewal Date: 06/01/2028

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Montana City Properties Inc	**(406) 443-0150**	**Davidhunter@mt.net**
Operator Contact:	Heather Russell;Montana City Properties Inc;Shawn McFadden	**(406) 443-0150**	**heatherrussell404@gmail.com;Davidhunter@mt.net;mtcitystore@outlook.com**

Owner/Operator: Montana City Properties Inc		(406) 443-0150	Davidhunter@mt.net
	Heather Russell, UST Class A Operator		Davidhunter@mt.net
	Heather Russell, UST Class A Operator		Davidhunter@mt.net
	Heather Russell, UST Class B Global Operator		Davidhunter@mt.net
	Heather Russell, UST Class B Global Operator		Davidhunter@mt.net
	Shawn McFadden, UST Class A Operator		mtcitystore@outlook.com
	Shawn McFadden, UST Class A Operator		mtcitystore@outlook.com
	Shawn McFadden, UST Class B Global Operator		mtcitystore@outlook.com
	Shawn McFadden, UST Class B Global Operator		mtcitystore@outlook.com

Tank Number	05	**Tank Age**	37	**Tank Installed Date**	07/01/1988	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	1668	**Spill Test Date**	05/15/2024	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**	04/23/2025	**Tank/Piping CP Test Date**	04/23/2025	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	04/23/2025	**Line Tightness Test Date**	12/20/2021	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Manual Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	05/15/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	06	**Tank Age**	37	**Tank Installed Date**	07/01/1988	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	1669	**Spill Test Date**	05/15/2024	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**	04/23/2025	**Tank/Piping CP Test Date**	04/23/2025	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No

Capacity	10000	**ATG Test Date**	04/23/2025	**Line Tightness Test Date**	10/21/2021	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Manual Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	05/15/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	07	**Tank Age**	37	**Tank Installed Date**	07/01/1988	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	1670	**Spill Test Date**	05/15/2024	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**	04/23/2025	**Tank/Piping CP Test Date**	04/23/2025	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	04/23/2025	**Line Tightness Test Date**	10/25/2021	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	05/15/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Jefferson County in the City of Whitehall

Location: GOLDEN SUNLIGHT MINES INC UST
453 MT Hwy 2 E
Whitehall, MT 59759-8637 Jefferson

System Facility ID:22-04689

Facility Code: 22546
Last Inspected On: 06/20/2024
Operating Permit Renewal Date: 12/17/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Golden Sunlight Mines Inc

Operator Contact: Charles Buus;Darrell Scharf;Debby Horne;Jerry Muething;Rick Henderson | **(406) 287-2018;(406) 287-2035** | **cbuus@barrick.com;jmuething@barrick.com**

Owner/Operator: Golden Sunlight Mines Inc

Charles Buus, UST Class A Operator	cbuus@barrick.com
Charles Buus, UST Class B Operator	cbuus@barrick.com
Darrell Scharf, UST Class A Operator	
Dave Lawrence, UST Class B Global Operator	
Debby Horne, UST Class A Operator	
Donald Pippin, UST Class B Global Operator	
George Clements, UST Class B Global Operator	
Jerry Muething, UST Class A Operator	jmuething@barrick.com
Jerry Muething, UST Class B Operator	jmuething@barrick.com
John Clements, UST Class B Global Operator	
John Perigo, UST Class B Global Operator	
Joseph Dillon, UST Class B Global Operator	
Ray Panisko, UST Class B Global Operator	
Rick Henderson, UST Class A Operator	
Seth Slatter, UST Class B Operator	sslatter@barrick.com
Travis Nielsen, UST Class B Global Operator	

Tank Number	06	**Tank Age**	17	**Tank Installed Date**	06/12/2008	**Tank Material Construction**	Unknown	**Piping Material**	Flexible Plastic	**Overfill Types**	
Tag Number	5218	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	Yes
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	06/20/2024	**Catastrophic L.D. Type 3.0**	Continuous Interstitial Monitoring	**Piping Type**	Pressurized	**CP Met Types**	
Product	Oil, Motor	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	1000	**ATG Test Date**	06/20/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No

		Overfill Test Date				**ATG Type**					
Tank Number	07	**Tank Age**	17	**Tank Installed Date**	06/12/2008	**Tank Material Construction**	Unknown	**Piping Material**	Flexible Plastic	**Overfill Types**	
Tag Number	5219	**Spill Test Date**		**Piping Installed Date**	06/23/2009	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	Yes
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	06/20/2024	**Catastrophic L.D. Type 3.0**	Continuous Interstitial Monitoring	**Piping Type**	Pressurized	**CP Met Types**	
Product	Oil, Motor	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	1000	**ATG Test Date**	06/20/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	08	**Tank Age**	16	**Tank Installed Date**	06/12/2009	**Tank Material Construction**	Unknown	**Piping Material**	Flexible Plastic	**Overfill Types**	
Tag Number	5220	**Spill Test Date**		**Piping Installed Date**	06/23/2009	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	Yes
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	06/20/2024	**Catastrophic L.D. Type 3.0**	Continuous Interstitial Monitoring	**Piping Type**	Pressurized	**CP Met Types**	
Product	Oil, Motor	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	1500	**ATG Test Date**	06/20/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	09	**Tank Age**	17	**Tank Installed Date**	06/12/2008	**Tank Material Construction**	Unknown	**Piping Material**	Steel - Terminal Piping	**Overfill Types**	
Tag Number	5221	**Spill Test Date**		**Piping Installed Date**	06/23/2009	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	Yes
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	06/20/2024	**Catastrophic L.D. Type 3.0**	Continuous Interstitial Monitoring	**Piping Type**	Pressurized	**CP Met Types**	
Product	Oil, Waste	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	2000	**ATG Test Date**	06/20/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	10	**Tank Age**	17	**Tank Installed Date**	06/12/2008	**Tank Material Construction**	Unknown	**Piping Material**	Flexible Plastic	**Overfill Types**	
Tag Number	5222	**Spill Test Date**		**Piping Installed Date**	06/23/2009	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	Yes

Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	06/20/2024	**Catastrophic L.D. Type 3.0**	Continuous Interstitial Monitoring	**Piping Type**	Pressurized	**CP Met Types**	
Product	Oil, Motor	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	2000	**ATG Test Date**	06/20/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					

Facility Summary in Jefferson County in the City of Whitehall

Location: THRIFTWAY SUPER STOP 17
203 W Legion Ave
Whitehall, MT 59759 Jefferson

System Facility ID:22-00980

Facility Code: 22479
Last Inspected On: 10/30/2024
Operating Permit Renewal Date: 02/27/2028

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Sutey Oil Co Inc	**(406) 494-2305**	**ldsutey66@thriftwayss.com**
Operator Contact:	Louie Sutey;Sutey Oil Co Inc;Louis Sutey;Marlys Weyer;Timothy Mulligan	**(406) 287-3787;(406) 491-5808;(406) 491-5808;(406) 494-2305**	**ldsutey66@thriftwayss.com;ldsutey66@thriftwayss.com;ldsutey66@thriftwayss.com;thriftway17@thriftwayss.com;Tim.cornerstone@gmail.com**

Owner/Operator: Sutey Oil Co Inc (406) 494-2305 ldsutey66@thriftwayss.com

Louie Sutey, UST Class A Operator	ldsutey66@thriftwayss.com
Louie Sutey, UST Class B Operator	ldsutey66@thriftwayss.com
Louis Sutey, UST Class A Operator	ldsutey66@thriftwayss.com
Louis Sutey, UST Class B Global Operator	ldsutey66@thriftwayss.com
Marlys Weyer, UST Class A Operator	thriftway17@thriftwayss.com
Marlys Weyer, UST Class A Operator	thriftway17@thriftwayss.com
Marlys Weyer, UST Class B Operator	thriftway17@thriftwayss.com
Marlys Weyer, UST Class B Operator	thriftway17@thriftwayss.com
Timothy Mulligan, UST Class A Operator	Tim.cornerstone@gmail.com
Timothy Mulligan, UST Class A Operator	Tim.cornerstone@gmail.com
Timothy Mulligan, UST Class B Operator	Tim.cornerstone@gmail.com
Timothy Mulligan, UST Class B Operator	Tim.cornerstone@gmail.com

Tank Number	04	**Tank Age**	32	**Tank Installed Date**	10/15/1993	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	527	**Spill Test Date**	10/30/2024	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	04/11/2019	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**	04/02/2024	**Tank/Piping CP Test Date**	10/30/2024	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	04/02/2024	**Line Tightness Test Date**	04/11/2019	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	10/30/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	05	**Tank Age**	32	**Tank Installed Date**	10/15/1993	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve

Tag Number	528	**Spill Test Date**	10/30/2024	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	04/11/2019	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**	04/02/2024	**Tank/Piping CP Test Date**	10/30/2024	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**	04/02/2024	**Line Tightness Test Date**	04/11/2019	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	10/30/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	06	**Tank Age**	32	**Tank Installed Date**	10/15/1993	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	529	**Spill Test Date**	10/30/2024	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	04/11/2019	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**	04/02/2024	**Tank/Piping CP Test Date**	10/30/2024	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**	04/02/2024	**Line Tightness Test Date**	04/11/2019	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	10/30/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Jefferson County in the City of Whitehall

Location: TOWN PUMP INC WHITEHALL
417 N Whitehall St
Whitehall, MT 59759 Jefferson

System Facility ID:22-03645

Facility Code: 22528
Last Inspected On: 04/30/2025
Operating Permit Renewal Date: 11/01/2025

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Whitehall 1 Town Pump LLC	**(406) 497-6700**	**environmental@townpump.com**
Operator Contact:	Trent Biggers		**Trentb@townpump.com**

Owner/Operator:	Whitehall 1 Town Pump LLC	(406) 497-6700	environmental@townpump.com
	Trent Biggers, UST Class A Operator		Trentb@townpump.com
	Trent Biggers, UST Class A Operator		Trentb@townpump.com
	Trent Biggers, UST Class B Global Operator		Trentb@townpump.com
	Trent Biggers, UST Class B Global Operator		Trentb@townpump.com

Tank Number	01	**Tank Age**	57	**Tank Installed Date**	01/01/1968	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	2476	**Spill Test Date**	06/30/2021	**Piping Installed Date**		**Tank Construction**	Lined Interior/Impressed Current	**Piping Construction**	None	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Diesel	**PLLD Test Date**	06/15/2022	**Tank/Piping CP Test Date**	04/14/2021	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	20000	**ATG Test Date**	06/15/2022	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	06/30/2021			**ATG Type**	Gilbarco-Veeder Root/TLS-350				
Tank Number	02	**Tank Age**	57	**Tank Installed Date**	01/01/1968	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	2477	**Spill Test Date**	06/30/2021	**Piping Installed Date**		**Tank Construction**	Lined Interior/Impressed Current	**Piping Construction**	None	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Diesel	**PLLD Test Date**	06/15/2022	**Tank/Piping CP Test Date**	04/14/2021	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	06/15/2022	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No

		Overfill Test Date	06/30/2021			**ATG Type**	Gilbarco-Veeder Root/TLS-350				
Tank Number	03	**Tank Age**	47	**Tank Installed Date**	01/01/1978	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	2478	**Spill Test Date**	06/30/2021	**Piping Installed Date**		**Tank Construction**	Lined Interior/Impressed Current	**Piping Construction**	None	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**	06/15/2022	**Tank/Piping CP Test Date**	04/14/2021	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	06/15/2022	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	06/30/2021			**ATG Type**	Gilbarco-Veeder Root/TLS-350				
Tank Number	04	**Tank Age**	49	**Tank Installed Date**	01/01/1976	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	2479	**Spill Test Date**	06/30/2021	**Piping Installed Date**		**Tank Construction**	Lined Interior/Impressed Current	**Piping Construction**	None	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**	06/15/2022	**Tank/Piping CP Test Date**	04/14/2021	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	24000	**ATG Test Date**	06/15/2022	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	06/30/2021			**ATG Type**	Gilbarco-Veeder Root/TLS-350				
Tank Number	05	**Tank Age**	47	**Tank Installed Date**	01/01/1978	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	2480	**Spill Test Date**	06/30/2021	**Piping Installed Date**		**Tank Construction**	Lined Interior/Impressed Current	**Piping Construction**	None	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**	06/15/2022	**Tank/Piping CP Test Date**	04/14/2021	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	06/15/2022	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	04/15/2021			**ATG Type**	Gilbarco-Veeder Root/TLS-350				
Tank Number	06	**Tank Age**	47	**Tank Installed Date**	01/01/1978	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve

Tag Number	2481	**Spill Test Date**	06/30/2021	**Piping Installed Date**		**Tank Construction**	Lined Interior/Impressed Current	**Piping Construction**	None	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**	06/15/2022	**Tank/Piping CP Test Date**	04/14/2021	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	24000	**ATG Test Date**	06/15/2022	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	06/30/2021			**ATG Type**	Gilbarco-Veeder Root/TLS-350				
Tank Number	07	**Tank Age**	39	**Tank Installed Date**	01/01/1986	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	2482	**Spill Test Date**	06/30/2021	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**	06/15/2022	**Tank/Piping CP Test Date**	04/14/2021	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	06/15/2022	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	04/15/2021			**ATG Type**	Gilbarco-Veeder Root/TLS-350				
Tank Number	08	**Tank Age**	38	**Tank Installed Date**	01/01/1987	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	2483	**Spill Test Date**	06/30/2021	**Piping Installed Date**	12/23/2015	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**	06/15/2022	**Sump Tightness Test Date**	11/01/2022	**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	04/14/2021	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	24000	**ATG Test Date**	06/15/2022	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	No
		Overfill Test Date	04/15/2021			**ATG Type**	Gilbarco-Veeder Root/TLS-350				
Tank Number	09	**Tank Age**	38	**Tank Installed Date**	01/01/1987	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	2484	**Spill Test Date**	06/30/2021	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	04/14/2021	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**		**Vapor Recovery**	No

Capacity	24000	**ATG Test Date**	06/15/2022	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	06/30/2021			**ATG Type**	Gilbarco-Veeder Root/TLS-350				
Tank Number	10	**Tank Age**	25	**Tank Installed Date**	05/01/2000	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve
Tag Number	4198	**Spill Test Date**	06/30/2021	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**	06/15/2022	**Sump Tightness Test Date**	07/20/2018	**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	05/04/2012	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	06/15/2022	**Line Tightness Test Date**	12/23/2019	**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	04/15/2021			**ATG Type**	Gilbarco-Veeder Root/TLS-350				
Tank Number	11	**Tank Age**	25	**Tank Installed Date**	05/01/2000	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve
Tag Number	4199	**Spill Test Date**	06/30/2021	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**	06/15/2022	**Sump Tightness Test Date**	07/20/2018	**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel, Dyed	**PLLD Test Date**		**Tank/Piping CP Test Date**	05/04/2012	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	20000	**ATG Test Date**	06/15/2022	**Line Tightness Test Date**	12/23/2019	**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	04/15/2021			**ATG Type**	Gilbarco-Veeder Root/TLS-350				
Tank Number	12	**Tank Age**	10	**Tank Installed Date**	08/01/2015	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Positive Shutoff
Tag Number	5598	**Spill Test Date**		**Piping Installed Date**	12/23/2015	**Tank Construction**	Double-Walled	**Piping Construction**	None	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Continuous Interstitial Monitoring	**Piping Type**	Pressurized	**CP Met Types**	
Product	DEF (Not Regulated)	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No

Capacity	20000	**ATG Test Date**		**Line Tightness Test Date**	12/23/2015	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring;Not Listed	**Energy Act**	Yes
		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	13	**Tank Age**	2	**Tank Installed Date**	05/23/2023	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	
Tag Number	6106	**Spill Test Date**	05/08/2024	**Piping Installed Date**	05/23/2023	**Tank Construction**		**Piping Construction**		**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	05/08/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Diesel	**PLLD Test Date**	05/08/2024	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	22000	**ATG Test Date**	05/08/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	05/08/2024			**ATG Type**					
Tank Number	14	**Tank Age**	2	**Tank Installed Date**	05/23/2023	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	
Tag Number	6107	**Spill Test Date**	05/08/2024	**Piping Installed Date**	05/23/2023	**Tank Construction**		**Piping Construction**		**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	05/08/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Gasoline	**PLLD Test Date**	05/08/2024	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	Yes
Capacity	8000	**ATG Test Date**	05/08/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	05/08/2024			**ATG Type**					
Tank Number	15	**Tank Age**	2	**Tank Installed Date**	05/23/2023	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	
Tag Number	6108	**Spill Test Date**	05/08/2024	**Piping Installed Date**	05/23/2023	**Tank Construction**		**Piping Construction**		**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	05/08/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Gasoline	**PLLD Test Date**	05/08/2024	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	Yes
Capacity	30000	**ATG Test Date**	05/08/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	05/08/2024			**ATG Type**					
Tank Number	16	**Tank Age**	2	**Tank Installed Date**	12/14/2023	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	

Tag Number	6109	**Spill Test Date**	05/08/2024	**Piping Installed Date**	12/14/2023	**Tank Construction**		**Piping Construction**		**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	05/08/2024	**Catastrophic L.D. Type 3.0**		**Piping Type**	Pressurized	**CP Met Types**	
Product	Diesel, Dyed	**PLLD Test Date**	05/08/2024	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	9000	**ATG Test Date**	05/08/2024	**Line Tightness Test Date**	09/06/2023	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	Yes
		Overfill Test Date	05/08/2024			**ATG Type**					
Tank Number	17	**Tank Age**	2	**Tank Installed Date**	05/23/2023	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	
Tag Number	6110	**Spill Test Date**	05/08/2024	**Piping Installed Date**	05/23/2023	**Tank Construction**		**Piping Construction**		**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	05/08/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Gasoline	**PLLD Test Date**	05/08/2024	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	Yes
Capacity	15000	**ATG Test Date**	05/08/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	05/08/2024			**ATG Type**					
Tank Number	18	**Tank Age**	2	**Tank Installed Date**	12/14/2023	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	
Tag Number	6111	**Spill Test Date**	05/08/2024	**Piping Installed Date**	12/14/2023	**Tank Construction**		**Piping Construction**		**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	05/08/2024	**Catastrophic L.D. Type 3.0**		**Piping Type**	Pressurized	**CP Met Types**	
Product	Diesel	**PLLD Test Date**	05/08/2024	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**	05/08/2024	**Line Tightness Test Date**	09/06/2023	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	Yes
		Overfill Test Date	05/08/2024			**ATG Type**					
Tank Number	19	**Tank Age**	2	**Tank Installed Date**	12/14/2023	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	
Tag Number	6112	**Spill Test Date**	05/08/2024	**Piping Installed Date**	12/14/2023	**Tank Construction**		**Piping Construction**		**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	05/08/2024	**Catastrophic L.D. Type 3.0**		**Piping Type**	Pressurized	**CP Met Types**	
Product	Diesel	**PLLD Test Date**	05/08/2024	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	30000	**ATG Test Date**	05/08/2024	**Line Tightness Test Date**	09/06/2023	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	Yes
		Overfill Test Date	05/08/2024			**ATG Type**					

Tank Number	20	**Tank Age**	2	**Tank Installed Date**	12/14/2023	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	
Tag Number	6113	**Spill Test Date**	05/08/2024	**Piping Installed Date**	12/14/2023	**Tank Construction**		**Piping Construction**		**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	05/08/2024	**Catastrophic L.D. Type 3.0**		**Piping Type**	Pressurized	**CP Met Types**	
Product	Diesel	**PLLD Test Date**	05/08/2024	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	30000	**ATG Test Date**	05/08/2024	**Line Tightness Test Date**	09/06/2023	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	Yes
		Overfill Test Date	05/08/2024			**ATG Type**					

Facility Summary in Judith Basin County in the City of Geyser

Location: GEYSER SCHOOL DIST 58
103 3rd St E
Geyser, MT 59447-0070 Judith Basin

System Facility ID:23-03795

Facility Code: 22697
Last Inspected On: 01/30/2024
Operating Permit Renewal Date: 03/26/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: School Dist 58 Geyser **(406) 735-4368** **jayme.simonis@geyser.k12.mt.us**

Operator Contact: Jamie Stahl **jstahl@geyser.k12.mt.us**

Owner/Operator: School Dist 58 Geyser (406) 735-4368 jayme.simonis@geyser.k12.mt.us

Jamie Stahl, UST Class A Operator jstahl@geyser.k12.mt.us
Jamie Stahl, UST Class A Operator jstahl@geyser.k12.mt.us
Kenneth Annala, UST Class B Operator swatkins@geyser.k12.mt.us

Tank Number	02	**Tank Age**	35	**Tank Installed Date**	07/19/1990	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	4609	**Spill Test Date**	01/30/2024	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	2200	**ATG Test Date**	01/30/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	01/30/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Judith Basin County in the City of Geyser

Location: MALMSTROM AFB A 3
US Hwy 87
Geyser, MT 59447 Judith Basin

System Facility ID:23-08977

Facility Code: 22771
Last Inspected On: 06/13/2024
Operating Permit Renewal Date: 09/25/2023

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: 341 CES CEANQ **(406) 731-6188**

Operator Contact: Candace Ellsworth;Curtis Hester;William Smith **(406) 731-6239;(406) 731-7128** **candace.ellsworth@us.af.mil;william.smith@us.af.mil**

Owner/Operator: 341 CES CEANQ (406) 731-6188

Candace Ellsworth, UST Class A Operator	candace.ellsworth@us.af.mil
Candace Ellsworth, UST Class B Global Operator	candace.ellsworth@us.af.mil
Curtis Hester, UST Class A Operator	
Curtis Hester, UST Class B Global Operator	
William Smith, UST Class A Operator	william.smith@us.af.mil
William Smith, UST Class B Global Operator	william.smith@us.af.mil

Tank Number	02	**Tank Age**	33	**Tank Installed Date**	10/01/1992	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	223	**Spill Test Date**	07/17/2020	**Piping Installed Date**	06/12/2020	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	07/10/2020	**Catastrophic L.D. Type 3.0**	Auto Dialer	**Piping Type**	U.S. Suction	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	05/02/2022	**Line Tightness Test Date**	07/08/2020	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	05/02/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Judith Basin County in the City of Geyser

Location: MALMSTROM AFB B 1
US Hwy 87
Geyser, MT 59447 Judith Basin

System Facility ID:23-08986

Facility Code: 22772
Last Inspected On: 06/12/2024
Operating Permit Renewal Date: 09/25/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: 341 CES CEANQ **(406) 731-6188**

Operator Contact: Candace Ellsworth;Curtis Hester;William Smith **(406) 731-6239;(406) 731-7128** **candace.ellsworth@us.af.mil;william.smith@us.af.mil**

Owner/Operator: 341 CES CEANQ (406) 731-6188

Candace Ellsworth, UST Class A Operator	candace.ellsworth@us.af.mil
Candace Ellsworth, UST Class B Global Operator	candace.ellsworth@us.af.mil
Curtis Hester, UST Class A Operator	
Curtis Hester, UST Class B Global Operator	
William Smith, UST Class A Operator	william.smith@us.af.mil
William Smith, UST Class B Global Operator	william.smith@us.af.mil

Tank Number	03	**Tank Age**	63	**Tank Installed Date**	05/02/1962	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	224	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**	Lined Interior/Impressed Current	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	05/18/2020	**Catastrophic L.D. Type 3.0**	Auto Dialer	**Piping Type**	U.S. Suction	**CP Met Types**	Impressed Current
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	07/07/2022	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	12/11/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	12/11/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				

Facility Summary in Judith Basin County in the City of Geyser

Location: MALMSTROM AFB B 10
US Hwy 87
Geyser, MT 59447 Judith Basin

System Facility ID:23-08995

Facility Code: 22778
Last Inspected On: 06/12/2024
Operating Permit Renewal Date: 09/26/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: 341 CES CEANQ **(406) 731-6188**

Operator Contact: Candace Ellsworth;Curtis Hester;William Smith **(406) 731-6239;(406) 731-7128** **candace.ellsworth@us.af.mil;william.smith@us.af.mil**

Owner/Operator: 341 CES CEANQ (406) 731-6188

Candace Ellsworth, UST Class A Operator	candace.ellsworth@us.af.mil
Candace Ellsworth, UST Class B Global Operator	candace.ellsworth@us.af.mil
Curtis Hester, UST Class A Operator	
Curtis Hester, UST Class B Global Operator	
William Smith, UST Class A Operator	william.smith@us.af.mil
William Smith, UST Class B Global Operator	william.smith@us.af.mil

Tank Number	02	**Tank Age**	33	**Tank Installed Date**	10/01/1992	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	230	**Spill Test Date**	05/09/2023	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	05/09/2023	**Catastrophic L.D. Type 3.0**	Auto Dialer	**Piping Type**	U.S. Suction	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	05/09/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	05/09/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Judith Basin County in the City of Geyser

Location: MALMSTROM AFB B 11
US Hwy 87
Geyser, MT 59447 Judith Basin

System Facility ID:23-08996

Facility Code: 22779
Last Inspected On: 06/12/2024
Operating Permit Renewal Date: 09/26/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	341 CES CEANQ	**(406) 731-6188**	
Operator Contact:	Candace Ellsworth;Curtis Hester;William Smith	**(406) 731-6239;(406) 731-7128**	**candace.ellsworth@us.af.mil;william.smith@us.af.mil**

Owner/Operator: 341 CES CEANQ (406) 731-6188

Candace Ellsworth, UST Class A Operator	candace.ellsworth@us.af.mil
Candace Ellsworth, UST Class B Global Operator	candace.ellsworth@us.af.mil
Curtis Hester, UST Class A Operator	
Curtis Hester, UST Class B Global Operator	
William Smith, UST Class A Operator	william.smith@us.af.mil
William Smith, UST Class B Global Operator	william.smith@us.af.mil

Tank Number	02	**Tank Age**	36	**Tank Installed Date**	06/21/1989	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	231	**Spill Test Date**	05/10/2023	**Piping Installed Date**	06/17/2016	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	05/10/2023	**Catastrophic L.D. Type 3.0**	Auto Dialer	**Piping Type**	U.S. Suction	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	05/10/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	05/10/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Judith Basin County in the City of Geyser

Location: MALMSTROM AFB B 7
US Hwy 87
Geyser, MT 59447 Judith Basin

System Facility ID:23-08992

Facility Code: 22775
Last Inspected On: 06/12/2024
Operating Permit Renewal Date: 09/26/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: 341 CES CEANQ **(406) 731-6188**

Operator Contact: Candace Ellsworth;Curtis Hester;William Smith **(406) 731-6239;(406) 731-7128** **candace.ellsworth@us.af.mil;william.smith@us.af.mil**

Owner/Operator: 341 CES CEANQ (406) 731-6188

Candace Ellsworth, UST Class A Operator	candace.ellsworth@us.af.mil
Candace Ellsworth, UST Class B Global Operator	candace.ellsworth@us.af.mil
Curtis Hester, UST Class A Operator	
Curtis Hester, UST Class B Global Operator	
William Smith, UST Class A Operator	william.smith@us.af.mil
William Smith, UST Class B Global Operator	william.smith@us.af.mil

Tank Number	02	**Tank Age**	33	**Tank Installed Date**	10/01/1992	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	227	**Spill Test Date**	05/09/2023	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	05/09/2023	**Catastrophic L.D. Type 3.0**	Auto Dialer	**Piping Type**	U.S. Suction	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	05/09/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	05/09/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Judith Basin County in the City of Geyser

Location: MALMSTROM AFB B 8
US Hwy 87
Geyser, MT 59447 Judith Basin

System Facility ID:23-08993

Facility Code: 22776
Last Inspected On: 06/12/2024
Operating Permit Renewal Date: 09/26/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: 341 CES CEANQ **(406) 731-6188**

Operator Contact: Candace Ellsworth;Curtis Hester;William Smith **(406) 731-6239;(406) 731-7128** **candace.ellsworth@us.af.mil;william.smith@us.af.mil**

Owner/Operator: 341 CES CEANQ (406) 731-6188

Candace Ellsworth, UST Class A Operator	candace.ellsworth@us.af.mil
Candace Ellsworth, UST Class B Global Operator	candace.ellsworth@us.af.mil
Curtis Hester, UST Class A Operator	
Curtis Hester, UST Class B Global Operator	
William Smith, UST Class A Operator	william.smith@us.af.mil
William Smith, UST Class B Global Operator	william.smith@us.af.mil

Tank Number	03	**Tank Age**	11	**Tank Installed Date**	01/01/2014	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	5466	**Spill Test Date**	05/10/2023	**Piping Installed Date**	11/25/2013	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	05/10/2023	**Catastrophic L.D. Type 3.0**	Auto Dialer	**Piping Type**	U.S. Suction	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	05/10/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	Yes
		Overfill Test Date	05/10/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Judith Basin County in the City of Geyser

Location: MALMSTROM AFB B 9
US Hwy 87
Geyser, MT 59447 Judith Basin

System Facility ID:23-08994

Facility Code: 22777
Last Inspected On: 06/12/2024
Operating Permit Renewal Date: 09/26/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: 341 CES CEANQ **(406) 731-6188**

Operator Contact: Candace Ellsworth;Curtis Hester;William Smith **(406) 731-6239;(406) 731-7128** **candace.ellsworth@us.af.mil;william.smith@us.af.mil**

Owner/Operator: 341 CES CEANQ (406) 731-6188

Candace Ellsworth, UST Class A Operator	candace.ellsworth@us.af.mil
Candace Ellsworth, UST Class B Global Operator	candace.ellsworth@us.af.mil
Curtis Hester, UST Class A Operator	
Curtis Hester, UST Class B Global Operator	
William Smith, UST Class A Operator	william.smith@us.af.mil
William Smith, UST Class B Global Operator	william.smith@us.af.mil

Tank Number	02	**Tank Age**	33	**Tank Installed Date**	10/01/1992	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	229	**Spill Test Date**	05/09/2023	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	05/09/2023	**Catastrophic L.D. Type 3.0**	Auto Dialer	**Piping Type**	U.S. Suction	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	05/09/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	05/09/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Judith Basin County in the City of Hobson

Location: HOBSON SCHOOL DIST 25
108 6th St S E, Hobson, MT 59452
Hobson, MT Judith Basin

System Facility ID:23-05904

Facility Code: 22732
Last Inspected On: 07/28/2021
Operating Permit Renewal Date: 08/22/2024

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	School Dist 25 Hobson	**(406) 423-5483**	
Operator Contact:	Amanda Barnes;Parker Campbell;Hobson School Dist 25	**(406) 423-5483**	**mandy.barnes@hobson.k12.mt.us;parker.campbell@hobson.k12.mt.us**

Amanda Barnes, UST Class A Operator	mandy.barnes@hobson.k12.mt.us
Amanda Barnes, UST Class A Operator	mandy.barnes@hobson.k12.mt.us
Amanda Barnes, UST Class B Operator	mandy.barnes@hobson.k12.mt.us
Amanda Barnes, UST Class B Operator	mandy.barnes@hobson.k12.mt.us
Parker Campbell, UST Class A Operator	parker.campbell@hobson.k12.mt.us
Parker Campbell, UST Class A Operator	parker.campbell@hobson.k12.mt.us
Parker Campbell, UST Class B Operator	parker.campbell@hobson.k12.mt.us
Parker Campbell, UST Class B Operator	parker.campbell@hobson.k12.mt.us

Tank Number	S3	**Tank Age**	35	**Tank Installed Date**	08/18/1990	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	1388	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Secondary Containment Chase	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**	07/28/2021	**Catastrophic L.D. Type 3.0**	Auto Dialer	**Piping Type**	U.S. Suction	**CP Met Types**	Galvanic
Product	Heating Oil	**PLLD Test Date**		**Tank/Piping CP Test Date**	07/28/2021	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	20000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**	Veeder Root/TLS-300				

Facility Summary in Judith Basin County in the City of Hobson

Location: MALMSTROM AFB L 9
Road 400
Hobson, MT 59452 Judith Basin

System Facility ID:23-09104

Facility Code: 22791
Last Inspected On: 03/27/2025
Operating Permit Renewal Date: 07/31/2028

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	341 CES CEANQ	**(406) 731-6188**	
Operator Contact:	Candace Ellsworth;Curtis Hester;Shannon Chouinard;Malmstrom A F B;William Smith	**(406) 731-6167;(406) 731-6239;(406) 731-7128**	**candace.ellsworth@us.af.mil;shannon.chouinard@us.af.mil;william.smith@us.af.mil**

Owner/Operator: 341 CES CEANQ (406) 731-6188

Candace Ellsworth, UST Class A Operator	candace.ellsworth@us.af.mil
Candace Ellsworth, UST Class B Global Operator	candace.ellsworth@us.af.mil
Curtis Hester, UST Class A Operator	
Curtis Hester, UST Class B Global Operator	
Shannon Chouinard, UST Class A Operator	shannon.chouinard@us.af.mil
Shannon Chouinard, UST Class B Operator	shannon.chouinard@us.af.mil
William Smith, UST Class A Operator	william.smith@us.af.mil
William Smith, UST Class B Global Operator	william.smith@us.af.mil

Tank Number	02	**Tank Age**	32	**Tank Installed Date**	05/01/1993	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	243	**Spill Test Date**	03/27/2025	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	03/27/2025	**Catastrophic L.D. Type 3.0**	Auto Dialer	**Piping Type**	U.S. Suction	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	03/27/2025	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	03/27/2025			**ATG Type**	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Judith Basin County in the City of Hobson

Location: MALMSTROM AFB M 8
Road 400
Hobson, MT 59452 Judith Basin

System Facility ID:23-09114

Facility Code: 22792
Last Inspected On: 03/28/2025
Operating Permit Renewal Date: 07/24/2028

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: 341 CES CEANQ **(406) 731-6188**

Operator Contact: Candace Ellsworth;Curtis Hester;William Smith **(406) 731-6239;(406) 731-7128** **candace.ellsworth@us.af.mil;william.smith@us.af.mil**

Owner/Operator: 341 CES CEANQ (406) 731-6188

Candace Ellsworth, UST Class A Operator	candace.ellsworth@us.af.mil
Candace Ellsworth, UST Class B Global Operator	candace.ellsworth@us.af.mil
Curtis Hester, UST Class A Operator	
Curtis Hester, UST Class B Global Operator	
William Smith, UST Class A Operator	william.smith@us.af.mil
William Smith, UST Class B Global Operator	william.smith@us.af.mil

Tank Number	02	**Tank Age**	32	**Tank Installed Date**	05/01/1993	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	244	**Spill Test Date**	03/28/2025	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	03/28/2025	**Catastrophic L.D. Type 3.0**	Auto Dialer	**Piping Type**	U.S. Suction	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	03/28/2025	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	03/28/2025			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Judith Basin County in the City of Hobson

Location: WOODHALL DISTRIBUTING HOBSON
21 Sawmill Rd
Hobson, MT 59452 Judith Basin

System Facility ID:23-06450

Facility Code: 22738
Last Inspected On: 03/27/2023
Operating Permit Renewal Date: 07/10/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: WOODHALL DISTRIBUTING LLC **woodhalldist@itstriangle.com**

Operator Contact: Greg Econom **(406) 567-2266** **woodhalldist2@itstriangle.com**

Owner/Operator: WOODHALL DISTRIBUTING LLC woodhalldist@itstriangle.com

Greg Econom, UST Class A Operator woodhalldist2@itstriangle.com
Greg Econom, UST Class A Operator woodhalldist2@itstriangle.com
Greg Econom, UST Class B Operator woodhalldist2@itstriangle.com
Greg Econom, UST Class B Operator woodhalldist2@itstriangle.com

Tank Number	05	**Tank Age**	27	**Tank Installed Date**	04/01/1998	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	4745	**Spill Test Date**	03/27/2023	**Piping Installed Date**	04/01/1998	**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	03/27/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**	03/27/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	03/27/2023			**ATG Type**	Gilbarco/EMC Basic				
Tank Number	06	**Tank Age**	27	**Tank Installed Date**	04/01/1998	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	4746	**Spill Test Date**	03/27/2023	**Piping Installed Date**	04/01/1998	**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	03/27/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**	03/27/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	03/27/2023			**ATG Type**	Gilbarco/EMC Basic				

Facility Summary in Judith Basin County in the City of Moccasin

Location: MALMSTROM AFB C 4
US Hwy 87
Moccasin, MT 59462 Judith Basin

System Facility ID:23-09000

Facility Code: 22783
Last Inspected On: 06/07/2024
Operating Permit Renewal Date: 07/08/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: 341 CES CEANQ **(406) 731-6188**

Operator Contact: Candace Ellsworth;Curtis Hester;William Smith **(406) 731-6239;(406) 731-7128** **candace.ellsworth@us.af.mil;william.smith@us.af.mil**

Owner/Operator: 341 CES CEANQ (406) 731-6188

Candace Ellsworth, UST Class A Operator	candace.ellsworth@us.af.mil
Candace Ellsworth, UST Class B Global Operator	candace.ellsworth@us.af.mil
Curtis Hester, UST Class A Operator	
Curtis Hester, UST Class B Global Operator	
William Smith, UST Class A Operator	william.smith@us.af.mil
William Smith, UST Class B Global Operator	william.smith@us.af.mil

Tank Number	02	**Tank Age**	33	**Tank Installed Date**	09/01/1992	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	235	**Spill Test Date**	03/31/2023	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	03/31/2023	**Catastrophic L.D. Type 3.0**	Auto Dialer	**Piping Type**	U.S. Suction	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	03/31/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	03/31/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Judith Basin County in the City of Moccasin

Location: MALMSTROM AFB C 5
US Hwy 87
Moccasin, MT 59462 Judith Basin

System Facility ID:23-09001

Facility Code: 22784
Last Inspected On: 06/07/2024
Operating Permit Renewal Date: 07/08/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: 341 CES CEANQ **(406) 731-6188**

Operator Contact: Candace Ellsworth;Curtis Hester;William Smith **(406) 731-6239;(406) 731-7128** **candace.ellsworth@us.af.mil;william.smith@us.af.mil**

Owner/Operator: 341 CES CEANQ (406) 731-6188

Candace Ellsworth, UST Class A Operator	candace.ellsworth@us.af.mil
Candace Ellsworth, UST Class B Global Operator	candace.ellsworth@us.af.mil
Curtis Hester, UST Class A Operator	
Curtis Hester, UST Class B Global Operator	
William Smith, UST Class A Operator	william.smith@us.af.mil
William Smith, UST Class B Global Operator	william.smith@us.af.mil

Tank Number	02	**Tank Age**	33	**Tank Installed Date**	09/01/1992	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	236	**Spill Test Date**	03/31/2023	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	03/31/2023	**Catastrophic L.D. Type 3.0**	Auto Dialer	**Piping Type**	U.S. Suction	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	03/31/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	03/31/2023			**ATG Type**					

Facility Summary in Judith Basin County in the City of Moccasin

Location: MALMSTROM AFB C 6
Road 239
Moccasin, MT 59462 Judith Basin

System Facility ID:23-09002

Facility Code: 22785
Last Inspected On: 06/07/2024
Operating Permit Renewal Date: 07/08/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: 341 CES CEANQ **(406) 731-6188**

Operator Contact: Candace Ellsworth;Curtis Hester;William Smith **(406) 731-6239;(406) 731-7128** **candace.ellsworth@us.af.mil;william.smith@us.af.mil**

Owner/Operator: 341 CES CEANQ (406) 731-6188

Candace Ellsworth, UST Class A Operator	candace.ellsworth@us.af.mil
Candace Ellsworth, UST Class B Global Operator	candace.ellsworth@us.af.mil
Curtis Hester, UST Class A Operator	
Curtis Hester, UST Class B Global Operator	
William Smith, UST Class A Operator	william.smith@us.af.mil
William Smith, UST Class B Global Operator	william.smith@us.af.mil

Tank Number	02	**Tank Age**	33	**Tank Installed Date**	09/01/1992	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	237	**Spill Test Date**	05/10/2023	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	05/10/2023	**Catastrophic L.D. Type 3.0**	Auto Dialer	**Piping Type**	U.S. Suction	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	05/10/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	05/10/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Judith Basin County in the City of Moccasin

Location: MALMSTROM AFB C 7
Road 239
Moccasin, MT 59462 Judith Basin

System Facility ID:23-09003

Facility Code: 22786
Last Inspected On: 06/07/2024
Operating Permit Renewal Date: 07/08/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: 341 CES CEANQ **(406) 731-6188**

Operator Contact: Candace Ellsworth;Curtis Hester;William Smith **(406) 731-6239;(406) 731-7128** **candace.ellsworth@us.af.mil;william.smith@us.af.mil**

Owner/Operator: 341 CES CEANQ (406) 731-6188

Candace Ellsworth, UST Class A Operator	candace.ellsworth@us.af.mil
Candace Ellsworth, UST Class B Global Operator	candace.ellsworth@us.af.mil
Curtis Hester, UST Class A Operator	
Curtis Hester, UST Class B Global Operator	
William Smith, UST Class A Operator	william.smith@us.af.mil
William Smith, UST Class B Global Operator	william.smith@us.af.mil

Tank Number	02	**Tank Age**	33	**Tank Installed Date**	09/01/1992	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	238	**Spill Test Date**	03/30/2023	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	03/30/2023	**Catastrophic L.D. Type 3.0**	Auto Dialer	**Piping Type**	U.S. Suction	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	03/30/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	03/30/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Judith Basin County in the City of Moccasin

Location: MALMSTROM AFB M 10
US Hwy 87
Moccasin, MT 59462 Judith Basin

System Facility ID:23-09116

Facility Code: 22794
Last Inspected On: 03/31/2025
Operating Permit Renewal Date: 08/06/2025

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: 341 CES CEANQ **(406) 731-6188**

Operator Contact: Candace Ellsworth;Curtis Hester;William Smith **(406) 731-6239;(406) 731-7128** **candace.ellsworth@us.af.mil;william.smith@us.af.mil**

Owner/Operator: 341 CES CEANQ (406) 731-6188

Candace Ellsworth, UST Class A Operator	candace.ellsworth@us.af.mil
Candace Ellsworth, UST Class B Global Operator	candace.ellsworth@us.af.mil
Curtis Hester, UST Class A Operator	
Curtis Hester, UST Class B Global Operator	
William Smith, UST Class A Operator	william.smith@us.af.mil
William Smith, UST Class B Global Operator	william.smith@us.af.mil

Tank Number	02	**Tank Age**	32	**Tank Installed Date**	05/01/1993	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	246	**Spill Test Date**	03/21/2022	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	03/21/2022	**Catastrophic L.D. Type 3.0**	Auto Dialer	**Piping Type**	U.S. Suction	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	03/21/2022	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	03/21/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Judith Basin County in the City of Moccasin

Location: MALMSTROM AFB M 9
US Hwy 87
Moccasin, MT 59462 Judith Basin

System Facility ID:23-09115

Facility Code: 22793
Last Inspected On: 03/28/2025
Operating Permit Renewal Date: 07/24/2028

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: 341 CES CEANQ **(406) 731-6188**

Operator Contact: Candace Ellsworth;Curtis Hester;William Smith **(406) 731-6239;(406) 731-7128** **candace.ellsworth@us.af.mil;william.smith@us.af.mil**

Owner/Operator: 341 CES CEANQ (406) 731-6188

Candace Ellsworth, UST Class A Operator	candace.ellsworth@us.af.mil
Candace Ellsworth, UST Class B Global Operator	candace.ellsworth@us.af.mil
Curtis Hester, UST Class A Operator	
Curtis Hester, UST Class B Global Operator	
William Smith, UST Class A Operator	william.smith@us.af.mil
William Smith, UST Class B Global Operator	william.smith@us.af.mil

Tank Number	02	**Tank Age**	32	**Tank Installed Date**	05/01/1993	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	245	**Spill Test Date**	03/28/2025	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	03/21/2022	**Catastrophic L.D. Type 3.0**	Auto Dialer	**Piping Type**	U.S. Suction	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	03/28/2025	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	03/28/2025	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	03/28/2025			**ATG Type**	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Judith Basin County in the City of Raynesford

Location: KIBBEY KORNER TRUCK STOP
US Hwy 87 & Rte 427
Raynesford, MT 59469-0197 Judith Basin

System Facility ID:23-03301

Facility Code: 22691
Last Inspected On: 06/10/2025
Operating Permit Renewal Date: 08/04/2025

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Mountain View Coop Black Eagle **(406) 453-5900** **ddouglas@mountainviewcoop.com**

Operator Contact: David Douglas **ddouglas@mountainviewcoop.com**

Owner/Operator: Mountain View Coop Black Eagle (406) 453-5900 ddouglas@mountainviewcoop.com
David Douglas, UST Class A Operator ddouglas@mountainviewcoop.com
David Douglas, UST Class B Global Operator ddouglas@mountainviewcoop.com

Tank Number	S6	**Tank Age**	29	**Tank Installed Date**	09/01/1996	**Tank Material Construction**	Bare Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	
Tag Number	1026	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	Yes
Status	**Currently in Use**	**MLLD Test Date**	02/14/2022	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	25000	**ATG Test Date**		**Line Tightness Test Date**	02/14/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	S7	**Tank Age**	29	**Tank Installed Date**	09/01/1996	**Tank Material Construction**	Bare Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	
Tag Number	1027	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	Yes
Status	**Currently in Use**	**MLLD Test Date**	02/14/2022	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**		**Line Tightness Test Date**	02/14/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	S8	**Tank Age**	29	**Tank Installed Date**	09/01/1996	**Tank Material Construction**	Bare Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	
Tag Number	1028	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	Yes

Status	**Currently in Use**	**MLLD Test Date**	02/14/2022	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Diesel, Dyed	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**		**Line Tightness Test Date**	02/14/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	S9	**Tank Age**	29	**Tank Installed Date**	09/01/1996	**Tank Material Construction**	Bare Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	
Tag Number	1029	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	Yes
Status	**Currently in Use**	**MLLD Test Date**	02/14/2022	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**		**Line Tightness Test Date**	02/14/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	S10	**Tank Age**	29	**Tank Installed Date**	09/01/1996	**Tank Material Construction**	Bare Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	
Tag Number	1030	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	Yes
Status	**Currently in Use**	**MLLD Test Date**	02/14/2022	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**		**Line Tightness Test Date**	02/14/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					

Facility Summary in Judith Basin County in the City of Raynesford

Location: MALMSTROM AFB A 1
US Hwy 87
Raynesford, MT 59469 Judith Basin

System Facility ID:23-08974

Facility Code: 22770
Last Inspected On: 06/14/2024
Operating Permit Renewal Date: 09/19/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: 341 CES CEANQ **(406) 731-6188**

Operator Contact: Candace Ellsworth;Curtis Hester;William Smith **(406) 731-6239;(406) 731-7128** **candace.ellsworth@us.af.mil;william.smith@us.af.mil**

Owner/Operator: 341 CES CEANQ (406) 731-6188

Candace Ellsworth, UST Class A Operator	candace.ellsworth@us.af.mil
Candace Ellsworth, UST Class B Global Operator	candace.ellsworth@us.af.mil
Curtis Hester, UST Class A Operator	
Curtis Hester, UST Class B Global Operator	
Gavin Johnson, UST Class B Global Operator	gavin_johnson@hotmail.com
Josi Brosam, UST Class B Global Operator	josibrosam@rmsi.coop
William Smith, UST Class A Operator	william.smith@us.af.mil
William Smith, UST Class B Global Operator	william.smith@us.af.mil

Tank Number	01	**Tank Age**	63	**Tank Installed Date**	05/02/1962	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	222	**Spill Test Date**	05/09/2023	**Piping Installed Date**		**Tank Construction**	Lined Interior/Impressed Current	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	05/09/2023	**Catastrophic L.D. Type 3.0**	Auto Dialer	**Piping Type**	U.S. Suction	**CP Met Types**	Impressed Current
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	04/01/2020	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	09/30/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	09/30/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				

Facility Summary in Judith Basin County in the City of Raynesford

Location: MALMSTROM AFB A 4
Road 427
Raynesford, MT 59469 Judith Basin

System Facility ID:20-08978

Facility Code: 22139
Last Inspected On: 06/14/2024
Operating Permit Renewal Date: 09/25/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: 341 CES CEANQ **(406) 731-6188**

Operator Contact: Candace Ellsworth;Curtis Hester;William Smith **(406) 731-6239;(406) 731-7128** **candace.ellsworth@us.af.mil;william.smith@us.af.mil**

Owner/Operator: 341 CES CEANQ (406) 731-6188

Candace Ellsworth, UST Class A Operator	candace.ellsworth@us.af.mil
Candace Ellsworth, UST Class B Global Operator	candace.ellsworth@us.af.mil
Curtis Hester, UST Class A Operator	
Curtis Hester, UST Class B Global Operator	
William Smith, UST Class A Operator	william.smith@us.af.mil
William Smith, UST Class B Global Operator	william.smith@us.af.mil

Tank Number	02	**Tank Age**	33	**Tank Installed Date**	06/01/1992	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	221	**Spill Test Date**	07/17/2020	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	05/18/2020	**Catastrophic L.D. Type 3.0**	Auto Dialer	**Piping Type**	U.S. Suction	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	05/03/2022	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	05/03/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Judith Basin County in the City of Stanford

Location: MALMSTROM AFB B 2
MT Hwy 80
Stanford, MT 59479 Judith Basin

System Facility ID:23-08987

Facility Code: 22773
Last Inspected On: 06/11/2024
Operating Permit Renewal Date: 09/26/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: 341 CES CEANQ **(406) 731-6188**

Operator Contact: Candace Ellsworth;Curtis Hester;William Smith **(406) 731-6239;(406) 731-7128** **candace.ellsworth@us.af.mil;william.smith@us.af.mil**

Owner/Operator: 341 CES CEANQ (406) 731-6188

Candace Ellsworth, UST Class A Operator	candace.ellsworth@us.af.mil
Candace Ellsworth, UST Class B Global Operator	candace.ellsworth@us.af.mil
Curtis Hester, UST Class A Operator	
Curtis Hester, UST Class B Global Operator	
William Smith, UST Class A Operator	william.smith@us.af.mil
William Smith, UST Class B Global Operator	william.smith@us.af.mil

Tank Number	02	**Tank Age**	33	**Tank Installed Date**	09/01/1992	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	225	**Spill Test Date**	05/04/2023	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	05/04/2023	**Catastrophic L.D. Type 3.0**	Auto Dialer	**Piping Type**	U.S. Suction	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	05/04/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	05/04/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Judith Basin County in the City of Stanford

Location: MALMSTROM AFB B 3
MT Hwy 81
Stanford, MT 59479 Judith Basin

System Facility ID:14-08988

Facility Code: 20308
Last Inspected On: 06/11/2024
Operating Permit Renewal Date: 09/26/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: 341 CES CEANQ **(406) 731-6188**

Operator Contact: Candace Ellsworth;Curtis Hester;William Smith **(406) 731-6239;(406) 731-7128** **candace.ellsworth@us.af.mil;william.smith@us.af.mil**

Owner/Operator: 341 CES CEANQ (406) 731-6188

Candace Ellsworth, UST Class A Operator	candace.ellsworth@us.af.mil
Candace Ellsworth, UST Class B Global Operator	candace.ellsworth@us.af.mil
Curtis Hester, UST Class A Operator	
Curtis Hester, UST Class B Global Operator	
William Smith, UST Class A Operator	william.smith@us.af.mil
William Smith, UST Class B Global Operator	william.smith@us.af.mil

Tank Number	02	**Tank Age**	33	**Tank Installed Date**	08/01/1992	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	163	**Spill Test Date**	08/14/2020	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	03/18/2020	**Catastrophic L.D. Type 3.0**	Auto Dialer	**Piping Type**	U.S. Suction	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	04/20/2022	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	04/20/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Judith Basin County in the City of Stanford

Location: MALMSTROM AFB B 4
MT Hwy 80
Stanford, MT 59479 Judith Basin

System Facility ID:14-08989

Facility Code: 20309
Last Inspected On: 06/11/2024
Operating Permit Renewal Date: 09/15/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	341 CES CEANQ	**(406) 731-6188**	
Operator Contact:	Candace Ellsworth;Curtis Hester;William Smith	**(406) 731-6239;(406) 731-7128**	**candace.ellsworth@us.af.mil;william.smith@us.af.mil**

Owner/Operator: 341 CES CEANQ (406) 731-6188

Candace Ellsworth, UST Class A Operator	candace.ellsworth@us.af.mil
Candace Ellsworth, UST Class A Operator	candace.ellsworth@us.af.mil
Candace Ellsworth, UST Class B Global Operator	candace.ellsworth@us.af.mil
Candace Ellsworth, UST Class B Global Operator	candace.ellsworth@us.af.mil
Curtis Hester, UST Class A Operator	
Curtis Hester, UST Class A Operator	
Curtis Hester, UST Class B Global Operator	
Curtis Hester, UST Class B Global Operator	
William Smith, UST Class A Operator	william.smith@us.af.mil
William Smith, UST Class A Operator	william.smith@us.af.mil
William Smith, UST Class B Global Operator	william.smith@us.af.mil
William Smith, UST Class B Global Operator	william.smith@us.af.mil

Tank Number	02	**Tank Age**	33	**Tank Installed Date**	09/01/1992	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	164	**Spill Test Date**	05/04/2023	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	05/04/2023	**Catastrophic L.D. Type 3.0**	Auto Dialer	**Piping Type**	U.S. Suction	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	04/20/2022	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	05/04/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Judith Basin County in the City of Stanford

Location: MALMSTROM AFB B 5
MT Hwy 80
Stanford, MT 59479 Judith Basin

System Facility ID:26-08990

Facility Code: 24068
Last Inspected On: 06/11/2024
Operating Permit Renewal Date: 09/26/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: 341 CES CEANQ **(406) 731-6188**

Operator Contact: Candace Ellsworth;Curtis Hester;William Smith **(406) 731-6239;(406) 731-7128** **candace.ellsworth@us.af.mil;william.smith@us.af.mil**

Owner/Operator: 341 CES CEANQ (406) 731-6188

Candace Ellsworth, UST Class A Operator	candace.ellsworth@us.af.mil
Candace Ellsworth, UST Class B Global Operator	candace.ellsworth@us.af.mil
Curtis Hester, UST Class A Operator	
Curtis Hester, UST Class B Global Operator	
William Smith, UST Class A Operator	william.smith@us.af.mil
William Smith, UST Class B Global Operator	william.smith@us.af.mil

Tank Number	02	**Tank Age**	33	**Tank Installed Date**	09/10/1992	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	258	**Spill Test Date**	05/04/2023	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	05/04/2023	**Catastrophic L.D. Type 3.0**	Auto Dialer	**Piping Type**	U.S. Suction	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	05/04/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	05/04/2023			**ATG Type**	Gilbarco-Veeder Root/				

Facility Summary in Judith Basin County in the City of Stanford

Location: MALMSTROM AFB B 6
US Hwy 87
Stanford, MT 59479 Judith Basin

System Facility ID:23-08991

Facility Code: 22774
Last Inspected On: 06/11/2024
Operating Permit Renewal Date: 09/26/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: 341 CES CEANQ **(406) 731-6188**

Operator Contact: Candace Ellsworth;Curtis Hester;William Smith **(406) 731-6239;(406) 731-7128** **candace.ellsworth@us.af.mil;william.smith@us.af.mil**

Owner/Operator: 341 CES CEANQ (406) 731-6188

Candace Ellsworth, UST Class A Operator	candace.ellsworth@us.af.mil
Candace Ellsworth, UST Class B Global Operator	candace.ellsworth@us.af.mil
Curtis Hester, UST Class A Operator	
Curtis Hester, UST Class B Global Operator	
William Smith, UST Class A Operator	william.smith@us.af.mil
William Smith, UST Class B Global Operator	william.smith@us.af.mil

Tank Number	02	**Tank Age**	33	**Tank Installed Date**	10/01/1992	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	226	**Spill Test Date**	05/04/2023	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	05/04/2023	**Catastrophic L.D. Type 3.0**	Auto Dialer	**Piping Type**	U.S. Suction	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	05/04/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	05/04/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Judith Basin County in the City of Stanford

Location: MALMSTROM AFB C 10
US Hwy 87
Stanford, MT 59479 Judith Basin

System Facility ID:23-09006

Facility Code: 22789
Last Inspected On: 06/10/2024
Operating Permit Renewal Date: 05/16/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: 341 CES CEANQ **(406) 731-6188**

Operator Contact: Candace Ellsworth;Curtis Hester;William Smith **(406) 731-6239;(406) 731-7128** **candace.ellsworth@us.af.mil;william.smith@us.af.mil**

Owner/Operator: 341 CES CEANQ (406) 731-6188

Candace Ellsworth, UST Class A Operator	candace.ellsworth@us.af.mil
Candace Ellsworth, UST Class B Global Operator	candace.ellsworth@us.af.mil
Curtis Hester, UST Class A Operator	
Curtis Hester, UST Class B Global Operator	
William Smith, UST Class A Operator	william.smith@us.af.mil
William Smith, UST Class B Global Operator	william.smith@us.af.mil

Tank Number	03	**Tank Age**	8	**Tank Installed Date**	04/01/2017	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve;High Level Alarm
Tag Number	5741	**Spill Test Date**	05/11/2023	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	03/16/2020	**Catastrophic L.D. Type 3.0**	Auto Dialer	**Piping Type**	U.S. Suction	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	05/11/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	Yes
		Overfill Test Date	05/11/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Judith Basin County in the City of Stanford

Location: MALMSTROM AFB C 11
US Hwy 87
Stanford, MT 59479 Judith Basin

System Facility ID:23-09007

Facility Code: 22790
Last Inspected On: 06/10/2024
Operating Permit Renewal Date: 09/26/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: 341 CES CEANQ **(406) 731-6188**

Operator Contact: Candace Ellsworth;Curtis Hester;William Smith **(406) 731-6239;(406) 731-7128** **candace.ellsworth@us.af.mil;william.smith@us.af.mil**

Owner/Operator: 341 CES CEANQ (406) 731-6188

Candace Ellsworth, UST Class A Operator	candace.ellsworth@us.af.mil
Candace Ellsworth, UST Class B Global Operator	candace.ellsworth@us.af.mil
Curtis Hester, UST Class A Operator	
Curtis Hester, UST Class B Global Operator	
William Smith, UST Class A Operator	william.smith@us.af.mil
William Smith, UST Class B Global Operator	william.smith@us.af.mil

Tank Number	02	**Tank Age**	33	**Tank Installed Date**	10/01/1992	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	242	**Spill Test Date**	03/31/2023	**Piping Installed Date**	06/11/2020	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	03/31/2023	**Catastrophic L.D. Type 3.0**	Auto Dialer	**Piping Type**	U.S. Suction	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	03/31/2023	**Line Tightness Test Date**	06/11/2020	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	03/31/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Judith Basin County in the City of Stanford

Location: MALMSTROM AFB C 2
US Hwy 87
Stanford, MT 59479 Judith Basin

System Facility ID:23-08998

Facility Code: 22781
Last Inspected On: 06/07/2024
Operating Permit Renewal Date: 07/08/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: 341 CES CEANQ **(406) 731-6188**

Operator Contact: Candace Ellsworth;Curtis Hester;William Smith **(406) 731-6239;(406) 731-7128** **candace.ellsworth@us.af.mil;william.smith@us.af.mil**

Owner/Operator: 341 CES CEANQ (406) 731-6188

Candace Ellsworth, UST Class A Operator	candace.ellsworth@us.af.mil
Candace Ellsworth, UST Class B Global Operator	candace.ellsworth@us.af.mil
Curtis Hester, UST Class A Operator	
Curtis Hester, UST Class B Global Operator	
William Smith, UST Class A Operator	william.smith@us.af.mil
William Smith, UST Class B Global Operator	william.smith@us.af.mil

Tank Number	02	**Tank Age**	33	**Tank Installed Date**	09/01/1992	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	233	**Spill Test Date**	03/31/2023	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	03/31/2023	**Catastrophic L.D. Type 3.0**	Continuous Interstitial Monitoring	**Piping Type**	U.S. Suction	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	03/31/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	03/31/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Judith Basin County in the City of Stanford

Location: MALMSTROM AFB C 3
US Hwy 87
Stanford, MT 59479 Judith Basin

System Facility ID:23-08999

Facility Code: 22782
Last Inspected On: 06/07/2024
Operating Permit Renewal Date: 07/08/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: 341 CES CEANQ **(406) 731-6188**

Operator Contact: Candace Ellsworth;Curtis Hester;William Smith **(406) 731-6239;(406) 731-7128** **candace.ellsworth@us.af.mil;william.smith@us.af.mil**

Owner/Operator: 341 CES CEANQ (406) 731-6188

Candace Ellsworth, UST Class A Operator	candace.ellsworth@us.af.mil
Candace Ellsworth, UST Class B Global Operator	candace.ellsworth@us.af.mil
Curtis Hester, UST Class A Operator	
Curtis Hester, UST Class B Global Operator	
William Smith, UST Class A Operator	william.smith@us.af.mil
William Smith, UST Class B Global Operator	william.smith@us.af.mil

Tank Number	02	**Tank Age**	33	**Tank Installed Date**	09/11/1992	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	234	**Spill Test Date**	03/31/2023	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	03/31/2023	**Catastrophic L.D. Type 3.0**	Auto Dialer	**Piping Type**	U.S. Suction	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	03/31/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	03/31/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Judith Basin County in the City of Stanford

Location: MALMSTROM AFB C 8
US Hwy 87
Stanford, MT 59479 Judith Basin

System Facility ID:23-09004

Facility Code: 22787
Last Inspected On: 06/10/2024
Operating Permit Renewal Date: 10/07/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: 341 CES CEANQ **(406) 731-6188**

Operator Contact: Candace Ellsworth;Curtis Hester;William Smith **(406) 731-6239;(406) 731-7128** **candace.ellsworth@us.af.mil;william.smith@us.af.mil**

Owner/Operator: 341 CES CEANQ (406) 731-6188

Candace Ellsworth, UST Class A Operator	candace.ellsworth@us.af.mil
Candace Ellsworth, UST Class B Global Operator	candace.ellsworth@us.af.mil
Curtis Hester, UST Class A Operator	
Curtis Hester, UST Class B Global Operator	
William Smith, UST Class A Operator	william.smith@us.af.mil
William Smith, UST Class B Global Operator	william.smith@us.af.mil

Tank Number	02	**Tank Age**	33	**Tank Installed Date**	09/01/1992	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	239	**Spill Test Date**	05/10/2023	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	05/10/2023	**Catastrophic L.D. Type 3.0**	Auto Dialer	**Piping Type**	U.S. Suction	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	05/10/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	05/10/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Judith Basin County in the City of Stanford

Location: MALMSTROM AFB C 9
US Hwy 87
Stanford, MT 59479 Judith Basin

System Facility ID:23-09005

Facility Code: 22788
Last Inspected On: 06/10/2024
Operating Permit Renewal Date: 10/07/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: 341 CES CEANQ **(406) 731-6188**

Operator Contact: Candace Ellsworth;Curtis Hester;William Smith **(406) 731-6239;(406) 731-7128** **candace.ellsworth@us.af.mil;william.smith@us.af.mil**

Owner/Operator: 341 CES CEANQ (406) 731-6188

Candace Ellsworth, UST Class A Operator	candace.ellsworth@us.af.mil
Candace Ellsworth, UST Class B Global Operator	candace.ellsworth@us.af.mil
Curtis Hester, UST Class A Operator	
Curtis Hester, UST Class B Global Operator	
William Smith, UST Class A Operator	william.smith@us.af.mil
William Smith, UST Class B Global Operator	william.smith@us.af.mil

Tank Number	02	**Tank Age**	33	**Tank Installed Date**	10/01/1992	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	240	**Spill Test Date**	05/10/2023	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	05/10/2023	**Catastrophic L.D. Type 3.0**	Auto Dialer	**Piping Type**	U.S. Suction	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	05/10/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	05/10/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Judith Basin County in the City of Stanford

Location: STANFORD SCHOOL DIST 12
104 4th Ave S
Stanford, MT 59479 Judith Basin

System Facility ID:23-01938

Facility Code: 22680
Last Inspected On: 08/10/2022
Operating Permit Renewal Date: 10/11/2025

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: School Dist 12 Stanford **(406) 566-2265**

Operator Contact: Arnold Smith **asmith@stanford.k12.mt.us**

Owner/Operator: School Dist 12 Stanford (406) 566-2265

Arnold Smith, UST Class A Operator asmith@stanford.k12.mt.us

Arnold Smith, UST Class B Global Operator asmith@stanford.k12.mt.us

Tank Number	S3	**Tank Age**	27	**Tank Installed Date**	10/09/1998	**Tank Material Construction**	Steel Clad	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	1893	**Spill Test Date**	08/10/2022	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	U.S. Suction	**CP Met Types**	Non-corrodible
Product	Heating Oil	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Manual Interstitial Monitoring	**Primary Pipe Leak Detection**	3-Year Line Tightness Test	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**		**Line Tightness Test Date**	08/10/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Manual Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	08/10/2022			**ATG Type**					

Facility Summary in Judith Basin County in the City of Stanford

Location: WOODHALL DISTRIBUTING STANFORD
219 Central Ave
Stanford, MT 59479 Judith Basin

System Facility ID:23-03303

Facility Code: 22692
Last Inspected On: 04/28/2025
Operating Permit Renewal Date: 06/11/2028

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: WOODHALL DISTRIBUTING LLC **woodhalldist@itstriangle.com**

Operator Contact: Dylan Woodhall;Woodhall Distributing - Stanford **(406) 366-5509;(406) 566-2671** **woodysfuelstop@gmail.com**

Owner/Operator: WOODHALL DISTRIBUTING LLC woodhalldist@itstriangle.com

Dylan Woodhall, UST Class A Operator woodysfuelstop@gmail.com

Gloria Hungate, UST Class B Global Operator

Greg Econom, UST Class B Operator woodhalldist2@itstriangle.com

Tank Number	04	**Tank Age**	27	**Tank Installed Date**	07/06/1998	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	1031	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Temporarily Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Vapor Monitoring	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	2000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	05	**Tank Age**	27	**Tank Installed Date**	07/06/1998	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	1032	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Temporarily Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Vapor Monitoring	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	2000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					

Facility Summary in Judith Basin County in the City of Stanford

Location: WOODYS FUEL STOP
36653 US Hwy 87
Stanford, MT 59479 Judith Basin

System Facility ID:23-01526

Facility Code: 22675
Last Inspected On: 05/24/2023
Operating Permit Renewal Date: 10/23/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Dylan Woodhall	**(406) 366-5509**	**woodysfuelstop@gmail.com**
Operator Contact:	Dylan Woodhall;Shirley Woodhall	**(406) 366-5509;(406) 566-2203**	**woodysfuelstop@gmail.com**

Owner/Operator: Dylan Woodhall (406) 366-5509 woodysfuelstop@gmail.com

Dylan Woodhall, UST Class A Operator woodysfuelstop@gmail.com
Dylan Woodhall, UST Class A Operator woodysfuelstop@gmail.com
Shirley Woodhall, UST Class A Operator
Shirley Woodhall, UST Class A Operator

Tank Number	06	**Tank Age**	29	**Tank Installed Date**	09/01/1996	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	4410	**Spill Test Date**	03/14/2025	**Piping Installed Date**	03/14/2025	**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	03/14/2025	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Safe Suction	**CP Met Types**	
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	09/08/2020	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	5000	**ATG Test Date**		**Line Tightness Test Date**	09/01/2011	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	03/14/2025			**ATG Type**	Franklin Fueling Systems/EVO 600				
Tank Number	07	**Tank Age**	27	**Tank Installed Date**	10/01/1998	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	4411	**Spill Test Date**	09/08/2020	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	09/08/2020	**Sump Tightness Test Date**	03/14/2025	**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	09/08/2020	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**		**Line Tightness Test Date**	09/06/2023	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	09/08/2020			**ATG Type**	Franklin Fueling Systems/EVO 600				

Tank Number	08	**Tank Age**	27	**Tank Installed Date**	10/01/1998	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	4412	**Spill Test Date**	09/08/2020	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	09/08/2020	**Sump Tightness Test Date**	03/14/2025	**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	09/08/2020	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	5000	**ATG Test Date**		**Line Tightness Test Date**	09/06/2023	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	09/08/2020			**ATG Type**	Franklin Fueling Systems/EVO 600				

Facility Summary in Judith Basin County in the City of WINDHAM

Location: MALMSTROM AFB C 1
US Hwy 87
WINDHAM, MT 59479 Judith Basin

System Facility ID:23-08997

Facility Code: 22780
Last Inspected On: 06/10/2024
Operating Permit Renewal Date: 09/25/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: 341 CES CEANQ **(406) 731-6188**

Operator Contact: Candace Ellsworth;Curtis Hester;William Smith **(406) 731-6239;(406) 731-7128** **candace.ellsworth@us.af.mil;william.smith@us.af.mil**

Owner/Operator: 341 CES CEANQ (406) 731-6188

Candace Ellsworth, UST Class A Operator	candace.ellsworth@us.af.mil
Candace Ellsworth, UST Class B Global Operator	candace.ellsworth@us.af.mil
Curtis Hester, UST Class A Operator	
Curtis Hester, UST Class B Global Operator	
William Smith, UST Class A Operator	william.smith@us.af.mil
William Smith, UST Class B Global Operator	william.smith@us.af.mil

Tank Number	02	**Tank Age**	63	**Tank Installed Date**	05/02/1962	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	232	**Spill Test Date**	05/11/2023	**Piping Installed Date**		**Tank Construction**	Lined Interior/Impressed Current	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	05/11/2023	**Catastrophic L.D. Type 3.0**	Auto Dialer	**Piping Type**	U.S. Suction	**CP Met Types**	Impressed Current
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	01/09/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	12/05/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	12/05/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				

Facility Summary in Lake County in the City of Arlee

Location: WILSON FOODS
92345 US Hwy 93
Arlee, MT 59821-9433 Lake

System Facility ID:24-06788

Facility Code: 23006
Last Inspected On: 02/19/2024
Operating Permit Renewal Date: 03/21/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Wilson Foods **(406) 745-4285**

Operator Contact: John Carranco;Velva Stuck;Wilson Foods **(406) 549-0891;(406) 745-4285** **velva1962@yahoo.com**

Owner/Operator: Wilson Foods (406) 745-4285

John Carranco, UST Class A Operator
John Carranco, UST Class B Operator
Velva Stuck, UST Class A Operator velva1962@yahoo.com
Velva Stuck, UST Class B Operator velva1962@yahoo.com

Tank Number	10	**Tank Age**	27	**Tank Installed Date**	11/01/1998	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	3320	**Spill Test Date**	09/15/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	02/19/2024	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	02/19/2024	**Line Tightness Test Date**	02/19/2024	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	09/15/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-300				
Tank Number	11	**Tank Age**	27	**Tank Installed Date**	11/01/1998	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	3321	**Spill Test Date**	09/15/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	02/19/2024	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	02/19/2024	**Line Tightness Test Date**	02/19/2024	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	09/15/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-300				

Tank Number	12	**Tank Age**	27	**Tank Installed Date**	11/01/1998	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	3322	**Spill Test Date**	09/15/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	02/19/2024	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	02/19/2024	**Line Tightness Test Date**	02/19/2024	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	11/15/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-300				

Facility Summary in Lake County in the City of Charlo

Location: CHARLO SCHOOL DIST 7 J
405 2nd Ave E
Charlo, MT 59824 Lake

System Facility ID:24-02789

Facility Code: 22907
Last Inspected On: 11/01/2023
Operating Permit Renewal Date: 03/27/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: School Dist 7 J Charlo **(406) 644-2207**

Operator Contact: Joe Broom;School Dist 7 J Charlo **(406) 249-8000;(406) 644-2207** **jbroom@charloschools.com**

Owner/Operator: School Dist 7 J Charlo (406) 644-2207

Joe Broom, UST Class A Operator jbroom@charloschools.com
Joe Broom, UST Class B Operator jbroom@charloschools.com

Tank Number	S5	**Tank Age**	27	**Tank Installed Date**	07/01/1998	**Tank Material Construction**	Unknown	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	611	**Spill Test Date**		**Piping Installed Date**	07/09/2012	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	Yes
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	11/01/2023	**Catastrophic L.D. Type 3.0**	Auto Dialer	**Piping Type**	U.S. Suction	**CP Met Types**	
Product	Heating Oil	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Deferred	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	11/01/2023	**Line Tightness Test Date**	08/27/2012	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	Yes
		Overfill Test Date				**ATG Type**					

Facility Summary in Lake County in the City of Charlo

Location: COULTER AUTOMOTIVE INC
104 Main St
Charlo, MT 59824-0097 Lake

System Facility ID:24-04615

Facility Code: 22947
Last Inspected On: 11/22/2024
Operating Permit Renewal Date: 04/01/2028

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Coulter Automotive Inc **(406) 644-2215**

Operator Contact: Sandra Coulter **(406) 644-2215** **coulterauto@charlo.net**

Owner/Operator: Coulter Automotive Inc (406) 644-2215

Sandra Coulter, UST Class A Operator	coulterauto@charlo.net
Sandra Coulter, UST Class A Operator	coulterauto@charlo.net
Sandra Coulter, UST Class A Operator	coulterauto@charlo.net
Sandra Coulter, UST Class B Operator	coulterauto@charlo.net
Sandra Coulter, UST Class B Operator	coulterauto@charlo.net
Sandra Coulter, UST Class B Operator	coulterauto@charlo.net

Tank Number	03	**Tank Age**	30	**Tank Installed Date**	07/01/1995	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	2281	**Spill Test Date**	11/22/2024	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	11/22/2024	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	09/28/2022	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**	11/22/2024	**Line Tightness Test Date**	11/22/2024	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	11/22/2024			**ATG Type**	EMCO Electronics/EECO 1500				
Tank Number	04	**Tank Age**	30	**Tank Installed Date**	07/01/1995	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	2282	**Spill Test Date**	11/22/2024	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	11/22/2024	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	09/28/2022	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	11/22/2024	**Line Tightness Test Date**	11/22/2024	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No

		Overfill Test Date	11/22/2024			**ATG Type**	EMCO Electronics/EECO 1500				

Facility Summary in Lake County in the City of Charlo

Location: MOIESE MERCANTILE
64620 MT Hwy 212
Charlo, MT 59824-9004 Lake

System Facility ID:24-06382

Facility Code: 22995
Last Inspected On: 02/04/2025
Operating Permit Renewal Date: 02/04/2028

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Moiese Mercantile	**(406) 644-3454**	**debh12703@gmail.com**
Operator Contact:	Debra Hall;Moiese Mercantile;Timothy Hall	**(406) 644-3454**	**debh12703@gmail.com;debh12703@gmail.com**

Owner/Operator: Moiese Mercantile (406) 644-3454 debh12703@gmail.com

Debra Hall, UST Class A Operator debh12703@gmail.com
Leslie Muth, UST Class B Operator llafrinire@gmail.com
Timothy Hall, UST Class A Operator

Tank Number	03	**Tank Age**	26	**Tank Installed Date**	03/01/1999	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	3968	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Single Walled	**AST**	No
Status	**Temporarily Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	1000	**ATG Test Date**		**Line Tightness Test Date**	10/25/2004	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					

Facility Summary in Lake County in the City of Pablo

Location: PABLO ELEMENTARY SCHOOL
608 4th Ave
Pablo, MT 59855 Lake

System Facility ID:24-04823

Facility Code: 22952
Last Inspected On: 02/03/2025
Operating Permit Renewal Date: 10/22/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: School Dist 30 Ronan **(406) 676-3390**

Operator Contact: Brad Benson;Lawrence Cordis;Rob Tougas **(406) 250-8008** **larry.cordis@ronank12.edu;rob.tougas@ronank12.edu**

Owner/Operator: School Dist 30 Ronan (406) 676-3390

Brad Benson, UST Class A Operator
Brad Benson, UST Class B Global Operator
Lawrence Cordis, UST Class A Operator larry.cordis@ronank12.edu
Lawrence Cordis, UST Class B Global Operator larry.cordis@ronank12.edu
Rob Tougas, UST Class A Operator rob.tougas@ronank12.edu
Rob Tougas, UST Class B Global Operator rob.tougas@ronank12.edu

Tank Number	S1	**Tank Age**	59	**Tank Installed Date**	04/28/1966	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	1903	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**	Lined Interior/Impressed Current	**Piping Construction**	Double Walled	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**	10/20/2020	**Catastrophic L.D. Type 3.0**	Auto Dialer	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Heating Oil	**PLLD Test Date**		**Tank/Piping CP Test Date**	10/20/2020	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	16000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**	Veeder Root/TLS-300				
Tank Number	02	**Tank Age**	1	**Tank Installed Date**	09/01/2024	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	
Tag Number	6250	**Spill Test Date**	02/03/2025	**Piping Installed Date**	08/21/2002	**Tank Construction**		**Piping Construction**		**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	02/03/2025	**Catastrophic L.D. Type 3.0**	Auto Dialer	**Piping Type**	U.S. Suction	**CP Met Types**	
Product	Heating Oil	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No

Capacity	8000	**ATG Test Date**	02/03/2025	**Line Tightness Test Date**	07/03/2024	**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**		**Energy Act**	Yes
		Overfill Test Date	02/03/2025			**ATG Type**					

Facility Summary in Lake County in the City of Pablo

Location: QUICKSILVER EXPRESS
52001 US Hwy 93
Pablo, MT 59855 Lake

System Facility ID:24-11124

Facility Code: 23179
Last Inspected On: 01/09/2023
Operating Permit Renewal Date: 03/16/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Quick Silver Express	**(406) 675-5000**	**corky.sias@cskt.org**
Operator Contact:	Corky Sias	**(406) 275-2792**	**corky.sias@cskt.org**

Owner/Operator: Quick Silver Express (406) 675-5000 corky.sias@cskt.org

Corky Sias, UST Class A Operator corky.sias@cskt.org

Corky Sias, UST Class B Operator corky.sias@cskt.org

Tank Number	01	**Tank Age**	38	**Tank Installed Date**	01/01/1987	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve;Flapper Valve
Tag Number	3296	**Spill Test Date**	10/27/2021	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Diesel, Dyed	**PLLD Test Date**		**Tank/Piping CP Test Date**	07/21/2022	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	07/18/2023	**Line Tightness Test Date**	03/16/2017	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	02/23/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	02	**Tank Age**	38	**Tank Installed Date**	01/01/1987	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve;Flapper Valve
Tag Number	3297	**Spill Test Date**	10/27/2021	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	07/21/2022	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	07/18/2023	**Line Tightness Test Date**	03/16/2017	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	02/23/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	03	**Tank Age**	38	**Tank Installed Date**	01/01/1987	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve;Flapper Valve

Tag Number	3298	**Spill Test Date**	10/27/2021	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	07/21/2022	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	07/18/2023	**Line Tightness Test Date**	03/16/2017	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	02/23/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	04	**Tank Age**	14	**Tank Installed Date**	05/01/2011	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve;Flapper Valve
Tag Number	5344	**Spill Test Date**	10/27/2021	**Piping Installed Date**	05/01/2011	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	03/16/2017	**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	07/18/2023	**Line Tightness Test Date**	03/16/2017	**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	02/23/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Lake County in the City of Polson

Location: CHERRY VALLEY SCHOOL
107 8th Ave W
Polson, MT 59860-2911 Lake

System Facility ID:24-02867

Facility Code: 22909
Last Inspected On: 01/27/2021
Operating Permit Renewal Date: 02/19/2024

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: School Dist 23 Polson **(406) 883-6333**

Operator Contact: Dan Giles;Dan Kinyon;John Hipp **(406) 249-2564**

Dan Giles, UST Class A Operator
Dan Giles, UST Class B Operator
Dan Kinyon, UST Class A Operator
Dan Kinyon, UST Class B Operator
John Hipp, UST Class A Operator
John Hipp, UST Class B Operator

Tank Number	S2	**Tank Age**	35	**Tank Installed Date**	08/01/1990	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	1805	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Galvanic
Product	Heating Oil	**PLLD Test Date**		**Tank/Piping CP Test Date**	01/27/2021	**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**		**Line Tightness Test Date**	01/27/2021	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/ILS-250				

Facility Summary in Lake County in the City of Polson

Location: GOLDES
33537 MT Hwy 35
Polson, MT 59860 Lake

System Facility ID:60-15208

Facility Code: 30928
Last Inspected On: 03/25/2024
Operating Permit Renewal Date: 07/16/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Jeffry Goldes **(406) 443-0454**

Operator Contact: Serena Keller;Travis Schenck **(406) 837-6679;(406) 885-1530** **serena@valleymaintenance.com;travis.schenck.p@gmail.com**

Owner/Operator: Jeffry Goldes (406) 443-0454

Frank Jasper, UST Class B Operator	frank.j.jasper@gmail.com
Serena Keller, UST Class A Operator	serena@valleymaintenance.com
Serena Keller, UST Class B Operator	serena@valleymaintenance.com
Travis Schenck, UST Class A Operator	travis.schenck.p@gmail.com

Tank Number	S2	**Tank Age**	13	**Tank Installed Date**	05/01/2012	**Tank Material Construction**	Aboveground Tank	**Piping Material**	Flexible Plastic	**Overfill Types**	
Tag Number	5365	**Spill Test Date**		**Piping Installed Date**	04/17/2012	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	Yes
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	04/05/2022	**Catastrophic L.D. Type 3.0**	Continuous Interstitial Monitoring	**Piping Type**	Gravity Feed	**CP Met Types**	
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	500	**ATG Test Date**	06/15/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	Yes
		Overfill Test Date				**ATG Type**					

Facility Summary in Lake County in the City of Polson

Location: HILLTOP GAS AND GO
44613 US Hwy 93
Polson, MT 59860-7585 Lake

System Facility ID:24-07247

Facility Code: 23026
Last Inspected On: 01/20/2024
Operating Permit Renewal Date: 01/20/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Hilltop Gas and Go	**(916) 997-0412**	**jill-grove@comcast.net**
Operator Contact:	Dustin Noakes		**jill-grove@comcast.net**

Owner/Operator: Hilltop Gas and Go (916) 997-0412 jill-grove@comcast.net

Dustin Noakes, UST Class A Operator jill-grove@comcast.net

Dustin Noakes, UST Class B Operator jill-grove@comcast.net

Tank Number	04	**Tank Age**	29	**Tank Installed Date**	04/01/1996	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve
Tag Number	1215	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Temporarily Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date				**ATG Type**	Incon/TS-1000				
Tank Number	05	**Tank Age**	29	**Tank Installed Date**	04/01/1996	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve
Tag Number	1216	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Temporarily Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date				**ATG Type**	Incon/TS-1000				
Tank Number	06	**Tank Age**	29	**Tank Installed Date**	04/01/1996	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve

Tag Number	1217	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Temporarily Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	5000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date				**ATG Type**	Incon/TS-1000				

Facility Summary in Lake County in the City of Polson

Location: MOUNTAIN WEST CO OP POLSON
808 Main St
Polson, MT 59860-3227 Lake

System Facility ID:24-04560

Facility Code: 22946
Last Inspected On: 08/16/2023
Operating Permit Renewal Date: 12/02/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: CHS Mountain West Coop

Operator Contact: Bob Westin;Dusty Smith;Joseph Allard;CHS Mountain West Coop **dusty.smith@chsinc.com;Joseph.Allard@chsinc.com**

Owner/Operator: CHS Mountain West Coop

Bob Westin, UST Class A Operator	
Bob Westin, UST Class B Global Operator	
Dusty Smith, UST Class A Operator	dusty.smith@chsinc.com
Dusty Smith, UST Class B Global Operator	dusty.smith@chsinc.com
John Adams, UST Class B Operator	john.adams@chsinc.com
Joseph Allard, UST Class A Operator	Joseph.Allard@chsinc.com
Joseph Allard, UST Class B Operator	Joseph.Allard@chsinc.com

Tank Number	05	**Tank Age**	25	**Tank Installed Date**	01/01/2000	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve
Tag Number	4155	**Spill Test Date**	03/27/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	03/30/2020	**Sump Tightness Test Date**	03/27/2023	**Catastrophic L.D. Type 3.0**	Auto Dialer;Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	04/03/2023	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**	03/27/2023	**Line Tightness Test Date**	03/30/2020	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date	07/12/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	06	**Tank Age**	25	**Tank Installed Date**	01/01/2000	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve
Tag Number	4156	**Spill Test Date**	04/04/2023	**Piping Installed Date**	10/09/2013	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No

Status	**Currently in Use**	**MLLD Test Date**	03/30/2020	**Sump Tightness Test Date**	03/27/2023	**Catastrophic L.D. Type 3.0**	Auto Dialer;Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	04/03/2023	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	5000	**ATG Test Date**	03/27/2023	**Line Tightness Test Date**	03/30/2020	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date	07/12/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	08	**Tank Age**	25	**Tank Installed Date**	01/01/2000	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve
Tag Number	4648	**Spill Test Date**	03/27/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	03/30/2020	**Sump Tightness Test Date**	03/27/2023	**Catastrophic L.D. Type 3.0**	Auto Dialer;Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	04/03/2023	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	5000	**ATG Test Date**	03/27/2023	**Line Tightness Test Date**	03/30/2020	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date	07/12/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	07	**Tank Age**	25	**Tank Installed Date**	01/01/2000	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve
Tag Number	4741	**Spill Test Date**	04/04/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	03/30/2020	**Sump Tightness Test Date**	03/27/2023	**Catastrophic L.D. Type 3.0**	Auto Dialer;Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	04/03/2023	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	03/27/2023	**Line Tightness Test Date**	03/30/2020	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date	07/12/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Lake County in the City of Polson

Location: PIER 93
49433 US Hwy 93
Polson, MT 59860 Lake

System Facility ID:24-05957

Facility Code: 22988
Last Inspected On: 01/06/2025
Operating Permit Renewal Date: 06/30/2028

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Jacks Pier 93		**jacobmiller1234@outlook.com**
Operator Contact:	Donald Miller;Jacob Miller	**(406) 376-3210;(406) 883-5768**	**jacobmiller1234@outlook.com;pier93@montanasky.net**

Owner/Operator: Jacks Pier 93 jacobmiller1234@outlook.com

Donald Miller, UST Class A Operator	pier93@montanasky.net
Donald Miller, UST Class A Operator	pier93@montanasky.net
Donald Miller, UST Class B Operator	pier93@montanasky.net
Donald Miller, UST Class B Operator	pier93@montanasky.net
Jacob Miller, UST Class A Operator	jacobmiller1234@outlook.com
Jacob Miller, UST Class A Operator	jacobmiller1234@outlook.com
Jacob Miller, UST Class B Global Operator	jacobmiller1234@outlook.com
Jacob Miller, UST Class B Global Operator	jacobmiller1234@outlook.com
Jacob Miller, UST Class B Operator	jacobmiller1234@outlook.com
Jacob Miller, UST Class B Operator	jacobmiller1234@outlook.com

Tank Number	01	**Tank Age**	39	**Tank Installed Date**	04/23/1986	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	1802	**Spill Test Date**	10/03/2024	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Single Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	05/09/2024	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	04/25/2022	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	05/09/2024	**Line Tightness Test Date**	05/09/2024	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	10/03/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350				
Tank Number	02	**Tank Age**	39	**Tank Installed Date**	04/23/1986	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	1803	**Spill Test Date**	05/05/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Single Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	05/09/2024	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic

Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	04/25/2022	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**	05/09/2024	**Line Tightness Test Date**	05/09/2024	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	05/05/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350				
Tank Number	06	**Tank Age**	35	**Tank Installed Date**	11/01/1990	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	1804	**Spill Test Date**	05/05/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Single Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	05/09/2024	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	04/25/2022	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	05/09/2024	**Line Tightness Test Date**	05/09/2024	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	05/05/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Lake County in the City of Polson

Location: POLSON BAY GROCERY 425
50451 US Hwy 93
Polson, MT 59860 Lake

System Facility ID:24-05770

Facility Code: 22983
Last Inspected On: 03/02/2023
Operating Permit Renewal Date: 08/09/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Jays Corporation		**polsonbay@yahoo.com**
Operator Contact:	Jagpreet Ghuman;Jaspal Sandhu;Jays Corporation	**(406) 880-7677**	**jas_sandhu75@hotmail.com;polsonbay@yahoo.com;jaysfood08@outlook.com**

Owner/Operator: Jays Corporation polsonbay@yahoo.com

Jagpreet Ghuman, UST Class A Operator	jaysfood08@outlook.com
Jagpreet Ghuman, UST Class A Operator	jaysfood08@outlook.com
Jagpreet Ghuman, UST Class B Operator	jays1stop21@outlook.com
Jagpreet Ghuman, UST Class B Operator	jays1stop21@outlook.com
Jaspal Sandhu, UST Class A Operator	polsonbay@yahoo.com
Jaspal Sandhu, UST Class B Operator	polsonbay@yahoo.com

Tank Number	04	**Tank Age**	23	**Tank Installed Date**	05/23/2002	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	4664	**Spill Test Date**	06/22/2021	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	04/28/2021	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	03/05/2020	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	20000	**ATG Test Date**	02/15/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	02/25/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	05	**Tank Age**	23	**Tank Installed Date**	05/23/2002	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	4665	**Spill Test Date**	06/22/2021	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	06/23/2013	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	03/05/2020	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No

Capacity	10000	**ATG Test Date**	02/15/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	02/25/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	06	**Tank Age**	23	**Tank Installed Date**	05/23/2002	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	4666	**Spill Test Date**	04/28/2021	**Piping Installed Date**	10/30/2018	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	04/28/2021	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	03/05/2020	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**	02/15/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date	02/15/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	07	**Tank Age**	23	**Tank Installed Date**	05/23/2002	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	4667	**Spill Test Date**	04/28/2021	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	06/23/2013	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	03/05/2020	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	02/15/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	02/25/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Lake County in the City of Polson

Location: POLSON COUNTRY CLUB
111 Bayview Dr
Polson, MT 59860-9609 Lake

System Facility ID:24-11824

Facility Code: 23227
Last Inspected On: 08/17/2022
Operating Permit Renewal Date: 11/08/2025

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: City of Polson **(406) 883-2131**

Operator Contact: Natalia Arlint;Patrick Nowlen **(406) 249-5141** **narlint@cityofpolson.com;polsonshop@centurytel.net**

Owner/Operator: City of Polson (406) 883-2131

Natalia Arlint, UST Class A Operator narlint@cityofpolson.com
Patrick Nowlen, UST Class A Operator polsonshop@centurytel.net
Patrick Nowlen, UST Class B Operator polsonshop@centurytel.net

Tank Number	01	**Tank Age**	35	**Tank Installed Date**	08/14/1990	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	647	**Spill Test Date**	08/17/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	08/17/2022	**Primary Tank Leak Detection**	Manual Tank Gauging	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	500	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	08/17/2022			**ATG Type**					

Facility Summary in Lake County in the City of Polson

Location: SAFEWAY FUEL STATION 1646
40772 MT Hwy 35
Polson, MT 59860 Lake

System Facility ID:60-15097

Facility Code: 30857
Last Inspected On: 12/27/2023
Operating Permit Renewal Date: 03/28/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Safeway Stores Inc

Operator Contact: Aaron Nelson;Cindy Standbrook;Lynn Pehrson;Rachel Jones **(208) 395-3269;(406) 883-2340;(425) 201-6301** **cinderella@ronan.net;ltollison@yokesfoods.com;rachel.jones@albertsons.com**

Owner/Operator: Safeway Stores Inc

Aaron Nelson, UST Class A Operator	
Cindy Standbrook, UST Class A Operator	cinderella@ronan.net
Cindy Stankbrook, UST Class B Global Operator	
Heidi Morgan, UST Class B Global Operator	
Lynn Pehrson, UST Class A Operator	ltollison@yokesfoods.com
Rachel Jones , UST Class A Operator	rachel.jones@albertsons.com
Rachel Jones , UST Class B Global Operator	rachel.jones@albertsons.com

Tank Number	01	**Tank Age**	17	**Tank Installed Date**	05/22/2008	**Tank Material Construction**	Steel Clad	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	5164	**Spill Test Date**	09/28/2022	**Piping Installed Date**	04/04/2008	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	09/28/2022	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Gasoline	**PLLD Test Date**	05/31/2023	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	20000	**ATG Test Date**	05/31/2023	**Line Tightness Test Date**	09/28/2022	**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	Yes
		Overfill Test Date	12/27/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	02	**Tank Age**	17	**Tank Installed Date**	05/22/2008	**Tank Material Construction**	Steel Clad	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	5165	**Spill Test Date**	09/28/2022	**Piping Installed Date**	04/04/2008	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	09/28/2022	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	05/31/2023	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No

Capacity	10000	**ATG Test Date**	05/31/2023	**Line Tightness Test Date**	09/28/2022	**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	Yes
		Overfill Test Date	12/27/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	03	**Tank Age**	17	**Tank Installed Date**	05/22/2008	**Tank Material Construction**	Steel Clad	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	5166	**Spill Test Date**	09/28/2022	**Piping Installed Date**	04/04/2008	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	09/28/2022	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	05/31/2023	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	05/31/2023	**Line Tightness Test Date**	09/28/2022	**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	Yes
		Overfill Test Date	12/27/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Lake County in the City of Polson

Location: TOWN PUMP INC POLSON
50667 US Hwy 93
Polson, MT 59860 Lake

System Facility ID:24-08717

Facility Code: 23066
Last Inspected On: 03/29/2023
Operating Permit Renewal Date: 09/29/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Polson 1 Town Pump LLC	**(406) 497-6700**	**environmental@townpump.com**
Operator Contact:	Trent Biggers		**Trentb@townpump.com**

Owner/Operator:	Polson 1 Town Pump LLC	(406) 497-6700	environmental@townpump.com
	Trent Biggers, UST Class A Operator		Trentb@townpump.com
	Trent Biggers, UST Class A Operator		Trentb@townpump.com
	Trent Biggers, UST Class B Global Operator		Trentb@townpump.com
	Trent Biggers, UST Class B Global Operator		Trentb@townpump.com

Tank Number	01	**Tank Age**	43	**Tank Installed Date**	09/01/1982	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	2490	**Spill Test Date**	08/23/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	05/06/2021	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	08/23/2022	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	03/29/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	08/23/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-450				
Tank Number	02	**Tank Age**	43	**Tank Installed Date**	09/01/1982	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	2491	**Spill Test Date**	08/23/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	05/06/2021	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	08/23/2022	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	03/29/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No

		Overfill Test Date	08/23/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-450				
Tank Number	03	**Tank Age**	43	**Tank Installed Date**	09/01/1982	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	2492	**Spill Test Date**	08/23/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	05/06/2021	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	08/23/2022	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	03/29/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	08/23/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-450				
Tank Number	04	**Tank Age**	43	**Tank Installed Date**	09/01/1982	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	2493	**Spill Test Date**	08/23/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	05/06/2021	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	08/23/2022	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	03/29/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	08/23/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-450				
Tank Number	05	**Tank Age**	43	**Tank Installed Date**	09/01/1982	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	2494	**Spill Test Date**	08/23/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	05/06/2021	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	08/23/2022	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	03/29/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	08/23/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-450				
Tank Number	11	**Tank Age**	23	**Tank Installed Date**	10/24/2002	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve

Tag Number	4819	**Spill Test Date**	08/23/2022	**Piping Installed Date**	10/24/2002	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	05/06/2021	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	01/04/2010	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	03/29/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	Yes
		Overfill Test Date	08/23/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-450				
Tank Number	12	**Tank Age**	23	**Tank Installed Date**	10/24/2002	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve
Tag Number	4820	**Spill Test Date**	08/23/2022	**Piping Installed Date**	10/24/2002	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	05/06/2021	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	01/04/2010	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	5000	**ATG Test Date**	08/23/2022	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	Yes
		Overfill Test Date	08/23/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-450				
Tank Number	13	**Tank Age**	8	**Tank Installed Date**	11/09/2017	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Positive Shutoff
Tag Number	5782	**Spill Test Date**	08/23/2022	**Piping Installed Date**	11/09/2017	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	05/06/2021	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	Yes
Capacity	4000	**ATG Test Date**	03/29/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Statistical Inventory Reconciliation	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	Yes
		Overfill Test Date	08/23/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-450				
Tank Number	14	**Tank Age**	8	**Tank Installed Date**	11/09/2017	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Positive Shutoff
Tag Number	5791	**Spill Test Date**		**Piping Installed Date**	11/09/2017	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Other**	**MLLD Test Date**		**Sump Tightness Test Date**	11/09/2017	**Catastrophic L.D. Type 3.0**	Continuous Interstitial Monitoring	**Piping Type**	Pressurized	**CP Met Types**	

Product	DEF (Not Regulated)	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Approved Remote Monitoring;Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	2000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring;Not Listed	**Energy Act**	Yes
		Overfill Test Date				**ATG Type**					

Facility Summary in Lake County in the City of Polson

Location: U OF M FLATHEAD LAKE BIOLOGICAL STATION
32125 Bio Station Ln
Polson, MT 59860 Lake

System Facility ID:24-00507

Facility Code: 22853
Last Inspected On: 12/21/2020
Operating Permit Renewal Date: 01/14/2021

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	University of Montana Flathead Lake Biological Station	**(406) 982-3301**	**mark.potter@umontana.edu**
Operator Contact:	Eric Anderson	**(406) 982-3301**	**eric.anderson@umontana.edu**

Owner/Operator:	University of Montana Flathead Lake Biological Station	(406) 982-3301	mark.potter@umontana.edu
	C Anderson, UST Class B Operator		eric.anderson@umontana.edu
	Eric Anderson, UST Class A Operator		eric.anderson@umontana.edu
	Reggie Heiser, UST Class B Operator		

Tank Number	05	**Tank Age**	34	**Tank Installed Date**	03/15/1991	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	2185	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	U.S. Suction	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	08/08/2017	**Primary Tank Leak Detection**	Manual Interstitial Monitoring	**Primary Pipe Leak Detection**	ELLD Line Tightness Testing;Not Listed	**Vapor Recovery**	No
Capacity	2000	**ATG Test Date**		**Line Tightness Test Date**	08/18/2017	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	S6	**Tank Age**	34	**Tank Installed Date**	03/15/1991	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	2186	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Temporarily Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**	12/21/2020	**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	U.S. Suction	**CP Met Types**	Galvanic
Product	Heating Oil	**PLLD Test Date**		**Tank/Piping CP Test Date**	12/21/2020	**Primary Tank Leak Detection**	Manual Interstitial Monitoring	**Primary Pipe Leak Detection**	3-Year Line Tightness Test	**Vapor Recovery**	No
Capacity	2000	**ATG Test Date**		**Line Tightness Test Date**	12/21/2020	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Manual Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date				**ATG Type**					

Facility Summary in Lake County in the City of Ravalli

Location: RAVALLI STORE
205 Buffalo St
Ravalli, MT 59863 Lake

System Facility ID:24-09997

Facility Code: 23099
Last Inspected On: 12/17/2020
Operating Permit Renewal Date: 12/17/2023

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Kenneth Cameron	**(208) 315-3517**	**kcameron8120@gmail.com**
Operator Contact:	Stacy Harris	**(406) 239-0655**	**theone872@hotmail.com**

Stacy Harris, UST Class A Operator	theone872@hotmail.com
Stacy Harris, UST Class A Operator	theone872@hotmail.com
Stacy Harris, UST Class B Global Operator	theone872@hotmail.com
Stacy Harris, UST Class B Global Operator	theone872@hotmail.com

Tank Number	01	**Tank Age**	36	**Tank Installed Date**	09/01/1989	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Positive Shutoff
Tag Number	3464	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	12/03/2020	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.1;Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	2000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	02	**Tank Age**	36	**Tank Installed Date**	09/01/1989	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Positive Shutoff
Tag Number	3465	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	12/03/2020	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.1;Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	2000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No

		Overfill Test Date				**ATG Type**					
Tank Number	03	**Tank Age**	36	**Tank Installed Date**	09/01/1989	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Positive Shutoff
Tag Number	3466	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	12/03/2020	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.1;Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	2000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					

Facility Summary in Lake County in the City of Rollins

Location: POINTS NORTH TRADING CO
87867 US Hwy 93
Rollins, MT 59931 Lake

System Facility ID:24-12730

Facility Code: 23274
Last Inspected On: 05/01/2025
Operating Permit Renewal Date: 07/22/2028

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Points North of Rollins LLC	**(406) 250-7058**	**pointsnorth01@yahoo.com**
Operator Contact:	Michael Serra;Thomas Gay	**(406) 250-7058;(406) 844-3942**	**mikeserra20@gmail.com;tomnjule@aboutmontana.net**

Owner/Operator: Points North of Rollins LLC (406) 250-7058 pointsnorth01@yahoo.com

Michael Serra, UST Class A Operator mikeserra20@gmail.com
Michael Serra, UST Class B Global Operator mikeserra20@gmail.com
Thomas A Gay, UST Class A Operator tomnjule@aboutmontana.net
Thomas A Gay, UST Class B Operator tomnjule@aboutmontana.net

Tank Number	03	**Tank Age**	30	**Tank Installed Date**	06/01/1995	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	3095	**Spill Test Date**	05/31/2024	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	05/01/2025	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	05/28/2024	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	05/01/2025	**Line Tightness Test Date**	05/01/2025	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	05/01/2025			**ATG Type**	EMCO Electronics/EECO 1500				
Tank Number	04	**Tank Age**	30	**Tank Installed Date**	06/01/1995	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	3096	**Spill Test Date**	05/31/2024	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	05/01/2025	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	05/28/2024	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	05/01/2025	**Line Tightness Test Date**	05/01/2025	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	05/01/2025			**ATG Type**	EMCO Electronics/EECO 1500				

Tank Number	05	**Tank Age**	30	**Tank Installed Date**	06/01/1995	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	3097	**Spill Test Date**	05/31/2024	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	05/01/2025	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	05/28/2024	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	05/01/2025	**Line Tightness Test Date**	05/01/2025	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	05/01/2025			**ATG Type**	EMCO Electronics/EECO 1500				

Facility Summary in Lake County in the City of Ronan

Location: ARNIES GAS AND TIRE CENTER INC
63145 US Hwy 93
Ronan, MT 59864-2808 Lake

System Facility ID:24-05517

Facility Code: 22970
Last Inspected On: 05/02/2023
Operating Permit Renewal Date: 08/15/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Arnies Gas and Tire Center Inc	**(406) 675-0400**	**arniesgt@gmail.com**
Operator Contact:	Amanda Hackman;Denise Aipperspach	**(406) 676-0400**	

Owner/Operator: Arnies Gas and Tire Center Inc (406) 675-0400 arniesgt@gmail.com

Amanda Hackman, UST Class A Operator
Amanda Hackman, UST Class A Operator
Amanda Hackman, UST Class B Global Operator
Amanda Hackman, UST Class B Global Operator
Denise Aipperspach, UST Class A Operator
Denise Aipperspach, UST Class A Operator
Denise Aipperspach, UST Class B Global Operator
Denise Aipperspach, UST Class B Global Operator
Denise Aipperspach, UST Class B Operator
Denise Aipperspach, UST Class B Operator

Tank Number	04	**Tank Age**	47	**Tank Installed Date**	05/07/1978	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	3888	**Spill Test Date**	05/02/2023	**Piping Installed Date**		**Tank Construction**	Lined Interior/Impressed Current	**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	05/02/2023	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	05/02/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	05/02/2023	**Line Tightness Test Date**	05/02/2023	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	05/02/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	03	**Tank Age**	54	**Tank Installed Date**	05/08/1971	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	3889	**Spill Test Date**	05/02/2023	**Piping Installed Date**		**Tank Construction**	Lined Interior/Impressed Current	**Piping Construction**	None	**AST**	No

Status	**Currently in Use**	**MLLD Test Date**	05/02/2023	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Diesel, Dyed	**PLLD Test Date**		**Tank/Piping CP Test Date**	05/02/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	05/02/2023	**Line Tightness Test Date**	05/02/2023	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	05/02/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	02	**Tank Age**	54	**Tank Installed Date**	05/08/1971	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	3890	**Spill Test Date**	05/02/2023	**Piping Installed Date**		**Tank Construction**	Lined Interior/Impressed Current	**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	05/02/2023	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	05/02/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**	05/02/2023	**Line Tightness Test Date**	05/02/2023	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	05/02/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	01	**Tank Age**	54	**Tank Installed Date**	05/08/1971	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	3891	**Spill Test Date**	05/02/2023	**Piping Installed Date**		**Tank Construction**	Lined Interior/Impressed Current	**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	05/02/2023	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	05/02/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	05/02/2023	**Line Tightness Test Date**	05/02/2023	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	05/02/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Lake County in the City of Ronan

Location: DYNO MART
62945 Hwy 93 N
Ronan, MT 59864 Lake

System Facility ID:24-05768

Facility Code: 22981
Last Inspected On: 04/24/2023
Operating Permit Renewal Date: 09/08/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	One Stop 3 Inc Loc 2	**(406) 676-3570**	**onestop3gm@yahoo.com**
Operator Contact:	Maureen McCrea;Tom Hoyt	**(406) 274-5536**	**dynomart1@yahoo.com**

Owner/Operator:	One Stop 3 Inc Loc 2	(406) 676-3570	onestop3gm@yahoo.com
	Gail Matt, UST Class B Global Operator		dynomart1@yahoo.com
	Gail Matt, UST Class B Global Operator		dynomart1@yahoo.com
	Gail Matt, UST Class B Operator		dynomart1@yahoo.com
	Gail Matt, UST Class B Operator		dynomart1@yahoo.com
	Maureen McCrea, UST Class A Operator		dynomart1@yahoo.com
	Maureen McCrea, UST Class A Operator		dynomart1@yahoo.com
	Tom Hoyt, UST Class A Operator		dynomart1@yahoo.com
	Tom Hoyt, UST Class A Operator		dynomart1@yahoo.com
	Tom Hoyt, UST Class B Operator		dynomart1@yahoo.com
	Tom Hoyt, UST Class B Operator		dynomart1@yahoo.com

Tank Number	01	**Tank Age**	41	**Tank Installed Date**	11/13/1984	**Tank Material Construction**	Bare Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	1315	**Spill Test Date**	08/05/2020	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	07/30/2019	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	03/27/2019	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**		**Line Tightness Test Date**	07/30/2019	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	02	**Tank Age**	41	**Tank Installed Date**	11/13/1984	**Tank Material Construction**	Bare Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	1316	**Spill Test Date**	03/27/2019	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	07/30/2019	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current

Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	03/27/2019	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**		**Line Tightness Test Date**	07/30/2019	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	03/27/2019			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	03	**Tank Age**	33	**Tank Installed Date**	04/01/1992	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	1317	**Spill Test Date**	03/27/2019	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	07/30/2019	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	03/27/2019	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**		**Line Tightness Test Date**	07/30/2019	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	03/27/2019			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Lake County in the City of Ronan

Location: EAST OF RONAN MIDDLE SCHOOL
200 Round Butte Rd W
Ronan, MT 59864 Lake

System Facility ID:24-04824

Facility Code: 22953
Last Inspected On: 05/25/2023
Operating Permit Renewal Date: 09/13/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: School Dist 30 Ronan **(406) 676-3390**

Operator Contact: Brad Benson;Lawrence Cordis;Rob Tougas **(406) 250-8008** **larry.cordis@ronank12.edu;rob.tougas@ronank12.edu**

Owner/Operator: School Dist 30 Ronan (406) 676-3390

Brad Benson, UST Class A Operator	
Brad Benson, UST Class B Global Operator	
Lawrence Cordis, UST Class A Operator	larry.cordis@ronank12.edu
Lawrence Cordis, UST Class B Global Operator	larry.cordis@ronank12.edu
Matt Gaut, UST Class B Operator	matt.gaut@ronank12.edu
Rob Tougas, UST Class A Operator	rob.tougas@ronank12.edu
Rob Tougas, UST Class B Global Operator	rob.tougas@ronank12.edu

Tank Number	S5	**Tank Age**	29	**Tank Installed Date**	08/01/1996	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Copper	**Overfill Types**	Flapper Valve
Tag Number	1904	**Spill Test Date**	05/25/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Secondary Containment Chase	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	05/25/2023	**Catastrophic L.D. Type 3.0**	Auto Dialer	**Piping Type**	U.S. Suction	**CP Met Types**	Non-corrodible
Product	Heating Oil	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	05/25/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	05/25/2023			**ATG Type**	Gilbarco-Veeder Root/Other				

Facility Summary in Lake County in the City of Ronan

Location: JOHNS FUEL FARM AND ENERGY
14 Cleveland St SE
Ronan, MT 59864-3027 Lake

System Facility ID:24-07437

Facility Code: 23032
Last Inspected On: 11/20/2024
Operating Permit Renewal Date: 04/26/2028

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Johns Fuel Farm and Energy		**hans.lund@tradhm.com**
Operator Contact:	Hans Lund;John Noel;Leevi Wadsworth	**(406) 261-7956**	**fuelfarm@ronan.net;hans.lund@johnsfuelfarm.com;leevij@hotmail.co**

Owner/Operator: Johns Fuel Farm and Energy — hans.lund@tradhm.com

Hans Lund, UST Class A Operator	hans.lund@johnsfuelfarm.com
Hans Lund, UST Class A Operator	hans.lund@johnsfuelfarm.com
Hans Lund, UST Class B Operator	hans.lund@johnsfuelfarm.com
Hans Lund, UST Class B Operator	hans.lund@johnsfuelfarm.com
John Noel, UST Class A Operator	fuelfarm@ronan.net
John Noel, UST Class A Operator	fuelfarm@ronan.net
John Noel, UST Class B Global Operator	fuelfarm@ronan.net
John Noel, UST Class B Global Operator	fuelfarm@ronan.net
Leevi Wadsworth, UST Class A Operator	leevij@hotmail.co
Leevi Wadsworth, UST Class A Operator	leevij@hotmail.co
Leevi Wadsworth, UST Class B Operator	leevij@hotmail.co
Leevi Wadsworth, UST Class B Operator	leevij@hotmail.co

Tank Number	01	**Tank Age**	64	**Tank Installed Date**	04/23/1961	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Steel	**Overfill Types**	High Level Alarm
Tag Number	3394	**Spill Test Date**	08/21/2024	**Piping Installed Date**	08/10/2009	**Tank Construction**	Lined Interior/Impressed Current	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	08/21/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**	08/21/2024	**Tank/Piping CP Test Date**	11/20/2024	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	08/21/2024	**Line Tightness Test Date**	08/30/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	08/21/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350				
Tank Number	02	**Tank Age**	0	**Tank Installed Date**		**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Steel	**Overfill Types**	High Level Alarm

Tag Number	3395	**Spill Test Date**	08/21/2024	**Piping Installed Date**	08/10/2009	**Tank Construction**	Lined Interior/Impressed Current	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	08/21/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Diesel	**PLLD Test Date**	08/21/2024	**Tank/Piping CP Test Date**	11/20/2024	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	08/21/2024	**Line Tightness Test Date**	08/30/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	08/21/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350				
Tank Number	03	**Tank Age**	54	**Tank Installed Date**	04/24/1971	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Steel	**Overfill Types**	High Level Alarm
Tag Number	3396	**Spill Test Date**	10/04/2021	**Piping Installed Date**	08/10/2009	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	10/26/2021	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	08/30/2022	**Tank/Piping CP Test Date**	10/26/2021	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	08/30/2022	**Line Tightness Test Date**	08/30/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	08/30/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350				
Tank Number	04	**Tank Age**	54	**Tank Installed Date**	04/24/1971	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	3397	**Spill Test Date**	10/04/2021	**Piping Installed Date**	08/10/2009	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	10/26/2021	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	08/30/2022	**Tank/Piping CP Test Date**	10/26/2021	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	08/30/2022	**Line Tightness Test Date**	08/30/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	08/30/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350				
Tank Number	05	**Tank Age**	54	**Tank Installed Date**	04/24/1971	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Steel	**Overfill Types**	High Level Alarm
Tag Number	3398	**Spill Test Date**	10/04/2021	**Piping Installed Date**	08/10/2009	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	10/26/2021	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	08/30/2022	**Tank/Piping CP Test Date**	10/26/2021	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No

Capacity	6000	**ATG Test Date**	08/30/2022	**Line Tightness Test Date**	08/30/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	08/30/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350				
Tank Number	06	**Tank Age**	64	**Tank Installed Date**	04/23/1961	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Steel	**Overfill Types**	High Level Alarm
Tag Number	3399	**Spill Test Date**	10/04/2021	**Piping Installed Date**	08/10/2009	**Tank Construction**	Lined Interior/Impressed Current	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	10/26/2021	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**	08/30/2022	**Tank/Piping CP Test Date**	10/26/2021	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**	08/30/2022	**Line Tightness Test Date**	08/30/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	08/30/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Lake County in the City of Ronan

Location: MOUNTAIN WEST CENEX
63980 Us Hwy 93
Ronan, MT 59864 Lake

System Facility ID:00-32579

Facility Code: 32579
Last Inspected On:
Operating Permit Renewal Date: 10/14/2025

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: CHS Mountain West

Operator Contact: Joseph Allard;CHS Mountain West Coop **Joseph.Allard@chsinc.com**

Owner/Operator: CHS Mountain West

Joseph Allard, UST Class A Operator Joseph.Allard@chsinc.com
Joseph Allard, UST Class B Operator Joseph.Allard@chsinc.com

Tank Number	01	**Tank Age**	1	**Tank Installed Date**	10/10/2024	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	6260	**Spill Test Date**	12/10/2024	**Piping Installed Date**	04/10/2025	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	11/13/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Gasoline	**PLLD Test Date**	04/14/2025	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	Yes
Capacity	20000	**ATG Test Date**	04/01/2025	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	04/01/2025			**ATG Type**					
Tank Number	02	**Tank Age**	1	**Tank Installed Date**	10/10/2024	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	6261	**Spill Test Date**	12/10/2024	**Piping Installed Date**	04/10/2025	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	11/13/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Gasoline	**PLLD Test Date**	04/14/2025	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	Yes
Capacity	12000	**ATG Test Date**	04/01/2025	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	04/01/2025			**ATG Type**					
Tank Number	03	**Tank Age**	1	**Tank Installed Date**	10/10/2024	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve

Tag Number	6262	**Spill Test Date**	12/10/2024	**Piping Installed Date**	04/10/2025	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	11/13/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Diesel, Dyed	**PLLD Test Date**	04/14/2025	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	04/01/2025	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	04/01/2025			**ATG Type**					
Tank Number	04	**Tank Age**	1	**Tank Installed Date**	10/10/2024	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	6263	**Spill Test Date**	12/10/2024	**Piping Installed Date**	04/10/2025	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	11/13/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Diesel	**PLLD Test Date**	04/14/2025	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	20000	**ATG Test Date**	04/01/2025	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	04/01/2025			**ATG Type**					
Tank Number	05	**Tank Age**	1	**Tank Installed Date**	10/10/2024	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	6264	**Spill Test Date**	12/10/2024	**Piping Installed Date**	04/10/2025	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	11/13/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Diesel, Dyed	**PLLD Test Date**	04/14/2025	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	20000	**ATG Test Date**	04/01/2025	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	04/01/2025			**ATG Type**					
Tank Number	06	**Tank Age**	1	**Tank Installed Date**	10/10/2024	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	6265	**Spill Test Date**	12/10/2024	**Piping Installed Date**	04/10/2025	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	11/13/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Diesel	**PLLD Test Date**	04/14/2025	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No

Capacity	20000	**ATG Test Date**	04/01/2025	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	04/01/2025			**ATG Type**					
Tank Number	07	**Tank Age**	1	**Tank Installed Date**	10/10/2024	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	6266	**Spill Test Date**	12/10/2024	**Piping Installed Date**	04/10/2025	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	11/13/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Diesel	**PLLD Test Date**	04/14/2025	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	20000	**ATG Test Date**	04/01/2025	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	04/01/2025			**ATG Type**					

Facility Summary in Lake County in the City of Ronan

Location: MOUNTAIN WEST CO OP RONAN
63932 US Hwy 93
Ronan, MT 59864 Lake

System Facility ID:24-04530

Facility Code: 22944
Last Inspected On: 09/13/2022
Operating Permit Renewal Date: 12/19/2025

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: CHS Mountain West Coop

Operator Contact: Bob Westin;Dusty Smith;John Thompson;Joseph Allard;CHS Mountain West Coop;Will Dukart | **(406) 665-1728;(406) 880-8169** | **chuck.thompson@chsinc.com;dusty.smith@chsinc.com;Joseph.Allard@chsinc.com;will.dukart@chsinc.com**

Owner/Operator: CHS Mountain West Coop

Bob Westin, UST Class A Operator	
Bob Westin, UST Class B Global Operator	
Carrie Clairmont, UST Class B Operator	carrie.clairmont@chsinc.com
Dusty Smith, UST Class A Operator	dusty.smith@chsinc.com
Dusty Smith, UST Class B Global Operator	dusty.smith@chsinc.com
John Thompson, UST Class A Operator	chuck.thompson@chsinc.com
John Thompson, UST Class A Operator	chuck.thompson@chsinc.com
John Thompson, UST Class B Global Operator	chuck.thompson@chsinc.com
John Thompson, UST Class B Global Operator	chuck.thompson@chsinc.com
John Thompson, UST Class B Operator	chuck.thompson@chsinc.com
John Thompson, UST Class B Operator	chuck.thompson@chsinc.com
Joseph Allard, UST Class A Operator	Joseph.Allard@chsinc.com
Joseph Allard, UST Class B Operator	Joseph.Allard@chsinc.com
Will Dukart, UST Class A Operator	will.dukart@chsinc.com
Will Dukart, UST Class A Operator	will.dukart@chsinc.com
Will Dukart, UST Class B Global Operator	will.dukart@chsinc.com
Will Dukart, UST Class B Global Operator	will.dukart@chsinc.com

Tank Number	09	**Tank Age**	28	**Tank Installed Date**	05/01/1997	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	2829	**Spill Test Date**	03/09/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	05/21/2019	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	09/13/2022	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	Yes
Capacity	10000	**ATG Test Date**	09/13/2022	**Line Tightness Test Date**	09/13/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.1	**Energy Act**	No

		Overfill Test Date	09/13/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350				
Tank Number	10	**Tank Age**	28	**Tank Installed Date**	05/01/1997	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	2830	**Spill Test Date**	03/09/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	05/21/2019	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	09/13/2022	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	Yes
Capacity	4000	**ATG Test Date**	09/13/2022	**Line Tightness Test Date**	09/13/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.1	**Energy Act**	No
		Overfill Test Date	09/13/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350				
Tank Number	11	**Tank Age**	28	**Tank Installed Date**	05/01/1997	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	2831	**Spill Test Date**	03/09/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	05/21/2019	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	09/13/2022	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	09/13/2022	**Line Tightness Test Date**	09/13/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.1	**Energy Act**	No
		Overfill Test Date	09/13/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350				
Tank Number	12	**Tank Age**	28	**Tank Installed Date**	05/01/1997	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	2832	**Spill Test Date**	03/09/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	05/21/2019	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel, Dyed	**PLLD Test Date**	09/13/2022	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**	09/13/2022	**Line Tightness Test Date**	09/13/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.1	**Energy Act**	No
		Overfill Test Date	09/13/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350				
Tank Number	13	**Tank Age**	28	**Tank Installed Date**	05/01/1997	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	2833	**Spill Test Date**	03/09/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	05/21/2019	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	09/13/2022	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No

Capacity	5000	**ATG Test Date**	09/13/2022	**Line Tightness Test Date**	09/13/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.1	**Energy Act**	No
		Overfill Test Date	09/13/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Lake County in the City of Ronan

Location: RONAN AIRPORT
35564 Ronan Airport Rd
Ronan, MT 59864-9267 Lake

System Facility ID:24-04649

Facility Code: 22948
Last Inspected On: 05/01/2024
Operating Permit Renewal Date: 10/22/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Lake County Joint Airport Board **(406) 883-7214**

Operator Contact: Vinson Jennison **vinsu@centurytel.net**

Owner/Operator: Lake County Joint Airport Board (406) 883-7214

Vinson Jennison, UST Class A Operator vinsu@centurytel.net

Vinson Jennison, UST Class B Global Operator vinsu@centurytel.net

Tank Number	02	**Tank Age**	26	**Tank Installed Date**	04/01/1999	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve;High Level Alarm
Tag Number	3984	**Spill Test Date**	05/31/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	08/02/2019	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Jet Fuel (Jet-A, Jet-A1, JP5)	**PLLD Test Date**	03/20/2024	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	03/20/2024	**Line Tightness Test Date**	03/03/2023	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	05/31/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Number	03	**Tank Age**	26	**Tank Installed Date**	04/01/1999	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve;High Level Alarm
Tag Number	3985	**Spill Test Date**	05/31/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	08/02/2019	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Aviation Gas	**PLLD Test Date**	03/20/2024	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	03/20/2024	**Line Tightness Test Date**	03/03/2023	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	05/31/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				

Facility Summary in Lake County in the City of Ronan

Location: ST LUKE COMMUNITY CLINIC- RONAN
107 6th Ave SW
Ronan, MT 59864 Lake

System Facility ID:24-03736

Facility Code: 22926
Last Inspected On: 06/20/2023
Operating Permit Renewal Date: 10/16/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Saint Luke Hospital		**gburdett@stlukehealthnet.org**
Operator Contact:	Gary Burdett;Nicholas Emerson;Steven DeLay	**(406) 240-5240;(406) 676-4441**	**gburdett@stlukeheathnet.org;nemerson@stlukehealthcare.org;sdelay57@gmail.com**

Owner/Operator: Saint Luke Hospital gburdett@stlukehealthnet.org

Gary Burdett, UST Class A Operator	gburdett@stlukeheathnet.org
Gary Burdett, UST Class B Operator	gburdett@stlukeheathnet.org
Nicholas Emerson, UST Class A Operator	nemerson@stlukehealthcare.org
Nicholas Emerson, UST Class B Operator	nemerson@stlukehealthcare.org
Steven DeLay, UST Class A Operator	sdelay57@gmail.com
Steven DeLay, UST Class B Operator	sdelay57@gmail.com

Tank Number	S3	**Tank Age**	26	**Tank Installed Date**	11/01/1999	**Tank Material Construction**	Unknown	**Piping Material**	Copper	**Overfill Types**	
Tag Number	4369	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Secondary Containment Chase	**AST**	Yes
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	08/25/2020	**Catastrophic L.D. Type 3.0**	Auto Dialer	**Piping Type**	U.S. Suction	**CP Met Types**	
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	2000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					

Facility Summary in Lake County in the City of Ronan

Location: TOWN PUMP INC RONAN
63459 US Hwy 93
Ronan, MT 59864-3007 Lake

System Facility ID:24-08718

Facility Code: 23067
Last Inspected On: 03/29/2023
Operating Permit Renewal Date: 09/30/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Ronan 1 Town Pump LLC	**(406) 497-6700**	**environmental@townpump.com**
Operator Contact:	Trent Biggers		**Trentb@townpump.com**

Owner/Operator: Ronan 1 Town Pump LLC (406) 497-6700 environmental@townpump.com

Trent Biggers, UST Class A Operator Trentb@townpump.com

Trent Biggers, UST Class B Global Operator Trentb@townpump.com

Tank Number	01	**Tank Age**	53	**Tank Installed Date**	04/14/1972	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	4822	**Spill Test Date**	08/22/2022	**Piping Installed Date**		**Tank Construction**	Lined Interior/Impressed Current	**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	12/06/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**	05/13/2021	**Tank/Piping CP Test Date**	08/22/2022	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	10/24/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	08/22/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Number	02	**Tank Age**	53	**Tank Installed Date**	04/14/1972	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	4823	**Spill Test Date**	08/22/2022	**Piping Installed Date**		**Tank Construction**	Lined Interior/Impressed Current	**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	12/06/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**	05/13/2021	**Tank/Piping CP Test Date**	08/22/2022	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	10/24/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No

		Overfill Test Date	08/22/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Number	03	**Tank Age**	53	**Tank Installed Date**	04/14/1972	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	4824	**Spill Test Date**	08/22/2022	**Piping Installed Date**		**Tank Construction**	Lined Interior/Impressed Current	**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	12/06/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**	05/13/2021	**Tank/Piping CP Test Date**	08/22/2022	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**	10/24/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	08/22/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Number	04	**Tank Age**	45	**Tank Installed Date**	04/14/1980	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	4825	**Spill Test Date**	08/22/2022	**Piping Installed Date**		**Tank Construction**	Lined Interior/Impressed Current	**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	12/06/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Diesel	**PLLD Test Date**	05/13/2021	**Tank/Piping CP Test Date**	08/22/2022	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**	10/24/2024	**Line Tightness Test Date**	09/19/2024	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	08/22/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Number	05	**Tank Age**	18	**Tank Installed Date**	07/05/2007	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve;Flapper Valve
Tag Number	5073	**Spill Test Date**	08/22/2022	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	05/13/2021	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	10/24/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	08/22/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				

Facility Summary in Lake County in the City of Saint Ignatius

Location: ALLARDS STAGE STOP LLC
77579 US Hwy 93 N
Saint Ignatius, MT 59865-0460 Lake

System Facility ID:24-05769

Facility Code: 22982
Last Inspected On: 01/25/2024
Operating Permit Renewal Date: 03/13/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Mission View Properties LLC	**(509) 994-6599**	**histarms01@yahoo.com**
Operator Contact:	Mamie Ahlborn	**(406) 207-2810**	**mamie_ahlborn@hotmail.com**

Owner/Operator: Mission View Properties LLC (509) 994-6599 histarms01@yahoo.com

Mamie Ahlborn, UST Class A Operator mamie_ahlborn@hotmail.com
Mamie Ahlborn, UST Class A Operator mamie_ahlborn@hotmail.com
Mamie Ahlborn, UST Class B Global Operator mamie_ahlborn@hotmail.com
Mamie Ahlborn, UST Class B Global Operator mamie_ahlborn@hotmail.com

Tank Number	04	**Tank Age**	20	**Tank Installed Date**	12/01/2005	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	5042	**Spill Test Date**	04/14/2023	**Piping Installed Date**	06/04/2019	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	10/12/2023	**Sump Tightness Test Date**	04/14/2023	**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	10/12/2023	**Line Tightness Test Date**	09/20/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	MLLD Line Tightness Testing	**Energy Act**	Yes
		Overfill Test Date	10/12/2023			**ATG Type**	Veeder Root/TLS-300				
Tank Number	05	**Tank Age**	20	**Tank Installed Date**	12/01/2005	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	5043	**Spill Test Date**	04/14/2023	**Piping Installed Date**	06/04/2019	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	10/12/2023	**Sump Tightness Test Date**	04/14/2023	**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	10/12/2023	**Line Tightness Test Date**	09/20/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	MLLD Line Tightness Testing	**Energy Act**	Yes
		Overfill Test Date	10/12/2023			**ATG Type**	Veeder Root/TLS-300				

Facility Summary in Lake County in the City of Saint Ignatius

Location: MOUNTAIN VIEW CENEX
240 Mountain View Dr
Saint Ignatius, MT 59865 Lake

System Facility ID:24-10647

Facility Code: 23153
Last Inspected On: 09/13/2023
Operating Permit Renewal Date: 09/13/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Mission View Properties LLC	**(509) 994-6599**	**histarms01@yahoo.com**
Operator Contact:	Mamie Ahlborn	**(406) 207-2810**	**mamie_ahlborn@hotmail.com**

Owner/Operator: Mission View Properties LLC (509) 994-6599 histarms01@yahoo.com

Mamie Ahlborn, UST Class A Operator	mamie_ahlborn@hotmail.com
Mamie Ahlborn, UST Class A Operator	mamie_ahlborn@hotmail.com
Mamie Ahlborn, UST Class B Global Operator	mamie_ahlborn@hotmail.com
Mamie Ahlborn, UST Class B Global Operator	mamie_ahlborn@hotmail.com
Mamie Ahlborn, UST Class B Operator	mamie_ahlborn@hotmail.com
Mamie Ahlborn, UST Class B Operator	mamie_ahlborn@hotmail.com

Tank Number	06	**Tank Age**	30	**Tank Installed Date**	05/01/1995	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	4595	**Spill Test Date**	06/22/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	10/12/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	10/12/2023	**Line Tightness Test Date**	08/22/2017	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	10/12/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	07	**Tank Age**	30	**Tank Installed Date**	05/01/1995	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	4596	**Spill Test Date**	06/22/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	10/12/2023	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	10/12/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	10/12/2023	**Line Tightness Test Date**	09/26/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No

		Overfill Test Date	10/12/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	08	**Tank Age**	30	**Tank Installed Date**	05/01/1995	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	4597	**Spill Test Date**	04/13/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	10/12/2023	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	10/12/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**	10/12/2023	**Line Tightness Test Date**	09/26/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	10/12/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	09	**Tank Age**	10	**Tank Installed Date**	10/01/2015	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	5619	**Spill Test Date**	04/13/2023	**Piping Installed Date**	10/23/2015	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	10/12/2023	**Sump Tightness Test Date**	10/23/2015	**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	10/12/2023	**Line Tightness Test Date**	09/26/2022	**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	MLLD Line Tightness Testing	**Energy Act**	Yes
		Overfill Test Date	10/12/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350;Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Lake County in the City of Saint Ignatius

Location: SAINT IGNATIUS SCHOOL
4th & Blaine St
Saint Ignatius, MT 59865 Lake

System Facility ID:24-03762

Facility Code: 22927
Last Inspected On: 02/08/2024
Operating Permit Renewal Date: 02/08/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: School Dist 28 Saint Ignatius **(406) 745-3811**

Operator Contact: Stephen McCollum **(406) 396-7842** **smccollum@stignatiusschools.org**

Owner/Operator: School Dist 28 Saint Ignatius (406) 745-3811

Stephen McCollum, UST Class A Operator smccollum@stignatiusschools.org

Stephen McCollum, UST Class B Global Operator smccollum@stignatiusschools.org

Tank Number	03	**Tank Age**	28	**Tank Installed Date**	06/01/1997	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	4563	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Temporarily Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**	08/18/2020	**Catastrophic L.D. Type 3.0**	Auto Dialer	**Piping Type**	U.S. Suction	**CP Met Types**	Galvanic
Product	Heating Oil	**PLLD Test Date**		**Tank/Piping CP Test Date**	10/24/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**	EMCO Electronics/EECO 1500				

Facility Summary in Lewis and Clark County in the City of Augusta

Location: AUGUSTA GAS STATION LLC
130 Main St
Augusta, MT 59410 Lewis and Clark

System Facility ID:25-02114

Facility Code: 23462
Last Inspected On: 06/01/2023
Operating Permit Renewal Date: 08/22/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Augusta Service Station LLP	**(406) 562-3477**	**augustastation2017@gmail.com**
Operator Contact:	Susan Carlstrom	**(406) 562-3377**	**augustastation2017@gmail.com**

Owner/Operator:	Augusta Service Station LLP	(406) 562-3477	augustastation2017@gmail.com
	Susan Carlstrom, UST Class A Operator		augustastation2017@gmail.com
	Susan Carlstrom, UST Class A Operator		augustastation2017@gmail.com
	Susan Carlstrom, UST Class B Operator		augustastation2017@gmail.com
	Susan Carlstrom, UST Class B Operator		augustastation2017@gmail.com

Tank Number	06	**Tank Age**	36	**Tank Installed Date**	06/06/1989	**Tank Material Construction**	Steel Clad	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	3950	**Spill Test Date**	06/01/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	07/08/2008	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	1500	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	06/01/2022			**ATG Type**					
Tank Number	05	**Tank Age**	36	**Tank Installed Date**	06/06/1989	**Tank Material Construction**	Steel Clad	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	3951	**Spill Test Date**	06/01/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	07/08/2008	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	750	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	06/01/2022			**ATG Type**					

Tank Number	04	**Tank Age**	36	**Tank Installed Date**	06/06/1989	**Tank Material Construction**	Steel Clad	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	3952	**Spill Test Date**	06/01/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	07/08/2008	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	750	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	06/01/2022			**ATG Type**					

Facility Summary in Lewis and Clark County in the City of Augusta

Location: MALMSTROM AFB F 1
US Hwy 287
Augusta, MT 59410 Lewis and Clark

System Facility ID:50-09030

Facility Code: 28877
Last Inspected On: 05/16/2024
Operating Permit Renewal Date: 09/22/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: 341 CES CEANQ **(406) 731-6188**

Operator Contact: Candace Ellsworth;Curtis Hester;William Smith **(406) 731-6239;(406) 731-7128** **candace.ellsworth@us.af.mil;william.smith@us.af.mil**

Owner/Operator: 341 CES CEANQ (406) 731-6188

Candace Ellsworth, UST Class A Operator	candace.ellsworth@us.af.mil
Candace Ellsworth, UST Class A Operator	candace.ellsworth@us.af.mil
Candace Ellsworth, UST Class B Global Operator	candace.ellsworth@us.af.mil
Candace Ellsworth, UST Class B Global Operator	candace.ellsworth@us.af.mil
Curtis Hester, UST Class A Operator	
Curtis Hester, UST Class A Operator	
Curtis Hester, UST Class B Global Operator	
Curtis Hester, UST Class B Global Operator	
William Smith, UST Class A Operator	william.smith@us.af.mil
William Smith, UST Class A Operator	william.smith@us.af.mil
William Smith, UST Class B Global Operator	william.smith@us.af.mil
William Smith, UST Class B Global Operator	william.smith@us.af.mil

Tank Number	01	**Tank Age**	63	**Tank Installed Date**	06/02/1962	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	303	**Spill Test Date**	05/16/2024	**Piping Installed Date**		**Tank Construction**	Lined Interior/Impressed Current	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	05/16/2024	**Catastrophic L.D. Type 3.0**	Auto Dialer	**Piping Type**	U.S. Suction	**CP Met Types**	Impressed Current
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	05/08/2021	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	11/06/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	11/06/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				

Facility Summary in Lewis and Clark County in the City of Augusta

Location: MALMSTROM AFB F 5
MT Hwy 21
Augusta, MT 59410 Lewis and Clark

System Facility ID:25-09034

Facility Code: 23808
Last Inspected On: 04/01/2024
Operating Permit Renewal Date: 09/22/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: 341 CES CEANQ **(406) 731-6188**

Operator Contact: Candace Ellsworth;Curtis Hester;William Smith **(406) 731-6239;(406) 731-7128** **candace.ellsworth@us.af.mil;william.smith@us.af.mil**

Owner/Operator: 341 CES CEANQ (406) 731-6188

Candace Ellsworth, UST Class A Operator	candace.ellsworth@us.af.mil
Candace Ellsworth, UST Class B Global Operator	candace.ellsworth@us.af.mil
Curtis Hester, UST Class A Operator	
Curtis Hester, UST Class B Global Operator	
William Smith, UST Class A Operator	william.smith@us.af.mil
William Smith, UST Class B Global Operator	william.smith@us.af.mil

Tank Number	02	**Tank Age**	33	**Tank Installed Date**	05/01/1992	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	247	**Spill Test Date**	04/01/2024	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	04/01/2024	**Catastrophic L.D. Type 3.0**	Auto Dialer	**Piping Type**	U.S. Suction	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	04/01/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	04/01/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Lewis and Clark County in the City of Augusta

Location: MALMSTROM AFB F 6
US Hwy 287
Augusta, MT 59410 Lewis and Clark

System Facility ID:25-09035

Facility Code: 23809
Last Inspected On: 04/01/2024
Operating Permit Renewal Date: 09/22/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: 341 CES CEANQ **(406) 731-6188**

Operator Contact: Candace Ellsworth;Curtis Hester;William Smith **(406) 731-6239;(406) 731-7128** **candace.ellsworth@us.af.mil;william.smith@us.af.mil**

Owner/Operator: 341 CES CEANQ (406) 731-6188

Candace Ellsworth, UST Class A Operator	candace.ellsworth@us.af.mil
Candace Ellsworth, UST Class B Global Operator	candace.ellsworth@us.af.mil
Curtis Hester, UST Class A Operator	
Curtis Hester, UST Class B Global Operator	
William Smith, UST Class A Operator	william.smith@us.af.mil
William Smith, UST Class B Global Operator	william.smith@us.af.mil

Tank Number	02	**Tank Age**	33	**Tank Installed Date**	05/01/1992	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	248	**Spill Test Date**	04/01/2024	**Piping Installed Date**	08/19/2018	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	04/01/2024	**Catastrophic L.D. Type 3.0**	Auto Dialer	**Piping Type**	U.S. Suction	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	04/01/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	04/01/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Lewis and Clark County in the City of Augusta

Location: MALMSTROM AFB F 7
Road 434
Augusta, MT 59410 Lewis and Clark

System Facility ID:25-09036

Facility Code: 23810
Last Inspected On: 04/01/2024
Operating Permit Renewal Date: 09/22/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	341 CES CEANQ	**(406) 731-6188**	
Operator Contact:	Candace Ellsworth;Curtis Hester;William Smith	**(406) 731-6239;(406) 731-7128**	**candace.ellsworth@us.af.mil;william.smith@us.af.mil**

Owner/Operator: 341 CES CEANQ (406) 731-6188

Candace Ellsworth, UST Class A Operator	candace.ellsworth@us.af.mil
Candace Ellsworth, UST Class B Global Operator	candace.ellsworth@us.af.mil
Curtis Hester, UST Class A Operator	
Curtis Hester, UST Class B Global Operator	
William Smith, UST Class A Operator	william.smith@us.af.mil
William Smith, UST Class B Global Operator	william.smith@us.af.mil

Tank Number	02	**Tank Age**	33	**Tank Installed Date**	06/01/1992	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	249	**Spill Test Date**	04/01/2024	**Piping Installed Date**	09/25/2018	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	04/01/2024	**Catastrophic L.D. Type 3.0**	Auto Dialer	**Piping Type**	U.S. Suction	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	04/01/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	04/01/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Lewis and Clark County in the City of Augusta

Location: MALMSTROM AFB G 10
US Hwy 287
Augusta, MT 59410 Lewis and Clark

System Facility ID:25-09050

Facility Code: 23816
Last Inspected On: 04/17/2024
Operating Permit Renewal Date: 09/23/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	341 CES CEANQ	**(406) 731-6188**	
Operator Contact:	Candace Ellsworth;Curtis Hester;William Smith	**(406) 731-6239;(406) 731-7128**	**candace.ellsworth@us.af.mil;william.smith@us.af.mil**

Owner/Operator: 341 CES CEANQ (406) 731-6188

Candace Ellsworth, UST Class A Operator	candace.ellsworth@us.af.mil
Candace Ellsworth, UST Class B Global Operator	candace.ellsworth@us.af.mil
Curtis Hester, UST Class A Operator	
Curtis Hester, UST Class B Global Operator	
William Smith, UST Class A Operator	william.smith@us.af.mil
William Smith, UST Class B Global Operator	william.smith@us.af.mil

Tank Number	02	**Tank Age**	33	**Tank Installed Date**	06/01/1992	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	255	**Spill Test Date**	04/17/2024	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	04/17/2024	**Catastrophic L.D. Type 3.0**	Auto Dialer	**Piping Type**	U.S. Suction	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	04/17/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	04/17/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Lewis and Clark County in the City of Augusta

Location: MALMSTROM AFB G 9
US Hwy 287
Augusta, MT 59410 Lewis and Clark

System Facility ID:25-09049

Facility Code: 23815
Last Inspected On: 04/17/2024
Operating Permit Renewal Date: 09/23/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	341 CES CEANQ	**(406) 731-6188**	
Operator Contact:	Candace Ellsworth;Curtis Hester;William Smith	**(406) 731-6239;(406) 731-7128**	**candace.ellsworth@us.af.mil;william.smith@us.af.mil**

Owner/Operator: 341 CES CEANQ (406) 731-6188

Candace Ellsworth, UST Class A Operator	candace.ellsworth@us.af.mil
Candace Ellsworth, UST Class B Global Operator	candace.ellsworth@us.af.mil
Curtis Hester, UST Class A Operator	
Curtis Hester, UST Class B Global Operator	
William Smith, UST Class A Operator	william.smith@us.af.mil
William Smith, UST Class B Global Operator	william.smith@us.af.mil

Tank Number	02	**Tank Age**	34	**Tank Installed Date**	10/01/1991	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	254	**Spill Test Date**	04/17/2024	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	04/17/2024	**Catastrophic L.D. Type 3.0**	Auto Dialer	**Piping Type**	U.S. Suction	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	04/17/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	04/17/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Lewis and Clark County in the City of East Helena

Location: CANYON FERRY MINI BASKET
3012 Canyon Ferry Rd
East Helena, MT 59635-3025 Lewis and Clark

System Facility ID:25-03122

Facility Code: 23511
Last Inspected On: 09/20/2023
Operating Permit Renewal Date: 05/25/2023

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Big Sky Food and Fuel Inc Helena;Robert Merzlak	**(406) 443-3608**	**Minibasket@live.com;Rob&Traci@msn.com**

Operator Contact:	Rob Merzlak;Big Sky Food and Fuel Inc Helena;Robert Merzlak	**(406) 443-3608**	**Minibasket@live.com;Minibasket@live.com;Rob&Traci@msn.com**

Owner/Operator:	Big Sky Food and Fuel Inc Helena	(406) 443-3608	Rob&Traci@msn.com
Owner/Operator:	Robert J Merzlak	(406) 443-3608	Rob&Traci@msn.com
	Rob Merzlak, UST Class A Operator		Rob&Traci@msn.com
	Rob Merzlak, UST Class B Operator		Rob&Traci@msn.com
	Robert J Merzlak, UST Class A Operator		Minibasket@live.com
	Robert J Merzlak, UST Class B Global Operator		Minibasket@live.com
	Robert J Merzlak, UST Class B Operator		Minibasket@live.com

Tank Number	01	**Tank Age**	31	**Tank Installed Date**	06/01/1994	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve
Tag Number	2319	**Spill Test Date**	01/24/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	01/25/2022	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	20000	**ATG Test Date**	01/24/2022	**Line Tightness Test Date**	03/30/2006	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	02/16/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-300				
Tank Number	04	**Tank Age**	18	**Tank Installed Date**	10/16/2007	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	5151	**Spill Test Date**	05/25/2023	**Piping Installed Date**	05/23/2023	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	01/24/2021	**Sump Tightness Test Date**	05/25/2023	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No

Capacity	5000	**ATG Test Date**	05/25/2023	**Line Tightness Test Date**	01/24/2021	**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	05/25/2023			**ATG Type**	Franklin Fueling Systems/EVO 6000				
Tank Number	05	**Tank Age**	18	**Tank Installed Date**	10/16/2007	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	5152	**Spill Test Date**	05/25/2023	**Piping Installed Date**	05/23/2023	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	05/25/2023	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	Yes
Capacity	6000	**ATG Test Date**	05/25/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	05/25/2023			**ATG Type**					
Tank Number	06	**Tank Age**	2	**Tank Installed Date**	05/23/2023	**Tank Material Construction**	Steel Clad	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	6153	**Spill Test Date**	05/25/2023	**Piping Installed Date**	05/23/2023	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	05/25/2023	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	Yes
Capacity	10000	**ATG Test Date**	05/25/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	05/25/2023			**ATG Type**					
Tank Number	07	**Tank Age**	2	**Tank Installed Date**	05/23/2023	**Tank Material Construction**	Steel Clad	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	6154	**Spill Test Date**	05/25/2023	**Piping Installed Date**	05/23/2023	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	05/25/2023	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Diesel, Dyed	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	5000	**ATG Test Date**	05/25/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	05/25/2023			**ATG Type**					

Facility Summary in Lewis and Clark County in the City of East Helena

Location: TOWN PUMP EAST HELENA 1
3680 East Hwy 12
East Helena, MT 59635 Lewis and Clark

System Facility ID:00-32557

Facility Code: 32557
Last Inspected On: 03/24/2025
Operating Permit Renewal Date: 11/19/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: EAST HELENA 1 RE2 LLC **(406) 497-6700**

Operator Contact: Trent Biggers;Town Pump **Trentb@townpump.com;environmental@townpump.com**

Owner/Operator: EAST HELENA 1 RE2 LLC (406) 497-6700

Trent Biggers, UST Class A Operator environmental@townpump.com
Trent Biggers, UST Class B Operator environmental@townpump.com

Tank Number	01	**Tank Age**	2	**Tank Installed Date**	11/02/2023	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	6201	**Spill Test Date**	07/17/2024	**Piping Installed Date**	09/12/2024	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	07/17/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	Yes
Capacity	30000	**ATG Test Date**	10/24/2024	**Line Tightness Test Date**	11/12/2024	**Secondary Tank Leak Detection**	Statistical Inventory Reconciliation	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	Yes
		Overfill Test Date	07/17/2024			**ATG Type**					
Tank Number	02	**Tank Age**	2	**Tank Installed Date**	11/02/2023	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	6202	**Spill Test Date**	07/17/2024	**Piping Installed Date**	09/12/2024	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	07/17/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	30000	**ATG Test Date**	10/24/2024	**Line Tightness Test Date**	11/12/2024	**Secondary Tank Leak Detection**	Statistical Inventory Reconciliation	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	Yes
		Overfill Test Date	07/17/2024			**ATG Type**					

Tank Number	03	**Tank Age**	2	**Tank Installed Date**	11/02/2023	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	6203	**Spill Test Date**	07/17/2024	**Piping Installed Date**	09/12/2024	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	07/17/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	Yes
Capacity	20000	**ATG Test Date**	10/24/2024	**Line Tightness Test Date**	11/12/2024	**Secondary Tank Leak Detection**	Statistical Inventory Reconciliation	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	Yes
		Overfill Test Date	07/17/2024			**ATG Type**					
Tank Number	04	**Tank Age**	2	**Tank Installed Date**	11/02/2023	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	6204	**Spill Test Date**	07/17/2024	**Piping Installed Date**	09/12/2024	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	07/17/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	Yes
Capacity	10000	**ATG Test Date**	10/24/2024	**Line Tightness Test Date**	11/12/2024	**Secondary Tank Leak Detection**	Statistical Inventory Reconciliation	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	Yes
		Overfill Test Date	07/17/2024			**ATG Type**					
Tank Number	05	**Tank Age**	2	**Tank Installed Date**	11/02/2023	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	6205	**Spill Test Date**	07/17/2024	**Piping Installed Date**	09/12/2024	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	30000	**ATG Test Date**	10/24/2024	**Line Tightness Test Date**	11/12/2024	**Secondary Tank Leak Detection**	Statistical Inventory Reconciliation	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	Yes
		Overfill Test Date	07/17/2024			**ATG Type**					
Tank Number	06	**Tank Age**	2	**Tank Installed Date**	11/02/2023	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	6206	**Spill Test Date**	07/17/2024	**Piping Installed Date**	09/12/2024	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No

Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	07/17/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	10/24/2024	**Line Tightness Test Date**	11/12/2024	**Secondary Tank Leak Detection**	Statistical Inventory Reconciliation	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	Yes
		Overfill Test Date	07/17/2024			**ATG Type**					
Tank Number	07	**Tank Age**	2	**Tank Installed Date**	11/02/2023	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	6207	**Spill Test Date**	07/17/2024	**Piping Installed Date**	09/12/2024	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	07/17/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Diesel, Dyed	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	10/24/2024	**Line Tightness Test Date**	11/12/2024	**Secondary Tank Leak Detection**	Statistical Inventory Reconciliation	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	Yes
		Overfill Test Date	07/17/2024			**ATG Type**					
Tank Number	08	**Tank Age**	2	**Tank Installed Date**	11/02/2023	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	
Tag Number	6208	**Spill Test Date**		**Piping Installed Date**	09/12/2024	**Tank Construction**		**Piping Construction**		**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**		**Piping Type**	Pressurized	**CP Met Types**	
Product	DEF (Not Regulated)	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	Yes
		Overfill Test Date				**ATG Type**					
Tank Number	09	**Tank Age**	2	**Tank Installed Date**	11/02/2023	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	6276	**Spill Test Date**	07/17/2024	**Piping Installed Date**	09/12/2024	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	07/17/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline, E85	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	Yes
Capacity	8000	**ATG Test Date**	10/24/2024	**Line Tightness Test Date**	11/12/2024	**Secondary Tank Leak Detection**	Statistical Inventory Reconciliation	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	Yes

		Overfill Test Date	07/17/2024			**ATG Type**					

Facility Summary in Lewis and Clark County in the City of East Helena

Location: TOWN PUMP EAST HELENA 2
116 S Lane Ave
East Helena, MT 59635 Lewis and Clark

System Facility ID:56-13915

Facility Code: 30585
Last Inspected On: 03/20/2025
Operating Permit Renewal Date: 07/29/2028

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: East Helena 2 Town Pump LLC **(406) 497-6700** **environmental@townpump.com**

Operator Contact: Trent Biggers **Trentb@townpump.com**

Owner/Operator: East Helena 2 Town Pump LLC (406) 497-6700 environmental@townpump.com

Trent Biggers, UST Class A Operator Trentb@townpump.com

Trent Biggers, UST Class B Global Operator Trentb@townpump.com

Tank Number	01	**Tank Age**	27	**Tank Installed Date**	12/01/1998	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve
Tag Number	4028	**Spill Test Date**	06/22/2024	**Piping Installed Date**	06/12/2013	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	06/22/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	03/20/2025	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	03/20/2025	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Statistical Inventory Reconciliation	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	No
		Overfill Test Date	06/22/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Number	02	**Tank Age**	27	**Tank Installed Date**	12/01/1998	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve
Tag Number	4029	**Spill Test Date**	06/22/2024	**Piping Installed Date**	06/12/2013	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	06/22/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	03/20/2025	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	03/20/2025	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Statistical Inventory Reconciliation	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	No

		Overfill Test Date	06/22/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Number	03	**Tank Age**	27	**Tank Installed Date**	12/01/1998	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve;Flapper Valve
Tag Number	4030	**Spill Test Date**	10/09/2024	**Piping Installed Date**	06/12/2013	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	06/22/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel, Dyed	**PLLD Test Date**	03/20/2025	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	03/20/2025	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Statistical Inventory Reconciliation	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	No
		Overfill Test Date	06/22/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Number	04	**Tank Age**	27	**Tank Installed Date**	12/01/1998	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve
Tag Number	4031	**Spill Test Date**	06/22/2024	**Piping Installed Date**	06/12/2013	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	06/22/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	03/20/2025	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	03/20/2025	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Statistical Inventory Reconciliation	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	No
		Overfill Test Date	06/22/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Number	05	**Tank Age**	27	**Tank Installed Date**	12/01/1998	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve
Tag Number	4032	**Spill Test Date**	06/22/2024	**Piping Installed Date**	06/12/2013	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	06/22/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	03/20/2025	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**	03/20/2025	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Statistical Inventory Reconciliation	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	No
		Overfill Test Date	06/22/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				

Tank Number	06	**Tank Age**	26	**Tank Installed Date**	03/01/1999	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve
Tag Number	4033	**Spill Test Date**	06/22/2024	**Piping Installed Date**	06/12/2013	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	06/22/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	03/20/2025	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	03/20/2025	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Statistical Inventory Reconciliation	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	No
		Overfill Test Date	06/22/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Number	07	**Tank Age**	22	**Tank Installed Date**	08/18/2003	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve
Tag Number	4861	**Spill Test Date**	06/22/2024	**Piping Installed Date**	06/12/2013	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	06/22/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	03/20/2025	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	03/20/2025	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Statistical Inventory Reconciliation	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	No
		Overfill Test Date	06/22/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				

Facility Summary in Lewis and Clark County in the City of East Helena

Location: TOWN PUMP INC EAST HELENA
418 W Main St
East Helena, MT 59635 Lewis and Clark

System Facility ID:25-08697

Facility Code: 23791
Last Inspected On: 07/22/2022
Operating Permit Renewal Date: 07/25/2025

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	East Helena 1 Town Pump LLC	**(406) 497-6700**	**environmental@townpump.com**
Operator Contact:	Trent Biggers		**Trentb@townpump.com**

Trent Biggers, UST Class A Operator	Trentb@townpump.com
Trent Biggers, UST Class A Operator	Trentb@townpump.com
Trent Biggers, UST Class B Global Operator	Trentb@townpump.com
Trent Biggers, UST Class B Global Operator	Trentb@townpump.com

Tank Number	01	**Tank Age**	57	**Tank Installed Date**	04/14/1968	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve
Tag Number	4672	**Spill Test Date**	08/11/2021	**Piping Installed Date**		**Tank Construction**	Lined Interior/Impressed Current	**Piping Construction**	None	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**	05/25/2022	**Tank/Piping CP Test Date**	06/04/2021	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	24000	**ATG Test Date**	05/25/2022	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	08/11/2021			**ATG Type**	Gilbarco-Veeder Root/TLS-350				
Tank Number	02	**Tank Age**	57	**Tank Installed Date**	04/14/1968	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve
Tag Number	4673	**Spill Test Date**	08/11/2021	**Piping Installed Date**		**Tank Construction**	Lined Interior/Impressed Current	**Piping Construction**	None	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**	05/25/2022	**Tank/Piping CP Test Date**	06/04/2021	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	24000	**ATG Test Date**	05/25/2022	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No

		Overfill Test Date	08/11/2021			**ATG Type**	Gilbarco-Veeder Root/TLS-350				
Tank Number	03	**Tank Age**	57	**Tank Installed Date**	04/14/1968	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve;Flapper Valve
Tag Number	4674	**Spill Test Date**	08/11/2021	**Piping Installed Date**		**Tank Construction**	Lined Interior/Impressed Current	**Piping Construction**	Single Walled	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**	08/28/2023	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**	05/25/2022	**Tank/Piping CP Test Date**	06/04/2021	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	16000	**ATG Test Date**	05/25/2022	**Line Tightness Test Date**	08/28/2023	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	06/21/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350				
Tank Number	04	**Tank Age**	57	**Tank Installed Date**	04/14/1968	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	4675	**Spill Test Date**	08/11/2021	**Piping Installed Date**		**Tank Construction**	Lined Interior/Impressed Current	**Piping Construction**	None	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Diesel	**PLLD Test Date**	05/25/2022	**Tank/Piping CP Test Date**	06/04/2021	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**	05/25/2022	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	08/11/2021			**ATG Type**	Gilbarco-Veeder Root/TLS-350				
Tank Number	05	**Tank Age**	57	**Tank Installed Date**	04/14/1968	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve
Tag Number	4676	**Spill Test Date**	08/11/2021	**Piping Installed Date**		**Tank Construction**	Lined Interior/Impressed Current	**Piping Construction**	None	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Diesel	**PLLD Test Date**	05/25/2022	**Tank/Piping CP Test Date**	06/04/2021	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	05/25/2022	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	08/11/2021			**ATG Type**	Gilbarco-Veeder Root/TLS-350				
Tank Number	06	**Tank Age**	48	**Tank Installed Date**	04/14/1977	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve

Tag Number	4677	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**	Lined Interior/Impressed Current	**Piping Construction**	None	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Diesel	**PLLD Test Date**	05/25/2022	**Tank/Piping CP Test Date**	06/04/2021	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	05/25/2022	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	08/11/2021			**ATG Type**	Gilbarco-Veeder Root/TLS-350				
Tank Number	07	**Tank Age**	48	**Tank Installed Date**	04/14/1977	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve
Tag Number	4678	**Spill Test Date**	08/11/2021	**Piping Installed Date**		**Tank Construction**	Lined Interior/Impressed Current	**Piping Construction**	None	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**	05/25/2022	**Tank/Piping CP Test Date**	06/04/2021	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	05/25/2022	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	08/11/2021			**ATG Type**	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Lewis and Clark County in the City of Fort Harrison

Location: VETERANS HEALTH ADMINISTRATION
3687 Veterans Dr Bldg 141
Fort Harrison, MT 59636 Lewis and Clark

System Facility ID:25-05908

Facility Code: 23656
Last Inspected On: 11/14/2023
Operating Permit Renewal Date: 02/03/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: US Dept of Veterans Affairs

Operator Contact: Gregory Riccaldo;Josiah Walker;Veterans Administration **(406) 594-8112;(406) 442-6410** **gregory.riccaldo@va.gov;Josiah.Walker@va.gov**

Owner/Operator: US Dept of Veterans Affairs

Gregory Riccaldo, UST Class A Operator gregory.riccaldo@va.gov
Josiah Walker, UST Class A Operator Josiah.Walker@va.gov
Josiah Walker, UST Class B Operator Josiah.Walker@va.gov

Tank Number	08	**Tank Age**	32	**Tank Installed Date**	12/01/1993	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	2214	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Temporarily Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	1000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	10	**Tank Age**	32	**Tank Installed Date**	12/01/1993	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	2216	**Spill Test Date**	08/21/2020	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	U.S. Suction	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	3-Year Line Tightness Test	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	04/08/2024	**Line Tightness Test Date**	08/14/2020	**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No

		Overfill Test Date	04/08/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350;Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	13	**Tank Age**	15	**Tank Installed Date**	10/01/2010	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	5278	**Spill Test Date**	08/21/2020	**Piping Installed Date**	04/26/2011	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	08/21/2020	**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	U.S. Suction	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**		**Line Tightness Test Date**	08/14/2020	**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	3-Year Line Tightness Test	**Energy Act**	Yes
		Overfill Test Date	08/13/2020			**ATG Type**	Gilbarco-Veeder Root/TLS-350;Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	14	**Tank Age**	13	**Tank Installed Date**	05/01/2012	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	5366	**Spill Test Date**	08/21/2020	**Piping Installed Date**	05/01/2012	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	08/21/2020	**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	U.S. Suction	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	08/13/2020	**Line Tightness Test Date**	08/14/2020	**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	3-Year Line Tightness Test	**Energy Act**	Yes
		Overfill Test Date	08/13/2020			**ATG Type**	Gilbarco-Veeder Root/TLS-450;Veeder Root/TLS-450				

Facility Summary in Lewis and Clark County in the City of Helena

Location: ARMY AVIATION SUPPORT FACILITY
3333 Skyway Dr
Helena, MT 59602 Lewis and Clark

System Facility ID:56-13821

Facility Code: 30507
Last Inspected On: 07/09/2024
Operating Permit Renewal Date: 07/17/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	US Dept of Military Affairs Helena	**(406) 324-3000**	**adel.m.johnson.mil@mail.mil**
Operator Contact:	Elizka McFetridge;Guthrie Oiestad;Matthew Kent;US Dept of Military Affairs Helena;Thad Waples	**(361) 249-5454;(406) 324-3000**	**matthew.kent10.nfg@army.mil;adel.m.johnson.mil@mail.mil;oiestadg@gmail.com;thad.waples@us.army.mil**

Owner/Operator: US Dept of Military Affairs Helena (406) 324-3000 adel.m.johnson.mil@mail.mil

Aaron Linz, UST Class B Global Operator	
Elizka McFetridge, UST Class A Operator	
Elizka McFetridge, UST Class B Operator	
Guthrie Oiestad, UST Class A Operator	oiestadg@gmail.com
Matthew Kent, UST Class A Operator	adel.m.johnson.mil@mail.mil
Matthew Kent, UST Class B Operator	adel.m.johnson.mil@mail.mil
Michael Bramhall, UST Class B Operator	michaeljbramhall323@gmail.com
Rylee Gannon, UST Class B Operator	ryleeratd@hotmail.com
Thad Waples, UST Class A Operator	thad.waples@us.army.mil
Victoria Stipcich, UST Class B Operator	vstipcich1@gmail.com

Tank Number	01	**Tank Age**	28	**Tank Installed Date**	03/01/1997	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	No Piping	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	827	**Spill Test Date**	07/09/2024	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Jet Fuel (Jet-A, Jet-A1, JP5)	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	25000	**ATG Test Date**	07/09/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	07/09/2024			**ATG Type**	Gilbarco-Veeder Root/Other				
Tank Number	02	**Tank Age**	28	**Tank Installed Date**	03/01/1997	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	No Piping	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	828	**Spill Test Date**	07/09/2024	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible

Product	Jet Fuel (Jet-A, Jet-A1, JP5)	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	25000	**ATG Test Date**	07/09/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	07/09/2024			**ATG Type**	Gilbarco-Veeder Root/Other				

Facility Summary in Lewis and Clark County in the City of Helena

Location: BOBS VALLEY SERVICE INC UST
7507 N Montana Ave
Helena, MT 59602-9389 Lewis and Clark

System Facility ID:25-07404

Facility Code: 23734
Last Inspected On: 11/07/2023
Operating Permit Renewal Date: 03/26/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Bobs Valley Market	**(406) 458-5140**	**steve@montanavalleyhams.com**

Operator Contact: Dylan Pizzini

Owner/Operator:	Bobs Valley Market	(406) 458-5140	steve@montanavalleyhams.com
	Craig Sprankle, UST Class B Operator		cls66@live.com
	Craig Sprankle, UST Class B Operator		cls66@live.com
	Dylan Pizzini, UST Class A Operator		
	Dylan Pizzini, UST Class A Operator		
	Dylan Pizzini, UST Class B Global Operator		
	Dylan Pizzini, UST Class B Global Operator		
	Stephen Bartmess, UST Class B Global Operator		steve@montanavalleyhams.com
	Stephen Bartmess, UST Class B Global Operator		steve@montanavalleyhams.com
	Steve Nummerdor, UST Class B Global Operator		steve@montanavalleyhams.com
	Steve Nummerdor, UST Class B Global Operator		steve@montanavalleyhams.com

Tank Number	05	**Tank Age**	37	**Tank Installed Date**	03/27/1988	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	474	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Temporarily Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	11/07/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	06	**Tank Age**	37	**Tank Installed Date**	03/27/1988	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	475	**Spill Test Date**	10/06/2021	**Piping Installed Date**	05/14/2011	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No

Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	10/06/2021	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**	09/06/2023	**Tank/Piping CP Test Date**	11/07/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**	09/06/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date	09/07/2021			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	07	**Tank Age**	33	**Tank Installed Date**	06/01/1992	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	476	**Spill Test Date**	10/06/2021	**Piping Installed Date**	05/14/2011	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	10/06/2021	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**	09/06/2023	**Tank/Piping CP Test Date**	11/07/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	09/06/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date	09/07/2021			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	08	**Tank Age**	27	**Tank Installed Date**	11/15/1998	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	477	**Spill Test Date**	04/08/2022	**Piping Installed Date**	05/14/2011	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	10/06/2021	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**	09/06/2023	**Tank/Piping CP Test Date**	11/07/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	20000	**ATG Test Date**	09/06/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date	05/29/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Lewis and Clark County in the City of Helena

Location: CEDAR STREET CONOCO
1701 Cedar St
Helena, MT 59601-1109 Lewis and Clark

System Facility ID:25-03466

Facility Code: 23531
Last Inspected On: 04/01/2024
Operating Permit Renewal Date: 06/11/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Cedar Street Conoco;Michael Salois	**(406) 495-0953**	**Gabes.7.Store@gmail.com**
Operator Contact:	Michael Salois		**mike.salois416@gmail.com**

Owner/Operator:	Cedar Street Conoco	(406) 495-0953	Gabes.7.Store@gmail.com
Owner/Operator:	Michael J Salois	(406) 495-0953	Gabes.7.Store@gmail.com
	Daren Griffeth, UST Class B Operator		luckyme6719@gmail.com
	Daren Griffeth, UST Class B Operator		luckyme6719@gmail.com
	Michael Salois, UST Class A Operator		mike.salois416@gmail.com
	Michael Salois, UST Class A Operator		mike.salois416@gmail.com

Tank Number	05	**Tank Age**	27	**Tank Installed Date**	09/01/1998	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	2228	**Spill Test Date**	04/01/2024	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	15000	**ATG Test Date**	04/01/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	04/01/2024			**ATG Type**	Veeder Root/TLS-350				
Tank Number	06	**Tank Age**	27	**Tank Installed Date**	09/01/1998	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	2229	**Spill Test Date**	04/01/2024	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	04/01/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No

		Overfill Test Date	04/01/2024			**ATG Type**	Veeder Root/TLS-350				
Tank Number	07	**Tank Age**	27	**Tank Installed Date**	09/01/1998	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	2230	**Spill Test Date**	04/01/2024	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	04/01/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	04/01/2024			**ATG Type**	Veeder Root/TLS-350				

Facility Summary in Lewis and Clark County in the City of Helena

Location: CIRCLE K STORE 2746270
401 Euclid Ave
Helena, MT 59601 Lewis and Clark

System Facility ID:25-08067

Facility Code: 23766
Last Inspected On: 06/06/2023
Operating Permit Renewal Date: 09/09/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Rocky Mountain Oil LLC	**(602) 728-8000**	**NT-ESS@Circlek.com**
Operator Contact:	Veronica Rivera		**ESS-WestCoast@circlek.com**

Owner/Operator: Rocky Mountain Oil LLC (602) 728-8000 NT-ESS@Circlek.com

Brad Lee, UST Class B Global Operator	brad.lee@holidaycompanies.com
Jeff Reed, UST Class B Global Operator	jeff.reed@holidaycompanies.com
Julie Cordie, UST Class B Operator	NT-ESS@Circlek.com
Veronica Rivera, UST Class A Operator	ESS-WestCoast@circlek.com

Tank Number	01	**Tank Age**	38	**Tank Installed Date**	05/01/1987	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve;Flapper Valve
Tag Number	3017	**Spill Test Date**	06/03/2020	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	06/03/2020	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	07/01/2020	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	Yes
Capacity	12000	**ATG Test Date**		**Line Tightness Test Date**	05/23/2020	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	02	**Tank Age**	38	**Tank Installed Date**	05/01/1987	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve;Flapper Valve
Tag Number	3018	**Spill Test Date**	06/03/2020	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	06/03/2020	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	07/01/2020	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**		**Line Tightness Test Date**	06/02/2020	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes

		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	03	**Tank Age**	38	**Tank Installed Date**	11/01/1987	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve;Flapper Valve
Tag Number	3019	**Spill Test Date**	06/03/2020	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	06/03/2020	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	07/01/2020	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	Yes
Capacity	10000	**ATG Test Date**		**Line Tightness Test Date**	05/23/2020	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	04	**Tank Age**	38	**Tank Installed Date**	11/01/1987	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve;Flapper Valve
Tag Number	3020	**Spill Test Date**	06/03/2020	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	06/03/2020	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	07/01/2020	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	Yes
Capacity	10000	**ATG Test Date**		**Line Tightness Test Date**	05/23/2020	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Lewis and Clark County in the City of Helena

Location: CIRCLE K STORE 2746723
606 N Fee St
Helena, MT 59601-3148 Lewis and Clark

System Facility ID:56-13956

Facility Code: 30624
Last Inspected On: 11/06/2018
Operating Permit Renewal Date: 03/30/2022

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Rocky Mountain Oil Co Inc	**(602) 728-8000**	**vrivera1@circlek.com**
Operator Contact:	Chuck Nyberg;Kegan Krueger;Patrick Patnaude;Robert Deninno;Stephen Reckinger;Valeria Jeffries;Veronica Rivera	**(406) 321-0938;(952) 830-8028;(952) 830-8721;(952) 830-8722**	**ESS-WestCoast@circlek.com;kegan.krueger@holidaycompanies.com;patrick.patnaude@holidaycompanies.com;steve.reckinger@holidaycompanies.com;valeria.jeffries@holidaycompanies.com**

Brad Lee, UST Class B Global Operator	brad.lee@holidaycompanies.com
Chuck Nyberg, UST Class A Operator	
Craig Hagmeier, UST Class B Operator	s02008.fir@albertsons.com
Cynthia Hellwitz, UST Class B Operator	chellwitz@yahoo.com
Julie Cordie, UST Class B Global Operator	tigger2_4u@yahoo.com
Kegan Krueger, UST Class A Operator	kegan.krueger@holidaycompanies.com
Patrick Patnaude, UST Class A Operator	patrick.patnaude@holidaycompanies.com
Robert Deninno, UST Class A Operator	
Ryan Coey, UST Class B Operator	s02004.adir@albertsons.com
Stephen Reckinger, UST Class A Operator	steve.reckinger@holidaycompanies.com
Stephen Reckinger, UST Class B Global Operator	steve.reckinger@holidaycompanies.com
Todd White, UST Class B Global Operator	todd.white@holidaycompanies.com
Valeria Jeffries, UST Class A Operator	valeria.jeffries@holidaycompanies.com
Veronica Rivera, UST Class A Operator	ESS-WestCoast@circlek.com
Veronica Rivera, UST Class B Global Operator	ESS-WestCoast@circlek.com

Tank Number	01	**Tank Age**	26	**Tank Installed Date**	10/01/1999	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Positive Shutoff
Tag Number	4128	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	30000	**ATG Test Date**		**Line Tightness Test Date**	09/05/2018	**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No

		Overfill Test Date				**ATG Type**	Veeder Root/TLS-450				
Tank Number	02	**Tank Age**	26	**Tank Installed Date**	10/01/1999	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Positive Shutoff
Tag Number	4129	**Spill Test Date**	04/25/2019	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	20000	**ATG Test Date**		**Line Tightness Test Date**	04/23/2018	**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date				**ATG Type**	Veeder Root/TLS-450				

Facility Summary in Lewis and Clark County in the City of Helena

Location: COMBINED CRIMINAL JUSTICE FACILITY
221 Breckenridge St
Helena, MT 59601-4230 Lewis and Clark

System Facility ID:25-00945

Facility Code: 23395
Last Inspected On: 09/06/2024
Operating Permit Renewal Date: 08/15/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Lewis and Clark County Jail **(406) 447-8299**

Operator Contact: Robert McCarley **(406) 447-8299**

Owner/Operator: Lewis and Clark County Jail (406) 447-8299

Robert McCarley, UST Class A Operator

Robert McCarley, UST Class B Global Operator

Tank Number	01	**Tank Age**	40	**Tank Installed Date**	04/21/1985	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	4060	**Spill Test Date**	09/06/2024	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	09/06/2024	**Catastrophic L.D. Type 3.0**	Continuous Interstitial Monitoring	**Piping Type**	U.S. Suction	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	09/06/2024	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	3000	**ATG Test Date**	09/06/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	09/06/2024			**ATG Type**	Gilbarco/EMC Basic				

Facility Summary in Lewis and Clark County in the City of Helena

Location: COSTCO GASOLINE 633
2195 E Custer Ave
Helena, MT 59602 Lewis and Clark

System Facility ID:60-15051

Facility Code: 30825
Last Inspected On: 12/12/2022
Operating Permit Renewal Date: 02/24/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Costco Wholesale	**(425) 251-6222**	**gaslicenses@costco.com**
Operator Contact:	Andrew Erdahl;Daniel Manibusan;Patty Vaughan;Costco Wholesale Corporation Seattle	**(406) 495-7042;(406) 652-8765;(425) 313-8100**	**w633gas@costco.com;w633gas@costco.com;gaslicenses@costco.com**

Owner/Operator: Costco Wholesale (425) 251-6222 gaslicenses@costco.com

Andrew Erdahl, UST Class A Operator	w633gas@costco.com
Andrew Erdahl, UST Class B Global Operator	w633gas@costco.com
Andrew Erdahl, UST Class B Operator	w633gas@costco.com
Daniel Manibusan, UST Class A Operator	w633gas@costco.com
Daniel Manibusan, UST Class B Operator	w633gas@costco.com
Patty Vaughan, UST Class A Operator	gaslicenses@costco.com
Patty Vaughan, UST Class B Operator	gaslicenses@costco.com

Tank Number	01	**Tank Age**	19	**Tank Installed Date**	10/05/2006	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	5095	**Spill Test Date**	04/22/2024	**Piping Installed Date**	08/23/2006	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	04/22/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	10/06/2022	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	30000	**ATG Test Date**	10/06/2022	**Line Tightness Test Date**	10/06/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	04/22/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350				
Tank Number	02	**Tank Age**	19	**Tank Installed Date**	10/05/2006	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	5096	**Spill Test Date**	04/22/2024	**Piping Installed Date**	08/23/2006	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	04/22/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	10/06/2022	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No

Capacity	30000	**ATG Test Date**	10/06/2022	**Line Tightness Test Date**	10/06/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	04/22/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350				
Tank Number	03	**Tank Age**	19	**Tank Installed Date**	10/05/2006	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	5097	**Spill Test Date**	04/22/2024	**Piping Installed Date**	08/23/2006	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	04/22/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	10/06/2022	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	30000	**ATG Test Date**	10/06/2022	**Line Tightness Test Date**	10/06/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	04/22/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350				
Tank Number	04	**Tank Age**	14	**Tank Installed Date**	04/12/2011	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	5281	**Spill Test Date**	04/22/2024	**Piping Installed Date**	10/25/2010	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	10/06/2022	**Sump Tightness Test Date**	04/22/2024	**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Hazardous Substance	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	1500	**ATG Test Date**	10/06/2022	**Line Tightness Test Date**	11/13/2019	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	MLLD Line Tightness Testing	**Energy Act**	Yes
		Overfill Test Date	04/22/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Lewis and Clark County in the City of Helena

Location: DAVES EXPRESS LUBE
4990 N Montana Ave
Helena, MT 59602-7268 Lewis and Clark

System Facility ID:56-13828

Facility Code: 30514
Last Inspected On: 04/23/2025
Operating Permit Renewal Date: 07/27/2028

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Dave's Express Lube Inc **(406) 449-9667**

Operator Contact: Dave Clemens **(406) 449-9667** **dcirocz@aol.com**

Owner/Operator: Dave's Express Lube Inc (406) 449-9667

Dave Clemens, UST Class A Operator dcirocz@aol.com

Dave Clemens, UST Class B Operator dcirocz@aol.com

Tank Number	01	**Tank Age**	27	**Tank Installed Date**	01/30/1998	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	372	**Spill Test Date**	04/23/2025	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	04/23/2025	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date	04/23/2025			**ATG Type**	Franklin Fueling Systems/EVO 600				
Tank Number	02	**Tank Age**	27	**Tank Installed Date**	01/30/1998	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	373	**Spill Test Date**	04/23/2025	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel, Dyed	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	5000	**ATG Test Date**	04/23/2025	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date	04/23/2025			**ATG Type**	Franklin Fueling Systems/EVO 600				
Tank Number	03	**Tank Age**	27	**Tank Installed Date**	01/30/1998	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm

Tag Number	374	**Spill Test Date**	04/23/2025	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	04/23/2025	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date	04/23/2025			**ATG Type**	Franklin Fueling Systems/EVO 600				
Tank Number	04	**Tank Age**	27	**Tank Installed Date**	01/30/1998	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve
Tag Number	375	**Spill Test Date**	04/23/2025	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	5000	**ATG Test Date**	04/23/2025	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date	04/23/2025			**ATG Type**	Franklin Fueling Systems/EVO 600				

Facility Summary in Lewis and Clark County in the City of Helena

Location: EXEC AIR MONTANA INC 1
2430 Airport Rd
Helena, MT 59601-1234 Lewis and Clark

System Facility ID:25-00642

Facility Code: 23382
Last Inspected On: 12/06/2023
Operating Permit Renewal Date: 04/14/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Exec Air Montana Inc **(406) 442-2190** **adam_weitz@execairmontana.com**

Operator Contact:

Owner/Operator: Exec Air Montana Inc (406) 442-2190 adam_weitz@execairmontana.com

Tank Number	05	**Tank Age**	34	**Tank Installed Date**	06/01/1991	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	No Piping	**Overfill Types**	High Level Alarm
Tag Number	3344	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Gravity Feed	**CP Met Types**	Galvanic
Product	Aviation Gas	**PLLD Test Date**		**Tank/Piping CP Test Date**	12/06/2023	**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	04/11/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	04/11/2024			**ATG Type**	Franklin Fueling Systems/EVO 600				
Tank Number	06	**Tank Age**	34	**Tank Installed Date**	06/01/1991	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	No Piping	**Overfill Types**	High Level Alarm
Tag Number	3345	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Jet Fuel (Jet-A, Jet-A1, JP5)	**PLLD Test Date**		**Tank/Piping CP Test Date**	12/06/2023	**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	04/11/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	04/11/2024			**ATG Type**	Franklin Fueling Systems/EVO 600				
Tank Number	07	**Tank Age**	8	**Tank Installed Date**	09/10/2017	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	No Piping	**Overfill Types**	High Level Alarm

Tag Number	5765	**Spill Test Date**		**Piping Installed Date**	09/10/2017	**Tank Construction**	Double-Walled	**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Not Listed	**CP Met Types**	Non-corrodible
Product	Jet Fuel (Jet-A, Jet-A1, JP5)	**PLLD Test Date**		**Tank/Piping CP Test Date**	12/06/2023	**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	30000	**ATG Test Date**	04/11/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**		**Energy Act**	Yes
		Overfill Test Date	04/11/2024			**ATG Type**	Franklin Fueling Systems/EVO 600;Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Lewis and Clark County in the City of Helena

Location: EXEC AIR MONTANA INC 2
2430 Airport Rd
Helena, MT 59601-1234 Lewis and Clark

System Facility ID:25-02123

Facility Code: 23464
Last Inspected On: 04/11/2016
Operating Permit Renewal Date: 07/09/2018

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Exec Air Montana Inc	**(406) 442-2190**	**adam_weitz@execairmontana.com**
Operator Contact:	John Maxness	**(406) 449-9337**	**john@execairmontana.com**

John Maxness, UST Class A Operator — john@execairmontana.com
John Maxness, UST Class B Global Operator — john@execairmontana.com

Tank Number	01	**Tank Age**	59	**Tank Installed Date**	04/01/1966	**Tank Material Construction**	Bare Steel	**Piping Material**	No Piping	**Overfill Types**	High Level Alarm
Tag Number	3646	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Not Listed	**CP Met Types**	Impressed Current
Product	Jet Fuel (Jet-A, Jet-A1, JP5)	**PLLD Test Date**		**Tank/Piping CP Test Date**	09/11/2013	**Primary Tank Leak Detection**	Vapor Monitoring	**Primary Pipe Leak Detection**	Deferred	**Vapor Recovery**	No
Capacity	30000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	02	**Tank Age**	59	**Tank Installed Date**	04/01/1966	**Tank Material Construction**	Bare Steel	**Piping Material**	No Piping	**Overfill Types**	High Level Alarm
Tag Number	3647	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Not Listed	**CP Met Types**	Impressed Current
Product	Jet Fuel (Jet-A, Jet-A1, JP5)	**PLLD Test Date**		**Tank/Piping CP Test Date**	09/11/2013	**Primary Tank Leak Detection**	Vapor Monitoring	**Primary Pipe Leak Detection**	Deferred	**Vapor Recovery**	No
Capacity	30000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	03	**Tank Age**	59	**Tank Installed Date**	04/01/1966	**Tank Material Construction**	Bare Steel	**Piping Material**	No Piping	**Overfill Types**	High Level Alarm
Tag Number	3648	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No

Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Not Listed	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	09/11/2013	**Primary Tank Leak Detection**	Vapor Monitoring	**Primary Pipe Leak Detection**	Deferred	**Vapor Recovery**	No
Capacity	30000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	04	**Tank Age**	59	**Tank Installed Date**	04/01/1966	**Tank Material Construction**	Bare Steel	**Piping Material**	No Piping	**Overfill Types**	High Level Alarm
Tag Number	3649	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Not Listed	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	09/11/2013	**Primary Tank Leak Detection**	Vapor Monitoring	**Primary Pipe Leak Detection**	Deferred	**Vapor Recovery**	No
Capacity	30000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					

Facility Summary in Lewis and Clark County in the City of Helena

Location: EXEC AIR SELF SERVICE
3122 Airport Rd
Helena, MT 59601 Lewis and Clark

System Facility ID:25-12834

Facility Code: 23905
Last Inspected On: 07/14/2023
Operating Permit Renewal Date: 08/19/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	LEADING EDGE MONTANA DBA EXEC AIR MONTANA	**(406) 442-2190**	**adam_weitz@execairmontana.com**
Operator Contact:	Adam Weitz;Exec Air Montana Inc	**(406) 442-2190;(406) 442-2190**	**adam_weitz@execairmontana.com;adam_weitz@execairmontana.com**

Owner/Operator: LEADING EDGE MONTANA DBA EXEC AIR MONTANA (406) 442-2190 adam_weitz@execairmontana.com

Adam Weitz, UST Class A Operator adam_weitz@execairmontana.com

Adam Weitz, UST Class B Operator adam_weitz@execairmontana.com

Tank Number	01	**Tank Age**	33	**Tank Installed Date**	09/01/1992	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve
Tag Number	4444	**Spill Test Date**	05/18/2020	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	05/18/2020	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Aviation Gas	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	08/10/2023	**Line Tightness Test Date**	05/18/2020	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	05/18/2020			**ATG Type**	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Lewis and Clark County in the City of Helena

Location: FEDERAL RESERVE BANK HELENA
100 Neill Ave
Helena, MT 59601-3329 Lewis and Clark

System Facility ID:25-11291

Facility Code: 23861
Last Inspected On: 11/20/2024
Operating Permit Renewal Date: 01/09/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Federal Reserve Bank	**(406) 447-3919**	**chris.bruski@mpls.frb.org**
Operator Contact:	Timothy Leonard	**(406) 447-3946**	**tim.leonard@mpls.frb.org**

Owner/Operator: Federal Reserve Bank (406) 447-3919 chris.bruski@mpls.frb.org

Timothy Leonard, UST Class A Operator tim.leonard@mpls.frb.org

Timothy Leonard, UST Class B Operator tim.leonard@mpls.frb.org

Tank Number	S1	**Tank Age**	36	**Tank Installed Date**	10/01/1989	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	2322	**Spill Test Date**		**Piping Installed Date**	12/02/2002	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Heating Oil	**PLLD Test Date**		**Tank/Piping CP Test Date**	10/17/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	3-Year Line Tightness Test	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	10/17/2023	**Line Tightness Test Date**	05/01/2023	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	10/17/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-300				
Tank Number	01	**Tank Age**	1	**Tank Installed Date**	06/18/2024	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Steel with plastic coating	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	6240	**Spill Test Date**	06/28/2024	**Piping Installed Date**	06/18/2024	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	06/28/2024	**Catastrophic L.D. Type 3.0**		**Piping Type**	U.S. Suction	**CP Met Types**	Non-corrodible
Product	Diesel, Dyed	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	06/28/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	Approved Remote Monitoring	**Energy Act**	Yes
		Overfill Test Date	06/28/2024			**ATG Type**					

Facility Summary in Lewis and Clark County in the City of Helena

Location: FRIENDLYS SINCLAIR
1831 11th Ave
Helena, MT 59601-4769 Lewis and Clark

System Facility ID:25-01314

Facility Code: 23408
Last Inspected On: 04/17/2023
Operating Permit Renewal Date: 07/26/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Friendlys Inc	**(406) 442-4865**	**friendlys03@gmail.com**
Operator Contact:	Barbara Leland;Edward Dimock	**(406) 442-4865**	**barb640@hotmail.com;Lamond1329@aol.com**

Owner/Operator: Friendlys Inc (406) 442-4865 friendlys03@gmail.com

Barbara Leland, UST Class A Operator	barb640@hotmail.com
Barbara Leland, UST Class A Operator	barb640@hotmail.com
Edward Dimock, UST Class A Operator	Lamond1329@aol.com
Edward Dimock, UST Class A Operator	Lamond1329@aol.com
Edward Dimock, UST Class B Operator	Lamond1329@aol.com
Edward Dimock, UST Class B Operator	Lamond1329@aol.com
Scott Leland, UST Class B Operator	friendlys03@gmail.com

Tank Number	05	**Tank Age**	23	**Tank Installed Date**	01/02/2002	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve;Flapper Valve
Tag Number	4611	**Spill Test Date**	06/22/2021	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	04/17/2023	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**	04/17/2023	**Line Tightness Test Date**	04/17/2023	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	08/07/2023			**ATG Type**	Veeder Root/TLS-300				
Tank Number	06	**Tank Age**	23	**Tank Installed Date**	01/02/2002	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve;Flapper Valve
Tag Number	4612	**Spill Test Date**	09/22/2021	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	04/17/2023	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No

Capacity	12000	**ATG Test Date**	04/17/2023	**Line Tightness Test Date**	04/17/2023	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	08/07/2023			**ATG Type**	Veeder Root/TLS-300				
Tank Number	07	**Tank Age**	23	**Tank Installed Date**	01/02/2002	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve;Flapper Valve
Tag Number	4613	**Spill Test Date**	09/22/2021	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	04/17/2023	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	20000	**ATG Test Date**	04/17/2023	**Line Tightness Test Date**	04/17/2023	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	08/07/2023			**ATG Type**	Veeder Root/TLS-300				

Facility Summary in Lewis and Clark County in the City of Helena

Location: GATES OF THE MOUNTAINS INC
3106 Gates of The Mountains Rd
Helena, MT 59604-4478 Lewis and Clark

System Facility ID:25-06619

Facility Code: 23697
Last Inspected On: 11/12/2024
Operating Permit Renewal Date: 04/30/2028

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Gates of The Mountains Inc **(406) 458-5241**

Operator Contact: Brian Zimmerman;Melissa Zimmerman **info@gatesofthemountains.com;tugcapt78@gmail.com**

Owner/Operator: Gates of The Mountains Inc (406) 458-5241

Brian Zimmerman, UST Class A Operator tugcapt78@gmail.com
Brian Zimmerman, UST Class B Global Operator tugcapt78@gmail.com
Melissa Zimmerman, UST Class A Operator info@gatesofthemountains.com
Melissa Zimmerman, UST Class B Operator info@gatesofthemountains.com

Tank Number	03	**Tank Age**	39	**Tank Installed Date**	04/29/1986	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Steel	**Overfill Types**	Flapper Valve
Tag Number	1202	**Spill Test Date**	04/30/2024	**Piping Installed Date**	03/12/2007	**Tank Construction**	Double-Walled	**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	04/30/2024	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	11/12/2024	**Primary Tank Leak Detection**	Manual Interstitial Monitoring	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	5000	**ATG Test Date**		**Line Tightness Test Date**	04/21/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	04/30/2024			**ATG Type**					
Tank Number	04	**Tank Age**	39	**Tank Installed Date**	04/29/1986	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Steel	**Overfill Types**	Flapper Valve
Tag Number	1203	**Spill Test Date**	04/30/2024	**Piping Installed Date**	03/12/2007	**Tank Construction**	Double-Walled	**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	04/30/2024	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	11/12/2024	**Primary Tank Leak Detection**	Manual Interstitial Monitoring	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	1000	**ATG Test Date**		**Line Tightness Test Date**	04/21/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	04/30/2024			**ATG Type**					

Facility Summary in Lewis and Clark County in the City of Helena

Location: H AND R INC 7
3300 Green Meadow Dr
Helena, MT 59602-7707 Lewis and Clark

System Facility ID:25-05688

Facility Code: 23648
Last Inspected On: 04/27/2022
Operating Permit Renewal Date: 08/13/2025

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Singh Inc **(406) 868-2062** **inder4030@yahoo.com**

Operator Contact:

Owner/Operator: Singh Inc (406) 868-2062 inder4030@yahoo.com

Tank Number	01	**Tank Age**	46	**Tank Installed Date**	10/01/1979	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	3243	**Spill Test Date**	11/06/2024	**Piping Installed Date**		**Tank Construction**	Lined Interior/Impressed Current	**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	11/06/2024	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	04/27/2022	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	11/06/2024	**Line Tightness Test Date**	11/06/2024	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	11/06/2024			**ATG Type**	Gilbarco/EMC Basic				
Tank Number	02	**Tank Age**	46	**Tank Installed Date**	10/01/1979	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	3244	**Spill Test Date**	11/06/2024	**Piping Installed Date**	08/08/2007	**Tank Construction**	Lined Interior/Impressed Current	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	11/06/2024	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	04/27/2022	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	11/06/2024	**Line Tightness Test Date**	11/06/2024	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	11/06/2024			**ATG Type**	Gilbarco/EMC Basic				
Tank Number	03	**Tank Age**	18	**Tank Installed Date**	08/08/2007	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve

Tag Number	5135	**Spill Test Date**	11/06/2024	**Piping Installed Date**	08/08/2007	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	11/06/2024	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	04/27/2022	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	11/06/2024	**Line Tightness Test Date**	11/06/2024	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	11/06/2024			**ATG Type**	Gilbarco/EMC Basic				
Tank Number	04	**Tank Age**	18	**Tank Installed Date**	08/08/2007	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	5136	**Spill Test Date**	11/06/2024	**Piping Installed Date**	08/08/2007	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	11/06/2024	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel, Dyed	**PLLD Test Date**		**Tank/Piping CP Test Date**	04/27/2022	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	7000	**ATG Test Date**	11/06/2024	**Line Tightness Test Date**	11/06/2024	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	11/06/2024			**ATG Type**	Gilbarco/EMC Basic				

Facility Summary in Lewis and Clark County in the City of Helena

Location: HELENA MAIN CENTRAL OFFICE
441 N Park Ave
Helena, MT 59601-5020 Lewis and Clark

System Facility ID:25-08775

Facility Code: 23796
Last Inspected On: 04/24/2023
Operating Permit Renewal Date: 10/18/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Qwest Corporation/Century Link **kevin.robison@centurylink.com**

Operator Contact: Stephanie Miller **(501) 680-8141** **Stephanie.miller@lumen.com**

Owner/Operator: Qwest Corporation/Century Link kevin.robison@centurylink.com

Stephanie Miller, UST Class A Operator Stephanie.miller@lumen.com

Stephanie Miller, UST Class B Global Operator Stephanie.miller@lumen.com

Tank Number	02	**Tank Age**	33	**Tank Installed Date**	01/01/1992	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Steel	**Overfill Types**	High Level Alarm
Tag Number	1728	**Spill Test Date**	04/24/2023	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Continuous Interstitial Monitoring	**Piping Type**	U.S. Suction	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	3-Year Line Tightness Test	**Vapor Recovery**	No
Capacity	2500	**ATG Test Date**	04/24/2023	**Line Tightness Test Date**	02/27/2023	**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	04/24/2023			**ATG Type**	Veeder Root/TLS-300				

Facility Summary in Lewis and Clark County in the City of Helena

Location: HELENA SERVICE CENTER
1315 N Last Chance Gulch
Helena, MT 59601-2909 Lewis and Clark

System Facility ID:25-01183

Facility Code: 23405
Last Inspected On: 03/02/2023
Operating Permit Renewal Date: 08/12/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Northwestern Energy Butte	**(406) 655-2521**	**beth.stimatz@northwestern.com**
Operator Contact:	Brian Ranf;John Habeger;Kellen Gilreath;Phil Hatfield	**(406) 239-0025;(406) 443-8951**	**brian.ranf@northwestern.com;Grimacepch@aol.com;john.habeger@northwestern.com;kellenjgilreath@yahoo.com**

Owner/Operator:	Northwestern Energy Butte	(406) 655-2521	beth.stimatz@northwestern.com
	Brian Ranf, UST Class A Operator		brian.ranf@northwestern.com
	John Habeger, UST Class A Operator		john.habeger@northwestern.com
	John Habeger, UST Class A Operator		john.habeger@northwestern.com
	John Habeger, UST Class A Operator		john.habeger@northwestern.com
	Kellen Gilreath, UST Class A Operator		kellenjgilreath@yahoo.com
	Kellen Gilreath, UST Class A Operator		kellenjgilreath@yahoo.com
	Kellen Gilreath, UST Class A Operator		kellenjgilreath@yahoo.com
	Kellen Gilreath, UST Class B Global Operator		kellenjgilreath@yahoo.com
	Kellen Gilreath, UST Class B Global Operator		kellenjgilreath@yahoo.com
	Kellen Gilreath, UST Class B Global Operator		kellenjgilreath@yahoo.com
	Phil Hatfield, UST Class A Operator		Grimacepch@aol.com
	Phil Hatfield, UST Class A Operator		Grimacepch@aol.com
	Phil Hatfield, UST Class A Operator		Grimacepch@aol.com
	Phil Hatfield, UST Class B Global Operator		Grimacepch@aol.com
	Phil Hatfield, UST Class B Global Operator		Grimacepch@aol.com
	Phil Hatfield, UST Class B Global Operator		Grimacepch@aol.com

Tank Number	04	**Tank Age**	27	**Tank Installed Date**	05/01/1998	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	1678	**Spill Test Date**	09/17/2021	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	06/08/2022	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No

		Overfill Test Date	09/17/2021			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	05	**Tank Age**	27	**Tank Installed Date**	05/01/1998	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	1679	**Spill Test Date**	09/17/2021	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	06/08/2022	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	09/17/2021			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Lewis and Clark County in the City of Helena

Location: JOLLY OS GAS N GO
1200 Cedar St
Helena, MT 59601 Lewis and Clark

System Facility ID:25-04966

Facility Code: 23600
Last Inspected On: 03/18/2025
Operating Permit Renewal Date: 03/18/2028

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Stockton Oil Co Billings **office@stocktonoil.com**

Operator Contact:

Owner/Operator: Stockton Oil Co Billings office@stocktonoil.com

Joseph Stockton, UST Class B Global Operator jstockton@stocktonoil.com

Joseph Stockton, UST Class B Global Operator jstockton@stocktonoil.com

Tank Number	01	**Tank Age**	40	**Tank Installed Date**	03/26/1985	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Steel	**Overfill Types**	Flapper Valve
Tag Number	4784	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Single Walled	**AST**	No
Status	**Temporarily Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	03/18/2025	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing;Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	02	**Tank Age**	40	**Tank Installed Date**	03/26/1985	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Steel	**Overfill Types**	Flapper Valve
Tag Number	4785	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Temporarily Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	03/18/2025	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing;Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No

		Overfill Test Date				**ATG Type**					
Tank Number	04	**Tank Age**	34	**Tank Installed Date**	09/01/1991	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Positive Shutoff
Tag Number	4786	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Temporarily Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	03/18/2025	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing;Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					

Facility Summary in Lewis and Clark County in the City of Helena

Location: KIMS MARINA AND RESORT
8015 Canyon Ferry Rd
Helena, MT 59602-8509 Lewis and Clark

System Facility ID:25-01091

Facility Code: 23401
Last Inspected On: 02/03/2023
Operating Permit Renewal Date: 05/10/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: 8015 LLC **(303) 356-4071** **lukejewett65@gmail.com**

Operator Contact: Joseph Musalek **jmusalek1@gmail.com**

Owner/Operator: 8015 LLC (303) 356-4071 lukejewett65@gmail.com

Joseph Musalek, UST Class A Operator jmusalek1@gmail.com

Joseph Musalek, UST Class B Operator jmusalek1@gmail.com

Tank Number	05	**Tank Age**	32	**Tank Installed Date**	05/01/1993	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	3516	**Spill Test Date**	06/15/2021	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	11/22/2022	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	3782	**ATG Test Date**	11/22/2022	**Line Tightness Test Date**	11/22/2022	**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	02/03/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Lewis and Clark County in the City of Helena

Location: LAKESIDE MARKET AND GAS
5330 York Rd
Helena, MT 59602 Lewis and Clark

System Facility ID:25-13657

Facility Code: 23950
Last Inspected On: 10/19/2023
Operating Permit Renewal Date: 03/30/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Sandra Gast;Sunflower LLC	**(406) 422-8407**	**sunflowerllc@outlook.com**
Operator Contact:	Sandra Gast;Shari Winters	**(406) 227-8157**	**winchums1@gmail.com**

Owner/Operator: Sandra Gast

Owner/Operator: Sunflower LLC

Jessica Minetti, UST Class B Operator	jminetti9@gmail.com
Sandra Gast, UST Class A Operator	
Sandra Gast, UST Class B Operator	
Shari Winters, UST Class A Operator	winchums1@gmail.com
Trisha Huston, UST Class B Operator	tmbr2010@gmail.com

Tank Number	02	**Tank Age**	30	**Tank Installed Date**	07/24/1995	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	4552	**Spill Test Date**	10/19/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	10/19/2023	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	5000	**ATG Test Date**	10/19/2023	**Line Tightness Test Date**	10/19/2023	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	10/19/2023			**ATG Type**	Veeder Root/TLS-300				
Tank Number	01	**Tank Age**	30	**Tank Installed Date**	07/01/1995	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	4553	**Spill Test Date**	10/19/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	10/19/2023	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	10/19/2023	**Line Tightness Test Date**	10/19/2023	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No

		Overfill Test Date	10/19/2023			**ATG Type**	Veeder Root/TLS-300				

Facility Summary in Lewis and Clark County in the City of Helena

Location: LITHIA CHRYSLER JEEP DODGE RAM OF HELENA
3401 US Hwy 12 E
Helena, MT 59601-9708 Lewis and Clark

System Facility ID:25-13687

Facility Code: 23952
Last Inspected On: 08/26/2020
Operating Permit Renewal Date: 08/28/2023

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Lithia Chrysler Jeep Dodge Ram of Helena **(406) 442-9994** **astewart@lithia.com**

Operator Contact:

Owner/Operator: Lithia Chrysler Jeep Dodge Ram of Helena (406) 442-9994 astewart@lithia.com

Howard Reed, UST Class B Operator hreed@lithia.com

Justin Smith, UST Class B Operator jsmith@lithia.com

Tank Number	01	**Tank Age**	29	**Tank Installed Date**	03/15/1996	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Steel	**Overfill Types**	
Tag Number	1244	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Secondary Containment Chase	**AST**	No
Status	**Temporarily Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	U.S. Suction	**CP Met Types**	Galvanic
Product	Oil, Waste	**PLLD Test Date**		**Tank/Piping CP Test Date**	08/26/2020	**Primary Tank Leak Detection**	Manual Interstitial Monitoring	**Primary Pipe Leak Detection**	Manual Interstitial Monitoring	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**		**Line Tightness Test Date**	04/03/2024	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	3-Year Line Tightness Test	**Energy Act**	No
		Overfill Test Date				**ATG Type**					

Facility Summary in Lewis and Clark County in the City of Helena

Location: MAVERIK # 731
3196 Colonial Drive
Helena, MT 59601 Lewis and Clark

System Facility ID:00-32528

Facility Code: 32528
Last Inspected On: 06/18/2024
Operating Permit Renewal Date: 06/18/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Maverick, Inc. **(801) 335-3898**

Operator Contact: Alana May;Maverik Inc **(801) 244-9025;(801) 910-7061** **alana.may@maverik.com;dennis.riding@maverik.com**

Owner/Operator: Maverick, Inc. (801) 335-3898

Alana May, UST Class A Operator dennis.riding@maverik.com
Alana May, UST Class B Operator dennis.riding@maverik.com
Erin Angove, UST Class B Operator hbigbearmt@aol.com

Tank Number	01	**Tank Age**	2	**Tank Installed Date**	08/01/2023	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	6181	**Spill Test Date**	02/21/2024	**Piping Installed Date**	10/23/2023	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	10/05/2023	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	Yes
Capacity	40000	**ATG Test Date**	02/21/2024	**Line Tightness Test Date**	09/23/2024	**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	02/21/2024			**ATG Type**					
Tank Number	02	**Tank Age**	2	**Tank Installed Date**	08/01/2023	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	6182	**Spill Test Date**	02/21/2024	**Piping Installed Date**	10/03/2023	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	10/05/2023	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	40000	**ATG Test Date**	02/21/2024	**Line Tightness Test Date**	09/23/2024	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	02/21/2024			**ATG Type**					

Tank Number	03	**Tank Age**	2	**Tank Installed Date**	08/01/2023	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	6183	**Spill Test Date**	02/21/2024	**Piping Installed Date**	10/03/2023	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	10/05/2023	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	Yes
Capacity	16000	**ATG Test Date**	02/21/2024	**Line Tightness Test Date**	02/21/2024	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	02/21/2024			**ATG Type**					
Tank Number	04	**Tank Age**	2	**Tank Installed Date**	08/01/2023	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	6184	**Spill Test Date**	02/21/2024	**Piping Installed Date**	10/03/2023	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	10/05/2023	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	Yes
Capacity	16000	**ATG Test Date**	02/21/2024	**Line Tightness Test Date**	02/21/2024	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	02/21/2024			**ATG Type**					
Tank Number	05	**Tank Age**	2	**Tank Installed Date**	08/01/2023	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	6185	**Spill Test Date**	02/21/2024	**Piping Installed Date**	10/03/2023	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	02/21/2024	**Catastrophic L.D. Type 3.0**		**Piping Type**	Pressurized	**CP Met Types**	
Product	DEF (Not Regulated)	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	02/21/2024	**Line Tightness Test Date**	02/21/2024	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	Yes
		Overfill Test Date	02/21/2024			**ATG Type**					

Facility Summary in Lewis and Clark County in the City of Helena

Location: MDOT HELENA HEADQUARTERS
2701 Prospect Ave
Helena, MT 59601-9746 Lewis and Clark

System Facility ID:25-06849

Facility Code: 23715
Last Inspected On: 08/15/2023
Operating Permit Renewal Date: 11/19/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	MDOT Helena	**(406) 444-6163**	**mmurolo@mt.gov**
Operator Contact:	Joe Radonich;Montana Dept of Transportation;Mike Murolo;Montana Dept of Transportation;Tracy Deeds;MDOT Helena;Walt Kerttula;Montana Dept of Transportation	**(406) 444-6151;(406) 444-7632;(406) 444-6163;(406) 444-7632;(406) 444-9204;(406) 444-7632;(406) 461-0769;(406) 444-6163**	**jradonich@mt.gov;jradonich@mt.gov;mmurolo@mt.gov;jradonich@mt.gov;tdeeds@mt.gov;mmurolo@mt.gov;wkerttula@mt.gov;jradonich@mt.gov**

Owner/Operator: MDOT Helena (406) 444-6163 mmurolo@mt.gov

Douglas Robbins, UST Class B Global Operator	jradonich@mt.gov
Joe Radonich, UST Class A Operator	jradonich@mt.gov
Joe Radonich, UST Class B Global Operator	jradonich@mt.gov
Karl Thalmann, UST Class B Operator	jradonich@mt.gov
Mike Murolo, UST Class A Operator	jradonich@mt.gov
Tracy Deeds, UST Class A Operator	mmurolo@mt.gov
Walt Kerttula, UST Class A Operator	jradonich@mt.gov

Tank Number	04	**Tank Age**	29	**Tank Installed Date**	03/01/1996	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve
Tag Number	2911	**Spill Test Date**	06/27/2023	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	06/27/2023	**Line Tightness Test Date**	01/27/2017	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	06/27/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	05	**Tank Age**	29	**Tank Installed Date**	03/01/1996	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve
Tag Number	2912	**Spill Test Date**	06/27/2023	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No

Capacity	12000	**ATG Test Date**	06/27/2023	**Line Tightness Test Date**	01/17/2017	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	06/27/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Lewis and Clark County in the City of Helena

Location: MDT EQUIPMENT DEVELOPMENT BUILDING
490 18th St
Helena, MT 59601 Lewis and Clark

System Facility ID:60-15139

Facility Code: 30883
Last Inspected On: 04/17/2023
Operating Permit Renewal Date: 05/15/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Montana Dept of Administration **(406) 444-3060**

Operator Contact: Ed Sivils **esivils@mt.gov**

Owner/Operator: Montana Dept of Administration (406) 444-3060

Daniel Messerli, UST Class B Operator	dan_messerli@hotmail.com
David Spradlin, UST Class B Operator	DSpradlin2@mt.gov
Ed Sivils, UST Class A Operator	esivils@mt.gov
Ed Sivils, UST Class B Operator	esivils@mt.gov
James Simmons, UST Class B Operator	jasimms35@yahoo.com

Tank Number	S1	**Tank Age**	16	**Tank Installed Date**	10/01/2009	**Tank Material Construction**	Aboveground Tank	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	5214	**Spill Test Date**		**Piping Installed Date**	07/08/2009	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	Yes
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	04/17/2023	**Catastrophic L.D. Type 3.0**	Auto Dialer	**Piping Type**	Pressurized	**CP Met Types**	
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	04/17/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	Yes
		Overfill Test Date	04/17/2023			**ATG Type**					
Tank Number	S2	**Tank Age**	13	**Tank Installed Date**	10/01/2012	**Tank Material Construction**	Aboveground Tank	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	5386	**Spill Test Date**		**Piping Installed Date**	07/31/2012	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	Yes
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	04/17/2023	**Catastrophic L.D. Type 3.0**	Auto Dialer	**Piping Type**	U.S. Suction	**CP Met Types**	
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	04/17/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	Yes

		Overfill Test Date	04/17/2023			**ATG Type**					

Facility Summary in Lewis and Clark County in the City of Helena

Location: MERGENTHALER TRANSFER AND STORAGE
CARTER DR
1430 Carter Dr
Helena, MT 59601-6429 Lewis and Clark

System Facility ID:56-13831

Facility Code: 30515
Last Inspected On: 12/21/2023
Operating Permit Renewal Date: 03/19/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Mergenthalers Transfer and Storage	**(406) 442-9470**	**merg_ap@mergenthaler.net**

Operator Contact:	Dave Gardner;Justin Archer;Mergenthalers Transfer and Storage	**(406) 442-9470**	**dgardner@mergenthaler.net;jarcher@ccfs.com;merg_ap@mergenthaler.net**

Owner/Operator: Mergenthalers Transfer and Storage (406) 442-9470 merg_ap@mergenthaler.net

Dave Gardner, UST Class A Operator dgardner@mergenthaler.net
Dave Gardner, UST Class B Operator dgardner@mergenthaler.net
Justin Archer, UST Class A Operator merg_ap@mergenthaler.net

Tank Number	01	**Tank Age**	28	**Tank Installed Date**	11/01/1997	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	
Tag Number	1609	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Gravity Feed	**CP Met Types**	Galvanic
Product	Oil, Waste	**PLLD Test Date**		**Tank/Piping CP Test Date**	12/21/2023	**Primary Tank Leak Detection**	Manual Interstitial Monitoring	**Primary Pipe Leak Detection**	3-Year Line Tightness Test	**Vapor Recovery**	No
Capacity	3000	**ATG Test Date**		**Line Tightness Test Date**	12/21/2023	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Manual Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date				**ATG Type**					

Facility Summary in Lewis and Clark County in the City of Helena

Location: MOUNTAIN VIEW COOP HELENA
720 Custer Ave
Helena, MT 59602 Lewis and Clark

System Facility ID:60-15323

Facility Code: 31020
Last Inspected On: 06/16/2023
Operating Permit Renewal Date: 06/21/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Mountain View Coop Black Eagle **(406) 453-5900** **ddouglas@mountainviewcoop.com**

Operator Contact: David Douglas **ddouglas@mountainviewcoop.com**

Owner/Operator: Mountain View Coop Black Eagle (406) 453-5900 ddouglas@mountainviewcoop.com

Cody Tripp, UST Class B Global Operator ctripp@mountainviewcoop.com

David Douglas, UST Class A Operator ddouglas@mountainviewcoop.com

Tank Number	01	**Tank Age**	7	**Tank Installed Date**	11/19/2018	**Tank Material Construction**	Steel Clad	**Piping Material**	Flexible Plastic	**Overfill Types**	Positive Shutoff
Tag Number	5841	**Spill Test Date**	06/16/2023	**Piping Installed Date**	11/19/2018	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	12/05/2019	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	06/16/2023	**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	Yes
Capacity	30000	**ATG Test Date**	06/16/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	06/16/2023			**ATG Type**	Incon/TS-550 EVO				
Tank Number	02	**Tank Age**	7	**Tank Installed Date**	11/19/2018	**Tank Material Construction**	Steel Clad	**Piping Material**	Flexible Plastic	**Overfill Types**	Positive Shutoff
Tag Number	5842	**Spill Test Date**	06/16/2023	**Piping Installed Date**	11/19/2018	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	12/05/2019	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	06/16/2023	**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	Yes
Capacity	9000	**ATG Test Date**	06/16/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	06/16/2023			**ATG Type**	Incon/TS-550 EVO				
Tank Number	03	**Tank Age**	7	**Tank Installed Date**	11/19/2018	**Tank Material Construction**	Steel Clad	**Piping Material**	Flexible Plastic	**Overfill Types**	Positive Shutoff

Tag Number	5843	**Spill Test Date**	06/16/2023	**Piping Installed Date**	11/19/2018	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	12/05/2019	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	06/16/2023	**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	Yes
Capacity	9000	**ATG Test Date**	06/16/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	06/16/2023			**ATG Type**	Incon/TS-550 EVO				
Tank Number	04	**Tank Age**	7	**Tank Installed Date**	11/19/2018	**Tank Material Construction**	Steel Clad	**Piping Material**	Flexible Plastic	**Overfill Types**	Positive Shutoff
Tag Number	5844	**Spill Test Date**	06/16/2023	**Piping Installed Date**	11/19/2018	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	12/05/2019	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	06/16/2023	**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	06/16/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	06/16/2023			**ATG Type**	Incon/TS-550 EVO				

Facility Summary in Lewis and Clark County in the City of Helena

Location: PAR MONTANA HELENA PRODUCTS TERMINAL
3120 E US Hwy 12
Helena, MT 59601-9701 Lewis and Clark

System Facility ID:25-08728

Facility Code: 23795
Last Inspected On: 07/01/2024
Operating Permit Renewal Date: 10/13/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	PAR MONTANA	**(281) 899-4847**	**bmcfarland@parpacific.com**
Operator Contact:	Bry Joaillier Allen;Christopher Martin;James Vokral;Janie Lee;Jason Martin;Michael Bailey;Michael James;Robert Ochsenbein	**(406) 586-6927;(406) 657-5404;(435) 764-7049;(832) 624-7774;(832) 624-7876**	**colt_ochsenbein@hotmail.com;jason.m.martin@exxonmobil.com**
Owner/Operator:	PAR MONTANA	(281) 899-4847	bmcfarland@parpacific.com

Bry Joaillier Allen, UST Class A Operator
Bry Joaillier Allen, UST Class A Operator
Bry Joaillier Allen, UST Class A Operator
Bry Joaillier Allen, UST Class B Global Operator
Bry Joaillier Allen, UST Class B Global Operator
Bry Joaillier Allen, UST Class B Global Operator
Christopher Martin, UST Class A Operator
Christopher Martin, UST Class A Operator
Christopher Martin, UST Class A Operator
Christopher Martin, UST Class B Operator
Christopher Martin, UST Class B Operator
Christopher Martin, UST Class B Operator
James Vokral, UST Class A Operator
James Vokral, UST Class A Operator
James Vokral, UST Class A Operator
James Vokral, UST Class B Global Operator
James Vokral, UST Class B Global Operator
James Vokral, UST Class B Global Operator
Janie Lee, UST Class A Operator
Janie Lee, UST Class A Operator
Janie Lee, UST Class A Operator
Janie Lee, UST Class B Global Operator
Janie Lee, UST Class B Global Operator
Janie Lee, UST Class B Global Operator
Jim Gullon, UST Class B Global Operator
Jim Gullon, UST Class B Global Operator

Jim Gullon, UST Class B Global Operator	
M Martin, UST Class A Operator	jason.m.martin@exxonmobil.com
M Martin, UST Class A Operator	jason.m.martin@exxonmobil.com
M Martin, UST Class A Operator	jason.m.martin@exxonmobil.com
M Martin, UST Class B Global Operator	jason.m.martin@exxonmobil.com
M Martin, UST Class B Global Operator	jason.m.martin@exxonmobil.com
M Martin, UST Class B Global Operator	jason.m.martin@exxonmobil.com
Marc Larson, UST Class B Global Operator	
Marc Larson, UST Class B Global Operator	
Marc Larson, UST Class B Global Operator	
Michael Bailey, UST Class A Operator	
Michael Bailey, UST Class A Operator	
Michael Bailey, UST Class A Operator	
Michael Bailey, UST Class B Global Operator	
Michael Bailey, UST Class B Global Operator	
Michael Bailey, UST Class B Global Operator	
Michael James, UST Class A Operator	
Michael James, UST Class A Operator	
Michael James, UST Class A Operator	
Michael James, UST Class B Global Operator	
Michael James, UST Class B Global Operator	
Michael James, UST Class B Global Operator	
Robert Ochsenbein, UST Class A Operator	colt_ochsenbein@hotmail.com
Robert Ochsenbein, UST Class A Operator	colt_ochsenbein@hotmail.com
Robert Ochsenbein, UST Class A Operator	colt_ochsenbein@hotmail.com
Robert Ochsenbein, UST Class B Global Operator	colt_ochsenbein@hotmail.com
Robert Ochsenbein, UST Class B Global Operator	colt_ochsenbein@hotmail.com
Robert Ochsenbein, UST Class B Global Operator	colt_ochsenbein@hotmail.com

Tank Number	14	**Tank Age**	38	**Tank Installed Date**	01/01/1987	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Steel	**Overfill Types**	High Level Alarm
Tag Number	2767	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	06/18/2024	**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Gravity Feed	**CP Met Types**	Impressed Current
Product	Mixture	**PLLD Test Date**		**Tank/Piping CP Test Date**	06/24/2021	**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Terminal Piping Annual Line Test	**Vapor Recovery**	No
Capacity	2000	**ATG Test Date**		**Line Tightness Test Date**	12/07/2023	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	07/01/2024			**ATG Type**	Other/Other				

Tank Number	S01	**Tank Age**	75	**Tank Installed Date**	01/01/1950	**Tank Material Construction**	Bare Steel	**Piping Material**	Steel - Terminal Piping	**Overfill Types**	
Tag Number	2768	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	Yes
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	07/13/2023	**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**	Terminal Piping Annual Line Test	**Vapor Recovery**	No
Capacity	603330	**ATG Test Date**		**Line Tightness Test Date**	12/06/2023	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	S03	**Tank Age**	75	**Tank Installed Date**	01/01/1950	**Tank Material Construction**	Bare Steel	**Piping Material**	Steel - Terminal Piping	**Overfill Types**	
Tag Number	2770	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	Yes
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Pressurized	**CP Met Types**	
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	07/13/2023	**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**	Terminal Piping Annual Line Test	**Vapor Recovery**	No
Capacity	604000	**ATG Test Date**		**Line Tightness Test Date**	12/15/2023	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	S05	**Tank Age**	75	**Tank Installed Date**	01/01/1950	**Tank Material Construction**	Bare Steel	**Piping Material**	Steel - Terminal Piping	**Overfill Types**	
Tag Number	2772	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	Yes
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Pressurized	**CP Met Types**	
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	07/13/2023	**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**	Terminal Piping Annual Line Test	**Vapor Recovery**	No
Capacity	1200000	**ATG Test Date**		**Line Tightness Test Date**	12/04/2024	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	S07	**Tank Age**	75	**Tank Installed Date**	01/01/1950	**Tank Material Construction**	Bare Steel	**Piping Material**	Steel - Terminal Piping	**Overfill Types**	
Tag Number	2774	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	Yes
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Pressurized	**CP Met Types**	
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	07/13/2023	**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**	Terminal Piping Annual Line Test	**Vapor Recovery**	No
Capacity	638000	**ATG Test Date**		**Line Tightness Test Date**	12/11/2023	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No

		Overfill Test Date				**ATG Type**					
Tank Number	S11	**Tank Age**	75	**Tank Installed Date**	01/01/1950	**Tank Material Construction**	Bare Steel	**Piping Material**	Steel - Terminal Piping	**Overfill Types**	
Tag Number	2778	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	Yes
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Pressurized	**CP Met Types**	
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	07/13/2023	**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**	Terminal Piping Annual Line Test	**Vapor Recovery**	No
Capacity	633000	**ATG Test Date**		**Line Tightness Test Date**	12/13/2023	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	S15	**Tank Age**	38	**Tank Installed Date**	01/01/1987	**Tank Material Construction**	Bare Steel	**Piping Material**	Steel	**Overfill Types**	
Tag Number	2780	**Spill Test Date**		**Piping Installed Date**	01/11/2017	**Tank Construction**		**Piping Construction**	Secondary Containment Chase	**AST**	Yes
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	06/18/2024	**Catastrophic L.D. Type 3.0**	Continuous Interstitial Monitoring	**Piping Type**	Pressurized	**CP Met Types**	
Product	Hazardous Substance	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	S18	**Tank Age**	38	**Tank Installed Date**	01/01/1987	**Tank Material Construction**	Bare Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	
Tag Number	2783	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	Yes
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	09/28/2021	**Catastrophic L.D. Type 3.0**	Continuous Interstitial Monitoring	**Piping Type**	Pressurized	**CP Met Types**	
Product	Hazardous Substance	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Deferred	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	3000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	S21	**Tank Age**	38	**Tank Installed Date**	01/01/1987	**Tank Material Construction**	Bare Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	
Tag Number	2786	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	Yes

Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	06/18/2024	**Catastrophic L.D. Type 3.0**	Continuous Interstitial Monitoring	**Piping Type**	Pressurized	**CP Met Types**	
Product	Hazardous Substance	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Deferred	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	1000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					

Facility Summary in Lewis and Clark County in the City of Helena

Location: PHILLIPS 66 HELENA TERMINAL
3180 E US Hwy 12
Helena, MT 59601-9701 Lewis and Clark

System Facility ID:25-01846

Facility Code: 23445
Last Inspected On: 10/26/2023
Operating Permit Renewal Date: 06/28/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Phillips 66 Helena Terminal	**(406) 255-5714**	
Operator Contact:	Brian Buckley;Ryan Norwood	**(406) 441-4752**	**Ryan.P.Norwood@p66.com**

Owner/Operator: Phillips 66 Helena Terminal (406) 255-5714

Brian Buckley, UST Class A Operator	
Brian Buckley, UST Class A Operator	
Brian Buckley, UST Class A Operator	
Brian Buckley, UST Class B Operator	
Brian Buckley, UST Class B Operator	
Brian Buckley, UST Class B Operator	
Clifford Pearce, UST Class B Operator	cliff.e.pearce@conocophillips.com
Clifford Pearce, UST Class B Operator	cliff.e.pearce@conocophillips.com
Clifford Pearce, UST Class B Operator	cliff.e.pearce@conocophillips.com
Dane Whittaker, UST Class B Global Operator	dane.t.whittaker@conocophillips.com
Dane Whittaker, UST Class B Global Operator	dane.t.whittaker@conocophillips.com
Dane Whittaker, UST Class B Global Operator	dane.t.whittaker@conocophillips.com
Jeb Pedrazzi, UST Class B Global Operator	jeb.c.pedrazzi@p66.com
Jeb Pedrazzi, UST Class B Global Operator	jeb.c.pedrazzi@p66.com
Jeb Pedrazzi, UST Class B Global Operator	jeb.c.pedrazzi@p66.com
Ryan Norwood, UST Class A Operator	Ryan.P.Norwood@p66.com
Ryan Norwood, UST Class A Operator	Ryan.P.Norwood@p66.com
Ryan Norwood, UST Class A Operator	Ryan.P.Norwood@p66.com
Ryan Norwood, UST Class B Operator	Ryan.P.Norwood@p66.com
Ryan Norwood, UST Class B Operator	Ryan.P.Norwood@p66.com
Ryan Norwood, UST Class B Operator	Ryan.P.Norwood@p66.com

Tank Number	S30OUT	**Tank Age**	72	**Tank Installed Date**	01/01/1953	**Tank Material Construction**	Unknown	**Piping Material**	Steel - Terminal Piping	**Overfill Types**	
Tag Number	4259	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Regulated by DOT**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Pressurized	**CP Met Types**	

Product	Kerosene	**PLLD Test Date**		**Tank/Piping CP Test Date**	06/13/2006	**Primary Tank Leak Detection**	Deferred	**Primary Pipe Leak Detection**	Approved Remote Monitoring;MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	840000	**ATG Test Date**		**Line Tightness Test Date**	08/23/2006	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	39	**Tank Age**	32	**Tank Installed Date**	01/01/1993	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Steel	**Overfill Types**	High Level Alarm
Tag Number	4919	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Gravity Feed	**CP Met Types**	
Product	Mixture	**PLLD Test Date**		**Tank/Piping CP Test Date**	05/14/2020	**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	3-Year Line Tightness Test	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**		**Line Tightness Test Date**	10/18/2023	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	10/26/2023			**ATG Type**	Other/Other				
Tank Number	S30IN	**Tank Age**	72	**Tank Installed Date**	01/01/1953	**Tank Material Construction**	Unknown	**Piping Material**	Steel - Terminal Piping	**Overfill Types**	
Tag Number	725	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Regulated by DOT**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Pressurized	**CP Met Types**	
Product	Kerosene	**PLLD Test Date**		**Tank/Piping CP Test Date**	06/13/2006	**Primary Tank Leak Detection**	Deferred	**Primary Pipe Leak Detection**	Approved Remote Monitoring;MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	840000	**ATG Test Date**		**Line Tightness Test Date**	08/23/2006	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	S31IN	**Tank Age**	72	**Tank Installed Date**	01/01/1953	**Tank Material Construction**	Unknown	**Piping Material**	Steel - Terminal Piping	**Overfill Types**	
Tag Number	727	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Regulated by DOT**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Pressurized	**CP Met Types**	
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	06/13/2006	**Primary Tank Leak Detection**	Not Listed	**Primary Pipe Leak Detection**	Approved Remote Monitoring;MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	1260000	**ATG Test Date**		**Line Tightness Test Date**	08/23/2006	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No

		Overfill Test Date				**ATG Type**					
Tank Number	S31OUT	**Tank Age**	72	**Tank Installed Date**	01/01/1953	**Tank Material Construction**	Unknown	**Piping Material**	Steel - Terminal Piping	**Overfill Types**	
Tag Number	728	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Regulated by DOT**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Pressurized	**CP Met Types**	
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	06/13/2006	**Primary Tank Leak Detection**	Not Listed	**Primary Pipe Leak Detection**	Approved Remote Monitoring;MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	1260000	**ATG Test Date**		**Line Tightness Test Date**	08/23/2006	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	S32IN	**Tank Age**	72	**Tank Installed Date**	01/01/1953	**Tank Material Construction**	Unknown	**Piping Material**	Steel - Terminal Piping	**Overfill Types**	
Tag Number	729	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Regulated by DOT**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Pressurized	**CP Met Types**	
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	06/13/2006	**Primary Tank Leak Detection**	Deferred	**Primary Pipe Leak Detection**	Approved Remote Monitoring;MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	840000	**ATG Test Date**		**Line Tightness Test Date**	08/23/2006	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	S32OUT	**Tank Age**	72	**Tank Installed Date**	01/01/1953	**Tank Material Construction**	Unknown	**Piping Material**	Steel - Terminal Piping	**Overfill Types**	
Tag Number	730	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Regulated by DOT**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Pressurized	**CP Met Types**	
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	06/13/2006	**Primary Tank Leak Detection**	Deferred	**Primary Pipe Leak Detection**	Approved Remote Monitoring;MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	840000	**ATG Test Date**		**Line Tightness Test Date**	08/23/2006	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	S33IN	**Tank Age**	72	**Tank Installed Date**	01/01/1953	**Tank Material Construction**	Unknown	**Piping Material**	Steel - Terminal Piping	**Overfill Types**	
Tag Number	731	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No

Status	**Regulated by DOT**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Pressurized	**CP Met Types**	
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	06/13/2006	**Primary Tank Leak Detection**	Not Listed	**Primary Pipe Leak Detection**	Approved Remote Monitoring;MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	1260000	**ATG Test Date**		**Line Tightness Test Date**	08/23/2006	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	S33OUT	**Tank Age**	72	**Tank Installed Date**	01/01/1953	**Tank Material Construction**	Unknown	**Piping Material**	Steel - Terminal Piping	**Overfill Types**	
Tag Number	732	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Regulated by DOT**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Pressurized	**CP Met Types**	
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	06/13/2006	**Primary Tank Leak Detection**	Not Listed	**Primary Pipe Leak Detection**	Approved Remote Monitoring;MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	1260000	**ATG Test Date**		**Line Tightness Test Date**	08/23/2006	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	S35OUT	**Tank Age**	66	**Tank Installed Date**	01/01/1959	**Tank Material Construction**	Unknown	**Piping Material**	Steel - Terminal Piping	**Overfill Types**	
Tag Number	733	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Regulated by DOT**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Pressurized	**CP Met Types**	
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	06/13/2006	**Primary Tank Leak Detection**	Not Listed	**Primary Pipe Leak Detection**	Approved Remote Monitoring;MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	1260000	**ATG Test Date**		**Line Tightness Test Date**	08/23/2006	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	S35IN	**Tank Age**	66	**Tank Installed Date**	01/01/1959	**Tank Material Construction**	Unknown	**Piping Material**	Steel - Terminal Piping	**Overfill Types**	
Tag Number	734	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Regulated by DOT**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Pressurized	**CP Met Types**	
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	06/13/2006	**Primary Tank Leak Detection**	Not Listed	**Primary Pipe Leak Detection**	Approved Remote Monitoring;MLLD Line Tightness Testing	**Vapor Recovery**	No

Capacity	1260000	**ATG Test Date**		**Line Tightness Test Date**	08/23/2006	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	S36IN	**Tank Age**	66	**Tank Installed Date**	01/01/1959	**Tank Material Construction**	Unknown	**Piping Material**	Steel - Terminal Piping	**Overfill Types**	
Tag Number	735	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Regulated by DOT**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Pressurized	**CP Met Types**	
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	06/13/2006	**Primary Tank Leak Detection**	Not Listed	**Primary Pipe Leak Detection**	Approved Remote Monitoring;MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	1260000	**ATG Test Date**		**Line Tightness Test Date**	08/23/2006	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	S36OUT	**Tank Age**	66	**Tank Installed Date**	01/01/1959	**Tank Material Construction**	Unknown	**Piping Material**	Steel - Terminal Piping	**Overfill Types**	
Tag Number	736	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Regulated by DOT**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Pressurized	**CP Met Types**	
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	06/13/2006	**Primary Tank Leak Detection**	Not Listed	**Primary Pipe Leak Detection**	Approved Remote Monitoring;MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	1260000	**ATG Test Date**		**Line Tightness Test Date**	08/23/2006	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	S37PIPE	**Tank Age**	72	**Tank Installed Date**	01/01/1953	**Tank Material Construction**	Unknown	**Piping Material**	Steel - Terminal Piping	**Overfill Types**	
Tag Number	737	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Regulated by DOT**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Pressurized	**CP Met Types**	
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	06/13/2006	**Primary Tank Leak Detection**	Deferred	**Primary Pipe Leak Detection**	Approved Remote Monitoring;MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	1260000	**ATG Test Date**		**Line Tightness Test Date**	08/23/2006	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					

Facility Summary in Lewis and Clark County in the City of Helena

Location: QUEEN CITY EXXON LLC
1721 Cedar St
Helena, MT 59601-1109 Lewis and Clark

System Facility ID:25-07848

Facility Code: 23755
Last Inspected On: 04/26/2024
Operating Permit Renewal Date: 08/27/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Queen City Exxon LLC;Timothy Hornbacher		**dnvogle@mt.net**
Operator Contact:	Darcie Ogle;Queen City Exxon LLC;Vaughn Ogle	**(406) 439-4469**	**dnvogle@mt.net;queencityexxon@gmail.com;dnvogle@mt.net**

Owner/Operator: Queen City Exxon LLC dnvogle@mt.net

Owner/Operator: Timothy C Hornbacher dnvogle@mt.net

Darcie Ogle, UST Class A Operator dnvogle@mt.net
Darcie Ogle, UST Class B Operator dnvogle@mt.net
Vaughn Ogle, UST Class A Operator dnvogle@mt.net
Vaughn Ogle, UST Class B Operator dnvogle@mt.net

Tank Number	04	**Tank Age**	38	**Tank Installed Date**	12/29/1987	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Steel	**Overfill Types**	Flapper Valve
Tag Number	1396	**Spill Test Date**	08/02/2024	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**	04/26/2024	**Tank/Piping CP Test Date**	04/26/2024	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	04/26/2024	**Line Tightness Test Date**	09/01/2004	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	04/26/2024			**ATG Type**	Gilbarco/EMC Basic				
Tank Number	05	**Tank Age**	38	**Tank Installed Date**	12/29/1987	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Steel	**Overfill Types**	Flapper Valve
Tag Number	1397	**Spill Test Date**	08/02/2024	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Diesel	**PLLD Test Date**	04/26/2024	**Tank/Piping CP Test Date**	04/26/2024	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	04/26/2024	**Line Tightness Test Date**	09/01/2004	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	04/26/2024			**ATG Type**	Gilbarco/EMC Basic				

Tank Number	06	**Tank Age**	38	**Tank Installed Date**	12/29/1987	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Steel	**Overfill Types**	Flapper Valve
Tag Number	1398	**Spill Test Date**	08/02/2024	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**	04/26/2024	**Tank/Piping CP Test Date**	04/26/2024	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	04/26/2024	**Line Tightness Test Date**	09/01/2004	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	04/26/2024			**ATG Type**	Gilbarco/EMC Basic				
Tank Number	08	**Tank Age**	35	**Tank Installed Date**	11/01/1990	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	No Piping	**Overfill Types**	
Tag Number	1399	**Spill Test Date**		**Piping Installed Date**	04/24/2009	**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Temporarily Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Gravity Feed	**CP Met Types**	Galvanic
Product	Oil, Waste	**PLLD Test Date**		**Tank/Piping CP Test Date**	04/26/2024	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	1000	**ATG Test Date**	04/26/2024	**Line Tightness Test Date**	09/01/2004	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco/EMC Basic				

Facility Summary in Lewis and Clark County in the City of Helena

Location: SAFEWAY GASOLINE HELENA
611 N Montana Ave
Helena, MT 59601-3827 Lewis and Clark

System Facility ID:56-14000

Facility Code: 30661
Last Inspected On: 02/05/2024
Operating Permit Renewal Date: 01/29/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Albertsons - Safeway	**(208) 412-2233**	**page.rost@albertsons.com**
Operator Contact:	Danny Sager;Rachel Jones	**(208) 395-3269**	**rachel.jones@albertsons.com;s1486c60@safeway.com**

Owner/Operator: Albertsons - Safeway (208) 412-2233 page.rost@albertsons.com

Danny Sager, UST Class A Operator	s1486c60@safeway.com
Danny Sager, UST Class B Global Operator	s1486c60@safeway.com
Page Rost, UST Class B Global Operator	page.rost@albertsons.com
Rachel Jones , UST Class A Operator	rachel.jones@albertsons.com
Rachel Jones , UST Class B Global Operator	rachel.jones@albertsons.com

Tank Number	01	**Tank Age**	24	**Tank Installed Date**	06/01/2001	**Tank Material Construction**	Steel Clad	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	4330	**Spill Test Date**	06/10/2021	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**	06/27/2020	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	08/09/2022	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	Yes
Capacity	40000	**ATG Test Date**	01/18/2023	**Line Tightness Test Date**	11/21/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	01/18/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350				
Tank Number	02	**Tank Age**	24	**Tank Installed Date**	06/01/2001	**Tank Material Construction**	Steel Clad	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	4331	**Spill Test Date**	06/10/2021	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**	06/17/2020	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	08/09/2022	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	Yes

Capacity	20000	**ATG Test Date**	01/18/2023	**Line Tightness Test Date**	11/22/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	01/18/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350				
Tank Number	03	**Tank Age**	24	**Tank Installed Date**	06/01/2001	**Tank Material Construction**	Steel Clad	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	4332	**Spill Test Date**	06/10/2021	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**	06/27/2020	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	08/09/2022	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	20000	**ATG Test Date**	01/18/2023	**Line Tightness Test Date**	11/18/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	01/18/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350				
Tank Number	04	**Tank Age**	2	**Tank Installed Date**	09/21/2023	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	6210	**Spill Test Date**	10/31/2023	**Piping Installed Date**	09/21/2023	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	10/31/2023	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	Yes
Capacity	20000	**ATG Test Date**	10/31/2023	**Line Tightness Test Date**	10/31/2023	**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	10/31/2023			**ATG Type**					
Tank Number	05	**Tank Age**	2	**Tank Installed Date**	09/21/2023	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	6211	**Spill Test Date**	10/31/2023	**Piping Installed Date**	09/21/2023	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	10/31/2023	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	Yes
Capacity	6000	**ATG Test Date**	10/31/2023	**Line Tightness Test Date**	10/31/2023	**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	10/31/2023			**ATG Type**					
Tank Number	06	**Tank Age**	2	**Tank Installed Date**	09/21/2023	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve;High Level Alarm

Tag Number	6212	**Spill Test Date**	10/31/2023	**Piping Installed Date**	09/21/2023	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	10/31/2023	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	10/31/2023	**Line Tightness Test Date**	10/31/2023	**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	10/31/2023			**ATG Type**					
Tank Number	07	**Tank Age**	2	**Tank Installed Date**	09/21/2023	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	6213	**Spill Test Date**	10/31/2023	**Piping Installed Date**	09/21/2023	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	10/31/2023	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	Yes
Capacity	6000	**ATG Test Date**	10/31/2023	**Line Tightness Test Date**	10/31/2023	**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	10/31/2023			**ATG Type**					

Facility Summary in Lewis and Clark County in the City of Helena

Location: SAMS HIGH COUNTRY TRAVEL PLAZA
3122 E US Hwy 12
Helena, MT 59601 Lewis and Clark

System Facility ID:25-08659

Facility Code: 23790
Last Inspected On: 02/16/2023
Operating Permit Renewal Date: 03/15/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Helena Food and Gas LLC **(530) 713-2805** **helenafgllc@gmail.com**

Operator Contact: Sukhvinder Singh **helenafgllc@gmail.com**

Owner/Operator: Helena Food and Gas LLC (530) 713-2805 helenafgllc@gmail.com

Sukhvinder Singh, UST Class A Operator helenafgllc@gmail.com

Sukhvinder Singh, UST Class B Operator helenafgllc@gmail.com

Tank Number	07	**Tank Age**	35	**Tank Installed Date**	06/19/1990	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve;High Level Alarm
Tag Number	4526	**Spill Test Date**	02/16/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	02/16/2023	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	02/16/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	02/16/2023	**Line Tightness Test Date**	02/16/2023	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	03/13/2023			**ATG Type**	Gilbarco/EMC Basic				
Tank Number	06	**Tank Age**	35	**Tank Installed Date**	06/19/1990	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve;High Level Alarm
Tag Number	4527	**Spill Test Date**	02/16/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	03/07/2023	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Diesel, Dyed	**PLLD Test Date**		**Tank/Piping CP Test Date**	02/16/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	02/16/2023	**Line Tightness Test Date**	02/16/2023	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	03/13/2023			**ATG Type**	Gilbarco/EMC Basic				
Tank Number	12	**Tank Age**	29	**Tank Installed Date**	10/01/1996	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve;High Level Alarm

Tag Number	4528	**Spill Test Date**	02/16/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	02/16/2023	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	10/16/2016	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	02/16/2023	**Line Tightness Test Date**	02/16/2023	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	03/13/2023			**ATG Type**	Gilbarco/EMC Basic				
Tank Number	13	**Tank Age**	29	**Tank Installed Date**	10/01/1996	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve;High Level Alarm
Tag Number	4529	**Spill Test Date**	02/16/2023	**Piping Installed Date**	05/19/2023	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	05/19/2023	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	10/16/2016	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	02/16/2023	**Line Tightness Test Date**	05/19/2023	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	03/13/2023			**ATG Type**	Gilbarco/EMC Basic				
Tank Number	14	**Tank Age**	29	**Tank Installed Date**	10/01/1996	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve;High Level Alarm
Tag Number	4530	**Spill Test Date**	02/16/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	02/16/2023	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	10/16/2016	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	02/16/2023	**Line Tightness Test Date**	02/16/2023	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	03/13/2023			**ATG Type**	Gilbarco/EMC Basic				
Tank Number	15	**Tank Age**	29	**Tank Installed Date**	10/01/1996	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve;High Level Alarm
Tag Number	4531	**Spill Test Date**	02/16/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	02/16/2023	**Sump Tightness Test Date**	08/23/2021	**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	10/16/2016	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No

Capacity	15000	**ATG Test Date**	02/16/2023	**Line Tightness Test Date**	02/16/2023	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	03/13/2023			**ATG Type**	Gilbarco/EMC Basic				

Facility Summary in Lewis and Clark County in the City of Helena

Location: SHODAIR CHILDRENS HOSPITAL
2755 Colonial Drive
Helena, MT 59601 Lewis and Clark

System Facility ID:00-32497

Facility Code: 32497
Last Inspected On: 04/27/2023
Operating Permit Renewal Date: 06/27/2023

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: MONTANA CHILDRENS HOME & HOSPITAL

Operator Contact:

Owner/Operator: MONTANA CHILDRENS HOME & HOSPITAL

Tank Number	01	**Tank Age**	3	**Tank Installed Date**	06/22/2022	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	6091	**Spill Test Date**	09/12/2022	**Piping Installed Date**	06/22/2022	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	09/12/2022	**Catastrophic L.D. Type 3.0**	Auto Dialer	**Piping Type**	U.S. Suction	**CP Met Types**	
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	1000	**ATG Test Date**	08/25/2022	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**		**Energy Act**	Yes
		Overfill Test Date	09/12/2022			**ATG Type**					

Facility Summary in Lewis and Clark County in the City of Helena

Location: SLEEPING GIANT CONVENIENCE STORE
3425 E US Hwy 12
Helena, MT 59601-9708 Lewis and Clark

System Facility ID:25-13763

Facility Code: 23958
Last Inspected On: 08/12/2019
Operating Permit Renewal Date: 10/22/2019

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Sleeping Giant Holding LLC		**chad@offthewallmt.com**
Operator Contact:	Mike Clasby;Todd Bachmeier	**(406) 422-9034**	**clasbym@bresnan.net;toddy600@yahoo.com**

Mike Clasby, UST Class A Operator	clasbym@bresnan.net
Mike Clasby, UST Class B Operator	clasbym@bresnan.net
Todd Bachmeier, UST Class A Operator	toddy600@yahoo.com
Todd Bachmeier, UST Class B Global Operator	toddy600@yahoo.com

Tank Number	01	**Tank Age**	29	**Tank Installed Date**	10/01/1996	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve
Tag Number	365	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	16000	**ATG Test Date**		**Line Tightness Test Date**	07/30/2016	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco/EMC Basic				
Tank Number	02	**Tank Age**	29	**Tank Installed Date**	10/01/1996	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve
Tag Number	366	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**		**Line Tightness Test Date**	07/30/2016	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco/EMC Basic				

Tank Number	04	**Tank Age**	29	**Tank Installed Date**	10/01/1996	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve
Tag Number	368	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**		**Line Tightness Test Date**	07/30/2016	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco/EMC Basic				
Tank Number	03	**Tank Age**	29	**Tank Installed Date**	10/01/1996	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve
Tag Number	4333	**Spill Test Date**		**Piping Installed Date**	07/13/2010	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	16000	**ATG Test Date**		**Line Tightness Test Date**	07/30/2016	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco/EMC Basic				

Facility Summary in Lewis and Clark County in the City of Helena

Location: SOUTHS COUNTRY STORE
3105 York Rd
Helena, MT 59602-8816 Lewis and Clark

System Facility ID:25-07353

Facility Code: 23731
Last Inspected On: 05/19/2025
Operating Permit Renewal Date: 09/23/2025

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	C And C Stores	**(406) 461-5504**	**cecilalexander1@gmail.com**
Operator Contact:	Cecil Alexander;Souths Country Store;Lonnie Bennett	**(406) 443-4833;(406) 461-5504;(406) 227-5757**	**cecilalexander1@gmail.com;lonnieshawna@gmail.com**

Owner/Operator: C And C Stores (406) 461-5504 cecilalexander1@gmail.com

Cecil Alexander, UST Class A Operator cecilalexander1@gmail.com
Cecil Alexander, UST Class B Operator cecilalexander1@gmail.com
Lonnie Bennett, UST Class A Operator lonnieshawna@gmail.com
Lonnie Bennett, UST Class B Operator lonnieshawna@gmail.com

Tank Number	05	**Tank Age**	32	**Tank Installed Date**	05/01/1993	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	3562	**Spill Test Date**	04/25/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	04/25/2022	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	07/06/2022	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	04/25/2022	**Line Tightness Test Date**	04/25/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	04/25/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	06	**Tank Age**	32	**Tank Installed Date**	05/01/1993	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	3563	**Spill Test Date**	04/25/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	04/25/2022	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	07/06/2022	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	04/25/2022	**Line Tightness Test Date**	04/25/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	04/25/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Lewis and Clark County in the City of Helena

Location: SPRINT HELENA POP
1100 Phoenix Ave
Helena, MT 59601 Lewis and Clark

System Facility ID:56-14011

Facility Code: 30671
Last Inspected On: 04/19/2023
Operating Permit Renewal Date: 08/08/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Sprint Communications Co LLP **(913) 762-5957**

Operator Contact: Brian Schmitt;Brian Wiedower **(913) 315-8631** **brian.c.wiedower@sprint.com;brian.schmitt@bolininc.com**

Owner/Operator: Sprint Communications Co LLP (913) 762-5957

Brandon Hyde, UST Class B Operator	brandon.i.hyde@sprint.com
Brian Schmitt, UST Class A Operator	brian.schmitt@bolininc.com
Brian Schmitt, UST Class B Operator	brian.schmitt@bolininc.com
Brian Wiedower, UST Class A Operator	brian.c.wiedower@sprint.com
Matt Santee, UST Class B Global Operator	matt.santee@bolininc.com
Scott Hallesy, UST Class B Operator	scott.g.hallesy@sprint.com

Tank Number	01	**Tank Age**	24	**Tank Installed Date**	06/01/2001	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	4322	**Spill Test Date**	03/19/2024	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	08/01/2023	**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	U.S. Suction	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	3-Year Line Tightness Test	**Vapor Recovery**	No
Capacity	2500	**ATG Test Date**	04/19/2024	**Line Tightness Test Date**	04/19/2024	**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	04/24/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-300				

Facility Summary in Lewis and Clark County in the City of Helena

Location: THRIFTWAY SUPER STOP 9
1405 Euclid Ave
Helena, MT 59601-2052 Lewis and Clark

System Facility ID:25-07931

Facility Code: 23761
Last Inspected On: 01/23/2025
Operating Permit Renewal Date: 06/12/2028

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Sutey Oil Co Inc	**(406) 494-2305**	**ldsutey66@thriftwayss.com**
Operator Contact:	Jack Hook;Linda Otonicar;Louis Sutey	**(406) 491-5808;(406) 494-2305**	**ldsutey66@thriftwayss.com;otonicarlinda@aol.com**

Owner/Operator: Sutey Oil Co Inc (406) 494-2305 ldsutey66@thriftwayss.com

Brody Sheehan, UST Class B Global Operator	beversheehan@gmail.com
Bryan Kelsey, UST Class B Operator	bkelsey66@thriftwayss.com
Douglas Bond, UST Class B Operator	db1131958@gmail.com
Jack Hook, UST Class A Operator	
Jack Hook, UST Class B Global Operator	
Jack Hook, UST Class B Operator	
Kirsten Jakubec, UST Class B Global Operator	wegs1203@yahoo.com
Kirsten Jakubec, UST Class B Operator	wegs1203@yahoo.com
Linda Otonicar, UST Class A Operator	otonicarlinda@aol.com
Louis Sutey, UST Class A Operator	ldsutey66@thriftwayss.com
Louis Sutey, UST Class B Global Operator	ldsutey66@thriftwayss.com
Peggy Johnson, UST Class B Operator	thriftway9@thriftwayss.com
Ruth Coladonato, UST Class B Operator	ruth.pettite@ymail.com

Tank Number	06	**Tank Age**	29	**Tank Installed Date**	09/01/1996	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	2056	**Spill Test Date**	01/22/2025	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	01/22/2025	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	Yes
Capacity	15000	**ATG Test Date**	01/22/2025	**Line Tightness Test Date**	12/27/2021	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	01/22/2025			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Tank Number	07	**Tank Age**	29	**Tank Installed Date**	09/01/1996	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	2057	**Spill Test Date**	01/22/2025	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	01/22/2025	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	Yes
Capacity	15000	**ATG Test Date**	01/22/2025	**Line Tightness Test Date**	12/10/2021	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	01/22/2025			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	08	**Tank Age**	29	**Tank Installed Date**	09/01/1996	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	2058	**Spill Test Date**	01/22/2025	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	01/22/2025	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**	01/22/2025	**Line Tightness Test Date**	12/02/2021	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	01/22/2025			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Lewis and Clark County in the City of Helena

Location: TOWN PUMP HELENA 8
2910 N Montana Ave
Helena, MT 59601-0549 Lewis and Clark

System Facility ID:56-13846

Facility Code: 30528
Last Inspected On: 08/29/2024
Operating Permit Renewal Date: 11/16/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Helena 8 RE2 LLC	**(406) 497-6700**	**arnoldo@townpump.com**
Operator Contact:	Trent Biggers		**Trentb@townpump.com**

Owner/Operator: Helena 8 RE2 LLC (406) 497-6700 arnoldo@townpump.com

Trent Biggers, UST Class A Operator Trentb@townpump.com
Trent Biggers, UST Class A Operator Trentb@townpump.com
Trent Biggers, UST Class B Global Operator Trentb@townpump.com
Trent Biggers, UST Class B Global Operator Trentb@townpump.com

Tank Number	01	**Tank Age**	27	**Tank Installed Date**	06/16/1998	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve;Flapper Valve
Tag Number	2680	**Spill Test Date**	03/11/2024	**Piping Installed Date**	03/11/2024	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	03/11/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	05/25/2021	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	03/11/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	Yes
		Overfill Test Date	03/11/2024			**ATG Type**	Veeder Root/TLS-450PLUS				
Tank Number	02	**Tank Age**	27	**Tank Installed Date**	06/16/1998	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve
Tag Number	2681	**Spill Test Date**	03/11/2024	**Piping Installed Date**	03/11/2024	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	03/11/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	05/25/2021	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	03/11/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	Yes

		Overfill Test Date	03/11/2024			**ATG Type**	Veeder Root/TLS-450PLUS				
Tank Number	03	**Tank Age**	27	**Tank Installed Date**	06/16/1998	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve
Tag Number	2682	**Spill Test Date**	03/11/2024	**Piping Installed Date**	03/11/2024	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	03/11/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	05/25/2021	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	03/11/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	Yes
		Overfill Test Date	03/11/2024			**ATG Type**	Veeder Root/TLS-450PLUS				
Tank Number	04	**Tank Age**	27	**Tank Installed Date**	06/16/1998	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve;Flapper Valve
Tag Number	2683	**Spill Test Date**	03/11/2024	**Piping Installed Date**	03/11/2024	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	03/11/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	05/25/2021	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	03/11/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	Yes
		Overfill Test Date	03/11/2024			**ATG Type**	Veeder Root/TLS-450PLUS				
Tank Number	05	**Tank Age**	27	**Tank Installed Date**	07/24/1998	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve;Flapper Valve
Tag Number	2684	**Spill Test Date**	03/11/2024	**Piping Installed Date**	03/11/2024	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	03/11/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	05/25/2021	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**	03/11/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	Yes
		Overfill Test Date	03/11/2024			**ATG Type**	Veeder Root/TLS-450PLUS				
Tank Number	06	**Tank Age**	24	**Tank Installed Date**	09/07/2001	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve

Tag Number	4671	**Spill Test Date**	03/11/2024	**Piping Installed Date**	03/11/2024	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	03/11/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	05/25/2021	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	03/11/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	Yes
		Overfill Test Date	03/11/2024			**ATG Type**	Veeder Root/TLS-450PLUS				
Tank Number	07	**Tank Age**	1	**Tank Installed Date**	03/07/2024	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	6152	**Spill Test Date**	03/11/2024	**Piping Installed Date**	03/11/2024	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	03/11/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	Yes
Capacity	15000	**ATG Test Date**	03/11/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	Yes
		Overfill Test Date	03/11/2024			**ATG Type**					

Facility Summary in Lewis and Clark County in the City of Helena

Location: TOWN PUMP INC HELENA #3
3161 N Sanders
Helena, MT 59602 Lewis and Clark

System Facility ID:60-15210

Facility Code: 30930
Last Inspected On: 04/26/2023
Operating Permit Renewal Date: 11/15/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Helena 3 Town Pump LLC **(406) 497-6700** **environmental@townpump.com**

Operator Contact: Trent Biggers **Trentb@townpump.com**

Owner/Operator: Helena 3 Town Pump LLC (406) 497-6700 environmental@townpump.com

Trent Biggers, UST Class A Operator Trentb@townpump.com

Trent Biggers, UST Class B Global Operator Trentb@townpump.com

Tank Number	01	**Tank Age**	13	**Tank Installed Date**	05/01/2012	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	5367	**Spill Test Date**	08/30/2022	**Piping Installed Date**	02/04/2012	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	08/30/2022	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	04/06/2023	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**	04/06/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Statistical Inventory Reconciliation	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	Yes
		Overfill Test Date	08/30/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Number	02	**Tank Age**	13	**Tank Installed Date**	05/01/2012	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	5369	**Spill Test Date**	11/23/2022	**Piping Installed Date**	02/04/2012	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	08/30/2022	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	04/06/2023	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	Yes
Capacity	20000	**ATG Test Date**	04/06/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Statistical Inventory Reconciliation	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	Yes

		Overfill Test Date	08/30/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Number	03	**Tank Age**	13	**Tank Installed Date**	05/01/2012	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	5370	**Spill Test Date**	11/23/2022	**Piping Installed Date**	02/04/2012	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	08/30/2022	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	04/06/2023	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	Yes
Capacity	15000	**ATG Test Date**	04/06/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Statistical Inventory Reconciliation	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	Yes
		Overfill Test Date	08/30/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Number	04	**Tank Age**	13	**Tank Installed Date**	05/01/2012	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	5371	**Spill Test Date**	08/30/2022	**Piping Installed Date**	02/04/2012	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	08/30/2022	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	04/06/2023	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**	04/06/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Statistical Inventory Reconciliation	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	Yes
		Overfill Test Date	08/30/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Number	05	**Tank Age**	13	**Tank Installed Date**	05/01/2012	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	5372	**Spill Test Date**	08/30/2022	**Piping Installed Date**	02/04/2012	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	08/30/2022	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	04/06/2023	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	15000	**ATG Test Date**	04/06/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Statistical Inventory Reconciliation	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	Yes
		Overfill Test Date	08/30/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				

Facility Summary in Lewis and Clark County in the City of Helena

Location: TOWN PUMP INC HELENA 1
1240 Prospect Ave
Helena, MT 59601 Lewis and Clark

System Facility ID:25-08706

Facility Code: 23792
Last Inspected On: 03/14/2023
Operating Permit Renewal Date: 10/29/2024

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Helena 1 Town Pump LLC **(406) 497-6700** **environmental@townpump.com**

Operator Contact: Trent Biggers **Trentb@townpump.com**

Owner/Operator: Helena 1 Town Pump LLC (406) 497-6700 environmental@townpump.com

Trent Biggers, UST Class A Operator Trentb@townpump.com
Trent Biggers, UST Class A Operator Trentb@townpump.com
Trent Biggers, UST Class B Global Operator Trentb@townpump.com
Trent Biggers, UST Class B Global Operator Trentb@townpump.com

Tank Number	01	**Tank Age**	42	**Tank Installed Date**	04/15/1983	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	2506	**Spill Test Date**	04/06/2022	**Piping Installed Date**	05/24/2024	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	05/24/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**	07/13/2023	**Tank/Piping CP Test Date**	09/06/2022	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	07/13/2023	**Line Tightness Test Date**	05/24/2024	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	04/06/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Number	02	**Tank Age**	42	**Tank Installed Date**	04/15/1983	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	2507	**Spill Test Date**	04/06/2022	**Piping Installed Date**	05/24/2024	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	05/24/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**	07/13/2023	**Tank/Piping CP Test Date**	09/06/2022	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No

Capacity	12000	**ATG Test Date**	07/13/2023	**Line Tightness Test Date**	05/24/2024	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	04/06/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Number	03	**Tank Age**	42	**Tank Installed Date**	04/15/1983	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	2508	**Spill Test Date**	04/06/2022	**Piping Installed Date**	05/24/2024	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	05/24/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**	07/13/2023	**Tank/Piping CP Test Date**	09/06/2022	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	07/13/2023	**Line Tightness Test Date**	05/24/2024	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	04/06/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Number	07	**Tank Age**	27	**Tank Installed Date**	11/01/1998	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	2509	**Spill Test Date**	04/06/2022	**Piping Installed Date**	05/24/2024	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	05/24/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	07/13/2023	**Tank/Piping CP Test Date**	09/25/2014	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	07/13/2023	**Line Tightness Test Date**	05/24/2024	**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	10/31/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Number	08	**Tank Age**	27	**Tank Installed Date**	11/01/1998	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve
Tag Number	2510	**Spill Test Date**	04/06/2022	**Piping Installed Date**	05/24/2024	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	05/24/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	07/13/2023	**Tank/Piping CP Test Date**	09/25/2014	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	07/13/2023	**Line Tightness Test Date**	05/24/2024	**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No

		Overfill Test Date	10/31/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				

Facility Summary in Lewis and Clark County in the City of Helena

Location: TOWN PUMP INC HELENA 2
1140 Euclid Ave
Helena, MT 59601 Lewis and Clark

System Facility ID:25-08707

Facility Code: 23793
Last Inspected On: 03/01/2023
Operating Permit Renewal Date: 11/14/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Helena 2 Town Pump LLC **(406) 497-6700** **environmental@townpump.com**

Operator Contact: Trent Biggers **Trentb@townpump.com**

Owner/Operator: Helena 2 Town Pump LLC (406) 497-6700 environmental@townpump.com

Trent Biggers, UST Class A Operator Trentb@townpump.com
Trent Biggers, UST Class A Operator Trentb@townpump.com
Trent Biggers, UST Class B Global Operator Trentb@townpump.com
Trent Biggers, UST Class B Global Operator Trentb@townpump.com

Tank Number	03	**Tank Age**	41	**Tank Installed Date**	04/14/1984	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	4832	**Spill Test Date**	09/07/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Single Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**	05/25/2021	**Tank/Piping CP Test Date**	09/07/2022	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	Yes
Capacity	6000	**ATG Test Date**	03/01/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	10/31/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350				
Tank Number	04	**Tank Age**	34	**Tank Installed Date**	07/01/1991	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	4833	**Spill Test Date**	09/07/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Single Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	05/25/2021	**Tank/Piping CP Test Date**	11/29/2005	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	03/01/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	09/07/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350				

Tank Number	05	**Tank Age**	34	**Tank Installed Date**	07/01/1991	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	4834	**Spill Test Date**	09/07/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Single Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	05/25/2021	**Tank/Piping CP Test Date**	11/29/2005	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	03/01/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	09/07/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350				
Tank Number	06	**Tank Age**	34	**Tank Installed Date**	07/01/1991	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	4835	**Spill Test Date**	09/07/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Single Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	05/25/2021	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	03/01/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	09/07/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Lewis and Clark County in the City of Helena

Location: TOWN PUMP INC HELENA 5
1822 E Custer Ave
Helena, MT 59602-1206 Lewis and Clark

System Facility ID:60-15029

Facility Code: 30813
Last Inspected On: 04/26/2023
Operating Permit Renewal Date: 11/17/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Helena 5 Town Pump LLC **(406) 497-6700** **environmental@townpump.com**

Operator Contact: Trent Biggers **Trentb@townpump.com**

Owner/Operator: Helena 5 Town Pump LLC (406) 497-6700 environmental@townpump.com

Trent Biggers, UST Class A Operator Trentb@townpump.com

Trent Biggers, UST Class B Global Operator Trentb@townpump.com

Tank Number	01	**Tank Age**	19	**Tank Installed Date**	12/06/2006	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve;Flapper Valve
Tag Number	5064	**Spill Test Date**	08/20/2022	**Piping Installed Date**	12/06/2006	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	08/10/2021	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	07/24/2023	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	Yes
Capacity	20000	**ATG Test Date**	07/24/2023	**Line Tightness Test Date**	12/07/2006	**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	08/20/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Number	02	**Tank Age**	19	**Tank Installed Date**	12/06/2006	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve;Flapper Valve
Tag Number	5065	**Spill Test Date**	08/20/2022	**Piping Installed Date**	12/06/2006	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	08/10/2021	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	07/24/2023	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	Yes
Capacity	10000	**ATG Test Date**	07/24/2023	**Line Tightness Test Date**	12/07/2006	**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No

		Overfill Test Date	08/20/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Number	03	**Tank Age**	19	**Tank Installed Date**	12/06/2006	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve
Tag Number	5066	**Spill Test Date**	11/02/2022	**Piping Installed Date**	12/06/2006	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	08/10/2021	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	07/24/2023	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	07/24/2023	**Line Tightness Test Date**	12/11/2006	**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	08/30/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Number	04	**Tank Age**	19	**Tank Installed Date**	12/06/2006	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve
Tag Number	5067	**Spill Test Date**	08/20/2022	**Piping Installed Date**	12/06/2006	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	08/10/2021	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	07/24/2023	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	07/24/2023	**Line Tightness Test Date**	12/11/2006	**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	08/20/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Number	05	**Tank Age**	19	**Tank Installed Date**	12/06/2006	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve
Tag Number	5068	**Spill Test Date**	08/20/2022	**Piping Installed Date**	12/06/2006	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	08/10/2021	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	07/24/2023	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	07/24/2023	**Line Tightness Test Date**	12/15/2006	**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	08/20/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				

Tank Number	06	**Tank Age**	19	**Tank Installed Date**	12/06/2006	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve
Tag Number	5074	**Spill Test Date**	08/30/2022	**Piping Installed Date**	12/06/2006	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	08/10/2021	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	07/24/2023	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	07/24/2023	**Line Tightness Test Date**	12/15/2006	**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	08/30/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				

Facility Summary in Lewis and Clark County in the City of Helena

Location: TOWN PUMP INC HELENA 6
2401 N Montana Ave
Helena, MT 59601-0876 Lewis and Clark

System Facility ID:56-13818

Facility Code: 30505
Last Inspected On: 05/11/2023
Operating Permit Renewal Date: 11/18/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Helena 6 Town Pump LLC **(406) 497-6700** **environmental@townpump.com**

Operator Contact: Trent Biggers **Trentb@townpump.com**

Owner/Operator: Helena 6 Town Pump LLC (406) 497-6700 environmental@townpump.com

Trent Biggers, UST Class A Operator Trentb@townpump.com

Trent Biggers, UST Class B Global Operator Trentb@townpump.com

Tank Number	02	**Tank Age**	28	**Tank Installed Date**	10/01/1997	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	3443	**Spill Test Date**	09/06/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	06/26/2023	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	Yes
Capacity	15000	**ATG Test Date**	06/26/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	09/06/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Number	01	**Tank Age**	28	**Tank Installed Date**	09/01/1997	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	4610	**Spill Test Date**	09/06/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	06/26/2023	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	Yes
Capacity	12000	**ATG Test Date**	06/26/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No

		Overfill Test Date	09/06/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				

Facility Summary in Lewis and Clark County in the City of Helena

Location: UNITED PARCEL SERVICES HELENA
3029 Airport Rd
Helena, MT 59601 Lewis and Clark

System Facility ID:25-04538

Facility Code: 23584
Last Inspected On: 10/25/2024
Operating Permit Renewal Date: 06/01/2028

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	United Parcel Service Inc Seattle		**cdd6jxd@ups.com**
Operator Contact:	Jonathan Dunbar;United Parcel Service Inc Seattle;Russell Stott	**(503) 978-7678**	**jstott@ups.com;jxdunbar@ups.com;cdd6jxd@ups.com**

Owner/Operator: United Parcel Service Inc Seattle cdd6jxd@ups.com

Jonathan Dunbar, UST Class A Operator	cdd6jxd@ups.com
Jonathan Dunbar, UST Class B Operator	cdd6jxd@ups.com
Russell Stott, UST Class A Operator	jstott@ups.com
Russell Stott, UST Class A Operator	jstott@ups.com
Russell Stott, UST Class B Operator	jstott@ups.com
Russell Stott, UST Class B Operator	jstott@ups.com

Tank Number	05	**Tank Age**	32	**Tank Installed Date**	12/01/1993	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	4446	**Spill Test Date**	04/09/2025	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	04/09/2025	**Sump Tightness Test Date**	04/29/2022	**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	04/09/2025	**Line Tightness Test Date**	04/09/2025	**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	04/09/2025			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Lewis and Clark County in the City of Helena

Location: WATKINS and SHEPARD TRUCKING HELENA
1500 Blaine St
Helena, MT 59601 Lewis and Clark

System Facility ID:25-12917

Facility Code: 23915
Last Inspected On: 05/24/2017
Operating Permit Renewal Date: 07/18/2020

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Albatross Inc	**(406) 434-5259**	**grizfan16@gmail.com**
Operator Contact:	Brandon Dulaney;Caryssa Berg;Derek Townsend	**(406) 442-9536;(920) 592-3928**	**bergc1@schneider.com;brandond@wksh.com;townsendd@schneider.com**

Brandon Dulaney, UST Class A Operator	brandond@wksh.com
Brandon Dulaney, UST Class B Operator	brandond@wksh.com
Caryssa Berg, UST Class A Operator	bergc1@schneider.com
Derek Townsend, UST Class A Operator	townsendd@schneider.com
Derek Townsend, UST Class B Global Operator	townsendd@schneider.com

Tank Number	01	**Tank Age**	32	**Tank Installed Date**	02/03/1993	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Steel	**Overfill Types**	
Tag Number	4458	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**	05/25/2017	**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Gravity Feed	**CP Met Types**	Galvanic
Product	Oil, Waste	**PLLD Test Date**		**Tank/Piping CP Test Date**	06/09/2017	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2;Manual Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Manual Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date				**ATG Type**	Veeder Root/TLS-300				
Tank Number	02	**Tank Age**	32	**Tank Installed Date**	02/03/1993	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Steel	**Overfill Types**	
Tag Number	4459	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**	05/25/2017	**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Gravity Feed	**CP Met Types**	Galvanic

Product	Oil, Waste	**PLLD Test Date**		**Tank/Piping CP Test Date**	06/09/2017	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2;Manual Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	1000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Manual Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date				**ATG Type**	Veeder Root/TLS-300				
Tank Number	03	**Tank Age**	30	**Tank Installed Date**	11/01/1995	**Tank Material Construction**	Steel Clad	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	4460	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**	05/25/2017	**Catastrophic L.D. Type 3.0**	Continuous Interstitial Monitoring	**Piping Type**	Pressurized	**CP Met Types**	
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	06/09/2017	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	24000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**	Veeder Root/TLS-300				

Facility Summary in Lewis and Clark County in the City of Helena

Location: ZIP TRIP 42
3100 N Montana Ave
Helena, MT 59602-7812 Lewis and Clark

System Facility ID:25-12353

Facility Code: 23889
Last Inspected On: 12/06/2023
Operating Permit Renewal Date: 03/02/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	CHS Inc Spokane Valley	**(509) 535-7701**	**Donald.Widdicombe@chsinc.com**
Operator Contact:	Jim Alford;Sean Hurley	**(509) 535-7701;(509) 536-7418**	**jim.alford@chsinc.com;sean.hurley@chsinc.com**

Jim Alford, UST Class A Operator	jim.alford@chsinc.com
Jim Alford, UST Class B Operator	jim.alford@chsinc.com
Luci Tuttle, UST Class B Operator	Lucinda.Tuttle@chsinc.com
Sean Hurley, UST Class A Operator	sean.hurley@chsinc.com
Travis Weber, UST Class B Operator	travis.weber3@chsinc.com

Tank Number	01	**Tank Age**	34	**Tank Installed Date**	06/07/1991	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	559	**Spill Test Date**	02/15/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**	07/26/2023	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	07/28/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	20000	**ATG Test Date**	07/26/2023	**Line Tightness Test Date**	07/26/2023	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	02/15/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	02	**Tank Age**	34	**Tank Installed Date**	06/07/1991	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	560	**Spill Test Date**	02/15/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**	07/26/2023	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	07/26/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	20000	**ATG Test Date**	07/26/2023	**Line Tightness Test Date**	07/26/2023	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No

		Overfill Test Date	02/15/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	03	**Tank Age**	34	**Tank Installed Date**	06/07/1991	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	561	**Spill Test Date**	02/15/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**	07/26/2023	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	07/26/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	20000	**ATG Test Date**	07/26/2023	**Line Tightness Test Date**	07/26/2023	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	02/15/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Lewis and Clark County in the City of Helena

Location: ZIP TRIP 43
1318 Euclid Ave
Helena, MT 59601-2169 Lewis and Clark

System Facility ID:25-05774

Facility Code: 23652
Last Inspected On: 12/06/2023
Operating Permit Renewal Date: 03/13/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	CHS Inc Spokane Valley	**(509) 535-7701**	**Donald.Widdicombe@chsinc.com**
Operator Contact:	Jim Alford;Sean Hurley	**(509) 535-7701;(509) 536-7418**	**jim.alford@chsinc.com;sean.hurley@chsinc.com**

Owner/Operator: CHS Inc Spokane Valley (509) 535-7701 Donald.Widdicombe@chsinc.com

Jim Alford, UST Class A Operator	jim.alford@chsinc.com
Jim Alford, UST Class A Operator	jim.alford@chsinc.com
Jim Alford, UST Class B Operator	jim.alford@chsinc.com
Jim Alford, UST Class B Operator	jim.alford@chsinc.com
Luci Tuttle, UST Class B Operator	Lucinda.Tuttle@chsinc.com
Sean Hurley, UST Class A Operator	sean.hurley@chsinc.com
Sean Hurley, UST Class A Operator	sean.hurley@chsinc.com
Travis Weber, UST Class B Operator	travis.weber3@chsinc.com

Tank Number	03	**Tank Age**	41	**Tank Installed Date**	04/26/1984	**Tank Material Construction**	Bare Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	4518	**Spill Test Date**	02/15/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	07/27/2023	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	08/24/2022	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**	07/27/2023	**Line Tightness Test Date**	07/27/2023	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	02/15/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	01	**Tank Age**	42	**Tank Installed Date**	04/26/1983	**Tank Material Construction**	Bare Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	4519	**Spill Test Date**	02/15/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	07/27/2023	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	08/24/2022	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No

Capacity	10000	**ATG Test Date**	07/27/2023	**Line Tightness Test Date**	07/27/2023	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	02/15/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	04	**Tank Age**	28	**Tank Installed Date**	04/23/1997	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	4520	**Spill Test Date**	08/28/2024	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	07/27/2023	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	08/24/2022	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	07/27/2023	**Line Tightness Test Date**	07/27/2023	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	08/28/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Lewis and Clark County in the City of Lincoln

Location: MOUNTAIN VIEW COOP LINCOLN
525 Main St
Lincoln, MT 59639 Lewis and Clark

System Facility ID:25-03995

Facility Code: 23557
Last Inspected On: 08/24/2023
Operating Permit Renewal Date: 10/16/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Mountain View Coop Black Eagle **(406) 453-5900** **ddouglas@mountainviewcoop.com**

Operator Contact: David Douglas **ddouglas@mountainviewcoop.com**

Owner/Operator: Mountain View Coop Black Eagle (406) 453-5900 ddouglas@mountainviewcoop.com

David Douglas, UST Class A Operator ddouglas@mountainviewcoop.com
David Douglas, UST Class B Global Operator ddouglas@mountainviewcoop.com
Ranae Brown, UST Class B Global Operator rbrown@mountainviewcoop.com
Ranae Brown, UST Class B Operator rbrown@mountainviewcoop.com

Tank Number	04	**Tank Age**	29	**Tank Installed Date**	07/01/1996	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	2252	**Spill Test Date**	05/16/2020	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	05/06/2021	**Sump Tightness Test Date**	09/08/2020	**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	09/02/2020	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**		**Line Tightness Test Date**	05/06/2021	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	05	**Tank Age**	29	**Tank Installed Date**	07/01/1996	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	2253	**Spill Test Date**	05/16/2020	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	05/06/2021	**Sump Tightness Test Date**	09/08/2020	**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	09/02/2020	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**		**Line Tightness Test Date**	05/06/2021	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No

		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	06	**Tank Age**	29	**Tank Installed Date**	07/01/1996	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	2254	**Spill Test Date**	05/16/2020	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	05/06/2021	**Sump Tightness Test Date**	09/08/2020	**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	09/02/2020	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**		**Line Tightness Test Date**	05/06/2021	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	07	**Tank Age**	29	**Tank Installed Date**	07/01/1996	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	2255	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	05/06/2021	**Sump Tightness Test Date**	09/08/2020	**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	09/02/2020	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**		**Line Tightness Test Date**	05/06/2021	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	05/16/2020			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Lewis and Clark County in the City of Wolf Creek

Location: CANYON STORE EXXON
175 Recreation Rd
Wolf Creek, MT 59648 Lewis and Clark

System Facility ID:25-04132

Facility Code: 23568
Last Inspected On: 11/09/2023
Operating Permit Renewal Date: 03/27/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Otheim Family LLC;Paul and Cheryl D Beister **(406) 235-4111**

Operator Contact: Shawn Otheim **(775) 527-4507** **otheims@yahoo.com**

Owner/Operator: Otheim Family LLC (406) 235-4111

Owner/Operator: Paul D and Cheryl D Beister (406) 235-4111

Shawn Otheim, UST Class A Operator otheims@yahoo.com
Shawn Otheim, UST Class A Operator otheims@yahoo.com
Shawn Otheim, UST Class B Operator otheims@yahoo.com
Shawn Otheim, UST Class B Operator otheims@yahoo.com

Tank Number	03	**Tank Age**	27	**Tank Installed Date**	11/30/1998	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	3483	**Spill Test Date**	11/09/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Auto Dialer;Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	3000	**ATG Test Date**	11/09/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	11/09/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	04	**Tank Age**	27	**Tank Installed Date**	11/30/1998	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	3484	**Spill Test Date**	11/09/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Auto Dialer;Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible

Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	7000	**ATG Test Date**	11/09/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	11/09/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	05	**Tank Age**	27	**Tank Installed Date**	11/30/1998	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	3946	**Spill Test Date**	11/09/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Auto Dialer;Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	11/09/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	11/09/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Lewis and Clark County in the City of Wolf Creek

Location: THE BOAT LOFT
1460 Beartooth Rd
Wolf Creek, MT 59648-8743 Lewis and Clark

System Facility ID:25-05921

Facility Code: 23657
Last Inspected On: 06/06/2024
Operating Permit Renewal Date: 06/06/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Sykes Marine Holdings II LLC	**(406) 868-1621**	**braylen.sykes@sykesind.com**
Operator Contact:	Darrell Greenwood	**(406) 727-0629**	**darrell.greenwood@launchwatersports.com**

Owner/Operator: Sykes Marine Holdings II LLC (406) 868-1621 braylen.sykes@sykesind.com

Darrell Greenwood, UST Class A Operator darrell.greenwood@launchwatersports.com
Darrell Greenwood, UST Class B Operator darrell.greenwood@launchwatersports.com
Marshall Trainor, UST Class B Global Operator boatloft@bresnan.net

Tank Number	02	**Tank Age**	32	**Tank Installed Date**	04/01/1993	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve
Tag Number	473	**Spill Test Date**	11/06/2024	**Piping Installed Date**	11/13/2002	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	11/06/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	06/06/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	11/06/2024			**ATG Type**	Gilbarco-Veeder Root/EMC Basic				

Facility Summary in Liberty County in the City of Chester

Location: AG AIR INC
Liberty County Airport
Chester, MT 59522-0670 Liberty

System Facility ID:26-02182

Facility Code: 23979
Last Inspected On: 05/17/2022
Operating Permit Renewal Date: 09/24/2025

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Ag Air Inc **(406) 355-4257**

Operator Contact:

Owner/Operator: Ag Air Inc (406) 355-4257

James Briden, UST Class B Operator jdbriden@itstriangle.com
James Briden, UST Class B Operator jdbriden@itstriangle.com
James Briden, UST Class B Operator jdbriden@itstriangle.com

Tank Number	05	**Tank Age**	31	**Tank Installed Date**	05/01/1994	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	358	**Spill Test Date**	07/30/2021	**Piping Installed Date**	07/30/2021	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	07/30/2021	**Catastrophic L.D. Type 3.0**	Continuous Interstitial Monitoring;Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Aviation Gas	**PLLD Test Date**	05/17/2022	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	05/17/2022	**Line Tightness Test Date**	10/03/2019	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date	08/30/2021			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Liberty County in the City of Chester

Location: CHESTER SUPERMARKET
1278 US Hwy 2
Chester, MT 59522 Liberty

System Facility ID:26-13532

Facility Code: 24091
Last Inspected On: 03/08/2024
Operating Permit Renewal Date: 03/13/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	MPR Inc		**chestersupermarket@gmail.com**
Operator Contact:	Harinder Singh;Manjit Maan	**(209) 647-8034;(406) 868-2062**	**inder4030@yahoo.com;mcpshelby@gmail.com**

Owner/Operator: MPR Inc chestersupermarket@gmail.com

Charnjit Maan, UST Class B Operator
Harinder Singh, UST Class A Operator inder4030@yahoo.com
Manjit Maan, UST Class A Operator mcpshelby@gmail.com
Pardeep Kumar, UST Class B Operator pardeep.k51@yahoo.com

Tank Number	01	**Tank Age**	30	**Tank Installed Date**	09/01/1995	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	3223	**Spill Test Date**	03/08/2024	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	03/08/2024	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	03/08/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	03/08/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Number	02	**Tank Age**	30	**Tank Installed Date**	09/01/1995	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	3224	**Spill Test Date**	03/08/2024	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	03/08/2024	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	5000	**ATG Test Date**	03/08/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No

		Overfill Test Date	03/08/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Number	03	**Tank Age**	30	**Tank Installed Date**	09/01/1995	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	3225	**Spill Test Date**	03/08/2024	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	03/08/2024	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	7000	**ATG Test Date**	03/08/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	03/08/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				

Facility Summary in Liberty County in the City of Chester

Location: FRASER OIL INC CHESTER
119 Washington Ave
Chester, MT 59522 Liberty

System Facility ID:26-13006

Facility Code: 24087
Last Inspected On: 11/16/2023
Operating Permit Renewal Date: 03/17/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Fraser Oil Inc

Operator Contact: Cory Fraser **frasfuel@yahoo.com**

Owner/Operator: Fraser Oil Inc

Cory Fraser, UST Class A Operator	frasfuel@yahoo.com
Cory Fraser, UST Class A Operator	frasfuel@yahoo.com
Cory Fraser, UST Class B Operator	frasfuel@yahoo.com
Cory Fraser, UST Class B Operator	frasfuel@yahoo.com
Craig Fraser, UST Class B Operator	fraser_46@hotmail.com
Craig Fraser, UST Class B Operator	fraser_46@hotmail.com
Jesse Kuegler, UST Class B Operator	kealohakuegler@gmail.com
Jesse Kuegler, UST Class B Operator	kealohakuegler@gmail.com

Tank Number	04	**Tank Age**	31	**Tank Installed Date**	10/01/1994	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	1123	**Spill Test Date**	11/16/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	11/16/2023	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	11/14/2022	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	2000	**ATG Test Date**	11/16/2023	**Line Tightness Test Date**	11/16/2023	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	11/16/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	05	**Tank Age**	31	**Tank Installed Date**	10/01/1994	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	1124	**Spill Test Date**	11/16/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	11/16/2023	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	11/14/2022	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No

Capacity	1000	**ATG Test Date**	11/16/2023	**Line Tightness Test Date**	11/16/2023	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	11/16/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	06	**Tank Age**	31	**Tank Installed Date**	10/01/1994	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	1125	**Spill Test Date**	11/16/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	11/16/2023	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	11/14/2022	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	1000	**ATG Test Date**	11/16/2023	**Line Tightness Test Date**	11/16/2023	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	11/16/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Liberty County in the City of Chester

Location: ROOSEVELT SERVICE INC
219 Washington Ave
Chester, MT 59522 Liberty

System Facility ID:26-06061

Facility Code: 24034
Last Inspected On: 06/17/2022
Operating Permit Renewal Date: 09/29/2025

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Roosevelt Service Inc

Operator Contact: Dan Davis;Teresa Barrett;Roosevelt Service Inc **admin@rooseveltservice.com;dan@rooseveltservice.com**

Owner/Operator: Roosevelt Service Inc

Dan Davis, UST Class A Operator	dan@rooseveltservice.com
Dan Davis, UST Class B Global Operator	dan@rooseveltservice.com
Teresa Barrett, UST Class A Operator	admin@rooseveltservice.com

Tank Number	06	**Tank Age**	34	**Tank Installed Date**	06/01/1991	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	1752	**Spill Test Date**	06/17/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	07/20/2022	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	06/17/2022	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	12/14/2023	**Line Tightness Test Date**	07/20/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	06/17/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-300				
Tank Number	07	**Tank Age**	34	**Tank Installed Date**	06/01/1991	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	1753	**Spill Test Date**	06/17/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	07/20/2022	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	06/17/2022	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	12/14/2023	**Line Tightness Test Date**	07/20/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	06/17/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-300				

Facility Summary in Liberty County in the City of Chester

Location: TIBER MARINA
669 Tiber Marina Rd
Chester, MT 59522 Liberty

System Facility ID:26-03877

Facility Code: 24011
Last Inspected On: 05/14/2025
Operating Permit Renewal Date: 09/29/2025

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Bureau of Reclamation Billings **(406) 247-7310**

Operator Contact: Eric Kleinsasser;Kenneth Scheffler **EKleinsasser@usbr.gov;kscheffler@usbr.gov**

Owner/Operator: Bureau of Reclamation Billings (406) 247-7310

Eric Kleinsasser, UST Class A Operator	EKleinsasser@usbr.gov
Eric Kleinsasser, UST Class B Global Operator	EKleinsasser@usbr.gov
Eric Kleinsasser, UST Class B Operator	EKleinsasser@usbr.gov
Kenneth Scheffler, UST Class A Operator	kscheffler@usbr.gov
Kenneth Scheffler, UST Class B Operator	kscheffler@usbr.gov

Tank Number	04	**Tank Age**	39	**Tank Installed Date**	05/01/1986	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	3997	**Spill Test Date**	06/02/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	06/02/2022	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	1000	**ATG Test Date**	06/02/2022	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	06/02/2022			**ATG Type**	EMCO Electronics/EECO 1500				

Facility Summary in Lincoln County in the City of Eureka

Location: BIG SKY TIRE and AUTO
495 US Hwy 93 N
Eureka, MT 59917 Lincoln

System Facility ID:27-02343

Facility Code: 24114
Last Inspected On: 03/17/2021
Operating Permit Renewal Date: 03/21/2024

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	EJ Properties LLC;Ernie Roo	**(406) 297-2623**	**dale@bigskytire.com**
Operator Contact:	Joey Burgess	**(406) 297-2623**	**joey@bigskytire.com**

Joey Burgess, UST Class A Operator	joey@bigskytire.com
Joey Burgess, UST Class A Operator	joey@bigskytire.com
Joey Burgess, UST Class B Operator	joey@bigskytire.com
Joey Burgess, UST Class B Operator	joey@bigskytire.com

Tank Number	05	**Tank Age**	45	**Tank Installed Date**	05/06/1980	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	1851	**Spill Test Date**	07/31/2023	**Piping Installed Date**		**Tank Construction**	Lined Interior/Impressed Current	**Piping Construction**	Single Walled	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	07/19/2018	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	24000	**ATG Test Date**		**Line Tightness Test Date**	10/04/2020	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	07/31/2023			**ATG Type**	Gilbarco/EMC Basic				
Tank Number	06	**Tank Age**	45	**Tank Installed Date**	05/06/1980	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	1852	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**	Lined Interior/Impressed Current	**Piping Construction**	None	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	07/19/2018	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	24000	**ATG Test Date**		**Line Tightness Test Date**	03/01/2021	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco/EMC Basic				

Tank Number	07	**Tank Age**	45	**Tank Installed Date**	05/06/1980	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	1853	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**	Lined Interior/Impressed Current	**Piping Construction**	None	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	03/17/2021	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	24000	**ATG Test Date**		**Line Tightness Test Date**	09/26/2020	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco/EMC Basic				
Tank Number	08	**Tank Age**	43	**Tank Installed Date**	05/06/1982	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	1854	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**	Lined Interior/Impressed Current	**Piping Construction**	None	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**	01/03/2023	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	03/17/2021	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**		**Line Tightness Test Date**	01/03/2023	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco/EMC Basic				
Tank Number	09	**Tank Age**	36	**Tank Installed Date**	05/06/1989	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve
Tag Number	1855	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**	01/03/2023	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	03/17/2021	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	30000	**ATG Test Date**		**Line Tightness Test Date**	01/03/2023	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco/EMC Basic				
Tank Number	10	**Tank Age**	32	**Tank Installed Date**	10/01/1993	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve
Tag Number	1856	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**	01/03/2023	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic;Impressed Current
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	03/17/2021	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No

Capacity	24000	**ATG Test Date**		**Line Tightness Test Date**	01/03/2023	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco/EMC Basic				

Facility Summary in Lincoln County in the City of Eureka

Location: EUREKA MIDDLE SCHOOL
335 6th St E
Eureka, MT 59917 Lincoln

System Facility ID:27-04550

Facility Code: 24154
Last Inspected On: 01/20/2023
Operating Permit Renewal Date: 01/20/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Eureka Public Schools LCHS **(406) 265-2525**

Operator Contact:

Tank Number	S5	**Tank Age**	28	**Tank Installed Date**	08/01/1997	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Copper	**Overfill Types**	Flapper Valve
Tag Number	1540	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Secondary Containment Chase	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**	03/24/2020	**Catastrophic L.D. Type 3.0**	Auto Dialer	**Piping Type**	U.S. Suction	**CP Met Types**	Non-corrodible
Product	Heating Oil	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	24000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**	Incon/TS-1000				
Tank Number	S6	**Tank Age**	28	**Tank Installed Date**	08/01/1997	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Copper	**Overfill Types**	Flapper Valve
Tag Number	1541	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Secondary Containment Chase	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	U.S. Suction	**CP Met Types**	
Product	Heating Oil	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Not Listed	**Vapor Recovery**	No
Capacity	16000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**	Incon/TS-1000				

Facility Summary in Lincoln County in the City of Eureka

Location: KSANKA STORE
1835 Hwy 93 N
Eureka, MT 59917 Lincoln

System Facility ID:27-05303

Facility Code: 24175
Last Inspected On: 06/06/2023
Operating Permit Renewal Date: 09/25/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	AR93, LLC;HARJ93, LLC	**(206) 834-5349;(914) 433-7643**	**sheragroupllc@gmail.com;shergroupllc@gmail.com**
Operator Contact:	Rahul Kumar		**tharejallc@gmail.com**

Owner/Operator:	AR93, LLC	(914) 433-7643	shergroupllc@gmail.com
Owner/Operator:	HARJ93, LLC	(914) 433-7643	shergroupllc@gmail.com
	Rahul Kumar, UST Class A Operator		tharejallc@gmail.com
	Rahul Kumar, UST Class B Operator		tharejallc@gmail.com

Tank Number	04	**Tank Age**	35	**Tank Installed Date**	04/20/1990	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve
Tag Number	3308	**Spill Test Date**	01/23/2025	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Single Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	06/06/2023	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	06/06/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	11/02/2023	**Line Tightness Test Date**	06/06/2023	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	11/02/2023			**ATG Type**	Veeder Root/TLS-250				
Tank Number	05	**Tank Age**	35	**Tank Installed Date**	04/20/1990	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve
Tag Number	3309	**Spill Test Date**	06/06/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	06/06/2023	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	06/06/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**	11/02/2023	**Line Tightness Test Date**	06/06/2023	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	11/02/2023			**ATG Type**	Veeder Root/TLS-250				

Facility Summary in Lincoln County in the City of Eureka

Location: RANCH HAND INC
1000 US Hwy 93 N
Eureka, MT 59917-9555 Lincoln

System Facility ID:27-12713

Facility Code: 24484
Last Inspected On: 10/07/2024
Operating Permit Renewal Date: 03/19/2028

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: AJR LLC **(509) 953-9787** **sheragroupllc@gmail.com**

Operator Contact: Rahul Kumar **tharejallc@gmail.com**

Owner/Operator: AJR LLC (509) 953-9787 sheragroupllc@gmail.com

Rahul Kumar, UST Class A Operator tharejallc@gmail.com

Rahul Kumar, UST Class B Operator tharejallc@gmail.com

Tank Number	08	**Tank Age**	27	**Tank Installed Date**	05/01/1998	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve
Tag Number	2960	**Spill Test Date**	10/07/2024	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	10/07/2024	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	20000	**ATG Test Date**	10/07/2024	**Line Tightness Test Date**	10/07/2024	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	10/07/2024			**ATG Type**	Gilbarco/EMC Basic				
Tank Number	09	**Tank Age**	27	**Tank Installed Date**	05/01/1998	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve
Tag Number	2961	**Spill Test Date**	03/05/2025	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	10/07/2024	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	15000	**ATG Test Date**	10/07/2024	**Line Tightness Test Date**	10/07/2024	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	10/07/2024			**ATG Type**	Gilbarco/EMC Basic				
Tank Number	10	**Tank Age**	27	**Tank Installed Date**	05/01/1998	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve
Tag Number	2962	**Spill Test Date**	10/07/2024	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No

Status	**Currently in Use**	**MLLD Test Date**	10/07/2024	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	15000	**ATG Test Date**	10/07/2024	**Line Tightness Test Date**	10/07/2024	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	10/07/2024			**ATG Type**	Gilbarco/EMC Basic				
Tank Number	11	**Tank Age**	27	**Tank Installed Date**	05/01/1998	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve
Tag Number	2963	**Spill Test Date**	05/26/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Temporarily Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	02/04/2022	**Line Tightness Test Date**	10/04/2018	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	02/03/2022			**ATG Type**	Gilbarco/EMC Basic				
Tank Number	12	**Tank Age**	27	**Tank Installed Date**	05/01/1998	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve
Tag Number	2964	**Spill Test Date**	10/07/2024	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	10/07/2024	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	10/07/2024	**Line Tightness Test Date**	10/07/2024	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	10/07/2024			**ATG Type**	Gilbarco/EMC Basic				
Tank Number	13	**Tank Age**	27	**Tank Installed Date**	05/01/1998	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve
Tag Number	2965	**Spill Test Date**	03/28/2025	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	10/07/2024	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	2000	**ATG Test Date**	10/07/2024	**Line Tightness Test Date**	10/07/2024	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	10/07/2024			**ATG Type**	Gilbarco/EMC Basic				

Facility Summary in Lincoln County in the City of Eureka

Location: TOWN PUMP INC EUREKA
10 Dewey Ave
Eureka, MT 59917 Lincoln

System Facility ID:27-08699

Facility Code: 24240
Last Inspected On: 05/18/2023
Operating Permit Renewal Date: 08/30/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Eureka 1 Town Pump LLC	**(406) 497-6700**	**environmental@townpump.com**
Operator Contact:	Trent Biggers		**Trentb@townpump.com**

Owner/Operator:	Eureka 1 Town Pump LLC	(406) 497-6700	environmental@townpump.com
	Trent Biggers, UST Class A Operator		Trentb@townpump.com
	Trent Biggers, UST Class A Operator		Trentb@townpump.com
	Trent Biggers, UST Class B Global Operator		Trentb@townpump.com
	Trent Biggers, UST Class B Global Operator		Trentb@townpump.com

Tank Number	04	**Tank Age**	34	**Tank Installed Date**	11/01/1991	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	2517	**Spill Test Date**	04/13/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Single Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	06/07/2023	**Tank/Piping CP Test Date**	03/25/2010	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	05/25/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	04/13/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Number	05	**Tank Age**	34	**Tank Installed Date**	11/01/1991	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	2518	**Spill Test Date**	04/13/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	06/07/2023	**Tank/Piping CP Test Date**	03/25/2010	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	05/25/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No

		Overfill Test Date	04/13/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Number	06	**Tank Age**	34	**Tank Installed Date**	11/01/1991	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	2519	**Spill Test Date**	04/13/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	06/07/2023	**Tank/Piping CP Test Date**	03/25/2010	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	05/25/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	04/13/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Number	07	**Tank Age**	34	**Tank Installed Date**	11/01/1991	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	2520	**Spill Test Date**	04/13/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	06/07/2023	**Tank/Piping CP Test Date**	03/25/2010	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	05/25/2023	**Line Tightness Test Date**	08/27/2024	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	04/13/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Number	08	**Tank Age**	34	**Tank Installed Date**	11/01/1991	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	2521	**Spill Test Date**	04/13/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	06/07/2023	**Tank/Piping CP Test Date**	03/25/2010	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	05/25/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	04/13/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Number	09	**Tank Age**	25	**Tank Installed Date**	11/01/2000	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve

Tag Number	4251	**Spill Test Date**	06/25/2021	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	06/25/2021	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	06/07/2023	**Tank/Piping CP Test Date**	03/25/2010	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	05/25/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	06/25/2021			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Number	10	**Tank Age**	25	**Tank Installed Date**	11/01/2000	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve
Tag Number	4252	**Spill Test Date**	06/25/2021	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	06/25/2021	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	06/07/2023	**Tank/Piping CP Test Date**	03/25/2010	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	5000	**ATG Test Date**	05/25/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	06/25/2021			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Number	11	**Tank Age**	11	**Tank Installed Date**	03/14/2014	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	5467	**Spill Test Date**	06/25/2021	**Piping Installed Date**	02/24/2014	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	06/25/2021	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	06/07/2023	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	Yes
Capacity	8000	**ATG Test Date**	05/25/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Statistical Inventory Reconciliation	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	Yes
		Overfill Test Date	06/25/2021			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Number	12	**Tank Age**	11	**Tank Installed Date**	03/14/2014	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	5468	**Spill Test Date**	06/25/2021	**Piping Installed Date**	02/24/2014	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No

Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	06/25/2021	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	06/07/2023	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	Yes
Capacity	20000	**ATG Test Date**	05/25/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Statistical Inventory Reconciliation	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	Yes
		Overfill Test Date	06/25/2021			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Number	13	**Tank Age**	11	**Tank Installed Date**	03/14/2014	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	5469	**Spill Test Date**	06/25/2021	**Piping Installed Date**	02/24/2014	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	06/25/2021	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	06/07/2023	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	05/25/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Statistical Inventory Reconciliation	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	Yes
		Overfill Test Date	06/25/2021			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				

Facility Summary in Lincoln County in the City of Fortine

Location: CRYSTAL LAKES RESORT INC
Crystal Lakes Rd
Fortine, MT 59918 Lincoln

System Facility ID:27-03824

Facility Code: 24145
Last Inspected On: 01/21/2025
Operating Permit Renewal Date: 04/02/2028

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	James Smith	**(406) 882-4432**	**clsupermt@gmail.com**
Operator Contact:	James Smith	**(406) 882-4432**	**clsupermt@gmail.com**

Owner/Operator: James E Smith (406) 882-4432 clsupermt@gmail.com

James E Smith, UST Class A Operator clsupermt@gmail.com

James E Smith, UST Class B Operator clsupermt@gmail.com

Tank Number	01	**Tank Age**	39	**Tank Installed Date**	06/01/1986	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Steel	**Overfill Types**	Flapper Valve
Tag Number	3892	**Spill Test Date**	01/21/2025	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Single Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	10/15/2024	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Jet Fuel (Jet-A, Jet-A1, JP5)	**PLLD Test Date**		**Tank/Piping CP Test Date**	01/21/2025	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.1	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	10/15/2024	**Line Tightness Test Date**	10/15/2024	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	01/21/2025			**ATG Type**	Incon/TS-1000				
Tank Number	02	**Tank Age**	39	**Tank Installed Date**	06/01/1986	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Steel	**Overfill Types**	Flapper Valve
Tag Number	3893	**Spill Test Date**	01/21/2025	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Single Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	10/15/2024	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Aviation Gas	**PLLD Test Date**		**Tank/Piping CP Test Date**	01/21/2025	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.1	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	10/15/2024	**Line Tightness Test Date**	10/15/2024	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	01/21/2025			**ATG Type**	Incon/TS-1000				

Facility Summary in Lincoln County in the City of Fortine

Location: FORTINE MERC LLC
12000 US Hwy 93 S
Fortine, MT 59918 Lincoln

System Facility ID:27-13725

Facility Code: 24537
Last Inspected On: 12/06/2023
Operating Permit Renewal Date: 03/26/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	FORTINE MERC LLC;Steven Vredenburg	**(406) 882-4446;(971) 404-9771**	**fortinemerc@gmail.com;tessamt@aol.com**
Operator Contact:	Debbie Peterson		**fortinemerc@gmail.com**
Owner/Operator:	FORTINE MERC LLC	(406) 882-4446	fortinemerc@gmail.com
Owner/Operator:	Steven Vredenburg	(406) 882-4446	fortinemerc@gmail.com
	Debbie Peterson, UST Class A Operator		fortinemerc@gmail.com
	Debbie Peterson, UST Class B Operator		fortinemerc@gmail.com

Tank Number	01	**Tank Age**	29	**Tank Installed Date**	04/01/1996	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve
Tag Number	4705	**Spill Test Date**	11/13/2024	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	12/05/2023	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	12/06/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	12/05/2023	**Line Tightness Test Date**	12/05/2023	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	12/05/2023			**ATG Type**	Gilbarco/EMC Basic				
Tank Number	02	**Tank Age**	29	**Tank Installed Date**	04/01/1996	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve
Tag Number	4706	**Spill Test Date**	11/13/2024	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	12/05/2023	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	12/06/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	12/05/2023	**Line Tightness Test Date**	12/05/2023	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	12/05/2023			**ATG Type**	Gilbarco/EMC Basic				
Tank Number	03	**Tank Age**	29	**Tank Installed Date**	04/01/1996	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve

Tag Number	4707	**Spill Test Date**	11/13/2024	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	12/05/2023	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	12/06/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	12/05/2023	**Line Tightness Test Date**	12/05/2023	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	12/05/2023			**ATG Type**	Gilbarco/EMC Basic				

Facility Summary in Lincoln County in the City of Libby

Location: ASA WOOD SCHOOL
700 Idaho Ave
Libby, MT 59923-1706 Lincoln

System Facility ID:27-05434

Facility Code: 24184
Last Inspected On: 03/01/2021
Operating Permit Renewal Date: 03/04/2024

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: School Dist 4 Libby **(406) 293-2791**

Operator Contact: David Nadolny **nadolnyd@libbyschools.org**

David Nadolny, UST Class A Operator nadolnyd@libbyschools.org
David Nadolny, UST Class B Operator nadolnyd@libbyschools.org

Tank Number	S2	**Tank Age**	32	**Tank Installed Date**	10/01/1993	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	1528	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Auto Dialer	**Piping Type**	U.S. Suction	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	03/03/2021	**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	3-Year Line Tightness Test	**Vapor Recovery**	No
Capacity	20000	**ATG Test Date**		**Line Tightness Test Date**	03/03/2021	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date				**ATG Type**	Other/Other				

Facility Summary in Lincoln County in the City of Libby

Location: BEARS QUICK STOP
36175 US Hwy 2 W
Libby, MT 59923 Lincoln

System Facility ID:27-10863

Facility Code: 24368
Last Inspected On: 11/28/2023
Operating Permit Renewal Date: 03/31/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: AJAM2, LLC **(206) 834-5349** **sheragroupllc@gmail.com**

Operator Contact: Jessica Parker **bearscountrystore2017@gmail.com**

Owner/Operator: AJAM2, LLC (206) 834-5349 sheragroupllc@gmail.com

Jessica Parker, UST Class A Operator bearscountrystore2017@gmail.com

Jessica Parker, UST Class B Operator bearscountrystore2017@gmail.com

Tank Number	04	**Tank Age**	34	**Tank Installed Date**	04/29/1991	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve
Tag Number	676	**Spill Test Date**	04/21/2024	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	11/28/2023	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	11/28/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	17000	**ATG Test Date**	11/28/2023	**Line Tightness Test Date**	11/28/2023	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	11/28/2023			**ATG Type**	Veeder Root/EMC Basic				
Tank Number	05	**Tank Age**	34	**Tank Installed Date**	04/29/1991	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve
Tag Number	677	**Spill Test Date**	11/28/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	11/28/2023	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	11/28/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	17000	**ATG Test Date**	11/28/2023	**Line Tightness Test Date**	11/28/2023	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	11/28/2023			**ATG Type**	Veeder Root/EMC Basic				
Tank Number	06	**Tank Age**	34	**Tank Installed Date**	04/29/1991	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve
Tag Number	678	**Spill Test Date**	04/21/2024	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No

Status	**Currently in Use**	**MLLD Test Date**	11/28/2023	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	11/28/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	11/28/2023	**Line Tightness Test Date**	11/28/2023	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	11/28/2023			**ATG Type**	Veeder Root/EMC Basic				
Tank Number	07	**Tank Age**	34	**Tank Installed Date**	04/29/1991	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve
Tag Number	679	**Spill Test Date**	04/21/2024	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	11/28/2023	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	11/28/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	11/28/2023	**Line Tightness Test Date**	11/28/2023	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	11/28/2023			**ATG Type**	Veeder Root/EMC Basic				
Tank Number	08	**Tank Age**	34	**Tank Installed Date**	04/29/1991	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve
Tag Number	680	**Spill Test Date**	04/21/2024	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	11/28/2023	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	11/28/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	11/28/2023	**Line Tightness Test Date**	11/28/2023	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	11/28/2023			**ATG Type**	Veeder Root/EMC Basic				

Facility Summary in Lincoln County in the City of Libby

Location: CABINET PEAKS MEDICAL CENTER
209 Health Park Dr
Libby, MT 59923 Lincoln

System Facility ID:60-15252

Facility Code: 30969
Last Inspected On: 10/18/2023
Operating Permit Renewal Date: 12/19/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Cabinet Peaks Medical Center	**(406) 283-7000**	**trebo@cabinetpeaks.org**
Operator Contact:	Tony Rebo		**trebo@sjlh.com**

Owner/Operator: Cabinet Peaks Medical Center (406) 283-7000 trebo@cabinetpeaks.org
Tony Rebo, UST Class A Operator trebo@sjlh.com
Tony Rebo, UST Class B Operator trebo@sjlh.com

Tank Number	S1	**Tank Age**	12	**Tank Installed Date**	11/29/2013	**Tank Material Construction**	Bare Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	5414	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	Yes
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	08/24/2020	**Catastrophic L.D. Type 3.0**	Auto Dialer	**Piping Type**	U.S. Suction	**CP Met Types**	
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					

Facility Summary in Lincoln County in the City of Libby

Location: HAPPY'S INN LLC
72576 US Hwy 2
Libby, MT 59923-8518 Lincoln

System Facility ID:27-05998

Facility Code: 24198
Last Inspected On: 03/01/2023
Operating Permit Renewal Date: 03/18/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Happy's Inn LLC	**(406) 334-3783**	**coles1222@aol.com**
Operator Contact:	Brandy Kraft;Carry Mick;Deb Steinke;Kristopher Cole	**(406) 293-4079;(406) 334-3783**	**coles1222@aol.com;d.steinke@frontier.com;happysroadhouseinn@gmail.com**

Owner/Operator: Happy's Inn LLC (406) 334-3783 coles1222@aol.com

Brandy Kraft, UST Class A Operator	happysroadhouseinn@gmail.com
Brandy Kraft, UST Class B Operator	happysroadhouseinn@gmail.com
Carry Mick, UST Class A Operator	happysroadhouseinn@gmail.com
Deb Steinke, UST Class A Operator	d.steinke@frontier.com
Deb Steinke, UST Class B Operator	d.steinke@frontier.com
Kristopher Cole, UST Class A Operator	coles1222@aol.com
Kristopher Cole, UST Class B Operator	coles1222@aol.com

Tank Number	01	**Tank Age**	41	**Tank Installed Date**	03/23/1984	**Tank Material Construction**	Bare Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	1282	**Spill Test Date**	03/01/2023	**Piping Installed Date**	09/29/2006	**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Impressed Current
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	01/19/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	03/01/2023			**ATG Type**	Incon/TS-1000				
Tank Number	02	**Tank Age**	41	**Tank Installed Date**	03/23/1984	**Tank Material Construction**	Bare Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	1283	**Spill Test Date**	03/01/2023	**Piping Installed Date**	09/29/2006	**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	01/19/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No

		Overfill Test Date	03/01/2023			**ATG Type**	Incon/TS-1000				

Facility Summary in Lincoln County in the City of Libby

Location: HARLOWS SCHOOL BUS SERVICE INC LIBBY
30772 US Hwy 2
Libby, MT 59923 Lincoln

System Facility ID:27-07523

Facility Code: 24224
Last Inspected On: 10/19/2023
Operating Permit Renewal Date: 12/17/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	HJJ Properties LLC	**(701) 224-1767**	**jeremy.hageness@goharlows.com**
Operator Contact:	Wesley Tangen	**(406) 293-8845**	**busservice@frontier.com**

Owner/Operator: HJJ Properties LLC (701) 224-1767 jeremy.hageness@goharlows.com

Wesley Tangen, UST Class A Operator busservice@frontier.com

Wesley Tangen, UST Class B Operator busservice@frontier.com

Tank Number	03	**Tank Age**	32	**Tank Installed Date**	02/01/1993	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	3101	**Spill Test Date**	10/19/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Temporarily Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	10/19/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	10/19/2023			**ATG Type**	Veeder Root/TLS-300				
Tank Number	04	**Tank Age**	32	**Tank Installed Date**	02/01/1993	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	3102	**Spill Test Date**	10/19/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Temporarily Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	10/19/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	10/19/2023			**ATG Type**	Veeder Root/TLS-300				

Facility Summary in Lincoln County in the City of Libby

Location: LIBBY CENTRAL OFFICE 9080 B01
114 E 4th St
Libby, MT 59923-2030 Lincoln

System Facility ID:27-07386

Facility Code: 24219
Last Inspected On: 07/25/2023
Operating Permit Renewal Date: 07/31/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Citizens Communications Company	**(916) 686-3499**	**legal@ziply.com**
Operator Contact:	Alan Kelly	**(406) 293-0010**	**alan.kelly@ziply.com**

Owner/Operator: Citizens Communications Company (916) 686-3499 legal@ziply.com

Alan Kelly, UST Class A Operator alan.kelly@ziply.com

Alan Kelly, UST Class B Operator alan.kelly@ziply.com

Tank Number	02	**Tank Age**	34	**Tank Installed Date**	08/01/1991	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Steel	**Overfill Types**	High Level Alarm
Tag Number	4307	**Spill Test Date**	10/05/2023	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	07/25/2023	**Catastrophic L.D. Type 3.0**	Auto Dialer	**Piping Type**	Gravity Feed	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	600	**ATG Test Date**	07/25/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	07/25/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-250				

Facility Summary in Lincoln County in the City of Libby

Location: LIBBY HIGH SCHOOL DIST 4
150 Education Way
Libby, MT 59923-2816 Lincoln

System Facility ID:27-05437

Facility Code: 24187
Last Inspected On: 09/05/2023
Operating Permit Renewal Date: 03/04/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: School Dist 4 Libby **(406) 293-2791**

Operator Contact: David Nadolny;Louie Mysse **myssel@libby.k12.mt.us;nadolnyd@libbyschools.org**

Owner/Operator: School Dist 4 Libby (406) 293-2791

David Nadolny, UST Class A Operator nadolnyd@libbyschools.org
David Nadolny, UST Class B Operator nadolnyd@libbyschools.org
Louie Mysse, UST Class A Operator myssel@libby.k12.mt.us
Louie Mysse, UST Class B Global Operator myssel@libby.k12.mt.us

Tank Number	S2	**Tank Age**	35	**Tank Installed Date**	02/05/1990	**Tank Material Construction**	Unknown	**Piping Material**	Copper	**Overfill Types**	Positive Shutoff
Tag Number	1531	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	Yes
Status	**Temporarily Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**	03/04/2021	**Catastrophic L.D. Type 3.0**	Auto Dialer	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Heating Oil	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	2000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	S3	**Tank Age**	35	**Tank Installed Date**	02/05/1990	**Tank Material Construction**	Unknown	**Piping Material**	Copper	**Overfill Types**	Positive Shutoff
Tag Number	1532	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	Yes
Status	**Temporarily Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**	03/04/2021	**Catastrophic L.D. Type 3.0**	Auto Dialer	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Heating Oil	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	2000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					

Tank Number	S4	**Tank Age**	31	**Tank Installed Date**	07/01/1994	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	1533	**Spill Test Date**	09/05/2023	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	03/04/2021	**Catastrophic L.D. Type 3.0**	Auto Dialer	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Heating Oil	**PLLD Test Date**		**Tank/Piping CP Test Date**	09/05/2023	**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**		**Line Tightness Test Date**	05/28/2015	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	09/05/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Lincoln County in the City of Libby

Location: LIBBY QUIK STOP
120 W 9th St
Libby, MT 59923-1965 Lincoln

System Facility ID:27-08831

Facility Code: 24249
Last Inspected On: 10/03/2024
Operating Permit Renewal Date: 03/02/2028

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: HIMALYAN LLC **(406) 293-7513** **LAKESIDEUNITY@GMAIL.COM**

Operator Contact:

Owner/Operator: HIMALYAN LLC (406) 293-7513 LAKESIDEUNITY@GMAIL.COM

Tank Number	03	**Tank Age**	51	**Tank Installed Date**	11/21/1974	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	1274	**Spill Test Date**	10/03/2024	**Piping Installed Date**		**Tank Construction**	Lined Interior/Impressed Current	**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	05/02/2024	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	10/03/2024	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	05/02/2024	**Line Tightness Test Date**	05/02/2024	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	10/03/2024			**ATG Type**	Veeder Root/TLS-300				
Tank Number	05	**Tank Age**	51	**Tank Installed Date**	11/21/1974	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	1276	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**	Lined Interior/Impressed Current	**Piping Construction**	None	**AST**	No
Status	**Temporarily Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	10/03/2024	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**		**Line Tightness Test Date**	05/09/2012	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**	Veeder Root/TLS-300				
Tank Number	04	**Tank Age**	51	**Tank Installed Date**	11/21/1974	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve

Tag Number	4881	**Spill Test Date**	10/03/2024	**Piping Installed Date**		**Tank Construction**	Lined Interior/Impressed Current	**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	05/02/2024	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	10/03/2024	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	05/02/2024	**Line Tightness Test Date**	05/02/2024	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	10/03/2024			**ATG Type**	Veeder Root/TLS-300				

Facility Summary in Lincoln County in the City of Libby

Location: MACS PLACE
1427 MT Hwy 37
Libby, MT 59923-9309 Lincoln

System Facility ID:27-10660

Facility Code: 24354
Last Inspected On: 08/16/2022
Operating Permit Renewal Date: 10/11/2025

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Northside Enterprises LLC **(406) 293-7799**

Operator Contact: Ann Siefke **(406) 293-2784** **a_montgirl@yahoo.com**

Owner/Operator: Northside Enterprises LLC (406) 293-7799

Ann Siefke, UST Class A Operator a_montgirl@yahoo.com
Ann Siefke, UST Class B Operator a_montgirl@yahoo.com

Tank Number	01	**Tank Age**	50	**Tank Installed Date**	03/23/1975	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Steel	**Overfill Types**	Flapper Valve
Tag Number	1272	**Spill Test Date**	08/16/2022	**Piping Installed Date**		**Tank Construction**	Lined Interior/Impressed Current	**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	08/16/2022	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	08/16/2022	**Line Tightness Test Date**	12/30/2005	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	08/16/2022			**ATG Type**	Veeder Root/TLS-300				
Tank Number	02	**Tank Age**	50	**Tank Installed Date**	03/23/1975	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Steel	**Overfill Types**	Flapper Valve
Tag Number	1273	**Spill Test Date**	08/16/2022	**Piping Installed Date**		**Tank Construction**	Lined Interior/Impressed Current	**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Impressed Current
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	08/16/2022	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	08/16/2022	**Line Tightness Test Date**	12/30/2005	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	08/16/2022			**ATG Type**	Veeder Root/TLS-300				

Facility Summary in Lincoln County in the City of Libby

Location: MCGRADE SCHOOL UST
933 Farm to Market Rd Ste C
Libby, MT 59923-8282 Lincoln

System Facility ID:27-05435

Facility Code: 24185
Last Inspected On: 11/29/2023
Operating Permit Renewal Date: 03/04/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: School Dist 4 Libby **(406) 293-2791**

Operator Contact: David Nadolny **nadolnyd@libbyschools.org**

Owner/Operator: School Dist 4 Libby (406) 293-2791

David Nadolny, UST Class A Operator nadolnyd@libbyschools.org
David Nadolny, UST Class B Operator nadolnyd@libbyschools.org

Tank Number	S2	**Tank Age**	30	**Tank Installed Date**	08/01/1995	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Steel	**Overfill Types**	Flapper Valve
Tag Number	1529	**Spill Test Date**	09/05/2023	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	06/21/2024	**Catastrophic L.D. Type 3.0**	Auto Dialer	**Piping Type**	U.S. Suction	**CP Met Types**	Galvanic
Product	Heating Oil	**PLLD Test Date**		**Tank/Piping CP Test Date**	09/05/2023	**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	09/05/2023	**Line Tightness Test Date**	03/03/2021	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	3-Year Line Tightness Test	**Energy Act**	No
		Overfill Test Date	09/05/2023			**ATG Type**	OPW / EMCO/EECO 1500				

Facility Summary in Lincoln County in the City of Libby

Location: MOORE OIL INC KARDGUARD
206 E 1st St
Libby, MT 59923 Lincoln

System Facility ID:27-10130

Facility Code: 24291
Last Inspected On: 04/13/2022
Operating Permit Renewal Date: 06/24/2025

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Moore Oil Inc Thompson Falls **(406) 827-4314**

Operator Contact: Larry Kelly **larry2mooreoil@frontier.com**

Larry Kelly, UST Class A Operator	larry2mooreoil@frontier.com
Larry Kelly, UST Class A Operator	larry2mooreoil@frontier.com
Larry Kelly, UST Class B Global Operator	larry2mooreoil@frontier.com
Larry Kelly, UST Class B Global Operator	larry2mooreoil@frontier.com

Tank Number	S1	**Tank Age**	41	**Tank Installed Date**	12/19/1984	**Tank Material Construction**	Bare Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	
Tag Number	1700	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	Yes
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**	04/13/2022	**Catastrophic L.D. Type 3.0**	Auto Dialer	**Piping Type**	Pressurized	**CP Met Types**	
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	20000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Manual Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	S2	**Tank Age**	41	**Tank Installed Date**	12/19/1984	**Tank Material Construction**	Bare Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	
Tag Number	1701	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	Yes
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**	04/13/2022	**Catastrophic L.D. Type 3.0**	Auto Dialer	**Piping Type**	Pressurized	**CP Met Types**	
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	20000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Manual Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date				**ATG Type**					

Tank Number	S4	**Tank Age**	51	**Tank Installed Date**	07/01/1974	**Tank Material Construction**	Bare Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	
Tag Number	1702	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	Yes
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**	04/13/2022	**Catastrophic L.D. Type 3.0**	Auto Dialer	**Piping Type**	Pressurized	**CP Met Types**	
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Manual Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date				**ATG Type**					

Facility Summary in Lincoln County in the City of Libby

Location: PLUMMER ELEMENTARY SCHOOL
247 Indian Head Rd
Libby, MT 59923-2982 Lincoln

System Facility ID:27-05436

Facility Code: 24186
Last Inspected On: 09/05/2023
Operating Permit Renewal Date: 02/19/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: School Dist 4 Libby **(406) 293-2791**

Operator Contact: David Nadolny **nadolnyd@libbyschools.org**

Owner/Operator: School Dist 4 Libby (406) 293-2791

David Nadolny, UST Class A Operator nadolnyd@libbyschools.org
David Nadolny, UST Class B Operator nadolnyd@libbyschools.org

Tank Number	S2	**Tank Age**	29	**Tank Installed Date**	08/01/1996	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Steel	**Overfill Types**	Flapper Valve
Tag Number	1530	**Spill Test Date**	09/05/2023	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	03/03/2021	**Catastrophic L.D. Type 3.0**	Auto Dialer	**Piping Type**	U.S. Suction	**CP Met Types**	Galvanic
Product	Heating Oil	**PLLD Test Date**		**Tank/Piping CP Test Date**	09/05/2023	**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	09/05/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	09/05/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Lincoln County in the City of Libby

Location: SAVE RITE SOUTH
33934 US Hwy 2
Libby, MT 59923-9011 Lincoln

System Facility ID:27-01240

Facility Code: 24106
Last Inspected On: 01/05/2025
Operating Permit Renewal Date: 04/01/2028

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Robert Uithof		**gsoil@frontiernet.net**
Operator Contact:	Jesse Knapp;Lloyd Holcomb	**(406) 283-1352;(406) 293-4119**	**knapp539@gmail.com;lazyway@montanasky.tv**

Owner/Operator: Robert Uithof — gsoil@frontiernet.net

Jesse Knapp, UST Class A Operator	knapp539@gmail.com
Jesse Knapp, UST Class B Operator	knapp539@gmail.com
Lloyd Holcomb, UST Class A Operator	lazyway@montanasky.tv
Lloyd Holcomb, UST Class A Operator	lazyway@montanasky.tv
Lloyd Holcomb, UST Class B Global Operator	lazyway@montanasky.tv
Lloyd Holcomb, UST Class B Global Operator	lazyway@montanasky.tv
Lloyd Holcomb, UST Class B Operator	lazyway@montanasky.tv
Lloyd Holcomb, UST Class B Operator	lazyway@montanasky.tv

Tank Number	06	**Tank Age**	36	**Tank Installed Date**	05/01/1989	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve
Tag Number	2167	**Spill Test Date**	10/03/2024	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	10/03/2024	**Sump Tightness Test Date**	10/03/2024	**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	05/18/2007	**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	10/03/2024	**Line Tightness Test Date**	10/03/2024	**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	10/03/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350;Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	07	**Tank Age**	36	**Tank Installed Date**	05/01/1989	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve
Tag Number	2168	**Spill Test Date**	10/03/2024	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No

Status	**Currently in Use**	**MLLD Test Date**	10/03/2024	**Sump Tightness Test Date**	10/03/2024	**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	05/18/2007	**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**	10/03/2024	**Line Tightness Test Date**	10/03/2024	**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	10/03/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350;Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	08	**Tank Age**	36	**Tank Installed Date**	05/01/1989	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve
Tag Number	2169	**Spill Test Date**	10/03/2024	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	10/03/2024	**Sump Tightness Test Date**	10/03/2024	**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	05/18/2007	**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	10/03/2024	**Line Tightness Test Date**	10/03/2024	**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	10/03/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350;Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	16	**Tank Age**	30	**Tank Installed Date**	06/03/1995	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve
Tag Number	2170	**Spill Test Date**	10/03/2024	**Piping Installed Date**	08/31/2012	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	10/03/2024	**Sump Tightness Test Date**	10/03/2024	**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	12/04/2021	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	10/03/2024	**Line Tightness Test Date**	10/03/2024	**Secondary Tank Leak Detection**	Manual Interstitial Monitoring	**Secondary Pipe Leak Detection**	MLLD Line Tightness Testing	**Energy Act**	No
		Overfill Test Date	10/03/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	17	**Tank Age**	30	**Tank Installed Date**	06/03/1995	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve
Tag Number	2171	**Spill Test Date**	04/10/2025	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No

Status	**Currently in Use**	**MLLD Test Date**	10/03/2024	**Sump Tightness Test Date**	10/03/2024	**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	12/04/2021	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	10/03/2024	**Line Tightness Test Date**	10/03/2024	**Secondary Tank Leak Detection**	Manual Interstitial Monitoring	**Secondary Pipe Leak Detection**	MLLD Line Tightness Testing	**Energy Act**	No
		Overfill Test Date	10/03/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	18	**Tank Age**	30	**Tank Installed Date**	06/03/1995	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve
Tag Number	2172	**Spill Test Date**	10/03/2024	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	10/03/2024	**Sump Tightness Test Date**	10/03/2024	**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	12/04/2021	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	10/03/2024	**Line Tightness Test Date**	10/03/2024	**Secondary Tank Leak Detection**	Manual Interstitial Monitoring	**Secondary Pipe Leak Detection**	MLLD Line Tightness Testing	**Energy Act**	No
		Overfill Test Date	10/03/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	19	**Tank Age**	30	**Tank Installed Date**	06/23/1995	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve
Tag Number	2173	**Spill Test Date**	04/10/2025	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	12/04/2021	**Sump Tightness Test Date**	12/04/2021	**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	10/03/2024	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	10/03/2024	**Line Tightness Test Date**	12/04/2021	**Secondary Tank Leak Detection**	Manual Interstitial Monitoring	**Secondary Pipe Leak Detection**	MLLD Line Tightness Testing	**Energy Act**	No
		Overfill Test Date	10/03/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	20	**Tank Age**	30	**Tank Installed Date**	06/23/1995	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve
Tag Number	2174	**Spill Test Date**	10/03/2024	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	10/03/2024	**Sump Tightness Test Date**	10/03/2024	**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	10/03/2024	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No

Capacity	10000	**ATG Test Date**	10/03/2024	**Line Tightness Test Date**	10/03/2024	**Secondary Tank Leak Detection**	Manual Interstitial Monitoring	**Secondary Pipe Leak Detection**	MLLD Line Tightness Testing	**Energy Act**	No
		Overfill Test Date	10/03/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	21	**Tank Age**	30	**Tank Installed Date**	06/23/1995	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve
Tag Number	2175	**Spill Test Date**	10/03/2024	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	10/03/2024	**Sump Tightness Test Date**	10/03/2024	**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	10/03/2024	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	10/03/2024	**Line Tightness Test Date**	10/03/2024	**Secondary Tank Leak Detection**	Manual Interstitial Monitoring	**Secondary Pipe Leak Detection**	MLLD Line Tightness Testing	**Energy Act**	No
		Overfill Test Date	10/03/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Lincoln County in the City of Libby

Location: SAVE RITE WEST
31978 US Hwy 2
Libby, MT 59923-3026 Lincoln

System Facility ID:27-01239

Facility Code: 24105
Last Inspected On: 01/05/2025
Operating Permit Renewal Date: 04/01/2028

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Robert Uithof		**gsoil@frontiernet.net**
Operator Contact:	Jesse Knapp;Lloyd Holcomb	**(406) 283-1352;(406) 293-4119**	**knapp539@gmail.com;lazyway@montanasky.tv**

Owner/Operator: Robert Uithof gsoil@frontiernet.net

Jesse Knapp, UST Class A Operator knapp539@gmail.com
Jesse Knapp, UST Class B Operator knapp539@gmail.com
Lloyd Holcomb, UST Class A Operator lazyway@montanasky.tv
Lloyd Holcomb, UST Class A Operator lazyway@montanasky.tv
Lloyd Holcomb, UST Class B Operator lazyway@montanasky.tv
Lloyd Holcomb, UST Class B Operator lazyway@montanasky.tv

Tank Number	13	**Tank Age**	31	**Tank Installed Date**	03/01/1994	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve
Tag Number	2158	**Spill Test Date**	10/03/2024	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	10/03/2024	**Sump Tightness Test Date**	04/18/2019	**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	05/18/2007	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	10/03/2024	**Line Tightness Test Date**	10/03/2024	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	10/03/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350				
Tank Number	14	**Tank Age**	31	**Tank Installed Date**	03/01/1994	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve
Tag Number	2159	**Spill Test Date**	10/03/2024	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	10/03/2024	**Sump Tightness Test Date**	04/18/2019	**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	05/20/2010	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	5000	**ATG Test Date**	10/03/2024	**Line Tightness Test Date**	10/03/2024	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No

		Overfill Test Date	10/03/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350				
Tank Number	15	**Tank Age**	31	**Tank Installed Date**	03/01/1994	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve
Tag Number	2160	**Spill Test Date**	10/03/2024	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	10/03/2024	**Sump Tightness Test Date**	04/18/2019	**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	05/20/2010	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	5000	**ATG Test Date**	10/03/2024	**Line Tightness Test Date**	10/03/2024	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	10/03/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350				
Tank Number	16	**Tank Age**	28	**Tank Installed Date**	06/01/1997	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve
Tag Number	2161	**Spill Test Date**	10/03/2024	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	10/03/2024	**Sump Tightness Test Date**	04/18/2019	**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	10/03/2024	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	10/03/2024	**Line Tightness Test Date**	10/03/2024	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	10/03/2024			**ATG Type**	Gilbarco/TLS-350				
Tank Number	17	**Tank Age**	28	**Tank Installed Date**	06/01/1997	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve
Tag Number	2162	**Spill Test Date**	10/03/2024	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	10/03/2024	**Sump Tightness Test Date**	04/18/2019	**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	10/03/2024	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	10/03/2024	**Line Tightness Test Date**	10/03/2024	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	10/03/2024			**ATG Type**	Gilbarco/TLS-350				
Tank Number	18	**Tank Age**	28	**Tank Installed Date**	06/01/1997	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve
Tag Number	2163	**Spill Test Date**	04/09/2025	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	10/03/2024	**Sump Tightness Test Date**	04/18/2019	**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic

Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	10/03/2024	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	10/03/2024	**Line Tightness Test Date**	10/03/2024	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	10/03/2024			**ATG Type**	Gilbarco/TLS-350				
Tank Number	19	**Tank Age**	28	**Tank Installed Date**	06/01/1997	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve
Tag Number	2164	**Spill Test Date**	10/03/2024	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	10/03/2024	**Sump Tightness Test Date**	04/18/2019	**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	10/03/2024	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**	10/03/2024	**Line Tightness Test Date**	10/03/2024	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	10/03/2024			**ATG Type**	Gilbarco/TLS-350				
Tank Number	20	**Tank Age**	28	**Tank Installed Date**	06/01/1997	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve
Tag Number	2165	**Spill Test Date**	10/03/2024	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	10/03/2024	**Sump Tightness Test Date**	04/18/2019	**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	10/03/2024	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	10/03/2024	**Line Tightness Test Date**	10/03/2024	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	10/03/2024			**ATG Type**	Gilbarco/TLS-350				
Tank Number	21	**Tank Age**	28	**Tank Installed Date**	06/01/1997	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve
Tag Number	2166	**Spill Test Date**	10/03/2024	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	10/03/2024	**Sump Tightness Test Date**	04/18/2019	**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	10/03/2024	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	3000	**ATG Test Date**	10/03/2024	**Line Tightness Test Date**	10/03/2024	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	10/03/2024			**ATG Type**	Gilbarco/TLS-350				

Facility Summary in Lincoln County in the City of Libby

Location: SEWER PLANT
750 City Service Rd
Libby, MT 59923 Lincoln

System Facility ID:27-03164

Facility Code: 24131
Last Inspected On: 03/01/2021
Operating Permit Renewal Date: 03/12/2024

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	City of Libby	**(406) 29-32731**	**cityoflibby.com**
Operator Contact:	Lucas Backen;Mike Voorhies	**(406) 293-4684**	**backenlucas@gmail.com;mavoorhies@gmail.com**

Lucas Backen, UST Class A Operator — backenlucas@gmail.com
Mike Voorhies, UST Class A Operator — mavoorhies@gmail.com

Tank Number	05	**Tank Age**	39	**Tank Installed Date**	12/01/1986	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Steel	**Overfill Types**	Flapper Valve
Tag Number	4089	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	U.S. Suction	**CP Met Types**	
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	10/29/2019	**Primary Tank Leak Detection**	Manual Tank Gauging	**Primary Pipe Leak Detection**	3-Year Line Tightness Test	**Vapor Recovery**	No
Capacity	1100	**ATG Test Date**		**Line Tightness Test Date**	10/29/2019	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					

Facility Summary in Lincoln County in the City of Libby

Location: ST JOHNS LUTHERAN HOSPITAL
350 Louisiana Ave
Libby, MT 59923-2198 Lincoln

System Facility ID:27-01695

Facility Code: 24110
Last Inspected On: 05/04/2023
Operating Permit Renewal Date: 09/25/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Cabinet Peaks Medical Center **(406) 283-7000** **trebo@cabinetpeaks.org**

Operator Contact: Tony Rebo **trebo@sjlh.com**

Owner/Operator: Cabinet Peaks Medical Center (406) 283-7000 trebo@cabinetpeaks.org

Tony Rebo, UST Class A Operator trebo@sjlh.com

Tony Rebo, UST Class B Operator trebo@sjlh.com

Tank Number	S3	**Tank Age**	27	**Tank Installed Date**	07/01/1998	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	1952	**Spill Test Date**	05/04/2023	**Piping Installed Date**	02/15/2013	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	05/04/2023	**Catastrophic L.D. Type 3.0**	Auto Dialer	**Piping Type**	U.S. Suction	**CP Met Types**	Non-corrodible
Product	Heating Oil	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	05/04/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	Yes
		Overfill Test Date	05/04/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-300				

Facility Summary in Lincoln County in the City of Libby

Location: ST JOSEPH PARISH
719 Utah Ave
Libby, MT 59923-2115 Lincoln

System Facility ID:27-07289

Facility Code: 24218
Last Inspected On: 09/03/2024
Operating Permit Renewal Date: 12/11/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Diocese of Helena	**(406) 293-4322**	**stjosephlibby@gmail.com**
Operator Contact:	Lauri Youso;Richard Kluk	**(406) 293-3216;(406) 293-4322**	**stjosephlibby@gmail.com**

Owner/Operator: Diocese of Helena (406) 293-4322 stjosephlibby@gmail.com

Lauri Youso, UST Class A Operator
Lauri Youso, UST Class B Operator stjosephlibby@gmail.com
Richard Kluk, UST Class A Operator stjosephlibby@gmail.com
Richard Kluk, UST Class B Operator stjosephlibby@gmail.com

Tank Number	S3	**Tank Age**	32	**Tank Installed Date**	11/30/1993	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Copper	**Overfill Types**	Flapper Valve
Tag Number	833	**Spill Test Date**	09/03/2024	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Secondary Containment Chase	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	10/09/2018	**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	U.S. Suction	**CP Met Types**	Non-corrodible
Product	Heating Oil	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Manual Interstitial Monitoring	**Vapor Recovery**	No
Capacity	1000	**ATG Test Date**	09/03/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	09/03/2024			**ATG Type**	Pneumercator/Other				

Facility Summary in Lincoln County in the City of Libby

Location: TAMARACK EXXON
203 Mineral Ave
Libby, MT 59923-1951 Lincoln

System Facility ID:27-10078

Facility Code: 24284
Last Inspected On:
Operating Permit Renewal Date: 07/01/1994

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Marvin Killam **(406) 293-5144**

Operator Contact:

Tank Number	01	**Tank Age**	51	**Tank Installed Date**	01/23/1974	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Steel	**Overfill Types**	
Tag Number		**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**		**Piping Type**	Not Listed	**CP Met Types**	
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Not Listed	**Primary Pipe Leak Detection**	Not Listed	**Vapor Recovery**	No
Capacity	36000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					

Facility Summary in Lincoln County in the City of Libby

Location: TOWN PUMP INC LIBBY 2
1315 Minnesota Ave
Libby, MT 59923 Lincoln

System Facility ID:56-14121

Facility Code: 30762
Last Inspected On: 02/07/2023
Operating Permit Renewal Date: 09/17/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Libby 2 Town Pump LLC	**(406) 497-6700**	**environmental@townpump.com**
Operator Contact:	Trent Biggers		**Trentb@townpump.com**

Owner/Operator:	Libby 2 Town Pump LLC	(406) 497-6700	environmental@townpump.com
	Trent Biggers, UST Class A Operator		Trentb@townpump.com
	Trent Biggers, UST Class A Operator		Trentb@townpump.com
	Trent Biggers, UST Class B Global Operator		Trentb@townpump.com
	Trent Biggers, UST Class B Global Operator		Trentb@townpump.com

Tank Number	01	**Tank Age**	21	**Tank Installed Date**	06/09/2004	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve
Tag Number	4922	**Spill Test Date**	08/15/2022	**Piping Installed Date**	06/09/2004	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	06/24/2021	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	02/07/2023	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	15000	**ATG Test Date**	02/07/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	08/15/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350				
Tank Number	02	**Tank Age**	21	**Tank Installed Date**	06/09/2004	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	4923	**Spill Test Date**	08/15/2022	**Piping Installed Date**	06/09/2004	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	06/24/2021	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	02/07/2023	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	02/07/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No

		Overfill Test Date	10/20/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350				
Tank Number	03	**Tank Age**	21	**Tank Installed Date**	06/09/2004	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	4924	**Spill Test Date**	12/07/2022	**Piping Installed Date**	06/09/2004	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	06/24/2021	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	02/07/2023	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	5000	**ATG Test Date**	02/07/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	12/07/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350				
Tank Number	04	**Tank Age**	21	**Tank Installed Date**	06/09/2004	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve
Tag Number	4925	**Spill Test Date**	08/15/2022	**Piping Installed Date**	06/09/2004	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	06/24/2021	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	02/07/2023	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	15000	**ATG Test Date**	02/07/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	08/15/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350				
Tank Number	05	**Tank Age**	21	**Tank Installed Date**	06/09/2004	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	4927	**Spill Test Date**	12/07/2022	**Piping Installed Date**	06/09/2004	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	06/24/2021	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel, Dyed	**PLLD Test Date**	02/07/2023	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	02/07/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	12/07/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350				
Tank Number	06	**Tank Age**	21	**Tank Installed Date**	06/09/2004	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve

Tag Number	4928	**Spill Test Date**	08/15/2022	**Piping Installed Date**	06/09/2004	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	06/24/2021	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	02/07/2023	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	5000	**ATG Test Date**	02/07/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	08/15/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Lincoln County in the City of Troy

Location: CENEX TROY MINI MART
217 E Missoula Ave
Troy, MT 59935 Lincoln

System Facility ID:27-03253

Facility Code: 24134
Last Inspected On: 06/22/2022
Operating Permit Renewal Date: 09/11/2025

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Joseph Lapham **(208) 263-7606**

Operator Contact: Mike DuPerault **(208) 610-1110** **2holidaymotel2@gmail.com.**

Owner/Operator: Joseph Lapham (208) 263-7606

Mike DuPerault, UST Class A Operator 2holidaymotel2@gmail.com.

Mike DuPerault, UST Class B Operator 2holidaymotel2@gmail.com.

Tank Number	07	**Tank Age**	32	**Tank Installed Date**	04/12/1993	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve
Tag Number	3129	**Spill Test Date**	06/20/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	06/20/2022	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	06/20/2022	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	06/20/2022	**Line Tightness Test Date**	06/20/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	08/29/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	08	**Tank Age**	32	**Tank Installed Date**	04/12/1993	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve
Tag Number	3130	**Spill Test Date**	06/20/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	06/20/2022	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	06/20/2022	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	06/20/2022	**Line Tightness Test Date**	06/20/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	08/29/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	09	**Tank Age**	32	**Tank Installed Date**	04/12/1993	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve

Tag Number	3131	**Spill Test Date**	06/20/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	06/20/2022	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	06/20/2022	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	5000	**ATG Test Date**	06/20/2022	**Line Tightness Test Date**	06/20/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	08/29/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	10	**Tank Age**	32	**Tank Installed Date**	04/12/1993	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve
Tag Number	3132	**Spill Test Date**	06/20/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	06/20/2022	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	06/20/2022	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	5000	**ATG Test Date**	06/20/2022	**Line Tightness Test Date**	06/20/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	08/29/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Lincoln County in the City of Troy

Location: LINCOLN COUNTY SHOP TROY
1210 E Missoula Ave
Troy, MT 59935-9640 Lincoln

System Facility ID:27-06716

Facility Code: 24202
Last Inspected On: 04/28/2025
Operating Permit Renewal Date: 07/02/2028

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Lincoln County Road Dept **(406) 295-4420**

Operator Contact: DJ Welch **road2@libby.org**

Owner/Operator: Lincoln County Road Dept (406) 295-4420

DJ Welch, UST Class A Operator road2@libby.org

DJ Welch, UST Class B Operator road2@libby.org

Tank Number	03	**Tank Age**	35	**Tank Installed Date**	05/01/1990	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Steel	**Overfill Types**	Flapper Valve
Tag Number	1538	**Spill Test Date**	04/28/2025	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Single Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	04/28/2025	**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	2000	**ATG Test Date**	04/28/2025	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	04/28/2025			**ATG Type**	OPW / EMCO/Auto Stik JR				
Tank Number	04	**Tank Age**	35	**Tank Installed Date**	05/01/1990	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Steel	**Overfill Types**	Flapper Valve
Tag Number	1539	**Spill Test Date**	04/28/2025	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Single Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	04/28/2025	**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	2000	**ATG Test Date**	04/28/2025	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	04/28/2025			**ATG Type**	OPW / EMCO/Auto Stik JR				

Facility Summary in Lincoln County in the City of Troy

Location: TOWN PUMP INC TROY
112 E Missoula Ave
Troy, MT 59935 Lincoln

System Facility ID:27-08722

Facility Code: 24241
Last Inspected On: 07/05/2023
Operating Permit Renewal Date: 09/16/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Troy 1 Town Pump LLC	**(406) 497-6700**	**environmental@townpump.com**
Operator Contact:	Trent Biggers		**Trentb@townpump.com**

Trent Biggers, UST Class A Operator	Trentb@townpump.com
Trent Biggers, UST Class A Operator	Trentb@townpump.com
Trent Biggers, UST Class A Operator	Trentb@townpump.com
Trent Biggers, UST Class B Global Operator	Trentb@townpump.com
Trent Biggers, UST Class B Global Operator	Trentb@townpump.com
Trent Biggers, UST Class B Global Operator	Trentb@townpump.com

Tank Number	01	**Tank Age**	53	**Tank Installed Date**	04/14/1972	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve
Tag Number	2522	**Spill Test Date**	08/15/2022	**Piping Installed Date**		**Tank Construction**	Lined Interior/Impressed Current	**Piping Construction**	None	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Diesel	**PLLD Test Date**	02/07/2023	**Tank/Piping CP Test Date**	06/23/2021	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	24000	**ATG Test Date**	02/07/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	08/15/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350				
Tank Number	02	**Tank Age**	53	**Tank Installed Date**	04/14/1972	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve
Tag Number	2523	**Spill Test Date**	08/15/2022	**Piping Installed Date**		**Tank Construction**	Lined Interior/Impressed Current	**Piping Construction**	None	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**	02/07/2023	**Tank/Piping CP Test Date**	06/23/2021	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No

Capacity	12000	**ATG Test Date**	02/07/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	08/15/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350				
Tank Number	03	**Tank Age**	45	**Tank Installed Date**	04/14/1980	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve
Tag Number	2524	**Spill Test Date**	08/15/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**	02/07/2023	**Tank/Piping CP Test Date**	06/23/2021	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	24000	**ATG Test Date**	02/07/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	08/15/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Lincoln County in the City of Troy

Location: TOWN PUMP TROY
107 E Missoula Ave
Troy, MT 59935 Lincoln

System Facility ID:00-32472

Facility Code: 32472
Last Inspected On: 09/08/2024
Operating Permit Renewal Date: 09/04/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Troy Town Pump, Inc.	**(406) 497-6700**	**arnoldo@townpump.com**
Operator Contact:	Trent Biggers;Town Pump		**Trentb@townpump.com;environmental@townpump.com**

Owner/Operator: Troy Town Pump, Inc. (406) 497-6700 arnoldo@townpump.com

Trent Biggers, UST Class A Operator environmental@townpump.com

Trent Biggers, UST Class B Operator environmental@townpump.com

Tank Number	01	**Tank Age**	2	**Tank Installed Date**	03/01/2023	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	6066	**Spill Test Date**	08/10/2022	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	08/10/2022	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	20000	**ATG Test Date**	08/10/2022	**Line Tightness Test Date**	02/14/2023	**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2;Statistical Inventory Reconciliation	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	Yes
		Overfill Test Date	08/10/2022			**ATG Type**					
Tank Number	02	**Tank Age**	2	**Tank Installed Date**	03/01/2023	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	6067	**Spill Test Date**	08/10/2022	**Piping Installed Date**	03/01/2023	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	08/10/2022	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No

Capacity	6000	**ATG Test Date**	08/10/2022	**Line Tightness Test Date**	02/14/2023	**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2;Statistical Inventory Reconciliation	**Secondary Pipe Leak Detection**		**Energy Act**	Yes
		Overfill Test Date	08/10/2022			**ATG Type**					
Tank Number	03	**Tank Age**	2	**Tank Installed Date**	03/01/2023	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	6068	**Spill Test Date**	08/10/2022	**Piping Installed Date**	03/01/2023	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	08/10/2022	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel, Dyed	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**	08/10/2022	**Line Tightness Test Date**	02/14/2023	**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2;Statistical Inventory Reconciliation	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	Yes
		Overfill Test Date	08/10/2022			**ATG Type**					
Tank Number	04	**Tank Age**	2	**Tank Installed Date**	03/01/2023	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	6069	**Spill Test Date**	08/10/2022	**Piping Installed Date**	03/01/2023	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	08/10/2022	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel, Dyed	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	08/10/2022	**Line Tightness Test Date**	02/14/2023	**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2;Statistical Inventory Reconciliation	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	Yes
		Overfill Test Date	08/10/2022			**ATG Type**					
Tank Number	05	**Tank Age**	2	**Tank Installed Date**	03/01/2023	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	
Tag Number	6070	**Spill Test Date**		**Piping Installed Date**	03/01/2023	**Tank Construction**		**Piping Construction**		**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**		**Piping Type**	Pressurized	**CP Met Types**	
Product	DEF (Not Regulated)	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	Yes

		Overfill Test Date				**ATG Type**					
Tank Number	06	**Tank Age**	2	**Tank Installed Date**	03/01/2023	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	6071	**Spill Test Date**	08/10/2023	**Piping Installed Date**	03/01/2023	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	08/10/2023	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	Yes
Capacity	6000	**ATG Test Date**	08/10/2023	**Line Tightness Test Date**	02/15/2023	**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2;Statistical Inventory Reconciliation	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	Yes
		Overfill Test Date	08/10/2023			**ATG Type**					
Tank Number	07	**Tank Age**	2	**Tank Installed Date**	03/01/2023	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	6072	**Spill Test Date**	08/10/2023	**Piping Installed Date**	03/01/2023	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	08/10/2023	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	Yes
Capacity	16000	**ATG Test Date**	08/10/2023	**Line Tightness Test Date**	02/15/2023	**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2;Statistical Inventory Reconciliation	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	Yes
		Overfill Test Date	08/10/2023			**ATG Type**					
Tank Number	08	**Tank Age**	2	**Tank Installed Date**	03/01/2023	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	6073	**Spill Test Date**	08/10/2023	**Piping Installed Date**	03/01/2023	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	08/10/2023	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	Yes
Capacity	8000	**ATG Test Date**	08/10/2023	**Line Tightness Test Date**	02/15/2023	**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2;Statistical Inventory Reconciliation	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	Yes

		Overfill Test Date	08/10/2023			**ATG Type**					
Tank Number	09	**Tank Age**	3	**Tank Installed Date**	06/20/2022	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	
Tag Number	6077	**Spill Test Date**	08/17/2022	**Piping Installed Date**	03/01/2023	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	08/17/2022	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	15000	**ATG Test Date**	05/09/2024	**Line Tightness Test Date**	05/15/2024	**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2;Statistical Inventory Reconciliation	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	Yes
		Overfill Test Date	08/17/2022			**ATG Type**					
Tank Number	10	**Tank Age**	3	**Tank Installed Date**	06/20/2022	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	
Tag Number	6078	**Spill Test Date**	08/17/2022	**Piping Installed Date**	03/01/2023	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	08/17/2022	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	Yes
Capacity	10000	**ATG Test Date**	05/09/2024	**Line Tightness Test Date**	05/15/2024	**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2;Statistical Inventory Reconciliation	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	Yes
		Overfill Test Date	08/17/2022			**ATG Type**					
Tank Number	11	**Tank Age**	3	**Tank Installed Date**	06/20/2022	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	
Tag Number	6079	**Spill Test Date**	08/17/2022	**Piping Installed Date**	03/01/2023	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	08/17/2022	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	Yes
Capacity	25000	**ATG Test Date**	05/09/2024	**Line Tightness Test Date**	05/15/2024	**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2;Statistical Inventory Reconciliation	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	Yes

		Overfill Test Date	08/17/2022			**ATG Type**					

Facility Summary in Lincoln County in the City of Troy

Location: TROY CENTRAL OFFICE 9140 B01
402 N 2nd St
Troy, MT 59935 Lincoln

System Facility ID:27-08082

Facility Code: 24235
Last Inspected On: 05/29/2025
Operating Permit Renewal Date: 06/01/2028

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Citizens Communications Company	**(916) 686-3499**	**legal@ziply.com**
Operator Contact:	Scott Kerzman;Citizens Communications Company	**(406) 293-1479;(916) 686-3499**	**scott.kerzman@ziply.com;legal@ziply.com**

Owner/Operator: Citizens Communications Company (916) 686-3499 legal@ziply.com

Scott Kerzman, UST Class A Operator legal@ziply.com

Scott Kerzman, UST Class B Operator legal@ziply.com

Tank Number	S2	**Tank Age**	34	**Tank Installed Date**	08/01/1991	**Tank Material Construction**	Unknown	**Piping Material**	Steel	**Overfill Types**	
Tag Number	3272	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	Yes
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	07/08/2022	**Catastrophic L.D. Type 3.0**	Auto Dialer	**Piping Type**	U.S. Suction	**CP Met Types**	
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	500	**ATG Test Date**	05/29/2025	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**	Veeder Root/TLS-350				

Facility Summary in Lincoln County in the City of Troy

Location: TROY ELEMENTARY SCHOOL
318 Kalispell Ave
Troy, MT 59935 Lincoln

System Facility ID:27-00764

Facility Code: 24102
Last Inspected On: 11/14/2024
Operating Permit Renewal Date: 03/02/2028

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: School Dist 1 Troy **(406) 295-4606**

Operator Contact: John Daniel;Keith Haggerty **(406) 293-1170;(406) 293-1693** **khaggerty@troyk12.org**

Owner/Operator: School Dist 1 Troy (406) 295-4606

John Daniel, UST Class A Operator
John Daniel, UST Class B Global Operator
Keith Haggerty, UST Class A Operator khaggerty@troyk12.org
Keith Haggerty, UST Class B Global Operator khaggerty@troyk12.org

Tank Number	S1	**Tank Age**	38	**Tank Installed Date**	08/01/1987	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Copper	**Overfill Types**	Flapper Valve
Tag Number	2149	**Spill Test Date**	11/14/2024	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	PVC	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	U.S. Suction	**CP Met Types**	Galvanic
Product	Heating Oil	**PLLD Test Date**		**Tank/Piping CP Test Date**	11/14/2024	**Primary Tank Leak Detection**	Manual Interstitial Monitoring	**Primary Pipe Leak Detection**	Manual Interstitial Monitoring	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	11/14/2024			**ATG Type**					

Facility Summary in Lincoln County in the City of Troy

Location: TROY HIGH SCHOOL MISSOULA AVE
204 Missoula Ave
Troy, MT 59935 Lincoln

System Facility ID:27-00763

Facility Code: 24101
Last Inspected On: 11/14/2024
Operating Permit Renewal Date: 03/02/2028

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: School Dist 1 Troy **(406) 295-4606**

Operator Contact: John Daniel;Keith Haggerty **(406) 293-1170;(406) 293-1693** **khaggerty@troyk12.org**

Owner/Operator: School Dist 1 Troy (406) 295-4606

John Daniel, UST Class A Operator
John Daniel, UST Class B Global Operator
Keith Haggerty, UST Class A Operator khaggerty@troyk12.org
Keith Haggerty, UST Class B Global Operator khaggerty@troyk12.org

Tank Number	S1	**Tank Age**	38	**Tank Installed Date**	08/01/1987	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Copper	**Overfill Types**	Flapper Valve
Tag Number	2147	**Spill Test Date**	11/14/2024	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	PVC	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	U.S. Suction	**CP Met Types**	Galvanic
Product	Heating Oil	**PLLD Test Date**		**Tank/Piping CP Test Date**	11/14/2024	**Primary Tank Leak Detection**	Manual Interstitial Monitoring	**Primary Pipe Leak Detection**	Manual Interstitial Monitoring	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	11/14/2024			**ATG Type**					
Tank Number	S3	**Tank Age**	38	**Tank Installed Date**	08/01/1987	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Copper	**Overfill Types**	Flapper Valve
Tag Number	2148	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	PVC	**AST**	No
Status	**Temporarily Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	U.S. Suction	**CP Met Types**	Galvanic
Product	Heating Oil	**PLLD Test Date**		**Tank/Piping CP Test Date**	11/14/2024	**Primary Tank Leak Detection**	Manual Interstitial Monitoring	**Primary Pipe Leak Detection**	Manual Interstitial Monitoring	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					

Facility Summary in Madison County in the City of Alder

Location: ALDER MARKET LLC
2325 Hwy 287
Alder, MT 59710 Madison

System Facility ID:28-04167

Facility Code: 24625
Last Inspected On: 04/13/2021
Operating Permit Renewal Date: 05/15/2024

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Alder Market LLC	**(406) 842-5679**	**caldwellwill@msn.com**
Operator Contact:	William Caldwell	**(406) 925-9713**	**caldwellwill@msn.com**

William Caldwell, UST Class A Operator caldwellwill@msn.com
William Caldwell, UST Class B Operator caldwellwill@msn.com

Tank Number	S3	**Tank Age**	37	**Tank Installed Date**	07/01/1988	**Tank Material Construction**	Unknown	**Piping Material**	Flexible Plastic	**Overfill Types**	
Tag Number	385	**Spill Test Date**		**Piping Installed Date**	11/14/2017	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	Yes
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**	04/13/2021	**Catastrophic L.D. Type 3.0**	Continuous Interstitial Monitoring	**Piping Type**	Pressurized	**CP Met Types**	
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**		**Line Tightness Test Date**	11/14/2017	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	S4	**Tank Age**	37	**Tank Installed Date**	07/01/1988	**Tank Material Construction**	Unknown	**Piping Material**	Flexible Plastic	**Overfill Types**	
Tag Number	386	**Spill Test Date**		**Piping Installed Date**	11/14/2017	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	Yes
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**	04/13/2021	**Catastrophic L.D. Type 3.0**	Continuous Interstitial Monitoring	**Piping Type**	Pressurized	**CP Met Types**	
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	5800	**ATG Test Date**		**Line Tightness Test Date**	11/14/2017	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					

Facility Summary in Madison County in the City of Cameron

Location: WARREN MILLER LODGE
Seven Bears Trl
Cameron, MT 59720 Madison

System Facility ID:60-15020

Facility Code: 30806
Last Inspected On: 01/30/2024
Operating Permit Renewal Date: 04/08/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Yellowstone Club	**(406) 993-2422**	**tyler.schmidt@yellowstoneclub.com**
Operator Contact:	Joe Robillard		**joe.robillard@yellowstoneclub.com**

Owner/Operator: Yellowstone Club (406) 993-2422 tyler.schmidt@yellowstoneclub.com

Dan Nitsche, UST Class B Global Operator

Joe Robillard, UST Class A Operator joe.robillard@yellowstoneclub.com

Tank Number	02	**Tank Age**	8	**Tank Installed Date**	08/14/2017	**Tank Material Construction**	Steel Clad	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	5766	**Spill Test Date**	11/06/2023	**Piping Installed Date**	08/14/2017	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	11/06/2023	**Catastrophic L.D. Type 3.0**	Auto Dialer	**Piping Type**	U.S. Suction	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	2000	**ATG Test Date**	11/06/2023	**Line Tightness Test Date**	09/18/2017	**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**		**Energy Act**	Yes
		Overfill Test Date	11/06/2023			**ATG Type**	OPW/EECO 1500				

Facility Summary in Madison County in the City of Ennis

Location: MADISON FOODS ENNIS
4939 US-287 N
Ennis, MT 59729 Madison

System Facility ID:00-32574

Facility Code: 32574
Last Inspected On: 12/18/2024
Operating Permit Renewal Date: 12/18/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Chris Gentry;JGC Land LLC	**(406) 579-2535**	**afsfoods@3rivers.nte**
Operator Contact:	Chris Gentry;JGC Land LLC	**(406) 579-2535**	**afsfoods@3rivers.nte**

Owner/Operator: Chris Gentry,JGC Land LLC (406) 579-2535 afsfoods@3rivers.nte
Chris Gentry, UST Class A Operator afsfoods@3rivers.nte
Chris Gentry, UST Class B Operator afsfoods@3rivers.nte

Tank Number	01	**Tank Age**	1	**Tank Installed Date**	07/01/2024	**Tank Material Construction**	Steel Clad	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	6228	**Spill Test Date**	08/06/2024	**Piping Installed Date**	07/01/2024	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	08/06/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	Yes
Capacity	13000	**ATG Test Date**	08/14/2024	**Line Tightness Test Date**	08/21/2024	**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	08/14/2024			**ATG Type**					
Tank Number	02	**Tank Age**	1	**Tank Installed Date**	07/01/2024	**Tank Material Construction**	Steel Clad	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	6229	**Spill Test Date**	08/06/2024	**Piping Installed Date**	07/01/2024	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	08/06/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	Yes
Capacity	7000	**ATG Test Date**	08/14/2024	**Line Tightness Test Date**	08/21/2024	**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	08/14/2024			**ATG Type**					
Tank Number	03	**Tank Age**	1	**Tank Installed Date**	07/01/2024	**Tank Material Construction**	Steel Clad	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm

Tag Number	6230	**Spill Test Date**	08/06/2024	**Piping Installed Date**	07/01/2024	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	08/06/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	08/14/2024	**Line Tightness Test Date**	08/21/2024	**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	08/14/2024			**ATG Type**					
Tank Number	04	**Tank Age**	1	**Tank Installed Date**	07/01/2024	**Tank Material Construction**	Steel Clad	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	6231	**Spill Test Date**	08/06/2024	**Piping Installed Date**	07/01/2024	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	08/06/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	Yes
Capacity	7000	**ATG Test Date**	08/14/2024	**Line Tightness Test Date**	08/21/2024	**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	08/14/2024			**ATG Type**					

Facility Summary in Madison County in the City of Ennis

Location: ROCKY MOUNTAIN SUPPLY INC ENNIS
4997 US Hwy 287 N
Ennis, MT 59729 Madison

System Facility ID:56-13826

Facility Code: 30512
Last Inspected On: 08/13/2024
Operating Permit Renewal Date: 11/29/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Rocky Mountain Supply Inc	**(406) 388-4009**	**billballiet@rmsi.coop**
Operator Contact:	Jason Rorabaugh	**(406) 388-6116**	**jasonrorabaugh@rmsi.coop**

Owner/Operator: Rocky Mountain Supply Inc (406) 388-4009 billballiet@rmsi.coop

Dan Lewis, UST Class B Operator daniellewis@rmsi.coop

Jason Rorabaugh, UST Class A Operator jasonrorabaugh@rmsi.coop

Tank Number	01	**Tank Age**	28	**Tank Installed Date**	07/01/1997	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	1768	**Spill Test Date**	04/22/2024	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	04/24/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	09/02/2020	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	04/24/2024	**Line Tightness Test Date**	04/24/2024	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	04/24/2024			**ATG Type**	Franklin Fueling Systems/EVO 600				
Tank Number	02	**Tank Age**	28	**Tank Installed Date**	07/01/1997	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve;High Level Alarm
Tag Number	1769	**Spill Test Date**	04/22/2024	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	04/24/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	09/02/2020	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	5000	**ATG Test Date**	04/24/2024	**Line Tightness Test Date**	04/24/2024	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	04/24/2024			**ATG Type**	Franklin Fueling Systems/EVO 6000				

Tank Number	03	**Tank Age**	28	**Tank Installed Date**	07/01/1997	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve;High Level Alarm
Tag Number	1770	**Spill Test Date**	04/22/2024	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	04/24/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	09/02/2020	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	04/24/2024	**Line Tightness Test Date**	04/24/2024	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	04/24/2024			**ATG Type**	Franklin Fueling Systems/EVO 6000				
Tank Number	04	**Tank Age**	28	**Tank Installed Date**	07/01/1997	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve;High Level Alarm
Tag Number	1771	**Spill Test Date**	04/22/2024	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	04/24/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	09/02/2020	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	5000	**ATG Test Date**	04/24/2024	**Line Tightness Test Date**	04/24/2024	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	04/24/2024			**ATG Type**	Franklin Fueling Systems/EVO 6000				
Tank Number	05	**Tank Age**	28	**Tank Installed Date**	07/01/1997	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve;High Level Alarm
Tag Number	1772	**Spill Test Date**	04/22/2024	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	04/24/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	09/02/2020	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	04/24/2024	**Line Tightness Test Date**	04/24/2024	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	04/24/2024			**ATG Type**	Franklin Fueling Systems/EVO 6000				
Tank Number	06	**Tank Age**	28	**Tank Installed Date**	07/01/1997	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve;High Level Alarm
Tag Number	1773	**Spill Test Date**	04/22/2024	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No

Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	04/24/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	04/24/2024	**Line Tightness Test Date**	04/24/2024	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	04/24/2024			**ATG Type**	Franklin Fueling Systems/TLS-350/Gilbarco EMC				
Tank Number	07	**Tank Age**	2	**Tank Installed Date**	10/01/2023	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	
Tag Number	6191	**Spill Test Date**	04/22/2024	**Piping Installed Date**	04/24/2024	**Tank Construction**		**Piping Construction**		**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	04/24/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	Yes
Capacity	12000	**ATG Test Date**	04/24/2024	**Line Tightness Test Date**	04/24/2024	**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	04/24/2024			**ATG Type**					
Tank Number	08	**Tank Age**	2	**Tank Installed Date**	10/01/2023	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	
Tag Number	6192	**Spill Test Date**	04/22/2024	**Piping Installed Date**	04/24/2024	**Tank Construction**		**Piping Construction**		**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	04/24/2024	**Catastrophic L.D. Type 3.0**		**Piping Type**	Pressurized	**CP Met Types**	
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	04/24/2024	**Line Tightness Test Date**	04/24/2024	**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	04/24/2024			**ATG Type**					
Tank Number	09	**Tank Age**	2	**Tank Installed Date**	10/01/2023	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	
Tag Number	6193	**Spill Test Date**		**Piping Installed Date**	04/24/2024	**Tank Construction**		**Piping Construction**		**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**		**Piping Type**	Pressurized	**CP Met Types**	
Product	DEF (Not Regulated)	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	Yes

		Overfill Test Date				**ATG Type**					

Facility Summary in Madison County in the City of Ennis

Location: TOWN PUMP INC ENNIS
116 W Main St
Ennis, MT 59729 Madison

System Facility ID:28-08698

Facility Code: 24722
Last Inspected On: 05/21/2025
Operating Permit Renewal Date: 09/23/2025

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Ennis 1 Town Pump LLC	**(406) 497-6700**	**environmental@townpump.com**
Operator Contact:	Trent Biggers		**Trentb@townpump.com**

Owner/Operator: Ennis 1 Town Pump LLC (406) 497-6700 environmental@townpump.com

Trent Biggers, UST Class A Operator — Trentb@townpump.com
Trent Biggers, UST Class A Operator — Trentb@townpump.com
Trent Biggers, UST Class B Global Operator — Trentb@townpump.com
Trent Biggers, UST Class B Global Operator — Trentb@townpump.com

Tank Number	01	**Tank Age**	45	**Tank Installed Date**	04/14/1980	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	2529	**Spill Test Date**	10/08/2024	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	04/22/2021	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**	07/05/2022	**Tank/Piping CP Test Date**	04/22/2021	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	07/05/2022	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	04/22/2021			**ATG Type**	Gilbarco-Veeder Root/TLS-350				
Tank Number	04	**Tank Age**	33	**Tank Installed Date**	04/01/1992	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	2530	**Spill Test Date**	07/07/2021	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	07/05/2022	**Sump Tightness Test Date**	04/22/2021	**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	07/05/2022	**Line Tightness Test Date**	07/13/2015	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No

		Overfill Test Date	04/22/2021			**ATG Type**	Gilbarco-Veeder Root/TLS-350				
Tank Number	05	**Tank Age**	33	**Tank Installed Date**	04/01/1992	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	2531	**Spill Test Date**	12/27/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	08/28/2024	**Sump Tightness Test Date**	04/22/2021	**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	07/05/2022	**Line Tightness Test Date**	08/28/2024	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	04/22/2021			**ATG Type**	Gilbarco-Veeder Root/TLS-350				
Tank Number	06	**Tank Age**	33	**Tank Installed Date**	04/01/1992	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	2532	**Spill Test Date**	07/07/2021	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	08/28/2024	**Sump Tightness Test Date**	04/22/2021	**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	07/05/2022	**Line Tightness Test Date**	08/28/2024	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	04/22/2021			**ATG Type**	Gilbarco-Veeder Root/TLS-350				
Tank Number	07	**Tank Age**	23	**Tank Installed Date**	10/16/2002	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve
Tag Number	4734	**Spill Test Date**	04/22/2021	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	04/22/2021	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel, Dyed	**PLLD Test Date**	07/05/2022	**Tank/Piping CP Test Date**	05/03/2012	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**	07/05/2022	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	04/22/2021			**ATG Type**	Gilbarco-Veeder Root/TLS-350				
Tank Number	08	**Tank Age**	23	**Tank Installed Date**	10/16/2002	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve
Tag Number	4735	**Spill Test Date**	07/07/2021	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No

Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	04/22/2021	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	07/05/2022	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	5000	**ATG Test Date**	07/05/2022	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	04/22/2021			**ATG Type**	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Madison County in the City of Norris

Location: MCLEOD MERCANTILE SW CORNER
6533 US Hwy 287
Norris, MT 59745 Madison

System Facility ID:56-14138

Facility Code: 30774
Last Inspected On: 10/10/2024
Operating Permit Renewal Date: 02/28/2028

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	A M Welles Inc		**Tim@amwelles.com**
Operator Contact:	Katie Burtchett;Marvena Rice;Patricia Lehman	**(406) 580-3664;(406) 685-3372**	**dsgrl4ever@hotmail.com;katie@amwelles.com;pg_lehman@yahoo.com**

Owner/Operator: A M Welles Inc — Tim@amwelles.com

Katie Burtchett, UST Class A Operator	katie@amwelles.com
Katie Burtchett, UST Class A Operator	katie@amwelles.com
Katie Burtchett, UST Class B Operator	katie@amwelles.com
Katie Burtchett, UST Class B Operator	katie@amwelles.com
Marvena Rice, UST Class A Operator	dsgrl4ever@hotmail.com
Marvena Rice, UST Class A Operator	dsgrl4ever@hotmail.com
Patricia Lehman, UST Class A Operator	pg_lehman@yahoo.com
Patricia Lehman, UST Class A Operator	pg_lehman@yahoo.com

Tank Number	06	**Tank Age**	34	**Tank Installed Date**	07/01/1991	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve
Tag Number	2712	**Spill Test Date**	10/10/2024	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**	10/10/2024	**Tank/Piping CP Test Date**	10/10/2024	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	2000	**ATG Test Date**	10/10/2024	**Line Tightness Test Date**	11/02/2009	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	10/10/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-450				
Tank Number	07	**Tank Age**	34	**Tank Installed Date**	07/01/1991	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve
Tag Number	2713	**Spill Test Date**	10/10/2024	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**	10/10/2024	**Tank/Piping CP Test Date**	10/10/2024	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No

Capacity	2000	**ATG Test Date**	10/10/2024	**Line Tightness Test Date**	11/02/2009	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	10/10/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-450				
Tank Number	08	**Tank Age**	34	**Tank Installed Date**	07/01/1991	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve
Tag Number	2714	**Spill Test Date**	10/10/2024	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**	10/10/2024	**Tank/Piping CP Test Date**	10/10/2024	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	2000	**ATG Test Date**	10/10/2024	**Line Tightness Test Date**	11/02/2009	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	10/10/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-450				
Tank Number	09	**Tank Age**	34	**Tank Installed Date**	07/01/1991	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve
Tag Number	2715	**Spill Test Date**	10/10/2024	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**	10/10/2024	**Tank/Piping CP Test Date**	10/10/2024	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**	10/10/2024	**Line Tightness Test Date**	11/02/2009	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	10/10/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-450				
Tank Number	10	**Tank Age**	34	**Tank Installed Date**	07/01/1991	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	2716	**Spill Test Date**	10/10/2024	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	10/10/2024	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	1000	**ATG Test Date**	10/10/2024	**Line Tightness Test Date**	11/02/2009	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	10/10/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-450				
Tank Number	11	**Tank Age**	34	**Tank Installed Date**	07/01/1991	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	2717	**Spill Test Date**	10/10/2024	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Galvanic

Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	10/10/2024	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	1000	**ATG Test Date**	10/10/2024	**Line Tightness Test Date**	11/02/2009	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	10/10/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-450				
Tank Number	14	**Tank Age**	21	**Tank Installed Date**	07/02/2004	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve
Tag Number	4892	**Spill Test Date**	10/10/2024	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	10/10/2024	**Tank/Piping CP Test Date**	11/04/2021	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	10/10/2024	**Line Tightness Test Date**	11/02/2009	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	10/10/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-450				

Facility Summary in Madison County in the City of Sheridan

Location: MCLEOD MERCANTILE 2802043
202 S Main St
Sheridan, MT 59749 Madison

System Facility ID:28-02043

Facility Code: 24575
Last Inspected On: 04/09/2024
Operating Permit Renewal Date: 11/08/2022

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: AM Welles Inc dba McLeod Merc **(406) 685-3372** **Tim@amwelles.com**

Operator Contact: Sandy Flager **sandylouhou@hotmail.com**

Owner/Operator: AM Welles Inc dba McLeod Merc (406) 685-3372 Tim@amwelles.com

Sandy Flager, UST Class A Operator sandylouhou@hotmail.com
Sandy Flager, UST Class A Operator sandylouhou@hotmail.com
Sandy Flager, UST Class B Operator sandylouhou@hotmail.com
Sandy Flager, UST Class B Operator sandylouhou@hotmail.com

Tank Number	09	**Tank Age**	30	**Tank Installed Date**	11/01/1995	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	2950	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	10	**Tank Age**	30	**Tank Installed Date**	11/01/1995	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	2951	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Tank Number	11	**Tank Age**	30	**Tank Installed Date**	11/01/1995	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	2952	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	12	**Tank Age**	30	**Tank Installed Date**	11/01/1995	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	2953	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	13	**Tank Age**	5	**Tank Installed Date**	11/19/2020	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	5999	**Spill Test Date**	04/09/2024	**Piping Installed Date**	11/19/2020	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	04/09/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	Yes
Capacity	12000	**ATG Test Date**	04/09/2024	**Line Tightness Test Date**	11/27/2020	**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	04/09/2024			**ATG Type**					
Tank Number	14	**Tank Age**	5	**Tank Installed Date**	11/19/2020	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	6000	**Spill Test Date**	04/09/2024	**Piping Installed Date**	11/19/2020	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	04/09/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible

Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	04/09/2024	**Line Tightness Test Date**	11/27/2020	**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	04/09/2024			**ATG Type**					
Tank Number	15	**Tank Age**	5	**Tank Installed Date**	11/19/2020	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	6001	**Spill Test Date**	04/09/2024	**Piping Installed Date**	11/19/2020	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	04/09/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	Yes
Capacity	6000	**ATG Test Date**	04/09/2024	**Line Tightness Test Date**	11/27/2020	**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	04/09/2024			**ATG Type**					
Tank Number	16	**Tank Age**	5	**Tank Installed Date**	11/19/2020	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	6002	**Spill Test Date**	04/09/2024	**Piping Installed Date**	11/19/2020	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	04/09/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel, Dyed	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**	04/09/2024	**Line Tightness Test Date**	11/27/2020	**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	04/09/2024			**ATG Type**					

Facility Summary in Madison County in the City of Sheridan

Location: SHERIDAN SINCLAIR
95 Tuke Ln
Sheridan, MT 59749 Madison

System Facility ID:60-15002

Facility Code: 30796
Last Inspected On: 08/04/2022
Operating Permit Renewal Date: 09/09/2025

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	AM Welles Inc dba McLeod Merc	**(406) 685-3372**	**Tim@amwelles.com**
Operator Contact:	Tim Nicholls	**(406) 596-0068**	**dimes-62@hotmail.com**

Owner/Operator: AM Welles Inc dba McLeod Merc (406) 685-3372 Tim@amwelles.com

Tim Nicholls, UST Class A Operator dimes-62@hotmail.com

Tim Nicholls, UST Class B Operator dimes-62@hotmail.com

Tank Number	02	**Tank Age**	20	**Tank Installed Date**	09/15/2005	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve;High Level Alarm
Tag Number	5007	**Spill Test Date**	08/04/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel, Dyed	**PLLD Test Date**	08/04/2022	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	15000	**ATG Test Date**	08/04/2022	**Line Tightness Test Date**	12/09/2019	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	08/04/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	03	**Tank Age**	20	**Tank Installed Date**	09/15/2005	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve;High Level Alarm
Tag Number	5008	**Spill Test Date**	08/11/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel, Dyed	**PLLD Test Date**	08/04/2022	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	08/04/2022	**Line Tightness Test Date**	12/17/2019	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	08/04/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Tank Number	04	**Tank Age**	20	**Tank Installed Date**	09/15/2005	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve;High Level Alarm
Tag Number	5009	**Spill Test Date**	08/11/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	08/04/2022	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	7000	**ATG Test Date**	08/04/2022	**Line Tightness Test Date**	12/17/2019	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	08/04/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	05	**Tank Age**	20	**Tank Installed Date**	09/15/2005	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve;High Level Alarm
Tag Number	5010	**Spill Test Date**	08/04/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	08/04/2022	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	15000	**ATG Test Date**	08/04/2022	**Line Tightness Test Date**	12/11/2019	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	08/04/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	06	**Tank Age**	20	**Tank Installed Date**	09/15/2005	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve;High Level Alarm
Tag Number	5011	**Spill Test Date**	08/04/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	12/26/2022	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	08/04/2022	**Line Tightness Test Date**	12/23/2019	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	08/04/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	01	**Tank Age**	20	**Tank Installed Date**	09/15/2005	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve;High Level Alarm
Tag Number	5044	**Spill Test Date**	08/11/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No

Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	08/04/2022	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	15000	**ATG Test Date**	08/04/2022	**Line Tightness Test Date**	12/05/2019	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	08/04/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Madison County in the City of Twin Bridges

Location: BOS CHEVRON AND TIRE SERVICE
100 S Main St
Twin Bridges, MT 59754 Madison

System Facility ID:28-07478

Facility Code: 24698
Last Inspected On: 10/24/2022
Operating Permit Renewal Date: 11/08/2025

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Bo Mailey	**(406) 684-5611**	**bosservice@gmail.com**

Operator Contact:	Bo Mailey	**(406) 684-5611**	**bosservice@gmail.com**

Owner/Operator: Bo Mailey (406) 684-5611 bosservice@gmail.com

Bo Mailey, UST Class A Operator bosservice@gmail.com

Bo Mailey, UST Class B Operator bosservice@gmail.com

Tank Number	05	**Tank Age**	26	**Tank Installed Date**	01/01/1999	**Tank Material Construction**	Steel Clad	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	3913	**Spill Test Date**	10/24/2022	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Manual Interstitial Monitoring	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	1000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	10/24/2022			**ATG Type**					
Tank Number	06	**Tank Age**	26	**Tank Installed Date**	01/01/1999	**Tank Material Construction**	Steel Clad	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	3914	**Spill Test Date**	10/24/2022	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Manual Interstitial Monitoring	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	1000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	10/24/2022			**ATG Type**					

Facility Summary in Madison County in the City of Twin Bridges

Location: THREE RIVERS QUICK STOP
325 S Main St
Twin Bridges, MT 59754-9740 Madison

System Facility ID:28-10708

Facility Code: 24759
Last Inspected On: 09/23/2024
Operating Permit Renewal Date: 01/19/2028

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Heath Pardieau **(559) 362-5850** **trqsandti@outlook.com**

Operator Contact: Heath Pardieau **(559) 362-5850** **trqsandti@outlook.com**

Owner/Operator: Heath Pardieau (559) 362-5850 trqsandti@outlook.com

Heath Pardieau, UST Class A Operator trqsandti@outlook.com

Heath Pardieau, UST Class B Operator trqsandti@outlook.com

Tank Number	04	**Tank Age**	33	**Tank Installed Date**	10/01/1992	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	1816	**Spill Test Date**	09/23/2024	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Single Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	09/10/2024	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	3000	**ATG Test Date**	09/10/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	09/10/2024			**ATG Type**	Gilbarco/EMC Basic				
Tank Number	05	**Tank Age**	33	**Tank Installed Date**	10/01/1992	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	1817	**Spill Test Date**	09/23/2024	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Single Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	09/10/2024	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	5000	**ATG Test Date**	09/10/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	09/10/2024			**ATG Type**	Gilbarco/EMC Basic				

Facility Summary in Madison County in the City of Virginia City

Location: VILLAGE PUMP AND INFORMATION CENTER
221 E Wallace St
Virginia City, MT 59755-0338 Madison

System Facility ID:28-05399

Facility Code: 24653
Last Inspected On: 09/08/2022
Operating Permit Renewal Date: 01/07/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Montana Heritage Preservation and Development Commission Virginia City	**(406) 843-5655**	**ksteeley@mt.gov**
Operator Contact:	Kate Steeley	**(406) 843-5247**	**ksteeley@mt.gov**

Owner/Operator:	Montana Heritage Preservation and Development Commission Virginia City	(406) 843-5655	ksteeley@mt.gov
	Kate Steeley, UST Class A Operator		ksteeley@mt.gov
	Kate Steeley, UST Class A Operator		ksteeley@mt.gov
	Kate Steeley, UST Class B Global Operator		ksteeley@mt.gov
	Kate Steeley, UST Class B Global Operator		ksteeley@mt.gov

Tank Number	04	**Tank Age**	6	**Tank Installed Date**	02/05/2019	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	5860	**Spill Test Date**	11/13/2024	**Piping Installed Date**	02/05/2019	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	11/10/2021	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	09/10/2024	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	Yes
Capacity	6000	**ATG Test Date**	09/10/2024	**Line Tightness Test Date**	02/11/2019	**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	11/10/2021			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS;Veeder Root/TLS-450PLUS				
Tank Number	05	**Tank Age**	6	**Tank Installed Date**	02/05/2019	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	5861	**Spill Test Date**	11/10/2021	**Piping Installed Date**	02/05/2019	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	11/10/2021	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	09/10/2024	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No

Capacity	6000	**ATG Test Date**	09/10/2024	**Line Tightness Test Date**	02/11/2019	**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	11/10/2021			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS;Veeder Root/TLS-450PLUS				

Facility Summary in McCone County in the City of Circle

Location: CIRCLE CONOCO
901 B Ave
Circle, MT 59215 McCone

System Facility ID:29-03684

Facility Code: 24887
Last Inspected On: 12/14/2023
Operating Permit Renewal Date: 12/14/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Chuck Hawkinson **(307) 389-3445** **chawkinson@outlook.com**

Operator Contact:

Owner/Operator: Chuck Hawkinson (307) 389-3445 chawkinson@outlook.com

Tank Number	05	**Tank Age**	35	**Tank Installed Date**	09/12/1990	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Steel	**Overfill Types**	Flapper Valve
Tag Number	1267	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	None	**AST**	No
Status	**Temporarily Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	12/15/2023	**Primary Tank Leak Detection**	Manual Interstitial Monitoring	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	5000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					

Facility Summary in McCone County in the City of Circle

Location: CIRCLE COUNTRY MARKET LLC
105 10th St
Circle, MT 59215 McCone

System Facility ID:29-00042

Facility Code: 24842
Last Inspected On: 12/09/2024
Operating Permit Renewal Date: 12/09/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Circle Country Market LLC		**circlefoods.graves@gmail.com**
Operator Contact:	Cody Carlsen;Julian Hoffman;Leonard Kuntz;Les Carlsen;Tammy Leeson	**(406) 485-2680;(406) 485-3645;(406) 941-2131**	**circlefoods.graves@gmail.com;circlefoods.leeson@gmail.com;lescarlsen@hotmail.com**

Owner/Operator: Circle Country Market LLC — circlefoods.graves@gmail.com

Cody Carlsen, UST Class A Operator	lescarlsen@hotmail.com
Cody Carlsen, UST Class B Global Operator	lescarlsen@hotmail.com
Cory Hirschfeld, UST Class B Global Operator	
Denny Hogan, UST Class B Global Operator	
Julian Hoffman, UST Class A Operator	circlefoods.graves@gmail.com
Julian Hoffman, UST Class B Global Operator	circlefoods.graves@gmail.com
Julian Hoffman, UST Class B Operator	circlefoods.graves@gmail.com
Leonard Kuntz, UST Class A Operator	
Les Carlsen, UST Class A Operator	lescarlsen@hotmail.com
Les Carlsen, UST Class B Global Operator	lescarlsen@hotmail.com
Tammy Leeson, UST Class A Operator	circlefoods.leeson@gmail.com
Tammy Leeson, UST Class B Global Operator	circlefoods.leeson@gmail.com
Tammy Leeson, UST Class B Operator	circlefoods.leeson@gmail.com

Tank Number	03	**Tank Age**	28	**Tank Installed Date**	10/01/1997	**Tank Material Construction**	Steel Clad	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	618	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	None	**AST**	No
Status	**Temporarily Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	10/26/2015	**Primary Tank Leak Detection**	Manual Interstitial Monitoring	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	04	**Tank Age**	28	**Tank Installed Date**	10/01/1997	**Tank Material Construction**	Steel Clad	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve

Tag Number	619	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	None	**AST**	No
Status	**Temporarily Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	10/26/2015	**Primary Tank Leak Detection**	Manual Interstitial Monitoring	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					

Facility Summary in McCone County in the City of Circle

Location: CIRCLE PUBLIC SCHOOL DIST 1
1105 F Ave
Circle, MT 59215 McCone

System Facility ID:29-00874

Facility Code: 24849
Last Inspected On: 03/12/2025
Operating Permit Renewal Date: 06/04/2028

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	School Dist 1 Circle	**(406) 485-3600**	**rkirkegard@cricleschools.k12.mt.us**
Operator Contact:	Tara Hubing;School Dist 1 Circle	**(406) 974-2464;(406) 485-3600**	**thubing@circleschools.k12.mt.us;rkirkegard@cricleschools.k12.mt.us**

Owner/Operator: School Dist 1 Circle (406) 485-3600 rkirkegard@cricleschools.k12.mt.us

Tara Hubing, UST Class A Operator rkirkegard@cricleschools.k12.mt.us

Tara Hubing, UST Class B Operator rkirkegard@cricleschools.k12.mt.us

Tank Number	S2	**Tank Age**	28	**Tank Installed Date**	08/01/1997	**Tank Material Construction**	Steel Clad	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	1890	**Spill Test Date**	03/12/2025	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	03/12/2025	**Catastrophic L.D. Type 3.0**	Auto Dialer	**Piping Type**	U.S. Suction	**CP Met Types**	Non-corrodible
Product	Heating Oil	**PLLD Test Date**		**Tank/Piping CP Test Date**	04/10/2013	**Primary Tank Leak Detection**	Manual Interstitial Monitoring	**Primary Pipe Leak Detection**	3-Year Line Tightness Test	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	03/12/2025	**Line Tightness Test Date**	03/10/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	03/12/2025			**ATG Type**					

Facility Summary in McCone County in the City of Circle

Location: CIRCLE SINCLAIR
210 A Ave
Circle, MT 59215 McCone

System Facility ID:29-00041

Facility Code: 24841
Last Inspected On: 03/20/2025
Operating Permit Renewal Date: 03/30/2028

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Grant Herden	**(406) 485-2268**	**slimjimgrant@gmail.com**
Operator Contact:	Grant Herden	**(406) 485-2268**	**slimjimgrant@gmail.com**

Owner/Operator: Grant Herden (406) 485-2268 slimjimgrant@gmail.com

Grant Herden, UST Class A Operator slimjimgrant@gmail.com

Grant Herden, UST Class B Operator slimjimgrant@gmail.com

Tank Number	08	**Tank Age**	28	**Tank Installed Date**	10/01/1997	**Tank Material Construction**	Steel Clad	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	612	**Spill Test Date**	03/20/2025	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Manual Interstitial Monitoring	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	03/20/2025			**ATG Type**					
Tank Number	09	**Tank Age**	28	**Tank Installed Date**	10/01/1997	**Tank Material Construction**	Steel Clad	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	613	**Spill Test Date**	03/20/2025	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Manual Interstitial Monitoring	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	2000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	03/20/2025			**ATG Type**					
Tank Number	10	**Tank Age**	28	**Tank Installed Date**	10/01/1997	**Tank Material Construction**	Steel Clad	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	614	**Spill Test Date**	03/20/2025	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No

Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Manual Interstitial Monitoring	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	2000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	03/20/2025			**ATG Type**					
Tank Number	11	**Tank Age**	28	**Tank Installed Date**	10/01/1997	**Tank Material Construction**	Steel Clad	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	615	**Spill Test Date**	03/20/2025	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Manual Interstitial Monitoring	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	03/20/2025			**ATG Type**					
Tank Number	12	**Tank Age**	28	**Tank Installed Date**	10/01/1997	**Tank Material Construction**	Steel Clad	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	616	**Spill Test Date**	03/20/2025	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Manual Interstitial Monitoring	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	03/20/2025			**ATG Type**					
Tank Number	13	**Tank Age**	28	**Tank Installed Date**	10/01/1997	**Tank Material Construction**	Steel Clad	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	617	**Spill Test Date**	03/20/2025	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Manual Interstitial Monitoring	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	2000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	03/20/2025			**ATG Type**					

Facility Summary in McCone County in the City of Circle

Location: FARMERS UNION OIL CO CIRCLE
906 A Ave
Circle, MT 59215 McCone

System Facility ID:29-06376

Facility Code: 24902
Last Inspected On: 10/21/2024
Operating Permit Renewal Date: 03/04/2028

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Farmers Union Oil Co Circle **(406) 485-3475**

Operator Contact: Cory Vorderbruggen;Jeffrey Schaefer;Terry Wahl **(406) 485-3475** **farmersgm@midrivers.com**

Owner/Operator: Farmers Union Oil Co Circle (406) 485-3475

Cory Vorderbruggen, UST Class A Operator	farmersgm@midrivers.com
Cory Vorderbruggen, UST Class A Operator	farmersgm@midrivers.com
Jeffrey Schaefer, UST Class A Operator	farmersgm@midrivers.com
Jeffrey Schaefer, UST Class A Operator	farmersgm@midrivers.com
Jeffrey Schaefer, UST Class B Operator	farmersgm@midrivers.com
Jeffrey Schaefer, UST Class B Operator	farmersgm@midrivers.com
Larry Kwasney, UST Class B Operator	farmers@midrivers.com
Larry Kwasney, UST Class B Operator	farmers@midrivers.com
Terry Wahl, UST Class A Operator	
Terry Wahl, UST Class A Operator	
Terry Wahl, UST Class B Global Operator	
Terry Wahl, UST Class B Global Operator	

Tank Number	S12	**Tank Age**	19	**Tank Installed Date**	10/06/2006	**Tank Material Construction**	Unknown	**Piping Material**	Flexible Plastic	**Overfill Types**	
Tag Number	5108	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	Yes
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Diesel	**PLLD Test Date**	05/01/2025	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	5000	**ATG Test Date**		**Line Tightness Test Date**	09/03/2021	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	S08	**Tank Age**	27	**Tank Installed Date**	11/01/1998	**Tank Material Construction**	Unknown	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	

Tag Number	951	**Spill Test Date**		**Piping Installed Date**	08/16/2006	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	Yes
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Gasoline	**PLLD Test Date**	06/10/2024	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	15000	**ATG Test Date**		**Line Tightness Test Date**	08/21/2021	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	S09	**Tank Age**	27	**Tank Installed Date**	11/01/1998	**Tank Material Construction**	Unknown	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	
Tag Number	952	**Spill Test Date**		**Piping Installed Date**	08/16/2006	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	Yes
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Gasoline	**PLLD Test Date**	06/10/2024	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	15000	**ATG Test Date**		**Line Tightness Test Date**	08/23/2021	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	S10	**Tank Age**	27	**Tank Installed Date**	11/01/1998	**Tank Material Construction**	Unknown	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	
Tag Number	953	**Spill Test Date**		**Piping Installed Date**	08/16/2006	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	Yes
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Diesel	**PLLD Test Date**	06/10/2024	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	15000	**ATG Test Date**		**Line Tightness Test Date**	09/30/2021	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	S11	**Tank Age**	27	**Tank Installed Date**	11/01/1998	**Tank Material Construction**	Unknown	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	
Tag Number	954	**Spill Test Date**		**Piping Installed Date**	08/16/2006	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	Yes
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Diesel	**PLLD Test Date**	06/10/2024	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No

Capacity	15000	**ATG Test Date**		**Line Tightness Test Date**	08/20/2021	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date				**ATG Type**					

Facility Summary in McCone County in the City of Circle

Location: FARMERS UNION OIL C-STORE
200 B Ave
Circle, MT 59215 McCone

System Facility ID:60-15206

Facility Code: 30926
Last Inspected On: 01/02/2025
Operating Permit Renewal Date: 04/09/2028

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Farmers Union Oil C-Store

Operator Contact: Cory Vorderbruggen;Jeffrey Schaefer;Terry Wahl **(406) 485-3475** **farmersgm@midrivers.com**

Owner/Operator: Farmers Union Oil C-Store

Cory Vorderbruggen, UST Class A Operator	farmersgm@midrivers.com
Dharlyne Kirkegard, UST Class B Operator	farmerscstore@midrivers.com
Dorothy Johnson, UST Class B Operator	farmers@midrivers.com
Jeffrey Schaefer, UST Class A Operator	farmersgm@midrivers.com
Jeffrey Schaefer, UST Class B Operator	farmersgm@midrivers.com
Sadie Idland, UST Class B Operator	farmerscstore@midrivers.com
Terry Wahl, UST Class A Operator	
Terry Wahl, UST Class B Global Operator	

Tank Number	02	**Tank Age**	13	**Tank Installed Date**	06/01/2012	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	5356	**Spill Test Date**	10/21/2024	**Piping Installed Date**	10/10/2012	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	10/21/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	06/10/2024	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	15000	**ATG Test Date**	06/10/2024	**Line Tightness Test Date**	10/19/2021	**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	10/21/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350;Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	03	**Tank Age**	13	**Tank Installed Date**	06/01/2012	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	5357	**Spill Test Date**	10/21/2024	**Piping Installed Date**	10/10/2012	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	10/21/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible

Product	Diesel	**PLLD Test Date**	06/10/2024	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	14000	**ATG Test Date**	06/10/2024	**Line Tightness Test Date**	10/19/2021	**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	10/21/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350;Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	04	**Tank Age**	13	**Tank Installed Date**	06/01/2012	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	5358	**Spill Test Date**	10/21/2024	**Piping Installed Date**	10/10/2012	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	10/21/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	06/10/2024	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	14000	**ATG Test Date**	06/10/2024	**Line Tightness Test Date**	10/25/2021	**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	10/21/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350;Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	05	**Tank Age**	13	**Tank Installed Date**	06/01/2012	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	5359	**Spill Test Date**	10/21/2024	**Piping Installed Date**	10/10/2012	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	10/21/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	06/10/2024	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**	06/10/2024	**Line Tightness Test Date**	05/02/2021	**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	10/21/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350;Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	06	**Tank Age**	13	**Tank Installed Date**	06/01/2012	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	5360	**Spill Test Date**	10/21/2024	**Piping Installed Date**	10/10/2012	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	10/21/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible

Product	Gasoline	**PLLD Test Date**	06/10/2024	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**	06/10/2024	**Line Tightness Test Date**	10/11/2021	**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	10/21/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350;Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in McCone County in the City of Circle

Location: KWASNEY LLC
706 B Ave
Circle, MT 59215 McCone

System Facility ID:29-03433

Facility Code: 24879
Last Inspected On: 05/15/2023
Operating Permit Renewal Date: 08/11/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	KWASNEY LLC	**(406) 485-3401**	**kwaz7@midrivers.com**
Operator Contact:	Tamra Englund;KWASNEY LLC	**(406) 485-3401**	**tamra.exxon2@gmail.com;kwaz7@midrivers.com**

Owner/Operator: KWASNEY LLC (406) 485-3401 kwaz7@midrivers.com

Tamra Englund, UST Class A Operator kwaz7@midrivers.com

Tamra Englund, UST Class B Operator kwaz7@midrivers.com

Tank Number	07	**Tank Age**	27	**Tank Installed Date**	11/01/1998	**Tank Material Construction**	Steel Clad	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	3802	**Spill Test Date**	05/15/2023	**Piping Installed Date**	02/14/2013	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	03/11/2020	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	03/11/2020	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**	03/23/2023	**Line Tightness Test Date**	02/03/2020	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date	05/15/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	08	**Tank Age**	27	**Tank Installed Date**	11/01/1998	**Tank Material Construction**	Steel Clad	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	3803	**Spill Test Date**	05/15/2023	**Piping Installed Date**	02/14/2013	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	03/11/2020	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	03/11/2020	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	03/23/2023	**Line Tightness Test Date**	02/05/2020	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date	05/15/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Tank Number	09	**Tank Age**	27	**Tank Installed Date**	11/01/1998	**Tank Material Construction**	Steel Clad	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	3804	**Spill Test Date**	05/15/2023	**Piping Installed Date**	02/14/2013	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	03/11/2020	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**	03/23/2023	**Line Tightness Test Date**	03/04/2020	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date	05/15/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in McCone County in the City of Vida

Location: AGLAND COOP VIDA
MT Hwy 13
Vida, MT 59274 McCone

System Facility ID:56-14042

Facility Code: 30697
Last Inspected On: 02/26/2024
Operating Permit Renewal Date: 08/07/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Agland Coop Wolf Point	**(406) 653-1221**	**dave.williams@agland-coop.com**
Operator Contact:	Aaron Bradley;David Parsley;Waldo Wall	**(406) 653-1510;(406) 853-0492**	**aaron.bradley@chsinc.com;dave.parsley@agland-coop.com**

Owner/Operator: Agland Coop Wolf Point (406) 653-1221 dave.williams@agland-coop.com

Aaron Bradley, UST Class A Operator	aaron.bradley@chsinc.com
Aaron Bradley, UST Class B Operator	aaron.bradley@chsinc.com
Allen Richard, UST Class B Global Operator	allen.richard@agland-coop.com
Allen Richard, UST Class B Operator	allen.richard@agland-coop.com
David Parsley, UST Class A Operator	dave.parsley@agland-coop.com
Michael Pallvoda, UST Class B Operator	fuoilwp@nemont.net
Waldo Wall, UST Class A Operator	
Waldo Wall, UST Class B Operator	
Weston Smith, UST Class B Global Operator	

Tank Number	01	**Tank Age**	24	**Tank Installed Date**	12/01/2001	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	4560	**Spill Test Date**	02/27/2024	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	02/27/2024	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	05/01/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	02/27/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	02	**Tank Age**	24	**Tank Installed Date**	12/01/2001	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	4561	**Spill Test Date**	02/27/2024	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Galvanic

Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	02/27/2024	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	05/01/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	02/27/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	03	**Tank Age**	24	**Tank Installed Date**	12/01/2001	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	4562	**Spill Test Date**	02/27/2024	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	02/27/2024	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	05/01/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	02/27/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Meagher County in the City of White Sulphur Springs

Location: BERG GARAGE INC
11 W Main St
White Sulphur Springs, MT 59645-0000 Meagher

System Facility ID:30-07694

Facility Code: 24982
Last Inspected On: 09/16/2022
Operating Permit Renewal Date: 12/19/2025

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Berg Garage Inc **(406) 547-3514**

Operator Contact: Jay Berg **(406) 547-2150** **cmd10067@mtintouch.net**

Owner/Operator: Berg Garage Inc (406) 547-3514

Jay Berg, UST Class A Operator	cmd10067@mtintouch.net
Jay Berg, UST Class A Operator	cmd10067@mtintouch.net
Jay Berg, UST Class B Operator	cmd10067@mtintouch.net
Jay Berg, UST Class B Operator	cmd10067@mtintouch.net

Tank Number	03	**Tank Age**	35	**Tank Installed Date**	01/01/1990	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	434	**Spill Test Date**	09/06/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	09/06/2022	**Primary Tank Leak Detection**	Manual Tank Gauging	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	500	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	09/06/2022			**ATG Type**					
Tank Number	04	**Tank Age**	35	**Tank Installed Date**	01/01/1990	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	435	**Spill Test Date**	09/06/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	09/06/2022	**Primary Tank Leak Detection**	Manual Tank Gauging	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	500	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	09/06/2022			**ATG Type**					
Tank Number	05	**Tank Age**	35	**Tank Installed Date**	01/01/1990	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve

Tag Number	436	**Spill Test Date**	09/06/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	09/06/2022	**Primary Tank Leak Detection**	Manual Tank Gauging	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	500	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	09/06/2022			**ATG Type**					
Tank Number	06	**Tank Age**	35	**Tank Installed Date**	01/01/1990	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	437	**Spill Test Date**	09/06/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	09/06/2022	**Primary Tank Leak Detection**	Manual Tank Gauging	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	500	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	09/06/2022			**ATG Type**					

Facility Summary in Meagher County in the City of White Sulphur Springs

Location: TOWN PUMP WHITE SULPHUR SPRINGS
309 E Main St
White Sulphur Springs, MT 59645 Meagher

System Facility ID:30-08724

Facility Code: 24989
Last Inspected On: 05/19/2025
Operating Permit Renewal Date: 08/13/2022

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Town Pump Inc White Sulphur Springs;White Sulphur Springs 1 Town Pump LLC **(406) 497-6700** **arnoldo@townpump.com;environmental@townpump.com**

Operator Contact: Trent Biggers **Trentb@townpump.com**

Owner/Operator: Town Pump Inc White Sulphur Springs arnoldo@townpump.com

Owner/Operator: White Sulphur Springs 1 Town Pump LLC arnoldo@townpump.com

Trent Biggers, UST Class A Operator Trentb@townpump.com
Trent Biggers, UST Class A Operator Trentb@townpump.com
Trent Biggers, UST Class B Global Operator Trentb@townpump.com
Trent Biggers, UST Class B Global Operator Trentb@townpump.com

Tank Number	01	**Tank Age**	53	**Tank Installed Date**	05/10/1972	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	2533	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**	08/01/2018	**Tank/Piping CP Test Date**	05/15/2019	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	48000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/EMC Basic				
Tank Number	02	**Tank Age**	53	**Tank Installed Date**	05/10/1972	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	2534	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**	08/01/2018	**Tank/Piping CP Test Date**	05/15/2019	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	24000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No

		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/EMC Basic				
Tank Number	03	**Tank Age**	45	**Tank Installed Date**	05/10/1980	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	2535	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**	08/01/2018	**Tank/Piping CP Test Date**	05/15/2019	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	48000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/EMC Basic				
Tank Number	04	**Tank Age**	36	**Tank Installed Date**	05/10/1989	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	2536	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**	02/06/2018	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**	08/01/2018	**Tank/Piping CP Test Date**	05/15/2019	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	40000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/EMC Basic				
Tank Number	05	**Tank Age**	33	**Tank Installed Date**	10/01/1992	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve;Flapper Valve
Tag Number	2537	**Spill Test Date**	05/19/2021	**Piping Installed Date**	08/16/2019	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	05/19/2021	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	07/14/2022	**Tank/Piping CP Test Date**	02/05/2010	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	07/14/2022	**Line Tightness Test Date**	11/04/2019	**Secondary Tank Leak Detection**	Approved Remote Monitoring	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	No
		Overfill Test Date	05/19/2021			**ATG Type**	Gilbarco-Veeder Root/TLS-450				
Tank Number	07	**Tank Age**	26	**Tank Installed Date**	09/01/1999	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve;Flapper Valve
Tag Number	4119	**Spill Test Date**	05/19/2021	**Piping Installed Date**	08/16/2019	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No

Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	05/19/2021	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel, Dyed	**PLLD Test Date**	07/14/2022	**Tank/Piping CP Test Date**	02/05/2010	**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	07/14/2022	**Line Tightness Test Date**	11/04/2019	**Secondary Tank Leak Detection**	Statistical Inventory Reconciliation	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	No
		Overfill Test Date	05/19/2021			**ATG Type**	Gilbarco-Veeder Root/TLS-450				
Tank Number	08	**Tank Age**	26	**Tank Installed Date**	09/01/1999	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve;Flapper Valve
Tag Number	4120	**Spill Test Date**	05/19/2021	**Piping Installed Date**	08/16/2019	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	05/19/2021	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	07/14/2022	**Tank/Piping CP Test Date**	02/05/2010	**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	5000	**ATG Test Date**	07/14/2022	**Line Tightness Test Date**	11/04/2019	**Secondary Tank Leak Detection**	Statistical Inventory Reconciliation	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	No
		Overfill Test Date	05/19/2021			**ATG Type**	Gilbarco-Veeder Root/TLS-450				
Tank Number	09	**Tank Age**	6	**Tank Installed Date**	08/02/2019	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	5875	**Spill Test Date**	05/19/2021	**Piping Installed Date**	08/02/2019	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	05/19/2021	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	07/14/2022	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	Yes
Capacity	24000	**ATG Test Date**	07/14/2022	**Line Tightness Test Date**	08/16/2019	**Secondary Tank Leak Detection**	Statistical Inventory Reconciliation	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	Yes
		Overfill Test Date	05/19/2021			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Number	10	**Tank Age**	6	**Tank Installed Date**	08/02/2019	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	5876	**Spill Test Date**	05/19/2021	**Piping Installed Date**	08/02/2019	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	05/19/2021	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	07/14/2022	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	Yes

Capacity	6000	**ATG Test Date**	07/14/2022	**Line Tightness Test Date**	08/16/2019	**Secondary Tank Leak Detection**	Statistical Inventory Reconciliation	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	Yes
		Overfill Test Date	05/19/2021			**ATG Type**	Gilbarco-Veeder Root/TLS-450				
Tank Number	11	**Tank Age**	6	**Tank Installed Date**	08/02/2019	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	5877	**Spill Test Date**	05/19/2021	**Piping Installed Date**	08/02/2019	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	05/19/2021	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	07/14/2022	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	07/14/2022	**Line Tightness Test Date**	08/16/2019	**Secondary Tank Leak Detection**	Statistical Inventory Reconciliation	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	Yes
		Overfill Test Date	05/19/2021			**ATG Type**	Gilbarco-Veeder Root/TLS-450				
Tank Number	12	**Tank Age**	6	**Tank Installed Date**	08/02/2019	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	5878	**Spill Test Date**	05/19/2021	**Piping Installed Date**	08/02/2019	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	05/19/2021	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	07/14/2022	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	Yes
Capacity	10000	**ATG Test Date**	07/14/2022	**Line Tightness Test Date**	08/16/2019	**Secondary Tank Leak Detection**	Statistical Inventory Reconciliation	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	Yes
		Overfill Test Date	05/19/2021			**ATG Type**	Gilbarco-Veeder Root/TLS-450				
Tank Number	13	**Tank Age**	6	**Tank Installed Date**	08/02/2019	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	5916	**Spill Test Date**	05/19/2021	**Piping Installed Date**	08/02/2019	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	05/19/2021	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel, Dyed	**PLLD Test Date**	07/14/2022	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**	07/14/2022	**Line Tightness Test Date**	08/16/2019	**Secondary Tank Leak Detection**	Statistical Inventory Reconciliation	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	Yes
		Overfill Test Date	05/19/2021			**ATG Type**					

Facility Summary in Meagher County in the City of White Sulphur Springs

Location: VAN OIL CO 12 W MAIN ST
12 W Main St
White Sulphur Springs, MT 59645 Meagher

System Facility ID:30-00478

Facility Code: 24943
Last Inspected On: 01/25/2022
Operating Permit Renewal Date: 01/25/2025

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Marga Johnson **(406) 547-3636**

Operator Contact:

Tank Number	06	**Tank Age**	34	**Tank Installed Date**	06/06/1991	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	2211	**Spill Test Date**		**Piping Installed Date**	04/16/2007	**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**		**Line Tightness Test Date**	08/17/2015	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**	Veeder Root/TLS-250				
Tank Number	07	**Tank Age**	34	**Tank Installed Date**	06/06/1991	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	2212	**Spill Test Date**		**Piping Installed Date**	04/16/2007	**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**		**Line Tightness Test Date**	08/17/2015	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**	Veeder Root/TLS-250				
Tank Number	08	**Tank Age**	34	**Tank Installed Date**	06/06/1991	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	2213	**Spill Test Date**		**Piping Installed Date**	04/16/2007	**Tank Construction**		**Piping Construction**	None	**AST**	No

Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**		**Line Tightness Test Date**	08/17/2015	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**	Veeder Root/TLS-250				

Facility Summary in Meagher County in the City of White Sulphur Springs

Location: WHITE SULPHUR SPRINGS SCHOOL DIST 8
405 Central Ave S
White Sulphur Springs, MT 59645 Meagher

System Facility ID:30-04720

Facility Code: 24962
Last Inspected On: 10/12/2023
Operating Permit Renewal Date: 12/16/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: School Dist 8 White Sulphur Springs **ksangray@whitesulphur.k12.mt.us**

Operator Contact: John Michaelson;School Dist 8 White Sulphur Springs **jmichaelson@whitesulphur.k12.mt.us;ksangray@whitesulphur.k12.mt.us**

Owner/Operator: School Dist 8 White Sulphur Springs ksangray@whitesulphur.k12.mt.us

John Michaelson, UST Class A Operator ksangray@whitesulphur.k12.mt.us

John Michaelson, UST Class B Operator ksangray@whitesulphur.k12.mt.us

Tank Number	S7	**Tank Age**	27	**Tank Installed Date**	08/01/1998	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	2262	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Auto Dialer	**Piping Type**	U.S. Suction	**CP Met Types**	Non-corrodible
Product	Heating Oil	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	3-Year Line Tightness Test	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	08/06/2024	**Line Tightness Test Date**	07/07/2020	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco/EMC Basic				

Facility Summary in Mineral County in the City of Alberton

Location: REYNCO LLC
415 Railroad Ave
Alberton, MT 59820-9488 Mineral

System Facility ID:56-13785

Facility Code: 30473
Last Inspected On: 01/07/2025
Operating Permit Renewal Date: 04/30/2028

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Reynco LLC	**(406) 218-9940**	**farmeroncall@gmail.com**
Operator Contact:	Bob Westin;Brenda Case;Dave Otto;John Thompson;Will Dukart	**(406) 370-8176;(406) 665-1728;(406) 880-8169**	**brendalea.rmdw@gmail.com;chuck.thompson@chsinc.com;will.dukart@chsinc.com**

Owner/Operator: Reynco LLC (406) 218-9940 farmeroncall@gmail.com

Bob Westin, UST Class A Operator	
Brenda Case, UST Class A Operator	brendalea.rmdw@gmail.com
Brenda Case, UST Class B Global Operator	brendalea.rmdw@gmail.com
Dave Otto, UST Class A Operator	
Dave Otto, UST Class B Global Operator	
John Thompson, UST Class A Operator	chuck.thompson@chsinc.com
John Thompson, UST Class B Global Operator	chuck.thompson@chsinc.com
John Thompson, UST Class B Operator	chuck.thompson@chsinc.com
Mike Dunlon, UST Class B Operator	michael.dunlop@chsinc.com
Will Dukart, UST Class A Operator	will.dukart@chsinc.com
Will Dukart, UST Class B Global Operator	will.dukart@chsinc.com

Tank Number	S1	**Tank Age**	28	**Tank Installed Date**	08/01/1997	**Tank Material Construction**	Bare Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	
Tag Number	3858	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	Yes
Status	**Currently in Use**	**MLLD Test Date**	01/07/2025	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**		**Line Tightness Test Date**	01/07/2025	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	S2	**Tank Age**	28	**Tank Installed Date**	08/01/1997	**Tank Material Construction**	Bare Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	
Tag Number	3859	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	Yes

Status	**Currently in Use**	**MLLD Test Date**	01/07/2025	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**		**Line Tightness Test Date**	01/07/2025	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	S3	**Tank Age**	28	**Tank Installed Date**	08/01/1997	**Tank Material Construction**	Bare Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	
Tag Number	3860	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	Yes
Status	**Currently in Use**	**MLLD Test Date**	01/07/2025	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Diesel, Dyed	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**		**Line Tightness Test Date**	01/07/2025	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	S4	**Tank Age**	28	**Tank Installed Date**	08/01/1997	**Tank Material Construction**	Bare Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	
Tag Number	3861	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	Yes
Status	**Currently in Use**	**MLLD Test Date**	01/07/2025	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**		**Line Tightness Test Date**	01/07/2025	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					

Facility Summary in Mineral County in the City of Haugan

Location: SILVER EXPRESS EXXON
Exit 16 & I-90
Haugan, MT 59842 Mineral

System Facility ID:31-13289

Facility Code: 25141
Last Inspected On: 04/15/2022
Operating Permit Renewal Date: 08/28/2025

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Brooke Lincoln;Silver Dollar Ventures Inc	**(406) 544-5880;(406) 678-4242**	**blincoln@blackfoot.net**
Operator Contact:	Brooke Lincoln	**(406) 544-5880**	**blincoln@blackfoot.net**

Owner/Operator:	Brooke Lincoln	(406) 544-5880	blincoln@blackfoot.net
Owner/Operator:	Silver Dollar Ventures Inc	(406) 544-5880	blincoln@blackfoot.net
	Brooke Lincoln, UST Class A Operator		blincoln@blackfoot.net
	Brooke Lincoln, UST Class A Operator		blincoln@blackfoot.net
	Brooke Lincoln, UST Class B Operator		blincoln@blackfoot.net
	Brooke Lincoln, UST Class B Operator		blincoln@blackfoot.net

Tank Number	01	**Tank Age**	31	**Tank Installed Date**	04/01/1994	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	3161	**Spill Test Date**	04/13/2022	**Piping Installed Date**	06/18/2024	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	04/13/2022	**Sump Tightness Test Date**	05/28/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	04/13/2022	**Line Tightness Test Date**	04/13/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date	04/13/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Number	02	**Tank Age**	31	**Tank Installed Date**	04/01/1994	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	3162	**Spill Test Date**	04/13/2022	**Piping Installed Date**	06/18/2024	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	04/13/2022	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No

Capacity	6000	**ATG Test Date**	04/13/2022	**Line Tightness Test Date**	04/13/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date	04/13/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-450				
Tank Number	03	**Tank Age**	31	**Tank Installed Date**	04/01/1994	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	3163	**Spill Test Date**	04/13/2022	**Piping Installed Date**	06/18/2024	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	04/13/2022	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	04/13/2022	**Line Tightness Test Date**	04/13/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date	04/13/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-450				
Tank Number	04	**Tank Age**	31	**Tank Installed Date**	04/01/1994	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	3164	**Spill Test Date**	04/13/2022	**Piping Installed Date**	06/18/2024	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	04/13/2022	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	04/13/2022	**Line Tightness Test Date**	04/13/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date	04/13/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-450				

Facility Summary in Mineral County in the City of Saint Regis

Location: SAINT REGIS EXXON
6 Old US Hwy 10 E
Saint Regis, MT 59866 Mineral

System Facility ID:31-05827

Facility Code: 25073
Last Inspected On: 05/11/2020
Operating Permit Renewal Date: 05/11/2023

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Lincoln Development Co Inc

Operator Contact: Gary Bullock **glbullock@hotmail.com**

Gary Bullock, UST Class A Operator glbullock@hotmail.com
Gary Bullock, UST Class B Operator glbullock@hotmail.com

Tank Number	01	**Tank Age**	52	**Tank Installed Date**	01/01/1973	**Tank Material Construction**	Bare Steel	**Piping Material**	Steel	**Overfill Types**	Flapper Valve
Tag Number	3630	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	05/09/2019	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing;Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	16000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	02	**Tank Age**	43	**Tank Installed Date**	04/22/1982	**Tank Material Construction**	Bare Steel	**Piping Material**	Steel	**Overfill Types**	Flapper Valve
Tag Number	3631	**Spill Test Date**		**Piping Installed Date**	04/30/2007	**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	05/09/2019	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing;Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	20000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No

		Overfill Test Date				**ATG Type**					
Tank Number	03	**Tank Age**	43	**Tank Installed Date**	04/22/1982	**Tank Material Construction**	Bare Steel	**Piping Material**	Steel	**Overfill Types**	Flapper Valve
Tag Number	3632	**Spill Test Date**		**Piping Installed Date**	04/30/2007	**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	05/09/2019	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing;Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	20000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	04	**Tank Age**	52	**Tank Installed Date**	04/23/1973	**Tank Material Construction**	Bare Steel	**Piping Material**	Steel	**Overfill Types**	Flapper Valve
Tag Number	3633	**Spill Test Date**		**Piping Installed Date**	04/30/2007	**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	05/09/2019	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing;Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					

Facility Summary in Mineral County in the City of Saint Regis

Location: SAINT REGIS TRAVEL CENTER
100 Mullan Rd W
Saint Regis, MT 59866 Mineral

System Facility ID:31-07690

Facility Code: 25085
Last Inspected On: 12/06/2022
Operating Permit Renewal Date: 03/28/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Lindevco Inc **(406) 649-2407**

Operator Contact: Gary Bullock **glbullock@hotmail.com**

Owner/Operator: Lindevco Inc (406) 649-2407

Gary Bullock, UST Class A Operator glbullock@hotmail.com
Gary Bullock, UST Class B Operator glbullock@hotmail.com

Tank Number	02	**Tank Age**	40	**Tank Installed Date**	04/22/1985	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	3813	**Spill Test Date**		**Piping Installed Date**	09/17/2016	**Tank Construction**	Lined Interior/Impressed Current	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	04/15/2016	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**	12/06/2022	**Tank/Piping CP Test Date**	09/08/2022	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	12/06/2022	**Line Tightness Test Date**	04/18/2016	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date	03/01/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	03	**Tank Age**	40	**Tank Installed Date**	04/22/1985	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	3814	**Spill Test Date**		**Piping Installed Date**	09/17/2016	**Tank Construction**	Lined Interior/Impressed Current	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	04/15/2016	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Diesel	**PLLD Test Date**	12/06/2022	**Tank/Piping CP Test Date**	09/08/2022	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	12/06/2022	**Line Tightness Test Date**	04/18/2016	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No

		Overfill Test Date	03/01/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	04	**Tank Age**	40	**Tank Installed Date**	04/22/1985	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	3815	**Spill Test Date**		**Piping Installed Date**	09/17/2016	**Tank Construction**	Lined Interior/Impressed Current	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	04/15/2016	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**	12/06/2022	**Tank/Piping CP Test Date**	09/08/2022	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**	12/06/2022	**Line Tightness Test Date**	04/18/2016	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date	03/01/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Mineral County in the City of Saint Regis

Location: ST REGIS GROCERY AND LIQUOR
85 Old US Hwy 10 E
Saint Regis, MT 59866-9715 Mineral

System Facility ID:31-07503

Facility Code: 25082
Last Inspected On: 05/14/2025
Operating Permit Renewal Date: 09/07/2025

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Hi-Star Properties LLC **histarms3@yahoo.com**

Operator Contact: Janice Hoskins;Robert Buss **(406) 321-1168** **janice.hoskins@stangsfood.com;robertbuss20@gmail.com**

Owner/Operator: Hi-Star Properties LLC histarms3@yahoo.com

Janice Hoskins, UST Class A Operator janice.hoskins@stangsfood.com
Robert Buss, UST Class A Operator robertbuss20@gmail.com
Robert Buss, UST Class B Operator robertbuss20@gmail.com

Tank Number	05	**Tank Age**	26	**Tank Installed Date**	08/01/1999	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve;High Level Alarm
Tag Number	4105	**Spill Test Date**	04/15/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	04/15/2022	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**	04/15/2022	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	06/11/2023			**ATG Type**	Gilbarco/TLS-300				
Tank Number	06	**Tank Age**	26	**Tank Installed Date**	08/01/1999	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve;High Level Alarm
Tag Number	4106	**Spill Test Date**	04/15/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	04/15/2022	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**	04/15/2022	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	06/11/2023			**ATG Type**	Gilbarco/TLS-300				

Tank Number	07	**Tank Age**	26	**Tank Installed Date**	08/01/1999	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve;High Level Alarm
Tag Number	4107	**Spill Test Date**	04/15/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	04/15/2022	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**	04/15/2022	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	06/11/2023			**ATG Type**	Gilbarco/TLS-300				

Facility Summary in Mineral County in the City of Saint Regis

Location: TWO RIVERS STATION
549 MT Hwy 135S, Saint Regis
Saint Regis, MT 59866 Mineral

System Facility ID:00-32490

Facility Code: 32490
Last Inspected On: 01/25/2023
Operating Permit Renewal Date: 04/11/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Jasper and Jasper **(406) 240-1815** **kenjmt@blackfoot.net**

Operator Contact: Cathy Briggs **catherynbriggs@gmail.com**

Owner/Operator: Jasper and Jasper (406) 240-1815 kenjmt@blackfoot.net

Cathy Briggs, UST Class A Operator catherynbriggs@gmail.com

Cathy Briggs, UST Class B Global Operator catherynbriggs@gmail.com

Tank Number	01	**Tank Age**	3	**Tank Installed Date**	05/20/2022	**Tank Material Construction**	Steel Clad	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	6087	**Spill Test Date**	06/02/2022	**Piping Installed Date**	05/20/2022	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	06/02/2022	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	Yes
Capacity	20000	**ATG Test Date**	06/02/2022	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	06/02/2022			**ATG Type**					
Tank Number	02	**Tank Age**	3	**Tank Installed Date**	05/20/2022	**Tank Material Construction**	Steel Clad	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	6088	**Spill Test Date**	06/02/2022	**Piping Installed Date**	05/20/2022	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	06/02/2022	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	20000	**ATG Test Date**	06/02/2022	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	06/02/2022			**ATG Type**					
Tank Number	03	**Tank Age**	3	**Tank Installed Date**	05/20/2022	**Tank Material Construction**	Steel Clad	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve

Tag Number	6089	**Spill Test Date**	06/02/2022	**Piping Installed Date**	05/20/2022	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	06/02/2022	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	Yes
Capacity	15000	**ATG Test Date**	06/02/2022	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	06/02/2022			**ATG Type**					
Tank Number	04	**Tank Age**	3	**Tank Installed Date**	05/20/2022	**Tank Material Construction**	Steel Clad	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	6090	**Spill Test Date**	06/02/2022	**Piping Installed Date**	05/20/2022	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	06/02/2022	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel, Dyed	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	06/02/2022	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	06/02/2022			**ATG Type**					

Facility Summary in Mineral County in the City of Saltese

Location: TAFT SUBSTATION
Randolph Creek Rd
Saltese, MT 59867 Mineral

System Facility ID:31-07747

Facility Code: 25086
Last Inspected On: 07/28/2022
Operating Permit Renewal Date: 08/18/2025

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Bonneville Power Administration Kalispell	**(406) 755-6202**	**aewojtasz@bpa.gov**
Operator Contact:	Jeremy Kerst;Raymond Lawrence	**(406) 210-7805;(541) 288-8175**	**jlkerst@bpa.gov;rtlawrence@bpa.gov**

Owner/Operator: Bonneville Power Administration Kalispell (406) 755-6202 aewojtasz@bpa.gov

Jeremy Kerst, UST Class A Operator	jlkerst@bpa.gov
Jeremy Kerst, UST Class B Operator	jlkerst@bpa.gov
Raymond Lawrence, UST Class A Operator	rtlawrence@bpa.gov
Raymond Lawrence, UST Class B Operator	rtlawrence@bpa.gov

Tank Number	03	**Tank Age**	35	**Tank Installed Date**	10/01/1990	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	478	**Spill Test Date**	07/28/2022	**Piping Installed Date**	04/24/2023	**Tank Construction**	Double-Walled	**Piping Construction**	Secondary Containment Chase	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	07/28/2022	**Catastrophic L.D. Type 3.0**	Continuous Interstitial Monitoring	**Piping Type**	U.S. Suction	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	07/28/2022	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	07/28/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Mineral County in the City of Superior

Location: ENERGY PARTNERS SUPERIOR
211 River St
Superior, MT 59872-9673 Mineral

System Facility ID:31-08916

Facility Code: 25094
Last Inspected On: 04/18/2025
Operating Permit Renewal Date: 04/30/2028

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	ENERGY PARTNERS LLC	**(406) 370-7765**	**teslinger@energypartnerspropane.com**
Operator Contact:	DeWayne O'Brien;ENERGY PARTNERS LLC;Michael Mueller;ENERGY PARTNERS LLC	**(406) 541-6800;(406) 370-7765;(406) 941-6800;(406) 370-7765**	**dobrien@energypartnerspropane.com;teslinger@energypartnerspropane.com;mmueller@energypartnerspropane.com;teslinger@energypartnerspropane.com**
Owner/Operator:	ENERGY PARTNERS LLC	(406) 370-7765	teslinger@energypartnerspropane.com
	DeWayne O'Brien, UST Class A Operator		teslinger@energypartnerspropane.com
	DeWayne O'Brien, UST Class B Global Operator		teslinger@energypartnerspropane.com
	Michael Mueller, UST Class A Operator		teslinger@energypartnerspropane.com
	Michael Mueller, UST Class B Global Operator		teslinger@energypartnerspropane.com

Tank Number	01	**Tank Age**	39	**Tank Installed Date**	05/01/1986	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve
Tag Number	1063	**Spill Test Date**	04/18/2025	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	04/18/2025	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	04/18/2025	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	2000	**ATG Test Date**	04/18/2025	**Line Tightness Test Date**	04/18/2025	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	04/18/2025			**ATG Type**	Gilbarco/EMC Basic				
Tank Number	02	**Tank Age**	39	**Tank Installed Date**	05/01/1986	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve
Tag Number	1064	**Spill Test Date**	04/18/2025	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	04/18/2025	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	04/18/2025	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	2000	**ATG Test Date**	04/18/2025	**Line Tightness Test Date**	04/18/2025	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	04/18/2025			**ATG Type**	Gilbarco/EMC Basic				

Tank Number	03	**Tank Age**	39	**Tank Installed Date**	05/01/1986	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve
Tag Number	1065	**Spill Test Date**	04/18/2025	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	04/18/2025	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	04/18/2025	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	2000	**ATG Test Date**	04/18/2025	**Line Tightness Test Date**	04/18/2025	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	04/18/2025			**ATG Type**	Gilbarco/EMC Basic				

Facility Summary in Mineral County in the City of Superior

Location: MINERAL COUNTY COURTHOUSE UST
300 River St
Superior, MT 59872 Mineral

System Facility ID:31-02302

Facility Code: 25033
Last Inspected On: 05/28/2023
Operating Permit Renewal Date: 05/28/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Mineral County Health Dept **healthinfo@co.mineral.mt.us**

Operator Contact: Norman Naef

Owner/Operator: Mineral County Health Dept healthinfo@co.mineral.mt.us

Norman Naef, UST Class A Operator

Norman Naef, UST Class B Global Operator

Tank Number	S2	**Tank Age**	31	**Tank Installed Date**	05/01/1994	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	4450	**Spill Test Date**	05/26/2023	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	05/26/2023	**Catastrophic L.D. Type 3.0**	Auto Dialer	**Piping Type**	U.S. Suction	**CP Met Types**	Galvanic
Product	Heating Oil	**PLLD Test Date**		**Tank/Piping CP Test Date**	05/26/2023	**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	5000	**ATG Test Date**	05/26/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	07/22/2024			**ATG Type**	Gilbarco-Veeder Root/ILS-350				

Facility Summary in Mineral County in the City of Superior

Location: S AND S FOODS
205 4th Ave E
Superior, MT 59872 Mineral

System Facility ID:31-12870

Facility Code: 25138
Last Inspected On: 06/21/2022
Operating Permit Renewal Date: 09/25/2025

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	D and T Properties LLC	**(406) 822-3342**	**sandsfoods.llc@gmail.com**
Operator Contact:	Dale Bullock;Gary Bullock	**(406) 822-3342**	**glbullock@hotmail.com;sandsfoods.llc@gmail.com**

Owner/Operator:	D and T Properties LLC	(406) 822-3342	sandsfoods.llc@gmail.com
	Dale Bullock, UST Class A Operator		sandsfoods.llc@gmail.com
	Dale Bullock, UST Class A Operator		sandsfoods.llc@gmail.com
	Dale Bullock, UST Class B Operator		sandsfoods.llc@gmail.com
	Dale Bullock, UST Class B Operator		sandsfoods.llc@gmail.com
	Gary Bullock, UST Class A Operator		glbullock@hotmail.com

Tank Number	01	**Tank Age**	33	**Tank Installed Date**	10/01/1992	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve;High Level Alarm
Tag Number	1968	**Spill Test Date**	06/21/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	06/21/2022	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	06/21/2022	**Line Tightness Test Date**	06/21/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	09/03/2022			**ATG Type**	Veeder Root/TLS-350				
Tank Number	02	**Tank Age**	33	**Tank Installed Date**	10/01/1992	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve;High Level Alarm
Tag Number	1969	**Spill Test Date**	09/03/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	06/21/2022	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	06/21/2022	**Line Tightness Test Date**	06/21/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	09/03/2022			**ATG Type**	Veeder Root/TLS-350				

Tank Number	03	**Tank Age**	33	**Tank Installed Date**	10/01/1992	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve;High Level Alarm
Tag Number	1970	**Spill Test Date**	06/21/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	06/21/2022	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**	06/21/2022	**Line Tightness Test Date**	06/21/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	09/03/2022			**ATG Type**	Veeder Root/TLS-350				
Tank Number	04	**Tank Age**	33	**Tank Installed Date**	10/01/1992	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve;High Level Alarm
Tag Number	1971	**Spill Test Date**	06/21/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	06/21/2022	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	3000	**ATG Test Date**	06/21/2022	**Line Tightness Test Date**	06/21/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	09/03/2022			**ATG Type**	Veeder Root/TLS-350				

Facility Summary in Mineral County in the City of Superior

Location: SUPERIOR DURANGOS LLC
204 4th Ave E
Superior, MT 59872 Mineral

System Facility ID:31-07433

Facility Code: 25081
Last Inspected On: 04/06/2024
Operating Permit Renewal Date: 04/26/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Ryan Gutierrez;202 Superior LLC	**(786) 314-1427;(786) 314-1427**	**ryrygutierrez@gmail.com;ryrygutierrez@gmail.com**
Operator Contact:	Loretta Dana	**(406) 214-0993**	**ldana11@outlook.com**

Owner/Operator: Ryan Gutierrez,202 Superior LLC (786) 314-1427 ryrygutierrez@gmail.com
Loretta Dana, UST Class A Operator ldana11@outlook.com
Loretta Dana, UST Class B Operator ldana11@outlook.com

Tank Number	01	**Tank Age**	41	**Tank Installed Date**	04/23/1984	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Steel	**Overfill Types**	Positive Shutoff
Tag Number	3816	**Spill Test Date**	04/06/2024	**Piping Installed Date**		**Tank Construction**	Lined Interior/Impressed Current	**Piping Construction**	Single Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	04/06/2024	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	04/22/2021	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**		**Line Tightness Test Date**	04/06/2024	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	04/06/2024			**ATG Type**					
Tank Number	02	**Tank Age**	41	**Tank Installed Date**	04/23/1984	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Steel	**Overfill Types**	Positive Shutoff
Tag Number	3817	**Spill Test Date**	04/06/2024	**Piping Installed Date**		**Tank Construction**	Lined Interior/Impressed Current	**Piping Construction**	Single Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	04/06/2024	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	04/06/2024	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**		**Line Tightness Test Date**	04/06/2024	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	04/06/2024			**ATG Type**					

Facility Summary in Mineral County in the City of Superior

Location: TOWN PUMP INC SUPERIOR
3961 Diamond Match Rd
Superior, MT 59872-9407 Mineral

System Facility ID:31-08719

Facility Code: 25093
Last Inspected On: 02/16/2023
Operating Permit Renewal Date: 10/01/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Superior 1 Town Pump LLC	**(406) 497-6700**	**environmental@townpump.com**
Operator Contact:	Trent Biggers		**Trentb@townpump.com**

Owner/Operator:	Superior 1 Town Pump LLC	(406) 497-6700	environmental@townpump.com
	Trent Biggers, UST Class A Operator		Trentb@townpump.com
	Trent Biggers, UST Class A Operator		Trentb@townpump.com
	Trent Biggers, UST Class B Global Operator		Trentb@townpump.com
	Trent Biggers, UST Class B Global Operator		Trentb@townpump.com

Tank Number	01	**Tank Age**	55	**Tank Installed Date**	01/22/1970	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	2538	**Spill Test Date**	08/08/2022	**Piping Installed Date**	04/22/2011	**Tank Construction**	Lined Interior/Impressed Current	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	03/07/2022	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	08/08/2022	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	02/16/2023	**Line Tightness Test Date**	03/08/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	No
		Overfill Test Date	08/08/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350				
Tank Number	02	**Tank Age**	55	**Tank Installed Date**	01/22/1970	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	2539	**Spill Test Date**	08/08/2022	**Piping Installed Date**	04/22/2011	**Tank Construction**	Lined Interior/Impressed Current	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	02/16/2023	**Sump Tightness Test Date**	05/18/2021	**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Diesel	**PLLD Test Date**	05/18/2021	**Tank/Piping CP Test Date**	08/08/2022	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**	02/16/2023	**Line Tightness Test Date**	03/08/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	No

		Overfill Test Date	08/08/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350				
Tank Number	03	**Tank Age**	39	**Tank Installed Date**	01/01/1986	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	2540	**Spill Test Date**	08/08/2022	**Piping Installed Date**	04/22/2011	**Tank Construction**	Lined Interior/Impressed Current	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	05/18/2021	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Diesel	**PLLD Test Date**	05/18/2021	**Tank/Piping CP Test Date**	08/08/2022	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	02/16/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	No
		Overfill Test Date	08/08/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350				
Tank Number	04	**Tank Age**	53	**Tank Installed Date**	01/01/1972	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve
Tag Number	2541	**Spill Test Date**	08/08/2022	**Piping Installed Date**	04/22/2011	**Tank Construction**	Lined Interior/Impressed Current	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	02/16/2023	**Sump Tightness Test Date**	05/18/2021	**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**	05/18/2021	**Tank/Piping CP Test Date**	08/08/2022	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	02/16/2023	**Line Tightness Test Date**	03/08/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	No
		Overfill Test Date	08/08/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350				
Tank Number	06	**Tank Age**	36	**Tank Installed Date**	01/01/1989	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve
Tag Number	2543	**Spill Test Date**	08/08/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	05/18/2021	**Tank/Piping CP Test Date**	02/20/2010	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	02/16/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	08/08/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350				
Tank Number	05	**Tank Age**	44	**Tank Installed Date**	01/01/1981	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve

Tag Number	4840	**Spill Test Date**	05/18/2024	**Piping Installed Date**		**Tank Construction**	Lined Interior/Impressed Current	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Diesel	**PLLD Test Date**	05/18/2021	**Tank/Piping CP Test Date**	08/08/2022	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	02/16/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	08/08/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350				
Tank Number	07	**Tank Age**	36	**Tank Installed Date**	01/01/1989	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve
Tag Number	4841	**Spill Test Date**	08/08/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	05/18/2021	**Tank/Piping CP Test Date**	02/20/2010	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	02/16/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	08/08/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350				
Tank Number	08	**Tank Age**	22	**Tank Installed Date**	06/09/2003	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve
Tag Number	4842	**Spill Test Date**	08/08/2022	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	05/05/2020	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	05/18/2021	**Tank/Piping CP Test Date**	02/20/2010	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	02/16/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	08/08/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350				
Tank Number	09	**Tank Age**	22	**Tank Installed Date**	06/09/2003	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve
Tag Number	4843	**Spill Test Date**	10/26/2022	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	05/05/2020	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible

Product	Diesel	**PLLD Test Date**	05/18/2021	**Tank/Piping CP Test Date**	02/20/2010	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	3000	**ATG Test Date**	02/16/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	08/08/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350				
Tank Number	10	**Tank Age**	12	**Tank Installed Date**	08/01/2013	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	
Tag Number	5432	**Spill Test Date**		**Piping Installed Date**	07/22/2013	**Tank Construction**	Double-Walled	**Piping Construction**	None	**AST**	No
Status	**Other**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Continuous Interstitial Monitoring	**Piping Type**	Pressurized	**CP Met Types**	
Product	DEF (Not Regulated)	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Approved Remote Monitoring;Continuous Interstitial Monitoring;Deferred	**Primary Pipe Leak Detection**	Approved Remote Monitoring;Continuous Interstitial Monitoring;Deferred	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Not Listed	**Energy Act**	No
		Overfill Test Date				**ATG Type**					

Facility Summary in Missoula County in the City of Bonner

Location: POTOMAC BAR AND COUNTRY STORE
29344 MT Hwy 200 E
Bonner, MT 59823-9526 Missoula

System Facility ID:32-12400

Facility Code: 25677
Last Inspected On: 03/04/2023
Operating Permit Renewal Date: 04/19/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Kenney Brown;Potomac Bar and Country Store, Inc;Potomac Bar and Country Store, Inc	**(406) 240-3863;(406) 240-3863;(406) 240-3863**	**kennybrown@blackfoot.net;kennybrown@blackfoot.net;kennybrown@blackfoot.net**
Operator Contact:	Christine Yednick		**potomacbar@outlook.com**

Owner/Operator:	Kenney Brown,Potomac Bar and Country Store, Inc	(406) 240-3863	kennybrown@blackfoot.net
Owner/Operator:	Potomac Bar and Country Store, Inc	(406) 240-3863	kennybrown@blackfoot.net
	Christine Yednick, UST Class A Operator		potomacbar@outlook.com
	Christine Yednick, UST Class B Operator		potomacbar@outlook.com

Tank Number	01	**Tank Age**	34	**Tank Installed Date**	05/28/1991	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve
Tag Number	3488	**Spill Test Date**	06/10/2020	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	06/09/2020	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**	03/04/2023	**Line Tightness Test Date**	11/06/2019	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	06/10/2020			**ATG Type**	Gilbarco/EMC Basic				
Tank Number	02	**Tank Age**	34	**Tank Installed Date**	05/28/1991	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve
Tag Number	3489	**Spill Test Date**	06/10/2020	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	06/09/2020	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	03/04/2023	**Line Tightness Test Date**	11/06/2019	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	06/10/2020			**ATG Type**	Gilbarco/EMC Basic				

Tank Number	03	**Tank Age**	34	**Tank Installed Date**	05/28/1991	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve
Tag Number	3490	**Spill Test Date**	06/10/2020	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	06/09/2020	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	03/04/2023	**Line Tightness Test Date**	11/06/2019	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	06/10/2020			**ATG Type**	Gilbarco/EMC Basic				
Tank Number	04	**Tank Age**	34	**Tank Installed Date**	05/28/1991	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve;Flapper Valve
Tag Number	3491	**Spill Test Date**	06/10/2020	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	06/09/2020	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	3000	**ATG Test Date**		**Line Tightness Test Date**	10/20/2010	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	06/10/2020			**ATG Type**	Gilbarco/EMC Basic				

Facility Summary in Missoula County in the City of Clinton

Location: BEARMOUTH EXPRESS
16595 US Hwy 10 E
Clinton, MT 59825-9678 Missoula

System Facility ID:32-01572

Facility Code: 25223
Last Inspected On: 07/20/2022
Operating Permit Renewal Date: 11/12/2025

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Gene Tripp **(406) 825-4000**

Operator Contact: Bryan Tripp;Jeff Tripp **(406) 825-4000** **bearmouth66@blackfoot.net;bryan.tripp44@gmail.com**

Owner/Operator: Gene Tripp (406) 825-4000

Bryan Tripp, UST Class A Operator bryan.tripp44@gmail.com
Bryan Tripp, UST Class B Operator bryan.tripp44@gmail.com
Jeff Tripp, UST Class A Operator bearmouth66@blackfoot.net
Jeff Tripp, UST Class B Operator bearmouth66@blackfoot.net

Tank Number	01	**Tank Age**	46	**Tank Installed Date**	04/29/1979	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Steel	**Overfill Types**	Flapper Valve
Tag Number	1205	**Spill Test Date**	07/20/2022	**Piping Installed Date**		**Tank Construction**	Lined Interior/Impressed Current	**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Impressed Current
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	07/20/2022	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	07/20/2022			**ATG Type**					

Facility Summary in Missoula County in the City of Clinton

Location: CLINTON MARKET
20500 Hwy 10 E
Clinton, MT 59825 Missoula

System Facility ID:56-14040

Facility Code: 30695
Last Inspected On: 11/19/2024
Operating Permit Renewal Date: 04/09/2028

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	RR Investments of Montana	**(406) 546-4940**	**roy.handley6543@gmail.com**
Operator Contact:	Roy Handley	**(406) 546-4940**	**roy.handley6543@gmail.com**

Owner/Operator: RR Investments of Montana (406) 546-4940 roy.handley6543@gmail.com

Roy Handley, UST Class A Operator roy.handley6543@gmail.com

Roy Handley, UST Class B Global Operator roy.handley6543@gmail.com

Tank Number	01	**Tank Age**	23	**Tank Installed Date**	05/16/2002	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	4651	**Spill Test Date**	05/17/2024	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	05/17/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Safe Suction	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	11/19/2024	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	11/19/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date	05/17/2024			**ATG Type**	Gilbarco/TLS-350				
Tank Number	02	**Tank Age**	23	**Tank Installed Date**	05/16/2002	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	4652	**Spill Test Date**	05/17/2024	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	05/17/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	11/19/2024	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	11/19/2024	**Line Tightness Test Date**	02/26/2019	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	05/17/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350				
Tank Number	03	**Tank Age**	23	**Tank Installed Date**	05/16/2002	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve

Tag Number	4653	**Spill Test Date**	05/17/2024	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	05/17/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	11/19/2024	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	5000	**ATG Test Date**	11/19/2024	**Line Tightness Test Date**	02/28/2019	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	05/17/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350				
Tank Number	04	**Tank Age**	16	**Tank Installed Date**	10/29/2009	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	5223	**Spill Test Date**	05/17/2024	**Piping Installed Date**	10/14/2009	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	05/17/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	11/19/2024	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**	11/19/2024	**Line Tightness Test Date**	02/26/2019	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	05/17/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350				
Tank Number	05	**Tank Age**	7	**Tank Installed Date**	08/28/2018	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	5851	**Spill Test Date**	05/17/2024	**Piping Installed Date**	08/28/2018	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	05/17/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	11/19/2024	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	Yes
Capacity	6000	**ATG Test Date**	11/19/2024	**Line Tightness Test Date**	02/26/2019	**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	05/17/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Missoula County in the City of Clinton

Location: ROCK CREEK LODGE
7 Rock Creek Rd
Clinton, MT 59825 Missoula

System Facility ID:32-11093

Facility Code: 25616
Last Inspected On: 01/05/2024
Operating Permit Renewal Date: 01/08/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Nicholas Caras;SEVEN ROCK LLC **(406) 203-4467;(406) 203-4467** **nickcaras@gmail.com;sjw@cararealestate.com**

Operator Contact:

Owner/Operator: Nicholas Caras,SEVEN ROCK LLC (406) 203-4467 nickcaras@gmail.com

Tank Number	03	**Tank Age**	31	**Tank Installed Date**	05/01/1994	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	4572	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Single Walled	**AST**	No
Status	**Temporarily Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.1;Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	5000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**	Veeder Root/TLS-300				
Tank Number	04	**Tank Age**	31	**Tank Installed Date**	05/01/1994	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	4573	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Temporarily Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	5000	**ATG Test Date**		**Line Tightness Test Date**	09/20/2017	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**	Veeder Root/TLS-300				

Facility Summary in Missoula County in the City of Condon

Location: MISSION MOUNTAINS MERCANTILE
7217 MT Hwy 83
Condon, MT 59826 Missoula

System Facility ID:32-01619

Facility Code: 25226
Last Inspected On: 04/12/2023
Operating Permit Renewal Date: 06/10/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Leonard Kobylenski	**(406) 754-2387**	**len@swanvalley.com**

Operator Contact:	Leonard Kobylenski	**(406) 754-2387**	**len@swanvalley.com**

Owner/Operator:	Len Kobylenski	(406) 754-2387	len@swanvalley.com
	Len Kobylenski, UST Class A Operator		len@swanvalley.com
	Len Kobylenski, UST Class A Operator		len@swanvalley.com
	Len Kobylenski, UST Class B Operator		len@swanvalley.com
	Len Kobylenski, UST Class B Operator		len@swanvalley.com

Tank Number	04	**Tank Age**	33	**Tank Installed Date**	05/20/1992	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Steel	**Overfill Types**	High Level Alarm
Tag Number	1495	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	04/12/2023	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	04/12/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**	04/12/2023	**Line Tightness Test Date**	04/12/2023	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	04/12/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	05	**Tank Age**	33	**Tank Installed Date**	05/20/1992	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Steel	**Overfill Types**	High Level Alarm
Tag Number	1496	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	04/12/2023	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	04/12/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	04/12/2023	**Line Tightness Test Date**	04/12/2023	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	04/12/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Tank Number	06	**Tank Age**	33	**Tank Installed Date**	05/20/1992	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Steel	**Overfill Types**	High Level Alarm
Tag Number	1497	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	04/12/2023	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	04/12/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	04/12/2023	**Line Tightness Test Date**	04/12/2023	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	04/12/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Missoula County in the City of Frenchtown

Location: BRONCS GROCERIES INC
16640 Beckwith St
Frenchtown, MT 59834-9747 Missoula

System Facility ID:32-05767

Facility Code: 25384
Last Inspected On: 11/28/2023
Operating Permit Renewal Date: 03/03/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Jeremy Louvar **(406) 546-3656** **jeremylouvar@yahoo.com**

Operator Contact:

Owner/Operator: Jeremy Louvar (406) 546-3656 jeremylouvar@yahoo.com

Jeremy Louvar, UST Class B Operator jeremylouvar@yahoo.com

Tank Number	04	**Tank Age**	27	**Tank Installed Date**	05/01/1998	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve;High Level Alarm
Tag Number	2702	**Spill Test Date**	05/30/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	05/06/2024	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	05/06/2024	**Line Tightness Test Date**	05/06/2024	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	05/06/2024			**ATG Type**	Gilbarco/EMC Basic				
Tank Number	05	**Tank Age**	27	**Tank Installed Date**	05/01/1998	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve;High Level Alarm
Tag Number	2703	**Spill Test Date**	05/30/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	05/06/2024	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	05/06/2024	**Line Tightness Test Date**	05/06/2024	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	05/06/2024			**ATG Type**	Gilbarco/EMC Basic				

Facility Summary in Missoula County in the City of Frenchtown

Location: FRENCHIES
16875 Beckwith St
Frenchtown, MT 59834-9646 Missoula

System Facility ID:32-11177

Facility Code: 25623
Last Inspected On: 05/13/2025
Operating Permit Renewal Date: 11/01/2025

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Tabish Brothers Distributors Inc	**(406) 543-7621**	**lss@gwpetrol.com**
Operator Contact:	Alivia Moseman;Joe Heuchert;Karly Shafer	**(406) 396-2206**	**amoseman19@gmail.com;dahoyk@yahoo.com;karly@gwpetrol.com**

Owner/Operator: Tabish Brothers Distributors Inc (406) 543-7621 lss@gwpetrol.com

Alivia Moseman, UST Class A Operator	amoseman19@gmail.com
Alivia Moseman, UST Class B Global Operator	amoseman19@gmail.com
Joe Heuchert, UST Class A Operator	dahoyk@yahoo.com
Karly Shafer, UST Class A Operator	karly@gwpetrol.com
Karly Shafer, UST Class B Global Operator	karly@gwpetrol.com

Tank Number	05	**Tank Age**	35	**Tank Installed Date**	06/25/1990	**Tank Material Construction**	Steel Clad	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	4372	**Spill Test Date**	11/09/2023	**Piping Installed Date**	11/20/2023	**Tank Construction**		**Piping Construction**	Single Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	05/18/2022	**Sump Tightness Test Date**	11/13/2023	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	11/09/2023	**Line Tightness Test Date**	12/30/2023	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date	11/09/2023			**ATG Type**	Veeder Root/TLS-450PLUS				
Tank Number	06	**Tank Age**	35	**Tank Installed Date**	06/25/1990	**Tank Material Construction**	Steel Clad	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	4373	**Spill Test Date**	11/09/2023	**Piping Installed Date**	11/20/2023	**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	05/18/2022	**Sump Tightness Test Date**	11/13/2023	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	11/09/2023	**Line Tightness Test Date**	12/30/2023	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No

		Overfill Test Date	11/09/2023			**ATG Type**	Veeder Root/TLS-450PLUS				
Tank Number	07	**Tank Age**	35	**Tank Installed Date**	06/25/1990	**Tank Material Construction**	Steel Clad	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	4374	**Spill Test Date**	11/09/2023	**Piping Installed Date**	11/20/2023	**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	05/18/2022	**Sump Tightness Test Date**	11/13/2023	**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**	11/09/2023	**Line Tightness Test Date**	12/30/2023	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	05/18/2022			**ATG Type**	Veeder Root/TLS-450PLUS				
Tank Number	08	**Tank Age**	35	**Tank Installed Date**	06/25/1990	**Tank Material Construction**	Steel Clad	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	4375	**Spill Test Date**	11/09/2023	**Piping Installed Date**	11/20/2023	**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	05/18/2022	**Sump Tightness Test Date**	11/13/2023	**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel, Dyed	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**	11/09/2023	**Line Tightness Test Date**	12/30/2023	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	05/18/2022			**ATG Type**	Veeder Root/TLS-450PLUS				
Tank Number	09	**Tank Age**	2	**Tank Installed Date**	11/16/2023	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	6209	**Spill Test Date**	11/09/2023	**Piping Installed Date**	11/20/2023	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	11/13/2023	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	Yes
Capacity	12000	**ATG Test Date**	11/09/2023	**Line Tightness Test Date**	12/30/2023	**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	11/09/2023			**ATG Type**					

Facility Summary in Missoula County in the City of Greenough

Location: CLEARWATER STOP N GO
44676 MT Hwy 200 E
Greenough, MT 59823-9557 Missoula

System Facility ID:32-07114

Facility Code: 25422
Last Inspected On: 03/27/2025
Operating Permit Renewal Date: 06/24/2028

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	The Cow Group	**(406) 396-8431**	**jjross9185@msn.com**
Operator Contact:	Jeff Stavish;Sherri Housley	**(406) 244-5598**	**clearwaterstopngo@gmail.com;jjross9185@msn.com**

Owner/Operator: The Cow Group (406) 396-8431 jjross9185@msn.com

Jeff Stavish, UST Class A Operator clearwaterstopngo@gmail.com
Jeff Stavish, UST Class B Global Operator clearwaterstopngo@gmail.com
Sherri Housley, UST Class A Operator jjross9185@msn.com
Sherri Housley, UST Class B Operator jjross9185@msn.com

Tank Number	04	**Tank Age**	26	**Tank Installed Date**	04/01/1999	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	4474	**Spill Test Date**	03/28/2024	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	03/27/2025	**Sump Tightness Test Date**	08/12/2022	**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	03/27/2025	**Line Tightness Test Date**	03/27/2025	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	03/28/2024			**ATG Type**	Gilbarco/EMC Basic				
Tank Number	05	**Tank Age**	26	**Tank Installed Date**	04/01/1999	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	4475	**Spill Test Date**	03/28/2024	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	03/27/2025	**Sump Tightness Test Date**	08/12/2022	**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**	03/27/2025	**Line Tightness Test Date**	03/27/2025	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	03/28/2024			**ATG Type**	Gilbarco/EMC Basic				

Tank Number	06	**Tank Age**	26	**Tank Installed Date**	04/01/1999	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	4476	**Spill Test Date**	03/27/2024	**Piping Installed Date**	03/19/2018	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	03/27/2025	**Sump Tightness Test Date**	08/12/2022	**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	03/27/2025	**Line Tightness Test Date**	03/27/2025	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	MLLD Line Tightness Testing	**Energy Act**	No
		Overfill Test Date	03/27/2024			**ATG Type**	Gilbarco/EMC Basic				

Facility Summary in Missoula County in the City of Lolo

Location: LOLO SUPERSTOP
12011 US Hwy 93 S
Lolo, MT 59847-9666 Missoula

System Facility ID:56-13795

Facility Code: 30482
Last Inspected On: 06/30/2022
Operating Permit Renewal Date: 10/03/2025

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Tabish Brothers Distributors Inc	**(406) 543-7621**	**lss@gwpetrol.com**
Operator Contact:	Bri Mader;Karly Shafer	**(406) 396-2206**	**karly@gwpetrol.com;knotts.brianna@yahoo.com**

Owner/Operator: Tabish Brothers Distributors Inc (406) 543-7621 lss@gwpetrol.com

Bri Mader, UST Class A Operator	knotts.brianna@yahoo.com
Bri Mader, UST Class B Operator	knotts.brianna@yahoo.com
Karly Shafer, UST Class A Operator	karly@gwpetrol.com
Karly Shafer, UST Class B Global Operator	karly@gwpetrol.com

Tank Number	05	**Tank Age**	27	**Tank Installed Date**	01/15/1998	**Tank Material Construction**	Steel Clad	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	2086	**Spill Test Date**	06/30/2022	**Piping Installed Date**	12/01/2016	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	06/30/2022	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	06/15/2022	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	06/15/2022	**Line Tightness Test Date**	04/27/2019	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date	02/01/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	06	**Tank Age**	27	**Tank Installed Date**	01/15/1998	**Tank Material Construction**	Steel Clad	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	2087	**Spill Test Date**	06/30/2022	**Piping Installed Date**	12/01/2016	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	06/30/2022	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	06/15/2022	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	06/15/2022	**Line Tightness Test Date**	05/01/2019	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No

		Overfill Test Date	02/01/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	07	**Tank Age**	27	**Tank Installed Date**	01/15/1998	**Tank Material Construction**	Steel Clad	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	2088	**Spill Test Date**	06/30/2022	**Piping Installed Date**	12/01/2016	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	06/30/2022	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel, Dyed	**PLLD Test Date**	06/15/2022	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	06/15/2022	**Line Tightness Test Date**	05/07/2019	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date	02/01/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	08	**Tank Age**	27	**Tank Installed Date**	01/15/1998	**Tank Material Construction**	Steel Clad	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	2089	**Spill Test Date**	06/30/2022	**Piping Installed Date**	12/01/2016	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	06/30/2022	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	06/15/2022	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	06/15/2022	**Line Tightness Test Date**	05/07/2019	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date	02/01/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	09	**Tank Age**	27	**Tank Installed Date**	01/15/1998	**Tank Material Construction**	Steel Clad	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	2090	**Spill Test Date**	06/30/2022	**Piping Installed Date**	12/01/2016	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	06/30/2022	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	06/15/2022	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	06/15/2022	**Line Tightness Test Date**	05/01/2019	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date	02/01/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Missoula County in the City of Lolo

Location: TOWN PUMP INC LOLO 1
10955 US Hwy 93 S
Lolo, MT 59847 Missoula

System Facility ID:32-09414

Facility Code: 25493
Last Inspected On: 03/31/2023
Operating Permit Renewal Date: 11/01/2024

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Lolo 1 Town Pump LLC	**(406) 497-6700**	**environmental@townpump.com**
Operator Contact:	Trent Biggers		**Trentb@townpump.com**

Owner/Operator:	Lolo 1 Town Pump LLC	(406) 497-6700	environmental@townpump.com
	Trent Biggers, UST Class A Operator		Trentb@townpump.com
	Trent Biggers, UST Class A Operator		Trentb@townpump.com
	Trent Biggers, UST Class B Global Operator		Trentb@townpump.com
	Trent Biggers, UST Class B Global Operator		Trentb@townpump.com

Tank Number	01	**Tank Age**	38	**Tank Installed Date**	07/01/1987	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	2555	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	12/06/2018	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	Yes
Capacity	24000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	02	**Tank Age**	38	**Tank Installed Date**	07/01/1987	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	2556	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	12/06/2018	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	24000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					

Tank Number	03	**Tank Age**	38	**Tank Installed Date**	07/01/1987	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	2557	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	12/06/2018	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	24000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	04	**Tank Age**	38	**Tank Installed Date**	07/01/1987	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	2558	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	12/06/2018	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	24000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	05	**Tank Age**	4	**Tank Installed Date**	04/20/2021	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	6029	**Spill Test Date**	07/19/2022	**Piping Installed Date**	04/20/2021	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	07/19/2022	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	03/24/2023	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	Yes
Capacity	20000	**ATG Test Date**	03/24/2023	**Line Tightness Test Date**	05/04/2021	**Secondary Tank Leak Detection**	Statistical Inventory Reconciliation	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	Yes
		Overfill Test Date	07/19/2022			**ATG Type**					
Tank Number	06	**Tank Age**	4	**Tank Installed Date**	04/20/2021	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	6030	**Spill Test Date**	07/19/2022	**Piping Installed Date**	04/20/2021	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	07/19/2022	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible

Product	Gasoline	**PLLD Test Date**	03/24/2023	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	Yes
Capacity	15000	**ATG Test Date**	03/24/2023	**Line Tightness Test Date**	05/04/2021	**Secondary Tank Leak Detection**	Statistical Inventory Reconciliation	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	Yes
		Overfill Test Date	07/19/2022			**ATG Type**					
Tank Number	07	**Tank Age**	4	**Tank Installed Date**	04/20/2021	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	6031	**Spill Test Date**	07/19/2022	**Piping Installed Date**	04/20/2021	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	07/19/2022	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	03/24/2023	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	Yes
Capacity	7000	**ATG Test Date**	03/24/2023	**Line Tightness Test Date**	05/04/2021	**Secondary Tank Leak Detection**	Statistical Inventory Reconciliation	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	Yes
		Overfill Test Date	07/19/2022			**ATG Type**					
Tank Number	08	**Tank Age**	4	**Tank Installed Date**	04/20/2021	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	6032	**Spill Test Date**	07/19/2022	**Piping Installed Date**	04/20/2021	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	07/19/2022	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	03/24/2023	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	20000	**ATG Test Date**	03/24/2023	**Line Tightness Test Date**	05/04/2021	**Secondary Tank Leak Detection**	Statistical Inventory Reconciliation	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	Yes
		Overfill Test Date	07/19/2022			**ATG Type**					
Tank Number	09	**Tank Age**	4	**Tank Installed Date**	04/20/2021	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	6033	**Spill Test Date**	03/10/2021	**Piping Installed Date**	04/20/2021	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	03/10/2021	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel, Dyed	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	7000	**ATG Test Date**		**Line Tightness Test Date**	05/04/2021	**Secondary Tank Leak Detection**	Statistical Inventory Reconciliation	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	Yes

		Overfill Test Date	03/02/2021			**ATG Type**					

Facility Summary in Missoula County in the City of Lolo

Location: TOWN PUMP INC LOLO 2
11880 US HWY 93 S, STE 1
Lolo, MT 59847 Missoula

System Facility ID:32-01639

Facility Code: 25228
Last Inspected On: 03/31/2023
Operating Permit Renewal Date: 10/22/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Lolo 2 Town Pump LLC	**(406) 497-6700**	**environmental@townpump.com**
Operator Contact:	Trent Biggers		**Trentb@townpump.com**

Owner/Operator:	Lolo 2 Town Pump LLC	(406) 497-6700	environmental@townpump.com
	Trent Biggers, UST Class A Operator		Trentb@townpump.com
	Trent Biggers, UST Class A Operator		Trentb@townpump.com
	Trent Biggers, UST Class B Global Operator		Trentb@townpump.com
	Trent Biggers, UST Class B Global Operator		Trentb@townpump.com

Tank Number	13	**Tank Age**	28	**Tank Installed Date**	09/01/1997	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve
Tag Number	2545	**Spill Test Date**	07/20/2022	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	07/20/2022	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	05/03/2021	**Tank/Piping CP Test Date**	12/05/2012	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**	03/23/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	07/20/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350				
Tank Number	14	**Tank Age**	28	**Tank Installed Date**	09/01/1997	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve
Tag Number	2546	**Spill Test Date**	07/20/2022	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	07/20/2022	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	05/03/2021	**Tank/Piping CP Test Date**	12/05/2012	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	03/23/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No

		Overfill Test Date	07/20/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350				
Tank Number	17	**Tank Age**	28	**Tank Installed Date**	09/01/1997	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve
Tag Number	2549	**Spill Test Date**	07/20/2022	**Piping Installed Date**	08/11/2013	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	07/20/2022	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	05/03/2021	**Tank/Piping CP Test Date**	12/05/2012	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	03/23/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	No
		Overfill Test Date	07/20/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350				
Tank Number	18	**Tank Age**	28	**Tank Installed Date**	09/01/1997	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve
Tag Number	2550	**Spill Test Date**	07/20/2022	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	07/20/2022	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	05/03/2021	**Tank/Piping CP Test Date**	12/05/2012	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**	03/23/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	07/20/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350				
Tank Number	15	**Tank Age**	28	**Tank Installed Date**	09/01/1997	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve
Tag Number	4289	**Spill Test Date**	07/20/2022	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	07/20/2022	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	05/03/2021	**Tank/Piping CP Test Date**	12/05/2012	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	03/23/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	07/20/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350				
Tank Number	16	**Tank Age**	28	**Tank Installed Date**	09/01/1997	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve

Tag Number	4290	**Spill Test Date**	07/20/2022	**Piping Installed Date**	08/11/2013	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	07/20/2022	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	05/03/2021	**Tank/Piping CP Test Date**	12/05/2012	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	03/23/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	No
		Overfill Test Date	07/20/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350				
Tank Number	20	**Tank Age**	21	**Tank Installed Date**	09/15/2004	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve
Tag Number	4942	**Spill Test Date**	07/20/2022	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	07/20/2022	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	05/03/2021	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	03/23/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	07/20/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350				
Tank Number	21	**Tank Age**	21	**Tank Installed Date**	09/15/2004	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve
Tag Number	4943	**Spill Test Date**	07/20/2022	**Piping Installed Date**	08/11/2013	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	07/20/2022	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	05/03/2021	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	03/23/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	No
		Overfill Test Date	07/20/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Missoula County in the City of Lolo

Location: TRAVELERS REST
10565 Lolo Creek Rd
Lolo, MT 59847-9471 Missoula

System Facility ID:32-11303

Facility Code: 25632
Last Inspected On: 09/26/2024
Operating Permit Renewal Date: 12/12/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Manpreet Singh **(509) 994-6599** **sbsm065@gmail.com**

Operator Contact: Emily Day;Jeffrey Toole **histar.jeff@gmail.com;Travelersrestlolo@gmail.com**

Owner/Operator: Manpreet Singh (509) 994-6599 sbsm065@gmail.com

Emily Day, UST Class A Operator Travelersrestlolo@gmail.com
Jeffrey Toole, UST Class A Operator histar.jeff@gmail.com
Jeffrey Toole, UST Class B Operator histar.jeff@gmail.com

Tank Number	S4	**Tank Age**	22	**Tank Installed Date**	08/13/2003	**Tank Material Construction**	Concrete	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	4854	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	Yes
Status	**Currently in Use**	**MLLD Test Date**	09/26/2024	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	09/26/2024	**Line Tightness Test Date**	09/26/2024	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	S5	**Tank Age**	22	**Tank Installed Date**	08/13/2003	**Tank Material Construction**	Concrete	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	4855	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	Yes
Status	**Currently in Use**	**MLLD Test Date**	09/26/2024	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	09/26/2024	**Line Tightness Test Date**	09/26/2024	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No

		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	S6	**Tank Age**	22	**Tank Installed Date**	06/23/2003	**Tank Material Construction**	Concrete	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	4856	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	Yes
Status	**Currently in Use**	**MLLD Test Date**	09/26/2024	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	09/26/2024	**Line Tightness Test Date**	09/26/2024	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	S7	**Tank Age**	22	**Tank Installed Date**	06/23/2003	**Tank Material Construction**	Concrete	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	4857	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	Yes
Status	**Currently in Use**	**MLLD Test Date**	09/26/2024	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	09/26/2024	**Line Tightness Test Date**	09/26/2024	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	S8	**Tank Age**	22	**Tank Installed Date**	06/23/2003	**Tank Material Construction**	Concrete	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	4858	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	Yes
Status	**Currently in Use**	**MLLD Test Date**	09/26/2024	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	09/26/2024	**Line Tightness Test Date**	09/26/2024	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Missoula County in the City of Milltown

Location: TOWN PUMP INC BONNER-MILLTOWN
7985 MT Hwy 200 E
Milltown, MT 59851 Missoula

System Facility ID:32-13629

Facility Code: 25772
Last Inspected On: 03/30/2023
Operating Permit Renewal Date: 11/03/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Bonner Town Pump and Casino Inc **(406) 497-6700** **environmental@townpump.com**

Operator Contact: Trent Biggers **Trentb@townpump.com**

Owner/Operator: Bonner Town Pump and Casino Inc (406) 497-6700 environmental@townpump.com
Trent Biggers, UST Class A Operator Trentb@townpump.com
Trent Biggers, UST Class B Global Operator Trentb@townpump.com

Tank Number	01	**Tank Age**	30	**Tank Installed Date**	09/01/1995	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve
Tag Number	2564	**Spill Test Date**	06/06/2022	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	07/07/2022	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	05/09/2021	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	03/17/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	06/06/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-450				
Tank Number	05	**Tank Age**	30	**Tank Installed Date**	09/01/1995	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve
Tag Number	2568	**Spill Test Date**	06/06/2022	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	07/07/2022	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	05/09/2021	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	03/17/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	06/06/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-450				

Tank Number	07	**Tank Age**	30	**Tank Installed Date**	09/01/1995	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve
Tag Number	2570	**Spill Test Date**	06/06/2022	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	07/07/2022	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	05/09/2021	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	03/17/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	06/06/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-450				
Tank Number	08	**Tank Age**	30	**Tank Installed Date**	09/01/1995	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve
Tag Number	2571	**Spill Test Date**	06/06/2022	**Piping Installed Date**	10/17/2016	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	07/07/2022	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	05/09/2021	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	03/17/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	No
		Overfill Test Date	06/06/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-450				
Tank Number	09	**Tank Age**	30	**Tank Installed Date**	09/01/1995	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve
Tag Number	2572	**Spill Test Date**	06/06/2022	**Piping Installed Date**	10/17/2016	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	07/07/2022	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	05/09/2021	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	03/17/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	No
		Overfill Test Date	06/06/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-450				
Tank Number	11	**Tank Age**	30	**Tank Installed Date**	09/01/1995	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve
Tag Number	2574	**Spill Test Date**	06/06/2022	**Piping Installed Date**	10/17/2016	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No

Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	07/07/2022	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	05/09/2021	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	Yes
Capacity	10000	**ATG Test Date**	03/17/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	No
		Overfill Test Date	06/06/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-450				
Tank Number	02	**Tank Age**	30	**Tank Installed Date**	09/01/1995	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve
Tag Number	4260	**Spill Test Date**	06/06/2022	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	07/07/2022	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	05/09/2021	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	03/17/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	06/06/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-450				
Tank Number	03	**Tank Age**	30	**Tank Installed Date**	09/01/1995	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve
Tag Number	4261	**Spill Test Date**	06/06/2022	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	07/07/2022	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	05/09/2021	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	03/17/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	06/06/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-450				
Tank Number	04	**Tank Age**	30	**Tank Installed Date**	09/01/1995	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve
Tag Number	4262	**Spill Test Date**	06/06/2022	**Piping Installed Date**	10/13/2006	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	03/17/2023	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	05/09/2021	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No

Capacity	12000	**ATG Test Date**	03/17/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	06/06/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-450				
Tank Number	06	**Tank Age**	30	**Tank Installed Date**	09/01/1995	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve
Tag Number	4263	**Spill Test Date**	06/06/2022	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	07/07/2022	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	05/09/2021	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	03/17/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	06/06/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-450				
Tank Number	12	**Tank Age**	22	**Tank Installed Date**	12/03/2003	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve
Tag Number	4871	**Spill Test Date**	06/06/2022	**Piping Installed Date**	10/17/2016	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	07/07/2022	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	05/09/2021	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	5000	**ATG Test Date**	03/17/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	No
		Overfill Test Date	06/06/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-450				
Tank Number	13	**Tank Age**	22	**Tank Installed Date**	12/03/2003	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve
Tag Number	4872	**Spill Test Date**	06/06/2022	**Piping Installed Date**	10/17/2016	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	07/07/2022	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	05/09/2021	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	03/17/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	No
		Overfill Test Date	06/06/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-450				

Tank Number	10	**Tank Age**	30	**Tank Installed Date**	09/01/1995	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve
Tag Number	4889	**Spill Test Date**	06/06/2022	**Piping Installed Date**	10/17/2016	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	07/07/2022	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	05/09/2021	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	Yes
Capacity	12000	**ATG Test Date**	03/17/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	No
		Overfill Test Date	06/06/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-450				
Tank Number	14	**Tank Age**	12	**Tank Installed Date**	06/01/2013	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	5363	**Spill Test Date**		**Piping Installed Date**	07/12/2013	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Other**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**		**Piping Type**	Pressurized	**CP Met Types**	
Product	DEF (Not Regulated)	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring;Deferred	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring;Deferred	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	15	**Tank Age**	7	**Tank Installed Date**	01/01/2018	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Positive Shutoff
Tag Number	5802	**Spill Test Date**	06/06/2022	**Piping Installed Date**	12/22/2017	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	07/07/2022	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	05/09/2021	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	Yes
Capacity	30000	**ATG Test Date**	03/17/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Statistical Inventory Reconciliation	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	Yes
		Overfill Test Date	06/06/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-450				

Facility Summary in Missoula County in the City of Missoula

Location: 3RD STREET MART
2340 S 3rd St W
Missoula, MT 59801 Missoula

System Facility ID:32-02179

Facility Code: 25246
Last Inspected On: 06/22/2022
Operating Permit Renewal Date: 08/28/2025

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Jays Corporation **polsonbay@yahoo.com**

Operator Contact: Jagpreet Ghuman;Jaspal Sandhu;Jays Corporation **(406) 880-7677** **jas_sandhu75@hotmail.com;polsonbay@yahoo.com;jaysfood08@outlook.com**

Owner/Operator: Jays Corporation polsonbay@yahoo.com

Jagpreet Ghuman, UST Class A Operator jaysfood08@outlook.com
Jagpreet Ghuman, UST Class B Operator jays1stop21@outlook.com
Jaspal Sandhu, UST Class A Operator polsonbay@yahoo.com
Jaspal Sandhu, UST Class B Operator polsonbay@yahoo.com

Tank Number	01	**Tank Age**	49	**Tank Installed Date**	04/23/1976	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	3624	**Spill Test Date**	04/27/2021	**Piping Installed Date**		**Tank Construction**	Lined Interior/Impressed Current	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**	01/17/2022	**Tank/Piping CP Test Date**	04/13/2022	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	01/17/2022	**Line Tightness Test Date**	04/01/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	01/17/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350				
Tank Number	02	**Tank Age**	49	**Tank Installed Date**	04/23/1976	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	3625	**Spill Test Date**	04/27/2021	**Piping Installed Date**		**Tank Construction**	Lined Interior/Impressed Current	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**	01/17/2022	**Tank/Piping CP Test Date**	04/13/2022	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	01/17/2022	**Line Tightness Test Date**	04/07/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No

		Overfill Test Date	01/17/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350				
Tank Number	03	**Tank Age**	49	**Tank Installed Date**	04/23/1976	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	3626	**Spill Test Date**	04/27/2021	**Piping Installed Date**		**Tank Construction**	Lined Interior/Impressed Current	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Diesel	**PLLD Test Date**	01/17/2022	**Tank/Piping CP Test Date**	04/13/2022	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	01/17/2022	**Line Tightness Test Date**	10/11/2021	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	01/17/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Missoula County in the City of Missoula

Location: 70 MILE SUPER STOP 2
930 N Russell St
Missoula, MT 59808 Missoula

System Facility ID:32-13472

Facility Code: 25751
Last Inspected On: 01/04/2024
Operating Permit Renewal Date: 01/06/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Hi-Star Properties LLC **histarms3@yahoo.com**

Operator Contact:

Owner/Operator: Hi-Star Properties LLC histarms3@yahoo.com

Tank Number	01	**Tank Age**	31	**Tank Installed Date**	06/01/1994	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	1450	**Spill Test Date**	10/23/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Single Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	10/23/2023	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	08/04/2011	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	20000	**ATG Test Date**	10/23/2023	**Line Tightness Test Date**	10/23/2023	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	02/28/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	02	**Tank Age**	31	**Tank Installed Date**	06/01/1994	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	1451	**Spill Test Date**	02/28/2024	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Single Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	10/23/2023	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	08/04/2011	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	10/23/2023	**Line Tightness Test Date**	10/23/2023	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	10/23/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	03	**Tank Age**	31	**Tank Installed Date**	06/01/1994	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve

Tag Number	1452	**Spill Test Date**	02/28/2024	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Single Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	10/23/2023	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	08/04/2011	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	10/23/2023	**Line Tightness Test Date**	10/23/2023	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	02/28/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Missoula County in the City of Missoula

Location: AIRWAY FLEET FUEL
5355 W Harrier
Missoula, MT 59808 Missoula

System Facility ID:56-14133

Facility Code: 30771
Last Inspected On: 01/17/2023
Operating Permit Renewal Date: 02/18/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Finest Oil Co	**(406) 543-6969**	
Operator Contact:	Christopher Glasser;James Brady;John Stordahl;Justin Gaudot;Stephen Hanson	**(406) 218-1563;(406) 543-6969;(406) 544-1005;(714) 333-8926**	**chrisglasser@hotmail.com;finestoil@finest-oil.com;fireman2201@msn.com;jeepin247.jb@gmail.com;justgaudot@yahoo.com**

Owner/Operator: Finest Oil Co (406) 543-6969

Christopher Glasser, UST Class A Operator	chrisglasser@hotmail.com
James Brady, UST Class A Operator	jeepin247.jb@gmail.com
John Stordahl, UST Class A Operator	fireman2201@msn.com
Joseph McClain, UST Class B Operator	jgmcclain25@gmail.com
Justin Gaudot, UST Class A Operator	justgaudot@yahoo.com
Justin Gaudot, UST Class B Global Operator	justgaudot@yahoo.com
Stephen Hanson, UST Class A Operator	finestoil@finest-oil.com
Stephen Hanson, UST Class B Operator	finestoil@finest-oil.com

Tank Number	01	**Tank Age**	20	**Tank Installed Date**	04/05/2005	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve
Tag Number	4904	**Spill Test Date**	01/16/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	12/19/2022	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	12/20/2022	**Line Tightness Test Date**	06/12/2013	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	12/19/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	02	**Tank Age**	20	**Tank Installed Date**	04/05/2005	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve
Tag Number	4905	**Spill Test Date**	12/19/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible

Product	Gasoline	**PLLD Test Date**	12/19/2022	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	15000	**ATG Test Date**	12/20/2022	**Line Tightness Test Date**	06/12/2013	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	12/19/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	03	**Tank Age**	20	**Tank Installed Date**	04/05/2005	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve
Tag Number	4906	**Spill Test Date**	12/19/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel, Dyed	**PLLD Test Date**	12/19/2022	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	12/20/2022	**Line Tightness Test Date**	06/12/2013	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	12/19/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	04	**Tank Age**	20	**Tank Installed Date**	04/05/2005	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve
Tag Number	4907	**Spill Test Date**	12/19/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	12/19/2022	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	25000	**ATG Test Date**	12/20/2022	**Line Tightness Test Date**	06/12/2013	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	12/19/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	05	**Tank Age**	20	**Tank Installed Date**	04/05/2005	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve
Tag Number	5038	**Spill Test Date**	12/19/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	12/19/2022	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	12/20/2022	**Line Tightness Test Date**	06/12/2013	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No

		Overfill Test Date	12/19/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Missoula County in the City of Missoula

Location: ALLIED WASTE SERVICES OF NORTH AMERICA LLC
1501 Rodgers St
Missoula, MT 59802-1735 Missoula

System Facility ID:32-09872

Facility Code: 25524
Last Inspected On: 07/15/2020
Operating Permit Renewal Date: 08/30/2023

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Allied Waste Services of North America LLC **(406) 543-3157**

Operator Contact: David Seeberger **(406) 543-3157** **dseeberger@republicservices.com**

David Seeberger, UST Class A Operator dseeberger@republicservices.com
David Seeberger, UST Class B Global Operator dseeberger@republicservices.com

Tank Number	04	**Tank Age**	35	**Tank Installed Date**	01/24/1990	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	500	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**	07/15/2020	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	07/15/2020	**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	20000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	05	**Tank Age**	35	**Tank Installed Date**	01/24/1990	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	501	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**	07/15/2020	**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Galvanic
Product	Oil, Waste	**PLLD Test Date**		**Tank/Piping CP Test Date**	07/15/2020	**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	3-Year Line Tightness Test	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**		**Line Tightness Test Date**	07/18/2006	**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**		**Energy Act**	No

		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Missoula County in the City of Missoula

Location: BEACH TRANSPORTATION CO
825 Mount Ave
Missoula, MT 59801-5607 Missoula

System Facility ID:32-11904

Facility Code: 25660
Last Inspected On: 04/01/2025
Operating Permit Renewal Date: 05/20/2028

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Beach Transportation **(406) 549-6121**

Operator Contact: Carlin Cavill;Shawnae Stanton;Beach Transportation **(406) 549-6121** **ccavill@beachtrans.com;sstanton@beachtrans.com**

Owner/Operator: Beach Transportation (406) 549-6121

Carlin Cavill, UST Class A Operator	ccavill@beachtrans.com
Carlin Cavill, UST Class A Operator	ccavill@beachtrans.com
Carlin Cavill, UST Class B Operator	ccavill@beachtrans.com
Carlin Cavill, UST Class B Operator	ccavill@beachtrans.com
Shawnae Stanton, UST Class A Operator	sstanton@beachtrans.com
Shawnae Stanton, UST Class B Operator	sstanton@beachtrans.com

Tank Number	03	**Tank Age**	28	**Tank Installed Date**	09/01/1997	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve
Tag Number	2361	**Spill Test Date**	04/01/2025	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	04/01/2025	**Sump Tightness Test Date**	03/31/2025	**Catastrophic L.D. Type 3.0**	Auto Dialer;Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	04/01/2025	**Line Tightness Test Date**	03/03/2020	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	04/01/2025			**ATG Type**	Gilbarco-Veeder Root/EMC Basic				

Facility Summary in Missoula County in the City of Missoula

Location: BIG SKY GAS N SHOP LLC
318 S Orange St
Missoula, MT 59801-1811 Missoula

System Facility ID:32-08715

Facility Code: 25471
Last Inspected On: 06/20/2023
Operating Permit Renewal Date: 10/29/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: BIG SKY GAS N SHOP LLC **(510) 714-5045**

Operator Contact:

Owner/Operator: BIG SKY GAS N SHOP LLC (510) 714-5045

Tank Number	04	**Tank Age**	35	**Tank Installed Date**	05/24/1990	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	2552	**Spill Test Date**	10/04/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Single Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	04/05/2023	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Gasoline	**PLLD Test Date**	05/12/2023	**Tank/Piping CP Test Date**	05/04/2021	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	06/20/2023	**Line Tightness Test Date**	05/12/2023	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	10/04/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Number	05	**Tank Age**	35	**Tank Installed Date**	05/29/1990	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	2553	**Spill Test Date**	07/11/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Gasoline	**PLLD Test Date**	05/12/2023	**Tank/Piping CP Test Date**	05/04/2021	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	06/20/2023	**Line Tightness Test Date**	05/12/2023	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	07/11/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				

Tank Number	06	**Tank Age**	35	**Tank Installed Date**	05/29/1990	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	2554	**Spill Test Date**	07/11/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Single Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Diesel	**PLLD Test Date**	05/12/2023	**Tank/Piping CP Test Date**	05/04/2021	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	06/20/2023	**Line Tightness Test Date**	05/12/2023	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	07/11/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				

Facility Summary in Missoula County in the City of Missoula

Location: BNSF MISSOULA YARD
101 International Dr
Missoula, MT 59808-1549 Missoula

System Facility ID:32-11226

Facility Code: 25626
Last Inspected On: 12/04/2023
Operating Permit Renewal Date: 03/27/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	BNSF Railway Helena	**(406) 256-4040**	**yueh.chuang@bnsf.com**
Operator Contact:	Devin Clary;Montana Rail Link Inc Missoula;Michael DeLozier;BNSF Railway Helena;Robert Mantle;BNSF Railway Helena	**(406) 256-4040;(406) 523-1500**	**bobmantle@hotmail.com;yueh.chuang@bnsf.com;michael.delozier@bnsf.com;yueh.chuang@bnsf.com;rshelley@mtrail.com**

Owner/Operator: BNSF Railway Helena	(406) 256-4040	yueh.chuang@bnsf.com
Devin Clary, UST Class A Operator		rshelley@mtrail.com
Devin Clary, UST Class A Operator		rshelley@mtrail.com
Devin Clary, UST Class B Operator		yueh.chuang@bnsf.com
Michael DeLozier, UST Class A Operator		yueh.chuang@bnsf.com
Robert Mantle, UST Class A Operator		yueh.chuang@bnsf.com

Tank Number	S5	**Tank Age**	35	**Tank Installed Date**	11/01/1990	**Tank Material Construction**	Unknown	**Piping Material**	Steel	**Overfill Types**	
Tag Number	3872	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	Yes
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Pressurized	**CP Met Types**	
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	11/01/2023	**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**	Terminal Piping Annual Line Test	**Vapor Recovery**	No
Capacity	30000	**ATG Test Date**		**Line Tightness Test Date**	11/17/2023	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					

Facility Summary in Missoula County in the City of Missoula

Location: CHS MISSOULA PETROLEUM TERMINAL
3576 Grant Creek Rd
Missoula, MT 59808 Missoula

System Facility ID:60-15296

Facility Code: 31000
Last Inspected On: 09/20/2022
Operating Permit Renewal Date: 01/17/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: CHS Inc Laurel **(406) 628-5200**

Operator Contact: Matthew Mill **(406) 721-3207** **Matt.Mill@chsinc.com**

Owner/Operator: CHS Inc Laurel (406) 628-5200

Matthew Mill, UST Class A Operator Matt.Mill@chsinc.com
Matthew Mill, UST Class B Operator Matt.Mill@chsinc.com

Tank Number	01	**Tank Age**	17	**Tank Installed Date**	02/01/2008	**Tank Material Construction**	Not Listed	**Piping Material**	Steel - Terminal Piping	**Overfill Types**	
Tag Number	5708	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	Yes
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Pressurized	**CP Met Types**	
Product	Mixture	**PLLD Test Date**		**Tank/Piping CP Test Date**	08/03/2022	**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**	Terminal Piping Annual Line Test	**Vapor Recovery**	No
Capacity	7750	**ATG Test Date**		**Line Tightness Test Date**	06/22/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					

Facility Summary in Missoula County in the City of Missoula

Location: CIRCLE K STORE 2746278
403 S Russell St
Missoula, MT 59801-2311 Missoula

System Facility ID:32-08072

Facility Code: 25460
Last Inspected On: 03/25/2025
Operating Permit Renewal Date: 04/23/2028

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Rocky Mountain Oil LLC	**(602) 728-8000**	**NT-ESS@Circlek.com**
Operator Contact:	Veronica Rivera		**ESS-WestCoast@circlek.com**

Owner/Operator:	Rocky Mountain Oil LLC	(602) 728-8000	NT-ESS@Circlek.com
	Brad Lee, UST Class B Global Operator		brad.lee@holidaycompanies.com
	Brad Lee, UST Class B Global Operator		brad.lee@holidaycompanies.com
	Jeff Reed, UST Class B Global Operator		jeff.reed@holidaycompanies.com
	Jeff Reed, UST Class B Global Operator		jeff.reed@holidaycompanies.com
	Veronica Rivera, UST Class A Operator		ESS-WestCoast@circlek.com
	Veronica Rivera, UST Class A Operator		ESS-WestCoast@circlek.com

Tank Number	06	**Tank Age**	30	**Tank Installed Date**	07/31/1995	**Tank Material Construction**	Steel Clad	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	3024	**Spill Test Date**	01/06/2025	**Piping Installed Date**	06/10/2021	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	03/25/2025	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	01/06/2025	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	01/06/2025	**Line Tightness Test Date**	07/25/2021	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date	01/06/2025			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	07	**Tank Age**	30	**Tank Installed Date**	07/31/1995	**Tank Material Construction**	Steel Clad	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	3025	**Spill Test Date**	01/06/2025	**Piping Installed Date**	06/10/2021	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	03/25/2025	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	01/06/2025	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	Yes

Capacity	8000	**ATG Test Date**	01/06/2025	**Line Tightness Test Date**	07/27/2021	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date	01/06/2025			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	08	**Tank Age**	30	**Tank Installed Date**	07/31/1995	**Tank Material Construction**	Steel Clad	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	3026	**Spill Test Date**	01/06/2025	**Piping Installed Date**	06/10/2021	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	03/25/2025	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	01/06/2025	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	Yes
Capacity	8000	**ATG Test Date**	01/06/2025	**Line Tightness Test Date**	08/02/2021	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date	01/06/2025			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	09	**Tank Age**	30	**Tank Installed Date**	07/31/1995	**Tank Material Construction**	Steel Clad	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	4700	**Spill Test Date**	01/06/2025	**Piping Installed Date**	06/10/2021	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	03/25/2025	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	01/06/2025	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	Yes
Capacity	12000	**ATG Test Date**	01/06/2025	**Line Tightness Test Date**	10/13/2021	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date	01/06/2025			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Missoula County in the City of Missoula

Location: CIRCLE K STORE 2746282
605 S Higgins Ave
Missoula, MT 59801-2733 Missoula

System Facility ID:32-09733

Facility Code: 25517
Last Inspected On: 05/03/2023
Operating Permit Renewal Date: 08/17/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Rocky Mountain Oil LLC	**(602) 728-8000**	**NT-ESS@Circlek.com**
Operator Contact:	Veronica Rivera		**ESS-WestCoast@circlek.com**

Owner/Operator: Rocky Mountain Oil LLC (602) 728-8000 NT-ESS@Circlek.com

Brad Lee, UST Class B Global Operator	brad.lee@holidaycompanies.com
Brad Lee, UST Class B Global Operator	brad.lee@holidaycompanies.com
Jeff Reed, UST Class B Global Operator	jeff.reed@holidaycompanies.com
Jeff Reed, UST Class B Global Operator	jeff.reed@holidaycompanies.com
Veronica Rivera, UST Class A Operator	ESS-WestCoast@circlek.com
Veronica Rivera, UST Class A Operator	ESS-WestCoast@circlek.com

Tank Number	01	**Tank Age**	37	**Tank Installed Date**	08/01/1988	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	3028	**Spill Test Date**	05/03/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	06/27/2022	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	Yes
Capacity	12000	**ATG Test Date**	06/27/2022	**Line Tightness Test Date**	06/27/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	06/27/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	02	**Tank Age**	37	**Tank Installed Date**	08/01/1988	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	3029	**Spill Test Date**	05/03/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	06/27/2022	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	Yes
Capacity	12000	**ATG Test Date**	06/27/2022	**Line Tightness Test Date**	06/27/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No

		Overfill Test Date	06/27/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	03	**Tank Age**	37	**Tank Installed Date**	08/01/1988	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	3030	**Spill Test Date**	05/03/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	06/27/2022	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	Yes
Capacity	12000	**ATG Test Date**	06/27/2022	**Line Tightness Test Date**	06/27/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	06/27/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Missoula County in the City of Missoula

Location: CIRCLE K STORE 2746283
2325 S Reserve St
Missoula, MT 59801-6446 Missoula

System Facility ID:32-09694

Facility Code: 25512
Last Inspected On: 10/17/2023
Operating Permit Renewal Date: 02/13/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Rocky Mountain Oil LLC	**(602) 728-8000**	**NT-ESS@Circlek.com**
Operator Contact:	Veronica Rivera		**ESS-WestCoast@circlek.com**

Owner/Operator:	Rocky Mountain Oil LLC	(602) 728-8000	NT-ESS@Circlek.com
	Brad Lee, UST Class B Global Operator		brad.lee@holidaycompanies.com
	Brad Lee, UST Class B Global Operator		brad.lee@holidaycompanies.com
	Jeff Reed, UST Class B Global Operator		jeff.reed@holidaycompanies.com
	Jeff Reed, UST Class B Global Operator		jeff.reed@holidaycompanies.com
	Jeff Reed, UST Class B Global Operator		jeff.reed@holidaycompanies.com
	Jeff Reed, UST Class B Global Operator		jeff.reed@holidaycompanies.com
	Veronica Rivera, UST Class A Operator		ESS-WestCoast@circlek.com
	Veronica Rivera, UST Class A Operator		ESS-WestCoast@circlek.com
	Veronica Rivera, UST Class A Operator		ESS-WestCoast@circlek.com

Tank Number	01	**Tank Age**	38	**Tank Installed Date**	08/01/1987	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	3706	**Spill Test Date**	11/21/2024	**Piping Installed Date**	04/10/2019	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	05/03/2022	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**	06/07/2023	**Tank/Piping CP Test Date**	06/07/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	Yes
Capacity	12000	**ATG Test Date**	06/07/2023	**Line Tightness Test Date**	07/06/2020	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date	06/07/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	02	**Tank Age**	38	**Tank Installed Date**	08/01/1987	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	3707	**Spill Test Date**	11/21/2024	**Piping Installed Date**	04/10/2019	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	05/03/2022	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current

Product	Gasoline	**PLLD Test Date**	06/07/2023	**Tank/Piping CP Test Date**	06/07/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	Yes
Capacity	10000	**ATG Test Date**	06/07/2023	**Line Tightness Test Date**	06/14/2020	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date	06/07/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	03	**Tank Age**	38	**Tank Installed Date**	08/01/1987	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	3708	**Spill Test Date**	04/11/2022	**Piping Installed Date**	04/10/2019	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	05/03/2022	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**	06/07/2023	**Tank/Piping CP Test Date**	06/07/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	Yes
Capacity	10000	**ATG Test Date**	06/07/2023	**Line Tightness Test Date**	06/17/2020	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date	06/07/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	04	**Tank Age**	38	**Tank Installed Date**	08/01/1987	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	3709	**Spill Test Date**	06/22/2021	**Piping Installed Date**	04/10/2019	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	05/03/2022	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Diesel	**PLLD Test Date**	06/07/2023	**Tank/Piping CP Test Date**	06/07/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	06/07/2023	**Line Tightness Test Date**	06/13/2020	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date	06/07/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Missoula County in the City of Missoula

Location: COMMUNITY MEDICAL CENTER
2827 Fort Missoula Rd
Missoula, MT 59804 Missoula

System Facility ID:32-11740

Facility Code: 25652
Last Inspected On: 11/29/2023
Operating Permit Renewal Date: 03/08/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: RCHP Billings - Missoula LLC **cclark@communitymed.org**

Operator Contact: Randy Allen;Community Medical Center **rallen6261@gmail.com**

Owner/Operator: RCHP Billings - Missoula LLC cclark@communitymed.org

Randy Allen, UST Class A Operator rallen6261@gmail.com

Randy Allen, UST Class B Operator rallen6261@gmail.com

Tank Number	04	**Tank Age**	31	**Tank Installed Date**	07/01/1994	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	2353	**Spill Test Date**	11/28/2023	**Piping Installed Date**	06/03/2015	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	03/11/2024	**Catastrophic L.D. Type 3.0**	Auto Dialer	**Piping Type**	U.S. Suction	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	06/05/2024	**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	11/28/2023	**Line Tightness Test Date**	11/28/2023	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	3-Year Line Tightness Test	**Energy Act**	No
		Overfill Test Date	11/28/2023			**ATG Type**	Franklin Fueling Systems/S940				

Facility Summary in Missoula County in the City of Missoula

Location: CORNER QWIK STOP
2480 39th St
Missoula, MT 59803-1123 Missoula

System Facility ID:32-09690

Facility Code: 25511
Last Inspected On: 03/01/2023
Operating Permit Renewal Date: 08/02/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Hi-Star Properties LLC		**histarms3@yahoo.com**
Operator Contact:	Jagpreet Ghuman;Manpreet Singh	**(406) 880-7677;(509) 994-6599**	**jaysfood08@outlook.com;sbsm065@gmail.com**

Owner/Operator: Hi-Star Properties LLC — histarms3@yahoo.com

Jagpreet Ghuman, UST Class A Operator	jaysfood08@outlook.com
Jagpreet Ghuman, UST Class A Operator	jaysfood08@outlook.com
Jaspal Sandhu, UST Class B Global Operator	jas_sandhu75@hotmail.com
Manpreet Singh, UST Class A Operator	sbsm065@gmail.com

Tank Number	01	**Tank Age**	43	**Tank Installed Date**	11/03/1982	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	1360	**Spill Test Date**	04/27/2021	**Piping Installed Date**	04/27/2018	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	04/27/2021	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	11/08/2022	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	Yes
Capacity	12000	**ATG Test Date**	11/08/2022	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date	06/22/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	02	**Tank Age**	43	**Tank Installed Date**	11/03/1982	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	1361	**Spill Test Date**	04/27/2021	**Piping Installed Date**	04/27/2018	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	04/27/2021	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	12/03/2019	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	Yes
Capacity	6000	**ATG Test Date**	11/08/2022	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No

		Overfill Test Date	06/22/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	03	**Tank Age**	43	**Tank Installed Date**	11/03/1982	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	1362	**Spill Test Date**	04/27/2021	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	04/27/2018	**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	11/08/2022	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**		**Vapor Recovery**	Yes
Capacity	6000	**ATG Test Date**	11/08/2022	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	06/22/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Missoula County in the City of Missoula

Location: COSTCO WHOLESALE FUELING FACILITY
3220 N Reserve St
Missoula, MT 59808-1556 Missoula

System Facility ID:56-13977

Facility Code: 30639
Last Inspected On: 07/11/2024
Operating Permit Renewal Date: 07/11/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Costco Wholesale	**(425) 251-6222**	**gaslicenses@costco.com**
Operator Contact:	Brandon Krause;Sean Davis;Costco Wholesale Corporation Missoula;Shawn Willis		**w067gas@costco.com;w067ops@costco.com**

Owner/Operator: Costco Wholesale (425) 251-6222 gaslicenses@costco.com

Brandon Krause, UST Class A Operator	w067gas@costco.com
Sean Davis, UST Class A Operator	w067ops@costco.com
Sean Davis, UST Class B Operator	w067ops@costco.com
Shawn Willis, UST Class A Operator	w067gas@costco.com
Shawn Willis, UST Class B Global Operator	w067gas@costco.com
Shawn Willis, UST Class B Operator	w067gas@costco.com

Tank Number	01	**Tank Age**	25	**Tank Installed Date**	05/15/2000	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	4189	**Spill Test Date**	07/10/2024	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	06/01/2022	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	07/11/2024	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	20000	**ATG Test Date**	07/10/2024	**Line Tightness Test Date**	07/10/2024	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date	07/10/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350				
Tank Number	02	**Tank Age**	25	**Tank Installed Date**	05/15/2000	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	4190	**Spill Test Date**	07/10/2024	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	06/01/2022	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	07/11/2024	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	20000	**ATG Test Date**	07/10/2024	**Line Tightness Test Date**	07/10/2024	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No

		Overfill Test Date	07/10/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350				
Tank Number	03	**Tank Age**	25	**Tank Installed Date**	05/15/2000	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	4191	**Spill Test Date**	07/10/2024	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	06/01/2022	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	07/11/2024	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	20000	**ATG Test Date**	07/10/2024	**Line Tightness Test Date**	07/10/2024	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date	07/10/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350				
Tank Number	04	**Tank Age**	14	**Tank Installed Date**	08/01/2011	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	5283	**Spill Test Date**	07/10/2024	**Piping Installed Date**	10/25/2010	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	07/11/2024	**Sump Tightness Test Date**	06/01/2022	**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Hazardous Substance	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	1500	**ATG Test Date**	07/10/2024	**Line Tightness Test Date**	07/10/2024	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	MLLD Line Tightness Testing	**Energy Act**	Yes
		Overfill Test Date	07/10/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Missoula County in the City of Missoula

Location: DEANOS TRAVEL PLAZA 14
5055 N Reserve St
Missoula, MT 59808-1401 Missoula

System Facility ID:32-03610

Facility Code: 25301
Last Inspected On: 10/24/2022
Operating Permit Renewal Date: 12/21/2025

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	DC Petroleum Inc	**(406) 728-6052**	**office.dcp@bresnan.net**
Operator Contact:	Sheri Taylor	**(406) 543-8885**	**office.dcp@gmail.com**

Owner/Operator: DC Petroleum Inc (406) 728-6052 office.dcp@bresnan.net

Sheri Taylor, UST Class A Operator office.dcp@gmail.com
Sheri Taylor, UST Class A Operator office.dcp@gmail.com
Sheri Taylor, UST Class B Operator office.dcp@gmail.com
Sheri Taylor, UST Class B Operator office.dcp@gmail.com

Tank Number	06	**Tank Age**	34	**Tank Installed Date**	04/02/1991	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	795	**Spill Test Date**	01/06/2023	**Piping Installed Date**	06/22/2007	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**	10/24/2022	**Tank/Piping CP Test Date**	10/24/2022	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	10/24/2022	**Line Tightness Test Date**	07/22/2017	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	01/06/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	07	**Tank Age**	34	**Tank Installed Date**	04/02/1991	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	796	**Spill Test Date**	01/06/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**	10/24/2022	**Tank/Piping CP Test Date**	10/24/2022	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	10/24/2022	**Line Tightness Test Date**	07/23/2017	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	01/06/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Tank Number	08	**Tank Age**	34	**Tank Installed Date**	04/02/1991	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	797	**Spill Test Date**	01/06/2023	**Piping Installed Date**	06/22/2007	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**	10/24/2022	**Tank/Piping CP Test Date**	10/24/2022	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	10/24/2022	**Line Tightness Test Date**	07/23/2017	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	01/06/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	09	**Tank Age**	34	**Tank Installed Date**	04/02/1991	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	798	**Spill Test Date**	01/06/2023	**Piping Installed Date**	06/22/2007	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**	10/24/2022	**Tank/Piping CP Test Date**	10/24/2022	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	10/24/2022	**Line Tightness Test Date**	07/25/2017	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	01/06/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	10	**Tank Age**	34	**Tank Installed Date**	04/02/1991	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	799	**Spill Test Date**	01/06/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**	10/24/2022	**Tank/Piping CP Test Date**	10/24/2022	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	10/24/2022	**Line Tightness Test Date**	08/22/2017	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	01/06/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Missoula County in the City of Missoula

Location: DEANOS TRAVEL PLAZA II
5318 W Harrier
Missoula, MT 59801 Missoula

System Facility ID:60-15010

Facility Code: 30800
Last Inspected On: 02/07/2024
Operating Permit Renewal Date: 04/27/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	DC Petroleum Inc	**(406) 728-6052**	**office.dcp@bresnan.net**
Operator Contact:	Dean Clinkenbeard;Sheri Taylor	**(406) 543-8885**	**office.dcp@bresnan.net;office.dcp@gmail.com**

Owner/Operator: DC Petroleum Inc (406) 728-6052 office.dcp@bresnan.net

Dean Clinkenbeard, UST Class A Operator	office.dcp@bresnan.net
Dean Clinkenbeard, UST Class B Global Operator	office.dcp@bresnan.net
Sheri Taylor, UST Class A Operator	office.dcp@gmail.com
Sheri Taylor, UST Class B Operator	office.dcp@gmail.com

Tank Number	01	**Tank Age**	19	**Tank Installed Date**	01/17/2006	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve
Tag Number	5027	**Spill Test Date**	01/10/2024	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	11/17/2023	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	20000	**ATG Test Date**	11/17/2023	**Line Tightness Test Date**	09/10/2017	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	01/10/2024			**ATG Type**	Gilbarco/TLS-350				
Tank Number	02	**Tank Age**	19	**Tank Installed Date**	01/17/2006	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve
Tag Number	5028	**Spill Test Date**	01/10/2024	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	11/17/2023	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	11/17/2023	**Line Tightness Test Date**	02/07/2018	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	01/10/2024			**ATG Type**	Gilbarco/TLS-350				

Tank Number	03	**Tank Age**	19	**Tank Installed Date**	01/17/2006	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve
Tag Number	5029	**Spill Test Date**	01/10/2024	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	11/17/2023	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	11/17/2023	**Line Tightness Test Date**	02/07/2018	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	01/10/2024			**ATG Type**	Gilbarco/TLS-350				

Facility Summary in Missoula County in the City of Missoula

Location: DECKER TRUCK LINE INC
8350 Old Hwy 10
Missoula, MT 59808 Missoula

System Facility ID:60-15231

Facility Code: 30948
Last Inspected On: 05/23/2023
Operating Permit Renewal Date: 09/01/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Decker Truck Line Inc	**(515) 574-4338**	**glawman@deckermail.com**
Operator Contact:	Liam Lederer	**(406) 274-7987**	**llederer@dtlinc.com**

Owner/Operator: Decker Truck Line Inc (515) 574-4338 glawman@deckermail.com

Cory Jelletich, UST Class B Global Operator dagumit13@hotmail.com
Liam Lederer, UST Class A Operator llederer@dtlinc.com
Liam Lederer, UST Class B Global Operator llederer@dtlinc.com

Tank Number	01	**Tank Age**	11	**Tank Installed Date**	03/01/2014	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	5438	**Spill Test Date**	11/16/2021	**Piping Installed Date**	08/30/2013	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	06/12/2020	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	11/16/2021	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	20000	**ATG Test Date**	11/16/2021	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	11/16/2021			**ATG Type**	Gilbarco-Veeder Root/TLS-350;Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	02	**Tank Age**	11	**Tank Installed Date**	03/01/2014	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	5439	**Spill Test Date**		**Piping Installed Date**	08/25/2013	**Tank Construction**	Double-Walled	**Piping Construction**	None	**AST**	No
Status	**Other**	**MLLD Test Date**		**Sump Tightness Test Date**	10/09/2013	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	DEF (Not Regulated)	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.1;Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	ELLD 0.1;ELLD 0.2	**Vapor Recovery**	No

Capacity	5000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Not Listed	**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Missoula County in the City of Missoula

Location: DEMAROIS, INC
3115 W Broadway St
Missoula, MT 59808-1613 Missoula

System Facility ID:32-10552

Facility Code: 25588
Last Inspected On: 11/06/2024
Operating Permit Renewal Date: 01/08/2028

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: DeMarois Inc

Operator Contact: Jack DeMarois **(406) 721-4000** **jack@demarois.com**

Owner/Operator: DeMarois Inc

Jack DeMarois, UST Class A Operator jack@demarois.com
Jack DeMarois, UST Class B Operator jack@demarois.com

Tank Number	03	**Tank Age**	27	**Tank Installed Date**	11/01/1998	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	2188	**Spill Test Date**	11/08/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	12/13/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	12/13/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-300				

Facility Summary in Missoula County in the City of Missoula

Location: FAST TRIP CONOCO
2730 S Reserve St
Missoula, MT 59801-7641 Missoula

System Facility ID:56-13914

Facility Code: 30584
Last Inspected On: 03/28/2025
Operating Permit Renewal Date: 07/02/2028

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Scott Worster **scottoej@gmail.com**

Operator Contact: Deb Privett **(406) 529-7771** **fasttripinc@gmail.com**

Owner/Operator: Scott Worster scottoej@gmail.com

Deb Privett, UST Class A Operator fasttripinc@gmail.com

Deb Privett, UST Class B Operator fasttripinc@gmail.com

Tank Number	01	**Tank Age**	26	**Tank Installed Date**	08/01/1999	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve;High Level Alarm
Tag Number	4913	**Spill Test Date**	06/24/2024	**Piping Installed Date**	06/03/2020	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	10/04/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	06/24/2024	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	15000	**ATG Test Date**	06/24/2024	**Line Tightness Test Date**	12/02/2021	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date	06/24/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	02	**Tank Age**	26	**Tank Installed Date**	08/01/1999	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve;High Level Alarm
Tag Number	4914	**Spill Test Date**	06/24/2024	**Piping Installed Date**	06/03/2020	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	10/04/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	06/24/2024	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	06/24/2024	**Line Tightness Test Date**	11/14/2021	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date	06/24/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Tank Number	03	**Tank Age**	26	**Tank Installed Date**	08/01/1999	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve;High Level Alarm
Tag Number	4915	**Spill Test Date**	06/24/2024	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	09/24/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	06/24/2024	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	06/24/2024	**Line Tightness Test Date**	10/25/2021	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date	06/24/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Missoula County in the City of Missoula

Location: FINEST OIL CO MISSOULA NORTHGATE
3665 Grant Creek Rd
Missoula, MT 59808-1431 Missoula

System Facility ID:32-02295

Facility Code: 25257
Last Inspected On: 06/14/2023
Operating Permit Renewal Date: 08/09/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Finest Oil Co	**(406) 543-6969**	
Operator Contact:	Christopher Glasser;David Peyton;James Brady;James DeWaters;Justin Gaudot;Stephen Hanson	**(406) 218-1563;(406) 360-6327;(406) 543-6969;(406) 544-1005;(714) 333-8926**	**chrisglasser@hotmail.com;finestoil@finest-oil.com;jeepin247.jb@gmail.com;justgaudot@yahoo.com;rivban22@gmail.com**

Owner/Operator: Finest Oil Co (406) 543-6969

Christopher Glasser, UST Class A Operator	chrisglasser@hotmail.com
David Peyton, UST Class A Operator	
David Peyton, UST Class B Global Operator	
James Brady, UST Class A Operator	jeepin247.jb@gmail.com
James DeWaters, UST Class A Operator	rivban22@gmail.com
Joseph McClain, UST Class B Operator	jgmcclain25@gmail.com
Justin Gaudot, UST Class A Operator	justgaudot@yahoo.com
Justin Gaudot, UST Class B Global Operator	justgaudot@yahoo.com
Stephen Hanson, UST Class A Operator	finestoil@finest-oil.com
Stephen Hanson, UST Class B Operator	finestoil@finest-oil.com

Tank Number	06	**Tank Age**	34	**Tank Installed Date**	07/01/1991	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	1066	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Temporarily Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	04/21/2020	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	5000	**ATG Test Date**	06/18/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	06/18/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Number	07	**Tank Age**	34	**Tank Installed Date**	07/01/1991	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	1067	**Spill Test Date**	06/14/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic

Product	Diesel	**PLLD Test Date**	06/14/2023	**Tank/Piping CP Test Date**	06/14/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	06/18/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	06/18/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Number	08	**Tank Age**	32	**Tank Installed Date**	06/01/1993	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	1068	**Spill Test Date**	06/14/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**	06/14/2023	**Tank/Piping CP Test Date**	06/14/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**	06/18/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	06/18/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Number	09	**Tank Age**	32	**Tank Installed Date**	06/01/1993	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	1069	**Spill Test Date**	06/14/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**	06/14/2023	**Tank/Piping CP Test Date**	06/14/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	06/18/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	06/18/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Number	10	**Tank Age**	32	**Tank Installed Date**	06/01/1993	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	1070	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**	06/14/2023	**Tank/Piping CP Test Date**	04/21/2020	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	06/18/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	06/18/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				

Tank Number	11	**Tank Age**	32	**Tank Installed Date**	06/01/1993	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	1071	**Spill Test Date**	08/04/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Single Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**	06/14/2023	**Tank/Piping CP Test Date**	04/21/2020	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	06/18/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	06/18/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Number	12	**Tank Age**	31	**Tank Installed Date**	05/01/1994	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	1072	**Spill Test Date**	08/04/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Single Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**	06/14/2023	**Tank/Piping CP Test Date**	04/21/2020	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**	06/18/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	06/18/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Number	13	**Tank Age**	31	**Tank Installed Date**	05/01/1994	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	1073	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**	06/14/2023	**Tank/Piping CP Test Date**	04/21/2020	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**	06/18/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	06/18/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				

Facility Summary in Missoula County in the City of Missoula

Location: FINEST OIL EASTGATE
940 E Broadway St
Missoula, MT 59802-4915 Missoula

System Facility ID:32-10284

Facility Code: 25565
Last Inspected On: 05/04/2022
Operating Permit Renewal Date: 09/17/2025

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Finest Oil Co	**(406) 543-6969**	
Operator Contact:	Christopher Glasser;David Peyton;James Brady;James DeWaters;Justin Gaudot;Stephen Hanson	**(406) 218-1563;(406) 360-6327;(406) 543-6969;(406) 544-1005;(714) 333-8926**	**chrisglasser@hotmail.com;finestoil@finest-oil.com;jeepin247.jb@gmail.com;justgaudot@yahoo.com;rivban22@gmail.com**

Owner/Operator: Finest Oil Co (406) 543-6969

Christopher Glasser, UST Class A Operator	chrisglasser@hotmail.com
Christopher Glasser, UST Class A Operator	chrisglasser@hotmail.com
David Peyton, UST Class A Operator	
David Peyton, UST Class B Global Operator	
James Brady, UST Class A Operator	jeepin247.jb@gmail.com
James Brady, UST Class A Operator	jeepin247.jb@gmail.com
James DeWaters, UST Class A Operator	rivban22@gmail.com
James DeWaters, UST Class A Operator	rivban22@gmail.com
John Stordahl, UST Class B Global Operator	fireman2201@msn.com
John Stordahl, UST Class B Global Operator	fireman2201@msn.com
Joseph McClain, UST Class B Operator	jgmcclain25@gmail.com
Joseph McClain, UST Class B Operator	jgmcclain25@gmail.com
Justin Gaudot, UST Class A Operator	justgaudot@yahoo.com
Justin Gaudot, UST Class A Operator	justgaudot@yahoo.com
Justin Gaudot, UST Class B Global Operator	justgaudot@yahoo.com
Justin Gaudot, UST Class B Global Operator	justgaudot@yahoo.com
Stephen Hanson, UST Class A Operator	finestoil@finest-oil.com
Stephen Hanson, UST Class A Operator	finestoil@finest-oil.com
Stephen Hanson, UST Class B Operator	finestoil@finest-oil.com
Stephen Hanson, UST Class B Operator	finestoil@finest-oil.com

Tank Number	07	**Tank Age**	28	**Tank Installed Date**	10/27/1997	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	1074	**Spill Test Date**	05/04/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible

Product	Gasoline	**PLLD Test Date**	05/04/2022	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	15000	**ATG Test Date**	05/04/2022	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	05/04/2022			**ATG Type**	Gilbarco/EMC Basic				
Tank Number	08	**Tank Age**	28	**Tank Installed Date**	10/27/1997	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	1075	**Spill Test Date**	05/04/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	05/04/2022	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	05/04/2022	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	05/04/2022			**ATG Type**	Gilbarco/EMC Basic				
Tank Number	09	**Tank Age**	28	**Tank Installed Date**	10/27/1997	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	1076	**Spill Test Date**	05/04/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	05/04/2022	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	05/04/2022	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	05/04/2022			**ATG Type**	Gilbarco/EMC Basic				

Facility Summary in Missoula County in the City of Missoula

Location: GREAT WESTERN PETROLEUM
1002 E Broadway St
Missoula, MT 59802-4930 Missoula

System Facility ID:32-07431

Facility Code: 25437
Last Inspected On: 05/01/2024
Operating Permit Renewal Date: 10/30/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Tabish Brothers Distributors Inc	**(406) 543-7621**	**lss@gwpetrol.com**
Operator Contact:	Heather Stiles		**hstiles@gwpetrol.com**

Owner/Operator:	Tabish Brothers Distributors Inc	(406) 543-7621	lss@gwpetrol.com
	Heather Stiles, UST Class A Operator		hstiles@gwpetrol.com
	Heather Stiles, UST Class A Operator		hstiles@gwpetrol.com
	Heather Stiles, UST Class B Global Operator		hstiles@gwpetrol.com
	Heather Stiles, UST Class B Global Operator		hstiles@gwpetrol.com

Tank Number	10	**Tank Age**	27	**Tank Installed Date**	06/01/1998	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	1432	**Spill Test Date**	10/17/2024	**Piping Installed Date**	08/26/2006	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	05/01/2024	**Sump Tightness Test Date**	07/27/2018	**Catastrophic L.D. Type 3.0**	Continuous Interstitial Monitoring;Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	5000	**ATG Test Date**	05/01/2024	**Line Tightness Test Date**	05/01/2024	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	05/01/2024			**ATG Type**	Gilbarco/EMC Basic				
Tank Number	S11	**Tank Age**	27	**Tank Installed Date**	06/01/1998	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	
Tag Number	1433	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	Yes
Status	**Currently in Use**	**MLLD Test Date**	05/01/2024	**Sump Tightness Test Date**	07/27/2018	**Catastrophic L.D. Type 3.0**	Continuous Interstitial Monitoring;Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No

Capacity	17000	**ATG Test Date**	10/07/2021	**Line Tightness Test Date**	05/01/2024	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	S12	**Tank Age**	27	**Tank Installed Date**	06/01/1998	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	
Tag Number	1434	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	Yes
Status	**Currently in Use**	**MLLD Test Date**	05/01/2024	**Sump Tightness Test Date**	07/27/2018	**Catastrophic L.D. Type 3.0**	Continuous Interstitial Monitoring;Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	11000	**ATG Test Date**	10/07/2021	**Line Tightness Test Date**	05/01/2024	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	S13	**Tank Age**	27	**Tank Installed Date**	06/01/1998	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	
Tag Number	1435	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	Yes
Status	**Currently in Use**	**MLLD Test Date**	05/01/2024	**Sump Tightness Test Date**	07/27/2018	**Catastrophic L.D. Type 3.0**	Continuous Interstitial Monitoring;Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	14600	**ATG Test Date**	10/07/2021	**Line Tightness Test Date**	05/01/2024	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	S14	**Tank Age**	27	**Tank Installed Date**	06/01/1998	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	
Tag Number	1436	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	Yes
Status	**Currently in Use**	**MLLD Test Date**	05/01/2024	**Sump Tightness Test Date**	07/27/2018	**Catastrophic L.D. Type 3.0**	Continuous Interstitial Monitoring;Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No

Capacity	11000	**ATG Test Date**	10/07/2021	**Line Tightness Test Date**	05/01/2024	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date				**ATG Type**					

Facility Summary in Missoula County in the City of Missoula

Location: HEATING PLANT
Physical Plant Bldg #32
Missoula, MT 59812 Missoula

System Facility ID:32-00505

Facility Code: 25184
Last Inspected On: 01/28/2023
Operating Permit Renewal Date: 02/22/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: University of Montana **(406) 243-2190**

Operator Contact: Anthony Ey **anthony.ey@mso.umt.edu>**

Owner/Operator: University of Montana (406) 243-2190

Anthony Ey, UST Class A Operator anthony.ey@mso.umt.edu>
Anthony Ey, UST Class B Operator anthony.ey@mso.umt.edu>

Tank Number	09	**Tank Age**	27	**Tank Installed Date**	11/01/1998	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	4221	**Spill Test Date**	01/27/2023	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	01/27/2023	**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	U.S. Suction	**CP Met Types**	Non-corrodible
Product	Diesel, Dyed	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	20000	**ATG Test Date**	01/27/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	01/27/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-300;Veeder Root/TLS-300				

Facility Summary in Missoula County in the City of Missoula

Location: HELLGATE CONOCO SERVICE CENTER
711 E Broadway St
Missoula, MT 59802-4609 Missoula

System Facility ID:32-00144

Facility Code: 25156
Last Inspected On: 06/12/2023
Operating Permit Renewal Date: 06/14/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Hellgate Conoco Service Center;Ross Grenfell;Hellgate Conoco Service Center	**(406) 728-9966;(406) 728-9966;(406) 728-9966**	**hellgateconoco@gmail.com**
Operator Contact:	Ross Grenfell;Hellgate Conoco Service Center	**(406) 728-9966;(406) 728-9966**	**hellgateconoco@gmail.com**

Owner/Operator: Hellgate Conoco Service Center (406) 728-9966

Owner/Operator: Ross Grenfell,Hellgate Conoco Service Center (406) 728-9966

Ross Grenfell, UST Class A Operator hellgateconoco@gmail.com

Ross Grenfell, UST Class B Global Operator hellgateconoco@gmail.com

Tank Number	01	**Tank Age**	59	**Tank Installed Date**	03/31/1966	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	3765	**Spill Test Date**	06/12/2023	**Piping Installed Date**		**Tank Construction**	Lined Interior/Impressed Current	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	06/12/2023	**Sump Tightness Test Date**	06/12/2023	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Safe Suction	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	06/12/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	03/26/2025	**Line Tightness Test Date**	06/12/2023	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date	06/12/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	02	**Tank Age**	59	**Tank Installed Date**	03/31/1966	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	3766	**Spill Test Date**	06/12/2023	**Piping Installed Date**		**Tank Construction**	Lined Interior/Impressed Current	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	06/12/2023	**Sump Tightness Test Date**	06/12/2023	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	06/12/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**	03/26/2025	**Line Tightness Test Date**	06/12/2023	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No

		Overfill Test Date	06/12/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350				
Tank Number	03	**Tank Age**	59	**Tank Installed Date**	03/31/1966	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	3767	**Spill Test Date**	06/12/2023	**Piping Installed Date**		**Tank Construction**	Lined Interior/Impressed Current	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	06/12/2023	**Sump Tightness Test Date**	06/12/2023	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	06/12/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**	03/26/2025	**Line Tightness Test Date**	06/12/2023	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	06/12/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350				
Tank Number	08	**Tank Age**	15	**Tank Installed Date**	12/16/2010	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	5279	**Spill Test Date**	06/12/2023	**Piping Installed Date**	12/16/2010	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	06/12/2023	**Sump Tightness Test Date**	06/12/2023	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	03/15/2017	**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	Yes
Capacity	8000	**ATG Test Date**	03/26/2025	**Line Tightness Test Date**	06/12/2023	**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	06/12/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350;Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Missoula County in the City of Missoula

Location: HELLGATE TRADING POST INC
6265 Mullan Rd
Missoula, MT 59808-5650 Missoula

System Facility ID:32-00211

Facility Code: 25173
Last Inspected On: 03/12/2025
Operating Permit Renewal Date: 06/03/2028

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Tabish Brothers Distributors Inc	**(406) 543-7621**	**lss@gwpetrol.com**
Operator Contact:	Karly Shafer	**(406) 396-2206**	**karly@gwpetrol.com**

Owner/Operator: Tabish Brothers Distributors Inc (406) 543-7621 lss@gwpetrol.com

Heather Stiles, UST Class B Global Operator hstiles@gwpetrol.com
Karly Shafer, UST Class A Operator karly@gwpetrol.com
Karly Shafer, UST Class B Global Operator karly@gwpetrol.com

Tank Number	03	**Tank Age**	31	**Tank Installed Date**	09/01/1994	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	1425	**Spill Test Date**	03/12/2025	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	03/12/2025	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	03/12/2025	**Line Tightness Test Date**	03/12/2025	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	03/12/2025			**ATG Type**	Gilbarco/EMC Basic				
Tank Number	04	**Tank Age**	31	**Tank Installed Date**	09/01/1994	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	1426	**Spill Test Date**	03/12/2025	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	03/12/2025	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	03/12/2025	**Line Tightness Test Date**	03/12/2025	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	03/12/2025			**ATG Type**	Gilbarco/EMC Basic				

Facility Summary in Missoula County in the City of Missoula

Location: JACKSON FOOD STORE 400
540 E Broadway St
Missoula, MT 59802-4614 Missoula

System Facility ID:32-03614

Facility Code: 25304
Last Inspected On: 04/09/2024
Operating Permit Renewal Date: 08/26/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: JACKSONS FOOD STORE INC **(208) 888-6061** **compliance@jacksons.com**

Operator Contact: Earl Allen

Owner/Operator: JACKSONS FOOD STORE INC (208) 888-6061 compliance@jacksons.com

Earl Allen, UST Class A Operator
Earl Allen, UST Class A Operator
Earl Allen, UST Class B Operator
Earl Allen, UST Class B Operator

Tank Number	05	**Tank Age**	10	**Tank Installed Date**	04/28/2015	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve
Tag Number	5573	**Spill Test Date**	04/09/2024	**Piping Installed Date**	04/28/2015	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	09/30/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	05/03/2023	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	18000	**ATG Test Date**	05/03/2023	**Line Tightness Test Date**	02/13/2021	**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	07/31/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350;Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	06	**Tank Age**	10	**Tank Installed Date**	04/28/2015	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve
Tag Number	5574	**Spill Test Date**	04/09/2024	**Piping Installed Date**	04/28/2015	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	04/09/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	05/03/2024	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No

Capacity	6000	**ATG Test Date**	05/03/2023	**Line Tightness Test Date**	02/13/2021	**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	07/31/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350;Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	07	**Tank Age**	10	**Tank Installed Date**	04/28/2015	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve
Tag Number	5575	**Spill Test Date**	05/18/2021	**Piping Installed Date**	04/28/2015	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	05/18/2021	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	05/18/2021	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	05/18/2021	**Line Tightness Test Date**	02/13/2021	**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	07/31/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Missoula County in the City of Missoula

Location: JACKSONS FOOD STORE 402
1250 39th St
Missoula, MT 59803 Missoula

System Facility ID:32-05763

Facility Code: 25380
Last Inspected On: 08/15/2022
Operating Permit Renewal Date: 12/10/2025

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: JACKSONS FOOD STORE INC **(208) 888-6061** **compliance@jacksons.com**

Operator Contact: Earl Allen

Owner/Operator: JACKSONS FOOD STORE INC (208) 888-6061 compliance@jacksons.com

Earl Allen, UST Class A Operator
Earl Allen, UST Class A Operator
Earl Allen, UST Class B Global Operator
Earl Allen, UST Class B Global Operator

Tank Number	01	**Tank Age**	45	**Tank Installed Date**	01/01/1980	**Tank Material Construction**	Bare Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	1348	**Spill Test Date**	05/04/2022	**Piping Installed Date**		**Tank Construction**	Lined Interior/Impressed Current	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	05/04/2022	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	05/04/2022	**Line Tightness Test Date**	06/14/2010	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	05/04/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	02	**Tank Age**	45	**Tank Installed Date**	01/01/1980	**Tank Material Construction**	Bare Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	1349	**Spill Test Date**	05/04/2022	**Piping Installed Date**		**Tank Construction**	Lined Interior/Impressed Current	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	05/04/2022	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	05/04/2022	**Line Tightness Test Date**	06/14/2010	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No

		Overfill Test Date	05/04/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	03	**Tank Age**	45	**Tank Installed Date**	01/01/1980	**Tank Material Construction**	Bare Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	1350	**Spill Test Date**	05/04/2022	**Piping Installed Date**		**Tank Construction**	Lined Interior/Impressed Current	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	05/04/2022	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	05/04/2022	**Line Tightness Test Date**	06/14/2010	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	05/04/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Missoula County in the City of Missoula

Location: JACKSONS FOOD STORES 401
1605 S Russell St
Missoula, MT 59801-5636 Missoula

System Facility ID:32-08863

Facility Code: 25478
Last Inspected On: 10/23/2024
Operating Permit Renewal Date: 02/09/2028

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: GYPSY LLC **(208) 888-6061** **compliance@jacksons.com**

Operator Contact: Earl Allen

Owner/Operator: GYPSY LLC (208) 888-6061 compliance@jacksons.com

Earl Allen, UST Class A Operator
Earl Allen, UST Class A Operator
Earl Allen, UST Class B Operator
Earl Allen, UST Class B Operator

Tank Number	01	**Tank Age**	40	**Tank Installed Date**	06/23/1985	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	1357	**Spill Test Date**	10/23/2024	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	04/25/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	10/23/2024			**ATG Type**	Veeder Root/TLS-300				
Tank Number	02	**Tank Age**	40	**Tank Installed Date**	06/23/1985	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	1358	**Spill Test Date**	11/26/2024	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	04/25/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	11/26/2024			**ATG Type**	Veeder Root/TLS-300				

Tank Number	03	**Tank Age**	40	**Tank Installed Date**	06/23/1985	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	1359	**Spill Test Date**	10/23/2024	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	04/25/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	10/23/2024			**ATG Type**	Veeder Root/TLS-300				

Facility Summary in Missoula County in the City of Missoula

Location: JAYS 1 STOP
505 Highton St
Missoula, MT 59801-5424 Missoula

System Facility ID:32-06680

Facility Code: 25412
Last Inspected On: 06/06/2023
Operating Permit Renewal Date: 07/31/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Jays Corporation		**polsonbay@yahoo.com**
Operator Contact:	Jagpreet Ghuman;Jays 1 Stop;Jaspal Sandhu;Jays Corporation	**(406) 880-7677;(406) 549-1031**	**jas_sandhu75@hotmail.com;polsonbay@yahoo.com;jaysfood08@outlook.com;jays1stop21@outlook.com**

Owner/Operator: Jays Corporation polsonbay@yahoo.com

Jagpreet Ghuman, UST Class A Operator jays1stop21@outlook.com
Jagpreet Ghuman, UST Class B Operator jays1stop21@outlook.com
Jaspal Sandhu, UST Class A Operator polsonbay@yahoo.com
Jaspal Sandhu, UST Class B Operator polsonbay@yahoo.com

Tank Number	03	**Tank Age**	35	**Tank Installed Date**	01/10/1990	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve
Tag Number	2298	**Spill Test Date**	09/03/2024	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	07/21/2022	**Sump Tightness Test Date**	09/11/2024	**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	07/12/2021	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**	02/25/2025	**Line Tightness Test Date**	07/21/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	MLLD Line Tightness Testing	**Energy Act**	No
		Overfill Test Date	03/03/2025			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	04	**Tank Age**	35	**Tank Installed Date**	01/10/1990	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve
Tag Number	2299	**Spill Test Date**	09/03/2024	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	07/21/2022	**Sump Tightness Test Date**	09/11/2024	**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	07/12/2021	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**	02/25/2025	**Line Tightness Test Date**	07/21/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	MLLD Line Tightness Testing	**Energy Act**	No

		Overfill Test Date	03/03/2025			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	05	**Tank Age**	35	**Tank Installed Date**	01/10/1990	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve
Tag Number	2300	**Spill Test Date**	09/03/2024	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	07/21/2022	**Sump Tightness Test Date**	09/11/2024	**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	07/12/2021	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**	02/25/2025	**Line Tightness Test Date**	07/21/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	MLLD Line Tightness Testing	**Energy Act**	No
		Overfill Test Date	03/03/2025			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Number	06	**Tank Age**	1	**Tank Installed Date**	08/07/2024	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	6252	**Spill Test Date**	09/03/2024	**Piping Installed Date**	02/21/2025	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	09/11/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	02/25/2025	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	03/03/2025			**ATG Type**					

Facility Summary in Missoula County in the City of Missoula

Location: JAYS FOOD STORE
2738 W Broadway St
Missoula, MT 59808-1622 Missoula

System Facility ID:32-05760

Facility Code: 25377
Last Inspected On: 03/01/2023
Operating Permit Renewal Date: 08/02/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Jays Corporation		**polsonbay@yahoo.com**
Operator Contact:	Jagpreet Ghuman;Jaspal Sandhu	**(406) 880-7677**	**jas_sandhu75@hotmail.com;jaysfood08@outlook.com**

Owner/Operator: Jays Corporation polsonbay@yahoo.com

Jagpreet Ghuman, UST Class A Operator	jaysfood08@outlook.com
Jagpreet Ghuman, UST Class B Global Operator	jaysfood08@outlook.com
Jaspal Sandhu, UST Class A Operator	jas_sandhu75@hotmail.com
Jaspal Sandhu, UST Class B Global Operator	jas_sandhu75@hotmail.com
Jaspal Sandhu, UST Class B Operator	jas_sandhu75@hotmail.com

Tank Number	01	**Tank Age**	53	**Tank Installed Date**	11/18/1972	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	1345	**Spill Test Date**	04/11/2022	**Piping Installed Date**	10/10/2015	**Tank Construction**	Lined Interior/Impressed Current	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	06/22/2021	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**	12/03/2019	**Tank/Piping CP Test Date**	03/01/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	11/08/2022	**Line Tightness Test Date**	10/12/2019	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date	04/11/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	02	**Tank Age**	49	**Tank Installed Date**	11/18/1976	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	1346	**Spill Test Date**	04/11/2022	**Piping Installed Date**	10/10/2015	**Tank Construction**	Lined Interior/Impressed Current	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	06/22/2021	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**	12/03/2019	**Tank/Piping CP Test Date**	03/01/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No

Capacity	4000	**ATG Test Date**		**Line Tightness Test Date**	10/14/2019	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date	04/11/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	03	**Tank Age**	53	**Tank Installed Date**	11/18/1972	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	1347	**Spill Test Date**	04/11/2022	**Piping Installed Date**	10/10/2015	**Tank Construction**	Lined Interior/Impressed Current	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	06/22/2021	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Diesel	**PLLD Test Date**	12/03/2019	**Tank/Piping CP Test Date**	03/01/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	11/08/2022	**Line Tightness Test Date**	10/14/2019	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date	04/11/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Missoula County in the City of Missoula

Location: JAYS FOOD STORE CARDLOCK
2738 W Broadway St
Missoula, MT 59808-1622 Missoula

System Facility ID:32-05761

Facility Code: 25378
Last Inspected On: 04/18/2025
Operating Permit Renewal Date: 06/11/2028

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Jays Corporation **polsonbay@yahoo.com**

Operator Contact: Jagpreet Ghuman **(406) 880-7677** **jaysfood08@outlook.com**

Owner/Operator: Jays Corporation polsonbay@yahoo.com

Jagpreet Ghuman, UST Class A Operator jaysfood08@outlook.com
Jagpreet Ghuman, UST Class B Global Operator jaysfood08@outlook.com
Jaspal Sandhu, UST Class B Global Operator jas_sandhu75@hotmail.com

Tank Number	01	**Tank Age**	46	**Tank Installed Date**	11/14/1979	**Tank Material Construction**	Bare Steel	**Piping Material**	Steel	**Overfill Types**	Flapper Valve
Tag Number	3627	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**	Lined Interior/Impressed Current	**Piping Construction**	None	**AST**	No
Status	**Temporarily Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	06/28/2022	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	02	**Tank Age**	50	**Tank Installed Date**	11/14/1975	**Tank Material Construction**	Bare Steel	**Piping Material**	Steel	**Overfill Types**	Flapper Valve
Tag Number	3628	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**	Lined Interior/Impressed Current	**Piping Construction**	None	**AST**	No
Status	**Temporarily Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Impressed Current
Product	Diesel, Dyed	**PLLD Test Date**		**Tank/Piping CP Test Date**	06/28/2022	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					

Tank Number	03	**Tank Age**	46	**Tank Installed Date**	11/14/1979	**Tank Material Construction**	Bare Steel	**Piping Material**	Steel	**Overfill Types**	Flapper Valve
Tag Number	3629	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**	Lined Interior/Impressed Current	**Piping Construction**	None	**AST**	No
Status	**Temporarily Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Impressed Current
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	06/28/2022	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					

Facility Summary in Missoula County in the City of Missoula

Location: LITHIA AUTO CENTER
5001 Grizzly Ct
Missoula, MT 59808-8672 Missoula

System Facility ID:56-14004

Facility Code: 30665
Last Inspected On: 05/16/2019
Operating Permit Renewal Date: 06/24/2022

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Lithia Chrysler Dodge of Missoula **(406) 721-5000**

Operator Contact: Betty Johnson **(406) 721-5000**

Betty Johnson, UST Class A Operator
Betty Johnson, UST Class B Operator

Tank Number	01	**Tank Age**	24	**Tank Installed Date**	06/01/2001	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	4359	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Continuous Interstitial Monitoring	**Piping Type**	Pressurized	**CP Met Types**	
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	02	**Tank Age**	24	**Tank Installed Date**	06/01/2001	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	4360	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Continuous Interstitial Monitoring	**Piping Type**	Pressurized	**CP Met Types**	
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					

Facility Summary in Missoula County in the City of Missoula

Location: LOVES TRAVEL STOP #753
8077 Hwy 10 W
Missoula, MT 59808 Missoula

System Facility ID:60-15321

Facility Code: 31018
Last Inspected On: 10/01/2024
Operating Permit Renewal Date: 01/28/2028

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Loves Travel Stops and Country Stores Inc		**environmental@loves.com**
Operator Contact:	Eric Bennett;Loves Travel Stops and Country Stores Inc;Ted Lowery;Loves Travel Stops and Country Stores Inc	**(405) 779-3768**	**environmental@loves.com;environmental@loves.com**

Owner/Operator: Loves Travel Stops and Country Stores Inc environmental@loves.com

Eric Bennett, UST Class A Operator	environmental@loves.com
Eric Bennett, UST Class B Operator	environmental@loves.com
Eric Candelaria, UST Class B Operator	environmental@loves.com
Ted Lowery, UST Class A Operator	environmental@loves.com
Ted Lowery, UST Class B Operator	environmental@loves.com

Tank Number	01	**Tank Age**	6	**Tank Installed Date**	08/15/2019	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	5830	**Spill Test Date**	09/20/2022	**Piping Installed Date**	08/15/2019	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	09/20/2022	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	Yes
Capacity	30000	**ATG Test Date**	01/22/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	Yes
		Overfill Test Date	09/20/2022			**ATG Type**	Incon/TS-550 EVO				
Tank Number	02	**Tank Age**	6	**Tank Installed Date**	08/15/2019	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	5831	**Spill Test Date**	09/20/2022	**Piping Installed Date**	08/15/2019	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	09/20/2022	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	11/15/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	Yes

		Overfill Test Date	09/20/2022			**ATG Type**	Incon/TS-550 EVO				
Tank Number	03	**Tank Age**	6	**Tank Installed Date**	08/15/2019	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	5832	**Spill Test Date**	09/20/2022	**Piping Installed Date**	08/15/2019	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	09/20/2022	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	11/15/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	Yes
		Overfill Test Date	09/20/2022			**ATG Type**	Incon/TS-550 EVO				
Tank Number	04	**Tank Age**	6	**Tank Installed Date**	08/15/2019	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	5833	**Spill Test Date**	09/20/2022	**Piping Installed Date**	08/15/2019	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	09/20/2022	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	30000	**ATG Test Date**	11/15/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	Yes
		Overfill Test Date	09/20/2022			**ATG Type**	Incon/TS-550 EVO				
Tank Number	05	**Tank Age**	6	**Tank Installed Date**	08/15/2019	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	5834	**Spill Test Date**	09/20/2022	**Piping Installed Date**	08/15/2019	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	09/20/2022	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Safe Suction	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	30000	**ATG Test Date**	11/15/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	Yes
		Overfill Test Date	09/20/2022			**ATG Type**	Incon/TS-550 EVO				
Tank Number	06	**Tank Age**	6	**Tank Installed Date**	08/15/2019	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	5835	**Spill Test Date**	09/22/2022	**Piping Installed Date**	08/15/2019	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No

Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	09/20/2022	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	30000	**ATG Test Date**	11/15/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	Yes
		Overfill Test Date	09/20/2022			**ATG Type**	Incon/TS-550 EVO				
Tank Number	07	**Tank Age**	6	**Tank Installed Date**	08/15/2019	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	5836	**Spill Test Date**	09/20/2022	**Piping Installed Date**	08/15/2019	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	09/20/2022	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Biodiesel B99	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	20000	**ATG Test Date**	11/15/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	Yes
		Overfill Test Date	09/20/2022			**ATG Type**	Incon/TS-550 EVO				
Tank Number	08	**Tank Age**	6	**Tank Installed Date**	08/15/2019	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	
Tag Number	5837	**Spill Test Date**		**Piping Installed Date**	08/15/2019	**Tank Construction**		**Piping Construction**		**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**		**Piping Type**	Pressurized	**CP Met Types**	
Product	DEF (Not Regulated)	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Not Listed	**Primary Pipe Leak Detection**	Not Listed	**Vapor Recovery**	No
Capacity	20000	**ATG Test Date**	11/29/2022	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Not Listed	**Energy Act**	Yes
		Overfill Test Date				**ATG Type**					
Tank Number	09	**Tank Age**	7	**Tank Installed Date**	10/26/2018	**Tank Material Construction**	Steel Clad	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	5863	**Spill Test Date**	10/01/2023	**Piping Installed Date**	12/17/2019	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	09/20/2022	**Catastrophic L.D. Type 3.0**	Auto Dialer	**Piping Type**	Safe Suction	**CP Met Types**	Non-corrodible
Product	Oil, Motor	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	2000	**ATG Test Date**	11/15/2023	**Line Tightness Test Date**	11/24/2020	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	Yes
		Overfill Test Date	02/24/2022			**ATG Type**	Incon/TS-550 EVO				

Tank Number	10	**Tank Age**	7	**Tank Installed Date**	10/26/2018	**Tank Material Construction**	Steel Clad	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	5864	**Spill Test Date**	10/01/2024	**Piping Installed Date**	12/17/2019	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	09/20/2022	**Catastrophic L.D. Type 3.0**	Auto Dialer	**Piping Type**	Safe Suction	**CP Met Types**	Non-corrodible
Product	Oil, Motor	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	11/15/2023	**Line Tightness Test Date**	11/24/2020	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	Yes
		Overfill Test Date	02/24/2022			**ATG Type**	Incon/TS-550 EVO				
Tank Number	11	**Tank Age**	7	**Tank Installed Date**	10/26/2018	**Tank Material Construction**	Steel Clad	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	5865	**Spill Test Date**	10/01/2024	**Piping Installed Date**	12/17/2019	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	09/20/2022	**Catastrophic L.D. Type 3.0**	Auto Dialer	**Piping Type**	Safe Suction	**CP Met Types**	Non-corrodible
Product	Oil, Motor	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	2000	**ATG Test Date**	11/15/2023	**Line Tightness Test Date**	11/24/2020	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	Yes
		Overfill Test Date	02/24/2022			**ATG Type**	Incon/TS-550 EVO				
Tank Number	12	**Tank Age**	7	**Tank Installed Date**	10/26/2018	**Tank Material Construction**	Steel Clad	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	5866	**Spill Test Date**	10/01/2023	**Piping Installed Date**	12/17/2019	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	09/20/2022	**Catastrophic L.D. Type 3.0**	Auto Dialer	**Piping Type**	Safe Suction	**CP Met Types**	Non-corrodible
Product	Oil, Motor	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	11/15/2023	**Line Tightness Test Date**	11/24/2020	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	Yes
		Overfill Test Date	02/24/2022			**ATG Type**	Incon/TS-550 EVO				
Tank Number	13	**Tank Age**	7	**Tank Installed Date**	10/26/2018	**Tank Material Construction**	Steel Clad	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	5867	**Spill Test Date**	10/01/2023	**Piping Installed Date**	12/17/2019	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	09/20/2022	**Catastrophic L.D. Type 3.0**	Auto Dialer	**Piping Type**	Safe Suction	**CP Met Types**	Non-corrodible

Product	Oil, Motor	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	2000	**ATG Test Date**	11/15/2023	**Line Tightness Test Date**	11/24/2020	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	Yes
		Overfill Test Date	02/24/2022			**ATG Type**	Incon/TS-550 EVO				
Tank Number	14	**Tank Age**	7	**Tank Installed Date**	10/26/2018	**Tank Material Construction**	Steel Clad	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	5868	**Spill Test Date**	10/01/2023	**Piping Installed Date**	12/17/2019	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	11/15/2023	**Catastrophic L.D. Type 3.0**	Auto Dialer	**Piping Type**	Safe Suction	**CP Met Types**	Non-corrodible
Product	Oil, Waste	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	7000	**ATG Test Date**	11/15/2023	**Line Tightness Test Date**	11/24/2020	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	Yes
		Overfill Test Date	02/24/2022			**ATG Type**	Incon/TS-550 EVO				
Tank Number	15	**Tank Age**	7	**Tank Installed Date**	10/26/2018	**Tank Material Construction**	Steel Clad	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	5869	**Spill Test Date**	10/01/2023	**Piping Installed Date**	12/17/2019	**Tank Construction**	Double-Walled	**Piping Construction**	Secondary Containment Chase	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	09/20/2022	**Catastrophic L.D. Type 3.0**	Auto Dialer	**Piping Type**	Safe Suction	**CP Met Types**	Non-corrodible
Product	Oil, Motor	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	2000	**ATG Test Date**	11/15/2023	**Line Tightness Test Date**	11/24/2020	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	Yes
		Overfill Test Date	02/24/2022			**ATG Type**	Incon/TS-550 EVO				

Facility Summary in Missoula County in the City of Missoula

Location: MDOT MISSOULA
2100 W Broadway St
Missoula, MT 59808-1816 Missoula

System Facility ID:32-09304

Facility Code: 25486
Last Inspected On: 03/11/2024
Operating Permit Renewal Date: 07/10/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	MDOT Helena	**(406) 444-6163**	**mmurolo@mt.gov**
Operator Contact:	Joe Radonich;Montana Dept of Transportation;Michael Carstensen;MDT 11 3211 Missoula W Broadway;Mike Murolo;Montana Dept of Transportation;Tracy Deeds;MDOT Helena;Walt Kerttula;Montana Dept of Transportation	**(406) 444-6151;(406) 444-7632;(406) 444-6163;(406) 444-7632;(406) 444-9204;(406) 444-7632;(406) 461-0769;(406) 444-6163;(406) 523-5836**	**jradonich@mt.gov;jradonich@mt.gov;mcarstensen@mt.gov;mmurolo@mt.gov;jradonich@mt.gov;tdeeds@mt.gov;mmurolo@mt.gov;wkerttula@mt.gov;jradonich@mt.gov**

Chad Pearson, UST Class B Operator	chpearson@mt.gov
Cody Crawford, UST Class B Operator	cocrawford@mt.gov
Joe Radonich, UST Class A Operator	jradonich@mt.gov
Joe Radonich, UST Class B Operator	jradonich@mt.gov
Michael Carstensen, UST Class A Operator	mcarstensen@mt.gov
Michael Carstensen, UST Class B Operator	mcarstensen@mt.gov
Mike Murolo, UST Class A Operator	jradonich@mt.gov
Tracy Deeds, UST Class A Operator	mmurolo@mt.gov
Walt Kerttula, UST Class A Operator	jradonich@mt.gov

Tank Number	01	**Tank Age**	41	**Tank Installed Date**	05/01/1984	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	2917	**Spill Test Date**	06/22/2021	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	03/11/2024	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	20000	**ATG Test Date**	03/11/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	09/30/2021			**ATG Type**	Gilbarco/EMC Basic				
Tank Number	06	**Tank Age**	38	**Tank Installed Date**	04/01/1987	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	2918	**Spill Test Date**	03/11/2024	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Galvanic

Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	03/11/2024	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	20000	**ATG Test Date**	03/11/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	03/11/2024			**ATG Type**	Gilbarco/EMC Basic				

Facility Summary in Missoula County in the City of Missoula

Location: MISSOULA #7 FLYING J
8745 Hwy 93 N
Missoula, MT 59808 Missoula

System Facility ID:60-15158

Facility Code: 30899
Last Inspected On: 06/27/2023
Operating Permit Renewal Date: 10/31/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Missoula 7 Town Pump LLC **(406) 497-6700** **environmental@townpump.com**

Operator Contact: Trent Biggers **Trentb@townpump.com**

Owner/Operator: Missoula 7 Town Pump LLC (406) 497-6700 environmental@townpump.com

Trent Biggers, UST Class A Operator Trentb@townpump.com

Trent Biggers, UST Class B Global Operator Trentb@townpump.com

Tank Number	01	**Tank Age**	15	**Tank Installed Date**	09/01/2010	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	5256	**Spill Test Date**	10/25/2022	**Piping Installed Date**	07/19/2010	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	05/07/2021	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	06/22/2023	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	30000	**ATG Test Date**	06/22/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Statistical Inventory Reconciliation	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	Yes
		Overfill Test Date	08/01/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-450				
Tank Number	02	**Tank Age**	15	**Tank Installed Date**	09/01/2010	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	5257	**Spill Test Date**	10/25/2022	**Piping Installed Date**	07/19/2010	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	05/07/2021	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	06/22/2023	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	30000	**ATG Test Date**	06/22/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Statistical Inventory Reconciliation	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	Yes
		Overfill Test Date	08/01/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-450				

Tank Number	03	**Tank Age**	15	**Tank Installed Date**	09/01/2010	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	5258	**Spill Test Date**	10/25/2022	**Piping Installed Date**	07/19/2010	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	05/07/2021	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	06/22/2023	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	25000	**ATG Test Date**	06/22/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Statistical Inventory Reconciliation	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	Yes
		Overfill Test Date	08/01/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-450				
Tank Number	04	**Tank Age**	15	**Tank Installed Date**	09/01/2010	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve
Tag Number	5259	**Spill Test Date**	10/25/2022	**Piping Installed Date**	07/19/2010	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	05/07/2021	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	06/22/2023	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	Yes
Capacity	30000	**ATG Test Date**	06/22/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Statistical Inventory Reconciliation	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	Yes
		Overfill Test Date	08/01/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-450				
Tank Number	05	**Tank Age**	15	**Tank Installed Date**	09/01/2010	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	5260	**Spill Test Date**	10/25/2022	**Piping Installed Date**	07/19/2010	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	05/07/2021	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	06/22/2023	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	Yes
Capacity	8000	**ATG Test Date**	06/22/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Statistical Inventory Reconciliation	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	Yes
		Overfill Test Date	08/01/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-450				
Tank Number	06	**Tank Age**	15	**Tank Installed Date**	09/01/2010	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve
Tag Number	5261	**Spill Test Date**	10/25/2022	**Piping Installed Date**	07/19/2010	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No

Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	05/07/2021	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	06/22/2023	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	Yes
Capacity	15000	**ATG Test Date**	06/22/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Statistical Inventory Reconciliation	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	Yes
		Overfill Test Date	08/01/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-450				
Tank Number	07	**Tank Age**	15	**Tank Installed Date**	09/01/2010	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	5262	**Spill Test Date**	10/25/2022	**Piping Installed Date**	07/19/2010	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	05/07/2021	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	06/22/2023	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	06/22/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Statistical Inventory Reconciliation	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	Yes
		Overfill Test Date	08/01/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-450				
Tank Number	08	**Tank Age**	15	**Tank Installed Date**	09/01/2010	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve
Tag Number	5331	**Spill Test Date**	10/25/2022	**Piping Installed Date**	07/19/2010	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	05/07/2021	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	06/22/2023	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	Yes
Capacity	6000	**ATG Test Date**	06/22/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Statistical Inventory Reconciliation	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	Yes
		Overfill Test Date	08/01/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-450				
Tank Number	09	**Tank Age**	15	**Tank Installed Date**	09/01/2010	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	5361	**Spill Test Date**		**Piping Installed Date**	04/11/2012	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Other**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Continuous Interstitial Monitoring	**Piping Type**	Not Listed	**CP Met Types**	

Product	DEF (Not Regulated)	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Approved Remote Monitoring;Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Approved Remote Monitoring;Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	Yes
		Overfill Test Date				**ATG Type**					

Facility Summary in Missoula County in the City of Missoula

Location: MISSOULA AIRPORT WASHINGTON HANGER
5225 W Broadway St
Missoula, MT 59808-9385 Missoula

System Facility ID:32-07606

Facility Code: 25444
Last Inspected On: 03/20/2023
Operating Permit Renewal Date: 05/25/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Washington Corporations **(406) 523-1349**

Operator Contact: Andrew Ihle;Missoula Airport Washington Hanger;Roy Felt;Ryan Opheim **(406) 214-8531** **aihle@washcorp.com;rfelt@washcorp.com;ropheim@washcorp.com**

Owner/Operator: Washington Corporations (406) 523-1349

Andrew Ihle, UST Class A Operator	aihle@washcorp.com
Andrew Ihle, UST Class B Operator	aihle@washcorp.com
Roy Felt, UST Class A Operator	rfelt@washcorp.com
Roy Felt, UST Class A Operator	rfelt@washcorp.com
Roy Felt, UST Class B Global Operator	rfelt@washcorp.com
Roy Felt, UST Class B Global Operator	rfelt@washcorp.com
Ryan Opheim, UST Class A Operator	ropheim@washcorp.com
Ryan Opheim, UST Class A Operator	ropheim@washcorp.com
Ryan Opheim, UST Class B Operator	ropheim@washcorp.com
Ryan Opheim, UST Class B Operator	ropheim@washcorp.com

Tank Number	01	**Tank Age**	41	**Tank Installed Date**	05/07/1984	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve;High Level Alarm
Tag Number	2242	**Spill Test Date**	03/20/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	07/17/2024	**Sump Tightness Test Date**	03/20/2023	**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Jet Fuel (Jet-A, Jet-A1, JP5)	**PLLD Test Date**		**Tank/Piping CP Test Date**	02/26/2020	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	07/17/2024	**Line Tightness Test Date**	03/20/2023	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	07/17/2024			**ATG Type**	Veeder Root/TLS-300				

Facility Summary in Missoula County in the City of Missoula

Location: MISSOULA CHEVROLET
3663 N Reserve St
Missoula, MT 59808-1509 Missoula

System Facility ID:56-14056

Facility Code: 30710
Last Inspected On: 05/13/2023
Operating Permit Renewal Date: 09/10/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	MISSOULA MOTOR COMPANY LLC	**(406) 721-2438**	**terryh@missoulamc.com**
Operator Contact:	Terry Hedrick	**(406) 532-2437**	**terryh@missoulamc.com**

Owner/Operator: MISSOULA MOTOR COMPANY LLC (406) 721-2438 terryh@missoulamc.com
Terry Hedrick, UST Class A Operator terryh@missoulamc.com
Terry Hedrick, UST Class B Operator terryh@missoulamc.com

Tank Number	02	**Tank Age**	23	**Tank Installed Date**	07/22/2002	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve;High Level Alarm
Tag Number	4695	**Spill Test Date**	11/17/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	11/17/2022	**Sump Tightness Test Date**	08/10/2020	**Catastrophic L.D. Type 3.0**	Continuous Interstitial Monitoring;Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**	11/17/2022	**Line Tightness Test Date**	09/20/2020	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	11/17/2022			**ATG Type**	Veeder Root/TLS-300				
Tank Number	03	**Tank Age**	23	**Tank Installed Date**	07/22/2002	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve;High Level Alarm
Tag Number	4696	**Spill Test Date**	11/17/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	11/17/2022	**Sump Tightness Test Date**	08/10/2020	**Catastrophic L.D. Type 3.0**	Continuous Interstitial Monitoring;Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No

Capacity	4000	**ATG Test Date**	11/17/2022	**Line Tightness Test Date**	09/20/2020	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	11/17/2022			**ATG Type**	Veeder Root/TLS-300				
Tank Number	S1	**Tank Age**	23	**Tank Installed Date**	07/30/2002	**Tank Material Construction**	Aboveground Tank	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	4699	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	Yes
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	08/10/2020	**Catastrophic L.D. Type 3.0**	Continuous Interstitial Monitoring	**Piping Type**	Pressurized	**CP Met Types**	
Product	Oil, Waste	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	11/17/2022	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					

Facility Summary in Missoula County in the City of Missoula

Location: MISSOULA COUNTY DETENTION CENTER
2340 Mullan Rd
Missoula, MT 59808-1830 Missoula

System Facility ID:56-13921

Facility Code: 30591
Last Inspected On: 11/14/2022
Operating Permit Renewal Date: 11/22/2025

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Missoula County Detention Center **(406) 829-4000**

Operator Contact: Gary Zinke;Jess Ebel **(406) 531-3627** **gezinke@missoulacounty.us;jebel@missoulacounty.us**

Owner/Operator: Missoula County Detention Center (406) 829-4000

Gary Zinke, UST Class A Operator	gezinke@missoulacounty.us
Gary Zinke, UST Class B Operator	gezinke@missoulacounty.us
Jess Ebel, UST Class A Operator	jebel@missoulacounty.us
Jess Ebel, UST Class B Operator	jebel@missoulacounty.us

Tank Number	S1	**Tank Age**	26	**Tank Installed Date**	06/01/1999	**Tank Material Construction**	Unknown	**Piping Material**	Copper	**Overfill Types**	
Tag Number	3774	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Secondary Containment Chase	**AST**	Yes
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	10/10/2024	**Catastrophic L.D. Type 3.0**	Continuous Interstitial Monitoring	**Piping Type**	Pressurized	**CP Met Types**	
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	3000	**ATG Test Date**	10/10/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					

Facility Summary in Missoula County in the City of Missoula

Location: MISSOULA SERVICE CENTER
1900 S Russell St
Missoula, MT 59801-6624 Missoula

System Facility ID:32-01182

Facility Code: 25203
Last Inspected On: 01/18/2023
Operating Permit Renewal Date: 06/13/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Northwestern Energy Butte	**(406) 655-2521**	**beth.stimatz@northwestern.com**
Operator Contact:	Brian Ranf;John Habeger		**brian.ranf@northwestern.com;john.habeger@northwestern.com**

Owner/Operator:	Northwestern Energy Butte	(406) 655-2521	beth.stimatz@northwestern.com
	Brian Ranf, UST Class A Operator		brian.ranf@northwestern.com
	Bruce Schlichenmayer, UST Class B Operator		bruce.schlichenmayer@northwestern.com
	Bruce Schlichenmayer, UST Class B Operator		bruce.schlichenmayer@northwestern.com
	Greg Sponseller, UST Class B Operator		gregory.sponseller@northwestern.com
	Greg Sponseller, UST Class B Operator		gregory.sponseller@northwestern.com
	Joe Vigue, UST Class B Operator		
	Joe Vigue, UST Class B Operator		
	John Habeger, UST Class A Operator		john.habeger@northwestern.com
	John Habeger, UST Class A Operator		john.habeger@northwestern.com

Tank Number	04	**Tank Age**	35	**Tank Installed Date**	07/27/1990	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	1680	**Spill Test Date**	08/25/2021	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	01/18/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	13000	**ATG Test Date**	07/19/2022	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	08/25/2021			**ATG Type**	Gilbarco-Veeder Root/TLS-300				
Tank Number	05	**Tank Age**	35	**Tank Installed Date**	07/27/1990	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	1681	**Spill Test Date**	08/25/2021	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Galvanic

Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	01/18/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	3000	**ATG Test Date**	07/19/2022	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	08/25/2021			**ATG Type**	Gilbarco-Veeder Root/TLS-300				

Facility Summary in Missoula County in the City of Missoula

Location: MISSOULA TRAVEL CENTER
8018 US Hwy 93 N
Missoula, MT 59808 Missoula

System Facility ID:32-02822

Facility Code: 25272
Last Inspected On: 08/17/2023
Operating Permit Renewal Date: 04/15/2019

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	TA Operating LLC	**(440) 808-7406**	**kgelske@ta-petro.com**
Operator Contact:	Ben Waverek;TA Operating LLC;Daniel Stubbs;TA Operating LLC;Kelly Gelske	**(406) 549-2327;(440) 808-7406;(440) 522-6761**	**bwaverek@ta-petro.com;kgelske@ta-petro.com;dstubbs@ta-petro.com;kgelske@ta-petro.com;kgelske@ta-petro.com**

Owner/Operator: TA Operating LLC (440) 808-7406 kgelske@ta-petro.com

Ben Waverek, UST Class A Operator	kgelske@ta-petro.com
Ben Waverek, UST Class B Operator	kgelske@ta-petro.com
Daniel Stubbs, UST Class A Operator	kgelske@ta-petro.com
Daniel Stubbs, UST Class B Operator	kgelske@ta-petro.com
Kelly Gelske, UST Class A Operator	kgelske@ta-petro.com
Kelly Gelske, UST Class B Global Operator	kgelske@ta-petro.com

Tank Number	13	**Tank Age**	11	**Tank Installed Date**	08/22/2014	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	5511	**Spill Test Date**		**Piping Installed Date**	07/29/2014	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Other**	**MLLD Test Date**		**Sump Tightness Test Date**	08/18/2014	**Catastrophic L.D. Type 3.0**		**Piping Type**	Pressurized	**CP Met Types**	
Product	DEF (Not Regulated)	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	Yes
Capacity	12000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Not Listed	**Energy Act**	No
		Overfill Test Date				**ATG Type**	Veeder Root/TLS-4I, B, C				
Tank Number	14	**Tank Age**	10	**Tank Installed Date**	02/24/2015	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve;High Level Alarm
Tag Number	5550	**Spill Test Date**		**Piping Installed Date**	09/18/2014	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	04/30/2020	**Catastrophic L.D. Type 3.0**	Continuous Interstitial Monitoring	**Piping Type**	U.S. Suction	**CP Met Types**	Non-corrodible
Product	Oil, Motor	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**		**Line Tightness Test Date**	03/12/2015	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	Yes

		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Number	15	**Tank Age**	10	**Tank Installed Date**	02/24/2015	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve;High Level Alarm
Tag Number	5551	**Spill Test Date**		**Piping Installed Date**	09/18/2014	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	04/30/2020	**Catastrophic L.D. Type 3.0**	Continuous Interstitial Monitoring	**Piping Type**	Gravity Feed	**CP Met Types**	Non-corrodible
Product	Oil, Waste	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**		**Line Tightness Test Date**	03/12/2015	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	Yes
		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Number	16	**Tank Age**	6	**Tank Installed Date**	07/31/2019	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	5929	**Spill Test Date**		**Piping Installed Date**	07/31/2019	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	04/30/2020	**Sump Tightness Test Date**	04/30/2020	**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**		**Line Tightness Test Date**	04/30/2020	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	MLLD Line Tightness Testing	**Energy Act**	Yes
		Overfill Test Date				**ATG Type**					
Tank Number	01	**Tank Age**	47	**Tank Installed Date**	02/17/1978	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	785	**Spill Test Date**		**Piping Installed Date**	06/10/2010	**Tank Construction**	Lined Interior/Impressed Current	**Piping Construction**	Double Walled	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**	08/18/2014	**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	07/18/2017	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2;Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	20000	**ATG Test Date**		**Line Tightness Test Date**	07/18/2017	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring;MLLD Line Tightness Testing	**Energy Act**	No

		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	02	**Tank Age**	47	**Tank Installed Date**	02/17/1978	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	786	**Spill Test Date**	02/01/2024	**Piping Installed Date**	08/22/2014	**Tank Construction**	Lined Interior/Impressed Current	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	02/01/2024	**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	05/16/2019	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**		**Line Tightness Test Date**	07/18/2017	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Number	03	**Tank Age**	47	**Tank Installed Date**	02/17/1978	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	787	**Spill Test Date**		**Piping Installed Date**	08/22/2014	**Tank Construction**	Lined Interior/Impressed Current	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	05/19/2021	**Sump Tightness Test Date**	02/01/2024	**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	05/16/2019	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**		**Line Tightness Test Date**	05/19/2021	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Number	09	**Tank Age**	32	**Tank Installed Date**	11/01/1993	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	788	**Spill Test Date**		**Piping Installed Date**	08/22/2014	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	04/30/2020	**Catastrophic L.D. Type 3.0**		**Piping Type**	Safe Suction	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**	04/30/2020	**Tank/Piping CP Test Date**	05/16/2020	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**		**Line Tightness Test Date**	04/30/2020	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				

Tank Number	10	**Tank Age**	32	**Tank Installed Date**	11/01/1993	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	789	**Spill Test Date**		**Piping Installed Date**	08/22/2014	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	04/30/2020	**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	05/16/2020	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**		**Line Tightness Test Date**	08/04/2014	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Number	11	**Tank Age**	32	**Tank Installed Date**	11/01/1993	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	790	**Spill Test Date**		**Piping Installed Date**	11/03/2010	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	08/18/2014	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**	04/30/2020	**Tank/Piping CP Test Date**	05/16/2019	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**		**Line Tightness Test Date**	04/30/2020	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Number	12	**Tank Age**	32	**Tank Installed Date**	11/01/1993	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	791	**Spill Test Date**		**Piping Installed Date**	11/03/2010	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	08/18/2014	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**	04/30/2020	**Tank/Piping CP Test Date**	05/16/2019	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**		**Line Tightness Test Date**	04/30/2020	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				

Facility Summary in Missoula County in the City of Missoula

Location: MISSOULA URBAN TRANSPORTATION
1221 Shakespeare St
Missoula, MT 59802-2307 Missoula

System Facility ID:32-04427

Facility Code: 25341
Last Inspected On: 03/24/2023
Operating Permit Renewal Date: 06/05/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Missoula Urban Transportation

Operator Contact: Jeffrey Logan;John Roseboom **(406) 215-2455;(406) 215-2458** **jlogan@mountainline.com;john@mountainline.com**

Owner/Operator: Missoula Urban Transportation

Brian Dildine, UST Class B Operator	bdildine@mountainline.com
Cody Bush, UST Class B Operator	cbush@mountainline.com
Cody Bush, UST Class B Operator	cbush@mountainline.com
David Loewen, UST Class B Operator	
David Loewen, UST Class B Operator	
Jacob Nolen, UST Class B Operator	jnolen@mountainline.com
Jacob Nolen, UST Class B Operator	jnolen@mountainline.com
Jeffrey Logan, UST Class A Operator	jlogan@mountainline.com
Jeffrey Logan, UST Class A Operator	jlogan@mountainline.com
Jeffrey Logan, UST Class B Operator	jlogan@mountainline.com
Jeffrey Logan, UST Class B Operator	jlogan@mountainline.com
John Roseboom, UST Class A Operator	john@mountainline.com
John Roseboom, UST Class B Operator	john@mountainline.com
Kent Russell, UST Class B Operator	krussell@mountainline.com
Kent Russell, UST Class B Operator	krussell@mountainline.com

Tank Number	04	**Tank Age**	27	**Tank Installed Date**	04/30/1998	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve;High Level Alarm
Tag Number	1658	**Spill Test Date**	03/24/2023	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	03/24/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No

		Overfill Test Date	03/24/2023			**ATG Type**	Gilbarco/EMC Basic;Gilbarco-Veeder Root/EMC Basic				
Tank Number	05	**Tank Age**	27	**Tank Installed Date**	04/30/1998	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	1659	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	03/24/2023	**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Gravity Feed	**CP Met Types**	Non-corrodible
Product	Oil, Waste	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	600	**ATG Test Date**	03/24/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	03/24/2023			**ATG Type**	Gilbarco/EMC Basic;Gilbarco-Veeder Root/EMC Basic				

Facility Summary in Missoula County in the City of Missoula

Location: MOUNTAIN WEST COOP
4570 N Reserve St
Missoula, MT 59808 Missoula

System Facility ID:32-02437

Facility Code: 25260
Last Inspected On: 03/27/2024
Operating Permit Renewal Date: 06/15/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	CHS Inc Inver Grove Heights	**(651) 355-6343**	**Kirsten.Tindall@chsinc.com**
Operator Contact:	Bob Westin;Dusty Smith;John Thompson;Michael Gourley;CHS Inc Inver Grove Heights;Robin McCurdy;Will Dukart	**(406) 370-3920;(651) 355-6343;(406) 546-4885;(406) 665-1728;(406) 880-8169**	**chuck.thompson@chsinc.com;dusty.smith@chsinc.com;michael.gourley@chsinc.com;Kirsten.Tindall@chsinc.com;robin.mccurdy@chsinc.com;will.dukart@chsinc.com**
Owner/Operator:	CHS Inc Inver Grove Heights	(651) 355-6343	Kirsten.Tindall@chsinc.com
	Bill Griffin, UST Class B Operator		
	Bill Griffin, UST Class B Operator		
	Bob Westin, UST Class A Operator		
	Bob Westin, UST Class B Global Operator		
	Dusty Smith, UST Class A Operator		dusty.smith@chsinc.com
	Dusty Smith, UST Class B Global Operator		dusty.smith@chsinc.com
	John Thompson, UST Class A Operator		chuck.thompson@chsinc.com
	John Thompson, UST Class A Operator		chuck.thompson@chsinc.com
	John Thompson, UST Class B Global Operator		chuck.thompson@chsinc.com
	John Thompson, UST Class B Global Operator		chuck.thompson@chsinc.com
	John Thompson, UST Class B Operator		chuck.thompson@chsinc.com
	John Thompson, UST Class B Operator		chuck.thompson@chsinc.com
	Michael Gourley, UST Class A Operator		Kirsten.Tindall@chsinc.com
	Mike Dunlon, UST Class B Operator		michael.dunlop@chsinc.com
	Mike Dunlon, UST Class B Operator		michael.dunlop@chsinc.com
	Robin McCurdy, UST Class A Operator		robin.mccurdy@chsinc.com
	Robin McCurdy, UST Class B Operator		robin.mccurdy@chsinc.com
	Will Dukart, UST Class A Operator		will.dukart@chsinc.com
	Will Dukart, UST Class A Operator		will.dukart@chsinc.com

Tank Number	16	**Tank Age**	30	**Tank Installed Date**	03/29/1995	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve;High Level Alarm
Tag Number	2859	**Spill Test Date**	10/07/2021	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	10/07/2021	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**	03/26/2024	**Tank/Piping CP Test Date**	03/27/2024	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No

Capacity	4000	**ATG Test Date**	02/27/2024	**Line Tightness Test Date**	06/12/2014	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	03/27/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	17	**Tank Age**	11	**Tank Installed Date**	11/01/2014	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	5554	**Spill Test Date**	10/07/2021	**Piping Installed Date**	01/16/2015	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	10/07/2021	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	03/26/2024	**Tank/Piping CP Test Date**	03/27/2024	**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	25000	**ATG Test Date**	03/27/2024	**Line Tightness Test Date**	01/16/2015	**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	03/27/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350;Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	18	**Tank Age**	11	**Tank Installed Date**	11/01/2014	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	5555	**Spill Test Date**	10/07/2021	**Piping Installed Date**	01/16/2015	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	10/07/2021	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	03/26/2024	**Tank/Piping CP Test Date**	03/27/2024	**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	Yes
Capacity	25000	**ATG Test Date**	03/27/2024	**Line Tightness Test Date**	01/16/2015	**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	03/27/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350;Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	19	**Tank Age**	11	**Tank Installed Date**	11/01/2014	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	5556	**Spill Test Date**	10/07/2021	**Piping Installed Date**	01/16/2015	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	10/07/2021	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	03/26/2024	**Tank/Piping CP Test Date**	03/27/2024	**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No

Capacity	10000	**ATG Test Date**	03/27/2024	**Line Tightness Test Date**	01/16/2015	**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	03/27/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350;Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	20	**Tank Age**	11	**Tank Installed Date**	11/01/2014	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	5557	**Spill Test Date**	10/07/2021	**Piping Installed Date**	01/16/2015	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	10/07/2021	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	03/26/2024	**Tank/Piping CP Test Date**	03/27/2024	**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**	03/27/2024	**Line Tightness Test Date**	01/16/2015	**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	03/27/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350;Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	21	**Tank Age**	11	**Tank Installed Date**	11/01/2014	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	5558	**Spill Test Date**	10/07/2021	**Piping Installed Date**	01/16/2015	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	10/07/2021	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	03/26/2024	**Tank/Piping CP Test Date**	03/27/2024	**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	03/27/2024	**Line Tightness Test Date**	01/16/2015	**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	10/07/2021			**ATG Type**	Gilbarco-Veeder Root/TLS-350;Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	22	**Tank Age**	11	**Tank Installed Date**	11/01/2014	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	5559	**Spill Test Date**	10/07/2021	**Piping Installed Date**	01/16/2015	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	10/07/2021	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	03/26/2024	**Tank/Piping CP Test Date**	03/27/2024	**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	Yes

Capacity	10000	**ATG Test Date**	03/27/2024	**Line Tightness Test Date**	09/16/2022	**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	03/27/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350;Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Missoula County in the City of Missoula

Location: MURALTS TRUCK PLAZA
8800 Truck Stop Rd
Missoula, MT 59808-9708 Missoula

System Facility ID:32-00146

Facility Code: 25157
Last Inspected On: 12/20/2023
Operating Permit Renewal Date: 01/14/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Muralts Inc;Walter Muralt	**(406) 728-4700**	**walt@muralts.com**
Operator Contact:	Curtis Wilson	**(406) 207-5448**	**curtis@muralts.com**

Owner/Operator: Muralts Inc (406) 728-4700

Owner/Operator: Walter Muralt (406) 728-4700

Bonnie Kelley, UST Class B Global Operator	bonnie@muralts.com
Curtis Wilson, UST Class A Operator	curtis@muralts.com
Curtis Wilson, UST Class A Operator	curtis@muralts.com
Curtis Wilson, UST Class B Operator	curtis@muralts.com
Curtis Wilson, UST Class B Operator	curtis@muralts.com
Kevin Linton, UST Class B Operator	jesselinton14@gmail.com

Tank Number	10	**Tank Age**	30	**Tank Installed Date**	11/01/1995	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	1734	**Spill Test Date**		**Piping Installed Date**	01/12/2016	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	12/17/2020	**Tank/Piping CP Test Date**	05/19/2009	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**		**Line Tightness Test Date**	01/08/2021	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/TLS-450				
Tank Number	11	**Tank Age**	30	**Tank Installed Date**	11/01/1995	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	1735	**Spill Test Date**		**Piping Installed Date**	01/12/2016	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	12/17/2020	**Tank/Piping CP Test Date**	05/19/2009	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No

Capacity	5000	**ATG Test Date**		**Line Tightness Test Date**	01/08/2021	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/TLS-450				
Tank Number	01	**Tank Age**	57	**Tank Installed Date**	03/26/1968	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	3650	**Spill Test Date**		**Piping Installed Date**	01/12/2016	**Tank Construction**	Lined Interior/Impressed Current	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Diesel	**PLLD Test Date**	12/17/2020	**Tank/Piping CP Test Date**	07/23/2018	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**		**Line Tightness Test Date**	01/08/2021	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/TLS-450				
Tank Number	02	**Tank Age**	57	**Tank Installed Date**	03/26/1968	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	3651	**Spill Test Date**		**Piping Installed Date**	01/12/2016	**Tank Construction**	Lined Interior/Impressed Current	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Diesel	**PLLD Test Date**	12/17/2020	**Tank/Piping CP Test Date**	07/23/2018	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**		**Line Tightness Test Date**	01/08/2021	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/TLS-450				
Tank Number	03	**Tank Age**	57	**Tank Installed Date**	03/26/1968	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	3652	**Spill Test Date**		**Piping Installed Date**	01/12/2016	**Tank Construction**	Lined Interior/Impressed Current	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Diesel	**PLLD Test Date**	12/17/2020	**Tank/Piping CP Test Date**	07/23/2018	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**		**Line Tightness Test Date**	01/08/2021	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/TLS-450				

Tank Number	04	**Tank Age**	57	**Tank Installed Date**	03/26/1968	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Steel	**Overfill Types**	Flapper Valve
Tag Number	3653	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**	Lined Interior/Impressed Current	**Piping Construction**	Single Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**	12/17/2020	**Tank/Piping CP Test Date**	07/23/2018	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**		**Line Tightness Test Date**	01/08/2021	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/TLS-450				
Tank Number	05	**Tank Age**	57	**Tank Installed Date**	03/26/1968	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Steel	**Overfill Types**	Flapper Valve
Tag Number	3654	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**	Lined Interior/Impressed Current	**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Diesel	**PLLD Test Date**	12/17/2020	**Tank/Piping CP Test Date**	07/23/2018	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**		**Line Tightness Test Date**	01/08/2021	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/TLS-450				
Tank Number	06	**Tank Age**	52	**Tank Installed Date**	03/26/1973	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Steel	**Overfill Types**	Flapper Valve
Tag Number	3655	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**	Lined Interior/Impressed Current	**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**	12/17/2020	**Tank/Piping CP Test Date**	07/23/2018	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**		**Line Tightness Test Date**	01/08/2021	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/TLS-450				

Facility Summary in Missoula County in the City of Missoula

Location: OLES COUNTRY STORE 11
1600 S Russell St
Missoula, MT 59801-5637 Missoula

System Facility ID:32-04620

Facility Code: 25345
Last Inspected On: 10/22/2024
Operating Permit Renewal Date: 03/05/2028

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	DDJ Investments LLC;Jennifer Louquet	**(406) 728-7618**	**olescs11@gmail.com**
Operator Contact:	Derek Louquet	**(406) 369-5855**	**derek.louquet@gmail.com**

Owner/Operator:	DDJ Investments LLC	(406) 728-7618	olescs11@gmail.com
Owner/Operator:	Jennifer Louquet	(406) 728-7618	olescs11@gmail.com
	Derek Louquet, UST Class A Operator		derek.louquet@gmail.com
	Derek Louquet, UST Class A Operator		derek.louquet@gmail.com
	Mary Fleming, UST Class B Operator		olescs11@gmail.com

Tank Number	04	**Tank Age**	37	**Tank Installed Date**	10/30/1988	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	1721	**Spill Test Date**	04/15/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	02/06/2024	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	10/23/2024	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	02/06/2024	**Line Tightness Test Date**	02/06/2024	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	02/06/2024			**ATG Type**	Gilbarco/EMC Basic				
Tank Number	05	**Tank Age**	37	**Tank Installed Date**	10/30/1988	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	1722	**Spill Test Date**	10/27/2021	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	02/06/2024	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	10/23/2024	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	02/06/2024	**Line Tightness Test Date**	02/06/2024	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	02/06/2024			**ATG Type**	Gilbarco/EMC Basic				

Tank Number	06	**Tank Age**	37	**Tank Installed Date**	10/30/1988	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	1723	**Spill Test Date**	10/27/2021	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	02/06/2024	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	10/23/2024	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**	02/06/2024	**Line Tightness Test Date**	02/06/2024	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	02/06/2024			**ATG Type**	Gilbarco/EMC Basic				

Facility Summary in Missoula County in the City of Missoula

Location: OLES COUNTRY STORE 12
3705 MT Hwy 200 E
Missoula, MT 59802 Missoula

System Facility ID:32-03190

Facility Code: 25284
Last Inspected On: 10/27/2022
Operating Permit Renewal Date: 02/09/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Tri East Inc **(406) 728-7736**

Operator Contact: Peggy Wolfe **peggy_wlf@yahoo.com**

Owner/Operator: Tri East Inc (406) 728-7736

LeeAnn Dean, UST Class B Global Operator
LeeAnn Dean, UST Class B Global Operator
Peggy Wolfe, UST Class A Operator peggy_wlf@yahoo.com
Peggy Wolfe, UST Class A Operator peggy_wlf@yahoo.com
Peggy Wolfe, UST Class B Operator peggy_wlf@yahoo.com
Peggy Wolfe, UST Class B Operator peggy_wlf@yahoo.com

Tank Number	01	**Tank Age**	61	**Tank Installed Date**	05/01/1964	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	1427	**Spill Test Date**	07/12/2021	**Piping Installed Date**	01/11/2018	**Tank Construction**	Lined Interior/Impressed Current	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	07/12/2021	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**	07/20/2022	**Tank/Piping CP Test Date**	07/20/2022	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	03/21/2025	**Line Tightness Test Date**	04/21/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date	07/20/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Number	02	**Tank Age**	61	**Tank Installed Date**	05/01/1964	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	1428	**Spill Test Date**	07/12/2021	**Piping Installed Date**	01/11/2018	**Tank Construction**	Lined Interior/Impressed Current	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	07/12/2021	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current

Product	Diesel	**PLLD Test Date**	07/20/2022	**Tank/Piping CP Test Date**	07/20/2022	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	03/21/2025	**Line Tightness Test Date**	04/21/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date	07/20/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Number	03	**Tank Age**	61	**Tank Installed Date**	05/01/1964	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	1429	**Spill Test Date**	07/12/2021	**Piping Installed Date**	01/11/2018	**Tank Construction**	Lined Interior/Impressed Current	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	07/12/2021	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Diesel	**PLLD Test Date**	07/20/2022	**Tank/Piping CP Test Date**	07/20/2022	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	03/21/2025	**Line Tightness Test Date**	04/21/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date	07/20/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Number	04	**Tank Age**	61	**Tank Installed Date**	05/01/1964	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	1430	**Spill Test Date**	07/12/2021	**Piping Installed Date**	01/11/2018	**Tank Construction**	Lined Interior/Impressed Current	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	07/12/2021	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**	07/20/2022	**Tank/Piping CP Test Date**	07/20/2022	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	03/21/2025	**Line Tightness Test Date**	04/21/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date	07/20/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Number	05	**Tank Age**	46	**Tank Installed Date**	05/02/1979	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	1431	**Spill Test Date**	07/12/2021	**Piping Installed Date**	01/11/2018	**Tank Construction**	Lined Interior/Impressed Current	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	07/12/2021	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**	07/20/2022	**Tank/Piping CP Test Date**	07/20/2022	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No

Capacity	4000	**ATG Test Date**	03/21/2025	**Line Tightness Test Date**	04/21/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date	07/20/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				

Facility Summary in Missoula County in the City of Missoula

Location: OLES COUNTRY STORE 2
923 N Orange St
Missoula, MT 59802-2927 Missoula

System Facility ID:32-05216

Facility Code: 25359
Last Inspected On: 11/08/2022
Operating Permit Renewal Date: 03/14/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Oles Country Stores Inc Missoula

Operator Contact: Casie Schwindt **rschwindt92@yahoo.com**

Owner/Operator: Oles Country Stores Inc Missoula

Casie Schwindt, UST Class A Operator	rschwindt92@yahoo.com
Casie Schwindt, UST Class A Operator	rschwindt92@yahoo.com
Casie Schwindt, UST Class B Operator	rschwindt92@yahoo.com
Casie Schwindt, UST Class B Operator	rschwindt92@yahoo.com

Tank Number	04	**Tank Age**	35	**Tank Installed Date**	09/25/1990	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	2357	**Spill Test Date**	11/08/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Secondary Containment Chase	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	11/08/2022	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	15000	**ATG Test Date**	11/08/2022	**Line Tightness Test Date**	08/22/2007	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	12/09/2022			**ATG Type**	Gilbarco/EMC Basic				
Tank Number	05	**Tank Age**	35	**Tank Installed Date**	09/25/1990	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	2358	**Spill Test Date**	11/08/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Secondary Containment Chase	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	10/07/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	11/08/2022	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	11/08/2022	**Line Tightness Test Date**	10/07/2024	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	12/09/2022			**ATG Type**	Gilbarco/EMC Basic				

Tank Number	06	**Tank Age**	35	**Tank Installed Date**	09/25/1990	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	2359	**Spill Test Date**	11/08/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Secondary Containment Chase	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	11/08/2022	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	11/08/2022	**Line Tightness Test Date**	08/22/2007	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	12/09/2022			**ATG Type**	Gilbarco/EMC Basic				

Facility Summary in Missoula County in the City of Missoula

Location: PHILLIPS 66 EXXON MOBIL JOINTLY OWNED MISSOULA TERMINAL
3330 Raser Dr
Missoula, MT 59808-1534 Missoula

System Facility ID:32-08732

Facility Code: 25472
Last Inspected On: 01/23/2025
Operating Permit Renewal Date: 06/09/2028

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Phillips 66/Exxon Mobil Jointly Owned Missoula Terminal	**(406) 255-5714**	**allen.eggen@p66.com**
Operator Contact:	Chris Cote;Phillips 66/Exxon Mobil Jointly Owned Missoula Terminal;Tanner Beadles;Phillips 66/Exxon Mobil Jointly Owned Missoula Terminal	**(406) 255-5714**	**chris.r.cote@p66.com;allen.eggen@p66.com;tanner.j.beadles@p66.com;allen.eggen@p66.com**

Owner/Operator:	Phillips 66/Exxon Mobil Jointly Owned Missoula Terminal	(406) 255-5714	allen.eggen@p66.com
	Andrew Snyder, UST Class B Operator		andrew.a.snyder@conocophillips.com
	Andrew Snyder, UST Class B Operator		andrew.a.snyder@conocophillips.com
	Chris Binder, UST Class B Operator		
	Chris Binder, UST Class B Operator		
	Chris Cote, UST Class A Operator		allen.eggen@p66.com
	Chris Cote, UST Class B Operator		allen.eggen@p66.com
	Dusty Nagel, UST Class B Operator		dusty.a.nagel@p66.com
	Orlando Rodriguez, UST Class B Operator		orlando.r.rodriquez@conocophillips.com
	Orlando Rodriguez, UST Class B Operator		orlando.r.rodriquez@conocophillips.com
	Tanner Beadles, UST Class A Operator		allen.eggen@p66.com
	Tanner Beadles, UST Class B Operator		allen.eggen@p66.com

Tank Number	S15	**Tank Age**	71	**Tank Installed Date**	06/01/1954	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Steel - Terminal Piping	**Overfill Types**	
Tag Number	2793	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	Yes
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Pressurized	**CP Met Types**	
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	05/21/2024	**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**	Terminal Piping Annual Line Test	**Vapor Recovery**	No
Capacity	630000	**ATG Test Date**		**Line Tightness Test Date**	09/03/2024	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	S18	**Tank Age**	71	**Tank Installed Date**	06/01/1954	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Steel - Terminal Piping	**Overfill Types**	
Tag Number	2796	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	Yes

Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Pressurized	**CP Met Types**	
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	05/21/2024	**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**	Terminal Piping Annual Line Test	**Vapor Recovery**	No
Capacity	1260000	**ATG Test Date**		**Line Tightness Test Date**	09/06/2024	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	S19	**Tank Age**	71	**Tank Installed Date**	06/01/1954	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Steel - Terminal Piping	**Overfill Types**	
Tag Number	2797	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	Yes
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Pressurized	**CP Met Types**	
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	05/21/2024	**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**	Terminal Piping Annual Line Test	**Vapor Recovery**	No
Capacity	647892	**ATG Test Date**		**Line Tightness Test Date**	08/30/2024	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	S23	**Tank Age**	71	**Tank Installed Date**	06/01/1954	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Steel - Terminal Piping	**Overfill Types**	
Tag Number	2800	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	Yes
Status	**Temporarily Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Pressurized	**CP Met Types**	
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	05/21/2024	**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**	Terminal Piping Annual Line Test	**Vapor Recovery**	No
Capacity	847000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	S24	**Tank Age**	71	**Tank Installed Date**	06/01/1954	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Steel - Terminal Piping	**Overfill Types**	
Tag Number	2801	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	Yes
Status	**Temporarily Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Pressurized	**CP Met Types**	
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	05/21/2024	**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**	Terminal Piping Annual Line Test	**Vapor Recovery**	No
Capacity	847000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	S25	**Tank Age**	71	**Tank Installed Date**	06/01/1954	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Steel - Terminal Piping	**Overfill Types**	

Tag Number	2802	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	Yes
Status	**Temporarily Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Pressurized	**CP Met Types**	
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	05/21/2024	**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**	Terminal Piping Annual Line Test	**Vapor Recovery**	No
Capacity	648000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	S26	**Tank Age**	71	**Tank Installed Date**	06/01/1954	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Steel - Terminal Piping	**Overfill Types**	
Tag Number	2803	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	Yes
Status	**Temporarily Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Pressurized	**CP Met Types**	
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	05/21/2024	**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**	Terminal Piping Annual Line Test	**Vapor Recovery**	No
Capacity	648000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	S13	**Tank Age**	71	**Tank Installed Date**	06/01/1954	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Steel - Terminal Piping	**Overfill Types**	
Tag Number	4581	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	Yes
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Pressurized	**CP Met Types**	
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	05/21/2024	**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**	Terminal Piping Annual Line Test	**Vapor Recovery**	No
Capacity	630000	**ATG Test Date**		**Line Tightness Test Date**	09/04/2024	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	S17	**Tank Age**	71	**Tank Installed Date**	06/01/1954	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Steel - Terminal Piping	**Overfill Types**	
Tag Number	4909	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	Yes
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Pressurized	**CP Met Types**	
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	05/21/2024	**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**	Terminal Piping Annual Line Test	**Vapor Recovery**	No
Capacity	840000	**ATG Test Date**		**Line Tightness Test Date**	08/29/2024	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					

Facility Summary in Missoula County in the City of Missoula

Location: PHILLIPS 66 EXXON MOBIL JOINTLY OWNED MISSOULA TERMINAL
3330 Raser Dr
Missoula, MT 59808-1534 Missoula

System Facility ID:32-03320

Facility Code: 25289
Last Inspected On: 01/23/2025
Operating Permit Renewal Date: 06/09/2028

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Phillips 66/Exxon Mobil Jointly Owned Missoula Terminal	**(406) 255-5714**	**allen.eggen@p66.com**
Operator Contact:	Adam Pfeifer;Dusty Nagel		**adam.pfeifer@p66.com;dusty.a.nagel@p66.com**

Owner/Operator:	Phillips 66/Exxon Mobil Jointly Owned Missoula Terminal	(406) 255-5714	allen.eggen@p66.com
	Adam Pfeifer, UST Class A Operator		adam.pfeifer@p66.com
	Adam Pfeifer, UST Class B Global Operator		adam.pfeifer@p66.com
	Andrew Snyder, UST Class B Operator		andrew.a.snyder@conocophillips.com
	Andrew Snyder, UST Class B Operator		andrew.a.snyder@conocophillips.com
	Chris Binder, UST Class B Operator		
	Chris Binder, UST Class B Operator		
	Dustin Rogers, UST Class B Operator		dustin.w.rogers@conocophilips.com
	Dustin Rogers, UST Class B Operator		dustin.w.rogers@conocophilips.com
	Dusty Nagel, UST Class A Operator		dusty.a.nagel@p66.com
	Dusty Nagel, UST Class B Operator		dusty.a.nagel@p66.com
	Marcus Eppard, UST Class B Operator		marcus.k.eppard@p66.com
	Orlando Rodriguez, UST Class B Operator		orlando.r.rodriquez@conocophillips.com
	Orlando Rodriguez, UST Class B Operator		orlando.r.rodriquez@conocophillips.com

Tank Number	22	**Tank Age**	28	**Tank Installed Date**	11/01/1997	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Steel - Terminal Piping	**Overfill Types**	High Level Alarm
Tag Number	738	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Gravity Feed	**CP Met Types**	
Product	Mixture	**PLLD Test Date**		**Tank/Piping CP Test Date**	05/21/2024	**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	3-Year Line Tightness Test	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**		**Line Tightness Test Date**	10/22/2024	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					

Tank Number	S09	**Tank Age**	72	**Tank Installed Date**	01/01/1953	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Steel - Terminal Piping	**Overfill Types**	
Tag Number	739	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	Yes
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Pressurized	**CP Met Types**	
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	05/21/2024	**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**	Terminal Piping Annual Line Test	**Vapor Recovery**	No
Capacity	1260000	**ATG Test Date**		**Line Tightness Test Date**	09/09/2024	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	S11	**Tank Age**	72	**Tank Installed Date**	01/01/1953	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Steel - Terminal Piping	**Overfill Types**	
Tag Number	741	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	Yes
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Pressurized	**CP Met Types**	
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	05/21/2024	**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**	Terminal Piping Annual Line Test	**Vapor Recovery**	No
Capacity	840000	**ATG Test Date**		**Line Tightness Test Date**	09/09/2024	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	S13	**Tank Age**	72	**Tank Installed Date**	01/01/1953	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Steel - Terminal Piping	**Overfill Types**	
Tag Number	743	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	Yes
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Pressurized	**CP Met Types**	
Product	Mixture	**PLLD Test Date**		**Tank/Piping CP Test Date**	05/21/2024	**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**	Terminal Piping Annual Line Test	**Vapor Recovery**	No
Capacity	840000	**ATG Test Date**		**Line Tightness Test Date**	09/16/2024	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	S15	**Tank Age**	72	**Tank Installed Date**	01/01/1953	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Steel - Terminal Piping	**Overfill Types**	
Tag Number	745	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	Yes
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Pressurized	**CP Met Types**	
Product	Gasohol/Ethanol	**PLLD Test Date**		**Tank/Piping CP Test Date**	05/21/2024	**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**	Terminal Piping Annual Line Test	**Vapor Recovery**	No
Capacity	840000	**ATG Test Date**		**Line Tightness Test Date**	08/27/2024	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No

		Overfill Test Date				**ATG Type**					
Tank Number	S17	**Tank Age**	53	**Tank Installed Date**	01/01/1972	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Steel - Terminal Piping	**Overfill Types**	
Tag Number	747	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	Yes
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Pressurized	**CP Met Types**	
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	05/21/2024	**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**	Terminal Piping Annual Line Test	**Vapor Recovery**	No
Capacity	840000	**ATG Test Date**		**Line Tightness Test Date**	09/24/2024	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	S19	**Tank Age**	51	**Tank Installed Date**	01/01/1974	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Steel - Terminal Piping	**Overfill Types**	
Tag Number	749	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	Yes
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Pressurized	**CP Met Types**	
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	05/21/2024	**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**	Terminal Piping Annual Line Test	**Vapor Recovery**	No
Capacity	4200000	**ATG Test Date**		**Line Tightness Test Date**	09/24/2024	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	S20	**Tank Age**	51	**Tank Installed Date**	01/01/1974	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Steel - Terminal Piping	**Overfill Types**	
Tag Number	750	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	Yes
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Pressurized	**CP Met Types**	
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	05/21/2024	**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**	Terminal Piping Annual Line Test	**Vapor Recovery**	No
Capacity	2646000	**ATG Test Date**		**Line Tightness Test Date**	09/06/2024	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					

Facility Summary in Missoula County in the City of Missoula

Location: PROVIDENCE CENTER
900 N Orange St
Missoula, MT 59802-2998 Missoula

System Facility ID:32-13405

Facility Code: 25746
Last Inspected On: 11/12/2023
Operating Permit Renewal Date: 04/03/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Saint Patricks Hospital **(406) 543-7271**

Operator Contact: Timothy Chopp **tchopp@saintpatrick.org**

Owner/Operator: Saint Patricks Hospital (406) 543-7271

Harry McGuire, UST Class B Operator	mtrses@q.com
Timothy Chopp, UST Class A Operator	tchopp@saintpatrick.org
Timothy Chopp, UST Class B Operator	tchopp@saintpatrick.org

Tank Number	02	**Tank Age**	30	**Tank Installed Date**	08/01/1995	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	1960	**Spill Test Date**	11/06/2023	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Auto Dialer	**Piping Type**	U.S. Suction	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	3-Year Line Tightness Test	**Vapor Recovery**	No
Capacity	2500	**ATG Test Date**	11/06/2023	**Line Tightness Test Date**	02/12/2021	**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	11/06/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-300;Veeder Root/TLS-300				

Facility Summary in Missoula County in the City of Missoula

Location: RANGITSCH BROTHERS 2001 WEST BROADWAY
2001 W Broadway St
Missoula, MT 59808-1817 Missoula

System Facility ID:32-09919

Facility Code: 25529
Last Inspected On: 08/21/2023
Operating Permit Renewal Date: 10/29/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Rangitsch Brothers	**(406) 728-4040**	**service1@rangitschbrosrv.com.**
Operator Contact:	Gerry Wolner;Joel Jasperson	**(406) 721-7561**	**joelj@rangitschbrosrv.com;service1@rangitschbrosrv.com.**

Owner/Operator: Rangitsch Brothers (406) 728-4040 service1@rangitschbrosrv.com.

David Crowder, UST Class B Operator	acewheeler65@gmail.com
Gerry Wolner, UST Class A Operator	service1@rangitschbrosrv.com.
Joel Jasperson, UST Class A Operator	joelj@rangitschbrosrv.com
Joel Jasperson, UST Class B Operator	joelj@rangitschbrosrv.com
Russ Dickey, UST Class B Operator	service2@rangitschbrosrv.com

Tank Number	03	**Tank Age**	26	**Tank Installed Date**	01/01/1999	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	3917	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**	EMCO Electronics/EECO 1500				

Facility Summary in Missoula County in the City of Missoula

Location: ROSAUERS 127 FUEL STATION
2350 S Reserve St
Missoula, MT 59801 Missoula

System Facility ID:60-15318

Facility Code: 31015
Last Inspected On: 09/23/2024
Operating Permit Renewal Date: 12/23/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Rosauers Supermarkets Inc Marshall	**(509) 326-8900**	**lillig@rosauers.com**
Operator Contact:	Dean Hansen;Paco Sutton	**(406) 721-5430**	**127mgr@rosauers.com**

Owner/Operator: Rosauers Supermarkets Inc Marshall (509) 326-8900 lillig@rosauers.com

Dean Hansen, UST Class A Operator	127mgr@rosauers.com
Dean Hansen, UST Class B Operator	127mgr@rosauers.com
Jerry Kuykendall, UST Class B Global Operator	
Paco Sutton, UST Class A Operator	127mgr@rosauers.com
Paco Sutton, UST Class B Operator	127mgr@rosauers.com

Tank Number	01	**Tank Age**	7	**Tank Installed Date**	06/21/2018	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	5814	**Spill Test Date**	08/31/2021	**Piping Installed Date**	06/24/2018	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	04/10/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	Yes
Capacity	20000	**ATG Test Date**	04/10/2025	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	04/10/2025			**ATG Type**	Incon/TS-550 EVO				
Tank Number	02	**Tank Age**	7	**Tank Installed Date**	06/21/2018	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	5815	**Spill Test Date**	07/25/2024	**Piping Installed Date**	06/24/2018	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	04/10/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	9000	**ATG Test Date**	04/10/2025	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes

		Overfill Test Date	04/10/2025			**ATG Type**	Incon/TS-550 EVO				
Tank Number	03	**Tank Age**	7	**Tank Installed Date**	06/21/2018	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	5816	**Spill Test Date**	07/25/2024	**Piping Installed Date**	06/24/2018	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	04/10/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	Yes
Capacity	6000	**ATG Test Date**	04/10/2025	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	04/10/2025			**ATG Type**	Incon/TS-550 EVO				

Facility Summary in Missoula County in the City of Missoula

Location: SILVER SLIPPER
4055 Hwy 93 S
Missoula, MT 59804-7300 Missoula

System Facility ID:32-13711

Facility Code: 25780
Last Inspected On: 08/18/2023
Operating Permit Renewal Date: 08/21/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Noah Castle;Preslyn LLC	**(406) 251-5402**	**noahcastle@hotmail.com**
Operator Contact:	Melissa Rausch	**(406) 253-4921**	**thesilverslippermissoula@gmail.com**

Owner/Operator:	Noah Castle	(406) 251-5402	noahcastle@hotmail.com
Owner/Operator:	Preslyn LLC	(406) 251-5402	noahcastle@hotmail.com
	Melissa Rausch, UST Class A Operator		thesilverslippermissoula@gmail.com
	Melissa Rausch, UST Class B Operator		thesilverslippermissoula@gmail.com

Tank Number	01	**Tank Age**	29	**Tank Installed Date**	03/01/1996	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve
Tag Number	3251	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Temporarily Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Continuous Interstitial Monitoring	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	15000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	02	**Tank Age**	29	**Tank Installed Date**	03/01/1996	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve
Tag Number	3252	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Temporarily Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Continuous Interstitial Monitoring	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	15000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No

		Overfill Test Date				**ATG Type**					
Tank Number	03	**Tank Age**	29	**Tank Installed Date**	03/01/1996	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve
Tag Number	3253	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Temporarily Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Continuous Interstitial Monitoring	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	5000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					

Facility Summary in Missoula County in the City of Missoula

Location: SORENSEN TRANSPORT
6575 US Hwy 10 W
Missoula, MT 59808-9086 Missoula

System Facility ID:32-13428

Facility Code: 25748
Last Inspected On: 05/30/2024
Operating Permit Renewal Date: 10/15/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Sorensen Transport	**(406) 721-5404**	**jake@sorco-inc.com**
Operator Contact:	Lane Sorensen	**(406) 721-5404**	**lsorensen@trans-system.com**

Owner/Operator: Sorensen Transport (406) 721-5404 jake@sorco-inc.com
Lane Sorensen, UST Class A Operator lsorensen@trans-system.com
Lane Sorensen, UST Class B Operator lsorensen@trans-system.com

Tank Number	02	**Tank Age**	10	**Tank Installed Date**	06/04/2015	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	5576	**Spill Test Date**	05/30/2024	**Piping Installed Date**	06/04/2015	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	05/30/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	05/30/2024	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	20000	**ATG Test Date**	05/30/2024	**Line Tightness Test Date**	06/03/2015	**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	05/30/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350;Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Missoula County in the City of Missoula

Location: SOUTH AVENUE MARKET #11
2401 S Higgins Ave
Missoula, MT 59801 Missoula

System Facility ID:32-05764

Facility Code: 25381
Last Inspected On: 11/11/2022
Operating Permit Renewal Date: 02/19/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Hi-Star Properties LLC **histarms3@yahoo.com**

Operator Contact: Manpreet Singh;Hi-Star Properties LLC **(509) 994-6599** **sbsm065@gmail.com;histarms3@yahoo.com**

Owner/Operator: Hi-Star Properties LLC histarms3@yahoo.com

Manpreet Singh, UST Class A Operator histarms3@yahoo.com

Manpreet Singh, UST Class B Operator histarms3@yahoo.com

Tank Number	02	**Tank Age**	44	**Tank Installed Date**	04/26/1981	**Tank Material Construction**	Bare Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	3849	**Spill Test Date**	08/18/2020	**Piping Installed Date**	07/21/2000	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	11/30/2021	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	04/29/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	08/18/2020			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Number	03	**Tank Age**	44	**Tank Installed Date**	04/26/1981	**Tank Material Construction**	Bare Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	3850	**Spill Test Date**	08/18/2020	**Piping Installed Date**	07/21/2000	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	11/30/2021	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	04/29/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	08/18/2020			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				

Tank Number	01	**Tank Age**	44	**Tank Installed Date**	04/26/1981	**Tank Material Construction**	Bare Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	4668	**Spill Test Date**	08/18/2020	**Piping Installed Date**	07/21/2000	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	02/21/2024	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	11/30/2021	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	04/29/2024	**Line Tightness Test Date**	02/21/2024	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	08/18/2020			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				

Facility Summary in Missoula County in the City of Missoula

Location: SOUTHGATE MARKET
1900 South Ave W
Missoula, MT 59801-6508 Missoula

System Facility ID:32-08862

Facility Code: 25477
Last Inspected On: 01/26/2024
Operating Permit Renewal Date: 03/13/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Jays Inc DBA Southgate Market	**(406) 549-1750**	**jaysfood08@yahoo.com**
Operator Contact:	Jagpreet Ghuman;Jays 1 Stop;Jaspal Sandhu;Jays Corporation	**(406) 880-7677;(406) 549-1031**	**jas_sandhu75@hotmail.com;polsonbay@yahoo.com;jaysfood08@outlook.com;jays1stop21@outlook.com**

Owner/Operator: Jays Inc DBA Southgate Market (406) 549-1750 jaysfood08@yahoo.com

Jagpreet Ghuman, UST Class A Operator	jays1stop21@outlook.com
Jagpreet Ghuman, UST Class A Operator	jays1stop21@outlook.com
Jagpreet Ghuman, UST Class B Operator	jays1stop21@outlook.com
Jagpreet Ghuman, UST Class B Operator	jays1stop21@outlook.com
Jaspal Sandhu, UST Class A Operator	polsonbay@yahoo.com
Jaspal Sandhu, UST Class B Operator	polsonbay@yahoo.com

Tank Number	01	**Tank Age**	40	**Tank Installed Date**	12/23/1985	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	1354	**Spill Test Date**	01/25/2024	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	01/25/2024	**Tank/Piping CP Test Date**	01/25/2024	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	01/25/2024	**Line Tightness Test Date**	01/28/2024	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	01/25/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	02	**Tank Age**	40	**Tank Installed Date**	12/23/1985	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	1355	**Spill Test Date**	01/25/2024	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	01/25/2024	**Tank/Piping CP Test Date**	01/25/2024	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	01/25/2024	**Line Tightness Test Date**	01/28/2024	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No

		Overfill Test Date	01/25/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	03	**Tank Age**	40	**Tank Installed Date**	12/23/1985	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	1356	**Spill Test Date**	01/25/2024	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	01/25/2024	**Tank/Piping CP Test Date**	01/25/2024	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	01/25/2024	**Line Tightness Test Date**	01/28/2024	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	01/25/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Missoula County in the City of Missoula

Location: SPRINT MISSOULA POP
2515 Railroad St W
Missoula, MT 59808-1680 Missoula

System Facility ID:56-14010

Facility Code: 30670
Last Inspected On: 04/18/2023
Operating Permit Renewal Date: 08/13/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Sprint Communications Co LLP **(913) 762-5957**

Operator Contact: Brian Schmitt;Brian Wiedower **(913) 315-8631** **brian.c.wiedower@sprint.com;brian.schmitt@bolininc.com**

Owner/Operator: Sprint Communications Co LLP (913) 762-5957

Brian Schmitt, UST Class A Operator	brian.schmitt@bolininc.com
Brian Schmitt, UST Class B Operator	brian.schmitt@bolininc.com
Brian Wiedower, UST Class A Operator	brian.c.wiedower@sprint.com
Matt Santee, UST Class B Global Operator	matt.santee@bolininc.com
Scott Hallesy, UST Class B Operator	scott.g.hallesy@sprint.com

Tank Number	01	**Tank Age**	24	**Tank Installed Date**	06/01/2001	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	4321	**Spill Test Date**	03/13/2024	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	U.S. Suction	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	3-Year Line Tightness Test;Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	2500	**ATG Test Date**	04/24/2024	**Line Tightness Test Date**	04/18/2023	**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	04/18/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-300				

Facility Summary in Missoula County in the City of Missoula

Location: ST PATRICKS HOSPITAL
500 W Broadway St
Missoula, MT 59802-4008 Missoula

System Facility ID:32-04266

Facility Code: 25338
Last Inspected On: 11/06/2023
Operating Permit Renewal Date: 05/29/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Saint Patricks Hospital **(406) 543-7271**

Operator Contact: Timothy Chopp **tchopp@saintpatrick.org**

Owner/Operator: Saint Patricks Hospital (406) 543-7271

Timothy Chopp, UST Class A Operator tchopp@saintpatrick.org

Timothy Chopp, UST Class B Operator tchopp@saintpatrick.org

Tank Number	03	**Tank Age**	24	**Tank Installed Date**	10/01/2001	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	4497	**Spill Test Date**	11/06/2023	**Piping Installed Date**	02/29/2008	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Auto Dialer	**Piping Type**	U.S. Suction	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	3-Year Line Tightness Test	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	11/06/2023	**Line Tightness Test Date**	11/06/2023	**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	11/06/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-300;Veeder Root/TLS-300				
Tank Number	04	**Tank Age**	17	**Tank Installed Date**	07/18/2008	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm;Positive Shutoff
Tag Number	5175	**Spill Test Date**	11/06/2023	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Auto Dialer	**Piping Type**	U.S. Suction	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	3-Year Line Tightness Test	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	11/06/2023	**Line Tightness Test Date**	11/06/2023	**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	Yes

		Overfill Test Date	11/06/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-300;Veeder Root/TLS-300				

Facility Summary in Missoula County in the City of Missoula

Location: TABISH BROTHERS DISTRIBUTORS INC
501 Taylor St
Missoula, MT 59802-4920 Missoula

System Facility ID:32-06523

Facility Code: 25407
Last Inspected On: 06/20/2023
Operating Permit Renewal Date: 06/22/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Tabish Brothers Distributors Inc **(406) 543-7621** **lss@gwpetrol.com**

Operator Contact: Heather Stiles **hstiles@gwpetrol.com**

Owner/Operator: Tabish Brothers Distributors Inc (406) 543-7621 lss@gwpetrol.com

Heather Stiles, UST Class A Operator hstiles@gwpetrol.com

Heather Stiles, UST Class B Global Operator hstiles@gwpetrol.com

Tank Number	01	**Tank Age**	44	**Tank Installed Date**	04/16/1981	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	2080	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Temporarily Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Continuous Interstitial Monitoring	**Piping Type**	U.S. Suction	**CP Met Types**	Non-corrodible
Product	Heating Oil	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.1;Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	7600	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	02	**Tank Age**	44	**Tank Installed Date**	04/16/1981	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	2081	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	06/20/2023	**Catastrophic L.D. Type 3.0**	Continuous Interstitial Monitoring	**Piping Type**	Gravity Feed	**CP Met Types**	Non-corrodible
Product	Oil, Waste	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	7600	**ATG Test Date**	06/20/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No

		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Missoula County in the City of Missoula

Location: THE OLDE DAIRY
2106 Clements Rd
Missoula, MT 59804-6212 Missoula

System Facility ID:32-08475

Facility Code: 25464
Last Inspected On: 08/16/2023
Operating Permit Renewal Date: 09/03/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Dale Johnson;Target Range Development LLC **(406) 721-3322** **mark@theoldedairy.com**

Operator Contact: Jessica Rogers;Target Range Development LLC **(406) 721-3322** **jessica@theoldedairy.com;mark@theoldedairy.com**

Owner/Operator: Dale L Johnson (406) 721-3322

Owner/Operator: Target Range Development LLC (406) 721-3322

Jessica Rogers, UST Class A Operator mark@theoldedairy.com

Jessica Rogers, UST Class B Operator mark@theoldedairy.com

Tank Number	05	**Tank Age**	26	**Tank Installed Date**	03/23/1999	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve;High Level Alarm
Tag Number	4086	**Spill Test Date**	08/16/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	07/20/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	07/20/2024			**ATG Type**	Gilbarco-Veeder Root/EMC Basic				
Tank Number	06	**Tank Age**	26	**Tank Installed Date**	03/23/1999	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve;High Level Alarm
Tag Number	4087	**Spill Test Date**	08/16/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	04/14/2022	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	07/20/2024	**Line Tightness Test Date**	02/01/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	07/20/2024			**ATG Type**	Gilbarco-Veeder Root/EMC Basic				

Tank Number	07	**Tank Age**	26	**Tank Installed Date**	03/23/1999	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve;High Level Alarm
Tag Number	4088	**Spill Test Date**	08/16/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	07/20/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	07/20/2024			**ATG Type**	Gilbarco-Veeder Root/EMC Basic				

Facility Summary in Missoula County in the City of Missoula

Location: TOWN PUMP INC MISSOULA 1
5310 Grant Creek Rd
Missoula, MT 59808-1483 Missoula

System Facility ID:32-13336

Facility Code: 25739
Last Inspected On: 06/09/2023
Operating Permit Renewal Date: 10/28/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Missoula 1 Town Pump LLC **(406) 497-6700** **environmental@townpump.com**

Operator Contact: Trent Biggers **Trentb@townpump.com**

Owner/Operator: Missoula 1 Town Pump LLC (406) 497-6700 environmental@townpump.com

Trent Biggers, UST Class A Operator Trentb@townpump.com

Trent Biggers, UST Class B Global Operator Trentb@townpump.com

Tank Number	01	**Tank Age**	32	**Tank Installed Date**	12/01/1993	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	2342	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Gasoline	**PLLD Test Date**	05/04/2021	**Tank/Piping CP Test Date**	03/19/2019	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	Yes
Capacity	12000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/TLS-350				
Tank Number	02	**Tank Age**	32	**Tank Installed Date**	12/01/1993	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	2343	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Gasoline	**PLLD Test Date**	05/04/2021	**Tank/Piping CP Test Date**	03/19/2019	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	Yes
Capacity	6000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/TLS-350				

Tank Number	03	**Tank Age**	32	**Tank Installed Date**	12/01/1993	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	2344	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Single Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Diesel	**PLLD Test Date**	05/04/2021	**Tank/Piping CP Test Date**	03/19/2019	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	Yes
Capacity	4000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/TLS-350				
Tank Number	04	**Tank Age**	32	**Tank Installed Date**	12/01/1993	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	2345	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Gasoline	**PLLD Test Date**	05/04/2021	**Tank/Piping CP Test Date**	03/19/2019	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/TLS-350				
Tank Number	05	**Tank Age**	16	**Tank Installed Date**	01/25/2009	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve
Tag Number	5196	**Spill Test Date**		**Piping Installed Date**	01/25/2009	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	05/04/2021	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Diesel	**PLLD Test Date**	05/04/2021	**Tank/Piping CP Test Date**	01/11/2010	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	Yes
Capacity	20000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/TLS-350				
Tank Number	06	**Tank Age**	16	**Tank Installed Date**	01/25/2009	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve
Tag Number	5197	**Spill Test Date**		**Piping Installed Date**	01/25/2009	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	05/04/2021	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	

Product	Gasoline	**PLLD Test Date**	05/04/2021	**Tank/Piping CP Test Date**	01/11/2010	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Missoula County in the City of Missoula

Location: TOWN PUMP INC MISSOULA 3
2210 N Reserve St
Missoula, MT 59808-1323 Missoula

System Facility ID:32-13172

Facility Code: 25725
Last Inspected On: 06/20/2023
Operating Permit Renewal Date: 10/30/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Missoula 3 Town Pump LLC **(406) 497-6700** **environmental@townpump.com**

Operator Contact: Trent Biggers **Trentb@townpump.com**

Owner/Operator: Missoula 3 Town Pump LLC (406) 497-6700 environmental@townpump.com

Trent Biggers, UST Class A Operator Trentb@townpump.com
Trent Biggers, UST Class A Operator Trentb@townpump.com
Trent Biggers, UST Class B Global Operator Trentb@townpump.com
Trent Biggers, UST Class B Global Operator Trentb@townpump.com

Tank Number	01	**Tank Age**	32	**Tank Installed Date**	06/01/1993	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve
Tag Number	2559	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	07/09/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	05/05/2021	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**		**Line Tightness Test Date**	09/22/2006	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/TLS-350				
Tank Number	02	**Tank Age**	32	**Tank Installed Date**	06/01/1993	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve
Tag Number	2560	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	05/05/2021	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**		**Line Tightness Test Date**	09/22/2006	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No

		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/TLS-350				
Tank Number	03	**Tank Age**	32	**Tank Installed Date**	06/01/1993	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve
Tag Number	2561	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	05/05/2021	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**		**Line Tightness Test Date**	09/30/2006	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/TLS-350				
Tank Number	04	**Tank Age**	32	**Tank Installed Date**	06/01/1993	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve
Tag Number	2562	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	05/05/2021	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**		**Line Tightness Test Date**	09/30/2006	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/TLS-350				
Tank Number	05	**Tank Age**	32	**Tank Installed Date**	06/01/1993	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve
Tag Number	2563	**Spill Test Date**	10/04/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	05/05/2021	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**		**Line Tightness Test Date**	09/30/2006	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	10/04/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Missoula County in the City of Missoula

Location: TOWN PUMP INC MISSOULA 8
3420 Mullan Rd Ste A
Missoula, MT 59808-5126 Missoula

System Facility ID:56-13823

Facility Code: 30509
Last Inspected On: 06/21/2023
Operating Permit Renewal Date: 06/21/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Missoula 8 Town Pump LLC **(406) 497-6700** **environmental@townpump.com**

Operator Contact: Trent Biggers **Trentb@townpump.com**

Owner/Operator: Missoula 8 Town Pump LLC (406) 497-6700 environmental@townpump.com

Trent Biggers, UST Class A Operator Trentb@townpump.com

Trent Biggers, UST Class B Global Operator Trentb@townpump.com

Tank Number	01	**Tank Age**	28	**Tank Installed Date**	08/01/1997	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve
Tag Number	1444	**Spill Test Date**	07/18/2022	**Piping Installed Date**	05/24/2016	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	04/27/2021	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	06/21/2023	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	06/21/2023	**Line Tightness Test Date**	05/05/2016	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	No
		Overfill Test Date	07/18/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350				
Tank Number	02	**Tank Age**	28	**Tank Installed Date**	08/01/1997	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve
Tag Number	1445	**Spill Test Date**	07/18/2022	**Piping Installed Date**	05/24/2016	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	04/27/2021	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	06/21/2023	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	06/21/2023	**Line Tightness Test Date**	05/18/2016	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	No
		Overfill Test Date	07/18/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350				
Tank Number	03	**Tank Age**	28	**Tank Installed Date**	08/01/1997	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve

Tag Number	1446	**Spill Test Date**	07/18/2022	**Piping Installed Date**	05/24/2016	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	04/27/2021	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	06/21/2023	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	5000	**ATG Test Date**	06/21/2023	**Line Tightness Test Date**	05/17/2016	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	No
		Overfill Test Date	07/18/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350				
Tank Number	04	**Tank Age**	9	**Tank Installed Date**	05/24/2016	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	5629	**Spill Test Date**	07/18/2022	**Piping Installed Date**	05/24/2016	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	04/27/2021	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	06/21/2023	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**	06/21/2023	**Line Tightness Test Date**	05/18/2016	**Secondary Tank Leak Detection**	Statistical Inventory Reconciliation	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	Yes
		Overfill Test Date	07/18/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Missoula County in the City of Missoula

Location: TOWN PUMP MISSOULA 9
2001 Brooks St
Missoula, MT 59808 Missoula

System Facility ID:60-15288

Facility Code: 30995
Last Inspected On: 06/22/2023
Operating Permit Renewal Date: 06/22/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Missoula 9 Town Pump LLC **(406) 497-6700** **environmental@townpump.com**

Operator Contact: Trent Biggers **Trentb@townpump.com**

Owner/Operator: Missoula 9 Town Pump LLC (406) 497-6700 environmental@townpump.com

Trent Biggers, UST Class A Operator Trentb@townpump.com

Trent Biggers, UST Class B Operator Trentb@townpump.com

Tank Number	01	**Tank Age**	8	**Tank Installed Date**	03/28/2017	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	5683	**Spill Test Date**	07/12/2022	**Piping Installed Date**	03/28/2017	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	05/10/2021	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	06/22/2023	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	Yes
Capacity	25000	**ATG Test Date**	06/22/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Statistical Inventory Reconciliation	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	Yes
		Overfill Test Date	07/12/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-450				
Tank Number	02	**Tank Age**	8	**Tank Installed Date**	03/28/2017	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	5684	**Spill Test Date**	07/12/2022	**Piping Installed Date**	03/28/2017	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	05/10/2021	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	06/22/2023	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	Yes
Capacity	15000	**ATG Test Date**	06/22/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Statistical Inventory Reconciliation	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	Yes
		Overfill Test Date	07/12/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-450				

Tank Number	03	**Tank Age**	8	**Tank Installed Date**	03/28/2017	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	5685	**Spill Test Date**	07/12/2022	**Piping Installed Date**	03/28/2017	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	05/10/2021	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	06/22/2023	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	15000	**ATG Test Date**	06/22/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Statistical Inventory Reconciliation	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	Yes
		Overfill Test Date	07/12/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-450				

Facility Summary in Missoula County in the City of Missoula

Location: UNITED PARCEL SERVICES MISSOULA
221 Expressway Ln
Missoula, MT 59808-1553 Missoula

System Facility ID:32-04536

Facility Code: 25343
Last Inspected On: 04/18/2022
Operating Permit Renewal Date: 10/11/2025

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: United Parcel Service Inc Seattle **cdd6jxd@ups.com**

Operator Contact: Dino Ostrow;Jonathan Dunbar;United Parcel Service Inc Seattle **(503) 329-7154** **dostrow@ups.com;jxdunbar@ups.com;cdd6jxd@ups.com**

Owner/Operator: United Parcel Service Inc Seattle cdd6jxd@ups.com

Dino Ostrow, UST Class A Operator dostrow@ups.com
Dino Ostrow, UST Class A Operator dostrow@ups.com
Dino Ostrow, UST Class B Operator dostrow@ups.com
Dino Ostrow, UST Class B Operator dostrow@ups.com
Jonathan Dunbar, UST Class A Operator cdd6jxd@ups.com
Jonathan Dunbar, UST Class B Operator cdd6jxd@ups.com

Tank Number	04	**Tank Age**	32	**Tank Installed Date**	07/01/1993	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	2182	**Spill Test Date**	04/18/2022	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	04/18/2022	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	04/18/2022	**Line Tightness Test Date**	04/18/2022	**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	04/26/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Missoula County in the City of Missoula

Location: WESTERN TRANSPORT
9310 Cartage Rd
Missoula, MT 59808-9758 Missoula

System Facility ID:32-01348

Facility Code: 25211
Last Inspected On: 04/17/2025
Operating Permit Renewal Date: 04/17/2028

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Western Land Investments LLC **(307) 674-6305**

Operator Contact: Cari Goss **(307) 674-6305** **cari@westerntransllc.com**

Owner/Operator: Western Land Investments LLC (307) 674-6305

Cari Goss, UST Class A Operator cari@westerntransllc.com

Tank Number	01	**Tank Age**	57	**Tank Installed Date**	01/17/1968	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Steel	**Overfill Types**	High Level Alarm
Tag Number	1654	**Spill Test Date**	09/29/2021	**Piping Installed Date**		**Tank Construction**	Lined Interior/Impressed Current	**Piping Construction**	Single Walled	**AST**	No
Status	**Temporarily Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Impressed Current
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	03/26/2025	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	09/30/2021	**Line Tightness Test Date**	09/12/2012	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**	Veeder Root/TLS-250				
Tank Number	02	**Tank Age**	57	**Tank Installed Date**	01/17/1968	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	1655	**Spill Test Date**	09/29/2021	**Piping Installed Date**	12/11/2006	**Tank Construction**	Lined Interior/Impressed Current	**Piping Construction**	Single Walled	**AST**	No
Status	**Temporarily Out of Use**	**MLLD Test Date**	03/22/2022	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	03/26/2025	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	09/30/2021	**Line Tightness Test Date**	03/22/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**	Veeder Root/TLS-250				
Tank Number	03	**Tank Age**	44	**Tank Installed Date**	01/16/1981	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm

Tag Number	1656	**Spill Test Date**		**Piping Installed Date**	12/11/2006	**Tank Construction**	Lined Interior/Impressed Current	**Piping Construction**	Single Walled	**AST**	No
Status	**Temporarily Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	03/26/2025	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**		**Line Tightness Test Date**	05/27/2010	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**	Veeder Root/TLS-250				

Facility Summary in Missoula County in the City of Missoula

Location: WESTFIELD MISSOULA
8448 US Hwy 10 W
Missoula, MT 59808-9319 Missoula

System Facility ID:32-13674

Facility Code: 25776
Last Inspected On: 05/01/2023
Operating Permit Renewal Date: 07/22/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Finest Oil Co	**(406) 543-6969**

Operator Contact:	Christopher Glasser;David Peyton;James Brady;James DeWaters;Justin Gaudot;Stephen Hanson	**(406) 218-1563;(406) 360-6327;(406) 543-6969;(406) 544-1005;(714) 333-8926**	**chrisglasser@hotmail.com;finestoil@finest-oil.com;jeepin247.jb@gmail.com;justgaudot@yahoo.com;rivban22@gmail.com**

Owner/Operator: Finest Oil Co (406) 543-6969

Christopher Glasser, UST Class A Operator	chrisglasser@hotmail.com
David Peyton, UST Class A Operator	
David Peyton, UST Class B Global Operator	
James Brady, UST Class A Operator	jeepin247.jb@gmail.com
James DeWaters, UST Class A Operator	rivban22@gmail.com
Joseph McClain, UST Class B Operator	jgmcclain25@gmail.com
Justin Gaudot, UST Class A Operator	justgaudot@yahoo.com
Justin Gaudot, UST Class B Global Operator	justgaudot@yahoo.com
Stephen Hanson, UST Class A Operator	finestoil@finest-oil.com
Stephen Hanson, UST Class B Operator	finestoil@finest-oil.com

Tank Number	01	**Tank Age**	30	**Tank Installed Date**	12/01/1995	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	1077	**Spill Test Date**	04/28/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	04/28/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**	04/28/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	04/28/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	02	**Tank Age**	30	**Tank Installed Date**	12/01/1995	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	1078	**Spill Test Date**	04/28/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No

Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	04/28/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**	04/28/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	04/28/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	03	**Tank Age**	30	**Tank Installed Date**	12/01/1995	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	1079	**Spill Test Date**	04/28/2023	**Piping Installed Date**	09/19/2007	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	04/28/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	04/28/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	04/28/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	04	**Tank Age**	30	**Tank Installed Date**	12/01/1995	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	1080	**Spill Test Date**	04/28/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	04/28/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	04/28/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	04/28/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	05	**Tank Age**	30	**Tank Installed Date**	12/01/1995	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	1081	**Spill Test Date**	04/28/2023	**Piping Installed Date**	05/17/2012	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	04/28/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No

Capacity	12000	**ATG Test Date**	04/28/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date	04/28/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	06	**Tank Age**	30	**Tank Installed Date**	12/01/1995	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	1082	**Spill Test Date**	04/28/2023	**Piping Installed Date**	05/17/2012	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	04/28/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	04/25/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	04/28/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Missoula County in the City of Missoula

Location: YOKES FRESH MARKET 21
800 W Broadway St
Missoula, MT 59802-3944 Missoula

System Facility ID:60-15098

Facility Code: 30858
Last Inspected On: 04/09/2024
Operating Permit Renewal Date: 06/11/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: YOKE'S FOOD INC **(509) 921-2292**

Operator Contact: Rebecca Spicer;Rich Thornock;Shari Goodmanson **(406) 251-7170;(406) 721-2549** **fuelmgr21@yokesfoods.com;MRMBR@YOKESFOODS.COM;sgoodmanson@yokesfoods.com**

Owner/Operator: YOKE'S FOOD INC (509) 921-2292

Rebecca Spicer, UST Class A Operator	fuelmgr21@yokesfoods.com
Rebecca Spicer, UST Class B Operator	fuelmgr21@yokesfoods.com
Rich Thornock, UST Class A Operator	MRMBR@YOKESFOODS.COM
Rich Thornock, UST Class B Operator	MRMBR@YOKESFOODS.COM
Shari Goodmanson, UST Class A Operator	sgoodmanson@yokesfoods.com
Shari Goodmanson, UST Class B Global Operator	sgoodmanson@yokesfoods.com

Tank Number	01	**Tank Age**	17	**Tank Installed Date**	08/08/2008	**Tank Material Construction**	Steel Clad	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	5167	**Spill Test Date**	10/01/2024	**Piping Installed Date**	07/01/2008	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	04/09/2024	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	20000	**ATG Test Date**	04/09/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	Yes
		Overfill Test Date	08/01/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Tank Number	02	**Tank Age**	17	**Tank Installed Date**	08/01/2008	**Tank Material Construction**	Steel Clad	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	5168	**Spill Test Date**	10/01/2024	**Piping Installed Date**	07/01/2008	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	04/09/2024	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No

Capacity	10000	**ATG Test Date**	04/09/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	Yes
		Overfill Test Date	08/01/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	03	**Tank Age**	17	**Tank Installed Date**	08/01/2008	**Tank Material Construction**	Steel Clad	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	5169	**Spill Test Date**	04/09/2024	**Piping Installed Date**	07/01/2008	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	04/09/2024	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	04/09/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	Yes
		Overfill Test Date	08/01/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC;OPW / EMCO/TLS-350				

Facility Summary in Missoula County in the City of Missoula

Location: YOKES FRESH MARKET 22
3801 S Reserve St
Missoula, MT 59801-7322 Missoula

System Facility ID:56-14025

Facility Code: 30684
Last Inspected On: 07/12/2022
Operating Permit Renewal Date: 01/04/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	YOKE'S FOOD INC	**(509) 921-2292**
Operator Contact:	Brittany Zeller;Charles Franklin;Jason Rhinehart;YOKE'S FOOD INC;Shari Goodmanson	**(406) 251-3311;(406) 251-7170;(509) 921-2292**

mrasst@yokesfoods.com;MRMGR@YOKESFOODS.COM;pipsnchips2@gmail.com;sgoodmanson@yokesfoods.com

Owner/Operator: YOKE'S FOOD INC (509) 921-2292

Brittany Zeller, UST Class A Operator	MRMGR@YOKESFOODS.COM
Charles Franklin, UST Class A Operator	pipsnchips2@gmail.com
Charles Franklin, UST Class B Global Operator	pipsnchips2@gmail.com
Jason Rhinehart, UST Class A Operator	mrasst@yokesfoods.com
Shari Goodmanson, UST Class A Operator	sgoodmanson@yokesfoods.com
Shari Goodmanson, UST Class B Global Operator	sgoodmanson@yokesfoods.com

Tank Number	01	**Tank Age**	24	**Tank Installed Date**	09/01/2001	**Tank Material Construction**	Steel Clad	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve;High Level Alarm
Tag Number	4416	**Spill Test Date**	10/19/2022	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	07/12/2022	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	20000	**ATG Test Date**	07/12/2022	**Line Tightness Test Date**	01/16/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	07/12/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350				
Tank Number	02	**Tank Age**	24	**Tank Installed Date**	09/01/2001	**Tank Material Construction**	Steel Clad	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve;High Level Alarm
Tag Number	4417	**Spill Test Date**	07/12/2022	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	07/12/2022	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No

Capacity	10000	**ATG Test Date**	07/12/2022	**Line Tightness Test Date**	01/17/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	07/12/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350				
Tank Number	03	**Tank Age**	24	**Tank Installed Date**	09/01/2001	**Tank Material Construction**	Steel Clad	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve;High Level Alarm
Tag Number	4418	**Spill Test Date**	07/12/2022	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	07/12/2022	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	07/12/2022	**Line Tightness Test Date**	07/09/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	07/12/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Missoula County in the City of Missoula

Location: ZIP TRIP 31
3325 Brooks St
Missoula, MT 59801-8289 Missoula

System Facility ID:32-09730

Facility Code: 25516
Last Inspected On: 02/05/2025
Operating Permit Renewal Date: 05/20/2028

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	CHS Inc Spokane Valley	**(509) 535-7701**	**Donald.Widdicombe@chsinc.com**
Operator Contact:	Jim Alford;Sean Hurley	**(509) 535-7701;(509) 536-7418**	**jim.alford@chsinc.com;sean.hurley@chsinc.com**

Owner/Operator: CHS Inc Spokane Valley (509) 535-7701 Donald.Widdicombe@chsinc.com

Jason Brenner, UST Class B Operator	jason.brenner@chsinc.com
Jim Alford, UST Class A Operator	jim.alford@chsinc.com
Jim Alford, UST Class B Operator	jim.alford@chsinc.com
Luci Tuttle, UST Class B Operator	Lucinda.Tuttle@chsinc.com
Sean Hurley, UST Class A Operator	sean.hurley@chsinc.com

Tank Number	01	**Tank Age**	37	**Tank Installed Date**	03/18/1988	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	1363	**Spill Test Date**	02/05/2025	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	08/06/2024	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	08/04/2010	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	08/06/2024	**Line Tightness Test Date**	08/06/2024	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	08/06/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	02	**Tank Age**	37	**Tank Installed Date**	03/18/1988	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	1364	**Spill Test Date**	02/05/2025	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	08/06/2024	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	08/06/2024	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	08/06/2024	**Line Tightness Test Date**	08/06/2024	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No

		Overfill Test Date	02/05/2025			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	03	**Tank Age**	37	**Tank Installed Date**	03/18/1988	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	1365	**Spill Test Date**	02/05/2025	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	08/06/2024	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	08/04/2010	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	08/06/2024	**Line Tightness Test Date**	08/06/2024	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	02/05/2025			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Missoula County in the City of Missoula

Location: ZIP TRIP 32
1540 Toole Ave
Missoula, MT 59802-2241 Missoula

System Facility ID:32-03912

Facility Code: 25317
Last Inspected On: 10/27/2022
Operating Permit Renewal Date: 02/04/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	CHS Inc Spokane Valley	**(509) 535-7701**	**Donald.Widdicombe@chsinc.com**
Operator Contact:	Jim Alford;Sean Hurley	**(509) 535-7701;(509) 536-7418**	**jim.alford@chsinc.com;sean.hurley@chsinc.com**

Owner/Operator: CHS Inc Spokane Valley (509) 535-7701 Donald.Widdicombe@chsinc.com

Jason Brenner, UST Class B Operator	jason.brenner@chsinc.com
Jim Alford, UST Class A Operator	jim.alford@chsinc.com
Jim Alford, UST Class A Operator	jim.alford@chsinc.com
Jim Alford, UST Class B Operator	jim.alford@chsinc.com
Jim Alford, UST Class B Operator	jim.alford@chsinc.com
Luci Tuttle, UST Class B Operator	Lucinda.Tuttle@chsinc.com
Sean Hurley, UST Class A Operator	sean.hurley@chsinc.com
Sean Hurley, UST Class A Operator	sean.hurley@chsinc.com

Tank Number	01	**Tank Age**	41	**Tank Installed Date**	03/22/1984	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	1342	**Spill Test Date**	01/13/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**	07/27/2022	**Tank/Piping CP Test Date**	07/27/2022	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	07/27/2022	**Line Tightness Test Date**	07/27/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	01/13/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	02	**Tank Age**	41	**Tank Installed Date**	03/22/1984	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	1343	**Spill Test Date**	01/13/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic

Product	Gasoline	**PLLD Test Date**	07/27/2022	**Tank/Piping CP Test Date**	07/27/2022	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	07/27/2022	**Line Tightness Test Date**	07/27/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	01/13/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	03	**Tank Age**	41	**Tank Installed Date**	03/22/1984	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	1344	**Spill Test Date**	08/31/2021	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**	07/27/2022	**Tank/Piping CP Test Date**	07/27/2022	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	07/27/2022	**Line Tightness Test Date**	07/27/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	08/31/2021			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Missoula County in the City of Missoula

Location: ZOOTOWN SUPER STOP
2105 S Higgins Ave
Missoula, MT 59801-6714 Missoula

System Facility ID:32-07244

Facility Code: 25429
Last Inspected On: 12/20/2023
Operating Permit Renewal Date: 03/13/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Greg Tabish	**(406) 728-2575**	**zootown@gwpetrol.com**
Operator Contact:	Daniel Marx;Erin Keffeler;Karly Shafer;Yvonne Bunch	**(406) 274-2435;(406) 396-2206;(406) 880-0056**	**DanielMarx@inmissoula.com;karly@gwpetrol.com;noons470@hi-noon.com;ybunch1@gmail.com**

Owner/Operator: Greg Tabish (406) 728-2575 zootown@gwpetrol.com

Daniel Marx, UST Class A Operator	DanielMarx@inmissoula.com
Daniel Marx, UST Class B Global Operator	DanielMarx@inmissoula.com
Erin Keffeler, UST Class A Operator	noons470@hi-noon.com
Erin Keffeler, UST Class B Operator	noons470@hi-noon.com
Karly Shafer, UST Class A Operator	karly@gwpetrol.com
Karly Shafer, UST Class B Global Operator	karly@gwpetrol.com
Yvonne Bunch, UST Class A Operator	ybunch1@gmail.com
Yvonne Bunch, UST Class B Operator	ybunch1@gmail.com

Tank Number	03	**Tank Age**	35	**Tank Installed Date**	12/07/1990	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve
Tag Number	1799	**Spill Test Date**	12/20/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**	12/20/2023	**Tank/Piping CP Test Date**	12/20/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	12/20/2023	**Line Tightness Test Date**	07/13/2011	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	12/20/2023			**ATG Type**	Gilbarco/EMC Basic				
Tank Number	04	**Tank Age**	35	**Tank Installed Date**	12/07/1990	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve
Tag Number	1800	**Spill Test Date**	12/20/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**	12/20/2023	**Tank/Piping CP Test Date**	12/20/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No

Capacity	6000	**ATG Test Date**	12/20/2023	**Line Tightness Test Date**	07/13/2011	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	12/20/2023			**ATG Type**	Gilbarco/EMC Basic				
Tank Number	05	**Tank Age**	35	**Tank Installed Date**	12/07/1990	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve
Tag Number	1801	**Spill Test Date**	12/20/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**	12/20/2023	**Tank/Piping CP Test Date**	12/20/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	12/20/2023	**Line Tightness Test Date**	07/13/2011	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	12/20/2023			**ATG Type**	Gilbarco/EMC Basic				

Facility Summary in Missoula County in the City of Missoula

Location: ZOOTOWN SUPER STOP 2
2125 S Higgins Ave
Missoula, MT 59801-6760 Missoula

System Facility ID:32-10053

Facility Code: 25541
Last Inspected On: 01/19/2024
Operating Permit Renewal Date: 01/19/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Great Western Petroleum **(406) 728-7736**

Operator Contact: Karly Shafer **(406) 396-2206** **karly@gwpetrol.com**

Owner/Operator: Great Western Petroleum (406) 728-7736

Karly Shafer, UST Class A Operator	karly@gwpetrol.com
Karly Shafer, UST Class A Operator	karly@gwpetrol.com
Karly Shafer, UST Class B Operator	karly@gwpetrol.com
Karly Shafer, UST Class B Operator	karly@gwpetrol.com

Tank Number	08	**Tank Age**	35	**Tank Installed Date**	09/30/1990	**Tank Material Construction**	Steel Clad	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	2139	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Single Walled	**AST**	No
Status	**Temporarily Out of Use**	**MLLD Test Date**	12/02/2020	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	5000	**ATG Test Date**		**Line Tightness Test Date**	12/02/2020	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/TLS-300				
Tank Number	09	**Tank Age**	35	**Tank Installed Date**	09/30/1990	**Tank Material Construction**	Steel Clad	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	2140	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Temporarily Out of Use**	**MLLD Test Date**	12/02/2020	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**		**Line Tightness Test Date**	12/02/2020	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/TLS-300				

Tank Number	10	**Tank Age**	35	**Tank Installed Date**	09/30/1990	**Tank Material Construction**	Steel Clad	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	2141	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Temporarily Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	3000	**ATG Test Date**		**Line Tightness Test Date**	10/15/2018	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/TLS-300				
Tank Number	11	**Tank Age**	0	**Tank Installed Date**		**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	
Tag Number	6200	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**		**AST**	No
Status	**Under Construction**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**		**Piping Type**	Pressurized	**CP Met Types**	
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**		**Vapor Recovery**	Yes
Capacity	12000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	Yes
		Overfill Test Date				**ATG Type**					

Facility Summary in Missoula County in the City of Seeley Lake

Location: 1 STOP SEELEY LAKE
3072 MT Hwy 83
Seeley Lake, MT 59868 Missoula

System Facility ID:32-09288

Facility Code: 25483
Last Inspected On: 04/10/2024
Operating Permit Renewal Date: 08/22/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	MONTANA GAS N SHOP LLC	**(510) 714-5045**	**TONY@MONTANAGNS.COM**
Operator Contact:	Gurinderbir Muhar	**(408) 660-9884**	**gasnshop133@gmail.com**

Owner/Operator: MONTANA GAS N SHOP LLC (510) 714-5045 TONY@MONTANAGNS.COM

Gurinderbir Muhar, UST Class A Operator gasnshop133@gmail.com

Gurinderbir Muhar, UST Class B Operator gasnshop133@gmail.com

Tank Number	S1	**Tank Age**	38	**Tank Installed Date**	04/22/1987	**Tank Material Construction**		**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve
Tag Number	416	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Single Walled	**AST**	Yes
Status	**Currently in Use**	**MLLD Test Date**	10/17/2023	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**		**Line Tightness Test Date**	10/17/2023	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	S2	**Tank Age**	38	**Tank Installed Date**	04/22/1987	**Tank Material Construction**		**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve
Tag Number	417	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Single Walled	**AST**	Yes
Status	**Currently in Use**	**MLLD Test Date**	10/17/2023	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**		**Line Tightness Test Date**	10/17/2023	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	S3	**Tank Age**	38	**Tank Installed Date**	04/22/1987	**Tank Material Construction**		**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve
Tag Number	418	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Single Walled	**AST**	Yes

Status	**Currently in Use**	**MLLD Test Date**	10/17/2023	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**		**Line Tightness Test Date**	10/17/2023	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					

Facility Summary in Missoula County in the City of Seeley Lake

Location: LINDEYS LANDING WEST SPB
MT Hwy 83
Seeley Lake, MT 59868 Missoula

System Facility ID:32-05837

Facility Code: 25389
Last Inspected On: 06/24/2023
Operating Permit Renewal Date: 10/17/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Lindeys Inc Saint Paul **(406) 677-9229**

Operator Contact: Michael Lindemer **(406) 677-4101** **lindeys@blackfoot.net**

Owner/Operator: Lindeys Inc Saint Paul (406) 677-9229

Michael Lindemer, UST Class A Operator	lindeys@blackfoot.net
Michael Lindemer, UST Class B Operator	lindeys@blackfoot.net
Tanner Stevenson, UST Class B Global Operator	jenco1992@gmail.com

Tank Number	S3	**Tank Age**	26	**Tank Installed Date**	05/01/1999	**Tank Material Construction**	Concrete	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	4104	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	Yes
Status	**Currently in Use**	**MLLD Test Date**	07/22/2024	**Sump Tightness Test Date**	06/24/2023	**Catastrophic L.D. Type 3.0**	Continuous Interstitial Monitoring;Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	1500	**ATG Test Date**		**Line Tightness Test Date**	10/25/2021	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					

Facility Summary in Missoula County in the City of Seeley Lake

Location: ROVEROS
3182 Hwy 83
Seeley Lake, MT 59868 Missoula

System Facility ID:60-15146

Facility Code: 30890
Last Inspected On: 10/18/2022
Operating Permit Renewal Date: 01/28/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Greg Tabish;Tabish Brothers Distributors Inc	**(406) 543-7621;(406) 728-2575**	**lss@gwpetrol.com;zootown@gwpetrol.com**
Operator Contact:	Karly Shafer;Kyle Marx	**(406) 396-2206;(406) 396-2296**	**karly@gwpetrol.com;roverosace@yahoo.com**

Owner/Operator:	Greg Tabish	(406) 728-2575	zootown@gwpetrol.com
Owner/Operator:	Tabish Brothers Distributors Inc	(406) 728-2575	zootown@gwpetrol.com
	Karly Shafer, UST Class A Operator		karly@gwpetrol.com
	Karly Shafer, UST Class B Global Operator		karly@gwpetrol.com
	Kyle Marx, UST Class A Operator		roverosace@yahoo.com
	Kyle Marx, UST Class B Global Operator		roverosace@yahoo.com
	RaeDean Bartlett, UST Class B Global Operator		raedean68@gmail.com

Tank Number	07	**Tank Age**	30	**Tank Installed Date**	04/01/1995	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	3337	**Spill Test Date**	10/18/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	7000	**ATG Test Date**	10/14/2022	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	01/23/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Number	08	**Tank Age**	30	**Tank Installed Date**	04/01/1995	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	3338	**Spill Test Date**	10/18/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	5000	**ATG Test Date**	10/14/2022	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No

		Overfill Test Date	01/23/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Number	09	**Tank Age**	30	**Tank Installed Date**	04/01/1995	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	3339	**Spill Test Date**	01/23/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	10/14/2022	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	01/23/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Number	10	**Tank Age**	30	**Tank Installed Date**	04/01/1995	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	3340	**Spill Test Date**	10/18/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	10/14/2022	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	01/23/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Number	11	**Tank Age**	30	**Tank Installed Date**	04/01/1995	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	3341	**Spill Test Date**	01/23/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel, Dyed	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	10/14/2022	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	01/23/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Number	12	**Tank Age**	30	**Tank Installed Date**	04/01/1995	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	3342	**Spill Test Date**	01/23/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No

Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	10/14/2022	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	01/23/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Number	13	**Tank Age**	30	**Tank Installed Date**	04/01/1995	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	3343	**Spill Test Date**	10/18/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	2000	**ATG Test Date**	10/14/2022	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	01/23/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				

Facility Summary in Missoula County in the City of TURAH

Location: TURAH STORE and CAMPGROUND
13555 Turah Rd
TURAH, MT 59825-9775 Missoula

System Facility ID:32-04899

Facility Code: 25351
Last Inspected On: 09/09/2019
Operating Permit Renewal Date: 11/01/2022

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Turah Store and Campground LLC **(406) 258-9773**

Operator Contact: Kathleen Marshall **turahrvpark@aol.com**

Jerry Kinney, UST Class B Operator	turahrvpark@aol.com
Jerry Kinney, UST Class B Operator	turahrvpark@aol.com
Kathleen Marshall, UST Class A Operator	turahrvpark@aol.com
Kathleen Marshall, UST Class B Global Operator	turahrvpark@aol.com
Pamela Asbridge, UST Class B Operator	1959pamz@optimum.net
Pamela Asbridge, UST Class B Operator	1959pamz@optimum.net

Tank Number	01	**Tank Age**	53	**Tank Installed Date**	04/18/1972	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Steel	**Overfill Types**	Flapper Valve
Tag Number	4007	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**	Lined Interior/Impressed Current	**Piping Construction**	None	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	07/17/2019	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**		**Line Tightness Test Date**	10/10/2007	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	02	**Tank Age**	53	**Tank Installed Date**	04/18/1972	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Steel	**Overfill Types**	Flapper Valve
Tag Number	4008	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**	Lined Interior/Impressed Current	**Piping Construction**	None	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	07/17/2019	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**		**Vapor Recovery**	No

Capacity	2000	**ATG Test Date**		**Line Tightness Test Date**	10/10/2007	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					

Facility Summary in Musselshell County in the City of Melstone

Location: JAKES GARAGE
221 US Hwy 12
Melstone, MT 59054 Musselshell

System Facility ID:33-01481

Facility Code: 25794
Last Inspected On: 06/03/2024
Operating Permit Renewal Date: 10/01/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Jake Zaharko;Jakes Garage Inc **(406) 358-2389**

Operator Contact: Larry Zaharko;Tim DeJaegher **(406) 358-2389** **Fivezs@midrivers.com;tdejaegher@live.com**

Owner/Operator: Jake Zaharko

Owner/Operator: Jakes Garage Inc

Larry Zaharko, UST Class A Operator	Fivezs@midrivers.com
Larry Zaharko, UST Class A Operator	Fivezs@midrivers.com
Larry Zaharko, UST Class B Operator	Fivezs@midrivers.com
Larry Zaharko, UST Class B Operator	Fivezs@midrivers.com
Tim DeJaegher, UST Class A Operator	tdejaegher@live.com
Tim DeJaegher, UST Class A Operator	tdejaegher@live.com
Tim DeJaegher, UST Class B Operator	tdejaegher@live.com
Tim DeJaegher, UST Class B Operator	tdejaegher@live.com

Tank Number	08	**Tank Age**	27	**Tank Installed Date**	12/01/1998	**Tank Material Construction**	Steel Clad	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	3770	**Spill Test Date**	06/03/2024	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	01/04/2013	**Primary Tank Leak Detection**	Manual Interstitial Monitoring	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	3750	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	06/03/2024			**ATG Type**					
Tank Number	09	**Tank Age**	27	**Tank Installed Date**	12/01/1998	**Tank Material Construction**	Steel Clad	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	3771	**Spill Test Date**	06/03/2024	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Non-corrodible

Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	01/04/2013	**Primary Tank Leak Detection**	Manual Interstitial Monitoring	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	2250	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	06/03/2024			**ATG Type**					

Facility Summary in Musselshell County in the City of Roundup

Location: CONOCO CONVENIENCE CENTER
806 Main St
Roundup, MT 59072-2224 Musselshell

System Facility ID:33-05030

Facility Code: 25845
Last Inspected On: 10/04/2022
Operating Permit Renewal Date: 12/14/2025

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: McCleary Distributing Inc **(406) 323-1108**

Operator Contact: Terry Watkins **(406) 323-1108** **dwatkins3389@hotmail.com**

Owner/Operator: McCleary Distributing Inc (406) 323-1108

Terry Watkins, UST Class A Operator dwatkins3389@hotmail.com
Terry Watkins, UST Class A Operator dwatkins3389@hotmail.com
Terry Watkins, UST Class B Operator dwatkins3389@hotmail.com
Terry Watkins, UST Class B Operator dwatkins3389@hotmail.com

Tank Number	06	**Tank Age**	36	**Tank Installed Date**	08/30/1989	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	1591	**Spill Test Date**	08/23/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Not Listed	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	08/23/2022	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	08/23/2022	**Line Tightness Test Date**	09/09/2016	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	08/23/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Tank Number	07	**Tank Age**	36	**Tank Installed Date**	08/30/1989	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	1592	**Spill Test Date**	08/23/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	08/23/2022	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	08/23/2022	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	08/23/2022	**Line Tightness Test Date**	08/23/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	08/23/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Tank Number	08	**Tank Age**	33	**Tank Installed Date**	09/01/1992	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	1593	**Spill Test Date**	08/23/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	03/05/2025	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	08/23/2022	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	08/23/2022	**Line Tightness Test Date**	03/05/2025	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	08/23/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	09	**Tank Age**	29	**Tank Installed Date**	10/01/1996	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	1594	**Spill Test Date**	08/23/2022	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	08/23/2022	**Sump Tightness Test Date**	07/10/2018	**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Diesel, Dyed	**PLLD Test Date**		**Tank/Piping CP Test Date**	08/23/2022	**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	08/23/2022	**Line Tightness Test Date**	08/23/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	08/23/2022			**ATG Type**	Gilbarco-Veeder Root/ILS-350				
Tank Number	10	**Tank Age**	29	**Tank Installed Date**	10/01/1996	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	1595	**Spill Test Date**	08/23/2022	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	08/23/2022	**Sump Tightness Test Date**	07/10/2018	**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Diesel, Dyed	**PLLD Test Date**		**Tank/Piping CP Test Date**	08/23/2022	**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	2000	**ATG Test Date**	08/23/2022	**Line Tightness Test Date**	08/23/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	08/23/2022			**ATG Type**	Gilbarco-Veeder Root/ILS-350				
Tank Number	11	**Tank Age**	29	**Tank Installed Date**	10/01/1996	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	1596	**Spill Test Date**	08/23/2022	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	08/23/2022	**Sump Tightness Test Date**	07/10/2018	**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic

Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	08/23/2022	**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	08/23/2022	**Line Tightness Test Date**	08/23/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	08/23/2022			**ATG Type**	Gilbarco-Veeder Root/ILS-350				
Tank Number	12	**Tank Age**	29	**Tank Installed Date**	10/01/1996	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	1597	**Spill Test Date**	08/23/2022	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	08/23/2022	**Sump Tightness Test Date**	07/10/2018	**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	08/23/2022	**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	2000	**ATG Test Date**	08/23/2022	**Line Tightness Test Date**	08/23/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	08/23/2022			**ATG Type**	Gilbarco-Veeder Root/ILS-350				

Facility Summary in Musselshell County in the City of Roundup

Location: EXPRESS STOP
701 1st Ave W
Roundup, MT 59072 Musselshell

System Facility ID:33-06612

Facility Code: 25862
Last Inspected On: 06/10/2025
Operating Permit Renewal Date: 09/10/2025

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Thind Inc **(510) 894-5533** **lakhbirkamboj@yahoo.com**

Operator Contact: Lakhbir Singh **(510) 894-5533** **lakhbirkamboj@yahoo.com**

Owner/Operator: Thind Inc (510) 894-5533 lakhbirkamboj@yahoo.com

Lakhbir Singh, UST Class A Operator lakhbirkamboj@yahoo.com

Lakhbir Singh, UST Class B Operator lakhbirkamboj@yahoo.com

Tank Number	04	**Tank Age**	27	**Tank Installed Date**	10/01/1998	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	1985	**Spill Test Date**	07/14/2022	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	07/14/2022	**Tank/Piping CP Test Date**	12/12/2011	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	07/14/2022	**Line Tightness Test Date**	02/10/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	07/14/2022			**ATG Type**	Gilbarco/TLS-350				
Tank Number	05	**Tank Age**	27	**Tank Installed Date**	10/01/1998	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	1986	**Spill Test Date**	07/14/2022	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel, Dyed	**PLLD Test Date**	07/14/2022	**Tank/Piping CP Test Date**	12/12/2011	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	5000	**ATG Test Date**	07/14/2022	**Line Tightness Test Date**	07/14/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	07/14/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Tank Number	06	**Tank Age**	27	**Tank Installed Date**	10/01/1998	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	1987	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Temporarily Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	12/12/2011	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	01	**Tank Age**	40	**Tank Installed Date**	03/26/1985	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	3757	**Spill Test Date**	07/14/2022	**Piping Installed Date**		**Tank Construction**	Lined Interior/Impressed Current	**Piping Construction**	Single Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**	07/14/2022	**Tank/Piping CP Test Date**	08/24/2022	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	07/14/2022	**Line Tightness Test Date**	02/08/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	07/14/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	02	**Tank Age**	40	**Tank Installed Date**	03/26/1985	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	3758	**Spill Test Date**	07/14/2022	**Piping Installed Date**		**Tank Construction**	Lined Interior/Impressed Current	**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**	07/14/2022	**Tank/Piping CP Test Date**	08/24/2022	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	07/14/2022	**Line Tightness Test Date**	02/06/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	07/14/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	03	**Tank Age**	40	**Tank Installed Date**	03/26/1985	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	3759	**Spill Test Date**	08/16/2022	**Piping Installed Date**		**Tank Construction**	Lined Interior/Impressed Current	**Piping Construction**	None	**AST**	No

Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**	07/14/2022	**Tank/Piping CP Test Date**	08/24/2022	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	07/14/2022	**Line Tightness Test Date**	07/14/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	08/24/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Musselshell County in the City of Roundup

Location: FORMER WELLS FARGO BANK ROUNDUP
12 Main St
Roundup, MT 59072-2828 Musselshell

System Facility ID:33-02079

Facility Code: 25806
Last Inspected On: 03/23/2022
Operating Permit Renewal Date: 07/02/2025

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Roundup SD 55 and 55H

Operator Contact: A. Paul Thompson;Scott Wells **(406) 860-7125;(406) 940-5377** **paulthompson@k12.mt.us;sckwells@gmail.com**

A. Paul Thompson, UST Class A Operator	paulthompson@k12.mt.us
A. Paul Thompson, UST Class B Global Operator	paulthompson@k12.mt.us
Scott Wells, UST Class A Operator	sckwells@gmail.com
Scott Wells, UST Class B Global Operator	sckwells@gmail.com

Tank Number	S2	**Tank Age**	32	**Tank Installed Date**	10/06/1993	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Copper	**Overfill Types**	Flapper Valve
Tag Number	3495	**Spill Test Date**	03/23/2022	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**	10/28/2016	**Catastrophic L.D. Type 3.0**	Auto Dialer	**Piping Type**	U.S. Suction	**CP Met Types**	Galvanic
Product	Heating Oil	**PLLD Test Date**		**Tank/Piping CP Test Date**	03/23/2022	**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	03/23/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-300				

Facility Summary in Park County in the City of Clyde Park

Location: DALES FUEL INC
301 1st Ave
Clyde Park, MT 59018 Park

System Facility ID:34-07600

Facility Code: 26059
Last Inspected On: 03/13/2025
Operating Permit Renewal Date: 06/15/2028

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Dales Fuel Inc **(406) 686-4681**

Operator Contact: Dale Jones

Owner/Operator: Dales Fuel Inc (406) 686-4681

Dale Jones, UST Class A Operator
Dale Jones, UST Class A Operator
Jackie Jones, UST Class B Operator dalesfuel@gmail.com
Jackie Jones, UST Class B Operator dalesfuel@gmail.com

Tank Number	05	**Tank Age**	26	**Tank Installed Date**	04/01/1999	**Tank Material Construction**	Steel Clad	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	3991	**Spill Test Date**	03/13/2025	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Manual Interstitial Monitoring	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	03/13/2025			**ATG Type**					
Tank Number	06	**Tank Age**	26	**Tank Installed Date**	04/01/1999	**Tank Material Construction**	Steel Clad	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	3992	**Spill Test Date**	03/13/2025	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Manual Interstitial Monitoring	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	2500	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	03/13/2025			**ATG Type**					
Tank Number	07	**Tank Age**	26	**Tank Installed Date**	04/01/1999	**Tank Material Construction**	Steel Clad	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve

Tag Number	3993	**Spill Test Date**	03/13/2025	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Manual Interstitial Monitoring	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	1900	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	03/13/2025			**ATG Type**					
Tank Number	08	**Tank Age**	26	**Tank Installed Date**	04/01/1999	**Tank Material Construction**	Steel Clad	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	3994	**Spill Test Date**	03/13/2025	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Manual Interstitial Monitoring	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	1900	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	03/13/2025			**ATG Type**					

Facility Summary in Park County in the City of Clyde Park

Location: SHIELDS VALLEY HIGH SCHOOL
401 1st St E
Clyde Park, MT 59018 Park

System Facility ID:34-12515

Facility Code: 26147
Last Inspected On: 10/29/2024
Operating Permit Renewal Date: 03/01/2028

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: School Dist Shields Valley **(406) 578-2176**

Operator Contact: Dan Johnston;Shields Valley School Dist **djohnston@shieldsvalleyschools.org**

Owner/Operator: School Dist Shields Valley (406) 578-2176

Dan Johnston, UST Class A Operator djohnston@shieldsvalleyschools.org
Mitchell Marx, UST Class B Operator mmarx@shieldsvalleyschools.org

Tank Number	01	**Tank Age**	60	**Tank Installed Date**	07/01/1965	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	2725	**Spill Test Date**	10/29/2024	**Piping Installed Date**		**Tank Construction**	Lined Interior/Impressed Current	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Impressed Current
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	10/29/2024	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	10/29/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	10/29/2024			**ATG Type**	Gilbarco/EMC Basic				

Facility Summary in Park County in the City of Cooke City

Location: COOKE CITY EXXON
204 Main St
Cooke City, MT 59020 Park

System Facility ID:34-01584

Facility Code: 25925
Last Inspected On: 06/13/2025
Operating Permit Renewal Date: 09/17/2025

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Wea Enterprises Inc.	**(406) 838-2244**	**cookecityexxon@gmail.com**
Operator Contact:	Joelle Passerello;Timmy Weamer	**(406) 855-5792**	**cookecityexxon@gmail.com;joellepasserello@gmail.com**

Owner/Operator: Wea Enterprises Inc. (406) 838-2244 cookecityexxon@gmail.com

Joelle Passerello, UST Class A Operator joellepasserello@gmail.com
Joelle Passerello, UST Class B Operator joellepasserello@gmail.com
Timmy Weamer, UST Class A Operator cookecityexxon@gmail.com
Timmy Weamer, UST Class B Global Operator cookecityexxon@gmail.com

Tank Number	07	**Tank Age**	34	**Tank Installed Date**	10/01/1991	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve;High Level Alarm
Tag Number	757	**Spill Test Date**	09/23/2021	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**	05/31/2022	**Tank/Piping CP Test Date**	09/23/2021	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**	05/26/2023	**Line Tightness Test Date**	05/30/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	07/05/2022			**ATG Type**	Franklin Fueling Systems/EVO 6000				
Tank Number	08	**Tank Age**	34	**Tank Installed Date**	10/01/1991	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve;High Level Alarm
Tag Number	758	**Spill Test Date**	09/23/2021	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Safe Suction	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**	06/03/2019	**Tank/Piping CP Test Date**	09/23/2021	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**	05/26/2023	**Line Tightness Test Date**	06/03/2019	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	07/05/2022			**ATG Type**	Franklin Fueling Systems/EVO 6000				

Tank Number	09	**Tank Age**	28	**Tank Installed Date**	10/01/1997	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	759	**Spill Test Date**	09/23/2021	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**	05/31/2022	**Tank/Piping CP Test Date**	09/23/2021	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	5000	**ATG Test Date**	05/26/2023	**Line Tightness Test Date**	05/30/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	07/05/2022			**ATG Type**	Franklin Fueling Systems/EVO 6000				
Tank Number	10	**Tank Age**	28	**Tank Installed Date**	10/01/1997	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	760	**Spill Test Date**	09/23/2021	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**	05/31/2022	**Tank/Piping CP Test Date**	09/23/2021	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	05/26/2023	**Line Tightness Test Date**	05/31/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	07/05/2022			**ATG Type**	Franklin Fueling Systems/EVO 6000				

Facility Summary in Park County in the City of Cooke City

Location: COOKE CITY SINCLAIR AND CABINS
115 Main St
Cooke City, MT 59020 Park

System Facility ID:34-10046

Facility Code: 26103
Last Inspected On: 05/20/2025
Operating Permit Renewal Date: 09/17/2025

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Cooke City Sinclair and Lodging, Inc.	**(406) 579-9993**	**benzavora@gmail.com**
Operator Contact:	Ben Zavora;Cooke City Sinclair and Lodging, Inc.;Benjamin Zavora;Cooke City Sinclair and Lodging, Inc.;Rick Sommers	**(406) 579-9993;(406) 838-2244**	**benzavora@gmail.com;benzavora@gmail.com**
Owner/Operator:	Cooke City Sinclair and Lodging, Inc.	(406) 579-9993	benzavora@gmail.com
	Ben Zavora, UST Class A Operator		benzavora@gmail.com
	Ben Zavora, UST Class A Operator		benzavora@gmail.com
	Ben Zavora, UST Class B Operator		benzavora@gmail.com
	Ben Zavora, UST Class B Operator		benzavora@gmail.com
	Benjamin Zavora, UST Class A Operator		benzavora@gmail.com
	Benjamin Zavora, UST Class B Operator		benzavora@gmail.com
	Rick Sommers, UST Class A Operator		
	Rick Sommers, UST Class A Operator		
	Rick Sommers, UST Class B Global Operator		
	Rick Sommers, UST Class B Global Operator		

Tank Number	06	**Tank Age**	27	**Tank Installed Date**	10/01/1998	**Tank Material Construction**	Steel Clad	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	3670	**Spill Test Date**	05/31/2022	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	05/31/2022	**Line Tightness Test Date**	06/03/2019	**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	05/31/2022			**ATG Type**	Incon/Other				
Tank Number	07	**Tank Age**	27	**Tank Installed Date**	10/01/1998	**Tank Material Construction**	Steel Clad	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	3671	**Spill Test Date**	05/31/2022	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No

Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	05/31/2022	**Line Tightness Test Date**	06/03/2019	**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	05/31/2022			**ATG Type**	Incon/				

Facility Summary in Park County in the City of Cooke City

Location: NORTHEAST ENTRANCE GAS PUMPS
NE Entrance of Park
Cooke City, MT 59020 Park

System Facility ID:34-08869

Facility Code: 26082
Last Inspected On: 07/12/2022
Operating Permit Renewal Date: 09/26/2025

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	National Park Service Mammoth	**(307) 344-2333**	
Operator Contact:	Claude Long;Harry Laney;Jason Ogle;Joel Browning;Nathan Munson	**(304) 344-2333;(307) 344-2333;(406) 581-9206;(406) 595-0840**	**claude_long@nps.gov;harry_laney@nps.gov;jason_ogle@nps.gov;joel_browning@nps.gov;nathan_munson@nps.gov**

Owner/Operator: National Park Service Mammoth (307) 344-2333

Claude Long, UST Class A Operator	claude_long@nps.gov
Harry Laney, UST Class A Operator	harry_laney@nps.gov
Harry Laney, UST Class B Operator	harry_laney@nps.gov
Jason Ogle, UST Class A Operator	jason_ogle@nps.gov
Joel Browning, UST Class A Operator	joel_browning@nps.gov
Nathan Munson, UST Class A Operator	nathan_munson@nps.gov

Tank Number	04	**Tank Age**	33	**Tank Installed Date**	08/01/1992	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Steel	**Overfill Types**	Flapper Valve
Tag Number	1741	**Spill Test Date**	08/05/2024	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	05/15/2022	**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	2000	**ATG Test Date**	08/25/2021	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	08/05/2024			**ATG Type**					
Tank Number	05	**Tank Age**	33	**Tank Installed Date**	08/01/1992	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Steel	**Overfill Types**	Flapper Valve
Tag Number	1742	**Spill Test Date**	08/05/2024	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	05/15/2022	**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	2000	**ATG Test Date**	08/25/2021	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No

		Overfill Test Date	08/05/2024			**ATG Type**					

Facility Summary in Park County in the City of Emigrant

Location: B BUNK INC
Parcel 38 N Glastonbury
Emigrant, MT 59027-0519 Park

System Facility ID:34-10959

Facility Code: 26118
Last Inspected On: 05/23/2023
Operating Permit Renewal Date: 08/27/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	B Bunk Inc	**(757) 498-6060**	**padma36mtnow@protonmail.com**
Operator Contact:	Bradford Tisdale	**(757) 498-6060**	**padma36mtnow@protonmail.com**

Owner/Operator: B Bunk Inc (757) 498-6060 padma36mtnow@protonmail.com

Bradford Tisdale, UST Class A Operator padma36mtnow@protonmail.com

Bradford Tisdale, UST Class B Operator padma36mtnow@protonmail.com

Tank Number	01	**Tank Age**	35	**Tank Installed Date**	04/18/1990	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	415	**Spill Test Date**	05/23/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	05/23/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	05/23/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	05/23/2023			**ATG Type**	Veeder Root/TLS-300				

Facility Summary in Park County in the City of Emigrant

Location: CAPSTONE SHELTER
Lot 105 S Glastonbury
Emigrant, MT 59027 Park

System Facility ID:34-10989

Facility Code: 26125
Last Inspected On: 04/23/2025
Operating Permit Renewal Date: 04/23/2028

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Capstone Project **(480) 657-2564**

Operator Contact: Enrico DArgenzio **(602) 859-4563** **rico4ddd@gmail.com**

Owner/Operator: Capstone Project (480) 657-2564

Enrico DArgenzio, UST Class A Operator rico4ddd@gmail.com

Enrico DArgenzio, UST Class B Operator rico4ddd@gmail.com

Tank Number	01	**Tank Age**	35	**Tank Installed Date**	04/13/1990	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Steel	**Overfill Types**	Flapper Valve
Tag Number	4827	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Temporarily Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	09/23/2021	**Primary Tank Leak Detection**	Vapor Monitoring	**Primary Pipe Leak Detection**	Not Listed	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					

Facility Summary in Park County in the City of Emigrant

Location: COMMUNITY CONSERVATION ASSOCIATION
2 B Taurus Rd
Emigrant, MT 59027 Park

System Facility ID:34-10934

Facility Code: 26116
Last Inspected On: 04/23/2025
Operating Permit Renewal Date: 06/12/2028

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Community Conservation Association Inc Emigrant **(406) 579-3399**

Operator Contact: Edward Dratz **(406) 579-3399** **edratz@gmail.com**

Owner/Operator: Community Conservation Association Inc Emigrant (406) 579-3399

Edward Dratz, UST Class A Operator edratz@gmail.com
Edward Dratz, UST Class B Global Operator edratz@gmail.com
Edward Dratz, UST Class B Operator edratz@gmail.com

Tank Number	01	**Tank Age**	35	**Tank Installed Date**	04/18/1990	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	4684	**Spill Test Date**	05/16/2025	**Piping Installed Date**	11/06/1998	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	05/18/2022	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	05/16/2025	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	05/16/2025			**ATG Type**	Veeder Root/TLS-300				

Facility Summary in Park County in the City of Emigrant

Location: COMMUNITY CONTINUITY INC
18 Polaris Way Parcel 70 S Glastonbury
Emigrant, MT 59027 Park

System Facility ID:34-10930

Facility Code: 26113
Last Inspected On: 06/16/2023
Operating Permit Renewal Date: 10/02/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Community Continuity Inc

Operator Contact: Daniel Kehoe **(406) 223-2232** **dankehoe56@gmail.com**

Owner/Operator: Community Continuity Inc

Daniel Kehoe, UST Class A Operator dankehoe56@gmail.com
Daniel Kehoe, UST Class B Operator dankehoe56@gmail.com
Dennis Franks, UST Class B Global Operator dennis@ajminc.net

Tank Number	01	**Tank Age**	35	**Tank Installed Date**	02/01/1990	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	4821	**Spill Test Date**	06/16/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	06/16/2023	**Catastrophic L.D. Type 3.0**	Auto Dialer	**Piping Type**	Gravity Feed	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	06/16/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	20000	**ATG Test Date**	06/16/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	06/16/2023			**ATG Type**	Veeder Root/TLS-300				

Facility Summary in Park County in the City of Emigrant

Location: COMMUNITY RESTORATION INC
Hercules Rd and Polaris Way
Emigrant, MT 59027 Park

System Facility ID:34-10931

Facility Code: 26114
Last Inspected On: 06/16/2023
Operating Permit Renewal Date: 10/02/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Community Restoration Inc **(800) 631-8885**

Operator Contact: Daniel Kehoe **(406) 223-2232** **dankehoe56@gmail.com**

Owner/Operator: Community Restoration Inc (800) 631-8885

Daniel Kehoe, UST Class A Operator dankehoe56@gmail.com
Daniel Kehoe, UST Class B Operator dankehoe56@gmail.com
Dennis Franks, UST Class B Global Operator dennis@ajminc.net

Tank Number	01	**Tank Age**	35	**Tank Installed Date**	02/20/1990	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	701	**Spill Test Date**	06/16/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	06/16/2023	**Catastrophic L.D. Type 3.0**	Auto Dialer	**Piping Type**	U.S. Suction	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	06/16/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	20000	**ATG Test Date**	06/16/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	06/16/2023			**ATG Type**	Veeder Root/TLS-300				

Facility Summary in Park County in the City of Emigrant

Location: DENNIS CURTIN
70 Ramshorn Rd
Emigrant, MT 59027 Park

System Facility ID:56-14035

Facility Code: 30691
Last Inspected On: 09/06/2022
Operating Permit Renewal Date: 12/31/2025

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	D M Curtin Family Limited Partnership	**(406) 333-4056**	**dcurtin@rmxreg.com**
Operator Contact:	Channell Libbey;Todd Fredericksen	**(406) 223-1459**	**chan.libbey@earthlink.net;fredericksentodd@gmail.com**

Owner/Operator: D M Curtin Family Limited Partnership (406) 333-4056 dcurtin@rmxreg.com

Channell Libbey, UST Class A Operator chan.libbey@earthlink.net
Todd Fredericksen, UST Class A Operator fredericksentodd@gmail.com
Todd Fredericksen, UST Class B Operator fredericksentodd@gmail.com

Tank Number	01	**Tank Age**	24	**Tank Installed Date**	10/15/2001	**Tank Material Construction**	Steel Clad	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	4435	**Spill Test Date**	09/06/2022	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	09/06/2022	**Catastrophic L.D. Type 3.0**	Auto Dialer	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel, Dyed	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	09/06/2022			**ATG Type**	Gilbarco-Veeder Root/ILS-350				

Facility Summary in Park County in the City of Emigrant

Location: EARTH HOME PROPERTIES LLC
Evening Star Dr
Emigrant, MT 59027 Park

System Facility ID:34-10978

Facility Code: 26123
Last Inspected On: 08/15/2024
Operating Permit Renewal Date: 08/15/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Earth Home Properties LLC	**(978) 658-3010**	**newhousebuilders@gmail.com**
Operator Contact:	Craig Newhouse	**(978) 65-87675**	**newhousebuilders@gmail.com**

Owner/Operator: Earth Home Properties LLC (978) 658-3010 newhousebuilders@gmail.com

Craig Newhouse, UST Class A Operator newhousebuilders@gmail.com

Craig Newhouse, UST Class B Operator newhousebuilders@gmail.com

Tank Number	01	**Tank Age**	35	**Tank Installed Date**	04/23/1990	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	4753	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Temporarily Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	11/11/2021	**Primary Tank Leak Detection**	Vapor Monitoring	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	02	**Tank Age**	35	**Tank Installed Date**	04/23/1990	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	No Piping	**Overfill Types**	Flapper Valve
Tag Number	4754	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Temporarily Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	11/11/2021	**Primary Tank Leak Detection**	Vapor Monitoring	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					

Facility Summary in Park County in the City of Emigrant

Location: EMIGRANT GENERAL STORE
3 Murphy Ln
Emigrant, MT 59027-6100 Park

System Facility ID:34-06713

Facility Code: 26035
Last Inspected On: 08/28/2024
Operating Permit Renewal Date: 05/28/2022

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	EMGS LLC	**(406) 333-4434**	**cameron@emigrantgeneralstore.com**
Operator Contact:	Cameron Ehrlich;Emigrant General Store	**(406) 333-4434**	**cehlich112@gmail.com;otisranch@wispwest.net**

Owner/Operator: EMGS LLC (406) 333-4434 cameron@emigrantgeneralstore.com

Cameron Ehrlich, UST Class A Operator otisranch@wispwest.net

Cameron Ehrlich, UST Class B Operator otisranch@wispwest.net

Tank Number	02	**Tank Age**	36	**Tank Installed Date**	09/01/1989	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	4351	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Temporarily Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	03/07/2019	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2;Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	ELLD 0.1;ELLD 0.2;ELLD Line Tightness Testing;Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date				**ATG Type**	Veeder Root/TLS-300				
Tank Number	06	**Tank Age**	28	**Tank Installed Date**	01/01/1997	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	4352	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Temporarily Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	03/07/2019	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2;Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	ELLD 0.1;ELLD 0.2;ELLD Line Tightness Testing;Statistical Inventory Reconciliation	**Vapor Recovery**	No

Capacity	10000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date				**ATG Type**	Veeder Root/TLS-300				
Tank Number	01	**Tank Age**	36	**Tank Installed Date**	09/01/1989	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	4353	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Temporarily Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	03/07/2019	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2;Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	ELLD 0.1;ELLD 0.2;ELLD Line Tightness Testing;Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date				**ATG Type**	Veeder Root/TLS-300				
Tank Number	07	**Tank Age**	7	**Tank Installed Date**	11/15/2018	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	5852	**Spill Test Date**	08/28/2024	**Piping Installed Date**	11/15/2018	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	08/28/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	Yes
Capacity	12000	**ATG Test Date**	08/28/2024	**Line Tightness Test Date**	03/01/2019	**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	08/28/2024			**ATG Type**	Incon/TS-550 EVO				
Tank Number	08	**Tank Age**	7	**Tank Installed Date**	11/15/2018	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	5853	**Spill Test Date**	08/28/2024	**Piping Installed Date**	11/15/2018	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	08/28/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	Yes
Capacity	8000	**ATG Test Date**	08/28/2024	**Line Tightness Test Date**	03/05/2019	**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	08/28/2024			**ATG Type**	Incon/TS-550 EVO				

Tank Number	09	**Tank Age**	7	**Tank Installed Date**	11/15/2018	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	5854	**Spill Test Date**	08/28/2024	**Piping Installed Date**	11/15/2018	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	08/28/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	08/28/2024	**Line Tightness Test Date**	03/05/2019	**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	08/28/2024			**ATG Type**	Incon/TS-550 EVO				

Facility Summary in Park County in the City of Emigrant

Location: LIFESAVERS INC
Lot 28 N Glastonbury
Emigrant, MT 59027-0056 Park

System Facility ID:34-10965

Facility Code: 26120
Last Inspected On: 06/21/2021
Operating Permit Renewal Date: 06/21/2024

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Lifesavers Inc

Operator Contact: Patricia Jones;Robert Smith **(406) 295-5852** **patricia_sk@sbcglobal.net**

Patricia Jones, UST Class A Operator	patricia_sk@sbcglobal.net
Patricia Jones, UST Class B Operator	patricia_sk@sbcglobal.net
Robert Smith, UST Class A Operator	
Robert Smith, UST Class B Operator	

Tank Number	01	**Tank Age**	35	**Tank Installed Date**	04/01/1990	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Copper	**Overfill Types**	Flapper Valve
Tag Number	4499	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	06/21/2021	**Primary Tank Leak Detection**	Vapor Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring;Vapor Monitoring	**Vapor Recovery**	No
Capacity	24000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					

Facility Summary in Park County in the City of Emigrant

Location: ROSKIND RANCH
65 Arcturus Dr
Emigrant, MT 59027 Park

System Facility ID:34-13180

Facility Code: 26156
Last Inspected On: 01/16/2023
Operating Permit Renewal Date: 01/16/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Alicia Roskind	**(424) 610-6640**	**asroskind@gmail.com**
Operator Contact:	Alicia Roskind;Kenneth Mueller	**(406) 333-4669;(424) 610-6640**	**asroskind@gmail.com;kencmueller@gmail.com**

Owner/Operator: Alicia Roskind (424) 610-6640 asroskind@gmail.com

Alicia Roskind, UST Class A Operator	asroskind@gmail.com
Alicia Roskind, UST Class B Global Operator	asroskind@gmail.com
Alicia Roskind, UST Class B Operator	asroskind@gmail.com
Kenneth Mueller, UST Class A Operator	kencmueller@gmail.com
Kenneth Mueller, UST Class B Operator	kencmueller@gmail.com

Tank Number	02	**Tank Age**	30	**Tank Installed Date**	12/01/1995	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	3123	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Temporarily Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	01/16/2023	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					

Facility Summary in Park County in the City of Emigrant

Location: SHELTER INVINCIBLE INC
25 Gemini Rd
Emigrant, MT 59027 Park

System Facility ID:34-10933

Facility Code: 26115
Last Inspected On: 09/21/2020
Operating Permit Renewal Date: 08/24/2023

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Shelter Invincible Inc	**(406) 333-4485**	**alane@vondir.com**
Operator Contact:	David Tonkin		**cdavid@wispwest.net**

Charles Widaman, UST Class B Operator
Charles Widaman, UST Class B Operator
David Tonkin, UST Class A Operator cdavid@wispwest.net
David Tonkin, UST Class A Operator cdavid@wispwest.net
David Tonkin, UST Class B Operator cdavid@wispwest.net
David Tonkin, UST Class B Operator cdavid@wispwest.net

Tank Number	01	**Tank Age**	35	**Tank Installed Date**	04/17/1990	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Copper	**Overfill Types**	Flapper Valve
Tag Number	1882	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Secondary Containment Chase	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	09/21/2020	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Park County in the City of Gardiner

Location: GARDINER SCHOOL DIST 4
510 Stone St
Gardiner, MT 59030-9378 Park

System Facility ID:34-09287

Facility Code: 26086
Last Inspected On: 11/09/2017
Operating Permit Renewal Date: 01/02/2021

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: School Dist 7 & 4 Gardiner Public **(406) 848-7563**

Operator Contact: Douglas Coy;Tom Nelson **tnelson@gardiner.org**

Douglas Coy, UST Class A Operator
Douglas Coy, UST Class B Operator
Tom Nelson, UST Class A Operator tnelson@gardiner.org
Tom Nelson, UST Class B Operator tnelson@gardiner.org

Tank Number	S2	**Tank Age**	38	**Tank Installed Date**	04/24/1987	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	4451	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**	10/31/2018	**Catastrophic L.D. Type 3.0**	Auto Dialer	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Heating Oil	**PLLD Test Date**		**Tank/Piping CP Test Date**	11/09/2017	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	16000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Park County in the City of Gardiner

Location: GARDINER SERVICE CENTER
US Hwy 89 S
Gardiner, MT 59030 Park

System Facility ID:34-08868

Facility Code: 26081
Last Inspected On: 03/01/2022
Operating Permit Renewal Date: 07/28/2025

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Xanterra Parks and Resorts Inc	**(307) 344-5340**	**DYHOFFMAN@XANTERRA.COM**
Operator Contact:	Anthony Bevill;Xanterra Parks and Resorts Inc;Dylan Hoffman;Josiah Reese;Samuel Krasnobrod	**(307) 344-5204;(307) 344-5340;(307) 344-5593;(406) 220-9348**	**abevill@xanterra.com;DYHOFFMAN@XANTERRA.COM;dhoffman@xanterra.com;jreese@xanterra.com;skrasnobrod@xanterra.com**

Owner/Operator:	Xanterra Parks and Resorts Inc	(307) 344-5340	DYHOFFMAN@XANTERRA.COM
	Anthony Bevill, UST Class A Operator		DYHOFFMAN@XANTERRA.COM
	Anthony Bevill, UST Class B Operator		DYHOFFMAN@XANTERRA.COM
	Dylan Hoffman, UST Class A Operator		dhoffman@xanterra.com
	Dylan Hoffman, UST Class A Operator		dhoffman@xanterra.com
	Dylan Hoffman, UST Class B Operator		dhoffman@xanterra.com
	Dylan Hoffman, UST Class B Operator		dhoffman@xanterra.com
	Josiah Reese, UST Class A Operator		jreese@xanterra.com
	Josiah Reese, UST Class A Operator		jreese@xanterra.com
	Josiah Reese, UST Class B Global Operator		jreese@xanterra.com
	Josiah Reese, UST Class B Global Operator		jreese@xanterra.com
	Samuel Krasnobrod, UST Class A Operator		skrasnobrod@xanterra.com

Tank Number	06	**Tank Age**	29	**Tank Installed Date**	04/01/1996	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	3492	**Spill Test Date**	04/29/2025	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	07/16/2018	**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	09/17/2021	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	04/29/2025			**ATG Type**	Gilbarco/EMC Basic;Gilbarco-Veeder Root/EMC Basic				
Tank Number	07	**Tank Age**	29	**Tank Installed Date**	04/01/1996	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve

Tag Number	3493	**Spill Test Date**	04/29/2025	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	07/16/2018	**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	5000	**ATG Test Date**	09/17/2021	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	04/29/2025			**ATG Type**	Gilbarco/EMC Basic;Gilbarco-Veeder Root/EMC Basic				

Facility Summary in Park County in the City of Gardiner

Location: GARDINER SINCLAIR
375 US Hwy 89 S
Gardiner, MT 59030 Park

System Facility ID:60-15332

Facility Code: 32332
Last Inspected On: 09/07/2022
Operating Permit Renewal Date: 02/15/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	GBP Enterprises LLC	**(406) 223-7333**	**jg@ypss.com**
Operator Contact:	Jeff Guengerich;Paul Bauer	**(406) 223-7333;(406) 224-2620**	**jg@ypss.com;paul.r.bauer@gmail.com**

Owner/Operator: GBP Enterprises LLC (406) 223-7333 jg@ypss.com

Jeff Guengerich, UST Class A Operator	jg@ypss.com
Jeff Guengerich, UST Class B Global Operator	jg@ypss.com
Paul Bauer, UST Class A Operator	paul.r.bauer@gmail.com
Paul Bauer, UST Class B Global Operator	paul.r.bauer@gmail.com

Tank Number	1	**Tank Age**	6	**Tank Installed Date**	08/12/2019	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	5904	**Spill Test Date**	09/07/2022	**Piping Installed Date**	08/12/2019	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	09/07/2022	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline, E10	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	Yes
Capacity	20000	**ATG Test Date**	09/07/2022	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	09/07/2022			**ATG Type**					
Tank Number	2	**Tank Age**	6	**Tank Installed Date**	08/12/2019	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	5905	**Spill Test Date**	09/07/2022	**Piping Installed Date**	08/12/2019	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	09/07/2022	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	Yes
Capacity	10000	**ATG Test Date**	09/07/2022	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	09/07/2022			**ATG Type**					

Tank Number	3	**Tank Age**	6	**Tank Installed Date**	08/12/2019	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	5906	**Spill Test Date**	09/07/2022	**Piping Installed Date**	08/12/2019	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	09/07/2022	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	15000	**ATG Test Date**	09/07/2022	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	09/07/2022			**ATG Type**					
Tank Number	4	**Tank Age**	6	**Tank Installed Date**	08/12/2019	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	5907	**Spill Test Date**	09/07/2022	**Piping Installed Date**	08/12/2019	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	09/07/2022	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	Yes
Capacity	10000	**ATG Test Date**	09/07/2022	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	09/07/2022			**ATG Type**					
Tank Number	5	**Tank Age**	6	**Tank Installed Date**	08/12/2019	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	5908	**Spill Test Date**	09/07/2022	**Piping Installed Date**	08/12/2019	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	09/07/2022	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel, Dyed	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	15000	**ATG Test Date**	09/07/2022	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	09/07/2022			**ATG Type**					

Facility Summary in Park County in the City of Gardiner

Location: RANCH OFFICE
558 Old Yellowstone Trl S
Gardiner, MT 59030-9359 Park

System Facility ID:34-03402

Facility Code: 25977
Last Inspected On: 06/05/2023
Operating Permit Renewal Date: 09/03/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Church Universal and Triumphant Inc **(406) 848-9200**

Operator Contact: David Otis **(406) 848-9043** **daotis@tsl.org**

Owner/Operator: Church Universal and Triumphant Inc (406) 848-9200

David Otis, UST Class A Operator daotis@tsl.org

David Otis, UST Class B Operator daotis@tsl.org

Tank Number	07	**Tank Age**	37	**Tank Installed Date**	10/21/1988	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Steel	**Overfill Types**	High Level Alarm
Tag Number	1861	**Spill Test Date**	06/05/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	06/05/2023	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	06/05/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	20000	**ATG Test Date**	06/05/2023	**Line Tightness Test Date**	06/05/2023	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	06/05/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	08	**Tank Age**	37	**Tank Installed Date**	10/21/1988	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Steel	**Overfill Types**	High Level Alarm
Tag Number	1862	**Spill Test Date**	06/05/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	06/05/2023	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	06/05/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	20000	**ATG Test Date**	06/05/2023	**Line Tightness Test Date**	06/05/2023	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	06/05/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Park County in the City of Gardiner

Location: TOWN STATION
401 Scott St W
Gardiner, MT 59030-0507 Park

System Facility ID:34-06531

Facility Code: 26030
Last Inspected On: 10/10/2023
Operating Permit Renewal Date: 03/03/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Gardiner Town Club Inc	**(406) 848-7322**	**townstation@outlook.com**
Operator Contact:	Wade Laubach	**(406) 223-0847**	**townstation@outlook.com**

Owner/Operator:	Gardiner Town Club Inc	(406) 848-7322	townstation@outlook.com
	Scott Kremer, UST Class B Global Operator		patty@kremerbrothers.com;kremer4mt@wildblue.net
	Scott Kremer, UST Class B Global Operator		patty@kremerbrothers.com;kremer4mt@wildblue.net
	Wade Laubach, UST Class A Operator		townstation@outlook.com
	Wade Laubach, UST Class A Operator		townstation@outlook.com

Tank Number	01	**Tank Age**	41	**Tank Installed Date**	04/16/1984	**Tank Material Construction**	Bare Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	3189	**Spill Test Date**		**Piping Installed Date**	11/12/2019	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	10/10/2023	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**	01/04/2024	**Tank/Piping CP Test Date**	10/10/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	01/04/2024	**Line Tightness Test Date**	10/03/2017	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date	10/10/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Number	02	**Tank Age**	41	**Tank Installed Date**	04/16/1984	**Tank Material Construction**	Bare Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	3190	**Spill Test Date**	10/10/2023	**Piping Installed Date**	11/12/2019	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	10/10/2023	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**	01/04/2024	**Tank/Piping CP Test Date**	10/10/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	01/04/2024	**Line Tightness Test Date**	10/03/2017	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No

		Overfill Test Date	10/10/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Number	03	**Tank Age**	41	**Tank Installed Date**	04/16/1984	**Tank Material Construction**	Bare Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	3191	**Spill Test Date**	10/10/2023	**Piping Installed Date**	11/12/2019	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	10/10/2023	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Diesel	**PLLD Test Date**	01/04/2024	**Tank/Piping CP Test Date**	10/10/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	01/04/2024	**Line Tightness Test Date**	10/03/2017	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date	10/10/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Number	04	**Tank Age**	41	**Tank Installed Date**	04/16/1984	**Tank Material Construction**	Bare Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	3192	**Spill Test Date**	10/10/2023	**Piping Installed Date**	11/12/2019	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	10/10/2023	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**	01/04/2024	**Tank/Piping CP Test Date**	10/10/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	01/04/2024	**Line Tightness Test Date**	10/03/2017	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date	10/10/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				

Facility Summary in Park County in the City of Livingston

Location: CASEYS CORNER 4
2050 S Park
Livingston, MT 59047-9133 Park

System Facility ID:34-09906

Facility Code: 26096
Last Inspected On: 04/08/2025
Operating Permit Renewal Date: 07/22/2028

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Superpumper Inc **(701) 852-1194**

Operator Contact: Vern Patterson;Parkland USA Corporation **(701) 720-6649;(701) 852-1194** **vern.patterson@parklandusa.com;Jake.thomas@parklandusa.com**

Owner/Operator: Superpumper Inc (701) 852-1194

Scott Trullinger, UST Class B Operator Jake.thomas@parklandusa.com
Vern Patterson, UST Class A Operator Jake.thomas@parklandusa.com
Vern Patterson, UST Class B Operator Jake.thomas@parklandusa.com

Tank Number	05	**Tank Age**	27	**Tank Installed Date**	05/01/1998	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	2033	**Spill Test Date**	04/16/2021	**Piping Installed Date**	02/20/2017	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	03/18/2021	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	04/08/2025	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	03/26/2025	**Line Tightness Test Date**	02/23/2016	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date	04/08/2025			**ATG Type**	Franklin Fueling Systems/EVO 6000				
Tank Number	06	**Tank Age**	27	**Tank Installed Date**	05/01/1998	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	2034	**Spill Test Date**	04/16/2021	**Piping Installed Date**	02/20/2017	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	03/18/2021	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	04/08/2025	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	03/26/2025	**Line Tightness Test Date**	02/23/2016	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No

		Overfill Test Date	04/08/2025			**ATG Type**	Franklin Fueling Systems/EVO 6000				
Tank Number	07	**Tank Age**	27	**Tank Installed Date**	05/01/1998	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	2035	**Spill Test Date**	03/18/2021	**Piping Installed Date**	02/20/2017	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	03/18/2021	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	04/08/2025	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	03/26/2025	**Line Tightness Test Date**	02/23/2016	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date	04/08/2025			**ATG Type**	Franklin Fueling Systems/EVO 6000				

Facility Summary in Park County in the City of Livingston

Location: CITY COUNTY COMPLEX
414 E Callender St
Livingston, MT 59047-2700 Park

System Facility ID:34-10573

Facility Code: 26105
Last Inspected On: 09/07/2022
Operating Permit Renewal Date: 10/01/2025

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Park County Shop - City of Livingston **(406) 222-4106**

Operator Contact: Kelly Johnson **(406) 222-4141** **maintenance@parkcounty.org**

Owner/Operator: Park County Shop - City of Livingston (406) 222-4106

Kelly Johnson, UST Class A Operator	maintenance@parkcounty.org
Kelly Johnson, UST Class A Operator	maintenance@parkcounty.org
Kelly Johnson, UST Class B Global Operator	maintenance@parkcounty.org
Kelly Johnson, UST Class B Global Operator	maintenance@parkcounty.org

Tank Number	02	**Tank Age**	30	**Tank Installed Date**	11/01/1995	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	1783	**Spill Test Date**	09/07/2022	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Continuous Interstitial Monitoring	**Piping Type**	U.S. Suction	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	3-Year Line Tightness Test	**Vapor Recovery**	No
Capacity	3000	**ATG Test Date**	09/07/2022	**Line Tightness Test Date**	09/28/2022	**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.1	**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	09/07/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-300;Veeder Root/TLS-300				

Facility Summary in Park County in the City of Livingston

Location: TJS GAS N CONVENIENCE
204 E Park St
Livingston, MT 59047-2713 Park

System Facility ID:34-13736

Facility Code: 26167
Last Inspected On: 05/05/2023
Operating Permit Renewal Date: 09/03/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: TJs Gas N Convenience **(406) 222-9720**

Operator Contact: Becky Thomas;William Woods **(406) 222-9720** **becalicious@yahoo.com;wjwoods10@gmail.com**

Owner/Operator: TJs Gas N Convenience (406) 222-9720

Becky Thomas, UST Class A Operator	becalicious@yahoo.com
Becky Thomas, UST Class B Global Operator	becalicious@yahoo.com
William Woods, UST Class A Operator	wjwoods10@gmail.com
William Woods, UST Class B Operator	wjwoods10@gmail.com

Tank Number	01	**Tank Age**	29	**Tank Installed Date**	05/01/1996	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	3371	**Spill Test Date**	05/05/2023	**Piping Installed Date**	06/24/2014	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	01/12/2022	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	01/22/2022	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	05/05/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date	05/05/2023			**ATG Type**	Veeder Root/TLS-300				
Tank Number	02	**Tank Age**	29	**Tank Installed Date**	05/01/1996	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	3372	**Spill Test Date**	05/05/2023	**Piping Installed Date**	06/24/2014	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	01/12/2022	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	01/22/2022	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	05/05/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date	05/05/2023			**ATG Type**	Veeder Root/TLS-300				

Facility Summary in Park County in the City of Livingston

Location: TOWN PUMP INC LIVINGSTON 2
716 E Park St
Livingston, MT 59047 Park

System Facility ID:34-08713

Facility Code: 26078
Last Inspected On: 03/25/2025
Operating Permit Renewal Date: 08/30/2028

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Livingston 2 Town Pump LLC **(406) 497-6700** **environmental@townpump.com**

Operator Contact: Trent Biggers **Trentb@townpump.com**

Owner/Operator: Livingston 2 Town Pump LLC (406) 497-6700 environmental@townpump.com

Trent Biggers, UST Class A Operator Trentb@townpump.com
Trent Biggers, UST Class A Operator Trentb@townpump.com
Trent Biggers, UST Class B Global Operator Trentb@townpump.com
Trent Biggers, UST Class B Global Operator Trentb@townpump.com

Tank Number	03	**Tank Age**	29	**Tank Installed Date**	09/01/1996	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	2575	**Spill Test Date**	08/06/2024	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	05/13/2021	**Sump Tightness Test Date**	08/15/2022	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	03/25/2025	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	03/25/2025	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	08/06/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Number	04	**Tank Age**	29	**Tank Installed Date**	09/01/1996	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	2576	**Spill Test Date**	08/06/2024	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	05/13/2021	**Sump Tightness Test Date**	08/15/2022	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	03/25/2025	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No

Capacity	12000	**ATG Test Date**	03/25/2025	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	08/06/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Number	05	**Tank Age**	29	**Tank Installed Date**	09/01/1996	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	2577	**Spill Test Date**	08/06/2024	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	05/13/2021	**Sump Tightness Test Date**	08/15/2022	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	03/25/2025	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	03/25/2025	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	08/06/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Number	06	**Tank Age**	29	**Tank Installed Date**	09/01/1996	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	2578	**Spill Test Date**	08/06/2024	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	05/13/2021	**Sump Tightness Test Date**	08/15/2022	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	03/25/2025	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	03/25/2025	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	Yes
		Overfill Test Date	08/06/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				

Facility Summary in Park County in the City of Livingston

Location: TOWN PUMP INC LIVINGSTON 3
2200 Park St S
Livingston, MT 59047 Park

System Facility ID:34-13409

Facility Code: 26162
Last Inspected On: 03/25/2025
Operating Permit Renewal Date: 08/02/2028

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Livingston 3 Town Pump LLC	**(406) 497-6700**	**environmental@townpump.com**
Operator Contact:	Trent Biggers		**Trentb@townpump.com**

Owner/Operator:	Livingston 3 Town Pump LLC	(406) 497-6700	environmental@townpump.com
	Trent Biggers, UST Class A Operator		Trentb@townpump.com
	Trent Biggers, UST Class A Operator		Trentb@townpump.com
	Trent Biggers, UST Class B Global Operator		Trentb@townpump.com
	Trent Biggers, UST Class B Global Operator		Trentb@townpump.com

Tank Number	01	**Tank Age**	31	**Tank Installed Date**	05/20/1994	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve
Tag Number	2579	**Spill Test Date**	11/04/2024	**Piping Installed Date**	04/20/2011	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	05/12/2021	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	12/30/2019	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	05/12/2021	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/TLS-450;Gilbarco-Veeder Root/TLS-450PLUS				
Tank Number	02	**Tank Age**	31	**Tank Installed Date**	05/20/1994	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve
Tag Number	2580	**Spill Test Date**	05/12/2021	**Piping Installed Date**	04/20/2011	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	05/12/2021	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	12/30/2019	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No

Capacity	12000	**ATG Test Date**	05/12/2021	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/TLS-450;Gilbarco-Veeder Root/TLS-450PLUS				
Tank Number	03	**Tank Age**	31	**Tank Installed Date**	05/01/1994	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve
Tag Number	2581	**Spill Test Date**	07/19/2021	**Piping Installed Date**	04/20/2011	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	05/12/2021	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	12/30/2019	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	05/12/2021	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/TLS-450;Gilbarco-Veeder Root/TLS-450PLUS				
Tank Number	04	**Tank Age**	31	**Tank Installed Date**	05/01/1994	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve
Tag Number	2582	**Spill Test Date**	07/19/2021	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	05/12/2021	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	12/30/2019	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	05/12/2021	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/TLS-450;Gilbarco-Veeder Root/TLS-450PLUS				
Tank Number	05	**Tank Age**	31	**Tank Installed Date**	05/01/1994	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve
Tag Number	2583	**Spill Test Date**	07/19/2021	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	05/12/2021	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible

Product	Diesel	**PLLD Test Date**	12/30/2019	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	05/12/2021	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/TLS-450;Gilbarco-Veeder Root/TLS-450PLUS				
Tank Number	06	**Tank Age**	24	**Tank Installed Date**	10/01/2001	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve
Tag Number	4377	**Spill Test Date**	07/19/2021	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	05/12/2021	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel, Dyed	**PLLD Test Date**	12/30/2019	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	05/12/2021	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/TLS-450;Gilbarco-Veeder Root/TLS-450PLUS				
Tank Number	07	**Tank Age**	24	**Tank Installed Date**	10/01/2001	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve
Tag Number	4378	**Spill Test Date**	11/04/2024	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	05/12/2021	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	12/30/2019	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	5000	**ATG Test Date**	05/12/2021	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/TLS-450;Gilbarco-Veeder Root/TLS-450PLUS				
Tank Number	08	**Tank Age**	24	**Tank Installed Date**	10/01/2001	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve
Tag Number	4379	**Spill Test Date**	11/04/2024	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No

Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	05/12/2021	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	12/30/2019	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	05/12/2021	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				

Facility Summary in Park County in the City of Livingston

Location: YELLOWSTONE TRAVEL PLAZA
1226 US Hwy 10 W
Livingston, MT 59047-9004 Park

System Facility ID:34-11200

Facility Code: 26137
Last Inspected On: 11/16/2022
Operating Permit Renewal Date: 03/25/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: LIVINGSTON 10W LLC **MOTIBALYAN@GMAIL.COM**

Operator Contact: Moti Balyan;Yellowstone Travel Plaza **(406) 222-6180** **MOTIBALYAN@GMAIL.COM;gchana26@gmail.com**

Owner/Operator: LIVINGSTON 10W LLC MOTIBALYAN@GMAIL.COM

Moti Balyan, UST Class A Operator gchana26@gmail.com

Moti Balyan, UST Class B Operator gchana26@gmail.com

Tank Number	01	**Tank Age**	36	**Tank Installed Date**	01/01/1989	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	2313	**Spill Test Date**	08/26/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	11/16/2022	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	07/21/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	08/26/2022			**ATG Type**	Incon/TS-1001				
Tank Number	02	**Tank Age**	36	**Tank Installed Date**	01/01/1989	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	2314	**Spill Test Date**	08/26/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	11/16/2022	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**	07/21/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	08/26/2022			**ATG Type**	Incon/TS-1001				
Tank Number	03	**Tank Age**	36	**Tank Installed Date**	01/01/1989	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	2315	**Spill Test Date**	08/26/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No

Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	11/16/2022	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**	07/21/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	08/26/2022			**ATG Type**	Incon/TS-1001				
Tank Number	04	**Tank Age**	36	**Tank Installed Date**	01/01/1989	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	2316	**Spill Test Date**	08/26/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	11/16/2022	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**	07/21/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	08/26/2022			**ATG Type**	Incon/TS-1001				

Facility Summary in Park County in the City of Livingston

Location: ZIP TRIP 47
101 Centennial Dr
Livingston, MT 59047-9155 Park

System Facility ID:34-11741

Facility Code: 26145
Last Inspected On: 09/03/2024
Operating Permit Renewal Date: 11/08/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	CHS Inc Spokane Valley	**(509) 535-7701**	**Donald.Widdicombe@chsinc.com**
Operator Contact:	Jim Alford;Sean Hurley	**(509) 535-7701;(509) 536-7418**	**jim.alford@chsinc.com;sean.hurley@chsinc.com**

Owner/Operator: CHS Inc Spokane Valley (509) 535-7701 Donald.Widdicombe@chsinc.com

Jim Alford, UST Class A Operator	jim.alford@chsinc.com
Jim Alford, UST Class A Operator	jim.alford@chsinc.com
Jim Alford, UST Class B Operator	jim.alford@chsinc.com
Jim Alford, UST Class B Operator	jim.alford@chsinc.com
Luci Tuttle, UST Class B Operator	Lucinda.Tuttle@chsinc.com
Sean Hurley, UST Class A Operator	sean.hurley@chsinc.com
Sean Hurley, UST Class A Operator	sean.hurley@chsinc.com
Travis Weber, UST Class B Operator	travis.weber3@chsinc.com

Tank Number	01	**Tank Age**	35	**Tank Installed Date**	09/01/1990	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	562	**Spill Test Date**	08/15/2024	**Piping Installed Date**	06/25/2018	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	08/15/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**	08/06/2024	**Tank/Piping CP Test Date**	08/15/2024	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	08/06/2024	**Line Tightness Test Date**	01/04/2021	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date	08/15/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	02	**Tank Age**	35	**Tank Installed Date**	09/01/1990	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	563	**Spill Test Date**	08/15/2024	**Piping Installed Date**	06/25/2018	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	08/15/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic

Product	Gasoline	**PLLD Test Date**	08/06/2024	**Tank/Piping CP Test Date**	08/15/2024	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	08/06/2024	**Line Tightness Test Date**	01/04/2021	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date	08/15/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	03	**Tank Age**	35	**Tank Installed Date**	09/01/1990	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	564	**Spill Test Date**	08/15/2024	**Piping Installed Date**	06/25/2018	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	08/15/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**	08/06/2024	**Tank/Piping CP Test Date**	08/15/2024	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	08/06/2024	**Line Tightness Test Date**	01/04/2021	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date	08/15/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Park County in the City of Wilsall

Location: PARK FARMERS COOP
114 S Elliot
Wilsall, MT 59086 Park

System Facility ID:34-06686

Facility Code: 26034
Last Inspected On: 05/06/2025
Operating Permit Renewal Date: 05/24/2028

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Park Farmers Coop **(406) 578-2543**

Operator Contact: Don Scott **pfcoop@aol.com**

Owner/Operator: Park Farmers Coop (406) 578-2543

Don Scott, UST Class A Operator	pfcoop@aol.com
Don Scott, UST Class A Operator	pfcoop@aol.com
Don Scott, UST Class B Operator	pfcoop@aol.com
Don Scott, UST Class B Operator	pfcoop@aol.com
Donald Scott, UST Class B Operator	pfcoop@aol.com
Donald Scott, UST Class B Operator	pfcoop@aol.com

Tank Number	13	**Tank Age**	32	**Tank Installed Date**	07/01/1993	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	1784	**Spill Test Date**	05/06/2025	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	05/06/2025	**Tank/Piping CP Test Date**	04/26/2010	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	05/06/2025	**Line Tightness Test Date**	02/05/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	05/06/2025			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	14	**Tank Age**	32	**Tank Installed Date**	07/01/1993	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	1785	**Spill Test Date**	05/06/2025	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel, Dyed	**PLLD Test Date**	05/06/2025	**Tank/Piping CP Test Date**	04/26/2010	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	05/06/2025	**Line Tightness Test Date**	02/06/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No

		Overfill Test Date	05/06/2025			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	15	**Tank Age**	32	**Tank Installed Date**	07/01/1993	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	1786	**Spill Test Date**	05/06/2025	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	05/06/2025	**Tank/Piping CP Test Date**	04/26/2010	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**	05/06/2025	**Line Tightness Test Date**	02/05/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	05/06/2025			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	16	**Tank Age**	32	**Tank Installed Date**	07/01/1993	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	1787	**Spill Test Date**	05/06/2025	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	05/06/2025	**Tank/Piping CP Test Date**	04/26/2010	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**	05/06/2025	**Line Tightness Test Date**	02/07/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	05/06/2025			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Petroleum County in the City of Winnett

Location: WINNETT TIRE AND SERVICE
115 N Broadway
Winnett, MT 59087 Petroleum

System Facility ID:35-00536

Facility Code: 26168
Last Inspected On: 03/19/2025
Operating Permit Renewal Date: 06/17/2028

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: WINNETT TIRE AND SERVICE LLC **(406) 429-2961** **zimmagcattle@yahoo.com**

Operator Contact: Jennifer Zimmerman;Winnett Tire

Owner/Operator: WINNETT TIRE AND SERVICE LLC (406) 429-2961 zimmagcattle@yahoo.com

Jennifer Zimmerman, UST Class A Operator

Jennifer Zimmerman, UST Class B Operator

Tank Number	S3	**Tank Age**	26	**Tank Installed Date**	09/27/1999	**Tank Material Construction**	Bare Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	4094	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	Yes
Status	**Currently in Use**	**MLLD Test Date**	03/19/2025	**Sump Tightness Test Date**	10/24/2016	**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	2000	**ATG Test Date**		**Line Tightness Test Date**	03/19/2025	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	S4	**Tank Age**	26	**Tank Installed Date**	09/27/1999	**Tank Material Construction**	Bare Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	4095	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	Yes
Status	**Currently in Use**	**MLLD Test Date**	03/19/2025	**Sump Tightness Test Date**	10/24/2016	**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	3000	**ATG Test Date**		**Line Tightness Test Date**	03/19/2025	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	S5	**Tank Age**	26	**Tank Installed Date**	09/27/1999	**Tank Material Construction**	Bare Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm

Tag Number	4096	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	Yes
Status	**Currently in Use**	**MLLD Test Date**	03/19/2025	**Sump Tightness Test Date**	10/24/2016	**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	3000	**ATG Test Date**		**Line Tightness Test Date**	03/19/2025	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	S6	**Tank Age**	26	**Tank Installed Date**	09/27/1999	**Tank Material Construction**	Bare Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	4097	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	Yes
Status	**Currently in Use**	**MLLD Test Date**	03/19/2025	**Sump Tightness Test Date**	10/24/2016	**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	3000	**ATG Test Date**		**Line Tightness Test Date**	03/19/2025	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date				**ATG Type**					

Facility Summary in Petroleum County in the City of Winnett

Location: WINNETT TRANSPORTATION SERVICES LLC
305 N BROADWAY AVE
Winnett, MT 59087-0131 Petroleum

System Facility ID:56-13897

Facility Code: 30570
Last Inspected On: 10/11/2024
Operating Permit Renewal Date: 01/26/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: WINNETT TRANSPORTATION SERVICES LLC **(406) 429-5291** **winnetttransportation@gmail.com**

Operator Contact:

Owner/Operator: WINNETT TRANSPORTATION SERVICES LLC (406) 429-5291 winnetttransportation@gmail.com

Tank Number	S5	**Tank Age**	26	**Tank Installed Date**	04/01/1999	**Tank Material Construction**	Unknown	**Piping Material**	Flexible Plastic	**Overfill Types**	
Tag Number	4001	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	Yes
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	10/11/2024	**Catastrophic L.D. Type 3.0**	Continuous Interstitial Monitoring	**Piping Type**	Pressurized	**CP Met Types**	
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	S6	**Tank Age**	26	**Tank Installed Date**	04/01/1999	**Tank Material Construction**	Unknown	**Piping Material**	Flexible Plastic	**Overfill Types**	
Tag Number	4002	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	Yes
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	10/11/2024	**Catastrophic L.D. Type 3.0**	Continuous Interstitial Monitoring	**Piping Type**	Pressurized	**CP Met Types**	
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					

Facility Summary in Phillips County in the City of Malta

Location: EQUITY COOP ASSOCIATION MALTA
428 S 1st St E
Malta, MT 59538 Phillips

System Facility ID:36-10706

Facility Code: 26305
Last Inspected On: 07/21/2022
Operating Permit Renewal Date: 10/30/2025

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Equity Coop Association Malta **(406) 654-2240**

Operator Contact: Angela Anderson;Dale Kaasa;Virgil Abrahamson **dareangi@yahoo.com;equityco-op@mtintouch.net**

Owner/Operator: Equity Coop Association Malta (406) 654-2240

Angela Anderson, UST Class A Operator	dareangi@yahoo.com
Angela Anderson, UST Class A Operator	dareangi@yahoo.com
Angela Anderson, UST Class B Operator	dareangi@yahoo.com
Angela Anderson, UST Class B Operator	dareangi@yahoo.com
Dale Kaasa, UST Class A Operator	equityco-op@mtintouch.net
Dale Kaasa, UST Class A Operator	equityco-op@mtintouch.net
Dale Kaasa, UST Class B Operator	equityco-op@mtintouch.net
Dale Kaasa, UST Class B Operator	equityco-op@mtintouch.net
Virgil Abrahamson, UST Class A Operator	equityco-op@mtintouch.net
Virgil Abrahamson, UST Class A Operator	equityco-op@mtintouch.net
Virgil Abrahamson, UST Class B Operator	equityco-op@mtintouch.net
Virgil Abrahamson, UST Class B Operator	equityco-op@mtintouch.net

Tank Number	S7	**Tank Age**	31	**Tank Installed Date**	12/01/1994	**Tank Material Construction**	Unknown	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	
Tag Number	5421	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	Yes
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	07/21/2022	**Catastrophic L.D. Type 3.0**	Continuous Interstitial Monitoring	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel, Dyed	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	3200	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	S3	**Tank Age**	31	**Tank Installed Date**	12/09/1994	**Tank Material Construction**	Unknown	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	

Tag Number	860	**Spill Test Date**		**Piping Installed Date**	07/20/2007	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	Yes
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	07/21/2022	**Catastrophic L.D. Type 3.0**	Continuous Interstitial Monitoring	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	25600	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	S4	**Tank Age**	31	**Tank Installed Date**	12/09/1994	**Tank Material Construction**	Unknown	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	
Tag Number	861	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	Yes
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	07/21/2022	**Catastrophic L.D. Type 3.0**	Continuous Interstitial Monitoring	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel, Dyed	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	17000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	S5	**Tank Age**	31	**Tank Installed Date**	12/09/1994	**Tank Material Construction**	Unknown	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	
Tag Number	862	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	Yes
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	07/21/2022	**Catastrophic L.D. Type 3.0**	Continuous Interstitial Monitoring	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	S6	**Tank Age**	31	**Tank Installed Date**	12/09/1994	**Tank Material Construction**	Unknown	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	
Tag Number	863	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	Yes
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	07/21/2022	**Catastrophic L.D. Type 3.0**	Continuous Interstitial Monitoring	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible

Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	9900	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					

Facility Summary in Phillips County in the City of Malta

Location: EZZIES BULK STORAGE
47259 US Hwy 2 E
Malta, MT 59538 Phillips

System Facility ID:60-15156

Facility Code: 30897
Last Inspected On: 10/26/2022
Operating Permit Renewal Date: 04/20/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Ezzies Wholesale Inc **bill@ezzies.com**

Operator Contact: Clayton Jesson;Conor Moran;Ezzies Wholesale Inc **(406) 654-2331** **clay@ezzies.com;conor@ezzies.com;bill@ezzies.com**

Owner/Operator: Ezzies Wholesale Inc bill@ezzies.com

Clayton Jesson, UST Class A Operator clay@ezzies.com
Conor Moran, UST Class A Operator bill@ezzies.com
Derek Oshio, UST Class B Operator loren@ezzies.com

Tank Number	01	**Tank Age**	15	**Tank Installed Date**	09/27/2010	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve;High Level Alarm
Tag Number	5246	**Spill Test Date**	11/13/2019	**Piping Installed Date**	09/27/2010	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	11/13/2019	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	30000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	01/21/2020			**ATG Type**	Incon/TS-5000				
Tank Number	02	**Tank Age**	15	**Tank Installed Date**	09/27/2010	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve;High Level Alarm
Tag Number	5247	**Spill Test Date**	11/13/2019	**Piping Installed Date**	09/27/2010	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	11/13/2019	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel, Dyed	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	01/21/2020			**ATG Type**	Incon/TS-5000				

Tank Number	03	**Tank Age**	15	**Tank Installed Date**	09/27/2010	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve;High Level Alarm
Tag Number	5248	**Spill Test Date**	11/13/2019	**Piping Installed Date**	09/27/2010	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	11/13/2019	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	01/21/2020			**ATG Type**	Incon/TS-5000				
Tank Number	04	**Tank Age**	15	**Tank Installed Date**	09/27/2010	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve;High Level Alarm
Tag Number	5249	**Spill Test Date**	11/13/2019	**Piping Installed Date**	09/27/2010	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	11/13/2019	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	01/21/2020			**ATG Type**	Incon/TS-5000				
Tank Number	05	**Tank Age**	15	**Tank Installed Date**	09/27/2010	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve;High Level Alarm
Tag Number	5250	**Spill Test Date**	11/13/2019	**Piping Installed Date**	09/27/2010	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	11/13/2019	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	01/21/2020			**ATG Type**	Incon/TS-5000				
Tank Number	06	**Tank Age**	15	**Tank Installed Date**	09/27/2010	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve;High Level Alarm
Tag Number	5251	**Spill Test Date**	11/13/2019	**Piping Installed Date**	09/27/2010	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	11/13/2019	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible

Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	01/21/2020			**ATG Type**	Incon/TS-5000				
Tank Number	07	**Tank Age**	15	**Tank Installed Date**	09/27/2010	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve;High Level Alarm
Tag Number	5252	**Spill Test Date**	01/10/2023	**Piping Installed Date**	09/27/2010	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	10/26/2022	**Sump Tightness Test Date**	11/13/2019	**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Hazardous Substance	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**		**Line Tightness Test Date**	09/21/2021	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	Yes
		Overfill Test Date	01/21/2020			**ATG Type**	Incon/TS-5000				
Tank Number	08	**Tank Age**	15	**Tank Installed Date**	09/27/2010	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve;High Level Alarm
Tag Number	5253	**Spill Test Date**	11/13/2019	**Piping Installed Date**	09/27/2010	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	11/13/2019	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel, Dyed	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	20000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	01/21/2020			**ATG Type**	Incon/TS-5000				
Tank Number	09	**Tank Age**	15	**Tank Installed Date**	09/27/2010	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve;High Level Alarm
Tag Number	5254	**Spill Test Date**	11/13/2019	**Piping Installed Date**	09/27/2010	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	11/13/2019	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel, Dyed	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	30000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	01/21/2020			**ATG Type**	Incon/TS-5000				

Facility Summary in Phillips County in the City of Malta

Location: EZZIES WHOLESALE US 2 E
US Hwy 2 E
Malta, MT 59538 Phillips

System Facility ID:36-11372

Facility Code: 26310
Last Inspected On: 05/05/2025
Operating Permit Renewal Date: 09/15/2025

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Ezzies Wholesale Inc **bill@ezzies.com**

Operator Contact: Conor Moran;Ezzies Wholesale Inc **conor@ezzies.com;bill@ezzies.com**

Owner/Operator: Ezzies Wholesale Inc bill@ezzies.com

Clayton Jesson, UST Class B Operator bill@ezzies.com

Conor Moran, UST Class A Operator bill@ezzies.com

Tank Number	01	**Tank Age**	35	**Tank Installed Date**	01/01/1990	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	886	**Spill Test Date**	09/10/2020	**Piping Installed Date**	07/23/2007	**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Diesel, Dyed	**PLLD Test Date**	07/12/2021	**Tank/Piping CP Test Date**	03/28/2022	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**	07/12/2021	**Line Tightness Test Date**	03/18/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	05/09/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	02	**Tank Age**	35	**Tank Installed Date**	01/01/1990	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	887	**Spill Test Date**	09/10/2020	**Piping Installed Date**	07/23/2007	**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Diesel	**PLLD Test Date**	07/12/2021	**Tank/Piping CP Test Date**	03/28/2022	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**	07/12/2021	**Line Tightness Test Date**	03/18/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	06/06/2019			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	03	**Tank Age**	35	**Tank Installed Date**	01/01/1990	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm

Tag Number	888	**Spill Test Date**	09/10/2020	**Piping Installed Date**	07/23/2007	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	03/28/2022	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Diesel	**PLLD Test Date**	07/12/2021	**Tank/Piping CP Test Date**	03/28/2022	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**	07/12/2021	**Line Tightness Test Date**	03/18/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	06/06/2019			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	04	**Tank Age**	35	**Tank Installed Date**	01/01/1990	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	889	**Spill Test Date**	09/10/2020	**Piping Installed Date**	07/23/2007	**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Diesel, Dyed	**PLLD Test Date**	07/12/2021	**Tank/Piping CP Test Date**	03/28/2022	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**	07/12/2021	**Line Tightness Test Date**	03/18/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	06/06/2019			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	05	**Tank Age**	35	**Tank Installed Date**	01/01/1990	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	890	**Spill Test Date**	09/10/2020	**Piping Installed Date**	07/23/2007	**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Gasoline	**PLLD Test Date**	07/12/2021	**Tank/Piping CP Test Date**	03/28/2022	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**	07/12/2021	**Line Tightness Test Date**	03/18/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	06/06/2019			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	06	**Tank Age**	35	**Tank Installed Date**	01/01/1990	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	891	**Spill Test Date**	09/10/2020	**Piping Installed Date**	07/23/2007	**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Gasoline	**PLLD Test Date**	07/12/2021	**Tank/Piping CP Test Date**	03/28/2022	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No

Capacity	6000	**ATG Test Date**	07/12/2021	**Line Tightness Test Date**	03/18/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	06/06/2019			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Phillips County in the City of Malta

Location: MALTA CONVENIENCE STORE
3 N 1st St E
Malta, MT 59538 Phillips

System Facility ID:36-02371

Facility Code: 26213
Last Inspected On: 05/05/2025
Operating Permit Renewal Date: 10/31/2025

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Horizon Resources **kquinnel@horizonresources.coop**

Operator Contact: Novalene Nelson **NNelson@horizonresources.coop**

Owner/Operator: Horizon Resources kquinnel@horizonresources.coop

Novalene Nelson, UST Class A Operator NNelson@horizonresources.coop

Novalene Nelson, UST Class B Global Operator NNelson@horizonresources.coop

Tank Number	02	**Tank Age**	39	**Tank Installed Date**	10/29/1986	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	3287	**Spill Test Date**	07/29/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Diesel, Dyed	**PLLD Test Date**	05/12/2022	**Tank/Piping CP Test Date**	05/13/2022	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**	07/29/2022	**Line Tightness Test Date**	05/13/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	07/29/2022			**ATG Type**	Veeder Root/TLS-300				
Tank Number	03	**Tank Age**	39	**Tank Installed Date**	10/29/1986	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	3288	**Spill Test Date**	07/29/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**	05/12/2022	**Tank/Piping CP Test Date**	05/13/2022	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**	07/29/2022	**Line Tightness Test Date**	05/13/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	07/29/2022			**ATG Type**	Veeder Root/TLS-300				
Tank Number	04	**Tank Age**	27	**Tank Installed Date**	10/01/1998	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm

Tag Number	3289	**Spill Test Date**	09/24/2024	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	05/12/2022	**Tank/Piping CP Test Date**	09/22/2010	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	07/29/2022	**Line Tightness Test Date**	05/13/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	09/24/2024			**ATG Type**	Veeder Root/TLS-300				
Tank Number	05	**Tank Age**	27	**Tank Installed Date**	10/01/1998	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	3290	**Spill Test Date**	09/24/2024	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	05/12/2022	**Tank/Piping CP Test Date**	09/22/2010	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	5000	**ATG Test Date**	07/29/2022	**Line Tightness Test Date**	05/13/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	09/24/2024			**ATG Type**	Veeder Root/TLS-300				

Facility Summary in Phillips County in the City of Malta

Location: PHILLIPS COUNTY MEDICAL CENTER
311 S 8th Ave E
Malta, MT 59538 Phillips

System Facility ID:56-14104

Facility Code: 30747
Last Inspected On: 07/12/2022
Operating Permit Renewal Date: 10/05/2025

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Phillips County Medical Center	**(406) 654-1100**	**bwinkel@hlrc.us**
Operator Contact:	Beu Winkel;Richard Ferrell;Thomas Miller	**(406) 390-4452;(406) 683-2175**	**bwinkel@hlrc.us;PCHM@pchospital.us**

Owner/Operator: Phillips County Medical Center (406) 654-1100 bwinkel@hlrc.us

Beu Winkel, UST Class A Operator	bwinkel@hlrc.us
Beu Winkel, UST Class B Operator	bwinkel@hlrc.us
Richard Ferrell, UST Class A Operator	PCHM@pchospital.us
Richard Ferrell, UST Class B Operator	PCHM@pchospital.us
Thomas Miller, UST Class A Operator	PCHM@pchospital.us
Thomas Miller, UST Class B Operator	PCHM@pchospital.us

Tank Number	01	**Tank Age**	21	**Tank Installed Date**	03/02/2004	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	4884	**Spill Test Date**	07/12/2022	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Temporarily Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**	06/12/2013	**Catastrophic L.D. Type 3.0**	Continuous Interstitial Monitoring	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	3-Year Line Tightness Test	**Vapor Recovery**	No
Capacity	1000	**ATG Test Date**	07/12/2022	**Line Tightness Test Date**	06/06/2019	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/TLS-300				
Tank Number	02	**Tank Age**	21	**Tank Installed Date**	03/02/2004	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	4885	**Spill Test Date**	07/12/2022	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	06/12/2013	**Catastrophic L.D. Type 3.0**	Continuous Interstitial Monitoring	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible

Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	3-Year Line Tightness Test	**Vapor Recovery**	No
Capacity	1000	**ATG Test Date**	07/12/2022	**Line Tightness Test Date**	07/12/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	07/12/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-300				

Facility Summary in Phillips County in the City of Malta

Location: WESTSIDE SELF SERVICE INC
200 US Hwy 2
Malta, MT 59538 Phillips

System Facility ID:36-06668

Facility Code: 26274
Last Inspected On: 04/15/2025
Operating Permit Renewal Date: 07/09/2028

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Robert Ereaux **(406) 654-7070**

Operator Contact: Darla Niebur;Westside Self Service Inc;Ron Welch;Westside Self Service Inc **(800) 892-6874** **dartomrj@mtintouch.net;wssklc@mtintouch.net;katherynwssklc@gmail.com;wssklc@mtintouch.net**

Owner/Operator: Robert Ereaux (406) 654-7070

Owner/Operator: Robert N Ereaux (406) 654-7070

Darla Niebur, UST Class A Operator	wssklc@mtintouch.net
Darla Niebur, UST Class B Operator	wssklc@mtintouch.net
Ron Welch, UST Class A Operator	wssklc@mtintouch.net
Ron Welch, UST Class B Operator	wssklc@mtintouch.net

Tank Number	06	**Tank Age**	19	**Tank Installed Date**	04/25/2006	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	5069	**Spill Test Date**	10/04/2021	**Piping Installed Date**	04/25/2006	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	03/30/2022	**Tank/Piping CP Test Date**	10/11/2006	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	15000	**ATG Test Date**	05/19/2023	**Line Tightness Test Date**	12/17/2021	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	05/19/2023			**ATG Type**	Franklin Fueling Systems/EVO 600				
Tank Number	07	**Tank Age**	19	**Tank Installed Date**	04/25/2006	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	5070	**Spill Test Date**	10/04/2021	**Piping Installed Date**	04/25/2006	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	01/27/2023	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	03/30/2022	**Tank/Piping CP Test Date**	10/12/2006	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	15000	**ATG Test Date**	05/19/2023	**Line Tightness Test Date**	01/27/2023	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No

		Overfill Test Date	05/19/2023			**ATG Type**	Franklin Fueling Systems/EVO 600				
Tank Number	08	**Tank Age**	19	**Tank Installed Date**	04/25/2006	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	5071	**Spill Test Date**	10/04/2021	**Piping Installed Date**	04/25/2006	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	03/30/2022	**Tank/Piping CP Test Date**	10/13/2006	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	15000	**ATG Test Date**	05/19/2023	**Line Tightness Test Date**	12/17/2021	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	05/19/2023			**ATG Type**	Franklin Fueling Systems/EVO 600				
Tank Number	09	**Tank Age**	19	**Tank Installed Date**	04/25/2006	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	5075	**Spill Test Date**	11/26/2021	**Piping Installed Date**	04/25/2006	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	01/27/2023	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	03/30/2022	**Tank/Piping CP Test Date**	10/14/2006	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	5000	**ATG Test Date**	05/19/2023	**Line Tightness Test Date**	01/27/2023	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	05/19/2023			**ATG Type**	Franklin Fueling Systems/EVO 600				
Tank Number	10	**Tank Age**	19	**Tank Installed Date**	04/25/2006	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	5076	**Spill Test Date**	10/04/2021	**Piping Installed Date**	04/25/2006	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	03/30/2022	**Tank/Piping CP Test Date**	10/20/2006	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	5000	**ATG Test Date**	05/19/2023	**Line Tightness Test Date**	12/17/2021	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	05/19/2023			**ATG Type**	Franklin Fueling Systems/EVO 600				
Tank Number	11	**Tank Age**	19	**Tank Installed Date**	04/25/2006	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	5077	**Spill Test Date**	11/26/2021	**Piping Installed Date**	04/25/2006	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No

Status	**Currently in Use**	**MLLD Test Date**	01/27/2023	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	03/30/2022	**Tank/Piping CP Test Date**	11/27/2006	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	5000	**ATG Test Date**	05/19/2023	**Line Tightness Test Date**	01/27/2023	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	05/19/2023			**ATG Type**	Franklin Fueling Systems/EVO 600				

Facility Summary in Phillips County in the City of Saco

Location: EZZIES WHOLESALE
100 Hwy 243
Saco, MT 59261 Phillips

System Facility ID:60-15270

Facility Code: 30982
Last Inspected On: 03/17/2025
Operating Permit Renewal Date: 07/05/2028

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Ezzies Wholesale Inc **bill@ezzies.com**

Operator Contact: Conor Moran;Ezzies Wholesale Inc **conor@ezzies.com;bill@ezzies.com**

Owner/Operator: Ezzies Wholesale Inc bill@ezzies.com

Clayton Jesson, UST Class B Operator clay@ezzies.com

Conor Moran, UST Class A Operator bill@ezzies.com

Tank Number	S1	**Tank Age**	9	**Tank Installed Date**	01/20/2016	**Tank Material Construction**	Aboveground Tank	**Piping Material**	Flexible Plastic	**Overfill Types**	
Tag Number	5626	**Spill Test Date**		**Piping Installed Date**	01/20/2016	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	Yes
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	03/17/2025	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	07/09/2024	**Line Tightness Test Date**	03/27/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date				**ATG Type**					
Tank Number	S2	**Tank Age**	9	**Tank Installed Date**	01/20/2016	**Tank Material Construction**	Aboveground Tank	**Piping Material**	Flexible Plastic	**Overfill Types**	
Tag Number	5627	**Spill Test Date**		**Piping Installed Date**	01/20/2016	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	Yes
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	03/17/2025	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	2000	**ATG Test Date**	07/09/2024	**Line Tightness Test Date**	03/27/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date				**ATG Type**					
Tank Number	S3	**Tank Age**	9	**Tank Installed Date**	01/20/2016	**Tank Material Construction**	Aboveground Tank	**Piping Material**	Flexible Plastic	**Overfill Types**	

Tag Number	5628	**Spill Test Date**		**Piping Installed Date**	01/20/2016	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	Yes
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	03/17/2025	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	2000	**ATG Test Date**	07/09/2024	**Line Tightness Test Date**	03/27/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date				**ATG Type**					

Facility Summary in Phillips County in the City of Whitewater

Location: EZZIES WHOLESALE INC
Main St
Whitewater, MT 59544 Phillips

System Facility ID:36-04082

Facility Code: 26227
Last Inspected On: 10/09/2023
Operating Permit Renewal Date: 10/09/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Ezzies Wholesale, Inc. **(406) 654-2331** **dave@ezzies.com**

Operator Contact: Conor Moran;Ezzies Wholesale Inc **conor@ezzies.com;bill@ezzies.com**

Owner/Operator: Ezzies Wholesale, Inc. (406) 654-2331 dave@ezzies.com

Clayton Jesson, UST Class B Operator bill@ezzies.com

Conor Moran, UST Class A Operator bill@ezzies.com

Tank Number	S5	**Tank Age**	27	**Tank Installed Date**	10/13/1998	**Tank Material Construction**	Unknown	**Piping Material**	Flexible Plastic	**Overfill Types**	
Tag Number	3599	**Spill Test Date**		**Piping Installed Date**	09/10/2007	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	Yes
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	04/03/2024	**Catastrophic L.D. Type 3.0**	Auto Dialer	**Piping Type**	Pressurized	**CP Met Types**	
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	10/09/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	S6	**Tank Age**	27	**Tank Installed Date**	10/13/1998	**Tank Material Construction**	Unknown	**Piping Material**	Flexible Plastic	**Overfill Types**	
Tag Number	3600	**Spill Test Date**		**Piping Installed Date**	09/10/2007	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	Yes
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	04/03/2024	**Catastrophic L.D. Type 3.0**	Auto Dialer	**Piping Type**	Pressurized	**CP Met Types**	
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	15000	**ATG Test Date**	10/09/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	S7	**Tank Age**	27	**Tank Installed Date**	10/13/1998	**Tank Material Construction**	Unknown	**Piping Material**	Flexible Plastic	**Overfill Types**	

Tag Number	3601	**Spill Test Date**		**Piping Installed Date**	09/10/2007	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	Yes
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	04/03/2024	**Catastrophic L.D. Type 3.0**	Auto Dialer	**Piping Type**	Pressurized	**CP Met Types**	
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	9000	**ATG Test Date**	10/09/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	S8	**Tank Age**	27	**Tank Installed Date**	10/13/1998	**Tank Material Construction**	Unknown	**Piping Material**	Flexible Plastic	**Overfill Types**	
Tag Number	3602	**Spill Test Date**		**Piping Installed Date**	09/10/2007	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	Yes
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	04/03/2024	**Catastrophic L.D. Type 3.0**	Auto Dialer	**Piping Type**	Pressurized	**CP Met Types**	
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	9000	**ATG Test Date**	10/09/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					

Facility Summary in Phillips County in the City of Zortman

Location: ZORTMAN GARAGE AND MOTEL
302 Main St
Zortman, MT 59546-0302 Phillips

System Facility ID:36-11549

Facility Code: 26314
Last Inspected On: 10/26/2022
Operating Permit Renewal Date: 11/27/2025

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: John Kalal;Zortman Garage and Motel **(406) 673-3160**

Operator Contact: Candy Kalal;Deirdre Hanners **zortman76@mtintouch.net**

Owner/Operator: John Kalal (406) 673-3160

Owner/Operator: Zortman Garage and Motel (406) 673-3160

Candy Kalal, UST Class A Operator zortman76@mtintouch.net
Candy Kalal, UST Class B Operator zortman76@mtintouch.net
Deirdre Hanners, UST Class A Operator

Tank Number	03	**Tank Age**	26	**Tank Installed Date**	06/17/1999	**Tank Material Construction**	Steel Clad	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	4020	**Spill Test Date**	10/03/2022	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	08/18/2010	**Primary Tank Leak Detection**	Manual Interstitial Monitoring	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	1000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	10/26/2022			**ATG Type**					
Tank Number	04	**Tank Age**	26	**Tank Installed Date**	06/17/1999	**Tank Material Construction**	Steel Clad	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	4021	**Spill Test Date**	10/03/2022	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	08/18/2010	**Primary Tank Leak Detection**	Manual Interstitial Monitoring	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	1000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	10/26/2022			**ATG Type**					

Facility Summary in Pondera County in the City of Brady

Location: MOUNTAIN VIEW COOP BRADY
102 Railroad St N
Brady, MT 59416 Pondera

System Facility ID:37-04241

Facility Code: 26390
Last Inspected On: 05/27/2025
Operating Permit Renewal Date: 08/04/2025

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Mountain View Coop Black Eagle **(406) 453-5900** **ddouglas@mountainviewcoop.com**

Operator Contact: David Douglas **ddouglas@mountainviewcoop.com**

Owner/Operator: Mountain View Coop Black Eagle (406) 453-5900 ddouglas@mountainviewcoop.com

David Douglas, UST Class A Operator ddouglas@mountainviewcoop.com
David Douglas, UST Class B Global Operator ddouglas@mountainviewcoop.com
Jeremy Kulpas, UST Class B Global Operator jkulpas@mountainviewcoop.com

Tank Number	S11	**Tank Age**	28	**Tank Installed Date**	11/01/1997	**Tank Material Construction**	Unknown	**Piping Material**	Flexible Plastic	**Overfill Types**	
Tag Number	2142	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	Yes
Status	**Currently in Use**	**MLLD Test Date**	06/03/2022	**Sump Tightness Test Date**	07/09/2019	**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	17000	**ATG Test Date**	06/21/2022	**Line Tightness Test Date**	03/02/2020	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	S12	**Tank Age**	28	**Tank Installed Date**	11/01/1997	**Tank Material Construction**	Unknown	**Piping Material**	Flexible Plastic	**Overfill Types**	
Tag Number	2143	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	Yes
Status	**Currently in Use**	**MLLD Test Date**	06/03/2022	**Sump Tightness Test Date**	07/09/2019	**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	17000	**ATG Test Date**	06/21/2022	**Line Tightness Test Date**	03/02/2020	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					

Tank Number	S13	**Tank Age**	28	**Tank Installed Date**	11/01/1997	**Tank Material Construction**	Unknown	**Piping Material**	Flexible Plastic	**Overfill Types**	
Tag Number	2144	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	Yes
Status	**Currently in Use**	**MLLD Test Date**	06/03/2022	**Sump Tightness Test Date**	07/09/2019	**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Diesel, Dyed	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	06/21/2022	**Line Tightness Test Date**	03/02/2020	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	S14	**Tank Age**	28	**Tank Installed Date**	11/01/1997	**Tank Material Construction**	Unknown	**Piping Material**	Flexible Plastic	**Overfill Types**	
Tag Number	2145	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	Yes
Status	**Currently in Use**	**MLLD Test Date**	06/03/2022	**Sump Tightness Test Date**	07/09/2019	**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	5000	**ATG Test Date**	06/21/2022	**Line Tightness Test Date**	03/02/2020	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					

Facility Summary in Pondera County in the City of Conrad

Location: MOUNTAIN VIEW COOP CONRAD
19 S Main St
Conrad, MT 59425-1828 Pondera

System Facility ID:37-01649

Facility Code: 26344
Last Inspected On: 12/21/2023
Operating Permit Renewal Date: 03/08/2023

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Mountain View Coop Black Eagle	**(406) 453-5900**	**ddouglas@mountainviewcoop.com**
Operator Contact:	Dave Douglas;Jeremy Kulpas	**(406) 278-5524;(406) 750-6748**	**ddouglas@mountainviewcoop.com;jkulpas@mountainviewcoop.com**

Owner/Operator: Mountain View Coop Black Eagle (406) 453-5900 ddouglas@mountainviewcoop.com

Dave Douglas, UST Class A Operator	ddouglas@mountainviewcoop.com
Jeremy Kulpas, UST Class A Operator	jkulpas@mountainviewcoop.com
Jeremy Kulpas, UST Class B Global Operator	jkulpas@mountainviewcoop.com
Jeremy Kulpas, UST Class B Operator	jkulpas@mountainviewcoop.com

Tank Number	13	**Tank Age**	5	**Tank Installed Date**	07/06/2020	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	5978	**Spill Test Date**	07/09/2020	**Piping Installed Date**	07/06/2020	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	11/29/2023	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	12/11/2023	**Line Tightness Test Date**	07/08/2020	**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	07/09/2020			**ATG Type**					
Tank Number	14	**Tank Age**	5	**Tank Installed Date**	07/06/2020	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	5979	**Spill Test Date**	12/11/2023	**Piping Installed Date**	07/06/2020	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	11/29/2023	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	11/29/2023	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	12/11/2023	**Line Tightness Test Date**	07/08/2020	**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	07/09/2020			**ATG Type**					

Tank Number	15	**Tank Age**	5	**Tank Installed Date**	07/06/2020	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	5980	**Spill Test Date**	12/11/2023	**Piping Installed Date**	07/06/2020	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	11/29/2023	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	11/29/2023	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	11000	**ATG Test Date**	12/11/2023	**Line Tightness Test Date**	07/08/2020	**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	07/09/2020			**ATG Type**					
Tank Number	16	**Tank Age**	5	**Tank Installed Date**	07/06/2020	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	5981	**Spill Test Date**	12/11/2023	**Piping Installed Date**	07/06/2020	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	11/29/2023	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	11/29/2023	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	9000	**ATG Test Date**	12/11/2023	**Line Tightness Test Date**	07/08/2020	**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	07/09/2020			**ATG Type**					
Tank Number	17	**Tank Age**	5	**Tank Installed Date**	07/06/2020	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	5982	**Spill Test Date**	12/11/2023	**Piping Installed Date**	07/06/2020	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	11/29/2023	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	11/29/2023	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	12/11/2023	**Line Tightness Test Date**	07/08/2020	**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	07/09/2020			**ATG Type**					
Tank Number	18	**Tank Age**	5	**Tank Installed Date**	07/06/2020	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	5983	**Spill Test Date**	12/11/2023	**Piping Installed Date**	07/06/2020	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	11/29/2023	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible

Product	Diesel	**PLLD Test Date**	11/29/2023	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	7000	**ATG Test Date**	12/11/2023	**Line Tightness Test Date**	07/08/2020	**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	07/09/2020			**ATG Type**					
Tank Number	19	**Tank Age**	5	**Tank Installed Date**	07/06/2020	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	5984	**Spill Test Date**	12/11/2023	**Piping Installed Date**	07/06/2020	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	11/29/2023	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	11/29/2023	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**	12/11/2023	**Line Tightness Test Date**	07/08/2020	**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	07/09/2020			**ATG Type**					
Tank Number	06	**Tank Age**	28	**Tank Installed Date**	01/08/1997	**Tank Material Construction**	Steel Clad	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	916	**Spill Test Date**		**Piping Installed Date**	07/09/2013	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**	08/15/2013	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	08/02/2013	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	ELLD 0.1;ELLD 0.2;ELLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	18000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	07	**Tank Age**	28	**Tank Installed Date**	01/08/1997	**Tank Material Construction**	Steel Clad	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	917	**Spill Test Date**		**Piping Installed Date**	07/09/2013	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**	08/15/2013	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	08/02/2013	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	ELLD 0.1;ELLD 0.2;ELLD Line Tightness Testing	**Vapor Recovery**	No

Capacity	12000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	08	**Tank Age**	28	**Tank Installed Date**	01/08/1997	**Tank Material Construction**	Steel Clad	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	918	**Spill Test Date**		**Piping Installed Date**	07/09/2013	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**	08/15/2013	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	08/02/2013	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	ELLD 0.1;ELLD 0.2;ELLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	18000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	09	**Tank Age**	28	**Tank Installed Date**	01/08/1997	**Tank Material Construction**	Steel Clad	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	919	**Spill Test Date**		**Piping Installed Date**	07/09/2013	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**	08/15/2013	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	08/02/2013	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	ELLD 0.1;ELLD 0.2;ELLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	10	**Tank Age**	28	**Tank Installed Date**	01/08/1997	**Tank Material Construction**	Steel Clad	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	920	**Spill Test Date**		**Piping Installed Date**	07/09/2013	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**	08/15/2013	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible

Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	08/02/2013	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	ELLD 0.1;ELLD 0.2;ELLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	14000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	11	**Tank Age**	28	**Tank Installed Date**	01/08/1997	**Tank Material Construction**	Steel Clad	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	921	**Spill Test Date**		**Piping Installed Date**	07/09/2013	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**	08/15/2013	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	08/02/2013	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	ELLD 0.1;ELLD 0.2;ELLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	14000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	12	**Tank Age**	28	**Tank Installed Date**	01/08/1997	**Tank Material Construction**	Steel Clad	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	922	**Spill Test Date**		**Piping Installed Date**	07/09/2013	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**	08/15/2013	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	08/02/2013	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	ELLD 0.1;ELLD 0.2;ELLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Pondera County in the City of Conrad

Location: TOWN PUMP INC CONRAD
215 N Main St
Conrad, MT 59425-1628 Pondera

System Facility ID:37-08692

Facility Code: 26453
Last Inspected On: 03/21/2024
Operating Permit Renewal Date: 08/06/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Conrad 1 Town Pump LLC	**(406) 497-6700**	**environmental@townpump.com**
Operator Contact:	Trent Biggers		**Trentb@townpump.com**

Owner/Operator:	Conrad 1 Town Pump LLC	(406) 497-6700	environmental@townpump.com
	Trent Biggers, UST Class A Operator		Trentb@townpump.com
	Trent Biggers, UST Class A Operator		Trentb@townpump.com
	Trent Biggers, UST Class B Global Operator		Trentb@townpump.com
	Trent Biggers, UST Class B Global Operator		Trentb@townpump.com

Tank Number	01	**Tank Age**	42	**Tank Installed Date**	08/30/1983	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve
Tag Number	2584	**Spill Test Date**	09/22/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**	03/21/2024	**Tank/Piping CP Test Date**	09/22/2023	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	03/21/2024	**Line Tightness Test Date**	07/28/2006	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	09/22/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350				
Tank Number	02	**Tank Age**	42	**Tank Installed Date**	08/30/1983	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve;Flapper Valve
Tag Number	2585	**Spill Test Date**	09/22/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**	03/21/2024	**Tank/Piping CP Test Date**	09/22/2023	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	03/21/2024	**Line Tightness Test Date**	07/29/2006	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	09/22/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350				

Tank Number	03	**Tank Age**	42	**Tank Installed Date**	08/30/1983	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	2586	**Spill Test Date**	09/22/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Diesel	**PLLD Test Date**	03/21/2024	**Tank/Piping CP Test Date**	09/22/2023	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	03/21/2024	**Line Tightness Test Date**	07/30/2006	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	09/22/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350				
Tank Number	04	**Tank Age**	39	**Tank Installed Date**	08/30/1986	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve;Flapper Valve
Tag Number	2587	**Spill Test Date**	09/22/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Diesel	**PLLD Test Date**	03/21/2024	**Tank/Piping CP Test Date**	09/22/2023	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	03/21/2024	**Line Tightness Test Date**	08/01/2006	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	09/22/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350				
Tank Number	05	**Tank Age**	37	**Tank Installed Date**	07/01/1988	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	2588	**Spill Test Date**	09/22/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	03/21/2024	**Tank/Piping CP Test Date**	12/03/2009	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	03/21/2024	**Line Tightness Test Date**	10/26/2006	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	09/22/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350				
Tank Number	08	**Tank Age**	26	**Tank Installed Date**	09/01/1999	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve
Tag Number	4151	**Spill Test Date**	09/22/2023	**Piping Installed Date**	04/16/2014	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	09/22/2023	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible

Product	Diesel	**PLLD Test Date**	03/21/2024	**Tank/Piping CP Test Date**	12/03/2009	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	03/21/2024	**Line Tightness Test Date**	10/30/2006	**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	No
		Overfill Test Date	09/22/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350				
Tank Number	09	**Tank Age**	26	**Tank Installed Date**	09/01/1999	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve;Flapper Valve
Tag Number	4152	**Spill Test Date**	09/22/2023	**Piping Installed Date**	04/16/2014	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	09/22/2023	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	03/21/2024	**Tank/Piping CP Test Date**	12/03/2009	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	5000	**ATG Test Date**	03/21/2024	**Line Tightness Test Date**	10/30/2006	**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	No
		Overfill Test Date	09/22/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350				
Tank Number	10	**Tank Age**	11	**Tank Installed Date**	07/01/2014	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	5495	**Spill Test Date**	09/22/2023	**Piping Installed Date**	04/16/2014	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	09/22/2023	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	03/21/2024	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	03/21/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Statistical Inventory Reconciliation	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	Yes
		Overfill Test Date	09/22/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350				
Tank Number	11	**Tank Age**	11	**Tank Installed Date**	07/01/2014	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	5496	**Spill Test Date**	09/22/2023	**Piping Installed Date**	04/16/2014	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	09/22/2023	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	03/21/2024	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	20000	**ATG Test Date**	08/21/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Statistical Inventory Reconciliation	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	Yes

		Overfill Test Date	09/22/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350				
Tank Number	12	**Tank Age**	11	**Tank Installed Date**	07/01/2014	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	5497	**Spill Test Date**	09/22/2023	**Piping Installed Date**	04/16/2014	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	09/22/2023	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	03/21/2024	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	03/21/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Statistical Inventory Reconciliation	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	Yes
		Overfill Test Date	09/22/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Pondera County in the City of Heart Butte

Location: HEART BUTTE SCHOOL DIST 1
School Bus Barn Rd
Heart Butte, MT 59448 Pondera

System Facility ID:37-09353

Facility Code: 26492
Last Inspected On: 07/11/2022
Operating Permit Renewal Date: 12/28/2025

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: School Dist 1 Heart Butte **(406) 338-2200**

Operator Contact: Dewey Skunk Cap

Owner/Operator: School Dist 1 Heart Butte (406) 338-2200

Dewey Skunk Cap, UST Class A Operator
Nathan Ironheart, UST Class B Operator nateironheart@gmail.com

Tank Number	03	**Tank Age**	39	**Tank Installed Date**	05/06/1986	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	1901	**Spill Test Date**	03/04/2021	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	2000	**ATG Test Date**	03/22/2022	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	03/04/2021			**ATG Type**	Gilbarco/EMC Basic				
Tank Number	04	**Tank Age**	39	**Tank Installed Date**	05/06/1986	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	1902	**Spill Test Date**	03/04/2021	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	2000	**ATG Test Date**	03/22/2022	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	03/04/2021			**ATG Type**	Gilbarco/EMC Basic				

Facility Summary in Pondera County in the City of Valier

Location: ONE STOP CENEX
518 Teton
Valier, MT 59486-0000 Pondera

System Facility ID:37-03112

Facility Code: 26371
Last Inspected On: 07/07/2023
Operating Permit Renewal Date: 12/17/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	One Stop LLC;Pardeep Kumar	**(406) 279-3600;(408) 449-9333**	**pardeep.k51@yahoo.com**
Operator Contact:	Pardeep Kumar;Paul Johnson;Scott Curry	**(406) 505-0386;(408) 449-9333**	**dstockton1223@gmail.com;onestop@3rivers.net;pardeep.k51@yahoo.com**

Owner/Operator: One Stop LLC (406) 279-3600

Owner/Operator: Pardeep Kumar (406) 279-3600

Pardeep Kumar, UST Class A Operator	pardeep.k51@yahoo.com
Paul Johnson, UST Class A Operator	dstockton1223@gmail.com
Paul Johnson, UST Class B Global Operator	dstockton1223@gmail.com
Scott Curry, UST Class A Operator	onestop@3rivers.net
Scott Curry, UST Class B Global Operator	onestop@3rivers.net
Scott Curry, UST Class B Operator	onestop@3rivers.net

Tank Number	03	**Tank Age**	35	**Tank Installed Date**	03/21/1990	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	1878	**Spill Test Date**	06/12/2024	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	07/07/2023	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	07/07/2023	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	1000	**ATG Test Date**		**Line Tightness Test Date**	07/07/2023	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	06/12/2024			**ATG Type**					
Tank Number	04	**Tank Age**	35	**Tank Installed Date**	03/21/1990	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	1879	**Spill Test Date**	06/12/2024	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	07/07/2023	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	07/07/2023	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No

Capacity	1000	**ATG Test Date**		**Line Tightness Test Date**	07/07/2023	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	06/12/2024			**ATG Type**					
Tank Number	05	**Tank Age**	35	**Tank Installed Date**	03/21/1990	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	4445	**Spill Test Date**	06/12/2024	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	07/07/2023	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	07/07/2023	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	2000	**ATG Test Date**		**Line Tightness Test Date**	07/07/2023	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	06/12/2024			**ATG Type**					

Facility Summary in Pondera County in the City of Valier

Location: VALIER CARDLOCK
810 Teton
Valier, MT 59486 Pondera

System Facility ID:56-14043

Facility Code: 30698
Last Inspected On: 12/11/2023
Operating Permit Renewal Date: 03/25/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Ben Taylor Inc **bti@3rivers.net**

Operator Contact: Scott Curry **onestop@3rivers.net**

Owner/Operator: Ben Taylor Inc bti@3rivers.net

Rita Swanson, UST Class B Operator
Scott Curry, UST Class A Operator onestop@3rivers.net
Scott Curry, UST Class B Global Operator onestop@3rivers.net
Scott Curry, UST Class B Operator onestop@3rivers.net

Tank Number	S1	**Tank Age**	23	**Tank Installed Date**	08/19/2002	**Tank Material Construction**	Concrete	**Piping Material**	Flexible Plastic	**Overfill Types**	
Tag Number	4710	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	Yes
Status	**Currently in Use**	**MLLD Test Date**	11/13/2023	**Sump Tightness Test Date**	04/25/2018	**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**		**Line Tightness Test Date**	11/13/2023	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	S2	**Tank Age**	23	**Tank Installed Date**	08/19/2002	**Tank Material Construction**	Concrete	**Piping Material**	Flexible Plastic	**Overfill Types**	
Tag Number	4711	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	Yes
Status	**Currently in Use**	**MLLD Test Date**	11/13/2023	**Sump Tightness Test Date**	04/25/2018	**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**		**Line Tightness Test Date**	11/13/2023	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date				**ATG Type**					

Tank Number	S3	**Tank Age**	23	**Tank Installed Date**	08/19/2002	**Tank Material Construction**	Concrete	**Piping Material**	Flexible Plastic	**Overfill Types**	
Tag Number	4712	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	Yes
Status	**Currently in Use**	**MLLD Test Date**	11/13/2023	**Sump Tightness Test Date**	04/25/2018	**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Deferred	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	17000	**ATG Test Date**		**Line Tightness Test Date**	11/13/2023	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	S4	**Tank Age**	23	**Tank Installed Date**	08/19/2002	**Tank Material Construction**	Concrete	**Piping Material**	Flexible Plastic	**Overfill Types**	
Tag Number	4713	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	Yes
Status	**Currently in Use**	**MLLD Test Date**	11/13/2023	**Sump Tightness Test Date**	04/25/2018	**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	17000	**ATG Test Date**		**Line Tightness Test Date**	11/13/2023	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date				**ATG Type**					

Facility Summary in Powder River County in the City of Biddle

Location: CROSS RANCH MERC
222 MT Hwy 59
Biddle, MT 59314 Powder River

System Facility ID:38-01493

Facility Code: 26537
Last Inspected On: 03/07/2023
Operating Permit Renewal Date: 08/10/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Nathan Rumph

Operator Contact: Connie Rumph **(406) 427-5447** **crossranchmerc@gmail.com**

Owner/Operator: Nathan Rumph

Connie Rumph, UST Class A Operator crossranchmerc@gmail.com
Connie Rumph, UST Class B Operator crossranchmerc@gmail.com

Tank Number	07	**Tank Age**	35	**Tank Installed Date**	09/11/1990	**Tank Material Construction**	Steel Clad	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	783	**Spill Test Date**	03/07/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	03/07/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	2000	**ATG Test Date**	03/07/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	03/07/2023			**ATG Type**	EBW/Auto Stik II				
Tank Number	08	**Tank Age**	35	**Tank Installed Date**	09/11/1990	**Tank Material Construction**	Steel Clad	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	784	**Spill Test Date**	03/07/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	03/07/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	2000	**ATG Test Date**	03/07/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	03/07/2023			**ATG Type**	EBW/Auto Stik II				

Facility Summary in Powder River County in the City of Broadus

Location: ALDERMAN OIL CO
601 S Park Ave
Broadus, MT 59317 Powder River

System Facility ID:38-03951

Facility Code: 26549
Last Inspected On: 03/07/2023
Operating Permit Renewal Date: 04/08/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Alderman Oil Co;Gary Alderman

Operator Contact: Gary Alderman;Theresa Alderman **(406) 436-2898** **galderman@rangeweb.net**

Owner/Operator: Alderman Oil Co

Owner/Operator: Gary Alderman

Gary Alderman, UST Class A Operator	galderman@rangeweb.net
Gary Alderman, UST Class A Operator	galderman@rangeweb.net
Gary Alderman, UST Class B Operator	galderman@rangeweb.net
Gary Alderman, UST Class B Operator	galderman@rangeweb.net
Raymond Rolfson, UST Class B Operator	
Raymond Rolfson, UST Class B Operator	
Theresa Alderman, UST Class A Operator	galderman@rangeweb.net
Theresa Alderman, UST Class A Operator	galderman@rangeweb.net
Theresa Alderman, UST Class B Operator	galderman@rangeweb.net
Theresa Alderman, UST Class B Operator	galderman@rangeweb.net

Tank Number	04	**Tank Age**	32	**Tank Installed Date**	05/10/1993	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Steel	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	359	**Spill Test Date**	03/29/2023	**Piping Installed Date**	04/15/2008	**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	03/07/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	2000	**ATG Test Date**	03/29/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	03/07/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	05	**Tank Age**	32	**Tank Installed Date**	05/10/1993	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Steel	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	360	**Spill Test Date**	03/29/2023	**Piping Installed Date**	04/15/2008	**Tank Construction**		**Piping Construction**	None	**AST**	No

Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	03/07/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	2000	**ATG Test Date**	03/29/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	03/07/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	06	**Tank Age**	32	**Tank Installed Date**	05/10/1993	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Steel	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	361	**Spill Test Date**	03/29/2023	**Piping Installed Date**	04/15/2008	**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	03/07/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	2000	**ATG Test Date**	03/29/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	03/07/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	07	**Tank Age**	27	**Tank Installed Date**	09/30/1998	**Tank Material Construction**	Steel Clad	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	362	**Spill Test Date**	04/07/2023	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	06/21/2011	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	03/29/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	03/07/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	08	**Tank Age**	27	**Tank Installed Date**	09/30/1998	**Tank Material Construction**	Steel Clad	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	363	**Spill Test Date**	03/07/2023	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	06/21/2011	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	03/29/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No

		Overfill Test Date	03/07/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	09	**Tank Age**	27	**Tank Installed Date**	09/30/1998	**Tank Material Construction**	Steel Clad	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	364	**Spill Test Date**	04/07/2023	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	06/21/2011	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	03/29/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	03/07/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Powder River County in the City of Broadus

Location: COUNTY SHOP MAINTENANCE YARD
3 County Shop Rd
Broadus, MT 59317 Powder River

System Facility ID:38-00548

Facility Code: 26532
Last Inspected On: 03/07/2023
Operating Permit Renewal Date: 05/23/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Powder River County **(406) 436-2361**

Operator Contact: Teel Mullanix **(406) 436-2248** **prcrd1@gmail.com**

Owner/Operator: Powder River County (406) 436-2361

Teel Mullanix, UST Class A Operator prcrd1@gmail.com
Teel Mullanix, UST Class A Operator prcrd1@gmail.com
Teel Mullanix, UST Class B Operator prcrd1@gmail.com
Teel Mullanix, UST Class B Operator prcrd1@gmail.com

Tank Number	03	**Tank Age**	34	**Tank Installed Date**	06/17/1991	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Steel	**Overfill Types**	High Level Alarm
Tag Number	1807	**Spill Test Date**	04/07/2020	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	03/07/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	5000	**ATG Test Date**	03/07/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	03/07/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Powell County in the City of Deer Lodge

Location: DINO MART DEER LODGE
1007 Village Ln
Deer Lodge, MT 59722 Powell

System Facility ID:39-10909

Facility Code: 26728
Last Inspected On: 10/25/2022
Operating Permit Renewal Date: 03/24/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	T and TF Inc	**(406) 846-3819**	**tfickler@montana.com**
Operator Contact:	Betty McGann;Brandon Avers;Hazel Ehry;Randy Livingston	**(406) 560-3776;(406) 846-3969;(503) 927-6167**	**deerlodgedinomart@gmail.com;i90plaza@montana.com;jimmiecricket69@yahoo.com**

Owner/Operator:	T and TF Inc	(406) 846-3819	tfickler@montana.com
	Betty McGann, UST Class A Operator		jimmiecricket69@yahoo.com
	Betty McGann, UST Class A Operator		jimmiecricket69@yahoo.com
	Betty McGann, UST Class B Operator		jimmiecricket69@yahoo.com
	Betty McGann, UST Class B Operator		jimmiecricket69@yahoo.com
	Brandon Avers, UST Class A Operator		deerlodgedinomart@gmail.com
	Brandon Avers, UST Class A Operator		deerlodgedinomart@gmail.com
	Brandon Avers, UST Class B Operator		deerlodgedinomart@gmail.com
	Brandon Avers, UST Class B Operator		deerlodgedinomart@gmail.com
	Hazel Ehry, UST Class A Operator		i90plaza@montana.com
	Hazel Ehry, UST Class A Operator		i90plaza@montana.com
	Hazel Ehry, UST Class B Global Operator		i90plaza@montana.com
	Hazel Ehry, UST Class B Global Operator		i90plaza@montana.com
	Marci Smith, UST Class B Global Operator		m78_sarci@hotmail.com
	Marci Smith, UST Class B Global Operator		m78_sarci@hotmail.com
	Randy Livingston, UST Class A Operator		
	Randy Livingston, UST Class A Operator		
	Randy Livingston, UST Class B Global Operator		
	Randy Livingston, UST Class B Global Operator		

Tank Number	06	**Tank Age**	9	**Tank Installed Date**	02/18/2016	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	5644	**Spill Test Date**	12/22/2020	**Piping Installed Date**	11/30/2016	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	12/22/2020	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	12/02/2021	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No

Capacity	6000	**ATG Test Date**	12/02/2021	**Line Tightness Test Date**	01/06/2020	**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	06/24/2021			**ATG Type**	Gilbarco-Veeder Root/TLS-350;Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	04	**Tank Age**	27	**Tank Installed Date**	11/19/1998	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	768	**Spill Test Date**	09/18/2022	**Piping Installed Date**	11/30/2016	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	05/02/2022	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	12/02/2021	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	12/02/2021	**Line Tightness Test Date**	01/06/2020	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date	06/24/2021			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	05	**Tank Age**	27	**Tank Installed Date**	11/19/1998	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	769	**Spill Test Date**	06/24/2021	**Piping Installed Date**	11/30/2016	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	12/22/2020	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	12/02/2021	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	12/02/2021	**Line Tightness Test Date**	01/06/2020	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date	06/24/2021			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Powell County in the City of Deer Lodge

Location: GRIECO FAMILY LIMITED PARTNERSHIP
3850 Eastside Rd
Deer Lodge, MT 59722-9521 Powell

System Facility ID:39-13744

Facility Code: 26753
Last Inspected On: 11/16/2023
Operating Permit Renewal Date: 03/26/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Grieco Family Limited Partnership	**(406) 382-0771**	**pagrieco44@gmail.com**
Operator Contact:	Scott Grieco	**(406) 531-1803**	**pagrieco44@gmail.com**

Owner/Operator: Grieco Family Limited Partnership (406) 382-0771 pagrieco44@gmail.com

Scott Grieco, UST Class A Operator pagrieco44@gmail.com

Scott Grieco, UST Class B Operator pagrieco44@gmail.com

Tank Number	01	**Tank Age**	29	**Tank Installed Date**	06/01/1996	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	4624	**Spill Test Date**	11/16/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	11/16/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	11/16/2023			**ATG Type**	Gilbarco/EMC Basic				
Tank Number	02	**Tank Age**	29	**Tank Installed Date**	06/01/1996	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	4625	**Spill Test Date**	11/16/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	11/16/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	11/16/2023			**ATG Type**	Gilbarco/EMC Basic				

Facility Summary in Powell County in the City of Deer Lodge

Location: I 90 AUTO TRUCK PLAZA
132 I-90 Interchange
Deer Lodge, MT 59722 Powell

System Facility ID:39-07856

Facility Code: 26710
Last Inspected On: 10/27/2022
Operating Permit Renewal Date: 12/26/2025

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Fickler Oil Co Inc Deer Lodge	**(406) 846-3970**	**tfickler@montana.com**
Operator Contact:	Bonnie Cyr;Hazel Ehry	**(406) 846-3969**	**i90plaza@montana.com**

Owner/Operator: Fickler Oil Co Inc Deer Lodge (406) 846-3970 tfickler@montana.com

Bonnie Cyr, UST Class A Operator	i90plaza@montana.com
Bonnie Cyr, UST Class A Operator	i90plaza@montana.com
Bonnie Cyr, UST Class B Operator	i90plaza@montana.com
Bonnie Cyr, UST Class B Operator	i90plaza@montana.com
Hazel Ehry, UST Class A Operator	i90plaza@montana.com
Hazel Ehry, UST Class A Operator	i90plaza@montana.com
Hazel Ehry, UST Class B Global Operator	i90plaza@montana.com
Hazel Ehry, UST Class B Global Operator	i90plaza@montana.com
Hazel Ehry, UST Class B Operator	i90plaza@montana.com
Hazel Ehry, UST Class B Operator	i90plaza@montana.com
Percy Moore, UST Class B Global Operator	
Percy Moore, UST Class B Global Operator	

Tank Number	10	**Tank Age**	27	**Tank Installed Date**	12/01/1998	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve;High Level Alarm
Tag Number	3612	**Spill Test Date**	12/21/2020	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	12/02/2021	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	15000	**ATG Test Date**	12/02/2021	**Line Tightness Test Date**	07/18/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	12/02/2021			**ATG Type**	Gilbarco/TLS-350				
Tank Number	11	**Tank Age**	27	**Tank Installed Date**	12/01/1998	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve;High Level Alarm

Tag Number	3613	**Spill Test Date**	12/21/2020	**Piping Installed Date**	11/20/2013	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	12/21/2020	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	12/02/2021	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**	12/02/2021	**Line Tightness Test Date**	07/17/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date	12/02/2021			**ATG Type**	Gilbarco/TLS-350				
Tank Number	12	**Tank Age**	24	**Tank Installed Date**	06/01/2001	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve;High Level Alarm
Tag Number	4436	**Spill Test Date**	12/21/2020	**Piping Installed Date**	11/20/2013	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	12/21/2020	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	12/02/2021	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	20000	**ATG Test Date**	12/02/2021	**Line Tightness Test Date**	03/28/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date	12/02/2021			**ATG Type**	Gilbarco/TLS-350				
Tank Number	13	**Tank Age**	24	**Tank Installed Date**	06/01/2001	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve;High Level Alarm
Tag Number	4437	**Spill Test Date**	04/02/2022	**Piping Installed Date**	11/20/2013	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	12/21/2020	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	12/02/2021	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	12/02/2021	**Line Tightness Test Date**	07/22/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date	12/02/2021			**ATG Type**	Gilbarco/TLS-350				
Tank Number	14	**Tank Age**	22	**Tank Installed Date**	06/26/2003	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve;High Level Alarm
Tag Number	4847	**Spill Test Date**	12/21/2020	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel, Dyed	**PLLD Test Date**	12/02/2021	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No

Capacity	12000	**ATG Test Date**	12/02/2021	**Line Tightness Test Date**	07/18/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	12/02/2021			**ATG Type**	Gilbarco/TLS-350				
Tank Number	15	**Tank Age**	22	**Tank Installed Date**	06/26/2003	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve;High Level Alarm
Tag Number	4848	**Spill Test Date**	05/18/2021	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel, Dyed	**PLLD Test Date**	12/02/2021	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	12/02/2021	**Line Tightness Test Date**	07/22/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	12/02/2021			**ATG Type**	Gilbarco/TLS-350				

Facility Summary in Powell County in the City of Deer Lodge

Location: TOWN PUMP INC DEER LODGE
203 N Main St
Deer Lodge, MT 59722 Powell

System Facility ID:39-08694

Facility Code: 26716
Last Inspected On: 05/19/2025
Operating Permit Renewal Date: 08/31/2025

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Deer Lodge 1 Town Pump LLC **(406) 497-6700** **environmental@townpump.com**

Operator Contact: Trent Biggers **Trentb@townpump.com**

Owner/Operator: Deer Lodge 1 Town Pump LLC (406) 497-6700 environmental@townpump.com

Trent Biggers, UST Class A Operator Trentb@townpump.com
Trent Biggers, UST Class A Operator Trentb@townpump.com
Trent Biggers, UST Class B Global Operator Trentb@townpump.com
Trent Biggers, UST Class B Global Operator Trentb@townpump.com

Tank Number	01	**Tank Age**	48	**Tank Installed Date**	04/14/1977	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	2589	**Spill Test Date**	07/06/2021	**Piping Installed Date**		**Tank Construction**	Lined Interior/Impressed Current	**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**	12/01/2022	**Tank/Piping CP Test Date**	04/19/2021	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	11/14/2022	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	07/06/2021			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Number	02	**Tank Age**	48	**Tank Installed Date**	04/14/1977	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	2590	**Spill Test Date**	07/06/2021	**Piping Installed Date**		**Tank Construction**	Lined Interior/Impressed Current	**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**	12/01/2022	**Tank/Piping CP Test Date**	04/19/2021	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No

Capacity	10000	**ATG Test Date**	11/14/2022	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	07/06/2021			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Number	05	**Tank Age**	48	**Tank Installed Date**	04/14/1977	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	2591	**Spill Test Date**	07/06/2021	**Piping Installed Date**		**Tank Construction**	Lined Interior/Impressed Current	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	08/16/2018	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Diesel	**PLLD Test Date**	12/01/2022	**Tank/Piping CP Test Date**	04/19/2021	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	11/14/2022	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	07/06/2021			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Number	07	**Tank Age**	27	**Tank Installed Date**	07/30/1998	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve
Tag Number	2592	**Spill Test Date**	07/06/2021	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	12/01/2022	**Tank/Piping CP Test Date**	06/24/2014	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	11/14/2022	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	07/06/2021			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Number	08	**Tank Age**	25	**Tank Installed Date**	09/15/2000	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve
Tag Number	4282	**Spill Test Date**	07/06/2021	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	08/16/2018	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	12/01/2022	**Tank/Piping CP Test Date**	06/24/2014	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	5000	**ATG Test Date**	11/14/2022	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**		**Energy Act**	No

		Overfill Test Date	07/06/2021			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Number	09	**Tank Age**	25	**Tank Installed Date**	09/15/2000	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve
Tag Number	4283	**Spill Test Date**	07/06/2021	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	08/16/2018	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel, Dyed	**PLLD Test Date**	12/01/2022	**Tank/Piping CP Test Date**	06/24/2014	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	11/14/2022	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	07/06/2021			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Number	10	**Tank Age**	3	**Tank Installed Date**	11/02/2022	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	6099	**Spill Test Date**	11/02/2022	**Piping Installed Date**	11/02/2022	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	11/03/2022	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Gasoline	**PLLD Test Date**	12/01/2022	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	Yes
Capacity	12000	**ATG Test Date**	11/14/2022	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	Yes
		Overfill Test Date	11/03/2022			**ATG Type**					

Facility Summary in Powell County in the City of Elliston

Location: ELLISTON STORE
104 E Front St
Elliston, MT 59728 Powell

System Facility ID:39-05196

Facility Code: 26668
Last Inspected On: 07/25/2024
Operating Permit Renewal Date: 12/19/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Catherine Stumberg	**(406) 492-6391**	**ellistonstore@gmail.com**
Operator Contact:	Catherine Stumberg	**(406) 492-6391**	**ellistonstore@gmail.com**

Owner/Operator: Catherine Stumberg (406) 492-6391 ellistonstore@gmail.com

Catherine Stumberg, UST Class A Operator ellistonstore@gmail.com

Catherine Stumberg, UST Class B Operator ellistonstore@gmail.com

Tank Number	03	**Tank Age**	40	**Tank Installed Date**	05/06/1985	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	3856	**Spill Test Date**	07/25/2024	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	07/25/2024	**Sump Tightness Test Date**	04/28/2015	**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	07/25/2024	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**	07/25/2024	**Line Tightness Test Date**	07/25/2024	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	07/25/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	04	**Tank Age**	40	**Tank Installed Date**	05/06/1985	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	3857	**Spill Test Date**	07/25/2024	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	07/25/2024	**Sump Tightness Test Date**	04/28/2015	**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	07/25/2024	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**	07/25/2024	**Line Tightness Test Date**	07/25/2024	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	07/25/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Powell County in the City of Garrison

Location: GARRISON MERCANTILE and POST OFFICE INC
140 Garrison Junction Rd
Garrison, MT 59731 Powell

System Facility ID:39-03405

Facility Code: 26638
Last Inspected On: 10/20/2018
Operating Permit Renewal Date: 10/20/2021

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Garrison Mercantile and Post Office Inc

Operator Contact:

Owner/Operator: Garrison Mercantile and Post Office Inc

Tank Number	01	**Tank Age**	44	**Tank Installed Date**	05/05/1981	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Steel	**Overfill Types**	
Tag Number	3934	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**	Lined Interior/Impressed Current	**Piping Construction**	None	**AST**	No
Status	**Temporarily Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**		**Piping Type**	Safe Suction	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	08/06/2018	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.1	**Primary Pipe Leak Detection**	Deferred	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	02	**Tank Age**	44	**Tank Installed Date**	05/05/1981	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Steel	**Overfill Types**	
Tag Number	3935	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**	Lined Interior/Impressed Current	**Piping Construction**	None	**AST**	No
Status	**Temporarily Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**		**Piping Type**	Safe Suction	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	08/06/2018	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.1	**Primary Pipe Leak Detection**	Deferred	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					

Facility Summary in Powell County in the City of Ovando

Location: BLACKFOOT COMMERCIAL CO LLC
406 Pine St W
Ovando, MT 59854 Powell

System Facility ID:39-02276

Facility Code: 26616
Last Inspected On: 09/14/2022
Operating Permit Renewal Date: 11/30/2025

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Blackfoot Valley Inn and Mercentile LLC	**(406) 793-5555**	**lavaliton@hughes.net**
Operator Contact:	Fred Valiton	**(406) 793-5555**	**fandla@blackfoot.net**

Owner/Operator:	Blackfoot Valley Inn and Mercentile LLC	(406) 793-5555	lavaliton@hughes.net
	Fred Valiton, UST Class A Operator		fandla@blackfoot.net
	Fred Valiton, UST Class A Operator		fandla@blackfoot.net
	Fred Valiton, UST Class B Operator		fandla@blackfoot.net
	Fred Valiton, UST Class B Operator		fandla@blackfoot.net

Tank Number	S07	**Tank Age**	29	**Tank Installed Date**	06/01/1996	**Tank Material Construction**	Aboveground Tank	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	
Tag Number	3362	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	Yes
Status	**Currently in Use**	**MLLD Test Date**	09/14/2022	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	1000	**ATG Test Date**		**Line Tightness Test Date**	09/14/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	S08	**Tank Age**	29	**Tank Installed Date**	06/01/1996	**Tank Material Construction**	Aboveground Tank	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	
Tag Number	3363	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	Yes
Status	**Currently in Use**	**MLLD Test Date**	09/14/2022	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	3000	**ATG Test Date**		**Line Tightness Test Date**	09/14/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	S09	**Tank Age**	29	**Tank Installed Date**	06/01/1996	**Tank Material Construction**	Aboveground Tank	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	

Tag Number	3364	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	Yes
Status	**Currently in Use**	**MLLD Test Date**	09/14/2022	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	1000	**ATG Test Date**		**Line Tightness Test Date**	09/14/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					

Facility Summary in Prairie County in the City of Terry

Location: 4 CORNERS
3 Ten Mile Rd
Terry, MT 59349 Prairie

System Facility ID:40-06798

Facility Code: 26798
Last Inspected On: 05/01/2024
Operating Permit Renewal Date: 08/03/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Robert Waylon and Leann Lantis	**(406) 635-5814**	**lantis@midrivers.coms**
Operator Contact:	Leann Lantis	**(406) 635-2198**	**lantis@midrivers.com**

Owner/Operator:	Robert Waylon and Leann Lantis	(406) 635-5814	lantis@midrivers.coms
	Leann Lantis, UST Class A Operator		lantis@midrivers.com
	Leann Lantis, UST Class A Operator		lantis@midrivers.com
	Leann Lantis, UST Class B Operator		lantis@midrivers.com
	Leann Lantis, UST Class B Operator		lantis@midrivers.com

Tank Number	09	**Tank Age**	11	**Tank Installed Date**	10/14/2014	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	5539	**Spill Test Date**	06/07/2021	**Piping Installed Date**	10/29/2014	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	05/01/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	06/07/2021	**Line Tightness Test Date**	07/30/2021	**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	06/07/2021			**ATG Type**	Incon/TS-550 EVO				
Tank Number	10	**Tank Age**	11	**Tank Installed Date**	10/14/2014	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	5540	**Spill Test Date**	06/07/2021	**Piping Installed Date**	10/29/2014	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	06/07/2021	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**	06/07/2021	**Line Tightness Test Date**	07/30/2021	**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	06/07/2021			**ATG Type**	Incon/TS-550 EVO				

Tank Number	11	**Tank Age**	11	**Tank Installed Date**	10/14/2014	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	5541	**Spill Test Date**	06/07/2021	**Piping Installed Date**	10/29/2014	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	06/07/2021	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	06/07/2021	**Line Tightness Test Date**	07/30/2021	**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	06/07/2021			**ATG Type**	Incon/TS-550 EVO				

Facility Summary in Prairie County in the City of Terry

Location: FARMERS UNION OIL CO TERRY
101 McDonald Ave
Terry, MT 59349 Prairie

System Facility ID:40-06797

Facility Code: 26797
Last Inspected On: 11/21/2022
Operating Permit Renewal Date: 03/14/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Farmers Union Oil Co Circle **(406) 485-3475**

Operator Contact: Dawnya Kirkpatrick **(406) 939-1559** **tfarmers@midrivers.com**

Owner/Operator: Farmers Union Oil Co Circle (406) 485-3475

Dawnya Kirkpatrick, UST Class A Operator	tfarmers@midrivers.com
Dawnya Kirkpatrick, UST Class A Operator	tfarmers@midrivers.com
Dawnya Kirkpatrick, UST Class B Operator	tfarmers@midrivers.com
Dawnya Kirkpatrick, UST Class B Operator	tfarmers@midrivers.com
Fritz Deines, UST Class B Global Operator	frd92372@comcast.net
Fritz Deines, UST Class B Global Operator	frd92372@comcast.net

Tank Number	06	**Tank Age**	35	**Tank Installed Date**	04/01/1990	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	955	**Spill Test Date**	11/21/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	11/21/2022	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	1000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	11/21/2022			**ATG Type**					
Tank Number	07	**Tank Age**	35	**Tank Installed Date**	04/01/1990	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	956	**Spill Test Date**	11/21/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	11/21/2022	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	1000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No

		Overfill Test Date	11/21/2022			**ATG Type**					
Tank Number	08	**Tank Age**	35	**Tank Installed Date**	04/01/1990	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	957	**Spill Test Date**	11/21/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	11/21/2022	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	560	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	11/21/2022			**ATG Type**					

Facility Summary in Prairie County in the City of Terry

Location: MTD PETROLEUM SERVICE LLC
14 Ten Mile Rd
Terry, MT 59349 Prairie

System Facility ID:56-14149

Facility Code: 30785
Last Inspected On: 09/26/2023
Operating Permit Renewal Date: 02/24/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Cross Petroleum Services Glendive;Mark Underberg **(406) 635-5479** **cross@midrivers.com;tfarmers@midrivers.com**

Operator Contact: Gregory Cross;R J Serpe;Timothy Fife **gcross@crosspetroleumservice.com;rlsrp@yahoo.com**

Owner/Operator: Cross Petroleum Services Glendive cross@midrivers.com

Owner/Operator: Mark Underberg cross@midrivers.com

Greg Cross, UST Class A Operator gcross@crosspetroleumservice.com
R J Serpe, UST Class A Operator rlsrp@yahoo.com
R J Serpe, UST Class B Global Operator rlsrp@yahoo.com
Ron Serpe, UST Class B Global Operator cross@midrivers.com
Timothy Fife, UST Class A Operator

Tank Number	S2	**Tank Age**	20	**Tank Installed Date**	05/05/2005	**Tank Material Construction**	Concrete	**Piping Material**	Flexible Plastic	**Overfill Types**	
Tag Number	4960	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	Yes
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Diesel	**PLLD Test Date**	08/25/2022	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	09/26/2023	**Line Tightness Test Date**	02/23/2021	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	S3	**Tank Age**	20	**Tank Installed Date**	05/05/2005	**Tank Material Construction**	Concrete	**Piping Material**	Flexible Plastic	**Overfill Types**	
Tag Number	4961	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	Yes
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Diesel	**PLLD Test Date**	08/25/2022	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No

Capacity	10000	**ATG Test Date**	09/26/2023	**Line Tightness Test Date**	02/23/2021	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	S4	**Tank Age**	20	**Tank Installed Date**	05/05/2005	**Tank Material Construction**	Concrete	**Piping Material**	Flexible Plastic	**Overfill Types**	
Tag Number	4962	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	Yes
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Diesel	**PLLD Test Date**	08/25/2022	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	09/26/2023	**Line Tightness Test Date**	02/23/2021	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	S5	**Tank Age**	20	**Tank Installed Date**	05/05/2005	**Tank Material Construction**	Concrete	**Piping Material**	Flexible Plastic	**Overfill Types**	
Tag Number	5039	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	Yes
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Gasoline	**PLLD Test Date**	08/25/2022	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	09/26/2023	**Line Tightness Test Date**	02/23/2021	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	S1	**Tank Age**	20	**Tank Installed Date**	05/05/2005	**Tank Material Construction**	Concrete	**Piping Material**	Flexible Plastic	**Overfill Types**	
Tag Number	5040	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	Yes
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Gasoline	**PLLD Test Date**	08/25/2022	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	09/26/2023	**Line Tightness Test Date**	02/23/2021	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date				**ATG Type**					

Facility Summary in Ravalli County in the City of Corvallis

Location: THE MERC FRESH MARKET INC
1000 Main St
Corvallis, MT 59828-9749 Ravalli

System Facility ID:41-02402

Facility Code: 26862
Last Inspected On: 11/21/2024
Operating Permit Renewal Date: 02/17/2028

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: The Merc Fresh Market Inc **mercfreshmarket@qwest.net**

Operator Contact: Shelby LaForge **slaforge@mcleodpartnersinc.com**

Owner/Operator: The Merc Fresh Market Inc mercfreshmarket@qwest.net

Shelby LaForge, UST Class A Operator slaforge@mcleodpartnersinc.com

Shelby LaForge, UST Class B Operator slaforge@mcleodpartnersinc.com

Tank Number	04	**Tank Age**	31	**Tank Installed Date**	02/01/1994	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	376	**Spill Test Date**	06/18/2024	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	06/18/2024	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	11/21/2024	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	06/18/2024	**Line Tightness Test Date**	06/18/2024	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	06/18/2024			**ATG Type**	Veeder Root/TLS-300				
Tank Number	05	**Tank Age**	29	**Tank Installed Date**	08/01/1996	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	377	**Spill Test Date**	06/18/2024	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	06/18/2024	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**	06/18/2024	**Line Tightness Test Date**	06/18/2024	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	06/18/2024			**ATG Type**	Veeder Root/TLS-300				
Tank Number	06	**Tank Age**	29	**Tank Installed Date**	08/01/1996	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	378	**Spill Test Date**	06/18/2024	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No

Status	**Currently in Use**	**MLLD Test Date**	06/18/2024	**Sump Tightness Test Date**	06/15/2022	**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	06/18/2024	**Line Tightness Test Date**	06/18/2024	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	06/18/2024			**ATG Type**	Veeder Root/TLS-300				

Facility Summary in Ravalli County in the City of Darby

Location: DARBY LUMBER
3299 US Hwy 93
Darby, MT 59829 Ravalli

System Facility ID:41-00853

Facility Code: 26844
Last Inspected On: 11/02/2021
Operating Permit Renewal Date: 11/02/2024

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	International Paper	**(901) 419-9000**	**tom.richardson@ipaper.com**
Operator Contact:	David Cosgriff	**(406) 293-1011**	**david@aelibby.com**

David Cosgriff, UST Class A Operator david@aelibby.com
David Cosgriff, UST Class B Global Operator david@aelibby.com

Tank Number	04	**Tank Age**	33	**Tank Installed Date**	04/01/1992	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	803	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	11/02/2021	**Primary Tank Leak Detection**	Inventory Reconciliation;Tank Tightness Testing	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	05	**Tank Age**	33	**Tank Installed Date**	04/01/1992	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	804	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	11/02/2021	**Primary Tank Leak Detection**	Manual Tank Gauging;Tank Tightness Testing	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	2000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					

Facility Summary in Ravalli County in the City of Darby

Location: MR TS FOOD AND FUEL
101 S Main St
Darby, MT 59829 Ravalli

System Facility ID:41-00028

Facility Code: 26829
Last Inspected On: 02/15/2023
Operating Permit Renewal Date: 05/16/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Roller Darby Properties LLC	**(509) 793-4164**	**jchana41@gmail.com**
Operator Contact:	Tohn Keagle	**(509) 250-3093**	**keagletohn@gmail.com**

Owner/Operator: Roller Darby Properties LLC (509) 793-4164 jchana41@gmail.com

Jesse Goodwin, UST Class B Operator
Tohn Keagle, UST Class A Operator keagletohn@gmail.com
Tohn Keagle, UST Class B Global Operator keagletohn@gmail.com

Tank Number	06	**Tank Age**	30	**Tank Installed Date**	04/13/1995	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve;Flapper Valve
Tag Number	3070	**Spill Test Date**	02/15/2023	**Piping Installed Date**	11/22/2016	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	03/10/2020	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	02/15/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date	03/29/2023			**ATG Type**	Incon/TS-1000				
Tank Number	07	**Tank Age**	30	**Tank Installed Date**	04/13/1995	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve;Flapper Valve
Tag Number	3071	**Spill Test Date**	02/15/2023	**Piping Installed Date**	11/22/2016	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	03/10/2020	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	02/15/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date	03/29/2023			**ATG Type**	Incon/TS-1000				

Tank Number	08	**Tank Age**	9	**Tank Installed Date**	10/01/2016	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	5725	**Spill Test Date**	02/15/2023	**Piping Installed Date**	11/22/2016	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	03/10/2020	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	02/15/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	02/15/2023			**ATG Type**	Incon/TS-1001				
Tank Number	09	**Tank Age**	9	**Tank Installed Date**	10/01/2016	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	5726	**Spill Test Date**	02/15/2023	**Piping Installed Date**	11/22/2016	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	03/10/2020	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel, Dyed	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	02/15/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	02/15/2023			**ATG Type**	Incon/TS-1001				

Facility Summary in Ravalli County in the City of Darby

Location: OLES COUNTRY STORE 6
450 Hwy 93 S
Darby, MT 59829 Ravalli

System Facility ID:41-10908

Facility Code: 26979
Last Inspected On: 05/23/2024
Operating Permit Renewal Date: 05/23/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Nathaniel Robbins;Town of Darby	**(406) 821-3753;(406) 821-3753**	**darbymontana@usa.net;darbymontana@usa.net**
Operator Contact:	Tammy Stuart;Town of Darby	**(406) 821-3753**	**darby-tammy@usa.net;darbymontana@usa.net**

Owner/Operator: Nathaniel Robbins,Town of Darby (406) 821-3753 darbymontana@usa.net

Tammy Stuart, UST Class A Operator darbymontana@usa.net

Tammy Stuart, UST Class B Operator darbymontana@usa.net

Tank Number	06	**Tank Age**	30	**Tank Installed Date**	04/01/1995	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve
Tag Number	1441	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Single Walled	**AST**	No
Status	**Temporarily Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.1;Automatic Tank Gauging 0.2;Inventory Reconciliation;Tank Tightness Testing	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	07	**Tank Age**	30	**Tank Installed Date**	04/01/1995	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve
Tag Number	1442	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Single Walled	**AST**	No
Status	**Temporarily Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible

Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.1;Automatic Tank Gauging 0.2;Inventory Reconciliation;Tank Tightness Testing	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	08	**Tank Age**	30	**Tank Installed Date**	04/01/1995	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve
Tag Number	1443	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Single Walled	**AST**	No
Status	**Temporarily Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.1;Automatic Tank Gauging 0.2;Inventory Reconciliation;Tank Tightness Testing	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	5000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					

Facility Summary in Ravalli County in the City of Darby

Location: PEOPLES MARKET
801 N Main St
Darby, MT 59829 Ravalli

System Facility ID:56-14029

Facility Code: 30688
Last Inspected On: 08/08/2022
Operating Permit Renewal Date: 12/26/2025

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Peoples Market **(651) 261-3851**

Operator Contact: Greg Bergren **(406) 821-3612** **peoplesharvest@gmail.com**

Owner/Operator: Peoples Market (651) 261-3851

Greg Bergren, UST Class A Operator peoplesharvest@gmail.com
Jesse Bergren, UST Class B Operator peoplesharvest@gmail.com

Tank Number	S1	**Tank Age**	24	**Tank Installed Date**	08/20/2001	**Tank Material Construction**	Unknown	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	4338	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	Yes
Status	**Currently in Use**	**MLLD Test Date**	10/26/2021	**Sump Tightness Test Date**	11/20/2019	**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	10/26/2021	**Line Tightness Test Date**	10/26/2021	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	S2	**Tank Age**	24	**Tank Installed Date**	08/20/2001	**Tank Material Construction**	Unknown	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	4339	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	Yes
Status	**Currently in Use**	**MLLD Test Date**	10/26/2021	**Sump Tightness Test Date**	11/20/2019	**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	10/26/2021	**Line Tightness Test Date**	10/26/2021	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	S3	**Tank Age**	24	**Tank Installed Date**	08/20/2001	**Tank Material Construction**	Unknown	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm

Tag Number	4340	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	Yes
Status	**Currently in Use**	**MLLD Test Date**	10/26/2021	**Sump Tightness Test Date**	11/20/2019	**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	5000	**ATG Test Date**	10/26/2021	**Line Tightness Test Date**	10/26/2021	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	S4	**Tank Age**	24	**Tank Installed Date**	08/20/2001	**Tank Material Construction**	Unknown	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	4341	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	Yes
Status	**Currently in Use**	**MLLD Test Date**	10/26/2021	**Sump Tightness Test Date**	11/20/2019	**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Diesel, Dyed	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	5000	**ATG Test Date**	10/26/2021	**Line Tightness Test Date**	10/26/2021	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date				**ATG Type**					

Facility Summary in Ravalli County in the City of Florence

Location: DYNA MART LLP
5323 US Hwy 93
Florence, MT 59833-6830 Ravalli

System Facility ID:41-11356

Facility Code: 26989
Last Inspected On: 10/30/2024
Operating Permit Renewal Date: 10/30/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Jeremy and Betsy Milyard	**(406) 552-2257**	**milyardhomes@yahoo.com**
Operator Contact:	Shannon Tomicek;Timbre Case	**(406) 949-3419**	**stomicek@yahoo.com;veritasconstruction1@gmail.com**

Owner/Operator:	Jeremy and Betsy Milyard	(406) 552-2257	milyardhomes@yahoo.com
	Shannon Tomicek, UST Class A Operator		stomicek@yahoo.com
	Shannon Tomicek, UST Class B Operator		stomicek@yahoo.com
	Timbre Case, UST Class A Operator		veritasconstruction1@gmail.com
	Timbre Case, UST Class B Operator		veritasconstruction1@gmail.com

Tank Number	S1	**Tank Age**	45	**Tank Installed Date**	01/01/1980	**Tank Material Construction**	Bare Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	
Tag Number	2331	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	Yes
Status	**Temporarily Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**		**Line Tightness Test Date**	10/20/2010	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	S2	**Tank Age**	45	**Tank Installed Date**	01/01/1980	**Tank Material Construction**	Bare Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	
Tag Number	2332	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	Yes
Status	**Temporarily Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**		**Line Tightness Test Date**	10/20/2010	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	S3	**Tank Age**	45	**Tank Installed Date**	01/01/1980	**Tank Material Construction**	Bare Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	

Tag Number	2333	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	Yes
Status	**Temporarily Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**		**Line Tightness Test Date**	10/20/2010	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	S4	**Tank Age**	45	**Tank Installed Date**	01/01/1980	**Tank Material Construction**	Bare Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	
Tag Number	2334	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	Yes
Status	**Temporarily Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	5000	**ATG Test Date**		**Line Tightness Test Date**	10/20/2010	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					

Facility Summary in Ravalli County in the City of Florence

Location: TOWN PUMP INC FLORENCE
5495 US Hwy 93 N
Florence, MT 59833-6862 Ravalli

System Facility ID:41-12720

Facility Code: 27032
Last Inspected On: 05/04/2023
Operating Permit Renewal Date: 10/17/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Florence 1 Town Pump LLC **(406) 497-6700** **environmental@townpump.com**

Operator Contact: Trent Biggers **Trentb@townpump.com**

Owner/Operator: Florence 1 Town Pump LLC (406) 497-6700 environmental@townpump.com

Trent Biggers, UST Class A Operator Trentb@townpump.com
Trent Biggers, UST Class A Operator Trentb@townpump.com
Trent Biggers, UST Class B Global Operator Trentb@townpump.com
Trent Biggers, UST Class B Global Operator Trentb@townpump.com

Tank Number	01	**Tank Age**	33	**Tank Installed Date**	01/01/1992	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	2967	**Spill Test Date**	07/26/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Single Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**	04/28/2023	**Tank/Piping CP Test Date**	07/26/2022	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	Yes
Capacity	9000	**ATG Test Date**	04/28/2023	**Line Tightness Test Date**	12/27/2009	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	10/18/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-450				
Tank Number	02	**Tank Age**	33	**Tank Installed Date**	01/01/1992	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	2968	**Spill Test Date**	07/26/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Single Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**	04/28/2023	**Tank/Piping CP Test Date**	07/26/2022	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	3000	**ATG Test Date**	04/28/2023	**Line Tightness Test Date**	12/27/2009	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	07/26/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-450				

Tank Number	03	**Tank Age**	33	**Tank Installed Date**	01/01/1992	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	2969	**Spill Test Date**	10/26/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**	04/28/2023	**Tank/Piping CP Test Date**	10/26/2022	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**	04/28/2023	**Line Tightness Test Date**	12/27/2009	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	10/26/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-450				
Tank Number	04	**Tank Age**	33	**Tank Installed Date**	01/01/1992	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	2970	**Spill Test Date**	07/26/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**	04/28/2023	**Tank/Piping CP Test Date**	07/26/2022	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**	04/28/2023	**Line Tightness Test Date**	12/27/2009	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	07/26/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-450				
Tank Number	05	**Tank Age**	25	**Tank Installed Date**	05/01/2000	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve
Tag Number	4192	**Spill Test Date**	07/26/2022	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	04/28/2021	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	04/28/2023	**Tank/Piping CP Test Date**	01/06/2010	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	5000	**ATG Test Date**	04/28/2023	**Line Tightness Test Date**	12/27/2009	**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	07/26/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-450				
Tank Number	06	**Tank Age**	25	**Tank Installed Date**	05/01/2000	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve
Tag Number	4193	**Spill Test Date**	07/26/2022	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	04/28/2021	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible

Product	Gasoline	**PLLD Test Date**	04/28/2023	**Tank/Piping CP Test Date**	01/06/2010	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	04/28/2023	**Line Tightness Test Date**	12/27/2009	**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	10/18/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-450				
Tank Number	07	**Tank Age**	25	**Tank Installed Date**	05/01/2000	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve
Tag Number	4194	**Spill Test Date**	07/26/2022	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	04/28/2021	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	04/28/2023	**Tank/Piping CP Test Date**	01/06/2010	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	5000	**ATG Test Date**	04/28/2023	**Line Tightness Test Date**	12/27/2009	**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	07/26/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-450				
Tank Number	08	**Tank Age**	25	**Tank Installed Date**	05/01/2000	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve
Tag Number	4195	**Spill Test Date**	07/26/2022	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	04/28/2021	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	04/28/2023	**Tank/Piping CP Test Date**	01/06/2010	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	04/28/2023	**Line Tightness Test Date**	12/27/2009	**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	07/26/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-450				
Tank Number	09	**Tank Age**	25	**Tank Installed Date**	05/01/2000	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve
Tag Number	4196	**Spill Test Date**	10/18/2022	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	04/28/2021	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	04/28/2023	**Tank/Piping CP Test Date**	01/06/2010	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	5000	**ATG Test Date**	04/28/2023	**Line Tightness Test Date**	12/27/2009	**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No

		Overfill Test Date	07/26/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-450				
Tank Number	10	**Tank Age**	25	**Tank Installed Date**	05/01/2000	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve
Tag Number	4197	**Spill Test Date**	07/26/2022	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	04/28/2021	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	04/28/2023	**Tank/Piping CP Test Date**	01/06/2010	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	04/28/2023	**Line Tightness Test Date**	12/27/2009	**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	07/26/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-450				

Facility Summary in Ravalli County in the City of Hamilton

Location: ANGLERS ROOST RV PARK AND CAMPGROUND
815 US Hwy 93 S
Hamilton, MT 59840-9746 Ravalli

System Facility ID:41-05798

Facility Code: 26904
Last Inspected On: 03/12/2021
Operating Permit Renewal Date: 03/12/2024

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	RJ DEVELOPMENT GROUP, LLC	**(406) 363-1268**	**RESMITH2011@RJ-DEVELOPMENT.NET**
Operator Contact:	John Cawley	**(406) 363-1268**	**anglersroost@cybernet1.com**

John G Cawley, UST Class A Operator	anglersroost@cybernet1.com
John G Cawley, UST Class A Operator	anglersroost@cybernet1.com
John G Cawley, UST Class B Global Operator	anglersroost@cybernet1.com
John G Cawley, UST Class B Global Operator	anglersroost@cybernet1.com

Tank Number	01	**Tank Age**	41	**Tank Installed Date**	04/25/1984	**Tank Material Construction**	Bare Steel	**Piping Material**	Steel	**Overfill Types**	Flapper Valve
Tag Number	3470	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	03/02/2021	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	20000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	02	**Tank Age**	40	**Tank Installed Date**	04/04/1985	**Tank Material Construction**	Bare Steel	**Piping Material**	Steel	**Overfill Types**	Flapper Valve
Tag Number	3471	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	03/02/2021	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	20000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					

Facility Summary in Ravalli County in the City of Hamilton

Location: LONE PINE INC
504 US Hwy 93 S
Hamilton, MT 59840-8967 Ravalli

System Facility ID:56-13874

Facility Code: 30553
Last Inspected On: 09/28/2024
Operating Permit Renewal Date: 02/17/2028

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	West Fork Holdings LLC	**(406) 375-0554**	**hawkes72@msn.com**
Operator Contact:	Brian Hawkes	**(406) 370-1612**	**hawkes72@msn.com**

Owner/Operator: West Fork Holdings LLC (406) 375-0554 hawkes72@msn.com

Brian R Hawkes, UST Class A Operator hawkes72@msn.com

Brian R Hawkes, UST Class B Operator hawkes72@msn.com

Tank Number	01	**Tank Age**	27	**Tank Installed Date**	07/01/1998	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	3513	**Spill Test Date**	09/22/2024	**Piping Installed Date**	10/20/2017	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	09/22/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	09/22/2024	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	09/22/2024	**Line Tightness Test Date**	05/14/2021	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date	09/22/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	02	**Tank Age**	27	**Tank Installed Date**	07/01/1998	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	3514	**Spill Test Date**	09/22/2024	**Piping Installed Date**	10/20/2017	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	09/22/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	09/22/2024	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	Yes
Capacity	8000	**ATG Test Date**	09/22/2024	**Line Tightness Test Date**	05/14/2021	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date	09/22/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Tank Number	03	**Tank Age**	27	**Tank Installed Date**	07/01/1998	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	3515	**Spill Test Date**	09/22/2024	**Piping Installed Date**	10/20/2017	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	09/22/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	09/22/2024	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	09/22/2024	**Line Tightness Test Date**	05/16/2021	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date	09/22/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	04	**Tank Age**	8	**Tank Installed Date**	10/20/2017	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	5787	**Spill Test Date**	09/22/2024	**Piping Installed Date**	10/20/2017	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	09/22/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	09/22/2024	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	Yes
Capacity	6000	**ATG Test Date**	09/22/2024	**Line Tightness Test Date**	11/06/2021	**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	09/22/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350;Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	05	**Tank Age**	8	**Tank Installed Date**	10/20/2017	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	5788	**Spill Test Date**	09/22/2024	**Piping Installed Date**	10/20/2017	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	09/22/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	09/22/2024	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	Yes
Capacity	12000	**ATG Test Date**	09/22/2024	**Line Tightness Test Date**	05/17/2021	**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	09/22/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350;Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Ravalli County in the City of Hamilton

Location: MARCUS DALY MEMORIAL HOSPITAL
1200 Westwood Dr
Hamilton, MT 59840-2345 Ravalli

System Facility ID:41-12767

Facility Code: 27034
Last Inspected On: 01/31/2024
Operating Permit Renewal Date: 02/13/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Marcus Daly Memorial Hospital **(406) 363-2211**

Operator Contact: Brand McBride;Eric Etter **(406) 375-4488;(406) 381-0873** **brandmcbride@bitterroothealth.org**

Owner/Operator: Marcus Daly Memorial Hospital (406) 363-2211

Brand McBride, UST Class A Operator brandmcbride@bitterroothealth.org
Brand McBride, UST Class B Operator brandmcbride@bitterroothealth.org
Daniel Healy, UST Class B Global Operator daniel.healy@mdmh.org
Eric Etter, UST Class A Operator

Tank Number	S3	**Tank Age**	13	**Tank Installed Date**	08/01/2012	**Tank Material Construction**	Concrete	**Piping Material**	Flexible Plastic	**Overfill Types**	
Tag Number	5376	**Spill Test Date**		**Piping Installed Date**	06/08/2012	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	Yes
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	01/31/2024	**Catastrophic L.D. Type 3.0**	Continuous Interstitial Monitoring	**Piping Type**	U.S. Suction	**CP Met Types**	
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	2000	**ATG Test Date**	01/31/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					

Facility Summary in Ravalli County in the City of Hamilton

Location: QUALITY USED CARS
400 N 1st St
Hamilton, MT 59840-2530 Ravalli

System Facility ID:41-13769

Facility Code: 27061
Last Inspected On: 09/27/2023
Operating Permit Renewal Date: 09/27/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: David Hull;Quality Investments **(208) 756-2236;(208) 756-2237**

Operator Contact: Donald Harrison **(406) 369-2291** **donharrison403@gmail.com**

Owner/Operator: David Hull (208) 756-2237

Owner/Operator: Quality Investments (208) 756-2237

Donald Harrison, UST Class A Operator donharrison403@gmail.com

Donald Harrison, UST Class B Operator donharrison403@gmail.com

Tank Number	01	**Tank Age**	28	**Tank Installed Date**	03/05/1997	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	3436	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Temporarily Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Pressurized	**CP Met Types**	
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	02	**Tank Age**	28	**Tank Installed Date**	03/05/1997	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	3437	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Temporarily Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Pressurized	**CP Met Types**	
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					

Tank Number	03	**Tank Age**	28	**Tank Installed Date**	03/05/1997	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	3438	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Temporarily Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Pressurized	**CP Met Types**	
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					

Facility Summary in Ravalli County in the City of Hamilton

Location: RAVALLI COUNTY ROAD DEPT
244 Fairgrounds Rd
Hamilton, MT 59840 Ravalli

System Facility ID:41-06546

Facility Code: 26917
Last Inspected On: 02/04/2025
Operating Permit Renewal Date: 02/04/2028

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Ravalli County **gwiles@rc.mt.gov**

Operator Contact: Jim Bryan **dsenn@rc.mt.gov**

Owner/Operator: Ravalli County gwiles@rc.mt.gov

Jim Bryan, UST Class A Operator dsenn@rc.mt.gov
Jim Bryan, UST Class A Operator dsenn@rc.mt.gov
Jim Bryan, UST Class B Operator dsenn@rc.mt.gov
Jim Bryan, UST Class B Operator dsenn@rc.mt.gov

Tank Number	05	**Tank Age**	34	**Tank Installed Date**	11/01/1991	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Steel	**Overfill Types**	Flapper Valve
Tag Number	1831	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Temporarily Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	02/17/2022	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**	Incon/TS-1001				

Facility Summary in Ravalli County in the City of Hamilton

Location: RIVERSIDE CONOCO
1987 N 1st St
Hamilton, MT 59840-3116 Ravalli

System Facility ID:41-13588

Facility Code: 27056
Last Inspected On: 06/07/2023
Operating Permit Renewal Date: 10/02/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Tsulkalu Holdings	**(406) 375-0536**	**sccghawkes@msn.com**
Operator Contact:	Stephen Hawkes	**(406) 375-0536**	**sccghawkes@msn.com**

Owner/Operator: Tsulkalu Holdings (406) 375-0536 sccghawkes@msn.com

Stephen Hawkes, UST Class A Operator sccghawkes@msn.com

Stephen Hawkes, UST Class B Operator sccghawkes@msn.com

Tank Number	02	**Tank Age**	27	**Tank Installed Date**	06/01/1998	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve;High Level Alarm
Tag Number	3262	**Spill Test Date**	04/25/2024	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	06/07/2023	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	06/07/2023	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	06/07/2023	**Line Tightness Test Date**	08/13/2014	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	06/07/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	03	**Tank Age**	27	**Tank Installed Date**	06/01/1998	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve;High Level Alarm
Tag Number	3263	**Spill Test Date**	06/07/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	06/07/2023	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	06/07/2023	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	06/07/2023	**Line Tightness Test Date**	08/13/2014	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	06/07/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Tank Number	04	**Tank Age**	27	**Tank Installed Date**	06/01/1998	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve;High Level Alarm
Tag Number	3264	**Spill Test Date**	04/25/2024	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	06/07/2023	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	06/07/2023	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	06/07/2023	**Line Tightness Test Date**	08/13/2014	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	06/07/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	05	**Tank Age**	20	**Tank Installed Date**	12/07/2005	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve;High Level Alarm
Tag Number	5061	**Spill Test Date**	06/07/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	06/07/2023	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	06/07/2023	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	06/07/2023	**Line Tightness Test Date**	08/13/2014	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	06/07/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	06	**Tank Age**	8	**Tank Installed Date**	04/01/2017	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	5745	**Spill Test Date**	06/07/2023	**Piping Installed Date**	05/19/2017	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	06/07/2023	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Not Listed	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	06/07/2023	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**	06/07/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	06/07/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350;Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Ravalli County in the City of Hamilton

Location: TIMBOS BITTERROOT FUEL SERVICE INC
410 S 1st St
Hamilton, MT 59840-2809 Ravalli

System Facility ID:41-04846

Facility Code: 26891
Last Inspected On: 04/10/2024
Operating Permit Renewal Date: 08/06/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Timbos Bitterroot Fuel Service Inc	**(406) 363-1933**	**Tim@StockdaleREG.com**
Operator Contact:	Tim McCrary;Timbos Bitterroot Fuel Service Inc	**(406) 363-1933**	**Timbo@TimbosFuelService.com;Tim@StockdaleREG.com**

Owner/Operator: Timbos Bitterroot Fuel Service Inc (406) 363-1933 Tim@StockdaleREG.com

Tim McCrary, UST Class A Operator Tim@StockdaleREG.com

Tim McCrary, UST Class B Operator Timbo@TimbosFuelService.com

Tank Number	S4	**Tank Age**	32	**Tank Installed Date**	03/01/1993	**Tank Material Construction**	Bare Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	
Tag Number	820	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	Yes
Status	**Currently in Use**	**MLLD Test Date**	05/30/2024	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	04/10/2024	**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	7050	**ATG Test Date**		**Line Tightness Test Date**	04/10/2024	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	S5	**Tank Age**	32	**Tank Installed Date**	03/01/1993	**Tank Material Construction**	Bare Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	
Tag Number	821	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	Yes
Status	**Temporarily Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	04/10/2024	**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	2678	**ATG Test Date**		**Line Tightness Test Date**	06/08/2015	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	S7	**Tank Age**	32	**Tank Installed Date**	03/03/1993	**Tank Material Construction**	Bare Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	
Tag Number	822	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	Yes

Status	**Currently in Use**	**MLLD Test Date**	05/30/2024	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	04/10/2024	**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	5000	**ATG Test Date**		**Line Tightness Test Date**	04/10/2024	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	S8	**Tank Age**	32	**Tank Installed Date**	03/03/1993	**Tank Material Construction**	Bare Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	
Tag Number	823	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	Yes
Status	**Currently in Use**	**MLLD Test Date**	05/30/2024	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	04/10/2024	**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	20000	**ATG Test Date**		**Line Tightness Test Date**	04/10/2024	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					

Facility Summary in Ravalli County in the City of Hamilton

Location: TOWN PUMP INC HAMILTON 1
1117 N 1st St
Hamilton, MT 59840-2103 Ravalli

System Facility ID:41-09670

Facility Code: 26952
Last Inspected On: 03/16/2023
Operating Permit Renewal Date: 10/18/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Hamilton 1 Town Pump LLC **(406) 497-6700** **environmental@townpump.com**

Operator Contact: Trent Biggers **Trentb@townpump.com**

Owner/Operator: Hamilton 1 Town Pump LLC (406) 497-6700 environmental@townpump.com
Trent Biggers, UST Class A Operator Trentb@townpump.com
Trent Biggers, UST Class A Operator Trentb@townpump.com
Trent Biggers, UST Class B Global Operator Trentb@townpump.com
Trent Biggers, UST Class B Global Operator Trentb@townpump.com

Tank Number	01	**Tank Age**	38	**Tank Installed Date**	02/23/1987	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	2597	**Spill Test Date**	04/23/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**	04/29/2021	**Tank/Piping CP Test Date**	07/26/2022	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	03/16/2023	**Line Tightness Test Date**	01/05/2010	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	04/30/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350				
Tank Number	02	**Tank Age**	38	**Tank Installed Date**	02/23/1987	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	2598	**Spill Test Date**	04/23/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**	04/29/2021	**Tank/Piping CP Test Date**	07/26/2022	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	03/16/2023	**Line Tightness Test Date**	01/05/2010	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	04/30/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350				

Tank Number	03	**Tank Age**	38	**Tank Installed Date**	02/23/1987	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	2599	**Spill Test Date**	04/23/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**	04/29/2021	**Tank/Piping CP Test Date**	07/26/2022	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	03/16/2023	**Line Tightness Test Date**	01/05/2010	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	04/30/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350				
Tank Number	05	**Tank Age**	38	**Tank Installed Date**	02/23/1987	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	2600	**Spill Test Date**	04/23/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**	04/29/2021	**Tank/Piping CP Test Date**	07/26/2022	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	03/16/2023	**Line Tightness Test Date**	01/05/2010	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	04/30/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350				
Tank Number	06	**Tank Age**	24	**Tank Installed Date**	06/01/2001	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve
Tag Number	4490	**Spill Test Date**	07/27/2022	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	04/29/2021	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	04/29/2021	**Tank/Piping CP Test Date**	01/06/2010	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	03/16/2023	**Line Tightness Test Date**	01/05/2010	**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	07/27/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350				
Tank Number	07	**Tank Age**	24	**Tank Installed Date**	06/01/2001	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve
Tag Number	4491	**Spill Test Date**	07/27/2022	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	04/29/2021	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible

Product	Diesel	**PLLD Test Date**	04/29/2021	**Tank/Piping CP Test Date**	01/06/2010	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	5000	**ATG Test Date**	03/16/2023	**Line Tightness Test Date**	01/05/2010	**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	07/27/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Ravalli County in the City of Hamilton

Location: TOWN PUMP INC HAMILTON 2
932 S 1st St
Hamilton, MT 59840-3018 Ravalli

System Facility ID:41-00145

Facility Code: 26830
Last Inspected On: 03/16/2023
Operating Permit Renewal Date: 10/19/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Hamilton 2 Town Pump LLC **(406) 497-6700** **environmental@townpump.com**

Operator Contact: Trent Biggers **Trentb@townpump.com**

Owner/Operator: Hamilton 2 Town Pump LLC (406) 497-6700 environmental@townpump.com

Trent Biggers, UST Class A Operator Trentb@townpump.com
Trent Biggers, UST Class A Operator Trentb@townpump.com
Trent Biggers, UST Class B Global Operator Trentb@townpump.com
Trent Biggers, UST Class B Global Operator Trentb@townpump.com

Tank Number	01	**Tank Age**	0	**Tank Installed Date**		**Tank Material Construction**	Bare Steel	**Piping Material**	Steel	**Overfill Types**	Flapper Valve
Tag Number	2593	**Spill Test Date**	07/27/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Single Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**	08/18/2023	**Tank/Piping CP Test Date**	07/28/2022	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	08/03/2023	**Line Tightness Test Date**	08/18/2023	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	10/20/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Number	02	**Tank Age**	41	**Tank Installed Date**	04/07/1984	**Tank Material Construction**	Bare Steel	**Piping Material**	Steel	**Overfill Types**	Flapper Valve
Tag Number	2594	**Spill Test Date**	11/20/2024	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Single Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**	08/18/2023	**Tank/Piping CP Test Date**	07/28/2022	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	08/18/2023	**Line Tightness Test Date**	08/18/2023	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No

		Overfill Test Date	10/20/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Number	03	**Tank Age**	41	**Tank Installed Date**	04/07/1984	**Tank Material Construction**	Bare Steel	**Piping Material**	Steel	**Overfill Types**	Flapper Valve
Tag Number	2595	**Spill Test Date**	07/27/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Single Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**	08/18/2023	**Tank/Piping CP Test Date**	07/28/2022	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**	08/03/2023	**Line Tightness Test Date**	08/18/2023	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	07/27/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Number	04	**Tank Age**	41	**Tank Installed Date**	04/07/1984	**Tank Material Construction**	Bare Steel	**Piping Material**	Steel	**Overfill Types**	Flapper Valve
Tag Number	2596	**Spill Test Date**	10/20/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Single Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	04/18/2023	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Diesel	**PLLD Test Date**	08/18/2023	**Tank/Piping CP Test Date**	07/28/2022	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**	08/03/2023	**Line Tightness Test Date**	08/18/2023	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	10/20/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				

Facility Summary in Ravalli County in the City of Stevensville

Location: CJS DEN
324 Main St
Stevensville, MT 59870-2530 Ravalli

System Facility ID:41-11429

Facility Code: 26992
Last Inspected On: 07/25/2024
Operating Permit Renewal Date: 07/25/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Cody Omlid **(406) 777-5605**

Operator Contact: Jon Vercruyssen **(406) 239-9335** **jonv.cjsden@gmail.com**

Owner/Operator: Cody Omlid (406) 777-5605

Jon Vercruyssen, UST Class A Operator jonv.cjsden@gmail.com

Jon Vercruyssen, UST Class B Operator jonv.cjsden@gmail.com

Tank Number	05	**Tank Age**	35	**Tank Installed Date**	10/28/1990	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	
Tag Number	2346	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Single Walled	**AST**	No
Status	**Temporarily Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**		**Piping Type**	U.S. Suction	**CP Met Types**	
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	07/25/2024	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.1;Vapor Monitoring	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	06	**Tank Age**	35	**Tank Installed Date**	10/28/1990	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	
Tag Number	2347	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Single Walled	**AST**	No
Status	**Temporarily Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**		**Piping Type**	U.S. Suction	**CP Met Types**	
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	07/25/2024	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.1;Vapor Monitoring	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					

Tank Number	07	**Tank Age**	35	**Tank Installed Date**	10/28/1990	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	
Tag Number	2348	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Single Walled	**AST**	No
Status	**Temporarily Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**		**Piping Type**	U.S. Suction	**CP Met Types**	
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	07/25/2024	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.1;Vapor Monitoring	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing;Vapor Monitoring	**Vapor Recovery**	No
Capacity	2000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					

Facility Summary in Ravalli County in the City of Stevensville

Location: EASTSIDE COUNTRY STORE AND DELI
2693 Eastside Hwy
Stevensville, MT 59870-6954 Ravalli

System Facility ID:41-10286

Facility Code: 26962
Last Inspected On: 01/01/2024
Operating Permit Renewal Date: 02/10/2028

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Eastside Country Store Inc

Operator Contact: Shane Cooke **maztech@aol.com**

Shane Cooke, UST Class A Operator maztech@aol.com
Shane Cooke, UST Class B Operator maztech@aol.com

Tank Number	S3	**Tank Age**	27	**Tank Installed Date**	12/01/1998	**Tank Material Construction**	Unknown	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	3614	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	Yes
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**	02/07/2022	**Catastrophic L.D. Type 3.0**	Continuous Interstitial Monitoring	**Piping Type**	U.S. Suction	**CP Met Types**	
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**	02/07/2022	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	S4	**Tank Age**	27	**Tank Installed Date**	12/01/1998	**Tank Material Construction**	Unknown	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	3615	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	Yes
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**	02/07/2022	**Catastrophic L.D. Type 3.0**	Continuous Interstitial Monitoring	**Piping Type**	U.S. Suction	**CP Met Types**	
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	3000	**ATG Test Date**	02/07/2022	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					

Tank Number	S5	**Tank Age**	27	**Tank Installed Date**	12/01/1998	**Tank Material Construction**	Unknown	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	3809	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	Yes
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**	02/07/2022	**Catastrophic L.D. Type 3.0**	Continuous Interstitial Monitoring	**Piping Type**	U.S. Suction	**CP Met Types**	
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	3000	**ATG Test Date**	02/07/2022	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					

Facility Summary in Ravalli County in the City of Stevensville

Location: MOUNTAIN WEST CO OP STEVENSVILLE
115 Main St
Stevensville, MT 59870-2110 Ravalli

System Facility ID:41-10330

Facility Code: 26965
Last Inspected On: 05/19/2023
Operating Permit Renewal Date: 06/20/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	CHS Inc Inver Grove Heights	**(651) 355-6343**	**Kirsten.Tindall@chsinc.com**
Operator Contact:	Bob Westin;Dusty Smith;John Thompson;Michael Gourley;CHS Inc Inver Grove Heights;Will Dukart	**(406) 370-3920;(651) 355-6343;(406) 665-1728;(406) 880-8169**	**chuck.thompson@chsinc.com;dusty.smith@chsinc.com;michael.gourley@chsinc.com;Kirsten.Tindall@chsinc.com;will.dukart@chsinc.com**

Owner/Operator:	CHS Inc Inver Grove Heights	(651) 355-6343	Kirsten.Tindall@chsinc.com
	Alicia Milner, UST Class B Operator		aliciahinton1982@icloud.com
	Alicia Milner, UST Class B Operator		aliciahinton1982@icloud.com
	Bob Westin, UST Class A Operator		
	Bob Westin, UST Class B Global Operator		
	Dusty Smith, UST Class A Operator		dusty.smith@chsinc.com
	Dusty Smith, UST Class B Global Operator		dusty.smith@chsinc.com
	John Thompson, UST Class A Operator		chuck.thompson@chsinc.com
	John Thompson, UST Class A Operator		chuck.thompson@chsinc.com
	John Thompson, UST Class B Global Operator		chuck.thompson@chsinc.com
	John Thompson, UST Class B Global Operator		chuck.thompson@chsinc.com
	John Thompson, UST Class B Operator		chuck.thompson@chsinc.com
	John Thompson, UST Class B Operator		chuck.thompson@chsinc.com
	Laura Tackes, UST Class B Operator		laura.tackes@chsinc.com
	Laura Tackes, UST Class B Operator		laura.tackes@chsinc.com
	Michael Gourley, UST Class A Operator		Kirsten.Tindall@chsinc.com
	Will Dukart, UST Class A Operator		will.dukart@chsinc.com
	Will Dukart, UST Class A Operator		will.dukart@chsinc.com
	Will Dukart, UST Class B Global Operator		will.dukart@chsinc.com
	Will Dukart, UST Class B Global Operator		will.dukart@chsinc.com

Tank Number	01	**Tank Age**	47	**Tank Installed Date**	02/14/1978	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	906	**Spill Test Date**	04/21/2023	**Piping Installed Date**	02/12/2007	**Tank Construction**	Lined Interior/Impressed Current	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current

Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	01/24/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	15000	**ATG Test Date**	01/23/2023	**Line Tightness Test Date**	02/23/2020	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	01/24/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	02	**Tank Age**	47	**Tank Installed Date**	02/14/1978	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	907	**Spill Test Date**	04/21/2023	**Piping Installed Date**	02/12/2007	**Tank Construction**	Lined Interior/Impressed Current	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	01/24/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	15000	**ATG Test Date**	01/24/2023	**Line Tightness Test Date**	02/24/2020	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	01/24/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	03	**Tank Age**	47	**Tank Installed Date**	02/14/1978	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	908	**Spill Test Date**	04/21/2023	**Piping Installed Date**	02/12/2007	**Tank Construction**	Lined Interior/Impressed Current	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	01/24/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	15000	**ATG Test Date**	01/24/2023	**Line Tightness Test Date**	01/23/2020	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	01/24/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	04	**Tank Age**	47	**Tank Installed Date**	02/14/1978	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	909	**Spill Test Date**	04/21/2023	**Piping Installed Date**	02/12/2007	**Tank Construction**	Lined Interior/Impressed Current	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	01/24/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No

Capacity	10000	**ATG Test Date**	01/24/2023	**Line Tightness Test Date**	02/24/2020	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	01/24/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	05	**Tank Age**	47	**Tank Installed Date**	02/14/1978	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	910	**Spill Test Date**	01/23/2023	**Piping Installed Date**	02/12/2007	**Tank Construction**	Lined Interior/Impressed Current	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	01/24/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	15000	**ATG Test Date**	01/24/2023	**Line Tightness Test Date**	02/24/2020	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	01/24/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	06	**Tank Age**	47	**Tank Installed Date**	02/14/1978	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	911	**Spill Test Date**	01/23/2023	**Piping Installed Date**	02/12/2007	**Tank Construction**	Lined Interior/Impressed Current	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	01/24/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	15000	**ATG Test Date**	01/24/2023	**Line Tightness Test Date**	01/22/2020	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	01/24/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	07	**Tank Age**	28	**Tank Installed Date**	12/29/1997	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	912	**Spill Test Date**	01/23/2023	**Piping Installed Date**	02/12/2007	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	02/07/2017	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	01/24/2023	**Line Tightness Test Date**	01/24/2020	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No

		Overfill Test Date	01/24/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Ravalli County in the City of Stevensville

Location: OLES 15 ROOSTERS CASINO
3912 US Hwy 93 N
Stevensville, MT 59870-6425 Ravalli

System Facility ID:41-13686

Facility Code: 27059
Last Inspected On: 09/19/2022
Operating Permit Renewal Date: 11/02/2025

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Ralls Inc **(406) 777-1179**

Operator Contact: Rob Ralls **(406) 240-0797** **stevioles@aol.com**

Owner/Operator: Ralls Inc (406) 777-1179

Rob Ralls, UST Class A Operator stevioles@aol.com

Rob Ralls, UST Class B Operator stevioles@aol.com

Tank Number	01	**Tank Age**	29	**Tank Installed Date**	05/01/1996	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	3316	**Spill Test Date**	08/16/2022	**Piping Installed Date**	11/04/2019	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	05/04/2022	**Sump Tightness Test Date**	09/19/2022	**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	05/04/2022	**Line Tightness Test Date**	06/28/2019	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	01/12/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-300				
Tank Number	02	**Tank Age**	29	**Tank Installed Date**	05/17/1996	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	3317	**Spill Test Date**	08/16/2022	**Piping Installed Date**	11/04/2019	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	05/04/2022	**Sump Tightness Test Date**	09/19/2022	**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	05/04/2022	**Line Tightness Test Date**	06/28/2019	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	01/12/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-300				
Tank Number	03	**Tank Age**	29	**Tank Installed Date**	05/17/1996	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm

Tag Number	3318	**Spill Test Date**	08/16/2022	**Piping Installed Date**	09/01/2016	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	05/04/2022	**Sump Tightness Test Date**	09/19/2022	**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	3000	**ATG Test Date**	05/04/2022	**Line Tightness Test Date**	06/28/2019	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	01/12/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-300				

Facility Summary in Ravalli County in the City of Stevensville

Location: THREE MILE MERCANTILE
899 Three Mile Creek Rd
Stevensville, MT 59870-6126 Ravalli

System Facility ID:41-00170

Facility Code: 26831
Last Inspected On: 12/23/2023
Operating Permit Renewal Date: 12/24/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	B Wayne Enterprise LLC	**(406) 396-4151**	**atotalbs@yahoo.com**
Operator Contact:	Bill Smith;Russell Cleveland	**(406) 396-4151;(406) 544-2650**	**atotalbs@yahoo.com;racleveland@hotmail.com**

Owner/Operator: B Wayne Enterprise LLC (406) 396-4151 atotalbs@yahoo.com

Bill Smith, UST Class A Operator	atotalbs@yahoo.com
Bill Smith, UST Class B Operator	atotalbs@yahoo.com
Russell Cleveland, UST Class A Operator	racleveland@hotmail.com
Russell Cleveland, UST Class B Global Operator	racleveland@hotmail.com
Russell Cleveland, UST Class B Operator	racleveland@hotmail.com

Tank Number	03	**Tank Age**	32	**Tank Installed Date**	03/01/1993	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Steel	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	2115	**Spill Test Date**	12/23/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	12/23/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	5000	**ATG Test Date**	08/17/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	12/23/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-300				
Tank Number	04	**Tank Age**	32	**Tank Installed Date**	03/01/1993	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Steel	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	2116	**Spill Test Date**	12/23/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	12/23/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	5000	**ATG Test Date**	08/17/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	12/23/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-300				

Tank Number	05	**Tank Age**	32	**Tank Installed Date**	03/01/1993	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Steel	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	2117	**Spill Test Date**	12/23/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	12/23/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	2000	**ATG Test Date**	08/17/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	12/23/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-300				

Facility Summary in Ravalli County in the City of Sula

Location: CAMP SULA
7060 US Hwy 93 S
Sula, MT 59871-9600 Ravalli

System Facility ID:41-10411

Facility Code: 26969
Last Inspected On: 10/17/2022
Operating Permit Renewal Date: 10/29/2025

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Camp Sula MT LLC	**(406) 821-3364**	**campsularesort@gmail.com**
Operator Contact:	Amie Wallace		**amiewallace@gmail.com**

Owner/Operator: Camp Sula MT LLC (406) 821-3364 campsularesort@gmail.com

Amie Wallace, UST Class A Operator amiewallace@gmail.com

Amie Wallace, UST Class B Global Operator amiewallace@gmail.com

Tank Number	03	**Tank Age**	27	**Tank Installed Date**	03/01/1998	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve;High Level Alarm
Tag Number	3485	**Spill Test Date**	03/14/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	10/17/2022	**Sump Tightness Test Date**	08/15/2016	**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	10/17/2022	**Line Tightness Test Date**	10/17/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	03/14/2023			**ATG Type**	Gilbarco/EMC Basic				
Tank Number	04	**Tank Age**	27	**Tank Installed Date**	03/01/1998	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve;High Level Alarm
Tag Number	3486	**Spill Test Date**	10/17/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	10/17/2022	**Sump Tightness Test Date**	08/15/2016	**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	5000	**ATG Test Date**	10/17/2022	**Line Tightness Test Date**	10/17/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	03/14/2023			**ATG Type**	Gilbarco/EMC Basic				
Tank Number	05	**Tank Age**	27	**Tank Installed Date**	03/01/1998	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve;High Level Alarm

Tag Number	3487	**Spill Test Date**	10/17/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	10/17/2022	**Sump Tightness Test Date**	08/15/2016	**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	10/17/2022	**Line Tightness Test Date**	10/17/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	03/14/2023			**ATG Type**	Gilbarco/EMC Basic				

Facility Summary in Ravalli County in the City of Sula

Location: LOST TRAIL SKI AREA
9485 US Hwy 93 S
Sula, MT 59871-9611 Ravalli

System Facility ID:41-11692

Facility Code: 27002
Last Inspected On: 09/21/2023
Operating Permit Renewal Date: 10/03/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Lost Trail Ski Area Inc **(406) 821-3742** **judy@losttrail.com**

Operator Contact: Judy Grasser;Scott Grasser **judy@losttrail.com;skilt@losttrail.com**

Owner/Operator: Lost Trail Ski Area Inc (406) 821-3742 judy@losttrail.com

Judy Grasser, UST Class A Operator judy@losttrail.com
Judy Grasser, UST Class B Operator judy@losttrail.com
Scott Grasser, UST Class A Operator skilt@losttrail.com
Scott Grasser, UST Class B Operator skilt@losttrail.com

Tank Number	01	**Tank Age**	35	**Tank Installed Date**	01/01/1990	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	No Piping	**Overfill Types**	Flapper Valve
Tag Number	2351	**Spill Test Date**	09/21/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Not Listed	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	09/21/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	09/21/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	09/21/2023			**ATG Type**	Veeder Root/TLS-300				
Tank Number	02	**Tank Age**	33	**Tank Installed Date**	10/01/1992	**Tank Material Construction**	Steel Clad	**Piping Material**	No Piping	**Overfill Types**	Flapper Valve
Tag Number	2352	**Spill Test Date**	09/21/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Not Listed	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	09/21/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	09/21/2023			**ATG Type**	Veeder Root/TLS-300				

Facility Summary in Ravalli County in the City of Victor

Location: BOWERS MARKET
2424 Meridian Rd
Victor, MT 59875 Ravalli

System Facility ID:00-32506

Facility Code: 32506
Last Inspected On: 02/02/2023
Operating Permit Renewal Date: 07/24/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Bowers Market 3 LLC;Bridget Joyner;Bowers Market 3 LLC	**(406) 642-3421;(406) 642-3421;(406) 642-3421**	**bjoyner@mcleodpartnersinc.com;sbelford@mcleodpartnersinc.com; sbelford@mcleodpartnersinc.com**
Operator Contact:	Eric Belford;Bowers Market 3 LLC;Shelby LaForge	**(406) 691-0267;(406) 642-3421**	**eric.t.belford@gmail.com;sbelford@mcleodpartnersinc.com;slaforge @mcleodpartnersinc.com**

Owner/Operator:	Bowers Market 3 LLC	(406) 642-3421	sbelford@mcleodpartnersinc.com
Owner/Operator:	Bridget Joyner,Bowers Market 3 LLC	(406) 642-3421	sbelford@mcleodpartnersinc.com
	Eric Belford, UST Class A Operator		sbelford@mcleodpartnersinc.com
	Eric Belford, UST Class B Operator		sbelford@mcleodpartnersinc.com
	Shelby LaForge, UST Class A Operator		slaforge@mcleodpartnersinc.com
	Shelby LaForge, UST Class B Operator		slaforge@mcleodpartnersinc.com

Tank Number	01	**Tank Age**	3	**Tank Installed Date**	11/13/2022	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	
Tag Number	6124	**Spill Test Date**	11/02/2022	**Piping Installed Date**	11/13/2022	**Tank Construction**		**Piping Construction**		**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	10/18/2022	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	Yes
Capacity	12000	**ATG Test Date**	10/25/2022	**Line Tightness Test Date**	11/09/2022	**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	10/25/2022			**ATG Type**					
Tank Number	02	**Tank Age**	3	**Tank Installed Date**	11/13/2022	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	
Tag Number	6125	**Spill Test Date**	11/02/2022	**Piping Installed Date**	11/13/2022	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	10/18/2022	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	Yes
Capacity	5000	**ATG Test Date**	10/25/2022	**Line Tightness Test Date**	11/09/2022	**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes

		Overfill Test Date	10/25/2022			**ATG Type**					
Tank Number	03	**Tank Age**	3	**Tank Installed Date**	11/13/2022	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	
Tag Number	6126	**Spill Test Date**	11/02/2022	**Piping Installed Date**	11/13/2022	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	10/18/2022	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	5000	**ATG Test Date**	10/25/2022	**Line Tightness Test Date**	11/09/2022	**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	10/25/2022			**ATG Type**					

Facility Summary in Ravalli County in the City of Victor

Location: TOWN PUMP OF WOODSIDE
915 US Hwy 93 N Suite 1
Victor, MT 59875 Ravalli

System Facility ID:60-15155

Facility Code: 30896
Last Inspected On: 12/13/2024
Operating Permit Renewal Date: 10/20/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Woodside 1 Town Pump LLC **(406) 497-6700** **environmental@townpump.com**

Operator Contact: Trent Biggers **Trentb@townpump.com**

Owner/Operator: Woodside 1 Town Pump LLC (406) 497-6700 environmental@townpump.com

Trent Biggers, UST Class A Operator Trentb@townpump.com

Trent Biggers, UST Class B Global Operator Trentb@townpump.com

Tank Number	01	**Tank Age**	15	**Tank Installed Date**	09/09/2010	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass	**Overfill Types**	Flapper Valve
Tag Number	5241	**Spill Test Date**	07/21/2022	**Piping Installed Date**	06/14/2010	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	07/21/2022	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	02/15/2023	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	Yes
Capacity	15000	**ATG Test Date**	02/15/2023	**Line Tightness Test Date**	09/16/2010	**Secondary Tank Leak Detection**	Statistical Inventory Reconciliation	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	Yes
		Overfill Test Date	07/21/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Number	02	**Tank Age**	15	**Tank Installed Date**	09/09/2010	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass	**Overfill Types**	Flapper Valve
Tag Number	5242	**Spill Test Date**	12/06/2022	**Piping Installed Date**	06/14/2010	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	07/21/2022	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	02/15/2023	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	Yes
Capacity	10000	**ATG Test Date**	02/15/2023	**Line Tightness Test Date**	09/16/2010	**Secondary Tank Leak Detection**	Statistical Inventory Reconciliation	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	Yes
		Overfill Test Date	12/06/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350				

Tank Number	03	**Tank Age**	15	**Tank Installed Date**	09/09/2010	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass	**Overfill Types**	Ball Float Valve
Tag Number	5243	**Spill Test Date**	07/21/2022	**Piping Installed Date**	06/14/2010	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	07/21/2022	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel, Dyed	**PLLD Test Date**	02/15/2023	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	5000	**ATG Test Date**	02/15/2023	**Line Tightness Test Date**	09/16/2010	**Secondary Tank Leak Detection**	Statistical Inventory Reconciliation	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	Yes
		Overfill Test Date	07/21/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350				
Tank Number	04	**Tank Age**	15	**Tank Installed Date**	09/09/2010	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass	**Overfill Types**	Ball Float Valve
Tag Number	5244	**Spill Test Date**	07/21/2022	**Piping Installed Date**	06/14/2010	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	07/21/2022	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	02/15/2023	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	02/15/2023	**Line Tightness Test Date**	09/16/2010	**Secondary Tank Leak Detection**	Statistical Inventory Reconciliation	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	Yes
		Overfill Test Date	07/21/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350				
Tank Number	05	**Tank Age**	15	**Tank Installed Date**	09/09/2010	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass	**Overfill Types**	Ball Float Valve
Tag Number	5245	**Spill Test Date**	07/21/2022	**Piping Installed Date**	06/14/2010	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	07/21/2022	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	02/15/2023	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	5000	**ATG Test Date**	02/15/2023	**Line Tightness Test Date**	09/16/2010	**Secondary Tank Leak Detection**	Statistical Inventory Reconciliation	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	Yes
		Overfill Test Date	07/21/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350				
Tank Number	06	**Tank Age**	2	**Tank Installed Date**	05/01/2023	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	
Tag Number	6155	**Spill Test Date**		**Piping Installed Date**	11/20/2023	**Tank Construction**		**Piping Construction**		**AST**	No

Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**		**Piping Type**	Pressurized	**CP Met Types**	
Product	DEF (Not Regulated)	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	07	**Tank Age**	2	**Tank Installed Date**	11/20/2023	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	6156	**Spill Test Date**	04/02/2024	**Piping Installed Date**	11/20/2023	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	04/02/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**	07/24/2024	**Line Tightness Test Date**	07/19/2024	**Secondary Tank Leak Detection**	Statistical Inventory Reconciliation	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	Yes
		Overfill Test Date	04/02/2024			**ATG Type**					
Tank Number	08	**Tank Age**	2	**Tank Installed Date**	11/20/2023	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	6157	**Spill Test Date**	04/02/2024	**Piping Installed Date**	11/20/2023	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	04/02/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Diesel, Dyed	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	15000	**ATG Test Date**	07/24/2024	**Line Tightness Test Date**	07/19/2024	**Secondary Tank Leak Detection**	Statistical Inventory Reconciliation	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	Yes
		Overfill Test Date	04/02/2024			**ATG Type**					
Tank Number	09	**Tank Age**	2	**Tank Installed Date**	11/20/2023	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	6158	**Spill Test Date**	04/02/2024	**Piping Installed Date**	11/20/2023	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	04/02/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No

Capacity	20000	**ATG Test Date**	07/24/2024	**Line Tightness Test Date**	07/19/2024	**Secondary Tank Leak Detection**	Statistical Inventory Reconciliation	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	Yes
		Overfill Test Date	04/02/2024			**ATG Type**					
Tank Number	10	**Tank Age**	2	**Tank Installed Date**	05/01/2023	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	6159	**Spill Test Date**	04/02/2024	**Piping Installed Date**	11/20/2023	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	04/02/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	Yes
Capacity	25000	**ATG Test Date**	07/24/2024	**Line Tightness Test Date**	07/19/2024	**Secondary Tank Leak Detection**	Statistical Inventory Reconciliation	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	Yes
		Overfill Test Date	04/02/2024			**ATG Type**					
Tank Number	11	**Tank Age**	2	**Tank Installed Date**	11/20/2023	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	6160	**Spill Test Date**	04/02/2024	**Piping Installed Date**	11/20/2023	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	04/02/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	Yes
Capacity	12000	**ATG Test Date**	07/24/2024	**Line Tightness Test Date**	07/19/2024	**Secondary Tank Leak Detection**	Statistical Inventory Reconciliation	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	Yes
		Overfill Test Date	04/02/2024			**ATG Type**					
Tank Number	12	**Tank Age**	2	**Tank Installed Date**	11/20/2023	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	6161	**Spill Test Date**	04/02/2024	**Piping Installed Date**	11/20/2023	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	04/02/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	Yes
Capacity	10000	**ATG Test Date**	07/24/2024	**Line Tightness Test Date**	07/19/2024	**Secondary Tank Leak Detection**	Statistical Inventory Reconciliation	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	Yes
		Overfill Test Date	04/02/2024			**ATG Type**					

Facility Summary in Ravalli County in the City of Victor

Location: VICTOR SINCLAIR
2381 US Hwy 93 N
Victor, MT 59875-9211 Ravalli

System Facility ID:41-13288

Facility Code: 27047
Last Inspected On: 04/04/2023
Operating Permit Renewal Date: 05/06/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: MONTANA GAS N SHOP LLC **(510) 714-5045** **TONY@MONTANAGNS.COM**

Operator Contact: Gurinderbir Muhar **(408) 660-9884** **gasnshop133@gmail.com**

Owner/Operator: MONTANA GAS N SHOP LLC (510) 714-5045 TONY@MONTANAGNS.COM

Gurinderbir Muhar, UST Class A Operator gasnshop133@gmail.com

Gurinderbir Muhar, UST Class B Operator gasnshop133@gmail.com

Tank Number	01	**Tank Age**	32	**Tank Installed Date**	11/01/1993	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve;High Level Alarm
Tag Number	3174	**Spill Test Date**	04/04/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	04/04/2023	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	04/04/2023	**Line Tightness Test Date**	04/04/2023	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	07/18/2023			**ATG Type**	Gilbarco/EMC Basic				
Tank Number	02	**Tank Age**	32	**Tank Installed Date**	11/01/1993	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve;High Level Alarm
Tag Number	3175	**Spill Test Date**	04/04/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	04/04/2023	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	04/04/2023	**Line Tightness Test Date**	04/04/2023	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	07/18/2023			**ATG Type**	Gilbarco/EMC Basic				
Tank Number	03	**Tank Age**	32	**Tank Installed Date**	11/01/1993	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve;High Level Alarm
Tag Number	3176	**Spill Test Date**	07/18/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No

Status	**Currently in Use**	**MLLD Test Date**	04/04/2023	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	04/04/2023	**Line Tightness Test Date**	04/04/2023	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	07/18/2023			**ATG Type**	Gilbarco/EMC Basic				
Tank Number	04	**Tank Age**	32	**Tank Installed Date**	11/01/1993	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve;High Level Alarm
Tag Number	3177	**Spill Test Date**	04/04/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	04/04/2023	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	04/04/2023	**Line Tightness Test Date**	04/04/2023	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	07/18/2023			**ATG Type**	Gilbarco/EMC Basic				

Facility Summary in Richland County in the City of Fairview

Location: BRAKE TIME 251717
516 S Ellery Ave
Fairview, MT 59221 Richland

System Facility ID:42-03914

Facility Code: 27193
Last Inspected On: 07/20/2022
Operating Permit Renewal Date: 10/04/2025

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	FAIRVIEW MT LLC	**(406) 747-5024**	**licensing@btcmstores.com**
Operator Contact:	Theodore Bezel;Mini Mart Inc dba Loaf 'N Jug Pueblo	**(513) 964-1568**	**eglegaldept@eg-america.com**

Owner/Operator: FAIRVIEW MT LLC (406) 747-5024 licensing@btcmstores.com

Theodore Bezel, UST Class A Operator eglegaldept@eg-america.com
Theodore Bezel, UST Class A Operator eglegaldept@eg-america.com
Theodore Bezel, UST Class B Global Operator
Theodore Bezel, UST Class B Global Operator
Theodore Bezel, UST Class B Operator
Theodore Bezel, UST Class B Operator

Tank Number	06	**Tank Age**	12	**Tank Installed Date**	03/01/2013	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	5410	**Spill Test Date**	09/26/2024	**Piping Installed Date**	03/01/2013	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	02/27/2025	**Sump Tightness Test Date**	09/26/2024	**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	07/20/2022	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	20000	**ATG Test Date**	07/20/2022	**Line Tightness Test Date**	02/27/2025	**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.1	**Secondary Pipe Leak Detection**		**Energy Act**	Yes
		Overfill Test Date	10/22/2020			**ATG Type**	Gilbarco-Veeder Root/TLS-350;Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	07	**Tank Age**	12	**Tank Installed Date**	03/01/2013	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	5411	**Spill Test Date**	09/26/2024	**Piping Installed Date**	03/01/2013	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	02/27/2025	**Sump Tightness Test Date**	02/27/2025	**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible

Product	Diesel	**PLLD Test Date**	07/20/2022	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	07/20/2022	**Line Tightness Test Date**	07/20/2022	**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.1	**Secondary Pipe Leak Detection**		**Energy Act**	Yes
		Overfill Test Date	10/22/2020			**ATG Type**	Gilbarco-Veeder Root/TLS-350;Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	08	**Tank Age**	12	**Tank Installed Date**	03/01/2013	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	5412	**Spill Test Date**	09/26/2024	**Piping Installed Date**	03/01/2013	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	02/27/2025	**Sump Tightness Test Date**	02/27/2025	**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	07/20/2022	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	07/20/2022	**Line Tightness Test Date**	07/20/2022	**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.1	**Secondary Pipe Leak Detection**		**Energy Act**	Yes
		Overfill Test Date	10/22/2020			**ATG Type**	Gilbarco-Veeder Root/TLS-350;Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Richland County in the City of Fairview

Location: HORIZON RESOURCES FAIRVIEW STORE
605 S Ellery Ave
Fairview, MT 59221 Richland

System Facility ID:42-03363

Facility Code: 27175
Last Inspected On: 04/12/2023
Operating Permit Renewal Date: 07/24/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Horizon Resources **kquinnel@horizonresources.coop**

Operator Contact: Darcie Yadon **dyadon@horizonresources.coop**

Owner/Operator: Horizon Resources kquinnel@horizonresources.coop

Darcie Yadon, UST Class A Operator dyadon@horizonresources.coop
Darcie Yadon, UST Class A Operator dyadon@horizonresources.coop
Darcie Yadon, UST Class B Operator dyadon@horizonresources.coop
Darcie Yadon, UST Class B Operator dyadon@horizonresources.coop

Tank Number	07	**Tank Age**	27	**Tank Installed Date**	12/01/1998	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	3722	**Spill Test Date**	12/14/2021	**Piping Installed Date**	01/24/2011	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	12/13/2021	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	11/09/2018	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	7800	**ATG Test Date**	11/22/2022	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date	04/12/2023			**ATG Type**	Veeder Root/TLS-450				
Tank Number	08	**Tank Age**	27	**Tank Installed Date**	12/01/1998	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	3723	**Spill Test Date**	12/14/2021	**Piping Installed Date**	01/24/2011	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	12/13/2021	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	11/09/2018	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	4200	**ATG Test Date**	11/22/2022	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date	04/12/2023			**ATG Type**	Veeder Root/TLS-450				

Tank Number	09	**Tank Age**	27	**Tank Installed Date**	12/01/1998	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	3724	**Spill Test Date**	12/14/2021	**Piping Installed Date**	01/24/2011	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	12/13/2021	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	11/09/2018	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	5500	**ATG Test Date**	11/22/2022	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date	04/12/2023			**ATG Type**	Veeder Root/TLS-450				
Tank Number	10	**Tank Age**	27	**Tank Installed Date**	12/01/1998	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	3725	**Spill Test Date**	12/14/2021	**Piping Installed Date**	01/24/2011	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	12/13/2021	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	11/09/2018	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	4500	**ATG Test Date**	11/22/2022	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date	04/12/2023			**ATG Type**	Veeder Root/TLS-450				
Tank Number	15	**Tank Age**	14	**Tank Installed Date**	01/02/2011	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	5274	**Spill Test Date**	12/14/2021	**Piping Installed Date**	01/24/2011	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	12/13/2021	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	11/22/2022	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	04/12/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-450;Veeder Root/TLS-450				
Tank Number	16	**Tank Age**	14	**Tank Installed Date**	01/02/2011	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	5275	**Spill Test Date**	12/14/2021	**Piping Installed Date**	01/24/2011	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	12/13/2021	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible

Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	11/22/2022	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	04/12/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-450;Veeder Root/TLS-450				

Facility Summary in Richland County in the City of Lambert

Location: NORTANA GRAIN CO
100 1st Ave SW
Lambert, MT 59243 Richland

System Facility ID:42-00317

Facility Code: 27067
Last Inspected On: 10/21/2024
Operating Permit Renewal Date: 03/04/2028

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Nortana Grain Co;Shane Keller	**(406) 443-2580;(406) 478-4122**	**kellershane@hotmail.com**
Operator Contact:	Mike Arneson;Shane Keller	**(406) 478-4122;(406) 489-3589**	**kellershane@hotmail.com;mikenortana@outlook.com**

Owner/Operator: Nortana Grain Co (406) 443-2580

Owner/Operator: Shane Keller (406) 443-2580

Mike Arneson, UST Class A Operator	mikenortana@outlook.com
Mike Arneson, UST Class A Operator	mikenortana@outlook.com
Mike Arneson, UST Class B Operator	mikenortana@outlook.com
Mike Arneson, UST Class B Operator	mikenortana@outlook.com
Shane Keller, UST Class A Operator	kellershane@hotmail.com
Shane Keller, UST Class A Operator	kellershane@hotmail.com
Shane Keller, UST Class B Operator	kellershane@hotmail.com
Shane Keller, UST Class B Operator	kellershane@hotmail.com

Tank Number	S5	**Tank Age**	16	**Tank Installed Date**	03/06/2009	**Tank Material Construction**	Concrete	**Piping Material**	Flexible Plastic	**Overfill Types**	
Tag Number	5201	**Spill Test Date**		**Piping Installed Date**	10/20/2008	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	Yes
Status	**Currently in Use**	**MLLD Test Date**	06/10/2024	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	21000	**ATG Test Date**		**Line Tightness Test Date**	06/10/2024	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	S6	**Tank Age**	16	**Tank Installed Date**	03/06/2009	**Tank Material Construction**	Concrete	**Piping Material**	Flexible Plastic	**Overfill Types**	
Tag Number	5202	**Spill Test Date**		**Piping Installed Date**	10/20/2008	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	Yes
Status	**Currently in Use**	**MLLD Test Date**	06/10/2024	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	

Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	21000	**ATG Test Date**		**Line Tightness Test Date**	06/10/2024	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	S7	**Tank Age**	16	**Tank Installed Date**	03/06/2009	**Tank Material Construction**	Concrete	**Piping Material**	Flexible Plastic	**Overfill Types**	
Tag Number	5203	**Spill Test Date**		**Piping Installed Date**	10/20/2008	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	Yes
Status	**Currently in Use**	**MLLD Test Date**	06/10/2024	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	13000	**ATG Test Date**		**Line Tightness Test Date**	06/10/2024	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	S8	**Tank Age**	16	**Tank Installed Date**	03/06/2009	**Tank Material Construction**	Concrete	**Piping Material**	Flexible Plastic	**Overfill Types**	
Tag Number	5204	**Spill Test Date**		**Piping Installed Date**	10/20/2008	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	Yes
Status	**Currently in Use**	**MLLD Test Date**	06/10/2024	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	15000	**ATG Test Date**		**Line Tightness Test Date**	06/10/2024	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	S9	**Tank Age**	16	**Tank Installed Date**	03/06/2009	**Tank Material Construction**	Concrete	**Piping Material**	Flexible Plastic	**Overfill Types**	
Tag Number	5205	**Spill Test Date**		**Piping Installed Date**	10/20/2008	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	Yes
Status	**Currently in Use**	**MLLD Test Date**	06/10/2024	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	21000	**ATG Test Date**		**Line Tightness Test Date**	06/10/2024	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date				**ATG Type**					

Facility Summary in Richland County in the City of Savage

Location: VALLEY FUEL SUPPLY
MT Hwy 16
Savage, MT 59262 Richland

System Facility ID:42-03815

Facility Code: 27187
Last Inspected On: 09/26/2023
Operating Permit Renewal Date: 03/14/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Gregory Cross **gcross@crosspetroleumservice.com**

Operator Contact: Gregory Cross;R J Serpe;Timothy Fife **gcross@crosspetroleumservice.com;rlsrp@yahoo.com**

Owner/Operator: Greg Cross gcross@crosspetroleumservice.com

Greg Cross, UST Class A Operator	gcross@crosspetroleumservice.com
R J Serpe, UST Class A Operator	rlsrp@yahoo.com
R J Serpe, UST Class B Global Operator	rlsrp@yahoo.com
Ron Serpe, UST Class B Global Operator	cross@midrivers.com
Timothy Fife, UST Class A Operator	

Tank Number	03	**Tank Age**	27	**Tank Installed Date**	08/25/1998	**Tank Material Construction**	Steel Clad	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	780	**Spill Test Date**	02/01/2023	**Piping Installed Date**	02/01/2023	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	02/01/2023	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	08/09/2022	**Tank/Piping CP Test Date**	11/18/2008	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	09/26/2023	**Line Tightness Test Date**	02/01/2023	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date	02/01/2023			**ATG Type**	Franklin Fueling Systems/EVO 600				
Tank Number	04	**Tank Age**	27	**Tank Installed Date**	08/01/1998	**Tank Material Construction**	Steel Clad	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	781	**Spill Test Date**	02/01/2023	**Piping Installed Date**	02/01/2023	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	02/01/2023	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	08/09/2022	**Tank/Piping CP Test Date**	11/18/2008	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	09/26/2023	**Line Tightness Test Date**	02/01/2023	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No

		Overfill Test Date	02/01/2023			**ATG Type**	Franklin Fueling Systems/EVO 600				
Tank Number	05	**Tank Age**	27	**Tank Installed Date**	08/01/1998	**Tank Material Construction**	Steel Clad	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	782	**Spill Test Date**	02/01/2023	**Piping Installed Date**	02/01/2023	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	02/01/2023	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	08/09/2022	**Tank/Piping CP Test Date**	11/18/2008	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	3000	**ATG Test Date**	09/26/2023	**Line Tightness Test Date**	02/01/2023	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date	02/01/2023			**ATG Type**	Franklin Fueling Systems/EVO 600				

Facility Summary in Richland County in the City of Sidney

Location: BRAKE TIME 251716
706 S Central Ave
Sidney, MT 59270-4939 Richland

System Facility ID:42-05084

Facility Code: 27233
Last Inspected On: 07/20/2022
Operating Permit Renewal Date: 10/04/2025

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	SIDNEY MT LLC	**(832) 539-8190**	**licensing@btcmstores.com**
Operator Contact:	Muhammad Akhtar	**(832) 539-8190**	**akhatarmuhammad65@gmail.com**

Owner/Operator: SIDNEY MT LLC (832) 539-8190 licensing@btcmstores.com

Muhammad Akhtar, UST Class A Operator akhatarmuhammad65@gmail.com
Natalee Crumley, UST Class B Operator
Natalee Crumley, UST Class B Operator

Tank Number	01	**Tank Age**	49	**Tank Installed Date**	04/24/1976	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	4586	**Spill Test Date**	09/25/2024	**Piping Installed Date**	12/22/2010	**Tank Construction**	Lined Interior/Impressed Current	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	09/25/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**	07/20/2022	**Tank/Piping CP Test Date**	10/21/2020	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	07/20/2022	**Line Tightness Test Date**	07/20/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date	10/21/2020			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	02	**Tank Age**	49	**Tank Installed Date**	04/24/1976	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	4587	**Spill Test Date**	09/25/2024	**Piping Installed Date**	12/22/2010	**Tank Construction**	Lined Interior/Impressed Current	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	09/25/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**	07/20/2022	**Tank/Piping CP Test Date**	10/21/2020	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	07/20/2022	**Line Tightness Test Date**	07/20/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No

		Overfill Test Date	10/21/2020			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	03	**Tank Age**	49	**Tank Installed Date**	04/24/1976	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	4588	**Spill Test Date**	09/25/2024	**Piping Installed Date**	12/22/2010	**Tank Construction**	Lined Interior/Impressed Current	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	09/25/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Diesel	**PLLD Test Date**	07/20/2022	**Tank/Piping CP Test Date**	10/21/2020	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	07/20/2022	**Line Tightness Test Date**	07/20/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date	10/21/2020			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Richland County in the City of Sidney

Location: LOWER YELLOWSTONE RURAL ELECTRIC ASSOCIATION INC
3200 W Holly St
Sidney, MT 59270 Richland

System Facility ID:42-00001

Facility Code: 27062
Last Inspected On: 06/11/2024
Operating Permit Renewal Date: 09/29/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Lower Yellowstone Rural Electric Association Inc **(406) 482-1602**

Operator Contact: Bodrey Kindopp;Justin King **(406) 488-1602** **bodreyk@lyrec.com;justink@lyrec.coop**

Owner/Operator: Lower Yellowstone Rural Electric Association Inc (406) 482-1602

Bodrey Kindopp, UST Class A Operator	bodreyk@lyrec.com
Justin King, UST Class A Operator	justink@lyrec.coop
Justin King, UST Class B Global Operator	justink@lyrec.coop
Mike Eberling, UST Class B Global Operator	arthur_mike@hotmail.com

Tank Number	05	**Tank Age**	32	**Tank Installed Date**	10/01/1993	**Tank Material Construction**	Steel Clad	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	1558	**Spill Test Date**	06/11/2024	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Manual Interstitial Monitoring	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	06/11/2024			**ATG Type**					
Tank Number	06	**Tank Age**	32	**Tank Installed Date**	10/01/1993	**Tank Material Construction**	Steel Clad	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	1559	**Spill Test Date**	06/11/2024	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Manual Interstitial Monitoring	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	06/11/2024			**ATG Type**					

Facility Summary in Richland County in the City of Sidney

Location: METZ FUEL and SERVICE
625 S Central Ave
Sidney, MT 59270-4936 Richland

System Facility ID:42-03224

Facility Code: 27172
Last Inspected On: 07/24/2024
Operating Permit Renewal Date: 10/01/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Metz Fuel Service Inc **metzfuel@gmail.com**

Operator Contact: Jim Metz **(406) 480-1872** **metzfuel@gmail.com**

Owner/Operator: Metz Fuel Service Inc metzfuel@gmail.com

Jim Metz, UST Class A Operator metzfuel@gmail.com
Jim Metz, UST Class A Operator metzfuel@gmail.com
Jim Metz, UST Class B Global Operator metzfuel@gmail.com
Jim Metz, UST Class B Global Operator metzfuel@gmail.com

Tank Number	10	**Tank Age**	34	**Tank Installed Date**	07/11/1991	**Tank Material Construction**	Steel Clad	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	2110	**Spill Test Date**	07/24/2024	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Manual Interstitial Monitoring	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	07/24/2024			**ATG Type**					
Tank Number	11	**Tank Age**	34	**Tank Installed Date**	07/11/1991	**Tank Material Construction**	Steel Clad	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	2111	**Spill Test Date**	07/26/2024	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Manual Interstitial Monitoring	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	07/26/2024			**ATG Type**					
Tank Number	12	**Tank Age**	34	**Tank Installed Date**	07/11/1991	**Tank Material Construction**	Steel Clad	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve

Tag Number	2112	**Spill Test Date**	07/24/2024	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	07/24/2024	**Sump Tightness Test Date**	07/24/2024	**Catastrophic L.D. Type 3.0**	Continuous Interstitial Monitoring;Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Manual Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**		**Line Tightness Test Date**	07/24/2024	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	07/24/2024			**ATG Type**					
Tank Number	13	**Tank Age**	34	**Tank Installed Date**	07/11/1991	**Tank Material Construction**	Steel Clad	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	2113	**Spill Test Date**	07/24/2024	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	07/24/2024	**Sump Tightness Test Date**	07/24/2024	**Catastrophic L.D. Type 3.0**	Continuous Interstitial Monitoring;Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Manual Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**		**Line Tightness Test Date**	07/24/2024	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	07/24/2024			**ATG Type**					

Facility Summary in Richland County in the City of Sidney

Location: MILLERS CORNER
2201 W Holly St
Sidney, MT 59270 Richland

System Facility ID:56-14071

Facility Code: 30723
Last Inspected On: 02/01/2023
Operating Permit Renewal Date: 04/22/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Millers Corner LLC	**(406) 433-4041**	**ohmg1975@gmail.com**
Operator Contact:	Gregory Miller;Nitin Patel	**(406) 433-4041**	**gregm@midrivers.com;millerscornersidney@gmail.com**

Owner/Operator: Millers Corner LLC (406) 433-4041 ohmg1975@gmail.com

Gregory Miller, UST Class A Operator gregm@midrivers.com
Gregory Miller, UST Class B Global Operator gregm@midrivers.com
Nitin Patel, UST Class A Operator millerscornersidney@gmail.com
Nitin Patel, UST Class B Operator millerscornersidney@gmail.com

Tank Number	01	**Tank Age**	22	**Tank Installed Date**	02/06/2003	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	4797	**Spill Test Date**	06/09/2021	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	10/24/2022	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	10/24/2022	**Line Tightness Test Date**	10/24/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	06/09/2021			**ATG Type**	Incon/TS-550				
Tank Number	02	**Tank Age**	22	**Tank Installed Date**	02/06/2003	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	4798	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	10/24/2022	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	10/24/2022	**Line Tightness Test Date**	10/24/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	06/09/2021			**ATG Type**	Incon/TS-550				

Tank Number	03	**Tank Age**	22	**Tank Installed Date**	02/06/2003	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	4799	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	10/24/2022	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	10/24/2022	**Line Tightness Test Date**	10/24/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	06/09/2021			**ATG Type**	Incon/TS-550				
Tank Number	04	**Tank Age**	13	**Tank Installed Date**	08/01/2012	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	5387	**Spill Test Date**	08/30/2021	**Piping Installed Date**	08/16/2012	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	06/09/2021	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	10/24/2022	**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	20000	**ATG Test Date**	10/24/2022	**Line Tightness Test Date**	10/24/2022	**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	06/09/2021			**ATG Type**	Incon/TS-550				

Facility Summary in Richland County in the City of Sidney

Location: SIDNEY CARDTROL
901 3rd St NE
Sidney, MT 59270 Richland

System Facility ID:42-02184

Facility Code: 27135
Last Inspected On: 07/20/2022
Operating Permit Renewal Date: 10/24/2025

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Cross Petroleum Services Glendive **cross@midrivers.com**

Operator Contact: Gregory Cross;Larry Garman;R J Serpe;Timothy Fife **(406) 482-4376** **gcross@crosspetroleumservice.com;rlsrp@yahoo.com**

Owner/Operator: Cross Petroleum Services Glendive cross@midrivers.com

Greg Cross, UST Class A Operator	gcross@crosspetroleumservice.com
Greg Cross, UST Class A Operator	gcross@crosspetroleumservice.com
Larry Garman, UST Class A Operator	
Larry Garman, UST Class A Operator	
Larry Garman, UST Class B Global Operator	
Larry Garman, UST Class B Global Operator	
R J Serpe, UST Class A Operator	rlsrp@yahoo.com
R J Serpe, UST Class A Operator	rlsrp@yahoo.com
R J Serpe, UST Class B Global Operator	rlsrp@yahoo.com
R J Serpe, UST Class B Global Operator	rlsrp@yahoo.com
Timothy Fife, UST Class A Operator	
Timothy Fife, UST Class A Operator	

Tank Number	01	**Tank Age**	43	**Tank Installed Date**	04/17/1982	**Tank Material Construction**	Bare Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	776	**Spill Test Date**	10/07/2021	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	10/13/2022	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	07/20/2022	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	07/20/2022	**Line Tightness Test Date**	10/13/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	10/07/2021			**ATG Type**	Incon/TS-1001				
Tank Number	02	**Tank Age**	43	**Tank Installed Date**	04/17/1982	**Tank Material Construction**	Bare Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	777	**Spill Test Date**	03/30/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No

Status	**Currently in Use**	**MLLD Test Date**	10/13/2022	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	07/20/2022	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	07/20/2022	**Line Tightness Test Date**	10/13/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	10/07/2021			**ATG Type**	Incon/TS-1001				
Tank Number	03	**Tank Age**	43	**Tank Installed Date**	04/17/1982	**Tank Material Construction**	Bare Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	778	**Spill Test Date**	10/07/2021	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	10/13/2022	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	07/20/2022	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	07/20/2022	**Line Tightness Test Date**	10/13/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	10/07/2021			**ATG Type**	Incon/TS-1001				
Tank Number	04	**Tank Age**	43	**Tank Installed Date**	04/17/1982	**Tank Material Construction**	Bare Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	779	**Spill Test Date**	10/07/2021	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	10/13/2022	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Diesel, Dyed	**PLLD Test Date**		**Tank/Piping CP Test Date**	07/20/2022	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	07/20/2022	**Line Tightness Test Date**	10/13/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	10/07/2021			**ATG Type**	Incon/TS-1001				

Facility Summary in Richland County in the City of Sidney

Location: SIDNEY HEALTH CENTER
216 14th Ave SW
Sidney, MT 59270-3519 Richland

System Facility ID:42-06159

Facility Code: 27255
Last Inspected On: 08/22/2024
Operating Permit Renewal Date: 09/14/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Sidney Health Center Inc **(406) 482-2120**

Operator Contact: Mark Delaney **mdelaney@sidneyhealth.org**

Owner/Operator: Sidney Health Center Inc (406) 482-2120

Mark Delaney, UST Class A Operator mdelaney@sidneyhealth.org

Mark Delaney, UST Class B Operator mdelaney@sidneyhealth.org

Tank Number	02	**Tank Age**	28	**Tank Installed Date**	09/01/1997	**Tank Material Construction**	Steel Clad	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	700	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	04/13/2021	**Catastrophic L.D. Type 3.0**	Continuous Interstitial Monitoring	**Piping Type**	U.S. Suction	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	04/19/2012	**Primary Tank Leak Detection**	Manual Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**		**Line Tightness Test Date**	03/18/2009	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					

Facility Summary in Richland County in the City of Sidney

Location: SIDNEY RICHLAND AIRPORT AUTHORITY
355 Airport Rd
Sidney, MT 59270-0355 Richland

System Facility ID:42-04444

Facility Code: 27214
Last Inspected On: 01/27/2025
Operating Permit Renewal Date: 01/27/2028

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: SIDNEY RICHLAND AIRPORT **(406) 480-1820**

Operator Contact: Ryan Huotari **(406) 433-2415** **sdyapt@midrivers.com**

Owner/Operator: SIDNEY RICHLAND AIRPORT (406) 480-1820

Ryan Huotari, UST Class A Operator sdyapt@midrivers.com

Ryan Huotari, UST Class B Operator sdyapt@midrivers.com

Tank Number	03	**Tank Age**	26	**Tank Installed Date**	04/01/1999	**Tank Material Construction**	Steel Clad	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	3969	**Spill Test Date**	12/14/2021	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Single Walled	**AST**	No
Status	**Temporarily Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	U.S. Suction	**CP Met Types**	Non-corrodible
Product	Aviation Gas	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Manual Interstitial Monitoring	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	12/14/2021			**ATG Type**					

Facility Summary in Richland County in the City of Sidney

Location: SUPERPUMPER 23
902 S Central Ave
Sidney, MT 59270-5216 Richland

System Facility ID:42-09718

Facility Code: 27348
Last Inspected On: 08/22/2024
Operating Permit Renewal Date: 12/26/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Parkland USA Corporation	**(701) 852-1194**	**Jake.thomas@parklandusa.com**
Operator Contact:	Vern Patterson;Parkland USA Corporation	**(701) 720-6649;(701) 852-1194**	**vern.patterson@parklandusa.com;Jake.thomas@parklandusa.com**

Owner/Operator: Parkland USA Corporation (701) 852-1194 Jake.thomas@parklandusa.com

Curtis McBride, UST Class B Operator Jake.thomas@parklandusa.com
Vern Patterson, UST Class A Operator Jake.thomas@parklandusa.com
Vern Patterson, UST Class B Operator Jake.thomas@parklandusa.com

Tank Number	06	**Tank Age**	10	**Tank Installed Date**	11/16/2015	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Positive Shutoff
Tag Number	5595	**Spill Test Date**	08/20/2023	**Piping Installed Date**	11/16/2015	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	07/09/2019	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	20000	**ATG Test Date**	08/22/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	08/20/2023			**ATG Type**	Incon/TS-550 EVO				
Tank Number	07	**Tank Age**	10	**Tank Installed Date**	11/16/2015	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Positive Shutoff
Tag Number	5596	**Spill Test Date**	08/20/2023	**Piping Installed Date**	11/16/2015	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	08/20/2023	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	08/22/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	08/20/2023			**ATG Type**	Incon/TS-550 EVO				

Tank Number	08	**Tank Age**	10	**Tank Installed Date**	11/16/2015	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Positive Shutoff
Tag Number	5597	**Spill Test Date**	08/20/2023	**Piping Installed Date**	11/16/2015	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	08/20/2023	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	08/22/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	08/20/2023			**ATG Type**	Incon/TS-550 EVO				

Facility Summary in Richland County in the City of Sidney

Location: SWELEY OIL INC BULK PLANT
1123 10th Ave SE
Sidney, MT 59270-6393 Richland

System Facility ID:42-00183

Facility Code: 27064
Last Inspected On: 10/22/2024
Operating Permit Renewal Date: 02/18/2028

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Nortana Grain Co **(406) 443-2580**

Operator Contact: John Sweley;Mike Arneson **(406) 482-2508;(406) 489-3589** **ksweley@midrivers.com;mikenortana@outlook.com**

Owner/Operator: Nortana Grain Co (406) 443-2580

John Sweley, UST Class A Operator	ksweley@midrivers.com
John Sweley, UST Class A Operator	ksweley@midrivers.com
John Sweley, UST Class B Operator	ksweley@midrivers.com
John Sweley, UST Class B Operator	ksweley@midrivers.com
Mike Arneson, UST Class A Operator	mikenortana@outlook.com
Mike Arneson, UST Class A Operator	mikenortana@outlook.com
Mike Arneson, UST Class B Operator	mikenortana@outlook.com
Mike Arneson, UST Class B Operator	mikenortana@outlook.com

Tank Number	S4	**Tank Age**	27	**Tank Installed Date**	06/16/1998	**Tank Material Construction**	Bare Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	
Tag Number	2076	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	Yes
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	10/22/2024	**Catastrophic L.D. Type 3.0**	Auto Dialer	**Piping Type**	Pressurized	**CP Met Types**	
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	17000	**ATG Test Date**	10/22/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	S5	**Tank Age**	27	**Tank Installed Date**	06/16/1998	**Tank Material Construction**	Bare Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	
Tag Number	2077	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	Yes
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	10/22/2024	**Catastrophic L.D. Type 3.0**	Auto Dialer	**Piping Type**	Pressurized	**CP Met Types**	

Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	17000	**ATG Test Date**	10/22/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					

Facility Summary in Richland County in the City of Sidney

Location: TOWN PUMP OF SIDNEY #3
12280 Hwy 200 Unit 1
Sidney, MT 59270 Richland

System Facility ID:60-15241

Facility Code: 30958
Last Inspected On: 09/17/2024
Operating Permit Renewal Date: 07/21/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Sidney 3 Town Pump LLC **(406) 497-6700** **environmental@townpump.com**

Operator Contact: Trent Biggers **Trentb@townpump.com**

Owner/Operator: Sidney 3 Town Pump LLC (406) 497-6700 environmental@townpump.com

Brian Volbrecht, UST Class B Global Operator bv2_bv2@yahoo.com
Trent Biggers, UST Class A Operator Trentb@townpump.com
Trent Biggers, UST Class B Global Operator Trentb@townpump.com

Tank Number	01	**Tank Age**	11	**Tank Installed Date**	03/01/2014	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	5471	**Spill Test Date**	10/01/2024	**Piping Installed Date**	03/24/2014	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	08/11/2020	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	08/09/2022	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	30000	**ATG Test Date**	06/14/2024	**Line Tightness Test Date**	06/14/2024	**Secondary Tank Leak Detection**	Statistical Inventory Reconciliation	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	Yes
		Overfill Test Date	10/01/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Number	02	**Tank Age**	11	**Tank Installed Date**	03/01/2014	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	5472	**Spill Test Date**	10/01/2024	**Piping Installed Date**	03/24/2014	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	08/11/2020	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	08/09/2022	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	30000	**ATG Test Date**	06/14/2024	**Line Tightness Test Date**	06/14/2024	**Secondary Tank Leak Detection**	Statistical Inventory Reconciliation	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	Yes

		Overfill Test Date	10/01/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Number	03	**Tank Age**	11	**Tank Installed Date**	03/01/2014	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve;Flapper Valve
Tag Number	5473	**Spill Test Date**	10/01/2024	**Piping Installed Date**	03/24/2014	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	08/11/2020	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	08/09/2022	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	30000	**ATG Test Date**	06/14/2024	**Line Tightness Test Date**	06/14/2024	**Secondary Tank Leak Detection**	Statistical Inventory Reconciliation	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	Yes
		Overfill Test Date	10/01/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Number	04	**Tank Age**	11	**Tank Installed Date**	03/01/2014	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	5474	**Spill Test Date**	10/01/2024	**Piping Installed Date**	03/24/2014	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	08/11/2020	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	08/09/2022	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	Yes
Capacity	30000	**ATG Test Date**	06/14/2024	**Line Tightness Test Date**	06/14/2024	**Secondary Tank Leak Detection**	Statistical Inventory Reconciliation	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	Yes
		Overfill Test Date	10/01/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Number	05	**Tank Age**	11	**Tank Installed Date**	03/01/2014	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve;Flapper Valve
Tag Number	5475	**Spill Test Date**	10/01/2024	**Piping Installed Date**	03/24/2014	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	08/11/2020	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	08/09/2022	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	Yes
Capacity	20000	**ATG Test Date**	06/14/2024	**Line Tightness Test Date**	06/14/2024	**Secondary Tank Leak Detection**	Statistical Inventory Reconciliation	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	Yes
		Overfill Test Date	10/01/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				

Tank Number	06	**Tank Age**	11	**Tank Installed Date**	03/01/2014	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve;Flapper Valve
Tag Number	5476	**Spill Test Date**	10/01/2024	**Piping Installed Date**	03/24/2014	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	08/11/2020	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	08/09/2022	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	06/14/2024	**Line Tightness Test Date**	06/14/2024	**Secondary Tank Leak Detection**	Statistical Inventory Reconciliation	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	Yes
		Overfill Test Date	10/01/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Number	07	**Tank Age**	11	**Tank Installed Date**	03/01/2014	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve;Flapper Valve
Tag Number	5477	**Spill Test Date**	10/01/2024	**Piping Installed Date**	03/24/2014	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	08/11/2020	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	08/09/2022	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	20000	**ATG Test Date**	06/14/2024	**Line Tightness Test Date**	06/14/2024	**Secondary Tank Leak Detection**	Statistical Inventory Reconciliation	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	Yes
		Overfill Test Date	10/01/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Number	08	**Tank Age**	11	**Tank Installed Date**	03/01/2014	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve
Tag Number	5478	**Spill Test Date**		**Piping Installed Date**	03/24/2014	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Other**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**		**Piping Type**	Pressurized	**CP Met Types**	
Product	DEF (Not Regulated)	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring;Not Listed	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Not Listed	**Energy Act**	No
		Overfill Test Date				**ATG Type**					

Facility Summary in Richland County in the City of Sidney

Location: WESTERN CHOICE COOPERATIVE SIDNEY
2920 West Holly Street (Highway 16)
Sidney, MT 59270-5221 Richland

System Facility ID:42-03364

Facility Code: 27176
Last Inspected On: 10/22/2024
Operating Permit Renewal Date: 02/11/2028

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Western Choice Cooperative	**(701) 764-6791**	**jreese@killdeercoop.com**
Operator Contact:	Jade Ziman;Western Choice Cooperative;Serena Ewer;Western Choice Cooperative	**(701) 590-0693;(701) 764-6791;(701) 764-6791**	**jziman@killdeercoop.com;jreese@killdeercoop.com;serewer@killdeercoop.com;jreese@killdeercoop.com**

Owner/Operator: Western Choice Cooperative (701) 764-6791 jreese@killdeercoop.com

Jade Ziman, UST Class A Operator jreese@killdeercoop.com
Jade Ziman, UST Class B Operator jreese@killdeercoop.com
Serena Ewer, UST Class A Operator jreese@killdeercoop.com
Serena Ewer, UST Class B Operator jreese@killdeercoop.com

Tank Number	05	**Tank Age**	44	**Tank Installed Date**	06/25/1981	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	4046	**Spill Test Date**	10/22/2024	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**	11/21/2023	**Tank/Piping CP Test Date**	11/23/2021	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	11/21/2023	**Line Tightness Test Date**	04/08/2021	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	10/22/2024			**ATG Type**	Veeder Root/TLS-450				
Tank Number	01	**Tank Age**	44	**Tank Installed Date**	06/25/1981	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	602	**Spill Test Date**	10/22/2024	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**	11/21/2023	**Tank/Piping CP Test Date**	11/23/2021	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	20000	**ATG Test Date**	11/21/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	10/22/2024			**ATG Type**	Veeder Root/TLS-450PLUS				

Tank Number	02	**Tank Age**	44	**Tank Installed Date**	06/25/1981	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	603	**Spill Test Date**	10/22/2024	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**	11/21/2023	**Tank/Piping CP Test Date**	11/23/2021	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	20000	**ATG Test Date**	11/21/2023	**Line Tightness Test Date**	04/08/2021	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	10/22/2024			**ATG Type**	Veeder Root/TLS-450				
Tank Number	03	**Tank Age**	44	**Tank Installed Date**	06/25/1981	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	604	**Spill Test Date**	12/15/2021	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**	11/23/2021	**Tank/Piping CP Test Date**	11/23/2021	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	20000	**ATG Test Date**	11/23/2021	**Line Tightness Test Date**	04/08/2021	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	06/14/2022			**ATG Type**	Veeder Root/TLS-450				
Tank Number	04	**Tank Age**	44	**Tank Installed Date**	06/25/1981	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	605	**Spill Test Date**	10/22/2024	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**	11/21/2023	**Tank/Piping CP Test Date**	11/23/2021	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	15000	**ATG Test Date**	11/21/2023	**Line Tightness Test Date**	04/08/2021	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	10/22/2024			**ATG Type**	Veeder Root/TLS-450				

Facility Summary in Roosevelt County in the City of Bainville

Location: THE WELCOME STOP
209 N Clinton St
Bainville, MT 59212 Roosevelt

System Facility ID:43-13761

Facility Code: 27568
Last Inspected On: 03/24/2022
Operating Permit Renewal Date: 07/27/2025

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Welcome Stop Retail LLC Scottsdale	**(480) 717-1776**	**john@gilligansretail.com**
Operator Contact:	John Gilligan;Melissa Bonebrake		**thewelcomestop@nemontel.net;welcomestopjohn@hotmail.com**

Owner/Operator:	Welcome Stop Retail LLC Scottsdale	(480) 717-1776	john@gilligansretail.com
	John Gilligan, UST Class A Operator		welcomestopjohn@hotmail.com
	John Gilligan, UST Class A Operator		welcomestopjohn@hotmail.com
	John Gilligan, UST Class B Global Operator		welcomestopjohn@hotmail.com
	John Gilligan, UST Class B Global Operator		welcomestopjohn@hotmail.com
	John Gilligan, UST Class B Operator		welcomestopjohn@hotmail.com
	John Gilligan, UST Class B Operator		welcomestopjohn@hotmail.com
	Melissa Bonebrake, UST Class A Operator		thewelcomestop@nemontel.net
	Melissa Bonebrake, UST Class A Operator		thewelcomestop@nemontel.net
	Melissa Bonebrake, UST Class B Operator		thewelcomestop@nemontel.net
	Melissa Bonebrake, UST Class B Operator		thewelcomestop@nemontel.net
	Rachelle Ryder, UST Class B Operator		thewelcomstop@hotmail.com
	Rachelle Ryder, UST Class B Operator		thewelcomstop@hotmail.com

Tank Number	S3	**Tank Age**	28	**Tank Installed Date**	12/01/1997	**Tank Material Construction**	Unknown	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	
Tag Number	3387	**Spill Test Date**		**Piping Installed Date**	09/07/2011	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	Yes
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	07/23/2020	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	S4	**Tank Age**	28	**Tank Installed Date**	12/01/1997	**Tank Material Construction**	Unknown	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	

Tag Number	3388	**Spill Test Date**		**Piping Installed Date**	09/07/2011	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	Yes
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	07/23/2020	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date				**ATG Type**					

Facility Summary in Roosevelt County in the City of Brockton

Location: B AND S QUICK STOP
US HIGHWAY 2 AND 7TH STREET
Brockton, MT 59213 Roosevelt

System Facility ID:43-02099

Facility Code: 27417
Last Inspected On: 01/03/2024
Operating Permit Renewal Date: 03/13/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Milo Stangeland;Stacy Stangeland **(406) 786-3229**

Operator Contact: Ian Drum **(406) 786-7483** **lilahsate@gmail.com**

Owner/Operator: Milo Stangeland

Owner/Operator: Stacy Stangeland

Ian Drum, UST Class A Operator lilahsate@gmail.com

Ian Drum, UST Class B Operator lilahsate@gmail.com

Tank Number	06	**Tank Age**	30	**Tank Installed Date**	06/12/1995	**Tank Material Construction**	Steel Clad	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	1828	**Spill Test Date**	04/07/2021	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Manual Interstitial Monitoring	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	7000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	04/07/2021			**ATG Type**					
Tank Number	07	**Tank Age**	30	**Tank Installed Date**	06/12/1995	**Tank Material Construction**	Steel Clad	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	1829	**Spill Test Date**	04/07/2021	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Manual Interstitial Monitoring	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	5000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	04/07/2021			**ATG Type**					

Facility Summary in Roosevelt County in the City of Brockton

Location: CENEX HARVEST STATES BROCKTON ELEVATOR
600 S Tracks Rd
Brockton, MT 59213-0000 Roosevelt

System Facility ID:43-13651

Facility Code: 27567
Last Inspected On: 06/11/2024
Operating Permit Renewal Date: 10/02/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	CHS Brockton	**(406) 786-3221**	**dave.corbin@chsinc.com**
Operator Contact:	David Corbin;Ron Shanks;Shari Cameron	**(406) 433-1401**	**dave.corbin@chsinc.com;ron.shanks@chsinc.com;shari.cameron@chsinc.com**

Owner/Operator: CHS Brockton (406) 786-3221 dave.corbin@chsinc.com

David Corbin, UST Class A Operator	dave.corbin@chsinc.com
David Corbin, UST Class B Operator	dave.corbin@chsinc.com
Ron Shanks, UST Class A Operator	ron.shanks@chsinc.com
Ron Shanks, UST Class A Operator	ron.shanks@chsinc.com
Ron Shanks, UST Class B Operator	ron.shanks@chsinc.com
Ron Shanks, UST Class B Operator	ron.shanks@chsinc.com
Shari Cameron, UST Class A Operator	shari.cameron@chsinc.com
Shari Cameron, UST Class A Operator	shari.cameron@chsinc.com
Shari Cameron, UST Class B Operator	shari.cameron@chsinc.com
Shari Cameron, UST Class B Operator	shari.cameron@chsinc.com

Tank Number	01	**Tank Age**	42	**Tank Installed Date**	01/01/1983	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	No Piping	**Overfill Types**	Flapper Valve
Tag Number	4317	**Spill Test Date**	06/11/2024	**Piping Installed Date**	08/13/2013	**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	10/09/2012	**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Not Listed	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	06/11/2024	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	20000	**ATG Test Date**	06/11/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	07/02/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	02	**Tank Age**	42	**Tank Installed Date**	01/01/1983	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	No Piping	**Overfill Types**	Flapper Valve
Tag Number	4318	**Spill Test Date**	06/11/2024	**Piping Installed Date**	08/13/2013	**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	10/09/2012	**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Not Listed	**CP Met Types**	Galvanic

Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	06/11/2024	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	06/11/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	06/11/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	03	**Tank Age**	26	**Tank Installed Date**	08/01/1999	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	4319	**Spill Test Date**	06/11/2024	**Piping Installed Date**	08/13/2013	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	10/09/2012	**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	06/11/2024	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	20000	**ATG Test Date**	06/11/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	07/02/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	04	**Tank Age**	26	**Tank Installed Date**	08/01/1999	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	4320	**Spill Test Date**	06/11/2024	**Piping Installed Date**	08/13/2013	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	10/09/2012	**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	06/11/2024	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	06/11/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	07/02/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Roosevelt County in the City of Culbertson

Location: MILLER OIL
2006 US Hwy 2
Culbertson, MT 59218 Roosevelt

System Facility ID:60-15191

Facility Code: 30916
Last Inspected On: 04/16/2024
Operating Permit Renewal Date: 07/18/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Gordon Miller

Operator Contact: Kevin Miller;Matthew Miller **(406) 765-7730** **kevinmiller28@hotmail.com;mwmiller@nemont.net**

Owner/Operator: Gordon Miller

Kevin Miller, UST Class A Operator	kevinmiller28@hotmail.com
Kevin Miller, UST Class B Operator	kevinmiller28@hotmail.com
Matthew Miller, UST Class A Operator	mwmiller@nemont.net
Matthew Miller, UST Class B Global Operator	mwmiller@nemont.net

Tank Number	S1	**Tank Age**	14	**Tank Installed Date**	09/01/2011	**Tank Material Construction**	Unknown	**Piping Material**	Fiberglass	**Overfill Types**	
Tag Number	5345	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	Yes
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	04/16/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Diesel	**PLLD Test Date**	10/10/2023	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	15000	**ATG Test Date**		**Line Tightness Test Date**	09/25/2020	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	Yes
		Overfill Test Date				**ATG Type**					
Tank Number	S2	**Tank Age**	14	**Tank Installed Date**	09/01/2011	**Tank Material Construction**	Unknown	**Piping Material**	Fiberglass	**Overfill Types**	
Tag Number	5346	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	Yes
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	04/16/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Diesel	**PLLD Test Date**	10/10/2023	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	15000	**ATG Test Date**		**Line Tightness Test Date**	09/20/2020	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	Yes
		Overfill Test Date				**ATG Type**					

Facility Summary in Roosevelt County in the City of Culbertson

Location: MISSOURI RIVER LOGISTICS
515 6th St E
Culbertson, MT 59218-9301 Roosevelt

System Facility ID:43-03015

Facility Code: 27434
Last Inspected On: 11/03/2022
Operating Permit Renewal Date: 11/03/2025

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Missouri River Logistics Frederick

Operator Contact:

Owner/Operator: Missouri River Logistics Frederick

Tank Number	01	**Tank Age**	47	**Tank Installed Date**	05/05/1978	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Steel	**Overfill Types**	Flapper Valve
Tag Number	3732	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**	Lined Interior/Impressed Current	**Piping Construction**	None	**AST**	No
Status	**Temporarily Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	11/03/2022	**Primary Tank Leak Detection**	Not Listed	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	02	**Tank Age**	47	**Tank Installed Date**	05/05/1978	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Steel	**Overfill Types**	Flapper Valve
Tag Number	3733	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**	Lined Interior/Impressed Current	**Piping Construction**	None	**AST**	No
Status	**Temporarily Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	11/03/2022	**Primary Tank Leak Detection**	Not Listed	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	03	**Tank Age**	47	**Tank Installed Date**	05/05/1978	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Steel	**Overfill Types**	Flapper Valve

Tag Number	3734	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**	Lined Interior/Impressed Current	**Piping Construction**	None	**AST**	No
Status	**Temporarily Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Impressed Current
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	11/03/2022	**Primary Tank Leak Detection**	Not Listed	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	04	**Tank Age**	47	**Tank Installed Date**	05/05/1978	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Steel	**Overfill Types**	Flapper Valve
Tag Number	3735	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**	Lined Interior/Impressed Current	**Piping Construction**	None	**AST**	No
Status	**Temporarily Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Impressed Current
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	11/03/2022	**Primary Tank Leak Detection**	Not Listed	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					

Facility Summary in Roosevelt County in the City of Culbertson

Location: OELKERS SERVICE CENTER
4 6th St E
Culbertson, MT 59218-0272 Roosevelt

System Facility ID:43-00030

Facility Code: 27384
Last Inspected On: 06/13/2023
Operating Permit Renewal Date: 10/18/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Oelkers Inc

Operator Contact: Ronald K Oelkers **(406) 787-5315** **2oelkers@nemont.net**

Owner/Operator: Oelkers Inc

Gordon Oelkers, UST Class B Operator	gordon@nemont.net
Gordon Oelkers, UST Class B Operator	gordon@nemont.net
Ronald K Oelkers, UST Class A Operator	2oelkers@nemont.net
Ronald K Oelkers, UST Class A Operator	2oelkers@nemont.net
Ronald K Oelkers, UST Class B Operator	2oelkers@nemont.net
Ronald K Oelkers, UST Class B Operator	2oelkers@nemont.net

Tank Number	01	**Tank Age**	72	**Tank Installed Date**	01/10/1953	**Tank Material Construction**	Bare Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	1774	**Spill Test Date**	06/13/2023	**Piping Installed Date**	05/21/2015	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	07/25/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	3000	**ATG Test Date**	06/13/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	06/13/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	02	**Tank Age**	72	**Tank Installed Date**	01/10/1953	**Tank Material Construction**	Bare Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	1775	**Spill Test Date**	06/13/2023	**Piping Installed Date**	05/21/2015	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Impressed Current
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	07/25/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	3000	**ATG Test Date**	06/13/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No

		Overfill Test Date	06/13/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	03	**Tank Age**	72	**Tank Installed Date**	01/10/1953	**Tank Material Construction**	Bare Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	1776	**Spill Test Date**	06/13/2023	**Piping Installed Date**	05/21/2015	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Impressed Current
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	07/25/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	3000	**ATG Test Date**	06/13/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	06/13/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	04	**Tank Age**	72	**Tank Installed Date**	01/10/1953	**Tank Material Construction**	Bare Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	1777	**Spill Test Date**	06/13/2023	**Piping Installed Date**	05/21/2015	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	07/25/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**	06/13/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	06/13/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Roosevelt County in the City of Culbertson

Location: TRIPLE M SINCLAIR
3 6th St W
Culbertson, MT 59218 Roosevelt

System Facility ID:43-07758

Facility Code: 27512
Last Inspected On: 03/11/2025
Operating Permit Renewal Date: 05/12/2028

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Miller Oil Co Inc Culbertson

Operator Contact: Kevin Miller;Matthew Miller **(406) 765-7730** **kevinmiller28@hotmail.com;mwmiller@nemont.net**

Owner/Operator: Miller Oil Co Inc Culbertson

Kevin Miller, UST Class A Operator	kevinmiller28@hotmail.com
Kevin Miller, UST Class B Operator	kevinmiller28@hotmail.com
Matthew Miller, UST Class A Operator	mwmiller@nemont.net

Tank Number	01	**Tank Age**	40	**Tank Installed Date**	07/01/1985	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	3635	**Spill Test Date**	10/22/2024	**Piping Installed Date**	04/06/2015	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	10/22/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**	10/22/2024	**Tank/Piping CP Test Date**	10/22/2024	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	10/22/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date	10/22/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-450				
Tank Number	02	**Tank Age**	40	**Tank Installed Date**	07/01/1985	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	3636	**Spill Test Date**	10/22/2024	**Piping Installed Date**	04/06/2015	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	10/22/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**	10/22/2024	**Tank/Piping CP Test Date**	10/22/2024	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	10/22/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date	10/22/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-450				

Tank Number	04	**Tank Age**	40	**Tank Installed Date**	07/01/1985	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	3637	**Spill Test Date**	10/22/2024	**Piping Installed Date**	04/06/2015	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	10/22/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**	10/22/2024	**Tank/Piping CP Test Date**	10/22/2024	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	10/22/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date	10/22/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-450				

Facility Summary in Roosevelt County in the City of Culbertson

Location: VAL AM STOP AND GO LLC
110 6th St W
Culbertson, MT 59218 Roosevelt

System Facility ID:43-01991

Facility Code: 27412
Last Inspected On: 10/10/2023
Operating Permit Renewal Date: 10/10/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Shanonne Oelkers;VAL AM STOP AND GO LLC CULBERTSON	**(406) 787-6327;(702) 802-1289**	**meand3boys@hotmail.com**
Operator Contact:	Kailey Bigler;VAL AM STOP AND GO LLC CULBERTSON;Shanonne Oelkers	**(435) 310-1116;(406) 787-6327;(702) 802-1289**	**meand3boys@hotmail.com;valam59218@hotmail.com**

Owner/Operator:	Shanonne Oelkers	(702) 802-1289	meand3boys@hotmail.com
Owner/Operator:	VAL AM STOP AND GO LLC CULBERTSON	(702) 802-1289	meand3boys@hotmail.com
	Kailey Bigler, UST Class A Operator		valam59218@hotmail.com
	Kailey Bigler, UST Class B Operator		valam59218@hotmail.com
	Shanonne Oelkers, UST Class A Operator		meand3boys@hotmail.com
	Shanonne Oelkers, UST Class A Operator		meand3boys@hotmail.com
	Shanonne Oelkers, UST Class B Operator		meand3boys@hotmail.com
	Shanonne Oelkers, UST Class B Operator		meand3boys@hotmail.com

Tank Number	05	**Tank Age**	35	**Tank Installed Date**	07/01/1990	**Tank Material Construction**	Steel Clad	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	3517	**Spill Test Date**	10/10/2023	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Manual Interstitial Monitoring	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	10/10/2023			**ATG Type**					

Tank Number	06	**Tank Age**	35	**Tank Installed Date**	07/01/1990	**Tank Material Construction**	Steel Clad	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	3518	**Spill Test Date**	10/10/2023	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Manual Interstitial Monitoring	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No

		Overfill Test Date	10/10/2023			**ATG Type**					

Facility Summary in Roosevelt County in the City of Froid

Location: AGLAND COOP FROID
105 2nd Ave N
Froid, MT 59226 Roosevelt

System Facility ID:43-04415

Facility Code: 27462
Last Inspected On: 05/01/2024
Operating Permit Renewal Date: 11/21/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Agland Coop Wolf Point	**(406) 653-1221**	**dave.williams@agland-coop.com**
Operator Contact:	Jeremy Breuer	**(406) 766-2463**	**jeremy.breuer@agland-coop.com**

Owner/Operator:	Agland Coop Wolf Point	(406) 653-1221	dave.williams@agland-coop.com
	Dan Kjelshus, UST Class B Operator		jeremy.breuer@agland-coop.com
	Danny Mogen, UST Class B Operator		jeremy.breuer@agland-coop.com
	Jeremy Breuer, UST Class A Operator		jeremy.breuer@agland-coop.com
	Jeremy Breuer, UST Class B Operator		jeremy.breuer@agland-coop.com

Tank Number	06	**Tank Age**	35	**Tank Installed Date**	10/01/1990	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	958	**Spill Test Date**	01/03/2024	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	01/03/2024	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	05/01/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	05/01/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Tank Number	07	**Tank Age**	35	**Tank Installed Date**	10/01/1990	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	959	**Spill Test Date**	01/03/2024	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	01/03/2024	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	05/01/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	05/01/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Tank Number	08	**Tank Age**	35	**Tank Installed Date**	10/01/1990	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	960	**Spill Test Date**	01/03/2024	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	01/03/2024	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	05/01/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	05/01/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	09	**Tank Age**	35	**Tank Installed Date**	10/01/1990	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	961	**Spill Test Date**	01/03/2024	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	01/03/2024	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	05/01/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	05/01/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Roosevelt County in the City of Poplar

Location: AGLAND COOP POPLAR
211 F St W
Poplar, MT 59255 Roosevelt

System Facility ID:43-10278

Facility Code: 27543
Last Inspected On: 05/01/2024
Operating Permit Renewal Date: 06/16/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Agland Coop Wolf Point	**(406) 653-1221**	**dave.williams@agland-coop.com**
Operator Contact:	David Parsley;Gary Sadler;Steven Long	**(406) 653-1510;(406) 768-7255**	**dave.parsley@agland-coop.com;gary.sadler@agland-coop.com**

Owner/Operator: Agland Coop Wolf Point	(406) 653-1221	dave.williams@agland-coop.com
Allen Richard, UST Class B Global Operator		allen.richard@agland-coop.com
Allen Richard, UST Class B Global Operator		allen.richard@agland-coop.com
Allen Richard, UST Class B Operator		allen.richard@agland-coop.com
Allen Richard, UST Class B Operator		allen.richard@agland-coop.com
David Parsley, UST Class A Operator		dave.parsley@agland-coop.com
David Parsley, UST Class B Operator		dave.parsley@agland-coop.com
Gary Sadler, UST Class A Operator		gary.sadler@agland-coop.com
Gary Sadler, UST Class A Operator		gary.sadler@agland-coop.com
Gary Sadler, UST Class B Operator		gary.sadler@agland-coop.com
Gary Sadler, UST Class B Operator		gary.sadler@agland-coop.com
Michael Pallvoda, UST Class B Operator		fuoilwp@nemont.net
Michael Pallvoda, UST Class B Operator		fuoilwp@nemont.net
Steven Long, UST Class A Operator		
Steven Long, UST Class A Operator		
Steven Long, UST Class B Operator		
Steven Long, UST Class B Operator		

Tank Number	01	**Tank Age**	41	**Tank Installed Date**	10/27/1984	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	993	**Spill Test Date**	03/25/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	07/19/2024	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**		**Line Tightness Test Date**	04/28/2024	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No

		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	02	**Tank Age**	41	**Tank Installed Date**	10/27/1984	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	994	**Spill Test Date**	03/25/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	06/16/2021	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**		**Line Tightness Test Date**	03/21/2007	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	03	**Tank Age**	41	**Tank Installed Date**	10/27/1984	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	995	**Spill Test Date**	03/25/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	06/16/2021	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**		**Line Tightness Test Date**	03/21/2007	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	04	**Tank Age**	31	**Tank Installed Date**	06/01/1994	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	996	**Spill Test Date**	03/25/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	07/19/2024	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**		**Line Tightness Test Date**	03/21/2007	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	05	**Tank Age**	31	**Tank Installed Date**	06/01/1994	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	997	**Spill Test Date**	03/25/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No

Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	06/16/2021	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**		**Line Tightness Test Date**	03/21/2007	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	06	**Tank Age**	31	**Tank Installed Date**	06/01/1994	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	998	**Spill Test Date**	03/25/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	06/16/2021	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**		**Line Tightness Test Date**	03/21/2007	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Roosevelt County in the City of Poplar

Location: FORT PECK DETENTION CENTER
6256 Buffalo Dr
Poplar, MT 59255 Roosevelt

System Facility ID:60-15207

Facility Code: 30927
Last Inspected On: 01/13/2021
Operating Permit Renewal Date: 11/30/2023

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Assiniboine and Sioux Tribes Poplar	**(406) 768-2389**	**martinawilson@fortpecktribes.net**
Operator Contact:	David Lezard	**(406) 478-2609**	**dlezard@fortpecktribes.net**

Owner/Operator: Assiniboine and Sioux Tribes Poplar (406) 768-2389 martinawilson@fortpecktribes.net

David Lezard, UST Class A Operator dlezard@fortpecktribes.net

David Lezard, UST Class B Global Operator dlezard@fortpecktribes.net

Tank Number	01	**Tank Age**	12	**Tank Installed Date**	09/01/2013	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	5419	**Spill Test Date**		**Piping Installed Date**	05/02/2013	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Temporarily Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**	11/19/2020	**Catastrophic L.D. Type 3.0**	Auto Dialer	**Piping Type**	U.S. Suction	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	3000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	Yes
		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/TLS-300				

Facility Summary in Roosevelt County in the City of Wolf Point

Location: AGLAND COOP EAST
300 US Hwy 2
Wolf Point, MT 59201 Roosevelt

System Facility ID:43-10279

Facility Code: 27544
Last Inspected On: 05/02/2024
Operating Permit Renewal Date: 06/16/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Agland Coop Wolf Point	**(406) 653-1221**	**dave.williams@agland-coop.com**
Operator Contact:	David Parsley;Monica Turnburke;Nancy Sietsema	**(406) 653-1510**	**dave.parsley@agland-coop.com**

Owner/Operator:	Agland Coop Wolf Point	(406) 653-1221	dave.williams@agland-coop.com
	Allen Richard, UST Class B Global Operator		allen.richard@agland-coop.com
	Allen Richard, UST Class B Global Operator		allen.richard@agland-coop.com
	Allen Richard, UST Class B Operator		allen.richard@agland-coop.com
	Allen Richard, UST Class B Operator		allen.richard@agland-coop.com
	Bruce Unger, UST Class B Operator		
	Bruce Unger, UST Class B Operator		
	David Parsley, UST Class A Operator		dave.parsley@agland-coop.com
	David Parsley, UST Class B Operator		dave.parsley@agland-coop.com
	Michael Pallvoda, UST Class B Operator		fuoilwp@nemont.net
	Michael Pallvoda, UST Class B Operator		fuoilwp@nemont.net
	Monica Turnburke, UST Class A Operator		
	Monica Turnburke, UST Class A Operator		
	Monica Turnburke, UST Class B Global Operator		
	Monica Turnburke, UST Class B Global Operator		
	Nancy Sietsema, UST Class A Operator		
	Nancy Sietsema, UST Class A Operator		
	Nancy Sietsema, UST Class B Operator		
	Nancy Sietsema, UST Class B Operator		
	Steven Long, UST Class B Operator		
	Steven Long, UST Class B Operator		
	Weston Smith, UST Class B Global Operator		
	Weston Smith, UST Class B Global Operator		

Tank Number	10	**Tank Age**	29	**Tank Installed Date**	08/01/1996	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	1000	**Spill Test Date**	09/02/2022	**Piping Installed Date**	09/23/2011	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No

Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	05/01/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	03/13/2020	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	30000	**ATG Test Date**		**Line Tightness Test Date**	05/01/2024	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date	09/01/2022			**ATG Type**	Veeder Root/TLS-450				
Tank Number	11	**Tank Age**	29	**Tank Installed Date**	08/01/1996	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	1001	**Spill Test Date**	09/02/2022	**Piping Installed Date**	09/23/2011	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	05/01/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	03/13/2020	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	20000	**ATG Test Date**		**Line Tightness Test Date**	05/01/2024	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date	09/01/2022			**ATG Type**	Veeder Root/TLS-450				
Tank Number	12	**Tank Age**	29	**Tank Installed Date**	08/01/1996	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	1002	**Spill Test Date**	09/02/2022	**Piping Installed Date**	09/23/2011	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	03/13/2020	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**		**Line Tightness Test Date**	09/01/2009	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date	09/01/2022			**ATG Type**	Veeder Root/TLS-450				
Tank Number	13	**Tank Age**	29	**Tank Installed Date**	08/01/1996	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	1003	**Spill Test Date**	09/02/2022	**Piping Installed Date**	09/23/2011	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	05/01/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	03/13/2020	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	14000	**ATG Test Date**		**Line Tightness Test Date**	05/01/2024	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No

		Overfill Test Date	09/01/2022			**ATG Type**	Veeder Root/TLS-450				
Tank Number	14	**Tank Age**	29	**Tank Installed Date**	08/01/1996	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	1004	**Spill Test Date**	09/02/2022	**Piping Installed Date**	09/23/2011	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	03/13/2020	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**		**Line Tightness Test Date**	09/01/2009	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date	09/01/2022			**ATG Type**	Veeder Root/TLS-450				
Tank Number	15	**Tank Age**	29	**Tank Installed Date**	08/01/1996	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	1005	**Spill Test Date**	09/02/2022	**Piping Installed Date**	09/23/2011	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	03/13/2020	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**		**Line Tightness Test Date**	09/01/2009	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date	09/01/2022			**ATG Type**	Veeder Root/TLS-450				
Tank Number	09	**Tank Age**	29	**Tank Installed Date**	08/01/1996	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	999	**Spill Test Date**	09/02/2022	**Piping Installed Date**	09/23/2011	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	03/03/2020	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**	05/02/2024	**Tank/Piping CP Test Date**	03/13/2020	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	30000	**ATG Test Date**		**Line Tightness Test Date**	09/01/2009	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date	09/01/2022			**ATG Type**	Veeder Root/TLS-450				

Facility Summary in Roosevelt County in the City of Wolf Point

Location: AGLAND COOP WEST
603 US Hwy 2
Wolf Point, MT 59201 Roosevelt

System Facility ID:43-06866

Facility Code: 27498
Last Inspected On: 03/15/2024
Operating Permit Renewal Date: 06/15/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Agland Coop Wolf Point	**(406) 653-1221**	**dave.williams@agland-coop.com**
Operator Contact:	Vicky Boysun		**vicky.boysun@agland-coop.net**

Owner/Operator:	Agland Coop Wolf Point	(406) 653-1221	dave.williams@agland-coop.com
	Allen Richard, UST Class B Global Operator		allen.richard@agland-coop.com
	Allen Richard, UST Class B Operator		allen.richard@agland-coop.com
	Michael Pallvoda, UST Class B Operator		fuoilwp@nemont.net
	Nancy Sietsema, UST Class B Operator		
	Steven Long, UST Class B Operator		
	Vicky Boysun, UST Class A Operator		vicky.boysun@agland-coop.net

Tank Number	07	**Tank Age**	31	**Tank Installed Date**	06/01/1994	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	4327	**Spill Test Date**	09/02/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**	01/04/2024	**Tank/Piping CP Test Date**	07/19/2024	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	05/02/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	09/01/2022			**ATG Type**	Veeder Root/TLS-450				
Tank Number	09	**Tank Age**	31	**Tank Installed Date**	06/01/1994	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	4328	**Spill Test Date**	09/02/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**	12/13/2023	**Tank/Piping CP Test Date**	07/19/2024	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	05/02/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No

		Overfill Test Date	09/01/2022			**ATG Type**	Veeder Root/TLS-450				
Tank Number	11	**Tank Age**	31	**Tank Installed Date**	06/01/1994	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	4329	**Spill Test Date**	09/02/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Diesel, Dyed	**PLLD Test Date**	01/04/2024	**Tank/Piping CP Test Date**	07/19/2024	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	05/02/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	09/01/2022			**ATG Type**	Veeder Root/TLS-450				
Tank Number	08	**Tank Age**	31	**Tank Installed Date**	06/01/1994	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	988	**Spill Test Date**	09/02/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**	01/04/2024	**Tank/Piping CP Test Date**	07/19/2024	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	05/02/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	09/01/2022			**ATG Type**	Veeder Root/TLS-450				
Tank Number	10	**Tank Age**	31	**Tank Installed Date**	06/01/1994	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	990	**Spill Test Date**	09/02/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**	01/04/2024	**Tank/Piping CP Test Date**	07/19/2024	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	05/02/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	09/01/2022			**ATG Type**	Veeder Root/TLS-450				
Tank Number	12	**Tank Age**	31	**Tank Installed Date**	06/01/1994	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	992	**Spill Test Date**	09/02/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Diesel, Dyed	**PLLD Test Date**	01/04/2024	**Tank/Piping CP Test Date**	07/19/2024	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No

Capacity	12000	**ATG Test Date**	05/02/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	09/01/2022			**ATG Type**	Veeder Root/TLS-450				

Facility Summary in Roosevelt County in the City of Wolf Point

Location: L M CLAYTON AIRPORT
MT Hwy 13
Wolf Point, MT 59201 Roosevelt

System Facility ID:43-00843

Facility Code: 27396
Last Inspected On: 10/23/2024
Operating Permit Renewal Date: 01/09/2028

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	City of Wolf Point	**(406) 653-1852**	**wppublicworks@nemont.net**
Operator Contact:	Edward Bach;Tom Romo	**(406) 650-8305**	**bachairport@nemont.net;lmclaytonairprt@memont.net**

Owner/Operator: City of Wolf Point (406) 653-1852 wppublicworks@nemont.net

Edward Bach, UST Class A Operator bachairport@nemont.net
Edward Bach, UST Class B Operator bachairport@nemont.net
Tom Romo, UST Class A Operator lmclaytonairprt@memont.net
Tom Romo, UST Class B Operator lmclaytonairprt@memont.net

Tank Number	06	**Tank Age**	33	**Tank Installed Date**	11/01/1992	**Tank Material Construction**	Steel Clad	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	648	**Spill Test Date**	10/23/2023	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Non-corrodible
Product	Aviation Gas	**PLLD Test Date**		**Tank/Piping CP Test Date**	02/20/2013	**Primary Tank Leak Detection**	Manual Interstitial Monitoring	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	10/23/2023			**ATG Type**					
Tank Number	07	**Tank Age**	33	**Tank Installed Date**	11/01/1992	**Tank Material Construction**	Steel Clad	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	649	**Spill Test Date**	10/23/2023	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Non-corrodible
Product	Diesel, Dyed	**PLLD Test Date**		**Tank/Piping CP Test Date**	02/20/2013	**Primary Tank Leak Detection**	Manual Interstitial Monitoring	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	10/23/2023			**ATG Type**					

Facility Summary in Roosevelt County in the City of Wolf Point

Location: TOWN PUMP INC WOLF POINT
401 Cascade St
Wolf Point, MT 59201-1339 Roosevelt

System Facility ID:43-08725

Facility Code: 27530
Last Inspected On: 02/05/2024
Operating Permit Renewal Date: 07/01/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: E-Z Supply Inc **(406) 497-6700**

Operator Contact: Trent Biggers **Trentb@townpump.com**

Owner/Operator: E-Z Supply Inc (406) 497-6700

Trent Biggers, UST Class A Operator	Trentb@townpump.com
Trent Biggers, UST Class A Operator	Trentb@townpump.com
Trent Biggers, UST Class B Global Operator	Trentb@townpump.com
Trent Biggers, UST Class B Global Operator	Trentb@townpump.com

Tank Number	01	**Tank Age**	40	**Tank Installed Date**	04/14/1985	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Steel	**Overfill Types**	Ball Float Valve;Flapper Valve
Tag Number	4774	**Spill Test Date**	08/03/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	08/27/2022	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**	01/26/2024	**Tank/Piping CP Test Date**	07/25/2023	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	01/31/2024	**Line Tightness Test Date**	09/01/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	08/03/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Number	02	**Tank Age**	40	**Tank Installed Date**	04/14/1985	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Steel	**Overfill Types**	Ball Float Valve;Flapper Valve
Tag Number	4775	**Spill Test Date**	07/01/2021	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**	06/22/2022	**Tank/Piping CP Test Date**	07/01/2021	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	01/31/2024	**Line Tightness Test Date**	11/13/2009	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No

		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Number	03	**Tank Age**	40	**Tank Installed Date**	04/14/1985	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Steel	**Overfill Types**	Ball Float Valve;Flapper Valve
Tag Number	4776	**Spill Test Date**	07/01/2021	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**	06/22/2022	**Tank/Piping CP Test Date**	07/01/2021	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	01/31/2024	**Line Tightness Test Date**	11/13/2009	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Number	04	**Tank Age**	39	**Tank Installed Date**	04/14/1986	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve
Tag Number	4777	**Spill Test Date**	07/01/2021	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**	06/22/2022	**Tank/Piping CP Test Date**	07/01/2021	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**	01/31/2024	**Line Tightness Test Date**	10/11/2006	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Number	05	**Tank Age**	39	**Tank Installed Date**	04/14/1986	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve
Tag Number	4778	**Spill Test Date**	07/01/2021	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Diesel, Dyed	**PLLD Test Date**	06/22/2022	**Tank/Piping CP Test Date**	07/01/2021	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	01/31/2024	**Line Tightness Test Date**	12/20/2006	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				

Tank Number	06	**Tank Age**	23	**Tank Installed Date**	06/28/2002	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve
Tag Number	4779	**Spill Test Date**	07/01/2021	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	06/22/2022	**Tank/Piping CP Test Date**	07/01/2021	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	01/31/2024	**Line Tightness Test Date**	12/21/2006	**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				

Facility Summary in Rosebud County in the City of Ashland

Location: CHEYENNE DEPOT 2
2363 W US Hwy 212
Ashland, MT 59003 Rosebud

System Facility ID:44-13200

Facility Code: 27702
Last Inspected On: 06/25/2024
Operating Permit Renewal Date: 06/27/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Northern Cheyenne Development Corporation **(406) 477-6794** **ncdcmt@gmail.com**

Operator Contact:

Owner/Operator: Northern Cheyenne Development Corporation (406) 477-6794 ncdcmt@gmail.com

Tank Number	01	**Tank Age**	32	**Tank Installed Date**	07/30/1993	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	4420	**Spill Test Date**	06/25/2024	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	06/25/2024	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	05/11/2022	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	06/25/2024	**Line Tightness Test Date**	06/25/2024	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	06/25/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	02	**Tank Age**	32	**Tank Installed Date**	07/30/1993	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	4421	**Spill Test Date**	06/25/2024	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	06/25/2024	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	05/11/2022	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	06/25/2024	**Line Tightness Test Date**	06/25/2024	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	06/25/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	05	**Tank Age**	32	**Tank Installed Date**	07/30/1993	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve

Tag Number	4424	**Spill Test Date**	06/25/2024	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	06/25/2024	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	05/11/2022	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	06/25/2024	**Line Tightness Test Date**	06/25/2024	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	06/25/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Rosebud County in the City of Ashland

Location: ST LABRE INDIAN SCHOOL UST
1000 Tongue River Rd
Ashland, MT 59003 Rosebud

System Facility ID:44-00701

Facility Code: 27579
Last Inspected On: 05/09/2024
Operating Permit Renewal Date: 10/09/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	St Labre Indian School	**(406) 784-4994**	**STLMAINTINV@STLABRE.ORG**
Operator Contact:	Dana Davis;Leney Mcnac		**ddavis@stlabre.org;lmcnac@stlabre.org**

Owner/Operator: St Labre Indian School (406) 784-4994 STLMAINTINV@STLABRE.ORG

Dana Davis, UST Class A Operator	ddavis@stlabre.org
Dana Davis, UST Class B Global Operator	ddavis@stlabre.org
Dana Davis, UST Class B Operator	ddavis@stlabre.org
Leney Mcnac, UST Class A Operator	lmcnac@stlabre.org
Leney Mcnac, UST Class B Global Operator	lmcnac@stlabre.org

Tank Number	10	**Tank Age**	32	**Tank Installed Date**	12/01/1993	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	1957	**Spill Test Date**	05/09/2024	**Piping Installed Date**	08/26/2011	**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	05/09/2024	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	15000	**ATG Test Date**	05/09/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	05/09/2024			**ATG Type**	Gilbarco/EMC Basic				

Facility Summary in Rosebud County in the City of Ashland

Location: WESTERN PUMP
US Hwy 212
Ashland, MT 59003 Rosebud

System Facility ID:44-01892

Facility Code: 27599
Last Inspected On: 09/18/2023
Operating Permit Renewal Date: 12/31/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Cleatus Stevenson **(406) 784-2400**

Operator Contact: James Stevenson **(406) 784-2400** **joats@rangeweb.net**

Owner/Operator: Cleatus Stevenson (406) 784-2400

James Stevenson, UST Class A Operator joats@rangeweb.net

James Stevenson, UST Class B Operator joats@rangeweb.net

Tank Number	01	**Tank Age**	32	**Tank Installed Date**	02/01/1993	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	3098	**Spill Test Date**	09/18/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	10/12/2020	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	2000	**ATG Test Date**	09/18/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	09/18/2023			**ATG Type**	Gilbarco-Veeder Root/				
Tank Number	02	**Tank Age**	32	**Tank Installed Date**	02/01/1993	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	3099	**Spill Test Date**	09/18/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	11/02/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	09/18/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	09/18/2023			**ATG Type**	Gilbarco-Veeder Root/				
Tank Number	03	**Tank Age**	28	**Tank Installed Date**	10/29/1997	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	3100	**Spill Test Date**	11/02/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No

Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	09/18/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	09/18/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	11/02/2023			**ATG Type**	Gilbarco-Veeder Root/				

Facility Summary in Rosebud County in the City of Colstrip

Location: COLSTRIP 500 KV SUBSTATION
86 Burtco Ct
Colstrip, MT 59323 Rosebud

System Facility ID:44-01432

Facility Code: 27593
Last Inspected On: 05/10/2016
Operating Permit Renewal Date: 02/21/2019

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Northwestern Energy Butte	**(406) 655-2521**	**beth.stimatz@northwestern.com**
Operator Contact:	John Habeger		**john.habeger@northwestern.com**

Darren Brockel, UST Class B Global Operator	darren.brockel@northwestern.com
Darren Brockel, UST Class B Global Operator	darren.brockel@northwestern.com
John Habeger, UST Class A Operator	john.habeger@northwestern.com
John Habeger, UST Class A Operator	john.habeger@northwestern.com

Tank Number	01	**Tank Age**	43	**Tank Installed Date**	04/30/1982	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	3998	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**	05/10/2016	**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	U.S. Suction	**CP Met Types**	
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Manual Interstitial Monitoring	**Vapor Recovery**	No
Capacity	5000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**	OPW/EECO 1500				

Facility Summary in Rosebud County in the City of Colstrip

Location: COLSTRIP STEAM ELECTRIC STATION UNITS 3 AND 4
601 Willow Ave
Colstrip, MT 59323 Rosebud

System Facility ID:44-06584

Facility Code: 27651
Last Inspected On: 10/13/2023
Operating Permit Renewal Date: 10/13/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Talen Montana LLC **(406) 748-5002** **gordon.criswell@talenenergy.com**

Operator Contact: Brian Sullivan **(406) 748-5038** **brian.sullivan@talenenergy.com**

Owner/Operator: Talen Montana LLC (406) 748-5002 gordon.criswell@talenenergy.com

Brian Sullivan, UST Class A Operator brian.sullivan@talenenergy.com

William Neumiller, UST Class B Operator wlneumiller@pplweb.com

Tank Number	S10-24	**Tank Age**	46	**Tank Installed Date**	05/01/1979	**Tank Material Construction**	Unknown	**Piping Material**	Steel	**Overfill Types**	
Tag Number	2863	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	Yes
Status	**Temporarily Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Pressurized	**CP Met Types**	
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	01/30/2024	**Primary Tank Leak Detection**	Deferred	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	40000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	S10-23	**Tank Age**	46	**Tank Installed Date**	05/01/1979	**Tank Material Construction**	Unknown	**Piping Material**	Steel	**Overfill Types**	
Tag Number	3703	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	Yes
Status	**Temporarily Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Pressurized	**CP Met Types**	
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	01/30/2024	**Primary Tank Leak Detection**	Deferred	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	500000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					

Facility Summary in Rosebud County in the City of Colstrip

Location: COLSTRIP STEAM ELECTRIC STATION WILLOW AVE
601 Willow Ave
Colstrip, MT 59323 Rosebud

System Facility ID:44-08921

Facility Code: 27669
Last Inspected On: 03/03/2017
Operating Permit Renewal Date: 08/22/2020

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Talen Montana LLC	**(406) 748-5002**	**gordon.criswell@talenenergy.com**
Operator Contact:	Brian Sullivan;Michael Holzwarth;Stephen Christian	**(406) 748-5019;(406) 748-5038**	**brian.sullivan@talenenergy.com;mvholzwarth@pplweb.com;sjchristian@pplweb.com**

Brian Sullivan, UST Class A Operator	brian.sullivan@talenenergy.com
David Millegan, UST Class B Operator	david.millegan@talenenergy.com
David Millegan, UST Class B Operator	david.millegan@talenenergy.com
Michael Holzwarth, UST Class A Operator	mvholzwarth@pplweb.com
Michael Holzwarth, UST Class A Operator	mvholzwarth@pplweb.com
Stephen Christian, UST Class A Operator	sjchristian@pplweb.com
Stephen Christian, UST Class A Operator	sjchristian@pplweb.com
Stephen Christian, UST Class B Global Operator	sjchristian@pplweb.com
Stephen Christian, UST Class B Global Operator	sjchristian@pplweb.com
William Neumiller, UST Class B Operator	wlneumiller@pplweb.com
William Neumiller, UST Class B Operator	wlneumiller@pplweb.com

Tank Number	01	**Tank Age**	34	**Tank Installed Date**	08/01/1991	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	2864	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	03/30/2011	**Primary Tank Leak Detection**	Manual Interstitial Monitoring	**Primary Pipe Leak Detection**	Deferred	**Vapor Recovery**	No
Capacity	20000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	02	**Tank Age**	34	**Tank Installed Date**	08/01/1991	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	2865	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No

Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	03/30/2011	**Primary Tank Leak Detection**	Manual Interstitial Monitoring	**Primary Pipe Leak Detection**	Deferred	**Vapor Recovery**	No
Capacity	20000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					

Facility Summary in Rosebud County in the City of Colstrip

Location: TOWN PUMP INC COLSTRIP
112 Willow Ave
Colstrip, MT 59323 Rosebud

System Facility ID:44-08689

Facility Code: 27667
Last Inspected On: 03/12/2024
Operating Permit Renewal Date: 07/01/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Colstrip 1 Town Pump LLC **(406) 497-6700** **environmental@townpump.com**

Operator Contact: Trent Biggers **Trentb@townpump.com**

Owner/Operator: Colstrip 1 Town Pump LLC (406) 497-6700 environmental@townpump.com

Trent Biggers, UST Class A Operator Trentb@townpump.com

Trent Biggers, UST Class B Global Operator Trentb@townpump.com

Tank Number	01	**Tank Age**	50	**Tank Installed Date**	04/12/1975	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	4787	**Spill Test Date**	07/27/2023	**Piping Installed Date**	04/20/2011	**Tank Construction**	Lined Interior/Impressed Current	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	06/08/2021	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Diesel	**PLLD Test Date**	06/07/2022	**Tank/Piping CP Test Date**	06/08/2021	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	15000	**ATG Test Date**	12/01/2023	**Line Tightness Test Date**	06/02/2006	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	No
		Overfill Test Date	08/17/2021			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Number	02	**Tank Age**	50	**Tank Installed Date**	04/12/1975	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	4788	**Spill Test Date**	08/17/2021	**Piping Installed Date**		**Tank Construction**	Lined Interior/Impressed Current	**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	04/16/2020	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**	06/07/2022	**Tank/Piping CP Test Date**	07/08/2021	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	12/01/2023	**Line Tightness Test Date**	07/02/2006	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No

		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Number	03	**Tank Age**	50	**Tank Installed Date**	04/12/1975	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	4789	**Spill Test Date**	07/27/2023	**Piping Installed Date**	04/20/2011	**Tank Construction**	Lined Interior/Impressed Current	**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	06/08/2021	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**	06/07/2022	**Tank/Piping CP Test Date**	06/08/2021	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	12/01/2023	**Line Tightness Test Date**	07/02/2006	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Number	04	**Tank Age**	50	**Tank Installed Date**	04/12/1975	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	4790	**Spill Test Date**	08/17/2021	**Piping Installed Date**		**Tank Construction**	Lined Interior/Impressed Current	**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	04/16/2020	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**	06/07/2022	**Tank/Piping CP Test Date**	06/08/2021	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	12/01/2023	**Line Tightness Test Date**	10/14/2006	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Number	05	**Tank Age**	50	**Tank Installed Date**	04/12/1975	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	4791	**Spill Test Date**	08/17/2021	**Piping Installed Date**		**Tank Construction**	Lined Interior/Impressed Current	**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	04/16/2020	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**	06/07/2022	**Tank/Piping CP Test Date**	06/08/2021	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**	12/01/2023	**Line Tightness Test Date**	10/14/2006	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	08/17/2021			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				

Tank Number	06	**Tank Age**	25	**Tank Installed Date**	01/01/2000	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve
Tag Number	4792	**Spill Test Date**	07/27/2023	**Piping Installed Date**	04/20/2011	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	06/08/2021	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	06/07/2022	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	12/01/2023	**Line Tightness Test Date**	10/25/2006	**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Number	07	**Tank Age**	25	**Tank Installed Date**	01/01/2000	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve
Tag Number	4793	**Spill Test Date**	08/17/2021	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	06/08/2021	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	06/07/2022	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**	12/01/2023	**Line Tightness Test Date**	10/25/2006	**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				

Facility Summary in Rosebud County in the City of Forsyth

Location: FORSYTH WATERING HOLE
1017 Front St
Forsyth, MT 59327 Rosebud

System Facility ID:44-01244

Facility Code: 27590
Last Inspected On: 08/16/2024
Operating Permit Renewal Date: 12/12/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	RRR Properties LLC	**(406) 346-2885**	**forsythwh@yahoo.com**
Operator Contact:	DeAnne Jonas	**(406) 346-2885**	**forsythwh@yahoo.com**

Owner/Operator: RRR Properties LLC (406) 346-2885 forsythwh@yahoo.com

DeAnne Jonas, UST Class A Operator forsythwh@yahoo.com
DeAnne Jonas, UST Class A Operator forsythwh@yahoo.com
DeAnne Jonas, UST Class B Global Operator forsythwh@yahoo.com
DeAnne Jonas, UST Class B Global Operator forsythwh@yahoo.com

Tank Number	04	**Tank Age**	33	**Tank Installed Date**	02/24/1992	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	1393	**Spill Test Date**	08/16/2024	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Single Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	08/16/2024	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	08/15/2018	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	08/16/2024	**Line Tightness Test Date**	08/16/2024	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	08/16/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	05	**Tank Age**	33	**Tank Installed Date**	02/24/1992	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	1394	**Spill Test Date**	08/16/2024	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	08/16/2024	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	07/27/2021	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	08/16/2024	**Line Tightness Test Date**	08/16/2024	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	08/16/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Tank Number	06	**Tank Age**	33	**Tank Installed Date**	02/24/1992	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	1395	**Spill Test Date**	08/16/2024	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Single Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	08/16/2024	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	07/27/2021	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	08/16/2024	**Line Tightness Test Date**	08/16/2024	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	08/16/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Rosebud County in the City of Forsyth

Location: PRINCE INC FORSYTH
W Frontage Rd
Forsyth, MT 59327 Rosebud

System Facility ID:44-06209

Facility Code: 27646
Last Inspected On: 09/26/2023
Operating Permit Renewal Date: 02/12/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Prince Inc **(406) 356-2137**

Operator Contact: Charlee Prince;Shelley Thompson;Steve Pulver **(406) 346-2137** **cprince@princeinc.us;slnpulver@live.com;sthompson@princeinc.us**

Owner/Operator: Prince Inc (406) 356-2137

Charlee Prince, UST Class A Operator	cprince@princeinc.us
Charlee Prince, UST Class B Global Operator	cprince@princeinc.us
Shelley Thompson, UST Class A Operator	sthompson@princeinc.us
Shelley Thompson, UST Class B Operator	sthompson@princeinc.us
Steve Pulver, UST Class A Operator	slnpulver@live.com
Steve Pulver, UST Class B Operator	slnpulver@live.com

Tank Number	05	**Tank Age**	27	**Tank Installed Date**	10/01/1998	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	4532	**Spill Test Date**	09/26/2023	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	09/26/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	09/26/2023	**Line Tightness Test Date**	11/21/2011	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	09/26/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	06	**Tank Age**	27	**Tank Installed Date**	10/01/1998	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	4533	**Spill Test Date**	09/26/2023	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	09/26/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	5000	**ATG Test Date**	09/26/2023	**Line Tightness Test Date**	11/21/2011	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No

		Overfill Test Date	09/26/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Rosebud County in the City of Forsyth

Location: ROSEBUD COUNTY ROAD DEPT
2975 US Hwy 10
Forsyth, MT 59327 Rosebud

System Facility ID:44-01288

Facility Code: 27592
Last Inspected On: 10/11/2023
Operating Permit Renewal Date: 10/11/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Rosebud County Road Dept **(406) 346-2261**

Operator Contact: Dawne Buck;Pat Zent;Wayne Buck **(406) 698-3778** **dbuck@rosebudcountymt.com;pzent@rosebudcountymt.com**

Owner/Operator: Rosebud County Road Dept (406) 346-2261

Dawne Buck, UST Class A Operator	dbuck@rosebudcountymt.com
Dawne Buck, UST Class B Operator	dbuck@rosebudcountymt.com
Pat Zent, UST Class A Operator	pzent@rosebudcountymt.com
Pat Zent, UST Class B Operator	pzent@rosebudcountymt.com
Wayne Buck, UST Class A Operator	dbuck@rosebudcountymt.com
Wayne Buck, UST Class B Operator	dbuck@rosebudcountymt.com

Tank Number	05	**Tank Age**	34	**Tank Installed Date**	04/01/1991	**Tank Material Construction**	Steel Clad	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	1858	**Spill Test Date**	09/26/2023	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	09/26/2023	**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**	09/26/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	09/26/2023			**ATG Type**	Gilbarco-Veeder Root/EMC Basic				
Tank Number	06	**Tank Age**	34	**Tank Installed Date**	04/01/1991	**Tank Material Construction**	Steel Clad	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	1859	**Spill Test Date**	09/26/2023	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	09/26/2023	**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	09/26/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No

		Overfill Test Date	09/26/2023			**ATG Type**	Gilbarco-Veeder Root/EMC Basic				
Tank Number	07	**Tank Age**	34	**Tank Installed Date**	04/01/1991	**Tank Material Construction**	Steel Clad	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	1860	**Spill Test Date**	09/26/2023	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	09/26/2023	**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	09/26/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	09/26/2023			**ATG Type**	Gilbarco-Veeder Root/EMC Basic				

Facility Summary in Rosebud County in the City of Forsyth

Location: ROSEBUD HEALTH CARE CENTER
383 N 17th Ave
Forsyth, MT 59327 Rosebud

System Facility ID:44-05262

Facility Code: 27633
Last Inspected On: 03/10/2025
Operating Permit Renewal Date: 03/14/2028

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Rosebud Health Care Center **(406) 356-2161**

Operator Contact: Chad Potts;Michael Jerhoff;Tim Davis **(406) 347-5222;(406) 351-2274;(406) 351-9095** **cpotts@rosebudhealthcare.com**

Owner/Operator: Rosebud Health Care Center (406) 356-2161

Chad Potts, UST Class A Operator cpotts@rosebudhealthcare.com
Clint Boyer, UST Class B Operator cboyer@rosebudhealthcare.com
Michael Jerhoff, UST Class A Operator
Michael Jerhoff, UST Class B Global Operator
Tim Davis, UST Class A Operator
Tim Davis, UST Class B Global Operator

Tank Number	02	**Tank Age**	34	**Tank Installed Date**	09/01/1991	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Steel	**Overfill Types**	Flapper Valve
Tag Number	4343	**Spill Test Date**	01/10/2022	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	None	**AST**	No
Status	**Temporarily Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	U.S. Suction	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	03/10/2025	**Primary Tank Leak Detection**	Manual Interstitial Monitoring	**Primary Pipe Leak Detection**	3-Year Line Tightness Test	**Vapor Recovery**	No
Capacity	500	**ATG Test Date**		**Line Tightness Test Date**	01/27/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	01/27/2022			**ATG Type**					

Facility Summary in Rosebud County in the City of Forsyth

Location: TOWN PUMP INC FORSYTH
974 Front St
Forsyth, MT 59327 Rosebud

System Facility ID:44-09356

Facility Code: 27672
Last Inspected On: 02/14/2024
Operating Permit Renewal Date: 07/01/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Forsyth 1 Town Pump LLC **(406) 497-6700** **environmental@townpump.com**

Operator Contact: Trent Biggers **Trentb@townpump.com**

Owner/Operator: Forsyth 1 Town Pump LLC (406) 497-6700 environmental@townpump.com

Trent Biggers, UST Class A Operator Trentb@townpump.com
Trent Biggers, UST Class A Operator Trentb@townpump.com
Trent Biggers, UST Class B Global Operator Trentb@townpump.com
Trent Biggers, UST Class B Global Operator Trentb@townpump.com

Tank Number	11	**Tank Age**	23	**Tank Installed Date**	10/21/2002	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve
Tag Number	4736	**Spill Test Date**	09/26/2023	**Piping Installed Date**	10/21/2002	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	02/14/2024	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	02/14/2024	**Line Tightness Test Date**	12/03/2009	**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	09/26/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350				
Tank Number	12	**Tank Age**	23	**Tank Installed Date**	10/21/2002	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve
Tag Number	4737	**Spill Test Date**	12/20/2023	**Piping Installed Date**	10/21/2002	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	02/14/2024	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	5000	**ATG Test Date**	02/14/2024	**Line Tightness Test Date**	12/03/2009	**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No

		Overfill Test Date	09/26/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350				
Tank Number	14	**Tank Age**	23	**Tank Installed Date**	10/21/2002	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve
Tag Number	4738	**Spill Test Date**	09/26/2023	**Piping Installed Date**	10/21/2002	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	02/14/2024	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	5000	**ATG Test Date**	02/14/2024	**Line Tightness Test Date**	12/03/2009	**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	09/26/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350				
Tank Number	13	**Tank Age**	23	**Tank Installed Date**	11/20/2002	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve
Tag Number	4755	**Spill Test Date**	09/26/2023	**Piping Installed Date**	11/20/2002	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	02/14/2024	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	02/14/2024	**Line Tightness Test Date**	12/03/2009	**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	09/26/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350				
Tank Number	15	**Tank Age**	23	**Tank Installed Date**	11/20/2002	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve
Tag Number	4756	**Spill Test Date**	09/26/2023	**Piping Installed Date**	11/20/2002	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	02/14/2024	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	02/14/2024	**Line Tightness Test Date**	12/03/2009	**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	09/26/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350				
Tank Number	16	**Tank Age**	23	**Tank Installed Date**	11/20/2002	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve

Tag Number	4757	**Spill Test Date**	09/26/2023	**Piping Installed Date**	11/20/2002	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	02/14/2024	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	5000	**ATG Test Date**	02/14/2024	**Line Tightness Test Date**	12/03/2009	**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	09/26/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Sanders County in the City of Heron

Location: THE HERON STORE AND CAFÉ
150 Railroad Ave
Heron, MT 59844-9596 Sanders

System Facility ID:45-10136

Facility Code: 27838
Last Inspected On: 10/02/2024
Operating Permit Renewal Date: 10/02/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Michael Kranzier	**(406) 847-1958**	**mayu.msrl@gmail.com**
Operator Contact:	Lisa Camara	**(406) 847-3663**	**cfgirl1111@outlook.com**

Owner/Operator: Michael Kranzier (406) 847-1958 mayu.msrl@gmail.com
Lisa Camara, UST Class A Operator cfgirl1111@outlook.com
Lisa Camara, UST Class B Global Operator cfgirl1111@outlook.com

Tank Number	03	**Tank Age**	30	**Tank Installed Date**	06/01/1995	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	3291	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	None	**AST**	No
Status	**Temporarily Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Not Listed	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	1080	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	04	**Tank Age**	30	**Tank Installed Date**	06/01/1995	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	3292	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	None	**AST**	No
Status	**Temporarily Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Not Listed	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	1080	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					

Facility Summary in Sanders County in the City of Hot Springs

Location: LONEPINE COUNTRY STORE
2534 MT Hwy 28
Hot Springs, MT 59845 Sanders

System Facility ID:45-12786

Facility Code: 27878
Last Inspected On: 04/09/2025
Operating Permit Renewal Date: 08/07/2025

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Lonepine General Store LLC	**(406) 741-2534**	**lonepinegeneralstore@yahoo.com**
Operator Contact:	Lindsey Herron;Rae Herman;Traci Salmi	**(406) 253-9240;(406) 471-2766;(406) 741-3454**	**lonepinegeneralstore@yahoo.com;rherman@hotsprings.k12,mt.us**

Owner/Operator: Lonepine General Store LLC (406) 741-2534 lonepinegeneralstore@yahoo.com

Lindsey Herron, UST Class A Operator	lonepinegeneralstore@yahoo.com
Lindsey Herron, UST Class B Operator	lonepinegeneralstore@yahoo.com
Rae Herman, UST Class A Operator	rherman@hotsprings.k12,mt.us
Rae Herman, UST Class B Operator	rherman@hotsprings.k12,mt.us
Traci Salmi, UST Class A Operator	lonepinegeneralstore@yahoo.com
Traci Salmi, UST Class B Operator	lonepinegeneralstore@yahoo.com

Tank Number	01	**Tank Age**	33	**Tank Installed Date**	06/01/1992	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	3536	**Spill Test Date**	03/16/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	03/16/2022	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	03/16/2022	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	03/16/2022	**Line Tightness Test Date**	03/16/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	03/16/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-300				
Tank Number	02	**Tank Age**	33	**Tank Installed Date**	06/01/1992	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	3537	**Spill Test Date**	03/16/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	03/16/2022	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	03/16/2022	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**	03/16/2022	**Line Tightness Test Date**	03/16/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No

		Overfill Test Date	03/16/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-300				
Tank Number	03	**Tank Age**	33	**Tank Installed Date**	06/01/1992	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	3538	**Spill Test Date**	03/16/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	03/16/2022	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Diesel, Dyed	**PLLD Test Date**		**Tank/Piping CP Test Date**	03/16/2022	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	03/16/2022	**Line Tightness Test Date**	03/16/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	03/16/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-300				

Facility Summary in Sanders County in the City of Hot Springs

Location: ONE STOP 3 INC LOC 473
1893 MT Hwy 28
Hot Springs, MT 59845 Sanders

System Facility ID:45-12871

Facility Code: 27881
Last Inspected On: 05/29/2023
Operating Permit Renewal Date: 08/13/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	One Stop 3 Inc	**(406) 279-3600**	**one-stop@outlook.com**
Operator Contact:	Carmen Carr;Danielle Chesley;Dianna Garcia;One Stop 3 Inc;Jan Montgomery;Jeffrey Jung;Manford Tempero;Pandora Fasciana;Sandra Brown	**(406) 279-3600;(406) 741-3200;(406) 741-3215;(406) 885-1406**	**cornerstone@gmail.com;cornerstone59903@gmail.com;jeff1jung@gmail.com;mmtent@hotsprgs.net;mrs.dmgarcia91@gmail.com;one-stop@outlook.com;northwestnovelties@yahoo.com;pandoraf@gmail.com**

Owner/Operator: One Stop 3 Inc (406) 279-3600 one-stop@outlook.com

Carmen Carr, UST Class A Operator	cornerstone@gmail.com
Carmen Carr, UST Class B Operator	cornerstone@gmail.com
Danielle Chesley, UST Class A Operator	northwestnovelties@yahoo.com
Danielle Chesley, UST Class B Global Operator	northwestnovelties@yahoo.com
Dianna Garcia, UST Class A Operator	one-stop@outlook.com
Dianna Garcia, UST Class B Operator	one-stop@outlook.com
Jan Montgomery, UST Class A Operator	cornerstone59903@gmail.com
Jan Montgomery, UST Class B Operator	cornerstone59903@gmail.com
Jeffrey J Jung, UST Class A Operator	jeff1jung@gmail.com
Jeffrey J Jung, UST Class B Operator	jeff1jung@gmail.com
Jetta Aldridge, UST Class B Operator	almosta@hotsprgs.net
Manford Tempero, UST Class A Operator	mmtent@hotsprgs.net
Manford Tempero, UST Class B Operator	mmtent@hotsprgs.net
Pandora Fasciana, UST Class A Operator	pandoraf@gmail.com
Sandra Brown, UST Class A Operator	cornerstone59903@gmail.com
Sandra Brown, UST Class B Operator	cornerstone59903@gmail.com

Tank Number	03	**Tank Age**	29	**Tank Installed Date**	05/01/1996	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve
Tag Number	2984	**Spill Test Date**	04/06/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	12/14/2022	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	12/14/2022	**Line Tightness Test Date**	12/14/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No

		Overfill Test Date	05/25/2023			**ATG Type**	Incon/TS-1000				
Tank Number	04	**Tank Age**	29	**Tank Installed Date**	05/01/1996	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve
Tag Number	2985	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	06/22/2020	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**		**Line Tightness Test Date**	06/22/2020	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**	Incon/TS-1000				
Tank Number	05	**Tank Age**	29	**Tank Installed Date**	05/01/1996	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve
Tag Number	2986	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	06/22/2020	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**		**Line Tightness Test Date**	06/22/2020	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**	Incon/TS-1000				
Tank Number	06	**Tank Age**	29	**Tank Installed Date**	06/01/1996	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve
Tag Number	2987	**Spill Test Date**	12/04/2019	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	06/22/2020	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**		**Line Tightness Test Date**	06/22/2020	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**	Incon/TS-1000				

Facility Summary in Sanders County in the City of Noxon

Location: AITKENS QUIK STOP INC NOXON
1402 MT Hwy 200 W
Noxon, MT 59853-9750 Sanders

System Facility ID:56-13810

Facility Code: 30497
Last Inspected On: 04/23/2025
Operating Permit Renewal Date: 10/17/2025

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Aitkens Quik Stop Inc **(406) 847-9191**

Operator Contact: Jeffrey Aitken;Travis Tammaro **(406) 396-4804;(406) 847-4080** **AITKEN@BLACKFOOT.NET;tammarot@gmail.com**

Owner/Operator: Aitkens Quik Stop Inc (406) 847-9191

Jeffrey Aitken, UST Class A Operator	AITKEN@BLACKFOOT.NET
Jeffrey Aitken, UST Class B Operator	AITKEN@BLACKFOOT.NET
Travis Tammaro, UST Class A Operator	tammarot@gmail.com
Travis Tammaro, UST Class B Global Operator	tammarot@gmail.com

Tank Number	01	**Tank Age**	28	**Tank Installed Date**	10/01/1997	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	4484	**Spill Test Date**	05/05/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**	05/05/2022	**Tank/Piping CP Test Date**	05/05/2022	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	05/05/2022	**Line Tightness Test Date**	05/10/2019	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	05/05/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	02	**Tank Age**	28	**Tank Installed Date**	10/01/1997	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	4485	**Spill Test Date**	06/24/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**	05/05/2022	**Tank/Piping CP Test Date**	05/05/2022	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	05/05/2022	**Line Tightness Test Date**	05/22/2019	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	06/24/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Tank Number	03	**Tank Age**	28	**Tank Installed Date**	10/01/1997	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	4486	**Spill Test Date**	06/24/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**	05/05/2022	**Tank/Piping CP Test Date**	05/05/2022	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	05/05/2022	**Line Tightness Test Date**	09/20/2019	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	06/24/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Sanders County in the City of Paradise

Location: PARADISE SCHOOL DIST 8
20 School House Hill Rd
Paradise, MT 59856 Sanders

System Facility ID:45-08864

Facility Code: 27812
Last Inspected On: 09/25/2020
Operating Permit Renewal Date: 10/17/2023

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Sanders County Commissioners **(406) 827-6942** **smaciel@co.sanders.mt.us**

Operator Contact: David Colyer **(406) 826-3679**

Owner/Operator: Sanders County Commissioners (406) 827-6942 smaciel@co.sanders.mt.us

David Colyer, UST Class A Operator

David Colyer, UST Class B Operator

Tank Number	S2	**Tank Age**	27	**Tank Installed Date**	07/30/1998	**Tank Material Construction**	Unknown	**Piping Material**	Copper	**Overfill Types**	
Tag Number	1782	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	PVC	**AST**	Yes
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	09/25/2020	**Catastrophic L.D. Type 3.0**	Auto Dialer	**Piping Type**	U.S. Suction	**CP Met Types**	
Product	Heating Oil	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	1000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					

Facility Summary in Sanders County in the City of Plains

Location: PLAINS TRAVEL PLAZA
100 E Railroad Ave
Plains, MT 59859 Sanders

System Facility ID:45-01147

Facility Code: 27721
Last Inspected On: 03/21/2025
Operating Permit Renewal Date: 06/30/2028

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Plains Properties LLC **(509) 883-6629** **tindic15@gmail.com**

Operator Contact:

Owner/Operator: Plains Properties LLC (509) 883-6629 tindic15@gmail.com

Tank Number	07	**Tank Age**	27	**Tank Installed Date**	12/01/1998	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	3594	**Spill Test Date**	03/21/2025	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	03/21/2025	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	5000	**ATG Test Date**	03/21/2025	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	03/21/2025			**ATG Type**	Gilbarco/EMC				
Tank Number	08	**Tank Age**	27	**Tank Installed Date**	12/01/1998	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	3595	**Spill Test Date**	03/21/2025	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel, Dyed	**PLLD Test Date**	03/21/2025	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	03/21/2025	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	03/21/2025			**ATG Type**	Gilbarco/EMC				
Tank Number	09	**Tank Age**	27	**Tank Installed Date**	12/01/1998	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve

Tag Number	3596	**Spill Test Date**	03/21/2025	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel, Dyed	**PLLD Test Date**	03/21/2025	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	5000	**ATG Test Date**	03/21/2025	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	03/21/2025			**ATG Type**	Gilbarco/EMC				
Tank Number	10	**Tank Age**	27	**Tank Installed Date**	12/01/1998	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	3597	**Spill Test Date**	04/04/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	09/29/2021	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	09/29/2021	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	09/29/2021			**ATG Type**	Gilbarco/EMC Basic				
Tank Number	11	**Tank Age**	27	**Tank Installed Date**	12/01/1998	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	3598	**Spill Test Date**	09/29/2021	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	09/29/2021	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	5000	**ATG Test Date**	09/29/2021	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	09/29/2021			**ATG Type**	Gilbarco/EMC Basic				

Facility Summary in Sanders County in the City of Plains

Location: TOWN PUMP INC PLAINS
335 Railroad Ave
Plains, MT 59859 Sanders

System Facility ID:45-08716

Facility Code: 27807
Last Inspected On: 04/29/2016
Operating Permit Renewal Date: 08/24/2019

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Plains 1 Town Pump LLC;Plains Town Pump Inc **(406) 497-6700;(406) 497-6948** **done@townpump.com;environmental@townpump.com**

Operator Contact:

Don Edmisten, UST Class B Global Operator done@townpump.com
Don Edmisten, UST Class B Global Operator done@townpump.com
Don Edmisten, UST Class B Global Operator done@townpump.com

Tank Number	01	**Tank Age**	59	**Tank Installed Date**	04/14/1966	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	2610	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Not Listed	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	04/27/2016	**Primary Tank Leak Detection**	Approved Remote Monitoring;Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Approved Remote Monitoring;Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	24000	**ATG Test Date**		**Line Tightness Test Date**	01/25/2006	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	02	**Tank Age**	59	**Tank Installed Date**	04/14/1966	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	2611	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Not Listed	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	04/27/2016	**Primary Tank Leak Detection**	Approved Remote Monitoring;Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Approved Remote Monitoring;Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**		**Line Tightness Test Date**	01/25/2006	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					

Tank Number	03	**Tank Age**	49	**Tank Installed Date**	04/14/1976	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	2612	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Not Listed	**CP Met Types**	Impressed Current
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	04/27/2016	**Primary Tank Leak Detection**	Approved Remote Monitoring;Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Approved Remote Monitoring;Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	24000	**ATG Test Date**		**Line Tightness Test Date**	01/26/2006	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	04	**Tank Age**	39	**Tank Installed Date**	04/14/1986	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	2613	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Not Listed	**CP Met Types**	Impressed Current
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	04/27/2016	**Primary Tank Leak Detection**	Approved Remote Monitoring;Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Approved Remote Monitoring;Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	16000	**ATG Test Date**		**Line Tightness Test Date**	01/26/2006	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					

Facility Summary in Sanders County in the City of Plains

Location: TOWN PUMP OF PLAINS
325 E Railroad Ave
Plains, MT 59859 Sanders

System Facility ID:45-03803

Facility Code: 27764
Last Inspected On: 04/27/2023
Operating Permit Renewal Date: 09/28/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Plains 1 Town Pump LLC	**(406) 497-6700**	**environmental@townpump.com**
Operator Contact:	Trent Biggers		**Trentb@townpump.com**

Owner/Operator:	Plains 1 Town Pump LLC	(406) 497-6700	environmental@townpump.com
	Trent Biggers, UST Class A Operator		Trentb@townpump.com
	Trent Biggers, UST Class A Operator		Trentb@townpump.com
	Trent Biggers, UST Class B Operator		Trentb@townpump.com
	Trent Biggers, UST Class B Operator		Trentb@townpump.com

Tank Number	07	**Tank Age**	0	**Tank Installed Date**		**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	4510	**Spill Test Date**	08/11/2022	**Piping Installed Date**	11/15/2018	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	08/11/2022	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**	04/27/2023	**Tank/Piping CP Test Date**	08/11/2022	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	04/27/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	No
		Overfill Test Date	08/11/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-450				
Tank Number	08	**Tank Age**	26	**Tank Installed Date**	02/01/1999	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	4511	**Spill Test Date**	01/18/2023	**Piping Installed Date**	11/15/2018	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	08/11/2022	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**	04/27/2023	**Tank/Piping CP Test Date**	08/11/2022	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**	04/27/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	No
		Overfill Test Date	08/11/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-450				

Tank Number	09	**Tank Age**	26	**Tank Installed Date**	02/01/1999	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	4512	**Spill Test Date**	08/11/2022	**Piping Installed Date**	11/15/2018	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	08/11/2022	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**	04/27/2023	**Tank/Piping CP Test Date**	08/11/2022	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**	04/27/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	No
		Overfill Test Date	08/11/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-450				
Tank Number	10	**Tank Age**	7	**Tank Installed Date**	11/15/2018	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	5810	**Spill Test Date**	08/11/2022	**Piping Installed Date**	11/15/2018	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	08/11/2022	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	04/27/2023	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	20000	**ATG Test Date**	04/27/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Statistical Inventory Reconciliation	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	Yes
		Overfill Test Date	08/11/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-450				
Tank Number	11	**Tank Age**	7	**Tank Installed Date**	11/15/2018	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	5811	**Spill Test Date**	08/11/2022	**Piping Installed Date**	11/15/2018	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	08/11/2022	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	04/27/2023	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**	04/27/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Statistical Inventory Reconciliation	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	Yes
		Overfill Test Date	08/11/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-450				
Tank Number	12	**Tank Age**	7	**Tank Installed Date**	11/15/2018	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	5812	**Spill Test Date**	08/11/2022	**Piping Installed Date**	11/15/2018	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	08/11/2022	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible

Product	Diesel	**PLLD Test Date**	04/27/2023	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	18000	**ATG Test Date**	04/27/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Statistical Inventory Reconciliation	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	Yes
		Overfill Test Date	08/11/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-450				
Tank Number	13	**Tank Age**	7	**Tank Installed Date**	11/15/2018	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	5813	**Spill Test Date**	08/11/2022	**Piping Installed Date**	11/15/2018	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	08/11/2022	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	04/27/2023	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**	04/27/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Statistical Inventory Reconciliation	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	Yes
		Overfill Test Date	08/11/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-450				

Facility Summary in Sanders County in the City of Thompson Falls

Location: EAST END FUEL INC
5236 MT Hwy 200
Thompson Falls, MT 59873-9417 Sanders

System Facility ID:45-13460

Facility Code: 27893
Last Inspected On: 09/21/2023
Operating Permit Renewal Date: 10/17/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	East End Fuel Inc.	**(406) 546-8430**	**eastendfuel71@gmail.com**
Operator Contact:	Bobbie Rasmussen;Bridget Knerr;East End Fuel Inc.;John Hoy;East End Fuel Inc.;Kimberly Pardee;East End Fuel Inc.	**(406) 210-0872;(406) 490-4245;(406) 546-8430;(406) 529-8406;(406) 546-8430;(406) 546-8430;(406) 546-8430**	**eastendfuel71@gmail.com;eastendfuel71@gmail.com;menmychillins3@gmail.com;pardeekim12@gmail.com;eastendfuel71@gmail.com;thenaturalhand@yahoo.com;eastendfuel71@gmail.com**

Owner/Operator: East End Fuel Inc. (406) 546-8430 eastendfuel71@gmail.com

Bobbie Rasmussen, UST Class A Operator	menmychillins3@gmail.com
Bobbie Rasmussen, UST Class B Operator	eastendfuel71@gmail.com
Bridget Knerr, UST Class A Operator	eastendfuel71@gmail.com
John Hoy, UST Class A Operator	eastendfuel71@gmail.com
Kimberly Pardee, UST Class A Operator	eastendfuel71@gmail.com
Kimberly Pardee, UST Class B Operator	eastendfuel71@gmail.com
Walter Klein, UST Class B Operator	eastendfuel71@gmail.com

Tank Number	01	**Tank Age**	31	**Tank Installed Date**	05/01/1994	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	2150	**Spill Test Date**	05/22/2023	**Piping Installed Date**	05/19/2023	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	05/22/2023	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date	05/22/2023			**ATG Type**	Franklin Fueling Systems/EVO 6000				
Tank Number	02	**Tank Age**	31	**Tank Installed Date**	05/01/1994	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	2151	**Spill Test Date**	05/22/2023	**Piping Installed Date**	05/19/2023	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	05/22/2023	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel, Dyed	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No

Capacity	10000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date	05/22/2023			**ATG Type**	Franklin Fueling Systems/EVO 6000				
Tank Number	03	**Tank Age**	31	**Tank Installed Date**	05/01/1994	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	2152	**Spill Test Date**	05/22/2023	**Piping Installed Date**	05/19/2023	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	05/22/2023	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date	05/22/2023			**ATG Type**	Franklin Fueling Systems/EVO 6000				
Tank Number	04	**Tank Age**	31	**Tank Installed Date**	05/01/1994	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	2153	**Spill Test Date**	05/22/2023	**Piping Installed Date**	05/19/2023	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	05/22/2023	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date	05/22/2023			**ATG Type**	Franklin Fueling Systems/EVO 6000				
Tank Number	05	**Tank Age**	2	**Tank Installed Date**	05/19/2023	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	6121	**Spill Test Date**	05/22/2023	**Piping Installed Date**	05/19/2023	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	05/22/2023	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	Yes
Capacity	20000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	05/22/2023			**ATG Type**					

Tank Number	06	**Tank Age**	2	**Tank Installed Date**	05/19/2023	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	6122	**Spill Test Date**	05/22/2023	**Piping Installed Date**	05/19/2023	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	05/22/2023	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	20000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	05/22/2023			**ATG Type**					
Tank Number	07	**Tank Age**	2	**Tank Installed Date**	05/19/2023	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	6123	**Spill Test Date**	05/22/2023	**Piping Installed Date**	05/19/2023	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	05/22/2023	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Gasoline, E10	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	Yes
Capacity	8000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	05/22/2023			**ATG Type**					

Facility Summary in Sanders County in the City of Thompson Falls

Location: ELEMENTARY SCHOOL
315 S Columbia St
Thompson Falls, MT 59873 Sanders

System Facility ID:45-08537

Facility Code: 27806
Last Inspected On: 12/11/2023
Operating Permit Renewal Date: 12/11/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: School Dist 2 Thompson Falls

Operator Contact: Mike Bates

Owner/Operator: School Dist 2 Thompson Falls

Mike Bates, UST Class A Operator
Mike Bates, UST Class B Operator

Tank Number	S3	**Tank Age**	33	**Tank Installed Date**	08/01/1992	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Steel	**Overfill Types**	Flapper Valve
Tag Number	1887	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Temporarily Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Auto Dialer	**Piping Type**	U.S. Suction	**CP Met Types**	Galvanic
Product	Heating Oil	**PLLD Test Date**		**Tank/Piping CP Test Date**	12/07/2023	**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Sanders County in the City of Thompson Falls

Location: MOODYS MARKET HARVEST FOODS
5254 MT Hwy 200
Thompson Falls, MT 59873-0880 Sanders

System Facility ID:56-14114

Facility Code: 30755
Last Inspected On: 01/16/2025
Operating Permit Renewal Date: 03/02/2028

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Gregory Hurtz	**(406) 827-4321**	**harvest@blackfoot.net**
Operator Contact:	Donald Lake;Michelle Mayfield;Richard Fargher	**(406) 721-3719**	**jimval422@gmail.com;lake72c@gmail.com;Wiggs1sm@gmail.com**

Owner/Operator: Gregory Hurtz (406) 827-4321 harvest@blackfoot.net

Donald Lake, UST Class A Operator	lake72c@gmail.com
Donald Lake, UST Class B Operator	lake72c@gmail.com
Michelle Mayfield, UST Class A Operator	Wiggs1sm@gmail.com
Michelle Mayfield, UST Class B Operator	Wiggs1sm@gmail.com
Richard Fargher, UST Class A Operator	jimval422@gmail.com
Richard Fargher, UST Class B Operator	jimval422@gmail.com

Tank Number	01	**Tank Age**	22	**Tank Installed Date**	11/04/2003	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve
Tag Number	4868	**Spill Test Date**	01/16/2025	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	01/16/2025	**Sump Tightness Test Date**	01/16/2025	**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	01/16/2025	**Line Tightness Test Date**	05/19/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	01/16/2025			**ATG Type**	Veeder Root/TLS-300				
Tank Number	02	**Tank Age**	22	**Tank Installed Date**	11/04/2003	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve
Tag Number	4869	**Spill Test Date**	01/16/2025	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	01/16/2025	**Sump Tightness Test Date**	01/16/2025	**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	5000	**ATG Test Date**	01/16/2025	**Line Tightness Test Date**	05/19/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No

		Overfill Test Date	01/16/2025			**ATG Type**	Veeder Root/TLS-300				
Tank Number	03	**Tank Age**	22	**Tank Installed Date**	11/04/2003	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve
Tag Number	4870	**Spill Test Date**	01/16/2025	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	01/16/2025	**Sump Tightness Test Date**	01/16/2025	**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	01/16/2025	**Line Tightness Test Date**	05/19/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	01/16/2025			**ATG Type**	Veeder Root/TLS-300				

Facility Summary in Sanders County in the City of Thompson Falls

Location: THOMPSON FALLS FEED AND FUEL LLC
1201 Main St
Thompson Falls, MT 59873 Sanders

System Facility ID:45-02633

Facility Code: 27741
Last Inspected On: 10/31/2023
Operating Permit Renewal Date: 12/02/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Thompson Falls Feed and Fuel LLC

Operator Contact: Carole Jensen **(406) 827-4325** **feedfuel2426@yahoo.com**

Owner/Operator: Thompson Falls Feed and Fuel LLC

Carole Jensen, UST Class A Operator feedfuel2426@yahoo.com
Carole Jensen, UST Class B Operator feedfuel2426@yahoo.com

Tank Number	01	**Tank Age**	37	**Tank Installed Date**	04/01/1988	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	3203	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	11/13/2020	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	11/13/2020	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**		**Line Tightness Test Date**	11/13/2020	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**	Veeder Root/TLS-300				
Tank Number	02	**Tank Age**	37	**Tank Installed Date**	04/01/1988	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	3204	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	11/13/2020	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	11/13/2020	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**		**Line Tightness Test Date**	11/13/2020	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**	Veeder Root/TLS-300				
Tank Number	03	**Tank Age**	37	**Tank Installed Date**	04/01/1988	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	3205	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No

Status	**Currently in Use**	**MLLD Test Date**	11/13/2020	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	11/13/2020	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**		**Line Tightness Test Date**	11/13/2020	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**	Veeder Root/TLS-300				
Tank Number	04	**Tank Age**	37	**Tank Installed Date**	04/01/1988	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	3206	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	11/13/2020	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	11/13/2020	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**		**Line Tightness Test Date**	11/13/2020	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**	Veeder Root/TLS-300				

Facility Summary in Sanders County in the City of Thompson Falls

Location: TOWN PUMP INC THOMPSON FALLS
1301 W Main St
Thompson Falls, MT 59873 Sanders

System Facility ID:45-08720

Facility Code: 27808
Last Inspected On: 04/27/2023
Operating Permit Renewal Date: 10/02/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Thompson Falls 1 Town Pump LLC;Town Pump Inc Thompson Falls	**(406) 497-6700**	**environmental@townpump.com**
Operator Contact:	Trent Biggers		**Trentb@townpump.com**

Owner/Operator:	Thompson Falls 1 Town Pump LLC	(406) 497-6700	environmental@townpump.com
Owner/Operator:	Town Pump Inc Thompson Falls	(406) 497-6700	environmental@townpump.com
	Trent Biggers, UST Class A Operator		Trentb@townpump.com
	Trent Biggers, UST Class A Operator		Trentb@townpump.com
	Trent Biggers, UST Class B Global Operator		Trentb@townpump.com
	Trent Biggers, UST Class B Global Operator		Trentb@townpump.com

Tank Number	04	**Tank Age**	45	**Tank Installed Date**	04/14/1980	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve
Tag Number	2614	**Spill Test Date**	08/10/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**	06/22/2021	**Tank/Piping CP Test Date**	08/09/2022	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	04/27/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	08/10/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350				
Tank Number	05	**Tank Age**	35	**Tank Installed Date**	04/27/1990	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve
Tag Number	2615	**Spill Test Date**	08/10/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	06/22/2021	**Tank/Piping CP Test Date**	12/01/2012	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No

Capacity	10000	**ATG Test Date**	04/27/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	08/10/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350				
Tank Number	06	**Tank Age**	35	**Tank Installed Date**	04/27/1990	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve
Tag Number	2616	**Spill Test Date**	08/10/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	06/22/2021	**Tank/Piping CP Test Date**	12/01/2012	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	04/27/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	08/10/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350				
Tank Number	07	**Tank Age**	35	**Tank Installed Date**	04/27/1990	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	2617	**Spill Test Date**	08/10/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	06/22/2021	**Tank/Piping CP Test Date**	12/01/2012	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	04/27/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	08/10/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350				
Tank Number	08	**Tank Age**	26	**Tank Installed Date**	10/01/1999	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	4115	**Spill Test Date**	08/10/2022	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Temporarily Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	06/22/2021	**Tank/Piping CP Test Date**	12/01/2012	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	04/27/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	08/10/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350				

Tank Number	09	**Tank Age**	26	**Tank Installed Date**	10/01/1999	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	4116	**Spill Test Date**	08/10/2022	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Temporarily Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	06/22/2021	**Tank/Piping CP Test Date**	12/01/2012	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	5000	**ATG Test Date**	04/27/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	08/10/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350				
Tank Number	10	**Tank Age**	0	**Tank Installed Date**		**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve
Tag Number	4932	**Spill Test Date**	08/10/2022	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	06/22/2021	**Tank/Piping CP Test Date**	12/01/2012	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	20000	**ATG Test Date**	04/27/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	08/10/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Sanders County in the City of Trout Creek

Location: TROUT CREEK LOCAL STORE INC
2954 MT Hwy 200
Trout Creek, MT 59874-9564 Sanders

System Facility ID:45-10228

Facility Code: 27844
Last Inspected On: 05/27/2023
Operating Permit Renewal Date: 08/07/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	The Local Store Inc	**(208) 610-5396**	**troutcreekstore@gmail.com**
Operator Contact:	John Fitchett;Michele Tammaro	**(208) 610-5396**	**tclsinc@gmail.com;troutcreekstore@gmail.com**

Owner/Operator: The Local Store Inc (208) 610-5396 troutcreekstore@gmail.com

John Fitchett, UST Class A Operator troutcreekstore@gmail.com
John Fitchett, UST Class B Operator troutcreekstore@gmail.com
Michele Tammaro, UST Class A Operator tclsinc@gmail.com
Michele Tammaro, UST Class B Operator tclsinc@gmail.com

Tank Number	03	**Tank Age**	36	**Tank Installed Date**	12/04/1989	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Steel	**Overfill Types**	Flapper Valve
Tag Number	1607	**Spill Test Date**	03/30/2023	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	06/28/2020	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	03/30/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	3000	**ATG Test Date**	03/30/2023	**Line Tightness Test Date**	06/28/2020	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	03/30/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-300				
Tank Number	04	**Tank Age**	27	**Tank Installed Date**	12/01/1998	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Steel	**Overfill Types**	Flapper Valve
Tag Number	1608	**Spill Test Date**	03/30/2023	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	03/30/2023	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	03/30/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	3000	**ATG Test Date**	03/30/2023	**Line Tightness Test Date**	03/30/2023	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	03/30/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Tank Number	S5	**Tank Age**	36	**Tank Installed Date**	12/01/1989	**Tank Material Construction**	Not Listed	**Piping Material**	Steel	**Overfill Types**	
Tag Number	5682	**Spill Test Date**	03/30/2023	**Piping Installed Date**	12/01/1989	**Tank Construction**		**Piping Construction**	None	**AST**	Yes
Status	**Currently in Use**	**MLLD Test Date**	03/30/2023	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	03/30/2023	**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	3000	**ATG Test Date**	03/30/2023	**Line Tightness Test Date**	03/30/2023	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	03/30/2023			**ATG Type**					

Facility Summary in Sanders County in the City of Trout Creek

Location: TROUT CREEK QUIK STOP
2950 MT Hwy 200
Trout Creek, MT 59874 Sanders

System Facility ID:56-14146

Facility Code: 30782
Last Inspected On: 01/26/2023
Operating Permit Renewal Date: 04/28/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	TC Quick Stop Inc	**(406) 396-4804**	**tammarot@gmail.com**
Operator Contact:	Tanner Tammaro;Tiffany Yee	**(406) 396-4949**	**tanner.tammaro@gmail.com**

Owner/Operator: TC Quick Stop Inc (406) 396-4804 tammarot@gmail.com

Cayla Emerson, UST Class B Operator	tclsinc@gmail.com
Tanner Tammaro, UST Class A Operator	tanner.tammaro@gmail.com
Tanner Tammaro, UST Class B Operator	tanner.tammaro@gmail.com
Tiffany Yee, UST Class A Operator	
Tiffany Yee, UST Class B Global Operator	

Tank Number	01	**Tank Age**	20	**Tank Installed Date**	04/21/2005	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve
Tag Number	4946	**Spill Test Date**	03/08/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Continuous Interstitial Monitoring;Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	10/05/2022	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	10/01/2021			**ATG Type**	Gilbarco/EMC Basic				
Tank Number	02	**Tank Age**	20	**Tank Installed Date**	04/21/2005	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve
Tag Number	4947	**Spill Test Date**	10/01/2021	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Continuous Interstitial Monitoring;Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible

Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	10/05/2022	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	10/01/2021			**ATG Type**	Gilbarco/EMC Basic				
Tank Number	03	**Tank Age**	20	**Tank Installed Date**	04/21/2005	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve
Tag Number	4948	**Spill Test Date**	10/01/2021	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Continuous Interstitial Monitoring;Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel, Dyed	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	10/05/2022	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	10/01/2021			**ATG Type**	Gilbarco/EMC Basic				
Tank Number	04	**Tank Age**	20	**Tank Installed Date**	04/21/2005	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve
Tag Number	4949	**Spill Test Date**	03/08/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Continuous Interstitial Monitoring;Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	10/05/2022	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	10/01/2021			**ATG Type**	Gilbarco/EMC Basic				

Facility Summary in Sanders County in the City of Trout Creek

Location: TROUT CREEK SCHOOL DIST 6
4 School Ln
Trout Creek, MT 59874 Sanders

System Facility ID:45-07647

Facility Code: 27802
Last Inspected On: 01/18/2023
Operating Permit Renewal Date: 04/08/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: School Dist 6 Trout Creek **(406) 827-3629**

Operator Contact: David Eldridge;School Dist 6 Trout Creek **(406) 827-3629** **deldridge@troutcreekeagles.org**

Owner/Operator: School Dist 6 Trout Creek (406) 827-3629

David Eldridge, UST Class A Operator deldridge@troutcreekeagles.org
David Eldridge, UST Class B Operator deldridge@troutcreekeagles.org

Tank Number	S2	**Tank Age**	32	**Tank Installed Date**	08/01/1993	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Copper	**Overfill Types**	Flapper Valve
Tag Number	2146	**Spill Test Date**	10/04/2022	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Secondary Containment Chase	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	11/20/2019	**Catastrophic L.D. Type 3.0**	Auto Dialer	**Piping Type**	U.S. Suction	**CP Met Types**	Galvanic
Product	Heating Oil	**PLLD Test Date**		**Tank/Piping CP Test Date**	10/04/2022	**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	1000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	10/04/2022			**ATG Type**					

Facility Summary in Sheridan County in the City of Medicine Lake

Location: LAKE PIT STOP
729 Main St
Medicine Lake, MT 59247 Sheridan

System Facility ID:46-01127

Facility Code: 27958
Last Inspected On: 01/30/2025
Operating Permit Renewal Date: 03/30/2028

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Chanel Johnson;Lake Pit Stop LLC	**(406) 789-2242**	**bcjfarm@hotmail.com;dbjfarm@nemont.net**
Operator Contact:	James BoBo	**(406) 480-5957**	**southlaketrucking@hotmail.com**

Owner/Operator: Chanel Johnson bcjfarm@hotmail.com

Owner/Operator: Lake Pit Stop LLC bcjfarm@hotmail.com

Chanel Johnson, UST Class B Operator bcjfarm@hotmail.com
Chanel Johnson, UST Class B Operator bcjfarm@hotmail.com
James BoBo, UST Class A Operator southlaketrucking@hotmail.com
James BoBo, UST Class B Operator southlaketrucking@hotmail.com

Tank Number	S6	**Tank Age**	28	**Tank Installed Date**	10/01/1997	**Tank Material Construction**	Unknown	**Piping Material**	Flexible Plastic	**Overfill Types**	
Tag Number	2323	**Spill Test Date**		**Piping Installed Date**	06/03/2013	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	Yes
Status	**Currently in Use**	**MLLD Test Date**	12/15/2021	**Sump Tightness Test Date**	01/30/2025	**Catastrophic L.D. Type 3.0**	Continuous Interstitial Monitoring;Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Deferred	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	15000	**ATG Test Date**		**Line Tightness Test Date**	04/24/2015	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	Yes
		Overfill Test Date				**ATG Type**					
Tank Number	S7	**Tank Age**	28	**Tank Installed Date**	10/01/1997	**Tank Material Construction**	Unknown	**Piping Material**	Flexible Plastic	**Overfill Types**	
Tag Number	2324	**Spill Test Date**		**Piping Installed Date**	06/03/2013	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	Yes
Status	**Currently in Use**	**MLLD Test Date**	12/15/2021	**Sump Tightness Test Date**	01/30/2025	**Catastrophic L.D. Type 3.0**	Continuous Interstitial Monitoring;Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	

Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Deferred	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**		**Line Tightness Test Date**	04/24/2015	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	Yes
		Overfill Test Date				**ATG Type**					
Tank Number	S8	**Tank Age**	28	**Tank Installed Date**	10/01/1997	**Tank Material Construction**	Unknown	**Piping Material**	Flexible Plastic	**Overfill Types**	
Tag Number	2325	**Spill Test Date**		**Piping Installed Date**	06/03/2013	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	Yes
Status	**Currently in Use**	**MLLD Test Date**	01/30/2025	**Sump Tightness Test Date**	01/30/2025	**Catastrophic L.D. Type 3.0**	Continuous Interstitial Monitoring;Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Deferred	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**		**Line Tightness Test Date**	04/24/2015	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	Yes
		Overfill Test Date				**ATG Type**					
Tank Number	S9	**Tank Age**	28	**Tank Installed Date**	10/01/1997	**Tank Material Construction**	Unknown	**Piping Material**	Flexible Plastic	**Overfill Types**	
Tag Number	2326	**Spill Test Date**		**Piping Installed Date**	06/03/2013	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	Yes
Status	**Currently in Use**	**MLLD Test Date**	12/15/2021	**Sump Tightness Test Date**	01/30/2025	**Catastrophic L.D. Type 3.0**	Continuous Interstitial Monitoring;Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Deferred	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**		**Line Tightness Test Date**	04/24/2015	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	Yes
		Overfill Test Date				**ATG Type**					

Facility Summary in Sheridan County in the City of Medicine Lake

Location: MEDICINE LAKE SCHOOL DIST 7
1 Young St
Medicine Lake, MT 59247 Sheridan

System Facility ID:46-01122

Facility Code: 27957
Last Inspected On: 03/11/2025
Operating Permit Renewal Date: 06/03/2028

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: School Dist 7 Medicine Lake **(406) 789-2211**

Operator Contact: Aaron Webster **(406) 789-2211** **awebster@medicinelake.k12.mt.us**

Owner/Operator: School Dist 7 Medicine Lake (406) 789-2211

Aaron Webster, UST Class A Operator awebster@medicinelake.k12.mt.us
Aaron Webster, UST Class B Global Operator awebster@medicinelake.k12.mt.us
Sandor Forizs, UST Class B Operator sforizs@medicinelake.k12.mt.us

Tank Number	S3	**Tank Age**	34	**Tank Installed Date**	08/01/1991	**Tank Material Construction**	Steel Clad	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	1603	**Spill Test Date**	03/11/2025	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	04/26/2019	**Catastrophic L.D. Type 3.0**	Auto Dialer	**Piping Type**	U.S. Suction	**CP Met Types**	Non-corrodible
Product	Heating Oil	**PLLD Test Date**		**Tank/Piping CP Test Date**	01/16/2014	**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	3-Year Line Tightness Test	**Vapor Recovery**	No
Capacity	10066	**ATG Test Date**	03/11/2025	**Line Tightness Test Date**	03/11/2025	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	03/11/2025			**ATG Type**	OPW / EMCO/EECO 1500				

Facility Summary in Sheridan County in the City of Plentywood

Location: AUTO TECH SERVICES
327 W 1st Ave
Plentywood, MT 59254-1802 Sheridan

System Facility ID:46-01524

Facility Code: 27977
Last Inspected On: 05/02/2024
Operating Permit Renewal Date: 04/21/2028

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Farmers Union Oil Co Plentywood	**(406) 765-1171**	**cenexpwd@hotmail.com**
Operator Contact:	James Kibbe;L Kibbe	**(406) 765-1180**	**cenexpwd@hotmail.com**

Owner/Operator:	Farmers Union Oil Co Plentywood	(406) 765-1171	cenexpwd@hotmail.com
	James Kibbe, UST Class A Operator		cenexpwd@hotmail.com
	James Kibbe, UST Class A Operator		cenexpwd@hotmail.com
	James Kibbe, UST Class B Global Operator		cenexpwd@hotmail.com
	James Kibbe, UST Class B Global Operator		cenexpwd@hotmail.com
	L James Kibbe, UST Class A Operator		cenexpwd@hotmail.com
	L James Kibbe, UST Class A Operator		cenexpwd@hotmail.com
	L James Kibbe, UST Class B Global Operator		cenexpwd@hotmail.com
	L James Kibbe, UST Class B Global Operator		cenexpwd@hotmail.com

Tank Number	08	**Tank Age**	36	**Tank Installed Date**	12/10/1989	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	1114	**Spill Test Date**	11/24/2023	**Piping Installed Date**	11/02/2023	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	11/24/2023	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Diesel, Dyed	**PLLD Test Date**	05/02/2024	**Tank/Piping CP Test Date**	10/09/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	05/02/2024	**Line Tightness Test Date**	11/07/2023	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date	11/07/2023			**ATG Type**	Veeder Root/TLS-450PLUS				
Tank Number	09	**Tank Age**	36	**Tank Installed Date**	12/10/1989	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	1115	**Spill Test Date**	11/24/2023	**Piping Installed Date**	11/02/2023	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	11/24/2023	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic

Product	Diesel	**PLLD Test Date**	05/02/2024	**Tank/Piping CP Test Date**	10/09/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	05/02/2024	**Line Tightness Test Date**	11/07/2023	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date	11/07/2023			**ATG Type**	Veeder Root/TLS-450PLUS				
Tank Number	10	**Tank Age**	36	**Tank Installed Date**	12/10/1989	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	1116	**Spill Test Date**	11/24/2023	**Piping Installed Date**	11/02/2023	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	11/24/2023	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**	05/02/2024	**Tank/Piping CP Test Date**	10/09/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	05/02/2024	**Line Tightness Test Date**	11/07/2023	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date	11/07/2023			**ATG Type**	Veeder Root/TLS-450PLUS				

Facility Summary in Sheridan County in the City of Plentywood

Location: FARMERS UNION OIL CO PLENTYWOOD
301 W 1st Ave
Plentywood, MT 59254-1802 Sheridan

System Facility ID:46-06801

Facility Code: 28147
Last Inspected On: 06/11/2024
Operating Permit Renewal Date: 08/23/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Farmers Union Oil Co Plentywood **(406) 765-1171** **cenexpwd@hotmail.com**

Operator Contact: L Kibbe **cenexpwd@hotmail.com**

Owner/Operator: Farmers Union Oil Co Plentywood (406) 765-1171 cenexpwd@hotmail.com

L James Kibbe, UST Class A Operator cenexpwd@hotmail.com
L James Kibbe, UST Class A Operator cenexpwd@hotmail.com
L James Kibbe, UST Class B Global Operator cenexpwd@hotmail.com
L James Kibbe, UST Class B Global Operator cenexpwd@hotmail.com

Tank Number	09	**Tank Age**	29	**Tank Installed Date**	06/01/1996	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	1038	**Spill Test Date**	09/27/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	06/13/2015	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**	06/02/2024	**Tank/Piping CP Test Date**	04/30/2025	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	20000	**ATG Test Date**	05/02/2024	**Line Tightness Test Date**	07/28/2016	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	09/30/2022			**ATG Type**	Veeder Root/TLS-450PLUS				
Tank Number	10	**Tank Age**	29	**Tank Installed Date**	06/01/1996	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	1039	**Spill Test Date**	09/27/2022	**Piping Installed Date**	05/20/2009	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	06/13/2015	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**	09/04/2024	**Tank/Piping CP Test Date**	09/28/2022	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	20000	**ATG Test Date**	05/02/2024	**Line Tightness Test Date**	07/28/2016	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	09/30/2022			**ATG Type**	Veeder Root/TLS-450PLUS				

Tank Number	11	**Tank Age**	29	**Tank Installed Date**	06/01/1996	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	1040	**Spill Test Date**	09/30/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	06/13/2015	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**	05/02/2024	**Tank/Piping CP Test Date**	09/28/2022	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	05/02/2024	**Line Tightness Test Date**	07/28/2016	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	09/30/2022			**ATG Type**	Veeder Root/TLS-450PLUS				
Tank Number	12	**Tank Age**	29	**Tank Installed Date**	06/01/1996	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	1041	**Spill Test Date**	09/27/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	06/13/2015	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**	05/02/2024	**Tank/Piping CP Test Date**	09/28/2022	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	05/02/2024	**Line Tightness Test Date**	03/24/2016	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	09/30/2022			**ATG Type**	Veeder Root/TLS-450PLUS				
Tank Number	13	**Tank Age**	29	**Tank Installed Date**	06/01/1996	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	1042	**Spill Test Date**	09/27/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	06/13/2015	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**	09/04/2024	**Tank/Piping CP Test Date**	09/28/2022	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	05/02/2024	**Line Tightness Test Date**	07/28/2016	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	09/30/2022			**ATG Type**	Veeder Root/TLS-450PLUS				
Tank Number	14	**Tank Age**	29	**Tank Installed Date**	06/01/1996	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	1043	**Spill Test Date**	09/27/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	06/13/2015	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic

Product	Diesel	**PLLD Test Date**	05/02/2024	**Tank/Piping CP Test Date**	09/28/2022	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	05/02/2024	**Line Tightness Test Date**	03/24/2016	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	09/30/2022			**ATG Type**	Veeder Root/TLS-450PLUS				
Tank Number	15	**Tank Age**	29	**Tank Installed Date**	06/01/1996	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	1044	**Spill Test Date**	09/27/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	06/13/2015	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**	09/04/2024	**Tank/Piping CP Test Date**	09/28/2024	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	05/02/2024	**Line Tightness Test Date**	03/24/2016	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	09/30/2022			**ATG Type**	Veeder Root/TLS-450PLUS				

Facility Summary in Sheridan County in the City of Plentywood

Location: MAVERIK PLENTYWOOD 5007
211 W 1st Ave
Plentywood, MT 59254-1830 Sheridan

System Facility ID:46-05200

Facility Code: 28101
Last Inspected On: 04/12/2023
Operating Permit Renewal Date: 09/10/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Kum and Go Store dba Maverik	**(801) 936-5557**	**environmental@maverik.com**
Operator Contact:	Aeon Long;Kevin Kautzman	**(701) 340-1435;(701) 609-1594**	**aeon.long@kumandgo.com;kek@kumandgo.com**

Owner/Operator:	Kum and Go Store dba Maverik	(801) 936-5557	environmental@maverik.com
	Aeon Long, UST Class A Operator		aeon.long@kumandgo.com
	Aeon Long, UST Class A Operator		aeon.long@kumandgo.com
	Aeon Long, UST Class A Operator		aeon.long@kumandgo.com
	Aeon Long, UST Class B Global Operator		aeon.long@kumandgo.com
	Aeon Long, UST Class B Global Operator		aeon.long@kumandgo.com
	Aeon Long, UST Class B Global Operator		aeon.long@kumandgo.com
	Kevin Kautzman, UST Class A Operator		kek@kumandgo.com
	Kevin Kautzman, UST Class A Operator		kek@kumandgo.com
	Kevin Kautzman, UST Class A Operator		kek@kumandgo.com
	Kevin Kautzman, UST Class B Global Operator		kek@kumandgo.com
	Kevin Kautzman, UST Class B Global Operator		kek@kumandgo.com
	Kevin Kautzman, UST Class B Global Operator		kek@kumandgo.com

Tank Number	03	**Tank Age**	43	**Tank Installed Date**	12/01/1982	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	1498	**Spill Test Date**	06/09/2020	**Piping Installed Date**	06/26/2009	**Tank Construction**	Lined Interior/Impressed Current	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	03/07/2023	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Diesel	**PLLD Test Date**	03/07/2023	**Tank/Piping CP Test Date**	04/12/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**	03/07/2023	**Line Tightness Test Date**	08/28/2014	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	01/03/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Number	05	**Tank Age**	37	**Tank Installed Date**	01/01/1988	**Tank Material Construction**	Bare Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve

Tag Number	1500	**Spill Test Date**	06/09/2020	**Piping Installed Date**	06/26/2009	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	03/07/2023	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**	03/07/2023	**Tank/Piping CP Test Date**	04/12/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	03/07/2023	**Line Tightness Test Date**	08/28/2014	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	09/27/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Number	04	**Tank Age**	37	**Tank Installed Date**	01/01/1988	**Tank Material Construction**	Bare Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	4358	**Spill Test Date**	06/09/2020	**Piping Installed Date**	06/26/2009	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	03/07/2023	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**	03/07/2023	**Tank/Piping CP Test Date**	04/12/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	03/07/2023	**Line Tightness Test Date**	08/28/2014	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	09/27/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				

Facility Summary in Sheridan County in the City of Plentywood

Location: MILLER OIL CO INC E RAILROAD AVE
416 W Railroad Ave
Plentywood, MT 59254 Sheridan

System Facility ID:46-08609

Facility Code: 28240
Last Inspected On: 10/23/2024
Operating Permit Renewal Date: 03/04/2028

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Miller Oil Co Inc Culbertson

Operator Contact: Kevin Miller;Matthew Miller **(406) 765-7730** **kevinmiller28@hotmail.com;mwmiller@nemont.net**

Owner/Operator: Miller Oil Co Inc Culbertson

Kevin Miller, UST Class A Operator	kevinmiller28@hotmail.com
Kevin Miller, UST Class B Operator	kevinmiller28@hotmail.com
Matthew Miller, UST Class A Operator	mwmiller@nemont.net
Matthew Miller, UST Class B Global Operator	mwmiller@nemont.net

Tank Number	S1	**Tank Age**	58	**Tank Installed Date**	04/08/1967	**Tank Material Construction**	Bare Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	
Tag Number	1617	**Spill Test Date**		**Piping Installed Date**	03/23/2009	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	Yes
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	06/18/2015	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	12048	**ATG Test Date**	10/23/2024	**Line Tightness Test Date**	08/05/2009	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	S2	**Tank Age**	64	**Tank Installed Date**	04/07/1961	**Tank Material Construction**	Bare Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	
Tag Number	1618	**Spill Test Date**		**Piping Installed Date**	03/23/2009	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	Yes
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	06/18/2015	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	08/08/2006	**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	5327	**ATG Test Date**	10/23/2024	**Line Tightness Test Date**	08/05/2009	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date				**ATG Type**					

Tank Number	S3	**Tank Age**	58	**Tank Installed Date**	04/08/1967	**Tank Material Construction**	Bare Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	
Tag Number	1619	**Spill Test Date**		**Piping Installed Date**	03/23/2009	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	Yes
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	06/18/2015	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	08/08/2006	**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	14848	**ATG Test Date**	10/23/2024	**Line Tightness Test Date**	08/05/2009	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	S4	**Tank Age**	57	**Tank Installed Date**	04/07/1968	**Tank Material Construction**	Bare Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	
Tag Number	1620	**Spill Test Date**		**Piping Installed Date**	03/23/2009	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	Yes
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	06/18/2015	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	08/08/2006	**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	14773	**ATG Test Date**	10/23/2024	**Line Tightness Test Date**	08/05/2009	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date				**ATG Type**					

Facility Summary in Sheridan County in the City of Plentywood

Location: MONTANA PIONEER MANOR INC
605 Sheridan St
Plentywood, MT 59254-1715 Sheridan

System Facility ID:46-10679

Facility Code: 28282
Last Inspected On: 03/11/2025
Operating Permit Renewal Date: 06/04/2028

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Montana Pioneer Manor Inc **(406) 765-1362** **pioneermanor@gmail.com**

Operator Contact:

Owner/Operator: Montana Pioneer Manor Inc (406) 765-1362 pioneermanor@gmail.com

Tank Number	S2	**Tank Age**	29	**Tank Installed Date**	05/01/1996	**Tank Material Construction**	Steel Clad	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	1673	**Spill Test Date**	03/11/2025	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	01/23/2019	**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	U.S. Suction	**CP Met Types**	Non-corrodible
Product	Heating Oil	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Manual Interstitial Monitoring	**Primary Pipe Leak Detection**	3-Year Line Tightness Test	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**		**Line Tightness Test Date**	03/11/2025	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Manual Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	03/11/2025			**ATG Type**					

Facility Summary in Sheridan County in the City of Plentywood

Location: SHERIDAN COUNTY
100 W Laurel Ave
Plentywood, MT 59254-1647 Sheridan

System Facility ID:46-06278

Facility Code: 28126
Last Inspected On: 04/12/2023
Operating Permit Renewal Date: 04/21/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Sheridan County Sanitarian	**(406) 765-2310**	
Operator Contact:	Arthur Kurk;Austin Tommerup;D. A. Michels;Gary Bartnes;Jerry Hendrickson;Monica Vines;Ricky Lagerquist	**(406) 489-2017;(406) 765-1221;(406) 765-2310;(406) 765-7046;(406) 765-7702;(406) 939-3719**	**2rlager@nemont.net;atommerup@sheridancountymt.gov;gbartnes@co.sheridan.mt.us;jhendrickson@co.sheridan.mt.us;monavines@hotmail.com;stefmichels@hotmail.com**

Owner/Operator: Sheridan County Sanitarian (406) 765-2310

Arthur Kurk, UST Class A Operator	
Austin Tommerup, UST Class A Operator	atommerup@sheridancountymt.gov
D. A. Michels, UST Class A Operator	stefmichels@hotmail.com
Gary Bartnes, UST Class A Operator	gbartnes@co.sheridan.mt.us
Gary Bartnes, UST Class B Global Operator	gbartnes@co.sheridan.mt.us
Jerry Hendrickson, UST Class A Operator	jhendrickson@co.sheridan.mt.us
Jody Lowe, UST Class B Operator	lowe83221@yahoo.com
Monica Vines, UST Class A Operator	monavines@hotmail.com
Ricky Lagerquist, UST Class A Operator	2rlager@nemont.net
Ryan Mitchell, UST Class B Operator	rmitchell@co.sheridan.mt.us

Tank Number	S2	**Tank Age**	30	**Tank Installed Date**	09/01/1995	**Tank Material Construction**	Steel Clad	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	1911	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Temporarily Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**	03/10/2020	**Catastrophic L.D. Type 3.0**	Auto Dialer	**Piping Type**	U.S. Suction	**CP Met Types**	Non-corrodible
Product	Heating Oil	**PLLD Test Date**		**Tank/Piping CP Test Date**	01/05/2011	**Primary Tank Leak Detection**	Manual Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**		**Line Tightness Test Date**	03/10/2020	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	3-Year Line Tightness Test	**Energy Act**	No
		Overfill Test Date				**ATG Type**					

Facility Summary in Sheridan County in the City of Plentywood

Location: SHERIDAN COUNTY SHOP
MT Hwy 16 E
Plentywood, MT 59254 Sheridan

System Facility ID:46-06279

Facility Code: 28127
Last Inspected On: 01/23/2023
Operating Permit Renewal Date: 02/19/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Sheridan County Sanitarian **(406) 765-2310**

Operator Contact: Arthur Kurk;Austin Tommerup **(406) 765-1221** **atommerup@sheridancountymt.gov**

Owner/Operator: Sheridan County Sanitarian (406) 765-2310

Arthur Kurk, UST Class A Operator
Arthur Kurk, UST Class A Operator
Austin Tommerup, UST Class A Operator atommerup@sheridancountymt.gov
Russell Christensen, UST Class B Operator rchristensen@sheridancountymt.gov
Russell Christensen, UST Class B Operator rchristensen@sheridancountymt.gov

Tank Number	05	**Tank Age**	35	**Tank Installed Date**	01/01/1990	**Tank Material Construction**	Steel Clad	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	1912	**Spill Test Date**	03/10/2020	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	01/05/2011	**Primary Tank Leak Detection**	Manual Interstitial Monitoring	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	01/23/2023			**ATG Type**					
Tank Number	06	**Tank Age**	35	**Tank Installed Date**	01/01/1990	**Tank Material Construction**	Steel Clad	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	1913	**Spill Test Date**	03/10/2020	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	01/05/2011	**Primary Tank Leak Detection**	Manual Interstitial Monitoring	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	10150	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	01/23/2023			**ATG Type**					

Tank Number	07	**Tank Age**	35	**Tank Installed Date**	01/01/1990	**Tank Material Construction**	Steel Clad	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	1914	**Spill Test Date**	03/10/2020	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	01/05/2011	**Primary Tank Leak Detection**	Manual Interstitial Monitoring	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	10150	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	01/23/2023			**ATG Type**					
Tank Number	08	**Tank Age**	35	**Tank Installed Date**	01/01/1990	**Tank Material Construction**	Steel Clad	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	
Tag Number	1915	**Spill Test Date**	03/10/2020	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	U.S. Suction	**CP Met Types**	Non-corrodible
Product	Oil, Waste	**PLLD Test Date**		**Tank/Piping CP Test Date**	01/05/2011	**Primary Tank Leak Detection**	Manual Interstitial Monitoring	**Primary Pipe Leak Detection**	3-Year Line Tightness Test	**Vapor Recovery**	No
Capacity	1002	**ATG Test Date**		**Line Tightness Test Date**	01/23/2023	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					

Facility Summary in Sheridan County in the City of Plentywood

Location: SHERIDAN MEMORIAL HOSPITAL
440 W Laurel Ave
Plentywood, MT 59254-1526 Sheridan

System Facility ID:46-00795

Facility Code: 27939
Last Inspected On: 03/11/2025
Operating Permit Renewal Date: 06/03/2028

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Sheridan Memorial Hospital

Operator Contact: Mark Brensdal;Murvin Anderson **(406) 765-2646;(406) 765-3700** **markb@nemontel.net;murvina@sheridanmemorial.net**

Owner/Operator: Sheridan Memorial Hospital

Athena Gardenier, UST Class B Global Operator	agardenier@sheridanmemorial.net
Athena Gardenier, UST Class B Operator	agardenier@sheridanmemorial.net
Mark Brensdal, UST Class A Operator	markb@nemontel.net
Martin Carlson, UST Class B Global Operator	
Murvin Anderson, UST Class A Operator	murvina@sheridanmemorial.net

Tank Number	S3	**Tank Age**	27	**Tank Installed Date**	10/01/1998	**Tank Material Construction**	Steel Clad	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	1918	**Spill Test Date**	03/11/2025	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	03/07/2022	**Catastrophic L.D. Type 3.0**	Auto Dialer	**Piping Type**	U.S. Suction	**CP Met Types**	Non-corrodible
Product	Heating Oil	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Manual Interstitial Monitoring	**Primary Pipe Leak Detection**	3-Year Line Tightness Test	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	03/11/2025	**Line Tightness Test Date**	03/11/2025	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	04/30/2025			**ATG Type**					

Facility Summary in Sheridan County in the City of Plentywood

Location: WELCOME STOP PLENTYWOOD, LLC
203 Raymond Rd
Plentywood, MT 59254-1545 Sheridan

System Facility ID:46-12667

Facility Code: 28312
Last Inspected On: 07/10/2024
Operating Permit Renewal Date: 11/13/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: John Gilligan **welcomestopjohn@hotmail.com**

Operator Contact: John Gilligan **welcomestopjohn@hotmail.com**

Owner/Operator: John Gilligan welcomestopjohn@hotmail.com

John Gilligan, UST Class A Operator welcomestopjohn@hotmail.com
John Gilligan, UST Class B Global Operator welcomestopjohn@hotmail.com
John Gilligan, UST Class B Operator welcomestopjohn@hotmail.com

Tank Number	01	**Tank Age**	34	**Tank Installed Date**	07/01/1991	**Tank Material Construction**	Steel Clad	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	2954	**Spill Test Date**	07/10/2024	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Manual Interstitial Monitoring	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	07/10/2024			**ATG Type**					
Tank Number	02	**Tank Age**	34	**Tank Installed Date**	07/01/1991	**Tank Material Construction**	Steel Clad	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	2955	**Spill Test Date**	07/10/2024	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Manual Interstitial Monitoring	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	07/10/2024			**ATG Type**					

Facility Summary in Sheridan County in the City of Reserve

Location: J AND R SERVICE
101 Main St
Reserve, MT 59258 Sheridan

System Facility ID:46-02103

Facility Code: 28008
Last Inspected On: 05/05/2025
Operating Permit Renewal Date: 08/10/2025

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	J and R Services	**(406) 286-5276**	**jandrservicesreserve@outlook.com**
Operator Contact:	Jeff Brensdal	**(406) 286-5276**	**jeffory_35@icloud.com**

Owner/Operator: J and R Services (406) 286-5276 jandrservicesreserve@outlook.com

Jeff Brensdal, UST Class A Operator	jeffory_35@icloud.com
Jeff Brensdal, UST Class A Operator	jeffory_35@icloud.com
Jeff Brensdal, UST Class B Global Operator	jeffory_35@icloud.com
Jeff Brensdal, UST Class B Global Operator	jeffory_35@icloud.com
Jeff Brensdal, UST Class B Operator	jeffory_35@icloud.com
Jeff Brensdal, UST Class B Operator	jeffory_35@icloud.com
Ryan Brensdal, UST Class B Operator	ryan_brensdal@yahoo.com
Ryan Brensdal, UST Class B Operator	ryan_brensdal@yahoo.com

Tank Number	05	**Tank Age**	25	**Tank Installed Date**	07/27/2000	**Tank Material Construction**	Steel Clad	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	4213	**Spill Test Date**	06/28/2022	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Manual Interstitial Monitoring	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	2000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	06/28/2022			**ATG Type**					
Tank Number	03	**Tank Age**	34	**Tank Installed Date**	05/21/1991	**Tank Material Construction**	Steel Clad	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	4733	**Spill Test Date**	06/28/2022	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Manual Interstitial Monitoring	**Primary Pipe Leak Detection**		**Vapor Recovery**	No

Capacity	2000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	06/28/2022			**ATG Type**					

Facility Summary in Silver Bow County in the City of Butte

Location: ACADIA BUILDING
55 Basin Creek Rd
Butte, MT 59701-9704 Silver Bow

System Facility ID:47-00458

Facility Code: 28332
Last Inspected On: 04/19/2022
Operating Permit Renewal Date: 09/21/2025

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Montana Dept of Corrections	**(406) 444-6551**	**JCHRISTOFFERSON@MT.GOV**
Operator Contact:	Bill English;Leon Huizinga;Todd Skartved	**(406) 496-6329;(406) 498-4550;(406) 782-2143**	**hbigbearmt@aol.com;leon.huizinga@acadiahealthcare.com;milehighpetro@gmail.com**

Owner/Operator: Montana Dept of Corrections (406) 444-6551 JCHRISTOFFERSON@MT.GOV

Bill English, UST Class A Operator	hbigbearmt@aol.com
Bill English, UST Class B Global Operator	hbigbearmt@aol.com
Leon Huizinga, UST Class A Operator	leon.huizinga@acadiahealthcare.com
Leon Huizinga, UST Class B Operator	leon.huizinga@acadiahealthcare.com
Todd Skartved, UST Class A Operator	milehighpetro@gmail.com

Tank Number	01	**Tank Age**	38	**Tank Installed Date**	06/22/1987	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Copper	**Overfill Types**	Flapper Valve
Tag Number	3974	**Spill Test Date**	04/19/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Secondary Containment Chase	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	04/19/2022	**Catastrophic L.D. Type 3.0**	Auto Dialer	**Piping Type**	U.S. Suction	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	2000	**ATG Test Date**	04/19/2022	**Line Tightness Test Date**	08/12/2021	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	3-Year Line Tightness Test	**Energy Act**	No
		Overfill Test Date	04/19/2022			**ATG Type**	Veeder Root/TLS-300				

Facility Summary in Silver Bow County in the City of Butte

Location: BUTTE MAIN CENTRAL OFFICE
200 W Broadway St
Butte, MT 59701-9226 Silver Bow

System Facility ID:56-14034

Facility Code: 30690
Last Inspected On: 10/12/2022
Operating Permit Renewal Date: 10/26/2025

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Century Link Communication	**(501) 680-8141**	**Stephanie.miller@lumen.com**
Operator Contact:	Stephanie Miller	**(501) 680-8141**	**Stephanie.miller@lumen.com**

Owner/Operator: Century Link Communication (501) 680-8141 Stephanie.miller@lumen.com

Stephanie Miller, UST Class A Operator Stephanie.miller@lumen.com

Stephanie Miller, UST Class B Global Operator Stephanie.miller@lumen.com

Tank Number	01	**Tank Age**	23	**Tank Installed Date**	10/02/2002	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	4732	**Spill Test Date**	10/04/2022	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	02/27/2020	**Catastrophic L.D. Type 3.0**	Auto Dialer	**Piping Type**	U.S. Suction	**CP Met Types**	
Product	Diesel, Dyed	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	3-Year Line Tightness Test	**Vapor Recovery**	No
Capacity	2500	**ATG Test Date**	10/04/2022	**Line Tightness Test Date**	09/28/2022	**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	10/04/2022			**ATG Type**					

Facility Summary in Silver Bow County in the City of Butte

Location: BUTTE SCHOOL DIST 1 BUS BARN
1220 E Front St
Butte, MT 59701-2936 Silver Bow

System Facility ID:47-01980

Facility Code: 28355
Last Inspected On: 09/29/2022
Operating Permit Renewal Date: 01/31/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: School Dist 1 Butte

Operator Contact: Bill English;Jed Johnson;Leonard Diaz;Todd Skartved **(406) 498-4550;(406) 782-2143** **hbigbearmt@aol.com;jedjohnson86@yahoo.com;leonard.diaz@rsd.k12.az.us;milehighpetro@gmail.com**

Owner/Operator: School Dist 1 Butte

Bill English, UST Class A Operator	hbigbearmt@aol.com
Bill English, UST Class A Operator	hbigbearmt@aol.com
Bill English, UST Class B Global Operator	hbigbearmt@aol.com
Bill English, UST Class B Global Operator	hbigbearmt@aol.com
Jed Johnson, UST Class A Operator	jedjohnson86@yahoo.com
Jed Johnson, UST Class A Operator	jedjohnson86@yahoo.com
Jed Johnson, UST Class B Global Operator	jedjohnson86@yahoo.com
Jed Johnson, UST Class B Global Operator	jedjohnson86@yahoo.com
Leonard Diaz, UST Class A Operator	leonard.diaz@rsd.k12.az.us
Leonard Diaz, UST Class A Operator	leonard.diaz@rsd.k12.az.us
Leonard Diaz, UST Class B Operator	leonard.diaz@rsd.k12.az.us
Leonard Diaz, UST Class B Operator	leonard.diaz@rsd.k12.az.us
Todd Skartved, UST Class A Operator	milehighpetro@gmail.com
Todd Skartved, UST Class B Global Operator	milehighpetro@gmail.com

Tank Number	03	**Tank Age**	33	**Tank Installed Date**	08/01/1992	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	1892	**Spill Test Date**	09/29/2022	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	09/24/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	09/29/2022			**ATG Type**	Gilbarco/EMC Basic;Gilbarco-Veeder Root/EMC Basic				

Facility Summary in Silver Bow County in the City of Butte

Location: BUTTE SILVER BOW MAINTENANCE CENTER
1700 Civic Center Rd
Butte, MT 59701-4857 Silver Bow

System Facility ID:47-08477

Facility Code: 28444
Last Inspected On: 01/16/2019
Operating Permit Renewal Date: 06/09/2022

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Butte Silver Bow County	**(406) 497-6569**	
Operator Contact:	Jed Johnson;John Stajcar;Todd Skartved	**(406) 497-6569;(406) 498-4550**	**jedjohnson86@yahoo.com;jstajcar@bsb.mt.gov;milehighpetro@gmail.com**

Jed Johnson, UST Class A Operator	jedjohnson86@yahoo.com
Jed Johnson, UST Class B Global Operator	jedjohnson86@yahoo.com
John Stajcar, UST Class A Operator	jstajcar@bsb.mt.gov
John Stajcar, UST Class B Global Operator	jstajcar@bsb.mt.gov
Todd Skartved, UST Class A Operator	milehighpetro@gmail.com
Todd Skartved, UST Class B Global Operator	milehighpetro@gmail.com

Tank Number	06	**Tank Age**	28	**Tank Installed Date**	01/01/1997	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve
Tag Number	511	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**	01/16/2019	**Sump Tightness Test Date**	10/01/2018	**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	30000	**ATG Test Date**		**Line Tightness Test Date**	05/04/2016	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco/EMC Basic				
Tank Number	07	**Tank Age**	28	**Tank Installed Date**	01/01/1997	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve
Tag Number	512	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**	01/16/2019	**Sump Tightness Test Date**	10/01/2015	**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	30000	**ATG Test Date**		**Line Tightness Test Date**	05/04/2016	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No

		Overfill Test Date				**ATG Type**	Gilbarco/EMC Basic				

Facility Summary in Silver Bow County in the City of Butte

Location: BUTTE'S HOMETOWN AUTO REPAIR
910 S Montana St
Butte, MT 59701 Silver Bow

System Facility ID:47-01835

Facility Code: 28353
Last Inspected On: 03/17/2020
Operating Permit Renewal Date: 03/17/2023

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Bigheads Inc;Catherine Shea	**(406) 782-2812**	**bigheadsinc@hotmail.com**
Operator Contact:	Jake Perusich		**buttehometownautorepair@yahoo.com**

Jake Perusich, UST Class A Operator — buttehometownautorepair@yahoo.com
Jake Perusich, UST Class B Global Operator — buttehometownautorepair@yahoo.com

Tank Number	07	**Tank Age**	26	**Tank Installed Date**	02/01/1999	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve
Tag Number	3959	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco/EMC Basic				
Tank Number	08	**Tank Age**	26	**Tank Installed Date**	02/01/1999	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve
Tag Number	3960	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco/EMC Basic				
Tank Number	09	**Tank Age**	26	**Tank Installed Date**	02/01/1999	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve

Tag Number	3961	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	16000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco/EMC Basic				

Facility Summary in Silver Bow County in the City of Butte

Location: CENEX ZIP TRIP 72
2801 Harrison Ave
Butte, MT 59701-3715 Silver Bow

System Facility ID:47-05148

Facility Code: 28404
Last Inspected On: 06/08/2023
Operating Permit Renewal Date: 12/26/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	CHS Inc Spokane Valley	**(509) 535-7701**	**Donald.Widdicombe@chsinc.com**
Operator Contact:	Jim Alford;Sean Hurley	**(509) 535-7701;(509) 536-7418**	**jim.alford@chsinc.com;sean.hurley@chsinc.com**

Owner/Operator: CHS Inc Spokane Valley (509) 535-7701 Donald.Widdicombe@chsinc.com

Jim Alford, UST Class A Operator	jim.alford@chsinc.com
Jim Alford, UST Class A Operator	jim.alford@chsinc.com
Jim Alford, UST Class B Operator	jim.alford@chsinc.com
Jim Alford, UST Class B Operator	jim.alford@chsinc.com
Luci Tuttle, UST Class B Operator	Lucinda.Tuttle@chsinc.com
Sean Hurley, UST Class A Operator	sean.hurley@chsinc.com
Sean Hurley, UST Class A Operator	sean.hurley@chsinc.com
Travis Weber, UST Class B Operator	travis.weber3@chsinc.com

Tank Number	08	**Tank Age**	35	**Tank Installed Date**	03/19/1990	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	1707	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**		**Line Tightness Test Date**	05/19/2020	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	09	**Tank Age**	35	**Tank Installed Date**	03/19/1990	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	1708	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No

Capacity	12000	**ATG Test Date**		**Line Tightness Test Date**	05/19/2020	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	10	**Tank Age**	35	**Tank Installed Date**	03/19/1990	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	1709	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**		**Line Tightness Test Date**	05/19/2020	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	11	**Tank Age**	35	**Tank Installed Date**	03/19/1990	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	1710	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**		**Line Tightness Test Date**	05/19/2020	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	12	**Tank Age**	35	**Tank Installed Date**	03/19/1990	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	1711	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**		**Line Tightness Test Date**	05/19/2020	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Silver Bow County in the City of Butte

Location: CENEX ZIP TRIP 73
848 W Park St
Butte, MT 59701-9066 Silver Bow

System Facility ID:47-00386

Facility Code: 28330
Last Inspected On: 02/24/2025
Operating Permit Renewal Date: 05/16/2028

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	CHS Inc Spokane Valley	**(509) 535-7701**	**Donald.Widdicombe@chsinc.com**
Operator Contact:	Jim Alford;Sean Hurley	**(509) 535-7701;(509) 536-7418**	**jim.alford@chsinc.com;sean.hurley@chsinc.com**

Owner/Operator:	CHS Inc Spokane Valley	(509) 535-7701	Donald.Widdicombe@chsinc.com
	Jim Alford, UST Class A Operator		jim.alford@chsinc.com
	Jim Alford, UST Class A Operator		jim.alford@chsinc.com
	Jim Alford, UST Class B Operator		jim.alford@chsinc.com
	Jim Alford, UST Class B Operator		jim.alford@chsinc.com
	Luci Tuttle, UST Class B Operator		Lucinda.Tuttle@chsinc.com
	Sean Hurley, UST Class A Operator		sean.hurley@chsinc.com
	Sean Hurley, UST Class A Operator		sean.hurley@chsinc.com
	Travis Weber, UST Class B Operator		travis.weber3@chsinc.com

Tank Number	05	**Tank Age**	27	**Tank Installed Date**	09/01/1998	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve
Tag Number	4425	**Spill Test Date**	10/05/2021	**Piping Installed Date**	05/15/2016	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	07/07/2020	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	05/22/2019	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	08/04/2022	**Line Tightness Test Date**	01/21/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	10/05/2021			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	06	**Tank Age**	27	**Tank Installed Date**	09/01/1998	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve
Tag Number	4426	**Spill Test Date**	10/05/2021	**Piping Installed Date**	05/15/2016	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	07/07/2020	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible

Product	Gasoline	**PLLD Test Date**	05/22/2019	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**	08/04/2022	**Line Tightness Test Date**	01/21/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	10/05/2021			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	07	**Tank Age**	27	**Tank Installed Date**	09/01/1998	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve
Tag Number	4427	**Spill Test Date**	10/05/2021	**Piping Installed Date**	05/15/2016	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	07/07/2020	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	05/22/2019	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	5000	**ATG Test Date**	08/04/2022	**Line Tightness Test Date**	01/20/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	10/05/2021			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Silver Bow County in the City of Butte

Location: DETENTION CENTER
155 W Quartz St
Butte, MT 59701-9200 Silver Bow

System Facility ID:56-14119

Facility Code: 30760
Last Inspected On: 02/06/2023
Operating Permit Renewal Date: 05/27/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Butte Silver Bow County	**(406) 497-6569**	
Operator Contact:	Bill English;Jed Johnson;John Stajcar	**(406) 497-6569;(406) 782-2143**	**hbigbearmt@aol.com;jedjohnson86@yahoo.com;jstajcar@bsb.mt.gov**

Owner/Operator: Butte Silver Bow County (406) 497-6569

Bill English, UST Class A Operator	hbigbearmt@aol.com
Bill English, UST Class B Global Operator	hbigbearmt@aol.com
Jed Johnson, UST Class A Operator	jedjohnson86@yahoo.com
John Stajcar, UST Class A Operator	jstajcar@bsb.mt.gov

Tank Number	01	**Tank Age**	20	**Tank Installed Date**	01/31/2005	**Tank Material Construction**	Steel Clad	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	5006	**Spill Test Date**	11/08/2022	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	02/23/2023	**Catastrophic L.D. Type 3.0**	Continuous Interstitial Monitoring	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	1000	**ATG Test Date**	02/06/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	02/06/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-300				

Facility Summary in Silver Bow County in the City of Butte

Location: FED EX DISTRIBUTION
119771 Rick Jones Way
Butte, MT 59750 Silver Bow

System Facility ID:60-15178

Facility Code: 30904
Last Inspected On: 11/27/2023
Operating Permit Renewal Date: 04/12/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Arc Febttmt 001 LLC **(215) 449-3600**

Operator Contact: Brenden Rose;Arc Febttmt 001 LLC;Chong Lee;Greg Peters **(215) 449-3600;(406) 782-4176;(408) 654-3112** **Brenden.Rose@fedex.com;chong.lee@fedex.com;greg.peters@fedex.com**

Owner/Operator: Arc Febttmt 001 LLC (215) 449-3600

Brenden Rose, UST Class A Operator	Brenden.Rose@fedex.com
Brenden Rose, UST Class B Operator	Brenden.Rose@fedex.com
Chong Lee, UST Class A Operator	chong.lee@fedex.com
Greg Peters, UST Class A Operator	greg.peters@fedex.com
Greg Peters, UST Class B Operator	greg.peters@fedex.com

Tank Number	01	**Tank Age**	14	**Tank Installed Date**	03/01/2011	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	5286	**Spill Test Date**	11/28/2023	**Piping Installed Date**	12/20/2010	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	11/27/2023	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	10/05/2023	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	20000	**ATG Test Date**	10/05/2023	**Line Tightness Test Date**	07/10/2020	**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	11/27/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350;Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Silver Bow County in the City of Butte

Location: HOLLOW CONSTRUCTION
404 W Greenwood Ave
Butte, MT 59701-2898 Silver Bow

System Facility ID:47-05359

Facility Code: 28410
Last Inspected On: 01/23/2024
Operating Permit Renewal Date: 05/22/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Hollow Contracting;William Hollow **(406) 782-6033**

Operator Contact: Susan Lasher **slasher@hollowcontracting.com**

Owner/Operator: Hollow Contracting (406) 782-6033

Owner/Operator: William J Hollow (406) 782-6033

Susan Lasher, UST Class A Operator slasher@hollowcontracting.com

Susan Lasher, UST Class B Operator slasher@hollowcontracting.com

Tank Number	02	**Tank Age**	25	**Tank Installed Date**	01/01/2000	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve;Flapper Valve
Tag Number	4162	**Spill Test Date**	04/30/2024	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	10/25/2023	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	04/03/2024	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	15000	**ATG Test Date**	04/04/2024	**Line Tightness Test Date**	04/30/2024	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	04/30/2024			**ATG Type**	Gilbarco-Veeder Root/EMC Basic				
Tank Number	03	**Tank Age**	25	**Tank Installed Date**	01/01/2000	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve;Flapper Valve
Tag Number	4163	**Spill Test Date**	04/30/2024	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	10/25/2023	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	10/25/2023	**Line Tightness Test Date**	04/30/2024	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	04/30/2024			**ATG Type**	Gilbarco-Veeder Root/EMC Basic				
Tank Number	04	**Tank Age**	25	**Tank Installed Date**	01/01/2000	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve;Flapper Valve

Tag Number	4164	**Spill Test Date**	04/30/2024	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	10/25/2023	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	5000	**ATG Test Date**	10/25/2023	**Line Tightness Test Date**	04/30/2024	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	04/30/2024			**ATG Type**	Gilbarco-Veeder Root/EMC Basic				

Facility Summary in Silver Bow County in the City of Butte

Location: JMT CORP MONTANA DBA JMT TRISTOP AND CASINO
2544 Harrison Ave
Butte, MT 59701 Silver Bow

System Facility ID:47-05202

Facility Code: 28406
Last Inspected On: 05/12/2023
Operating Permit Renewal Date: 08/19/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: JMT Corp Montana **(406) 782-9359** **jmann@jmtpetro.com**

Operator Contact:

Owner/Operator: JMT Corp Montana (406) 782-9359 jmann@jmtpetro.com

Tank Number	06	**Tank Age**	35	**Tank Installed Date**	03/08/1990	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve
Tag Number	1546	**Spill Test Date**	04/24/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	01/09/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	04/24/2023	**Line Tightness Test Date**	07/05/2020	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	04/24/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	07	**Tank Age**	35	**Tank Installed Date**	03/08/1990	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve
Tag Number	1547	**Spill Test Date**	04/24/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	01/09/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	04/24/2023	**Line Tightness Test Date**	07/05/2020	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	04/24/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Tank Number	08	**Tank Age**	30	**Tank Installed Date**	06/01/1995	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	1548	**Spill Test Date**	04/24/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	04/24/2023	**Line Tightness Test Date**	07/07/2020	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	04/27/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	09	**Tank Age**	30	**Tank Installed Date**	06/01/1995	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve
Tag Number	1549	**Spill Test Date**	04/24/2023	**Piping Installed Date**	02/12/2021	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	02/21/2021	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	5000	**ATG Test Date**	04/24/2023	**Line Tightness Test Date**	07/04/2020	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	04/24/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Silver Bow County in the City of Butte

Location: MDOT BUTTE
3751 Wynne Ave
Butte, MT 59701-6712 Silver Bow

System Facility ID:47-01062

Facility Code: 28342
Last Inspected On: 05/01/2024
Operating Permit Renewal Date: 10/26/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	MDOT Helena	**(406) 444-6163**	**mmurolo@mt.gov**
Operator Contact:	Joe Radonich;Montana Dept of Transportation;Mike Murolo;Montana Dept of Transportation;Walt Kerttula;Montana Department of Transportation Helena	**(406) 444-6151;(406) 444-6163;(406) 444-7632;(406) 444-9204;(406) 444-7632**	**jradonich@mt.gov;jradonich@mt.gov;mmurolo@mt.gov;jradonich@mt.gov;wkerttula@mt.gov**

Owner/Operator: MDOT Helena (406) 444-6163 mmurolo@mt.gov

Charles Stratford, UST Class B Operator	cstratford@mt.gov
Joe Radonich, UST Class A Operator	jradonich@mt.gov
Joe Radonich, UST Class B Operator	jradonich@mt.gov
Mike Murolo, UST Class A Operator	jradonich@mt.gov
Paul Jordan, UST Class B Operator	pjordan@mt.gov
Walt Kerttula, UST Class A Operator	wkerttula@mt.gov

Tank Number	08	**Tank Age**	31	**Tank Installed Date**	08/01/1994	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	2937	**Spill Test Date**	05/01/2024	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Single Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	05/01/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	05/01/2024			**ATG Type**	Gilbarco/EMC Basic				
Tank Number	09	**Tank Age**	31	**Tank Installed Date**	08/01/1994	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	2938	**Spill Test Date**	05/01/2024	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Single Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Non-corrodible
Product	Diesel, Dyed	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Deferred	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	05/01/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No

		Overfill Test Date	05/09/2024			**ATG Type**	Gilbarco/EMC Basic				

Facility Summary in Silver Bow County in the City of Butte

Location: MONTANA RESOURCES INC
600 Shields Ave
Butte, MT 59701-2705 Silver Bow

System Facility ID:47-13549

Facility Code: 28507
Last Inspected On: 11/14/2023
Operating Permit Renewal Date: 03/05/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Montana Resources LLC	**(406) 723-9542**	**jfleege@montanaresounces.com**
Operator Contact:	Jeremy Fleege;Thomas Dale	**(406) 498-8360**	**jfleege@jbrenv.com**

Owner/Operator: Montana Resources LLC (406) 723-9542 jfleege@montanaresounces.com

Daniel Lorengo, UST Class B Operator	dlorengo@montanaresources.com
Jeremy Fleege, UST Class A Operator	jfleege@jbrenv.com
Jerry Frohreich, UST Class B Operator	jfrohreich@montanaresources.com
Jody D'Arcy, UST Class B Operator	drc2251@hotmail.com
Thomas Dale, UST Class A Operator	
Thomas Dale, UST Class B Operator	

Tank Number	02	**Tank Age**	28	**Tank Installed Date**	10/01/1997	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	1687	**Spill Test Date**	11/14/2023	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	11/14/2023	**Catastrophic L.D. Type 3.0**	Continuous Interstitial Monitoring	**Piping Type**	Gravity Feed	**CP Met Types**	Non-corrodible
Product	Oil, Waste	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**	11/14/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/ILS-350				

Facility Summary in Silver Bow County in the City of Butte

Location: NORTHWEST PETROLEUM FACILITY
28 Dewey Blvd
Butte, MT 59701-3195 Silver Bow

System Facility ID:56-14033

Facility Code: 30689
Last Inspected On: 03/26/2025
Operating Permit Renewal Date: 08/02/2028

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Northwest Petroleum Co	**(406) 497-6700**	**done@townpump.com**
Operator Contact:	Trent Biggers		**Trentb@townpump.com**

Owner/Operator:	Northwest Petroleum Co	(406) 497-6700	done@townpump.com
	Trent Biggers, UST Class A Operator		Trentb@townpump.com
	Trent Biggers, UST Class A Operator		Trentb@townpump.com
	Trent Biggers, UST Class B Global Operator		Trentb@townpump.com
	Trent Biggers, UST Class B Global Operator		Trentb@townpump.com

Tank Number	01	**Tank Age**	23	**Tank Installed Date**	04/17/2002	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	4639	**Spill Test Date**		**Piping Installed Date**	09/15/2006	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	04/14/2021	**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	25000	**ATG Test Date**	03/26/2025	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	08/07/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Number	02	**Tank Age**	23	**Tank Installed Date**	04/17/2002	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	4640	**Spill Test Date**		**Piping Installed Date**	09/15/2006	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	04/14/2021	**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No

Capacity	25000	**ATG Test Date**	03/26/2025	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	08/07/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Number	03	**Tank Age**	23	**Tank Installed Date**	04/17/2002	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	4641	**Spill Test Date**		**Piping Installed Date**	09/15/2006	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	04/14/2021	**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	25000	**ATG Test Date**	03/26/2025	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	08/07/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Number	04	**Tank Age**	23	**Tank Installed Date**	04/17/2002	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	4642	**Spill Test Date**		**Piping Installed Date**	09/15/2006	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	04/14/2021	**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	25000	**ATG Test Date**	03/26/2025	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	08/07/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Number	05	**Tank Age**	23	**Tank Installed Date**	04/17/2002	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	4643	**Spill Test Date**		**Piping Installed Date**	09/15/2006	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	04/14/2021	**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Non-corrodible
Product	Diesel, Dyed	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	25000	**ATG Test Date**	03/26/2025	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No

		Overfill Test Date	08/07/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Number	06	**Tank Age**	23	**Tank Installed Date**	04/17/2002	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	4644	**Spill Test Date**		**Piping Installed Date**	09/15/2006	**Tank Construction**	Double-Walled	**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	04/14/2021	**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	25000	**ATG Test Date**	03/26/2025	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	08/07/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Number	07	**Tank Age**	23	**Tank Installed Date**	04/17/2002	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	4645	**Spill Test Date**		**Piping Installed Date**	09/15/2006	**Tank Construction**	Double-Walled	**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	04/14/2021	**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	25000	**ATG Test Date**	03/26/2025	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	08/07/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Number	08	**Tank Age**	23	**Tank Installed Date**	04/17/2002	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	4646	**Spill Test Date**		**Piping Installed Date**	09/15/2006	**Tank Construction**	Double-Walled	**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	04/14/2021	**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	25000	**ATG Test Date**	03/26/2025	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	08/07/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				

Facility Summary in Silver Bow County in the City of Butte

Location: RD'S QUICK FUEL
16 E Dewey Blvd
Butte, MT 59701-3195 Silver Bow

System Facility ID:47-13531

Facility Code: 28506
Last Inspected On: 08/10/2022
Operating Permit Renewal Date: 12/05/2025

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: City Service Valcon LLC **tamara.noble@cityservicevalcon.com**

Operator Contact: Kary Tonjum **(406) 755-4321**

Owner/Operator: City Service Valcon LLC tamara.noble@cityservicevalcon.com

Kary Tonjum, UST Class A Operator
Kary Tonjum, UST Class A Operator
Kary Tonjum, UST Class B Operator
Kary Tonjum, UST Class B Operator
Mitchell Kilmer, UST Class B Operator mkilmer@bresnan.net
Mitchell Kilmer, UST Class B Operator mkilmer@bresnan.net
Roy Morris, UST Class B Global Operator roy@morris-marketing.com
Roy Morris, UST Class B Global Operator roy@morris-marketing.com

Tank Number	01	**Tank Age**	31	**Tank Installed Date**	08/01/1994	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve
Tag Number	1712	**Spill Test Date**	12/08/2021	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel, Dyed	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	20000	**ATG Test Date**	05/09/2022	**Line Tightness Test Date**	08/20/2013	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	04/13/2021			**ATG Type**	Incon/TS-550 EVO				
Tank Number	02	**Tank Age**	31	**Tank Installed Date**	08/01/1994	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve
Tag Number	1713	**Spill Test Date**	04/13/2021	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	12/19/2023	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No

Capacity	20000	**ATG Test Date**	05/09/2022	**Line Tightness Test Date**	08/20/2013	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	04/13/2021			**ATG Type**	Incon/TS-550 EVO				
Tank Number	03	**Tank Age**	31	**Tank Installed Date**	08/01/1994	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve
Tag Number	1714	**Spill Test Date**	12/08/2021	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	12/19/2023	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	20000	**ATG Test Date**	05/09/2022	**Line Tightness Test Date**	08/20/2013	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	04/13/2021			**ATG Type**	Incon/TS-550 EVO				
Tank Number	04	**Tank Age**	31	**Tank Installed Date**	08/01/1994	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve
Tag Number	1715	**Spill Test Date**	04/13/2021	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	12/19/2023	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	05/09/2022	**Line Tightness Test Date**	08/20/2013	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	04/13/2021			**ATG Type**	Incon/TS-550 EVO				
Tank Number	05	**Tank Age**	31	**Tank Installed Date**	08/01/1994	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve
Tag Number	1716	**Spill Test Date**	04/13/2021	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	05/09/2022	**Line Tightness Test Date**	08/20/2013	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	04/13/2021			**ATG Type**	Incon/TS-550 EVO				
Tank Number	06	**Tank Age**	31	**Tank Installed Date**	08/01/1994	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve
Tag Number	1717	**Spill Test Date**	04/13/2021	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible

Product	Diesel, Dyed	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	05/09/2022	**Line Tightness Test Date**	08/20/2013	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	04/13/2021			**ATG Type**	Incon/TS-550 EVO				
Tank Number	07	**Tank Age**	31	**Tank Installed Date**	08/01/1994	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve
Tag Number	1718	**Spill Test Date**	04/13/2021	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	05/09/2022	**Line Tightness Test Date**	08/20/2013	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	04/13/2021			**ATG Type**	Incon/TS-550 EVO				

Facility Summary in Silver Bow County in the City of Butte

Location: SILVER BOW COUNTY PUBLIC WORKS
Browns Gulch
Butte, MT 59701 Silver Bow

System Facility ID:47-13157

Facility Code: 28500
Last Inspected On: 03/10/2025
Operating Permit Renewal Date: 06/09/2028

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Silver Bow County Browns Gulch Landfill **(406) 497-6521**

Operator Contact: Todd Skartved **(406) 498-4550** **milehighpetro@gmail.com**

Owner/Operator: Silver Bow County Browns Gulch Landfill (406) 497-6521

Todd Skartved, UST Class A Operator milehighpetro@gmail.com

Todd Skartved, UST Class B Global Operator milehighpetro@gmail.com

Tank Number	01	**Tank Age**	32	**Tank Installed Date**	06/01/1993	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	4465	**Spill Test Date**	10/29/2024	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	03/10/2025	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	09/24/2024			**ATG Type**	Gilbarco/EMC Basic				

Facility Summary in Silver Bow County in the City of Butte

Location: ST JAMES HEALTHCARE INC
400 S Clark St
Butte, MT 59701-2328 Silver Bow

System Facility ID:47-06924

Facility Code: 28426
Last Inspected On: 09/29/2022
Operating Permit Renewal Date: 12/05/2025

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: St James Healthcare Inc **(406) 723-2747**

Operator Contact: Thomas McKenna **(406) 698-6391** **tmckennaco@icloud.com**

Owner/Operator: St James Healthcare Inc (406) 723-2747

Mark McGivern, UST Class B Operator	mark.mcgivern@sclhealth.org
Richard Giuffra, UST Class B Operator	richard.giuffra@imail2.org
Thomas McKenna, UST Class A Operator	tmckennaco@icloud.com
Thomas McKenna, UST Class B Global Operator	tmckennaco@icloud.com

Tank Number	05	**Tank Age**	24	**Tank Installed Date**	05/01/2001	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	4449	**Spill Test Date**	11/11/2021	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	11/11/2021	**Catastrophic L.D. Type 3.0**	Auto Dialer;Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	01/17/2023	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	15000	**ATG Test Date**	01/17/2023	**Line Tightness Test Date**	01/17/2023	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	10/03/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				

Facility Summary in Silver Bow County in the City of Butte

Location: THREE BEARS ALASKA
45 Three Bears Dr
Butte, MT 59701-7171 Silver Bow

System Facility ID:60-15058

Facility Code: 30832
Last Inspected On: 11/21/2022
Operating Permit Renewal Date: 01/09/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	FIP Master Funding II, LLC	**(602) 448-5226**	**matt@fundamentalincome.com**
Operator Contact:	Dave Goody;Lindsay Myers;Wendy Whelchel	**(406) 494-7547**	**lmeyers@threebearsalaska.com;lmyers@threebearsalaska.com;store70@threebearsalaska.com**

Owner/Operator: FIP Master Funding II, LLC (602) 448-5226 matt@fundamentalincome.com

Dave Goody, UST Class A Operator store70@threebearsalaska.com
Lindsay Myers, UST Class A Operator lmyers@threebearsalaska.com
Lindsay Myers, UST Class B Operator lmyers@threebearsalaska.com
Wendy Whelchel, UST Class A Operator lmeyers@threebearsalaska.com

Tank Number	01	**Tank Age**	18	**Tank Installed Date**	04/24/2007	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	5103	**Spill Test Date**	11/21/2022	**Piping Installed Date**	10/25/2006	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	04/22/2020	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	Yes
Capacity	17000	**ATG Test Date**	09/24/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	12/22/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350				
Tank Number	02	**Tank Age**	18	**Tank Installed Date**	04/24/2007	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve
Tag Number	5104	**Spill Test Date**	11/21/2022	**Piping Installed Date**	10/25/2006	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	04/22/2020	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	11/21/2022	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	10/11/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	11/21/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Silver Bow County in the City of Butte

Location: THRIFTWAY SUPER STOP 1
3501 Harrison Ave
Butte, MT 59701-3547 Silver Bow

System Facility ID:47-07932

Facility Code: 28433
Last Inspected On: 03/07/2025
Operating Permit Renewal Date: 05/06/2028

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Sutey Oil Co Inc	**(406) 494-2305**	**ldsutey66@thriftwayss.com**
Operator Contact:	Jack Hook;Linda Otonicar;Louis Sutey	**(406) 491-5808;(406) 494-2305**	**ldsutey66@thriftwayss.com;otonicarlinda@aol.com**

Owner/Operator: Sutey Oil Co Inc (406) 494-2305 ldsutey66@thriftwayss.com

Cindy Beck, UST Class B Operator	thriftway1@thriftwayss.com
Jack Hook, UST Class A Operator	
Jack Hook, UST Class B Global Operator	
Jack Hook, UST Class B Operator	
James Brown, UST Class B Operator	dsbrown@ttc-cmc.net
Linda Otonicar, UST Class A Operator	otonicarlinda@aol.com
Louis Sutey, UST Class A Operator	ldsutey66@thriftwayss.com
Louis Sutey, UST Class B Global Operator	ldsutey66@thriftwayss.com
Shelby Hart, UST Class B Operator	srandall59701@gmail.com

Tank Number	07	**Tank Age**	35	**Tank Installed Date**	04/10/1990	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	2062	**Spill Test Date**	03/06/2025	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Single Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Not Listed	**CP Met Types**	
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	12/04/2024	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	14783	**ATG Test Date**	12/04/2024	**Line Tightness Test Date**	09/09/2021	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	12/04/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	08	**Tank Age**	35	**Tank Installed Date**	04/10/1990	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	2063	**Spill Test Date**	12/04/2024	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Single Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Not Listed	**CP Met Types**	

Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	12/04/2024	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	11627	**ATG Test Date**	04/03/2024	**Line Tightness Test Date**	08/30/2021	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	03/06/2025			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	09	**Tank Age**	35	**Tank Installed Date**	04/10/1990	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	2064	**Spill Test Date**	12/04/2024	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Single Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Not Listed	**CP Met Types**	
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	12/04/2024	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	11627	**ATG Test Date**	04/03/2024	**Line Tightness Test Date**	08/28/2021	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	12/04/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	10	**Tank Age**	35	**Tank Installed Date**	04/10/1990	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	2065	**Spill Test Date**	12/04/2024	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Single Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Not Listed	**CP Met Types**	
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	12/04/2024	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	5929	**ATG Test Date**	04/03/2024	**Line Tightness Test Date**	09/05/2021	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	12/04/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	11	**Tank Age**	35	**Tank Installed Date**	04/10/1990	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	2066	**Spill Test Date**	12/04/2024	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Single Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Not Listed	**CP Met Types**	
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	12/04/2024	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	5929	**ATG Test Date**	04/03/2024	**Line Tightness Test Date**	09/19/2021	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	12/04/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Silver Bow County in the City of Butte

Location: THRIFTWAY SUPER STOP 16
4701 Harrison Ave
Butte, MT 59701-7002 Silver Bow

System Facility ID:47-10657

Facility Code: 28486
Last Inspected On: 05/21/2025
Operating Permit Renewal Date: 07/10/2028

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Sutey Oil Co Inc	**(406) 494-2305**	**ldsutey66@thriftwayss.com**
Operator Contact:	Linda Otonicar;Louis Sutey	**(406) 491-5808;(406) 494-2305**	**ldsutey66@thriftwayss.com;otonicarlinda@aol.com**

Owner/Operator: Sutey Oil Co Inc (406) 494-2305 ldsutey66@thriftwayss.com

Linda Otonicar, UST Class A Operator otonicarlinda@aol.com

Louis Sutey, UST Class A Operator ldsutey66@thriftwayss.com

Tank Number	01	**Tank Age**	38	**Tank Installed Date**	11/01/1987	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Steel	**Overfill Types**	Flapper Valve
Tag Number	1921	**Spill Test Date**	05/20/2025	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Single Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**	05/20/2025	**Tank/Piping CP Test Date**	10/13/2022	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	05/20/2025	**Line Tightness Test Date**	02/10/2019	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	05/20/2025			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	02	**Tank Age**	38	**Tank Installed Date**	11/01/1987	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Steel	**Overfill Types**	Flapper Valve
Tag Number	1922	**Spill Test Date**	05/20/2025	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Single Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**	05/20/2025	**Tank/Piping CP Test Date**	10/13/2022	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	05/20/2025	**Line Tightness Test Date**	02/11/2019	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	05/20/2025			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	03	**Tank Age**	38	**Tank Installed Date**	11/01/1987	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Steel	**Overfill Types**	Flapper Valve

Tag Number	1923	**Spill Test Date**	05/20/2025	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Single Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**	05/20/2025	**Tank/Piping CP Test Date**	10/13/2022	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**	05/20/2025	**Line Tightness Test Date**	02/11/2019	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	05/20/2025			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	04	**Tank Age**	38	**Tank Installed Date**	11/01/1987	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Steel	**Overfill Types**	Flapper Valve
Tag Number	1924	**Spill Test Date**	03/18/2022	**Piping Installed Date**	09/14/2006	**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**	06/28/2022	**Tank/Piping CP Test Date**	10/13/2022	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**	01/04/2023	**Line Tightness Test Date**	02/12/2019	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	06/28/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Silver Bow County in the City of Butte

Location: THRIFTWAY SUPER STOP 2
1900 S Montana St
Butte, MT 59701-3023 Silver Bow

System Facility ID:47-07935

Facility Code: 28436
Last Inspected On: 05/01/2025
Operating Permit Renewal Date: 06/12/2028

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Sutey Oil Co Inc	**(406) 494-2305**	**ldsutey66@thriftwayss.com**
Operator Contact:	Jack Hook;Linda Otonicar;Louis Sutey	**(406) 491-5808;(406) 494-2305**	**ldsutey66@thriftwayss.com;otonicarlinda@aol.com**

Owner/Operator: Sutey Oil Co Inc (406) 494-2305 ldsutey66@thriftwayss.com

Jack Hook, UST Class A Operator	
Jessica Willis, UST Class B Global Operator	clownprincess269@gmail.com
Linda Otonicar, UST Class A Operator	otonicarlinda@aol.com
Louis Sutey, UST Class A Operator	ldsutey66@thriftwayss.com
Louis Sutey, UST Class B Global Operator	ldsutey66@thriftwayss.com

Tank Number	04	**Tank Age**	36	**Tank Installed Date**	05/15/1989	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	2070	**Spill Test Date**	04/21/2025	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Single Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	04/15/2019	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Gasoline	**PLLD Test Date**	04/21/2025	**Tank/Piping CP Test Date**	06/29/2022	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	11627	**ATG Test Date**	04/21/2025	**Line Tightness Test Date**	04/15/2019	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	04/21/2025			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	05	**Tank Age**	36	**Tank Installed Date**	05/15/1989	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	2071	**Spill Test Date**	04/21/2025	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Single Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	04/15/2019	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Diesel	**PLLD Test Date**	04/21/2025	**Tank/Piping CP Test Date**	06/29/2022	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	11627	**ATG Test Date**	04/21/2025	**Line Tightness Test Date**	04/15/2019	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No

		Overfill Test Date	04/21/2025			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	06	**Tank Age**	36	**Tank Installed Date**	05/15/1989	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	2072	**Spill Test Date**	04/21/2025	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Single Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	04/15/2019	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Gasoline	**PLLD Test Date**	04/21/2025	**Tank/Piping CP Test Date**	06/29/2022	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	11627	**ATG Test Date**	04/21/2025	**Line Tightness Test Date**	04/15/2019	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	04/21/2025			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Silver Bow County in the City of Butte

Location: THRIFTWAY SUPER STOP 4
2610 Harrison Ave
Butte, MT 59701 Silver Bow

System Facility ID:47-07934

Facility Code: 28435
Last Inspected On: 05/02/2025
Operating Permit Renewal Date: 06/20/2028

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	David Sutey;Sutey Oil Co Inc	**(406) 494-2305**	**ldsutey66@thriftwayss.com**
Operator Contact:	Geoff Gifford;Jack Hook;Linda Otonicar;Louis Sutey	**(406) 491-5808;(406) 494-2305;(406) 494-3155**	**ldsutey66@thriftwayss.com;otonicarlinda@aol.com;Thriftway16@Thriftwayss.com**

Owner/Operator: David L Sutey

Owner/Operator: Sutey Oil Co Inc

Geoff Gifford, UST Class A Operator	Thriftway16@Thriftwayss.com
Jack Hook, UST Class A Operator	
Jack Hook, UST Class A Operator	
Kasey Maes, UST Class B Operator	maeskasey@gmail.com
Kasey Maes, UST Class B Operator	maeskasey@gmail.com
Linda Otonicar, UST Class A Operator	otonicarlinda@aol.com
Linda Otonicar, UST Class B Global Operator	otonicarlinda@aol.com
Louis Sutey, UST Class A Operator	ldsutey66@thriftwayss.com
Louis Sutey, UST Class B Global Operator	ldsutey66@thriftwayss.com

Tank Number	05	**Tank Age**	35	**Tank Installed Date**	03/13/1990	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	2067	**Spill Test Date**	04/28/2025	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Single Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	04/15/2019	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	04/28/2025	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	11627	**ATG Test Date**	04/28/2025	**Line Tightness Test Date**	01/25/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	04/28/2025			**ATG Type**	Veeder Root/TLS-350				
Tank Number	06	**Tank Age**	35	**Tank Installed Date**	03/13/1990	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	2068	**Spill Test Date**	04/28/2025	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Single Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	04/15/2019	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible

Product	Gasoline	**PLLD Test Date**	04/28/2025	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	11627	**ATG Test Date**	04/28/2025	**Line Tightness Test Date**	01/25/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	04/28/2025			**ATG Type**	Veeder Root/TLS-350				
Tank Number	07	**Tank Age**	35	**Tank Installed Date**	03/13/1990	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	2069	**Spill Test Date**	04/28/2025	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Single Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	04/15/2019	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	04/28/2025	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	11627	**ATG Test Date**	04/28/2025	**Line Tightness Test Date**	01/25/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	04/28/2025			**ATG Type**	Veeder Root/TLS-350				

Facility Summary in Silver Bow County in the City of Butte

Location: THRIFTWAY SUPER STOP 5
901 E Front St
Butte, MT 59701-2929 Silver Bow

System Facility ID:47-00942

Facility Code: 28334
Last Inspected On: 01/22/2025
Operating Permit Renewal Date: 06/12/2028

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	David Sutey;Sutey Oil Co Inc	**(406) 494-2305**	**ldsutey66@thriftwayss.com**
Operator Contact:	Jack Hook;Linda Otonicar;Louis Sutey	**(406) 491-5808;(406) 494-2305**	**ldsutey66@thriftwayss.com;otonicarlinda@aol.com**

Owner/Operator: David L Sutey

Owner/Operator: Sutey Oil Co Inc

Allen Beagley, UST Class B Global Operator	thriftway5@thriftwayss.com
Allen Beagley, UST Class B Global Operator	thriftway5@thriftwayss.com
Allen Beagley, UST Class B Operator	thriftway5@thriftwayss.com
Allen Beagley, UST Class B Operator	thriftway5@thriftwayss.com
Jack Hook, UST Class A Operator	
Jack Hook, UST Class A Operator	
Jack Hook, UST Class B Global Operator	
Jack Hook, UST Class B Global Operator	
Jack Hook, UST Class B Operator	
Jack Hook, UST Class B Operator	
Katie Black, UST Class B Operator	katie.black1369@gmail.com
Kenneth Beck, UST Class B Global Operator	suesman@hotmail.com
Linda Otonicar, UST Class A Operator	otonicarlinda@aol.com
Linda Otonicar, UST Class B Operator	otonicarlinda@aol.com
Louis Sutey, UST Class A Operator	ldsutey66@thriftwayss.com
Louis Sutey, UST Class B Global Operator	ldsutey66@thriftwayss.com
Robert Osmanson, UST Class B Operator	bobby.osmanson@yahoo.com
Robert Osmanson, UST Class B Operator	bobby.osmanson@yahoo.com

Tank Number	05	**Tank Age**	31	**Tank Installed Date**	08/01/1994	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve;Flapper Valve
Tag Number	2059	**Spill Test Date**	01/22/2025	**Piping Installed Date**	11/07/2016	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	02/11/2022	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible

Product	Gasoline	**PLLD Test Date**	04/09/2024	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	04/09/2025	**Line Tightness Test Date**	08/16/2021	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date	01/21/2025			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	06	**Tank Age**	31	**Tank Installed Date**	08/01/1994	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve;Flapper Valve
Tag Number	2060	**Spill Test Date**	01/22/2025	**Piping Installed Date**	11/07/2016	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	02/11/2022	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Diesel	**PLLD Test Date**	04/09/2024	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	04/09/2025	**Line Tightness Test Date**	11/18/2021	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date	01/21/2025			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	07	**Tank Age**	31	**Tank Installed Date**	08/01/1994	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve;Flapper Valve
Tag Number	2061	**Spill Test Date**	01/22/2025	**Piping Installed Date**	11/07/2016	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	02/11/2022	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Gasoline	**PLLD Test Date**	04/09/2024	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	04/09/2024	**Line Tightness Test Date**	08/20/2021	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date	01/21/2025			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Silver Bow County in the City of Butte

Location: THRIFTWAY SUPER STOP 6
2401 Continental Dr
Butte, MT 59701-6562 Silver Bow

System Facility ID:47-07936

Facility Code: 28437
Last Inspected On: 10/29/2024
Operating Permit Renewal Date: 02/27/2028

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	David Sutey;Sutey Oil Co Inc	**(406) 494-2305**	**ldsutey66@thriftwayss.com**
Operator Contact:	Jack Hook;Ken Beck;Linda Otonicar;Louis Sutey	**(406) 491-5808;(406) 494-2305;(406) 723-2022**	**ldsutey66@thriftwayss.com;otonicarlinda@aol.com;suesman@hotmail.com**

Owner/Operator: David L Sutey

Owner/Operator: Sutey Oil Co Inc

Dean Brown, UST Class B Operator	twaydb36016@gmail.com
Jack Hook, UST Class A Operator	
Jack Hook, UST Class B Global Operator	
Jack Hook, UST Class B Operator	
Jessica Willis, UST Class B Global Operator	clownprincess269@gmail.com
Ken Beck, UST Class A Operator	suesman@hotmail.com
Ken Beck, UST Class B Operator	suesman@hotmail.com
Linda Otonicar, UST Class A Operator	otonicarlinda@aol.com
Louis Sutey, UST Class A Operator	ldsutey66@thriftwayss.com
Louis Sutey, UST Class B Global Operator	ldsutey66@thriftwayss.com
Marianne Taylor, UST Class B Operator	thriftway2@thriftwayss.com
Tracy Brown, UST Class B Operator	ldsutey66@thriftwayss.com

Tank Number	01	**Tank Age**	57	**Tank Installed Date**	05/07/1968	**Tank Material Construction**	Bare Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	2073	**Spill Test Date**	10/29/2024	**Piping Installed Date**	06/23/2014	**Tank Construction**	Lined Interior/Impressed Current	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	12/13/2021	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**	04/11/2024	**Tank/Piping CP Test Date**	04/05/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	04/11/2024	**Line Tightness Test Date**	01/17/2019	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date	10/29/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-450				

Tank Number	02	**Tank Age**	57	**Tank Installed Date**	05/07/1968	**Tank Material Construction**	Bare Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	2074	**Spill Test Date**	10/29/2024	**Piping Installed Date**	06/23/2014	**Tank Construction**	Lined Interior/Impressed Current	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	12/13/2021	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**	04/11/2024	**Tank/Piping CP Test Date**	04/05/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	04/11/2024	**Line Tightness Test Date**	01/21/2019	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date	10/29/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-450				
Tank Number	03	**Tank Age**	52	**Tank Installed Date**	05/07/1973	**Tank Material Construction**	Bare Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	2075	**Spill Test Date**	10/29/2024	**Piping Installed Date**	06/23/2014	**Tank Construction**	Lined Interior/Impressed Current	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	12/13/2021	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Diesel	**PLLD Test Date**	04/11/2024	**Tank/Piping CP Test Date**	04/05/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	04/11/2024	**Line Tightness Test Date**	01/19/2019	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date	10/29/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-450				

Facility Summary in Silver Bow County in the City of Butte

Location: TOWN PUMP BUTTE #5
2305 Continental Dr
Butte, MT 59701 Silver Bow

System Facility ID:60-15187

Facility Code: 30912
Last Inspected On: 03/26/2025
Operating Permit Renewal Date: 08/31/2028

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Butte 5 Town Pump LLC **(406) 497-6700** **environmental@townpump.com**

Operator Contact: Trent Biggers **Trentb@townpump.com**

Owner/Operator: Butte 5 Town Pump LLC (406) 497-6700 environmental@townpump.com

Trent Biggers, UST Class A Operator Trentb@townpump.com

Trent Biggers, UST Class B Global Operator Trentb@townpump.com

Tank Number	01	**Tank Age**	14	**Tank Installed Date**	11/01/2011	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	5310	**Spill Test Date**	10/02/2024	**Piping Installed Date**	07/28/2011	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	06/07/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	03/26/2025	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	Yes
Capacity	20000	**ATG Test Date**	03/26/2025	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Statistical Inventory Reconciliation	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	Yes
		Overfill Test Date	10/02/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Number	02	**Tank Age**	14	**Tank Installed Date**	11/01/2011	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	5311	**Spill Test Date**	06/07/2024	**Piping Installed Date**	07/28/2011	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	06/07/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	03/26/2025	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	03/26/2025	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Statistical Inventory Reconciliation	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	Yes

		Overfill Test Date	06/07/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Number	03	**Tank Age**	14	**Tank Installed Date**	11/01/2011	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	5312	**Spill Test Date**	06/07/2024	**Piping Installed Date**	07/28/2011	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	06/07/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	03/26/2025	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	Yes
Capacity	12000	**ATG Test Date**	03/26/2025	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Statistical Inventory Reconciliation	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	Yes
		Overfill Test Date	06/07/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				

Facility Summary in Silver Bow County in the City of Butte

Location: TOWN PUMP INC BUTTE 1
1370 Harrison Ave
Butte, MT 59701-4848 Silver Bow

System Facility ID:47-08679

Facility Code: 28450
Last Inspected On: 05/19/2025
Operating Permit Renewal Date: 09/19/2025

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Butte 1 Town Pump LLC **(406) 497-6700** **environmental@townpump.com**

Operator Contact: Trent Biggers **Trentb@townpump.com**

Owner/Operator: Butte 1 Town Pump LLC (406) 497-6700 environmental@townpump.com

Trent Biggers, UST Class A Operator Trentb@townpump.com
Trent Biggers, UST Class A Operator Trentb@townpump.com
Trent Biggers, UST Class B Global Operator Trentb@townpump.com
Trent Biggers, UST Class B Global Operator Trentb@townpump.com

Tank Number	05	**Tank Age**	37	**Tank Installed Date**	04/11/1988	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve
Tag Number	2618	**Spill Test Date**	10/07/2024	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**	05/01/2023	**Tank/Piping CP Test Date**	04/27/2021	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	05/01/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	10/07/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Number	06	**Tank Age**	39	**Tank Installed Date**	04/11/1986	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve
Tag Number	2619	**Spill Test Date**	10/07/2024	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**	05/01/2023	**Tank/Piping CP Test Date**	04/27/2021	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No

Capacity	8000	**ATG Test Date**	05/01/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	10/07/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Number	07	**Tank Age**	37	**Tank Installed Date**	04/11/1988	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve
Tag Number	2620	**Spill Test Date**	10/07/2024	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**	05/01/2023	**Tank/Piping CP Test Date**	04/27/2021	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	05/01/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	10/07/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Number	08	**Tank Age**	34	**Tank Installed Date**	07/28/1991	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve
Tag Number	2621	**Spill Test Date**	04/28/2021	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	05/01/2023	**Tank/Piping CP Test Date**	04/27/2021	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	05/01/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	04/28/2021			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				

Facility Summary in Silver Bow County in the City of Butte

Location: TOWN PUMP INC BUTTE 10
901 N Excelsior Ave
Butte, MT 59701 Silver Bow

System Facility ID:47-08687

Facility Code: 28458
Last Inspected On: 03/26/2025
Operating Permit Renewal Date: 08/03/2028

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Butte 10 Town Pump LLC	**(406) 497-6700**	**environmental@townpump.com**
Operator Contact:	Trent Biggers		**Trentb@townpump.com**

Owner/Operator:	Butte 10 Town Pump LLC	(406) 497-6700	environmental@townpump.com
	Trent Biggers, UST Class A Operator		Trentb@townpump.com
	Trent Biggers, UST Class A Operator		Trentb@townpump.com
	Trent Biggers, UST Class B Global Operator		Trentb@townpump.com
	Trent Biggers, UST Class B Global Operator		Trentb@townpump.com

Tank Number	01	**Tank Age**	54	**Tank Installed Date**	04/12/1971	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	2633	**Spill Test Date**	10/31/2024	**Piping Installed Date**	11/01/2019	**Tank Construction**	Lined Interior/Impressed Current	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	04/17/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**	03/26/2025	**Tank/Piping CP Test Date**	04/27/2021	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	04/17/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	No
		Overfill Test Date	04/17/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Number	02	**Tank Age**	54	**Tank Installed Date**	04/12/1971	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	2634	**Spill Test Date**	04/17/2024	**Piping Installed Date**	11/01/2019	**Tank Construction**	Lined Interior/Impressed Current	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	04/17/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**	03/26/2025	**Tank/Piping CP Test Date**	04/27/2021	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No

Capacity	4000	**ATG Test Date**	03/26/2025	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	No
		Overfill Test Date	04/17/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				

Facility Summary in Silver Bow County in the City of Butte

Location: TOWN PUMP INC BUTTE 2
531 S Montana St
Butte, MT 59701 Silver Bow

System Facility ID:47-08680

Facility Code: 28451
Last Inspected On: 05/20/2025
Operating Permit Renewal Date: 02/09/2024

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Butte 2 Town Pump LLC	**(406) 497-6700**	**environmental@townpump.com**
Operator Contact:	Trent Biggers		**Trentb@townpump.com**

Owner/Operator:	Butte 2 Town Pump LLC	(406) 497-6700	environmental@townpump.com
	Trent Biggers, UST Class A Operator		Trentb@townpump.com
	Trent Biggers, UST Class A Operator		Trentb@townpump.com
	Trent Biggers, UST Class B Global Operator		Trentb@townpump.com
	Trent Biggers, UST Class B Global Operator		Trentb@townpump.com

Tank Number	01	**Tank Age**	40	**Tank Installed Date**	09/01/1985	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Steel	**Overfill Types**	Flapper Valve
Tag Number	2622	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	08/28/2020	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	24000	**ATG Test Date**		**Line Tightness Test Date**	05/07/2006	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/TLS-350				
Tank Number	02	**Tank Age**	40	**Tank Installed Date**	09/01/1985	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Steel	**Overfill Types**	Flapper Valve
Tag Number	2623	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	08/28/2020	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	24000	**ATG Test Date**		**Line Tightness Test Date**	05/07/2006	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/TLS-350				

Tank Number	03	**Tank Age**	37	**Tank Installed Date**	09/01/1988	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	2624	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	08/28/2020	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	20000	**ATG Test Date**		**Line Tightness Test Date**	05/07/2006	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/TLS-350				
Tank Number	04	**Tank Age**	4	**Tank Installed Date**	03/31/2021	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	6038	**Spill Test Date**	06/28/2021	**Piping Installed Date**	03/31/2021	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	06/28/2021	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	07/18/2022	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	Yes
Capacity	24000	**ATG Test Date**	07/18/2022	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Statistical Inventory Reconciliation	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	Yes
		Overfill Test Date	07/18/2022			**ATG Type**					
Tank Number	05	**Tank Age**	4	**Tank Installed Date**	03/31/2021	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	6039	**Spill Test Date**	06/28/2021	**Piping Installed Date**	03/31/2021	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	06/28/2021	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	07/18/2022	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	Yes
Capacity	6000	**ATG Test Date**	07/18/2022	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Statistical Inventory Reconciliation	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	Yes
		Overfill Test Date	07/18/2022			**ATG Type**					
Tank Number	06	**Tank Age**	4	**Tank Installed Date**	03/31/2021	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	6040	**Spill Test Date**	05/09/2024	**Piping Installed Date**	03/31/2021	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	06/28/2021	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible

Product	Gasoline	**PLLD Test Date**	07/18/2022	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	Yes
Capacity	15000	**ATG Test Date**	07/18/2022	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Statistical Inventory Reconciliation	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	Yes
		Overfill Test Date	07/18/2022			**ATG Type**					
Tank Number	07	**Tank Age**	4	**Tank Installed Date**	03/31/2021	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	6041	**Spill Test Date**	06/28/2021	**Piping Installed Date**	03/31/2021	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	06/28/2021	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	07/18/2022	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**	07/18/2022	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Statistical Inventory Reconciliation	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	Yes
		Overfill Test Date	07/18/2022			**ATG Type**					
Tank Number	08	**Tank Age**	4	**Tank Installed Date**	03/31/2021	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	6042	**Spill Test Date**	06/28/2021	**Piping Installed Date**	03/31/2021	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	06/28/2021	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	07/18/2022	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	15000	**ATG Test Date**	07/18/2022	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Statistical Inventory Reconciliation	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	Yes
		Overfill Test Date	07/18/2022			**ATG Type**					
Tank Number	09	**Tank Age**	4	**Tank Installed Date**	03/31/2021	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	6043	**Spill Test Date**	06/28/2021	**Piping Installed Date**	03/31/2021	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	06/28/2021	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel, Dyed	**PLLD Test Date**	07/18/2022	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**	07/18/2022	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Statistical Inventory Reconciliation	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	Yes

		Overfill Test Date	07/18/2022			**ATG Type**					

Facility Summary in Silver Bow County in the City of Butte

Location: TOWN PUMP INC BUTTE 3
2328 S Montana St
Butte, MT 59701 Silver Bow

System Facility ID:47-08682

Facility Code: 28453
Last Inspected On: 03/20/2025
Operating Permit Renewal Date: 07/27/2028

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Butte 3 Town Pump LLC	**(406) 497-6700**	**environmental@townpump.com**
Operator Contact:	Trent Biggers		**Trentb@townpump.com**

Owner/Operator:	Butte 3 Town Pump LLC	(406) 497-6700	environmental@townpump.com
	Trent Biggers, UST Class A Operator		Trentb@townpump.com
	Trent Biggers, UST Class A Operator		Trentb@townpump.com
	Trent Biggers, UST Class B Global Operator		Trentb@townpump.com
	Trent Biggers, UST Class B Global Operator		Trentb@townpump.com

Tank Number	01	**Tank Age**	44	**Tank Installed Date**	04/11/1981	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve
Tag Number	2625	**Spill Test Date**	07/25/2024	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Single Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**	03/20/2025	**Tank/Piping CP Test Date**	07/25/2024	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	03/20/2025	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Approved Remote Monitoring	**Secondary Pipe Leak Detection**	Approved Remote Monitoring	**Energy Act**	No
		Overfill Test Date	07/25/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Number	04	**Tank Age**	35	**Tank Installed Date**	10/01/1990	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve
Tag Number	2626	**Spill Test Date**	07/25/2024	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Single Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	03/20/2025	**Tank/Piping CP Test Date**	05/05/2012	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	03/20/2025	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Approved Remote Monitoring	**Secondary Pipe Leak Detection**	Approved Remote Monitoring	**Energy Act**	No

		Overfill Test Date	07/25/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Number	05	**Tank Age**	35	**Tank Installed Date**	10/01/1990	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	2627	**Spill Test Date**	07/25/2024	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Single Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	03/20/2025	**Tank/Piping CP Test Date**	05/05/2012	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	03/20/2025	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Approved Remote Monitoring	**Secondary Pipe Leak Detection**	Approved Remote Monitoring	**Energy Act**	No
		Overfill Test Date	07/25/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Number	06	**Tank Age**	35	**Tank Installed Date**	10/01/1990	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	2628	**Spill Test Date**	07/25/2024	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Single Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	03/20/2025	**Tank/Piping CP Test Date**	05/05/2012	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	03/20/2025	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Approved Remote Monitoring	**Secondary Pipe Leak Detection**	Approved Remote Monitoring	**Energy Act**	No
		Overfill Test Date	07/25/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				

Facility Summary in Silver Bow County in the City of Butte

Location: TOWN PUMP INC BUTTE 4
3700 Harrison Ave
Butte, MT 59701 Silver Bow

System Facility ID:56-13911

Facility Code: 30581
Last Inspected On: 05/20/2025
Operating Permit Renewal Date: 09/15/2025

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Butte 4 Town Pump LLC	**(406) 497-6700**	**environmental@townpump.com**
Operator Contact:	Trent Biggers		**Trentb@townpump.com**

Owner/Operator:	Butte 4 Town Pump LLC	(406) 497-6700	environmental@townpump.com
	Trent Biggers, UST Class A Operator		Trentb@townpump.com
	Trent Biggers, UST Class A Operator		Trentb@townpump.com
	Trent Biggers, UST Class A Operator		Trentb@townpump.com
	Trent Biggers, UST Class B Global Operator		Trentb@townpump.com
	Trent Biggers, UST Class B Global Operator		Trentb@townpump.com
	Trent Biggers, UST Class B Global Operator		Trentb@townpump.com

Tank Number	01	**Tank Age**	26	**Tank Installed Date**	04/01/1999	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	4022	**Spill Test Date**	10/02/2024	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	06/19/2018	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	05/18/2023	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	05/18/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	06/01/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Number	02	**Tank Age**	26	**Tank Installed Date**	04/01/1999	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	4023	**Spill Test Date**	04/26/2021	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	06/19/2018	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	05/18/2023	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No

Capacity	10000	**ATG Test Date**	05/18/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	06/29/2021			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Number	03	**Tank Age**	26	**Tank Installed Date**	04/01/1999	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	4024	**Spill Test Date**	06/01/2022	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	06/19/2018	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	05/18/2023	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	15000	**ATG Test Date**	05/18/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	06/01/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Number	04	**Tank Age**	26	**Tank Installed Date**	04/01/1999	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	4025	**Spill Test Date**	06/01/2022	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	06/19/2018	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	05/18/2023	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	05/18/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	06/29/2021			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Number	05	**Tank Age**	26	**Tank Installed Date**	04/01/1999	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	4026	**Spill Test Date**	06/01/2022	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	06/19/2018	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	05/18/2023	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**	05/18/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No

		Overfill Test Date	09/14/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Number	06	**Tank Age**	26	**Tank Installed Date**	04/01/1999	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	4294	**Spill Test Date**	06/01/2022	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	06/19/2018	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel, Dyed	**PLLD Test Date**	05/18/2023	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**	05/18/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	09/14/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				

Facility Summary in Silver Bow County in the City of Butte

Location: TOWN PUMP INC BUTTE 8
2001 Dewey Blvd
Butte, MT 59701 Silver Bow

System Facility ID:47-08686

Facility Code: 28457
Last Inspected On: 10/20/2022
Operating Permit Renewal Date: 10/20/2025

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Butte 8 Town Pump LLC	**(406) 497-6700**	**environmental@townpump.com**
Operator Contact:	Trent Biggers		**Trentb@townpump.com**

Owner/Operator:	Butte 8 Town Pump LLC	(406) 497-6700	environmental@townpump.com
	Trent Biggers, UST Class A Operator		Trentb@townpump.com
	Trent Biggers, UST Class A Operator		Trentb@townpump.com
	Trent Biggers, UST Class A Operator		Trentb@townpump.com
	Trent Biggers, UST Class B Global Operator		Trentb@townpump.com
	Trent Biggers, UST Class B Global Operator		Trentb@townpump.com
	Trent Biggers, UST Class B Global Operator		Trentb@townpump.com

Tank Number	01	**Tank Age**	44	**Tank Installed Date**	10/01/1981	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Steel	**Overfill Types**	Flapper Valve
Tag Number	2629	**Spill Test Date**	07/20/2021	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**	08/10/2022	**Tank/Piping CP Test Date**	05/03/2021	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	120000	**ATG Test Date**	08/10/2022	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	07/20/2021			**ATG Type**	Gilbarco-Veeder Root/TLS-350				
Tank Number	03	**Tank Age**	48	**Tank Installed Date**	01/01/1977	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Steel	**Overfill Types**	Flapper Valve
Tag Number	2631	**Spill Test Date**	07/20/2021	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**	10/20/2022	**Tank/Piping CP Test Date**	05/03/2021	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	48000	**ATG Test Date**	08/10/2022	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No

		Overfill Test Date	07/20/2021			**ATG Type**	Gilbarco-Veeder Root/TLS-350				
Tank Number	04	**Tank Age**	44	**Tank Installed Date**	10/01/1981	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Steel	**Overfill Types**	Flapper Valve
Tag Number	2632	**Spill Test Date**	07/20/2021	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Diesel	**PLLD Test Date**	08/10/2022	**Tank/Piping CP Test Date**	05/03/2021	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	48000	**ATG Test Date**	08/10/2022	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	07/20/2021			**ATG Type**	Gilbarco-Veeder Root/TLS-350				
Tank Number	02	**Tank Age**	44	**Tank Installed Date**	10/01/1981	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Steel	**Overfill Types**	Flapper Valve
Tag Number	4265	**Spill Test Date**	07/20/2021	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Single Walled	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**	01/30/2025	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**	10/20/2022	**Tank/Piping CP Test Date**	05/03/2021	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	120000	**ATG Test Date**	08/10/2022	**Line Tightness Test Date**	01/30/2025	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	07/20/2021			**ATG Type**	Gilbarco-Veeder Root/TLS-350				
Tank Number	05	**Tank Age**	0	**Tank Installed Date**	06/04/2025	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	6246	**Spill Test Date**		**Piping Installed Date**	06/04/2025	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline, E10	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	Yes
Capacity	15000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Statistical Inventory Reconciliation	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	Yes
		Overfill Test Date				**ATG Type**					
Tank Number	06	**Tank Age**	0	**Tank Installed Date**	06/04/2025	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	6247	**Spill Test Date**		**Piping Installed Date**	06/04/2025	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No

Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	15000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Statistical Inventory Reconciliation	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	Yes
		Overfill Test Date				**ATG Type**					
Tank Number	07	**Tank Age**	0	**Tank Installed Date**	06/04/2025	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	6248	**Spill Test Date**		**Piping Installed Date**	06/04/2025	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	Yes
Capacity	6000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Statistical Inventory Reconciliation	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	Yes
		Overfill Test Date				**ATG Type**					
Tank Number	08	**Tank Age**	0	**Tank Installed Date**	06/04/2025	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	6249	**Spill Test Date**		**Piping Installed Date**	06/04/2025	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline, E10	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	Yes
Capacity	24000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Statistical Inventory Reconciliation	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	Yes
		Overfill Test Date				**ATG Type**					

Facility Summary in Silver Bow County in the City of Melrose

Location: MELROSE BAR
120 Main St
Melrose, MT 59743 Silver Bow

System Facility ID:47-07486

Facility Code: 28431
Last Inspected On: 11/15/2023
Operating Permit Renewal Date: 03/03/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Melrose License Holdings LLC;Rebecca Mergenthaler	**(406) 799-3577**	**melrosebar@yahoo.com**
Operator Contact:	Lee Lively;Rebecca Mergenthaler	**(406) 799-3577**	**brkcano@3rivers.net;melrosebar@yahoo.com**

Owner/Operator:	Melrose License Holdings LLC	(406) 799-3577	melrosebar@yahoo.com
Owner/Operator:	Rebecca Mergenthaler	(406) 799-3577	melrosebar@yahoo.com
	Lee Lively, UST Class A Operator		brkcano@3rivers.net
	Lee Lively, UST Class A Operator		brkcano@3rivers.net
	Lee Lively, UST Class B Operator		brkcano@3rivers.net
	Lee Lively, UST Class B Operator		brkcano@3rivers.net
	Rebecca Mergenthaler, UST Class A Operator		melrosebar@yahoo.com
	Rebecca Mergenthaler, UST Class A Operator		melrosebar@yahoo.com
	Rebecca Mergenthaler, UST Class B Operator		melrosebar@yahoo.com
	Rebecca Mergenthaler, UST Class B Operator		melrosebar@yahoo.com

Tank Number	01	**Tank Age**	42	**Tank Installed Date**	05/08/1983	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	4054	**Spill Test Date**	11/09/2021	**Piping Installed Date**	08/16/2011	**Tank Construction**	Lined Interior/Impressed Current	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	07/20/2023	**Sump Tightness Test Date**	11/09/2021	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**	08/18/2022	**Tank/Piping CP Test Date**	02/03/2021	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	07/20/2023	**Line Tightness Test Date**	10/06/2020	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date	02/10/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	02	**Tank Age**	42	**Tank Installed Date**	05/08/1983	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	4055	**Spill Test Date**	11/09/2021	**Piping Installed Date**	08/16/2011	**Tank Construction**	Lined Interior/Impressed Current	**Piping Construction**	Double Walled	**AST**	No

Status	**Currently in Use**	**MLLD Test Date**	07/20/2023	**Sump Tightness Test Date**	11/09/2021	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Diesel	**PLLD Test Date**	08/18/2022	**Tank/Piping CP Test Date**	02/03/2021	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**	07/20/2023	**Line Tightness Test Date**	10/06/2020	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date	02/10/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Silver Bow County in the City of Rocker

Location: ROCKER FLYING J
122000 N Browns Gulch Rd
Rocker, MT 59701 Silver Bow

System Facility ID:47-09893

Facility Code: 28472
Last Inspected On: 03/27/2025
Operating Permit Renewal Date: 11/11/2025

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Rocker 3 Town Pump LLC	**(406) 497-6700**	**environmental@townpump.com**
Operator Contact:	Trent Biggers		**Trentb@townpump.com**

Owner/Operator:	Rocker 3 Town Pump LLC	(406) 497-6700	environmental@townpump.com
	Trent Biggers, UST Class A Operator		Trentb@townpump.com
	Trent Biggers, UST Class A Operator		Trentb@townpump.com
	Trent Biggers, UST Class A Operator		Trentb@townpump.com
	Trent Biggers, UST Class B Global Operator		Trentb@townpump.com
	Trent Biggers, UST Class B Global Operator		Trentb@townpump.com
	Trent Biggers, UST Class B Global Operator		Trentb@townpump.com

Tank Number	15	**Tank Age**	13	**Tank Installed Date**	04/12/2012	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve;Flapper Valve
Tag Number	5302	**Spill Test Date**	04/16/2024	**Piping Installed Date**	04/12/2012	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	04/25/2025	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	03/27/2025	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	30000	**ATG Test Date**	03/27/2025	**Line Tightness Test Date**	09/06/2014	**Secondary Tank Leak Detection**	Statistical Inventory Reconciliation	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	Yes
		Overfill Test Date	04/16/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Number	16	**Tank Age**	13	**Tank Installed Date**	04/12/2012	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve;Flapper Valve
Tag Number	5303	**Spill Test Date**	08/01/2024	**Piping Installed Date**	08/26/2014	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	04/25/2025	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	03/27/2025	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No

Capacity	30000	**ATG Test Date**	03/27/2025	**Line Tightness Test Date**	09/06/2014	**Secondary Tank Leak Detection**	Statistical Inventory Reconciliation	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	Yes
		Overfill Test Date	04/16/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Number	17	**Tank Age**	13	**Tank Installed Date**	04/12/2012	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve;Flapper Valve
Tag Number	5304	**Spill Test Date**	04/16/2024	**Piping Installed Date**	08/26/2014	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	04/25/2025	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	03/27/2025	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	30000	**ATG Test Date**	03/27/2025	**Line Tightness Test Date**	09/06/2014	**Secondary Tank Leak Detection**	Statistical Inventory Reconciliation	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	Yes
		Overfill Test Date	04/16/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Number	18	**Tank Age**	13	**Tank Installed Date**	04/12/2012	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve;Flapper Valve
Tag Number	5305	**Spill Test Date**	04/16/2024	**Piping Installed Date**	08/26/2014	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	04/25/2025	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	03/27/2025	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	Yes
Capacity	30000	**ATG Test Date**	03/27/2025	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Statistical Inventory Reconciliation	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	Yes
		Overfill Test Date	04/16/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Number	19	**Tank Age**	13	**Tank Installed Date**	04/12/2012	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve;Flapper Valve
Tag Number	5306	**Spill Test Date**	04/16/2024	**Piping Installed Date**	07/25/2011	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	04/25/2025	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel, Dyed	**PLLD Test Date**	03/27/2025	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	03/27/2025	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Statistical Inventory Reconciliation	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	Yes

		Overfill Test Date	04/16/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Number	20	**Tank Age**	13	**Tank Installed Date**	04/12/2012	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve;Flapper Valve
Tag Number	5307	**Spill Test Date**	08/01/2024	**Piping Installed Date**	07/25/2011	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	04/25/2025	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	03/27/2025	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	Yes
Capacity	15000	**ATG Test Date**	03/27/2025	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Statistical Inventory Reconciliation	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	Yes
		Overfill Test Date	04/16/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Number	21	**Tank Age**	13	**Tank Installed Date**	04/12/2012	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve;Flapper Valve
Tag Number	5308	**Spill Test Date**	04/16/2024	**Piping Installed Date**	07/25/2011	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	04/25/2025	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	03/27/2025	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	03/27/2025	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Statistical Inventory Reconciliation	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	Yes
		Overfill Test Date	04/16/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Number	23	**Tank Age**	14	**Tank Installed Date**	07/25/2011	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Unknown	**Overfill Types**	
Tag Number	5364	**Spill Test Date**		**Piping Installed Date**	07/25/2011	**Tank Construction**	Double-Walled	**Piping Construction**	None	**AST**	No
Status	**Other**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**		**Piping Type**	Not Listed	**CP Met Types**	
Product	DEF (Not Regulated)	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Not Listed	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**		**Energy Act**	Yes
		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				

Tank Number	24	**Tank Age**	0	**Tank Installed Date**	02/19/2025	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	6283	**Spill Test Date**	04/25/2025	**Piping Installed Date**	03/01/2025	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	04/25/2025	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	Yes
Capacity	22000	**ATG Test Date**	04/25/2025	**Line Tightness Test Date**	03/03/2025	**Secondary Tank Leak Detection**	Statistical Inventory Reconciliation	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	Yes
		Overfill Test Date	04/25/2025			**ATG Type**					
Tank Number	25	**Tank Age**	0	**Tank Installed Date**	02/19/2025	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	6284	**Spill Test Date**	04/25/2025	**Piping Installed Date**	03/01/2025	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	04/25/2025	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	Yes
Capacity	8000	**ATG Test Date**	04/25/2025	**Line Tightness Test Date**	03/03/2025	**Secondary Tank Leak Detection**	Statistical Inventory Reconciliation	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	Yes
		Overfill Test Date	04/25/2025			**ATG Type**					
Tank Number	26	**Tank Age**	0	**Tank Installed Date**	02/19/2025	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	
Tag Number	6285	**Spill Test Date**	04/25/2025	**Piping Installed Date**	03/01/2025	**Tank Construction**		**Piping Construction**		**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	04/25/2025	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	22000	**ATG Test Date**	04/25/2025	**Line Tightness Test Date**	03/03/2025	**Secondary Tank Leak Detection**	Statistical Inventory Reconciliation	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	Yes
		Overfill Test Date	04/25/2025			**ATG Type**					
Tank Number	27	**Tank Age**	0	**Tank Installed Date**	02/19/2025	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	6286	**Spill Test Date**	04/25/2025	**Piping Installed Date**	03/01/2025	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No

Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	04/25/2025	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Gasoline, E10	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	Yes
Capacity	8000	**ATG Test Date**	04/25/2025	**Line Tightness Test Date**	03/03/2025	**Secondary Tank Leak Detection**	Statistical Inventory Reconciliation	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	Yes
		Overfill Test Date	04/25/2025			**ATG Type**					

Facility Summary in Silver Bow County in the City of Rocker

Location: TOWN PUMP INC ROCKER
1000 Grizzly Trl
Rocker, MT 59701-9646 Silver Bow

System Facility ID:47-13173

Facility Code: 28501
Last Inspected On: 03/27/2025
Operating Permit Renewal Date: 09/15/2028

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Rocker 1 Town Pump LLC **(406) 497-6700** **environmental@townpump.com**

Operator Contact: Trent Biggers **Trentb@townpump.com**

Owner/Operator: Rocker 1 Town Pump LLC (406) 497-6700 environmental@townpump.com

Trent Biggers, UST Class A Operator Trentb@townpump.com
Trent Biggers, UST Class A Operator Trentb@townpump.com
Trent Biggers, UST Class B Global Operator Trentb@townpump.com
Trent Biggers, UST Class B Global Operator Trentb@townpump.com

Tank Number	01	**Tank Age**	32	**Tank Installed Date**	06/01/1993	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve
Tag Number	2635	**Spill Test Date**	04/16/2024	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	03/27/2025	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	03/27/2025	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Approved Remote Monitoring	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	04/16/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Number	02	**Tank Age**	32	**Tank Installed Date**	06/01/1993	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve
Tag Number	2636	**Spill Test Date**	07/31/2024	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	03/27/2025	**Sump Tightness Test Date**	05/13/2024	**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No

Capacity	12000	**ATG Test Date**	03/27/2025	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Approved Remote Monitoring	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	04/16/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Number	03	**Tank Age**	32	**Tank Installed Date**	06/01/1993	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve
Tag Number	2637	**Spill Test Date**	07/31/2024	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	02/25/2020	**Sump Tightness Test Date**	05/13/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	03/27/2025	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	03/27/2025	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Approved Remote Monitoring	**Secondary Pipe Leak Detection**	Approved Remote Monitoring;Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	04/16/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Number	04	**Tank Age**	32	**Tank Installed Date**	06/01/1993	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve
Tag Number	2638	**Spill Test Date**	07/31/2024	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	02/25/2020	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	03/27/2025	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	03/27/2025	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Approved Remote Monitoring	**Secondary Pipe Leak Detection**	Approved Remote Monitoring	**Energy Act**	No
		Overfill Test Date	04/16/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Number	05	**Tank Age**	32	**Tank Installed Date**	06/01/1993	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve
Tag Number	2639	**Spill Test Date**	04/16/2024	**Piping Installed Date**	09/14/2006	**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	03/27/2025	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	03/27/2025	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Approved Remote Monitoring	**Secondary Pipe Leak Detection**	Approved Remote Monitoring	**Energy Act**	No

		Overfill Test Date	04/16/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Number	06	**Tank Age**	32	**Tank Installed Date**	06/01/1993	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve
Tag Number	2640	**Spill Test Date**	04/16/2024	**Piping Installed Date**	09/14/2006	**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	03/27/2025	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	03/27/2025	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Approved Remote Monitoring	**Secondary Pipe Leak Detection**	Approved Remote Monitoring	**Energy Act**	No
		Overfill Test Date	04/16/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Number	07	**Tank Age**	32	**Tank Installed Date**	06/01/1993	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve
Tag Number	2641	**Spill Test Date**	04/16/2024	**Piping Installed Date**	09/14/2006	**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	03/27/2025	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Approved Remote Monitoring	**Secondary Pipe Leak Detection**	Approved Remote Monitoring	**Energy Act**	No
		Overfill Test Date	04/16/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Number	08	**Tank Age**	32	**Tank Installed Date**	06/01/1993	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve
Tag Number	2642	**Spill Test Date**	07/31/2024	**Piping Installed Date**	09/14/2006	**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	03/27/2025	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	03/27/2025	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Approved Remote Monitoring	**Secondary Pipe Leak Detection**	Approved Remote Monitoring	**Energy Act**	No
		Overfill Test Date	04/16/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Number	09	**Tank Age**	32	**Tank Installed Date**	06/01/1993	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve

Tag Number	2643	**Spill Test Date**	04/16/2024	**Piping Installed Date**	09/14/2006	**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	03/27/2025	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	03/27/2025	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Approved Remote Monitoring	**Secondary Pipe Leak Detection**	Approved Remote Monitoring	**Energy Act**	No
		Overfill Test Date	04/16/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Number	10	**Tank Age**	32	**Tank Installed Date**	06/01/1993	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve
Tag Number	2644	**Spill Test Date**	04/16/2024	**Piping Installed Date**	09/14/2006	**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	03/27/2025	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	03/27/2025	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Approved Remote Monitoring	**Secondary Pipe Leak Detection**	Approved Remote Monitoring	**Energy Act**	No
		Overfill Test Date	04/16/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Number	11	**Tank Age**	32	**Tank Installed Date**	06/01/1993	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve
Tag Number	2645	**Spill Test Date**	07/31/2024	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	03/27/2025	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	03/27/2025	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Approved Remote Monitoring	**Secondary Pipe Leak Detection**	Approved Remote Monitoring	**Energy Act**	No
		Overfill Test Date	04/16/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Number	12	**Tank Age**	26	**Tank Installed Date**	06/01/1999	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve
Tag Number	4103	**Spill Test Date**	04/16/2024	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	03/27/2025	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible

Product	Diesel, Dyed	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	03/27/2025	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	04/16/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Number	13	**Tank Age**	13	**Tank Installed Date**	11/01/2012	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	
Tag Number	5375	**Spill Test Date**		**Piping Installed Date**	05/07/2012	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Other**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Auto Dialer	**Piping Type**	Pressurized	**CP Met Types**	
Product	DEF (Not Regulated)	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	07/25/2022	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	Yes
		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				

Facility Summary in Stillwater County in the City of Absarokee

Location: ROCKIN J
2993 MT Hwy 78
Absarokee, MT 59001 Stillwater

System Facility ID:56-13932

Facility Code: 30602
Last Inspected On: 08/21/2023
Operating Permit Renewal Date: 11/08/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Automatic Car Wash Inc;Gene Carlson;Automatic Car Wash Inc	**(406) 248-2558**	**donscarwashmt@gmail.com;donscarwashmt@gmail.com;donscarwashmt@gmail.com**
Operator Contact:	Eric Carlson;Gene Carlson;Automatic Car Wash Inc	**(406) 248-2558;(406) 894-2373**	**donscarwashmt@gmail.com;donscarwashmt@gmail.com;donsxpress24@outlook.com**

Owner/Operator:	Automatic Car Wash Inc	donscarwashmt@gmail.com
Owner/Operator:	Gene Carlson,Automatic Car Wash Inc	donscarwashmt@gmail.com
	Eric Carlson, UST Class A Operator	donsxpress24@outlook.com
	Eric Carlson, UST Class A Operator	donsxpress24@outlook.com
	Eric Carlson, UST Class B Operator	donsxpress24@outlook.com
	Eric Carlson, UST Class B Operator	donsxpress24@outlook.com
	Gene Carlson, UST Class A Operator	donscarwashmt@gmail.com
	Gene Carlson, UST Class A Operator	donscarwashmt@gmail.com
	Gene Carlson, UST Class B Operator	donscarwashmt@gmail.com
	Gene Carlson, UST Class B Operator	donscarwashmt@gmail.com

Tank Number	01	**Tank Age**	26	**Tank Installed Date**	05/01/1999	**Tank Material Construction**	Steel Clad	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	4038	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	2000	**ATG Test Date**		**Line Tightness Test Date**	05/08/2023	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	02	**Tank Age**	26	**Tank Installed Date**	05/01/1999	**Tank Material Construction**	Steel Clad	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	4039	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Single Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible

Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**		**Line Tightness Test Date**	12/07/2023	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	03	**Tank Age**	26	**Tank Installed Date**	05/01/1999	**Tank Material Construction**	Steel Clad	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	4040	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	11/25/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**		**Line Tightness Test Date**	11/25/2024	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	04	**Tank Age**	26	**Tank Installed Date**	05/01/1999	**Tank Material Construction**	Steel Clad	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	4041	**Spill Test Date**	05/20/2020	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	11/25/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**		**Line Tightness Test Date**	11/25/2024	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	05	**Tank Age**	26	**Tank Installed Date**	05/01/1999	**Tank Material Construction**	Steel Clad	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	4042	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	11/25/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**		**Line Tightness Test Date**	11/25/2024	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Tank Number	06	**Tank Age**	2	**Tank Installed Date**	05/02/2023	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	6151	**Spill Test Date**	05/02/2023	**Piping Installed Date**	05/02/2023	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	05/02/2023	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	Yes
Capacity	10000	**ATG Test Date**		**Line Tightness Test Date**	05/08/2023	**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	Yes
		Overfill Test Date	05/02/2023			**ATG Type**					

Facility Summary in Stillwater County in the City of Columbus

Location: FARMERS UNION TRADING CO
101 S Pratten St
Columbus, MT 59019-0509 Stillwater

System Facility ID:48-03409

Facility Code: 28554
Last Inspected On: 07/11/2022
Operating Permit Renewal Date: 10/31/2025

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Farmers Union Trading Co Columbus	**(406) 780-0660**	**manager@farmersuniontrading.com**
Operator Contact:	Jeff Parker	**(503) 298-3965**	**jjp7850@gmail.com**

Owner/Operator: Farmers Union Trading Co Columbus (406) 780-0660 manager@farmersuniontrading.com

Clarence McCade, UST Class B Operator
Jeff Parker, UST Class A Operator jjp7850@gmail.com
Jeff Parker, UST Class B Operator jjp7850@gmail.com

Tank Number	10	**Tank Age**	33	**Tank Installed Date**	10/01/1992	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	1033	**Spill Test Date**	07/11/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**	07/11/2022	**Tank/Piping CP Test Date**	07/11/2022	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	5500	**ATG Test Date**	07/11/2022	**Line Tightness Test Date**	07/10/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	07/11/2022			**ATG Type**	Gilbarco/EMC Basic				
Tank Number	11	**Tank Age**	33	**Tank Installed Date**	10/01/1992	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	1034	**Spill Test Date**	07/11/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**	07/11/2022	**Tank/Piping CP Test Date**	07/11/2022	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	2500	**ATG Test Date**	07/11/2022	**Line Tightness Test Date**	01/09/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	07/11/2022			**ATG Type**	Gilbarco/EMC Basic				
Tank Number	12	**Tank Age**	33	**Tank Installed Date**	10/01/1992	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm

Tag Number	1035	**Spill Test Date**	07/11/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	07/11/2022	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	2500	**ATG Test Date**	07/11/2022	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	07/11/2022			**ATG Type**	Gilbarco/EMC Basic				
Tank Number	14	**Tank Age**	27	**Tank Installed Date**	07/01/1998	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	1037	**Spill Test Date**	07/11/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**	07/11/2022	**Tank/Piping CP Test Date**	07/11/2022	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	07/11/2022	**Line Tightness Test Date**	01/13/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	07/11/2022			**ATG Type**	Gilbarco/EMC Basic				
Tank Number	13	**Tank Age**	27	**Tank Installed Date**	07/01/1998	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	4731	**Spill Test Date**	07/11/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Diesel, Dyed	**PLLD Test Date**	07/11/2022	**Tank/Piping CP Test Date**	07/11/2022	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	07/11/2022	**Line Tightness Test Date**	04/10/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	07/11/2022			**ATG Type**	Gilbarco/EMC Basic				

Facility Summary in Stillwater County in the City of Columbus

Location: GITS CONOCO
740 E Pike Ave
Columbus, MT 59019 Stillwater

System Facility ID:48-07859

Facility Code: 28599
Last Inspected On: 07/11/2022
Operating Permit Renewal Date: 10/26/2025

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Gits Inc	**(406) 322-4111**	
Operator Contact:	Gary Woltermann;Tracy Gernant	**(406) 322-4111;(406) 322-5026**	**warheart@q.com**

Owner/Operator: Gits Inc (406) 322-4111

Gary Woltermann, UST Class A Operator	
Gary Woltermann, UST Class A Operator	
Gary Woltermann, UST Class B Global Operator	
Gary Woltermann, UST Class B Global Operator	
Tracy Gernant, UST Class A Operator	warheart@q.com
Tracy Gernant, UST Class A Operator	warheart@q.com
Tracy Gernant, UST Class B Global Operator	warheart@q.com
Tracy Gernant, UST Class B Global Operator	warheart@q.com

Tank Number	01	**Tank Age**	46	**Tank Installed Date**	05/08/1979	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	3209	**Spill Test Date**	07/11/2022	**Piping Installed Date**		**Tank Construction**	Lined Interior/Impressed Current	**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**	07/11/2022	**Tank/Piping CP Test Date**	07/11/2022	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	07/11/2022	**Line Tightness Test Date**	07/09/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	07/11/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	02	**Tank Age**	46	**Tank Installed Date**	05/08/1979	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	3210	**Spill Test Date**	07/11/2022	**Piping Installed Date**		**Tank Construction**	Lined Interior/Impressed Current	**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current

Product	Gasoline	**PLLD Test Date**	07/11/2022	**Tank/Piping CP Test Date**	07/11/2022	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	07/11/2022	**Line Tightness Test Date**	07/11/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	07/11/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Stillwater County in the City of Columbus

Location: TOWN PUMP INC COLUMBUS UST
602 E 8th Ave N
Columbus, MT 59019 Stillwater

System Facility ID:48-08691

Facility Code: 28607
Last Inspected On: 03/05/2024
Operating Permit Renewal Date: 07/21/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Columbus 1 Town Pump LLC	**(406) 497-6700**	**environmental@townpump.com**
Operator Contact:	Trent Biggers		**Trentb@townpump.com**

Owner/Operator:	Columbus 1 Town Pump LLC	(406) 497-6700	environmental@townpump.com
	Trent Biggers, UST Class A Operator		Trentb@townpump.com
	Trent Biggers, UST Class A Operator		Trentb@townpump.com
	Trent Biggers, UST Class B Global Operator		Trentb@townpump.com
	Trent Biggers, UST Class B Global Operator		Trentb@townpump.com

Tank Number	03	**Tank Age**	41	**Tank Installed Date**	05/01/1984	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	2646	**Spill Test Date**	08/18/2023	**Piping Installed Date**		**Tank Construction**	Lined Interior/Impressed Current	**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Diesel	**PLLD Test Date**	03/05/2024	**Tank/Piping CP Test Date**	08/18/2023	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**	03/05/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	08/18/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Number	06	**Tank Age**	41	**Tank Installed Date**	09/01/1984	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	2647	**Spill Test Date**	08/18/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**	03/05/2024	**Tank/Piping CP Test Date**	08/18/2023	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	03/05/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No

		Overfill Test Date	08/18/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-450				
Tank Number	07	**Tank Age**	37	**Tank Installed Date**	12/29/1988	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	2648	**Spill Test Date**	08/18/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**	03/05/2024	**Tank/Piping CP Test Date**	08/18/2023	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	03/05/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	08/18/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-450				
Tank Number	08	**Tank Age**	37	**Tank Installed Date**	11/01/1988	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	2649	**Spill Test Date**	08/18/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**	03/05/2024	**Tank/Piping CP Test Date**	08/18/2023	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Approved Remote Monitoring;Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	03/05/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	08/18/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-450				
Tank Number	09	**Tank Age**	37	**Tank Installed Date**	11/01/1988	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	2650	**Spill Test Date**	08/18/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**	03/05/2024	**Tank/Piping CP Test Date**	08/18/2023	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	03/05/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	08/18/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-450				
Tank Number	10	**Tank Age**	37	**Tank Installed Date**	11/01/1988	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	2651	**Spill Test Date**	08/18/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Single Walled	**AST**	No

Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**	03/05/2024	**Tank/Piping CP Test Date**	08/18/2023	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	03/05/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	08/18/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Number	11	**Tank Age**	26	**Tank Installed Date**	06/25/1999	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	4064	**Spill Test Date**	08/18/2023	**Piping Installed Date**	06/16/2020	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	08/18/2023	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	03/05/2024	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	15000	**ATG Test Date**	03/05/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	No
		Overfill Test Date	08/18/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-450				
Tank Number	12	**Tank Age**	26	**Tank Installed Date**	06/25/1999	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve
Tag Number	4065	**Spill Test Date**	08/18/2023	**Piping Installed Date**	06/16/2020	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	08/18/2023	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	03/05/2024	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	03/05/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	No
		Overfill Test Date	08/18/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-450				
Tank Number	13	**Tank Age**	26	**Tank Installed Date**	06/25/1999	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve
Tag Number	4066	**Spill Test Date**	08/18/2023	**Piping Installed Date**	06/16/2020	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	08/18/2023	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	03/05/2024	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No

Capacity	8000	**ATG Test Date**	03/05/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	No
		Overfill Test Date	08/18/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-450				
Tank Number	14	**Tank Age**	21	**Tank Installed Date**	12/30/2004	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve
Tag Number	4933	**Spill Test Date**	08/18/2023	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	08/18/2023	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	03/05/2024	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	20000	**ATG Test Date**	03/05/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	08/18/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Number	15	**Tank Age**	12	**Tank Installed Date**	10/01/2013	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	
Tag Number	5437	**Spill Test Date**		**Piping Installed Date**	08/25/2013	**Tank Construction**	Double-Walled	**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**		**Piping Type**	Pressurized	**CP Met Types**	
Product	DEF (Not Regulated)	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Not Listed	**Primary Pipe Leak Detection**	Not Listed	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Not Listed	**Energy Act**	Yes
		Overfill Test Date				**ATG Type**					
Tank Number	16	**Tank Age**	5	**Tank Installed Date**	06/16/2020	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	5968	**Spill Test Date**	08/18/2023	**Piping Installed Date**	06/16/2020	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	08/18/2023	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	03/05/2024	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	Yes
Capacity	8000	**ATG Test Date**	03/05/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Statistical Inventory Reconciliation	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	Yes
		Overfill Test Date	08/18/2023			**ATG Type**					

Tank Number	17	**Tank Age**	0	**Tank Installed Date**		**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	
Tag Number	5969	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**		**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**		**Piping Type**	Pressurized	**CP Met Types**	
Product	DEF (Not Regulated)	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					

Facility Summary in Stillwater County in the City of Fishtail

Location: FISHTAIL BASIN RANCH
633 Fiddler Creek Rd
Fishtail, MT 59028-8021 Stillwater

System Facility ID:56-13917

Facility Code: 30587
Last Inspected On: 12/13/2023
Operating Permit Renewal Date: 01/28/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Francis Abbott;Francis Abbott Jr **(610) 353-9700**

Operator Contact: Francis Abbott **(610) 353-9700**

Owner/Operator: Francis Abbott (610) 353-9700

Owner/Operator: Francis H Abbott Jr (610) 353-9700

Francis Abbott, UST Class A Operator

Francis Abbott, UST Class B Operator

Tank Number	S1	**Tank Age**	26	**Tank Installed Date**	03/01/1999	**Tank Material Construction**	Steel Clad	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	4400	**Spill Test Date**	11/02/2023	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	11/10/2020	**Catastrophic L.D. Type 3.0**	Continuous Interstitial Monitoring	**Piping Type**	U.S. Suction	**CP Met Types**	Non-corrodible
Product	Heating Oil	**PLLD Test Date**		**Tank/Piping CP Test Date**	12/13/2011	**Primary Tank Leak Detection**	Manual Interstitial Monitoring	**Primary Pipe Leak Detection**	3-Year Line Tightness Test	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**		**Line Tightness Test Date**	11/03/2023	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Manual Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	12/13/2023			**ATG Type**					

Facility Summary in Stillwater County in the City of Fishtail

Location: FISHTAIL GENERAL STORE
35 W Main St
Fishtail, MT 59028-0040 Stillwater

System Facility ID:48-03599

Facility Code: 28556
Last Inspected On: 10/24/2024
Operating Permit Renewal Date: 03/09/2028

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Fishtail General Store **(406) 328-4260** **fishtailstore@montana.net**

Operator Contact: Katy Martin

Owner/Operator: Fishtail General Store (406) 328-4260 fishtailstore@montana.net

Katy Martin, UST Class A Operator
Katy Martin, UST Class A Operator
Katy Martin, UST Class B Operator
Katy Martin, UST Class B Operator

Tank Number	02	**Tank Age**	32	**Tank Installed Date**	05/01/1993	**Tank Material Construction**	Steel Clad	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	1086	**Spill Test Date**	10/18/2024	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	10/08/2024	**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	09/25/2015	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	1000	**ATG Test Date**	10/18/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	10/18/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	03	**Tank Age**	32	**Tank Installed Date**	05/01/1993	**Tank Material Construction**	Steel Clad	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	1087	**Spill Test Date**	10/18/2024	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	10/08/2024	**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	09/25/2015	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	1002	**ATG Test Date**	10/18/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No

		Overfill Test Date	10/18/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Stillwater County in the City of Fishtail

Location: NYE TRADING POST
1997 Nye Rd
Fishtail, MT 59028 Stillwater

System Facility ID:48-09647

Facility Code: 28616
Last Inspected On: 11/11/2024
Operating Permit Renewal Date: 03/05/2028

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Chance Kukowski;Nye MT LLC	**(406) 328-6262;(720) 383-3694**	**hbenson4469@yahoo.com;tandil@live.com**
Operator Contact:	Heath Benson	**(720) 383-3694**	**hbenson4469@yahoo.com**

Owner/Operator:	Chance Kukowski	(406) 328-6262	tandil@live.com
Owner/Operator:	Nye MT LLC	(406) 328-6262	tandil@live.com
	Heath Benson, UST Class A Operator		hbenson4469@yahoo.com
	Heath Benson, UST Class B Global Operator		hbenson4469@yahoo.com

Tank Number	03	**Tank Age**	32	**Tank Installed Date**	10/01/1993	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	1296	**Spill Test Date**	11/11/2024	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	11/11/2024	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	1000	**ATG Test Date**	11/11/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	11/11/2024			**ATG Type**	Veeder Root/TLS-300				
Tank Number	04	**Tank Age**	32	**Tank Installed Date**	10/01/1993	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	1297	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Temporarily Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	11/11/2024	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	1000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**	Veeder Root/TLS-300				

Facility Summary in Stillwater County in the City of Fishtail

Location: TIPPET RISE COTTONWOOD SITE
96 S Grove Creek Rd
Fishtail, MT 59028 Stillwater

System Facility ID:60-15267

Facility Code: 30980
Last Inspected On: 06/12/2023
Operating Permit Renewal Date: 10/16/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Tippet Rise Cottonwood Site **(406) 255-9287**

Operator Contact: Carl Mayer;Dan Luttschwager **(207) 620-6273;(406) 860-0947** **carl.mayer@tippetrise.org**

Owner/Operator: Tippet Rise Cottonwood Site (406) 255-9287

Carl Mayer, UST Class A Operator carl.mayer@tippetrise.org
Carl Mayer, UST Class B Global Operator carl.mayer@tippetrise.org
Dan Luttschwager, UST Class A Operator

Tank Number	01	**Tank Age**	9	**Tank Installed Date**	10/07/2016	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	5618	**Spill Test Date**	05/30/2023	**Piping Installed Date**	10/07/2016	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	05/30/2023	**Catastrophic L.D. Type 3.0**	Continuous Interstitial Monitoring	**Piping Type**	U.S. Suction	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	1000	**ATG Test Date**	05/30/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**		**Energy Act**	Yes
		Overfill Test Date	05/30/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-300				

Facility Summary in Stillwater County in the City of Park City

Location: KWIK STOP INC
1 N Clark St
Park City, MT 59063 Stillwater

System Facility ID:48-06610

Facility Code: 28591
Last Inspected On: 03/14/2025
Operating Permit Renewal Date: 03/17/2028

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Margaret Keating	**(406) 633-2730**	**whoawhat@aol.com**

Operator Contact:	Margaret Keating	**(406) 633-2730**	**whoawhat@aol.com**

Owner/Operator: Margaret Keating (406) 633-2730 whoawhat@aol.com

Margaret Keating, UST Class A Operator whoawhat@aol.com

Margaret Keating, UST Class B Operator whoawhat@aol.com

Tank Number	03	**Tank Age**	28	**Tank Installed Date**	05/05/1997	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	1507	**Spill Test Date**	02/24/2025	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Single Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	03/14/2025	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	02/14/2025	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	02/14/2025			**ATG Type**	Veeder Root/TLS-300				
Tank Number	04	**Tank Age**	28	**Tank Installed Date**	05/05/1997	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	1508	**Spill Test Date**	02/24/2025	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Single Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	03/14/2025	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	02/14/2025	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	02/14/2025			**ATG Type**	Veeder Root/TLS-300				

Facility Summary in Stillwater County in the City of Park City

Location: ZIP TRIP 50
EXIT 426 AND I-90
Park City, MT 59063 Stillwater

System Facility ID:48-08910

Facility Code: 28609
Last Inspected On: 08/24/2023
Operating Permit Renewal Date: 04/24/2020

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	CHS Inc Spokane Valley	**(509) 535-7701**	**Donald.Widdicombe@chsinc.com**
Operator Contact:	Jim Alford;Sean Hurley	**(509) 535-7701;(509) 536-7418**	**jim.alford@chsinc.com;sean.hurley@chsinc.com**

Owner/Operator: CHS Inc Spokane Valley (509) 535-7701 Donald.Widdicombe@chsinc.com

Hannah Smith, UST Class B Operator	hannah.smith3@chsinc.com
Jim Alford, UST Class A Operator	jim.alford@chsinc.com
Jim Alford, UST Class A Operator	jim.alford@chsinc.com
Jim Alford, UST Class B Operator	jim.alford@chsinc.com
Jim Alford, UST Class B Operator	jim.alford@chsinc.com
Luci Tuttle, UST Class B Operator	Lucinda.Tuttle@chsinc.com
Sean Hurley, UST Class A Operator	sean.hurley@chsinc.com
Sean Hurley, UST Class A Operator	sean.hurley@chsinc.com

Tank Number	17	**Tank Age**	10	**Tank Installed Date**	06/01/2015	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	
Tag Number	5599	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Other**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Continuous Interstitial Monitoring	**Piping Type**	Not Listed	**CP Met Types**	
Product	DEF (Not Regulated)	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Not Listed	**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	08	**Tank Age**	33	**Tank Installed Date**	05/01/1992	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	568	**Spill Test Date**		**Piping Installed Date**	06/04/2015	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**	05/07/2015	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic

Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	12/14/2015	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2;ELLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	24000	**ATG Test Date**		**Line Tightness Test Date**	05/19/2011	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	09	**Tank Age**	33	**Tank Installed Date**	05/01/1992	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	569	**Spill Test Date**		**Piping Installed Date**	06/04/2015	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**	05/07/2015	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	12/14/2015	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2;ELLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	24000	**ATG Test Date**		**Line Tightness Test Date**	05/19/2011	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	10	**Tank Age**	33	**Tank Installed Date**	05/01/1992	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	570	**Spill Test Date**		**Piping Installed Date**	06/04/2015	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**	05/07/2015	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	12/14/2015	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2;ELLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	24000	**ATG Test Date**		**Line Tightness Test Date**	08/17/2005	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	11	**Tank Age**	33	**Tank Installed Date**	05/01/1992	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	571	**Spill Test Date**		**Piping Installed Date**	06/04/2015	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**	05/07/2015	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	12/14/2015	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2;ELLD Line Tightness Testing	**Vapor Recovery**	No

Capacity	24000	**ATG Test Date**		**Line Tightness Test Date**	08/17/2005	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	12	**Tank Age**	33	**Tank Installed Date**	05/01/1992	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	572	**Spill Test Date**		**Piping Installed Date**	06/04/2015	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**	05/07/2015	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	12/14/2015	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2;ELLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	24000	**ATG Test Date**		**Line Tightness Test Date**	08/17/2005	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	13	**Tank Age**	33	**Tank Installed Date**	05/01/1992	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	573	**Spill Test Date**		**Piping Installed Date**	06/04/2015	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**	05/07/2015	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	12/14/2015	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2;ELLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	24000	**ATG Test Date**		**Line Tightness Test Date**	08/17/2005	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	14	**Tank Age**	27	**Tank Installed Date**	08/01/1998	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm;Positive Shutoff
Tag Number	574	**Spill Test Date**		**Piping Installed Date**	06/04/2015	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**	05/07/2015	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	12/14/2015	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2;ELLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	30000	**ATG Test Date**		**Line Tightness Test Date**	08/17/2005	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No

		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	15	**Tank Age**	27	**Tank Installed Date**	08/01/1998	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm;Positive Shutoff
Tag Number	575	**Spill Test Date**		**Piping Installed Date**	06/04/2015	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**	05/07/2015	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	12/14/2015	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2;ELLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	30000	**ATG Test Date**		**Line Tightness Test Date**	08/17/2005	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	16	**Tank Age**	27	**Tank Installed Date**	08/01/1998	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm;Positive Shutoff
Tag Number	576	**Spill Test Date**		**Piping Installed Date**	06/04/2015	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**	05/07/2015	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	12/14/2015	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2;ELLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	30000	**ATG Test Date**		**Line Tightness Test Date**	08/17/2005	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	18	**Tank Age**	6	**Tank Installed Date**	10/25/2019	**Tank Material Construction**	Steel Clad	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	5954	**Spill Test Date**	08/26/2021	**Piping Installed Date**	10/25/2019	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	08/02/2021	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	Yes
Capacity	20000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	08/26/2021			**ATG Type**					

Tank Number	19	**Tank Age**	6	**Tank Installed Date**	10/25/2019	**Tank Material Construction**	Steel Clad	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	5955	**Spill Test Date**	08/26/2021	**Piping Installed Date**	10/25/2019	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	08/02/2021	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	Yes
Capacity	10000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	08/26/2021			**ATG Type**					
Tank Number	20	**Tank Age**	6	**Tank Installed Date**	10/25/2019	**Tank Material Construction**	Steel Clad	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	5957	**Spill Test Date**	08/26/2021	**Piping Installed Date**	10/25/2019	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	08/02/2021	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	Yes
Capacity	15000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	08/26/2021			**ATG Type**					
Tank Number	21	**Tank Age**	6	**Tank Installed Date**	10/25/2019	**Tank Material Construction**	Steel Clad	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	5958	**Spill Test Date**	08/26/2021	**Piping Installed Date**	10/25/2019	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	08/02/2021	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	15000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	08/26/2021			**ATG Type**					
Tank Number	22	**Tank Age**	6	**Tank Installed Date**	10/25/2019	**Tank Material Construction**	Steel Clad	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	5959	**Spill Test Date**	08/26/2021	**Piping Installed Date**	10/25/2019	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	08/02/2021	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible

Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	20000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	08/26/2021			**ATG Type**					
Tank Number	23	**Tank Age**	6	**Tank Installed Date**	10/25/2019	**Tank Material Construction**	Steel Clad	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	5960	**Spill Test Date**	08/26/2021	**Piping Installed Date**	10/25/2019	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	08/02/2021	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel, Dyed	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	08/26/2021			**ATG Type**					
Tank Number	24	**Tank Age**	6	**Tank Installed Date**	10/25/2019	**Tank Material Construction**	Steel Clad	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	5961	**Spill Test Date**	08/26/2021	**Piping Installed Date**	10/25/2019	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	08/02/2021	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	30000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	08/26/2021			**ATG Type**					

Facility Summary in Stillwater County in the City of Reed Point

Location: VALLEY FARMERS SUPPLY SURE STOP
8 Divison St
Reed Point, MT 59069 Stillwater

System Facility ID:48-01521

Facility Code: 28529
Last Inspected On: 05/08/2023
Operating Permit Renewal Date: 09/04/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Julie Pratton;Valley Farmers Supply	**(406) 967-3100**	**sblack@vfarmers.com**
Operator Contact:	Elisha Lewis;Scott Black;Steven Shelton	**(406) 322-5214;(406) 967-3100**	**cenex@imt.net;sblack@vfarmers.com;sshelton@vfarmers.com**

Owner/Operator: Julie L Pratton

Owner/Operator: Valley Farmers Supply

Elisha Lewis, UST Class A Operator	cenex@imt.net
Elisha Lewis, UST Class A Operator	cenex@imt.net
Elisha Lewis, UST Class B Global Operator	cenex@imt.net
Elisha Lewis, UST Class B Global Operator	cenex@imt.net
Scott Black, UST Class A Operator	sblack@vfarmers.com
Scott Black, UST Class A Operator	sblack@vfarmers.com
Scott Black, UST Class B Global Operator	sblack@vfarmers.com
Scott Black, UST Class B Global Operator	sblack@vfarmers.com
Stephanie Joy, UST Class B Operator	sblack@vfarmers.com
Stephanie Joy, UST Class B Operator	sblack@vfarmers.com
Steven Shelton, UST Class A Operator	sshelton@vfarmers.com

Tank Number	01	**Tank Age**	39	**Tank Installed Date**	12/10/1986	**Tank Material Construction**	Bare Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	3303	**Spill Test Date**	05/08/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**	11/04/2022	**Tank/Piping CP Test Date**	11/04/2022	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**	11/04/2022	**Line Tightness Test Date**	03/21/2023	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	11/04/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	02	**Tank Age**	39	**Tank Installed Date**	12/10/1986	**Tank Material Construction**	Bare Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm

Tag Number	3304	**Spill Test Date**	05/08/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**	11/04/2022	**Tank/Piping CP Test Date**	11/04/2022	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**	11/04/2022	**Line Tightness Test Date**	03/23/2023	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	11/04/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	03	**Tank Age**	39	**Tank Installed Date**	12/10/1986	**Tank Material Construction**	Bare Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	3305	**Spill Test Date**	03/30/2021	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Diesel	**PLLD Test Date**	11/04/2022	**Tank/Piping CP Test Date**	03/31/2020	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**		**Line Tightness Test Date**	03/23/2023	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Sweet Grass County in the City of Big Timber

Location: THE FORT
228 Big Timber Loop
Big Timber, MT 59011 Sweet Grass

System Facility ID:49-02680

Facility Code: 28652
Last Inspected On: 06/22/2023
Operating Permit Renewal Date: 09/21/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: J Diamond L Inc;Jeffrey Cowell **(406) 932-5992**

Operator Contact: Justin Cowell **(406) 932-5992** **justincowell@fortmt.com**

Owner/Operator: J Diamond L Inc (406) 932-5992

Owner/Operator: Jeffrey L Cowell (406) 932-5992

Jeremy Frisk, UST Class B Operator sports@fortmt.com

Justin Cowell, UST Class A Operator justincowell@fortmt.com

Tank Number	04	**Tank Age**	29	**Tank Installed Date**	08/01/1996	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve;Flapper Valve
Tag Number	3229	**Spill Test Date**	02/17/2022	**Piping Installed Date**	06/25/2010	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	02/19/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**	06/22/2023	**Tank/Piping CP Test Date**	06/22/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	06/22/2023	**Line Tightness Test Date**	02/19/2024	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date	07/13/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	05	**Tank Age**	29	**Tank Installed Date**	08/01/1996	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve
Tag Number	3230	**Spill Test Date**	02/17/2022	**Piping Installed Date**	06/25/2010	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	02/19/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Diesel, Dyed	**PLLD Test Date**	08/17/2022	**Tank/Piping CP Test Date**	09/19/2020	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	08/17/2022	**Line Tightness Test Date**	02/19/2024	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No

		Overfill Test Date	02/17/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	06	**Tank Age**	29	**Tank Installed Date**	08/01/1996	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve;Flapper Valve
Tag Number	3231	**Spill Test Date**	07/13/2023	**Piping Installed Date**	06/25/2010	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	02/19/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**	08/17/2022	**Tank/Piping CP Test Date**	09/19/2020	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**	08/17/2022	**Line Tightness Test Date**	02/19/2024	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date	07/13/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	07	**Tank Age**	20	**Tank Installed Date**	10/31/2005	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve;Flapper Valve
Tag Number	5052	**Spill Test Date**		**Piping Installed Date**	06/25/2010	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	02/19/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**	08/17/2022	**Tank/Piping CP Test Date**	09/19/2020	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	20000	**ATG Test Date**	08/17/2022	**Line Tightness Test Date**	02/19/2024	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Sweet Grass County in the City of Big Timber

Location: TOWN PUMP BIG TIMBER 2
20 A Big Timber Loop Rd
Big Timber, MT 59011 Sweet Grass

System Facility ID:49-09311

Facility Code: 28709
Last Inspected On: 03/18/2025
Operating Permit Renewal Date: 08/23/2028

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Big Timber 2 Town Pump LLC	**(406) 497-6700**	**environmental@townpump.com**
Operator Contact:	Trent Biggers		**Trentb@townpump.com**

Owner/Operator: Big Timber 2 Town Pump LLC (406) 497-6700 environmental@townpump.com

Trent Biggers, UST Class A Operator Trentb@townpump.com
Trent Biggers, UST Class A Operator Trentb@townpump.com
Trent Biggers, UST Class B Global Operator Trentb@townpump.com
Trent Biggers, UST Class B Global Operator Trentb@townpump.com

Tank Number	05	**Tank Age**	22	**Tank Installed Date**	04/30/2003	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	4828	**Spill Test Date**	10/17/2024	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	07/08/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	03/18/2025	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	03/18/2025	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	07/08/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-450				
Tank Number	06	**Tank Age**	22	**Tank Installed Date**	04/30/2003	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	4829	**Spill Test Date**	10/17/2024	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	07/08/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	03/18/2025	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	03/18/2025	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No

		Overfill Test Date	07/08/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-450				
Tank Number	07	**Tank Age**	22	**Tank Installed Date**	04/30/2003	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	4830	**Spill Test Date**	07/08/2024	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	07/08/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	03/18/2025	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	03/18/2025	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	07/08/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-450				
Tank Number	08	**Tank Age**	22	**Tank Installed Date**	04/30/2003	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	4831	**Spill Test Date**	07/08/2024	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	07/08/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	03/18/2025	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	03/18/2025	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	07/08/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-450				
Tank Number	09	**Tank Age**	3	**Tank Installed Date**	02/24/2022	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	6050	**Spill Test Date**	10/17/2024	**Piping Installed Date**	02/24/2022	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	03/18/2025	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	03/18/2025	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	Yes
Capacity	20000	**ATG Test Date**	03/18/2025	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Statistical Inventory Reconciliation	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	Yes
		Overfill Test Date	07/08/2024			**ATG Type**					
Tank Number	10	**Tank Age**	3	**Tank Installed Date**	02/24/2022	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve

Tag Number	6051	**Spill Test Date**	02/15/2022	**Piping Installed Date**	02/24/2022	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	07/08/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	03/18/2025	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	Yes
Capacity	6000	**ATG Test Date**	03/18/2025	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Statistical Inventory Reconciliation	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	Yes
		Overfill Test Date	07/08/2024			**ATG Type**					
Tank Number	11	**Tank Age**	3	**Tank Installed Date**	02/24/2022	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	6052	**Spill Test Date**	10/17/2024	**Piping Installed Date**	02/24/2022	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	07/08/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	03/18/2025	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	18000	**ATG Test Date**	03/18/2025	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Statistical Inventory Reconciliation	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	Yes
		Overfill Test Date	07/08/2024			**ATG Type**					
Tank Number	12	**Tank Age**	3	**Tank Installed Date**	02/24/2022	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	6053	**Spill Test Date**	07/08/2024	**Piping Installed Date**	02/24/2022	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	07/08/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	03/18/2025	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	Yes
Capacity	12000	**ATG Test Date**	03/18/2025	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Statistical Inventory Reconciliation	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	Yes
		Overfill Test Date	02/21/2022			**ATG Type**					
Tank Number	13	**Tank Age**	3	**Tank Installed Date**	04/05/2022	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	6054	**Spill Test Date**	07/08/2024	**Piping Installed Date**	04/05/2022	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	07/08/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible

Product	Diesel	**PLLD Test Date**	03/18/2025	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	30000	**ATG Test Date**	03/18/2025	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Statistical Inventory Reconciliation	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	Yes
		Overfill Test Date	03/31/2025			**ATG Type**					
Tank Number	14	**Tank Age**	3	**Tank Installed Date**	04/05/2022	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	6055	**Spill Test Date**	07/08/2024	**Piping Installed Date**	04/05/2022	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	07/08/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel, Dyed	**PLLD Test Date**	03/18/2025	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	03/18/2025	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Statistical Inventory Reconciliation	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	Yes
		Overfill Test Date	07/08/2024			**ATG Type**					
Tank Number	15	**Tank Age**	3	**Tank Installed Date**	04/05/2022	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	6056	**Spill Test Date**	07/08/2024	**Piping Installed Date**	04/05/2022	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	07/08/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	03/18/2025	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**	03/18/2025	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Statistical Inventory Reconciliation	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	Yes
		Overfill Test Date	07/08/2024			**ATG Type**					
Tank Number	16	**Tank Age**	3	**Tank Installed Date**	04/05/2022	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	6057	**Spill Test Date**	02/21/2022	**Piping Installed Date**	04/05/2022	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	02/24/2022	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	DEF (Not Regulated)	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	04/06/2022	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	Yes

		Overfill Test Date				**ATG Type**					

Facility Summary in Sweet Grass County in the City of Big Timber

Location: TOWN PUMP INC BIG TIMBER 1ST AVE
510 W 1st Ave
Big Timber, MT 59011 Sweet Grass

System Facility ID:49-13756

Facility Code: 28726
Last Inspected On: 04/29/2025
Operating Permit Renewal Date: 10/19/2028

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Big Timber 1 Town Pump LLC **(406) 497-6700** **environmental@townpump.com**

Operator Contact: Trent Biggers **Trentb@townpump.com**

Owner/Operator: Big Timber 1 Town Pump LLC (406) 497-6700 environmental@townpump.com

Trent Biggers, UST Class A Operator Trentb@townpump.com

Trent Biggers, UST Class B Global Operator Trentb@townpump.com

Tank Number	01	**Tank Age**	29	**Tank Installed Date**	08/01/1996	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve
Tag Number	2652	**Spill Test Date**	11/06/2024	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	04/29/2025	**Sump Tightness Test Date**	06/27/2024	**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	04/29/2025	**Line Tightness Test Date**	09/01/2015	**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	06/27/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350				
Tank Number	02	**Tank Age**	29	**Tank Installed Date**	10/01/1996	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve
Tag Number	2653	**Spill Test Date**	11/06/2024	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	04/29/2025	**Sump Tightness Test Date**	06/27/2024	**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	04/29/2025	**Line Tightness Test Date**	09/01/2015	**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	06/27/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350				

Tank Number	03	**Tank Age**	29	**Tank Installed Date**	10/01/1996	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve
Tag Number	2654	**Spill Test Date**	11/06/2024	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	04/29/2025	**Sump Tightness Test Date**	06/27/2024	**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	04/29/2025	**Line Tightness Test Date**	09/01/2015	**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	06/27/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350				
Tank Number	04	**Tank Age**	29	**Tank Installed Date**	10/01/1996	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve
Tag Number	2655	**Spill Test Date**	06/27/2024	**Piping Installed Date**	10/29/2020	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	06/27/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	04/29/2025	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	06/27/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	Yes
		Overfill Test Date	06/27/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350				
Tank Number	05	**Tank Age**	29	**Tank Installed Date**	10/01/1996	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve
Tag Number	2656	**Spill Test Date**	06/27/2024	**Piping Installed Date**	10/29/2020	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	06/27/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	04/29/2025	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	04/29/2025	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	Yes
		Overfill Test Date	06/27/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350				
Tank Number	06	**Tank Age**	23	**Tank Installed Date**	05/01/2002	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve
Tag Number	4649	**Spill Test Date**	06/27/2024	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No

Status	**Currently in Use**	**MLLD Test Date**	04/29/2025	**Sump Tightness Test Date**	06/27/2024	**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel, Dyed	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	04/29/2025	**Line Tightness Test Date**	09/01/2015	**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	06/27/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350				
Tank Number	07	**Tank Age**	23	**Tank Installed Date**	05/01/2002	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve
Tag Number	4650	**Spill Test Date**	11/06/2024	**Piping Installed Date**	10/29/2020	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	04/29/2025	**Sump Tightness Test Date**	06/27/2024	**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	5000	**ATG Test Date**	04/29/2025	**Line Tightness Test Date**	09/01/2015	**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	Yes
		Overfill Test Date	11/06/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Teton County in the City of

Location: MALMSTROM AFB F 8
US Hwy 287 Rural Location
, MT Teton

System Facility ID:50-09037

Facility Code: 28881
Last Inspected On: 04/01/2024
Operating Permit Renewal Date: 09/22/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	341 CES CEANQ	**(406) 731-6188**	
Operator Contact:	Candace Ellsworth;Curtis Hester;William Smith	**(406) 731-6239;(406) 731-7128**	**candace.ellsworth@us.af.mil;william.smith@us.af.mil**

Owner/Operator: 341 CES CEANQ (406) 731-6188

Candace Ellsworth, UST Class A Operator	candace.ellsworth@us.af.mil
Candace Ellsworth, UST Class B Global Operator	candace.ellsworth@us.af.mil
Curtis Hester, UST Class A Operator	
Curtis Hester, UST Class B Global Operator	
William Smith, UST Class A Operator	william.smith@us.af.mil
William Smith, UST Class B Global Operator	william.smith@us.af.mil

Tank Number	02	**Tank Age**	33	**Tank Installed Date**	06/01/1992	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	307	**Spill Test Date**	04/01/2024	**Piping Installed Date**	09/18/2018	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	04/01/2024	**Catastrophic L.D. Type 3.0**	Auto Dialer	**Piping Type**	U.S. Suction	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	04/01/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	04/01/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Teton County in the City of Choteau

Location: BREEN OIL CARD LOCK S
505 S Main St
Choteau, MT 59422 Teton

System Facility ID:56-14147

Facility Code: 30783
Last Inspected On: 06/23/2022
Operating Permit Renewal Date: 10/15/2025

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: K B Leasing

Operator Contact: Jerold Breen;Jesse Jenkins;Liam Breen **(406) 446-2575;(406) 590-8788** **jerry.breen@hotmail.com;jesse.jenkins.mt@gmail.com;liam.breen@ndus.edu**

Owner/Operator: K B Leasing

Jerold Breen, UST Class A Operator	jerry.breen@hotmail.com
Jerold Breen, UST Class B Operator	jerry.breen@hotmail.com
Jesse Jenkins, UST Class A Operator	jesse.jenkins.mt@gmail.com
Liam Breen, UST Class A Operator	liam.breen@ndus.edu
Liam Breen, UST Class B Global Operator	liam.breen@ndus.edu
Liam Breen, UST Class B Operator	liam.breen@ndus.edu

Tank Number	S1	**Tank Age**	20	**Tank Installed Date**	01/14/2005	**Tank Material Construction**	Concrete	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	4950	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	Yes
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**	06/23/2022	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco/EMC Basic				
Tank Number	S2	**Tank Age**	20	**Tank Installed Date**	01/14/2005	**Tank Material Construction**	Concrete	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	4951	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	Yes
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	3000	**ATG Test Date**	06/23/2022	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No

		Overfill Test Date				**ATG Type**	Gilbarco/EMC Basic				
Tank Number	S3	**Tank Age**	20	**Tank Installed Date**	01/14/2005	**Tank Material Construction**	Concrete	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	4952	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	Yes
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Diesel, Dyed	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	3000	**ATG Test Date**	06/23/2022	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco/EMC Basic				
Tank Number	S4	**Tank Age**	20	**Tank Installed Date**	01/14/2005	**Tank Material Construction**	Concrete	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	4953	**Spill Test Date**		**Piping Installed Date**	05/10/2012	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	Yes
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	06/23/2022	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	5000	**ATG Test Date**	06/23/2022	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco/EMC Basic				
Tank Number	S5	**Tank Age**	20	**Tank Installed Date**	01/14/2005	**Tank Material Construction**	Concrete	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	4954	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	Yes
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Diesel, Dyed	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	06/23/2022	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco/EMC Basic				
Tank Number	S6	**Tank Age**	20	**Tank Installed Date**	01/14/2005	**Tank Material Construction**	Concrete	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	4955	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	Yes

Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	3000	**ATG Test Date**	06/23/2022	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco/EMC Basic				

Facility Summary in Teton County in the City of Choteau

Location: DESHS TIRE AND AUTO LLC
401 Main Ave S
Choteau, MT 59422 Teton

System Facility ID:50-07565

Facility Code: 28865
Last Inspected On: 04/19/2024
Operating Permit Renewal Date: 04/29/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Roy and Pandora Deshner	**(406) 466-2066**	**pandora@3rivers.net**
Operator Contact:	Roy Deshner	**(406) 466-2066**	**rdeshner@gmail.com**

Owner/Operator: Roy and Pandora Deshner (406) 466-2066 pandora@3rivers.net

Roy Deshner, UST Class A Operator rdeshner@gmail.com

Roy Deshner, UST Class B Global Operator rdeshner@gmail.com

Tank Number	05	**Tank Age**	33	**Tank Installed Date**	04/01/1992	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	1487	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Temporarily Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco/EMC Basic				
Tank Number	06	**Tank Age**	33	**Tank Installed Date**	04/01/1992	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	1488	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Temporarily Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco/EMC Basic				

Facility Summary in Teton County in the City of Choteau

Location: MAIN STREET EXPRESS LLP
222 Main Ave N
Choteau, MT 59422 Teton

System Facility ID:56-13816

Facility Code: 30503
Last Inspected On: 11/03/2022
Operating Permit Renewal Date: 11/21/2025

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Main Street Express LLP

Operator Contact: Jerold Breen;Liam Breen **(406) 446-2575** **jerry.breen@hotmail.com;liam.breen@ndus.edu**

Owner/Operator: Main Street Express LLP

Jerold Breen, UST Class A Operator	jerry.breen@hotmail.com
Jerold Breen, UST Class B Operator	jerry.breen@hotmail.com
Liam Breen, UST Class A Operator	liam.breen@ndus.edu
Liam Breen, UST Class B Global Operator	liam.breen@ndus.edu
Liam Breen, UST Class B Operator	liam.breen@ndus.edu
Rhonda Brewster, UST Class B Operator	mainstreetexpressexxon@gmail.com

Tank Number	01	**Tank Age**	28	**Tank Installed Date**	10/01/1997	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	488	**Spill Test Date**	11/16/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	5000	**ATG Test Date**	11/01/2022	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	01/12/2023			**ATG Type**	Gilbarco/EMC Basic				
Tank Number	02	**Tank Age**	28	**Tank Installed Date**	10/01/1997	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	489	**Spill Test Date**	11/16/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	11/01/2022	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No

		Overfill Test Date	01/12/2023			**ATG Type**	Gilbarco/EMC Basic				
Tank Number	03	**Tank Age**	28	**Tank Installed Date**	10/01/1997	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	490	**Spill Test Date**	11/16/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	5000	**ATG Test Date**	11/01/2022	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	01/12/2023			**ATG Type**	Gilbarco/EMC Basic				

Facility Summary in Teton County in the City of Choteau

Location: MALMSTROM AFB F 10
US Hwy 89
Choteau, MT 59422 Teton

System Facility ID:50-09039

Facility Code: 28883
Last Inspected On: 04/02/2024
Operating Permit Renewal Date: 09/22/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: 341 CES CEANQ **(406) 731-6188**

Operator Contact: Candace Ellsworth;Curtis Hester;William Smith **(406) 731-6239;(406) 731-7128** **candace.ellsworth@us.af.mil;william.smith@us.af.mil**

Owner/Operator: 341 CES CEANQ (406) 731-6188

Candace Ellsworth, UST Class A Operator	candace.ellsworth@us.af.mil
Candace Ellsworth, UST Class B Global Operator	candace.ellsworth@us.af.mil
Curtis Hester, UST Class A Operator	
Curtis Hester, UST Class B Global Operator	
William Smith, UST Class A Operator	william.smith@us.af.mil
William Smith, UST Class B Global Operator	william.smith@us.af.mil

Tank Number	02	**Tank Age**	33	**Tank Installed Date**	06/01/1992	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	309	**Spill Test Date**	04/02/2024	**Piping Installed Date**	06/19/2015	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	04/02/2024	**Catastrophic L.D. Type 3.0**	Auto Dialer	**Piping Type**	U.S. Suction	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	04/02/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	04/02/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Teton County in the City of Choteau

Location: MALMSTROM AFB F 11
US Hwy 89
Choteau, MT 59422 Teton

System Facility ID:50-09040

Facility Code: 28884
Last Inspected On: 04/02/2024
Operating Permit Renewal Date: 09/22/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: 341 CES CEANQ **(406) 731-6188**

Operator Contact: Candace Ellsworth;William Smith **(406) 731-6239;(406) 731-7128** **candace.ellsworth@us.af.mil;william.smith@us.af.mil**

Owner/Operator: 341 CES CEANQ (406) 731-6188

Candace Ellsworth, UST Class A Operator	candace.ellsworth@us.af.mil
Candace Ellsworth, UST Class B Global Operator	candace.ellsworth@us.af.mil
William Smith, UST Class A Operator	william.smith@us.af.mil
William Smith, UST Class B Global Operator	william.smith@us.af.mil

Tank Number	02	**Tank Age**	33	**Tank Installed Date**	06/01/1992	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	310	**Spill Test Date**	04/02/2024	**Piping Installed Date**	06/19/2015	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	04/02/2024	**Catastrophic L.D. Type 3.0**	Auto Dialer	**Piping Type**	U.S. Suction	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	04/02/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	04/02/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Teton County in the City of Choteau

Location: MALMSTROM AFB F 2
US Hwy 89
Choteau, MT 59422 Teton

System Facility ID:50-09031

Facility Code: 28878
Last Inspected On: 04/02/2024
Operating Permit Renewal Date: 09/22/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: 341 CES CEANQ **(406) 731-6188**

Operator Contact: Candace Ellsworth;Curtis Hester;William Smith **(406) 731-6239;(406) 731-7128** **candace.ellsworth@us.af.mil;william.smith@us.af.mil**

Owner/Operator: 341 CES CEANQ (406) 731-6188

Candace Ellsworth, UST Class A Operator	candace.ellsworth@us.af.mil
Candace Ellsworth, UST Class B Global Operator	candace.ellsworth@us.af.mil
Curtis Hester, UST Class A Operator	
Curtis Hester, UST Class B Global Operator	
William Smith, UST Class A Operator	william.smith@us.af.mil
William Smith, UST Class B Global Operator	william.smith@us.af.mil

Tank Number	02	**Tank Age**	33	**Tank Installed Date**	06/01/1992	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	304	**Spill Test Date**	04/02/2024	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	04/02/2024	**Catastrophic L.D. Type 3.0**	Auto Dialer	**Piping Type**	U.S. Suction	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	04/02/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	04/02/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Teton County in the City of Choteau

Location: MALMSTROM AFB F 3
US Hwy 287
Choteau, MT 59422 Teton

System Facility ID:50-09032

Facility Code: 28879
Last Inspected On: 04/01/2024
Operating Permit Renewal Date: 09/22/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: 341 CES CEANQ **(406) 731-6188**

Operator Contact: Candace Ellsworth;Curtis Hester;William Smith **(406) 731-6239;(406) 731-7128** **candace.ellsworth@us.af.mil;william.smith@us.af.mil**

Owner/Operator: 341 CES CEANQ (406) 731-6188

Candace Ellsworth, UST Class A Operator	candace.ellsworth@us.af.mil
Candace Ellsworth, UST Class B Global Operator	candace.ellsworth@us.af.mil
Curtis Hester, UST Class A Operator	
Curtis Hester, UST Class B Global Operator	
William Smith, UST Class A Operator	william.smith@us.af.mil
William Smith, UST Class B Global Operator	william.smith@us.af.mil

Tank Number	02	**Tank Age**	33	**Tank Installed Date**	06/01/1992	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	305	**Spill Test Date**	04/01/2024	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	04/01/2024	**Catastrophic L.D. Type 3.0**	Auto Dialer	**Piping Type**	U.S. Suction	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	04/01/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	04/01/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Teton County in the City of Choteau

Location: MALMSTROM AFB F 9
US Hwy 89
Choteau, MT 59422 Teton

System Facility ID:50-09038

Facility Code: 28882
Last Inspected On: 04/02/2024
Operating Permit Renewal Date: 09/22/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: 341 CES CEANQ **(406) 731-6188**

Operator Contact: Candace Ellsworth;Curtis Hester;William Smith **(406) 731-6239;(406) 731-7128** **candace.ellsworth@us.af.mil;william.smith@us.af.mil**

Owner/Operator: 341 CES CEANQ (406) 731-6188

Candace Ellsworth, UST Class A Operator	candace.ellsworth@us.af.mil
Candace Ellsworth, UST Class B Global Operator	candace.ellsworth@us.af.mil
Curtis Hester, UST Class A Operator	
Curtis Hester, UST Class B Global Operator	
William Smith, UST Class A Operator	william.smith@us.af.mil
William Smith, UST Class B Global Operator	william.smith@us.af.mil

Tank Number	02	**Tank Age**	33	**Tank Installed Date**	06/01/1992	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	308	**Spill Test Date**	04/02/2024	**Piping Installed Date**	09/11/2018	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	04/02/2024	**Catastrophic L.D. Type 3.0**	Auto Dialer	**Piping Type**	U.S. Suction	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	04/02/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	04/02/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Teton County in the City of Choteau

Location: MALMSTROM AFB H 10
US Hwy 89
Choteau, MT 59422 Teton

System Facility ID:50-09061

Facility Code: 28889
Last Inspected On: 04/03/2024
Operating Permit Renewal Date: 09/22/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: 341 CES CEANQ **(406) 731-6188**

Operator Contact: Candace Ellsworth;Curtis Hester;William Smith **(406) 731-6239;(406) 731-7128** **candace.ellsworth@us.af.mil;william.smith@us.af.mil**

Owner/Operator: 341 CES CEANQ (406) 731-6188

Candace Ellsworth, UST Class A Operator	candace.ellsworth@us.af.mil
Candace Ellsworth, UST Class B Global Operator	candace.ellsworth@us.af.mil
Curtis Hester, UST Class A Operator	
Curtis Hester, UST Class B Global Operator	
William Smith, UST Class A Operator	william.smith@us.af.mil
William Smith, UST Class B Global Operator	william.smith@us.af.mil

Tank Number	02	**Tank Age**	34	**Tank Installed Date**	09/01/1991	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	315	**Spill Test Date**	04/03/2024	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	04/03/2024	**Catastrophic L.D. Type 3.0**	Auto Dialer	**Piping Type**	U.S. Suction	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	04/03/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	04/03/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Teton County in the City of Choteau

Location: MALMSTROM AFB H 11
Road 221
Choteau, MT 59422 Teton

System Facility ID:50-09062

Facility Code: 28890
Last Inspected On: 04/03/2024
Operating Permit Renewal Date: 09/22/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: 341 CES CEANQ **(406) 731-6188**

Operator Contact: Candace Ellsworth;Curtis Hester;William Smith **(406) 731-6239;(406) 731-7128** **candace.ellsworth@us.af.mil;william.smith@us.af.mil**

Owner/Operator: 341 CES CEANQ (406) 731-6188

Candace Ellsworth, UST Class A Operator	candace.ellsworth@us.af.mil
Candace Ellsworth, UST Class B Global Operator	candace.ellsworth@us.af.mil
Curtis Hester, UST Class A Operator	
Curtis Hester, UST Class B Global Operator	
William Smith, UST Class A Operator	william.smith@us.af.mil
William Smith, UST Class B Global Operator	william.smith@us.af.mil

Tank Number	02	**Tank Age**	34	**Tank Installed Date**	09/01/1991	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	316	**Spill Test Date**	04/03/2024	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	04/03/2024	**Catastrophic L.D. Type 3.0**	Auto Dialer	**Piping Type**	U.S. Suction	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	04/03/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	04/03/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Teton County in the City of Choteau

Location: MOUNTAIN VIEW CO-OP 158
215 Main Ave S
Choteau, MT 59422 Teton

System Facility ID:50-03593

Facility Code: 28795
Last Inspected On: 09/26/2022
Operating Permit Renewal Date: 10/19/2025

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Mountain View Coop

Operator Contact: Timothy Kelly **(406) 466-2583** **skelly@3rivers.net**

Owner/Operator: Mountain View Coop

Timothy Kelly, UST Class A Operator	skelly@3rivers.net
Timothy Kelly, UST Class A Operator	skelly@3rivers.net
Timothy Kelly, UST Class B Operator	skelly@3rivers.net
Timothy Kelly, UST Class B Operator	skelly@3rivers.net

Tank Number	S6	**Tank Age**	29	**Tank Installed Date**	05/15/1996	**Tank Material Construction**	Bare Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	
Tag Number	1469	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	Yes
Status	**Currently in Use**	**MLLD Test Date**	05/24/2022	**Sump Tightness Test Date**	10/16/2013	**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	02/23/2023	**Line Tightness Test Date**	05/26/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	S7	**Tank Age**	29	**Tank Installed Date**	08/15/1996	**Tank Material Construction**	Bare Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	
Tag Number	1470	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	Yes
Status	**Currently in Use**	**MLLD Test Date**	05/24/2022	**Sump Tightness Test Date**	10/16/2013	**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	02/23/2023	**Line Tightness Test Date**	05/26/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date				**ATG Type**					

Tank Number	S8	**Tank Age**	22	**Tank Installed Date**	11/26/2003	**Tank Material Construction**	Concrete	**Piping Material**	Flexible Plastic	**Overfill Types**	
Tag Number	4929	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	Yes
Status	**Currently in Use**	**MLLD Test Date**	05/24/2022	**Sump Tightness Test Date**	10/16/2013	**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Diesel, Dyed	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	02/23/2023	**Line Tightness Test Date**	05/26/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	S9	**Tank Age**	22	**Tank Installed Date**	11/26/2003	**Tank Material Construction**	Concrete	**Piping Material**	Flexible Plastic	**Overfill Types**	
Tag Number	4930	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	Yes
Status	**Currently in Use**	**MLLD Test Date**	05/24/2022	**Sump Tightness Test Date**	10/16/2013	**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	02/23/2023	**Line Tightness Test Date**	05/26/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date				**ATG Type**					

Facility Summary in Teton County in the City of Dutton

Location: DUTTON SCHOOL DIST 28
101 2nd St NE
Dutton, MT 59433-9670 Teton

System Facility ID:50-03600

Facility Code: 28797
Last Inspected On: 08/15/2023
Operating Permit Renewal Date: 08/27/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: School Dist 28C Dutton Brady

Operator Contact: Jeremy Locke;School Dist 28C Dutton Brady **jlocke@dbps.us**

Owner/Operator: School Dist 28C Dutton Brady

Jeremy Locke, UST Class A Operator jlocke@dbps.us

Jeremy Locke, UST Class B Operator jlocke@dbps.us

Tank Number	S2	**Tank Age**	36	**Tank Installed Date**	08/21/1989	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	842	**Spill Test Date**	08/15/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Single Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Auto Dialer	**Piping Type**	U.S. Suction	**CP Met Types**	Non-corrodible
Product	Heating Oil	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	3-Year Line Tightness Test	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	08/15/2023	**Line Tightness Test Date**	09/29/2020	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	11/15/2023			**ATG Type**	EMCO Electronics/EECO 1500				

Facility Summary in Teton County in the City of Dutton

Location: MALMSTROM AFB H 2
Road 221
Dutton, MT 59433 Teton

System Facility ID:50-09053

Facility Code: 28886
Last Inspected On: 04/03/2024
Operating Permit Renewal Date: 09/22/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: 341 CES CEANQ **(406) 731-6188**

Operator Contact: Candace Ellsworth;Curtis Hester;William Smith **(406) 731-6239;(406) 731-7128** **candace.ellsworth@us.af.mil;william.smith@us.af.mil**

Owner/Operator: 341 CES CEANQ (406) 731-6188

Candace Ellsworth, UST Class A Operator	candace.ellsworth@us.af.mil
Candace Ellsworth, UST Class B Global Operator	candace.ellsworth@us.af.mil
Curtis Hester, UST Class A Operator	
Curtis Hester, UST Class B Global Operator	
William Smith, UST Class A Operator	william.smith@us.af.mil
William Smith, UST Class B Global Operator	william.smith@us.af.mil

Tank Number	02	**Tank Age**	36	**Tank Installed Date**	05/21/1989	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	312	**Spill Test Date**	04/03/2024	**Piping Installed Date**	06/30/2016	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	04/03/2024	**Catastrophic L.D. Type 3.0**	Auto Dialer	**Piping Type**	U.S. Suction	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	04/03/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	04/03/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Teton County in the City of Dutton

Location: MALMSTROM AFB J 1
I-15
Dutton, MT 59433 Teton

System Facility ID:50-09074

Facility Code: 28891
Last Inspected On: 05/16/2024
Operating Permit Renewal Date: 09/22/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: 341 CES CEANQ **(406) 731-6188**

Operator Contact: Candace Ellsworth;Curtis Hester;William Smith **(406) 731-6239;(406) 731-7128** **candace.ellsworth@us.af.mil;william.smith@us.af.mil**

Owner/Operator: 341 CES CEANQ (406) 731-6188

Candace Ellsworth, UST Class A Operator	candace.ellsworth@us.af.mil
Candace Ellsworth, UST Class B Global Operator	candace.ellsworth@us.af.mil
Curtis Hester, UST Class A Operator	
Curtis Hester, UST Class B Global Operator	
William Smith, UST Class A Operator	william.smith@us.af.mil
William Smith, UST Class B Global Operator	william.smith@us.af.mil

Tank Number	01	**Tank Age**	63	**Tank Installed Date**	06/02/1962	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	317	**Spill Test Date**	05/16/2024	**Piping Installed Date**		**Tank Construction**	Lined Interior/Impressed Current	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	05/16/2024	**Catastrophic L.D. Type 3.0**	Auto Dialer	**Piping Type**	U.S. Suction	**CP Met Types**	Impressed Current
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	08/27/2022	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	11/07/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	11/07/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				

Facility Summary in Teton County in the City of Dutton

Location: MALMSTROM AFB J 11
I-15
Dutton, MT 59433 Teton

System Facility ID:50-09084

Facility Code: 28894
Last Inspected On: 04/16/2024
Operating Permit Renewal Date: 09/22/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: 341 CES CEANQ **(406) 731-6188**

Operator Contact: Candace Ellsworth;Curtis Hester;William Smith **(406) 731-6239;(406) 731-7128** **candace.ellsworth@us.af.mil;william.smith@us.af.mil**

Owner/Operator: 341 CES CEANQ (406) 731-6188

Candace Ellsworth, UST Class A Operator	candace.ellsworth@us.af.mil
Candace Ellsworth, UST Class B Global Operator	candace.ellsworth@us.af.mil
Curtis Hester, UST Class A Operator	
Curtis Hester, UST Class B Global Operator	
William Smith, UST Class A Operator	william.smith@us.af.mil
William Smith, UST Class B Global Operator	william.smith@us.af.mil

Tank Number	02	**Tank Age**	34	**Tank Installed Date**	08/01/1991	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	320	**Spill Test Date**	04/16/2024	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	04/16/2024	**Catastrophic L.D. Type 3.0**	Auto Dialer	**Piping Type**	U.S. Suction	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	04/16/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	04/16/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Teton County in the City of Dutton

Location: MALMSTROM AFB J 2
Road 379
Dutton, MT 59433 Teton

System Facility ID:50-09075

Facility Code: 28892
Last Inspected On: 04/16/2024
Operating Permit Renewal Date: 05/25/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: 341 CES CEANQ **(406) 731-6188**

Operator Contact: Candace Ellsworth;Curtis Hester;William Smith **(406) 731-6239;(406) 731-7128** **candace.ellsworth@us.af.mil;william.smith@us.af.mil**

Owner/Operator: 341 CES CEANQ (406) 731-6188

Candace Ellsworth, UST Class A Operator	candace.ellsworth@us.af.mil
Candace Ellsworth, UST Class B Global Operator	candace.ellsworth@us.af.mil
Curtis Hester, UST Class A Operator	
Curtis Hester, UST Class B Global Operator	
William Smith, UST Class A Operator	william.smith@us.af.mil
William Smith, UST Class B Global Operator	william.smith@us.af.mil

Tank Number	02	**Tank Age**	34	**Tank Installed Date**	08/01/1991	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	318	**Spill Test Date**	04/16/2024	**Piping Installed Date**	01/04/2016	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	04/16/2024	**Catastrophic L.D. Type 3.0**	Auto Dialer	**Piping Type**	U.S. Suction	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	04/16/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	04/16/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Teton County in the City of Dutton

Location: MOUNTAIN VIEW CO OP
210 N Grain Ave
Dutton, MT 59433 Teton

System Facility ID:60-15071

Facility Code: 30842
Last Inspected On: 04/21/2023
Operating Permit Renewal Date: 05/07/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Mountain View Coop Black Eagle	**(406) 453-5900**	**ddouglas@mountainviewcoop.com**
Operator Contact:	Pat Trainor;William (Ralph) Floyd	**(406) 401-6025;(800) 823-3276**	**rfloyd@mvc.ag**

Owner/Operator: Mountain View Coop Black Eagle (406) 453-5900 ddouglas@mountainviewcoop.com

Pat Trainor, UST Class A Operator
Pat Trainor, UST Class B Global Operator
William (Ralph) Floyd, UST Class A Operator rfloyd@mvc.ag
William (Ralph) Floyd, UST Class B Operator rfloyd@mvc.ag

Tank Number	01	**Tank Age**	18	**Tank Installed Date**	11/07/2007	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	5111	**Spill Test Date**	05/29/2019	**Piping Installed Date**	01/24/2006	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	10/16/2019	**Catastrophic L.D. Type 3.0**	Continuous Interstitial Monitoring;Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	06/19/2020	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	20000	**ATG Test Date**		**Line Tightness Test Date**	06/19/2020	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	Yes
		Overfill Test Date	03/10/2020			**ATG Type**	Veeder Root/TLS-350				
Tank Number	02	**Tank Age**	18	**Tank Installed Date**	11/07/2007	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	5112	**Spill Test Date**	05/29/2019	**Piping Installed Date**	01/24/2006	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	10/16/2019	**Catastrophic L.D. Type 3.0**	Continuous Interstitial Monitoring;Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible

Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	20000	**ATG Test Date**		**Line Tightness Test Date**	06/19/2020	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	Yes
		Overfill Test Date	03/10/2020			**ATG Type**	Veeder Root/TLS-350				
Tank Number	03	**Tank Age**	18	**Tank Installed Date**	11/07/2007	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	5113	**Spill Test Date**	05/29/2019	**Piping Installed Date**	01/24/2006	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	10/16/2019	**Catastrophic L.D. Type 3.0**	Continuous Interstitial Monitoring;Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	20000	**ATG Test Date**		**Line Tightness Test Date**	06/19/2020	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	Yes
		Overfill Test Date	03/10/2020			**ATG Type**	Veeder Root/TLS-350				
Tank Number	04	**Tank Age**	18	**Tank Installed Date**	11/07/2007	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	5114	**Spill Test Date**	05/29/2019	**Piping Installed Date**	01/24/2006	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	10/16/2019	**Catastrophic L.D. Type 3.0**	Continuous Interstitial Monitoring;Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	30000	**ATG Test Date**		**Line Tightness Test Date**	06/19/2020	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	Yes
		Overfill Test Date	03/10/2020			**ATG Type**	Veeder Root/TLS-350				
Tank Number	05	**Tank Age**	18	**Tank Installed Date**	11/07/2007	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	5115	**Spill Test Date**	05/29/2019	**Piping Installed Date**	01/24/2006	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	10/16/2019	**Catastrophic L.D. Type 3.0**	Continuous Interstitial Monitoring;Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible

Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	30000	**ATG Test Date**		**Line Tightness Test Date**	06/19/2020	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	Yes
		Overfill Test Date	03/10/2020			**ATG Type**	Veeder Root/TLS-350				
Tank Number	06	**Tank Age**	18	**Tank Installed Date**	11/07/2007	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	5116	**Spill Test Date**	05/29/2019	**Piping Installed Date**	01/24/2006	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	10/16/2019	**Catastrophic L.D. Type 3.0**	Continuous Interstitial Monitoring;Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	30000	**ATG Test Date**		**Line Tightness Test Date**	06/19/2020	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	Yes
		Overfill Test Date	03/10/2020			**ATG Type**	Veeder Root/TLS-350				
Tank Number	07	**Tank Age**	18	**Tank Installed Date**	11/07/2007	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	5117	**Spill Test Date**	05/29/2019	**Piping Installed Date**	01/24/2006	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	10/16/2019	**Catastrophic L.D. Type 3.0**	Continuous Interstitial Monitoring;Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	40000	**ATG Test Date**		**Line Tightness Test Date**	06/19/2020	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	Yes
		Overfill Test Date	03/10/2020			**ATG Type**	Veeder Root/TLS-350				
Tank Number	08	**Tank Age**	18	**Tank Installed Date**	11/07/2007	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	5118	**Spill Test Date**	05/29/2019	**Piping Installed Date**	01/24/2006	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No

Status	**Currently in Use**	**MLLD Test Date**	06/19/2020	**Sump Tightness Test Date**	10/16/2019	**Catastrophic L.D. Type 3.0**	Continuous Interstitial Monitoring;Electronic Line Leak Detector;Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	40000	**ATG Test Date**		**Line Tightness Test Date**	06/19/2020	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	Yes
		Overfill Test Date	03/10/2020			**ATG Type**	Veeder Root/TLS-350				
Tank Number	09	**Tank Age**	18	**Tank Installed Date**	11/07/2007	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	5119	**Spill Test Date**	05/29/2019	**Piping Installed Date**	01/24/2006	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	10/16/2019	**Catastrophic L.D. Type 3.0**	Continuous Interstitial Monitoring;Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	40000	**ATG Test Date**		**Line Tightness Test Date**	06/19/2020	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	Yes
		Overfill Test Date	03/10/2020			**ATG Type**	Veeder Root/TLS-350				
Tank Number	10	**Tank Age**	18	**Tank Installed Date**	11/07/2007	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	5120	**Spill Test Date**	05/29/2019	**Piping Installed Date**	01/24/2006	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	10/16/2019	**Catastrophic L.D. Type 3.0**	Continuous Interstitial Monitoring;Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	40000	**ATG Test Date**		**Line Tightness Test Date**	06/19/2020	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	Yes
		Overfill Test Date	03/10/2020			**ATG Type**	Veeder Root/TLS-350				
Tank Number	11	**Tank Age**	18	**Tank Installed Date**	11/07/2007	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm

Tag Number	5121	**Spill Test Date**	05/29/2019	**Piping Installed Date**	01/24/2006	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	06/19/2020	**Sump Tightness Test Date**	10/16/2019	**Catastrophic L.D. Type 3.0**	Continuous Interstitial Monitoring;Electronic Line Leak Detector;Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	40000	**ATG Test Date**		**Line Tightness Test Date**	06/19/2020	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	Yes
		Overfill Test Date	03/10/2020			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Teton County in the City of Dutton

Location: MOUNTAIN VIEW COOP DUTTON
110 Main St W
Dutton, MT 59433-9686 Teton

System Facility ID:50-03701

Facility Code: 28798
Last Inspected On: 08/17/2022
Operating Permit Renewal Date: 09/05/2025

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Mountain View Coop Black Eagle **(406) 453-5900** **ddouglas@mountainviewcoop.com**

Operator Contact: David Douglas **ddouglas@mountainviewcoop.com**

Owner/Operator: Mountain View Coop Black Eagle (406) 453-5900 ddouglas@mountainviewcoop.com

David Douglas, UST Class A Operator ddouglas@mountainviewcoop.com
David Douglas, UST Class B Global Operator ddouglas@mountainviewcoop.com
Thomas DeMars, UST Class B Operator tdemars@mountainviewcoop.com
Thomas DeMars, UST Class B Operator tdemars@mountainviewcoop.com

Tank Number	07	**Tank Age**	26	**Tank Installed Date**	08/01/1999	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	4108	**Spill Test Date**	08/16/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	03/28/2022	**Sump Tightness Test Date**	08/04/2022	**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	07/12/2016	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	07/12/2022	**Line Tightness Test Date**	03/28/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	08/16/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	04	**Tank Age**	35	**Tank Installed Date**	04/16/1990	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	4688	**Spill Test Date**	08/16/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	03/28/2022	**Sump Tightness Test Date**	08/04/2022	**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	11/14/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	2000	**ATG Test Date**	07/12/2022	**Line Tightness Test Date**	03/28/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No

		Overfill Test Date	08/16/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	05	**Tank Age**	35	**Tank Installed Date**	04/16/1990	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	4689	**Spill Test Date**	08/16/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	03/28/2022	**Sump Tightness Test Date**	08/04/2022	**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	11/14/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	2000	**ATG Test Date**	07/12/2022	**Line Tightness Test Date**	03/28/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	08/16/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	06	**Tank Age**	35	**Tank Installed Date**	04/16/1990	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	4690	**Spill Test Date**	08/16/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	03/28/2022	**Sump Tightness Test Date**	08/04/2022	**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	11/14/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	2000	**ATG Test Date**	07/12/2022	**Line Tightness Test Date**	03/28/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	08/16/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Teton County in the City of Fairfield

Location: GREENFIELDS IRRIGATION DISTRICT UST
105 Central Ave W
Fairfield, MT 59436 Teton

System Facility ID:50-07428

Facility Code: 28858
Last Inspected On: 03/14/2023
Operating Permit Renewal Date: 08/05/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Greenfields Irrigation District **(406) 467-2533**

Operator Contact: Eric Mayer **(406) 590-3254** **eric@gid-mt.com**

Owner/Operator: Greenfields Irrigation District (406) 467-2533

Eric Mayer, UST Class A Operator eric@gid-mt.com

Eric Mayer, UST Class B Operator eric@gid-mt.com

Tank Number	03	**Tank Age**	33	**Tank Installed Date**	10/01/1992	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	1241	**Spill Test Date**	03/01/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	03/01/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	03/01/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-300				
Tank Number	04	**Tank Age**	33	**Tank Installed Date**	10/01/1992	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	1242	**Spill Test Date**	03/01/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Single Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	03/01/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	03/01/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-300				

Facility Summary in Teton County in the City of Fairfield

Location: MALMSTROM AFB F 4
Road 408
Fairfield, MT 59436 Teton

System Facility ID:50-09033

Facility Code: 28880
Last Inspected On: 04/02/2024
Operating Permit Renewal Date: 09/22/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	341 CES CEANQ	**(406) 731-6188**	
Operator Contact:	Candace Ellsworth;Curtis Hester;William Smith	**(406) 731-6239;(406) 731-7128**	**candace.ellsworth@us.af.mil;william.smith@us.af.mil**

Owner/Operator: 341 CES CEANQ (406) 731-6188

Candace Ellsworth, UST Class A Operator	candace.ellsworth@us.af.mil
Candace Ellsworth, UST Class B Global Operator	candace.ellsworth@us.af.mil
Curtis Hester, UST Class A Operator	
William Smith, UST Class A Operator	william.smith@us.af.mil
William Smith, UST Class B Global Operator	william.smith@us.af.mil

Tank Number	02	**Tank Age**	33	**Tank Installed Date**	07/01/1992	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	306	**Spill Test Date**	04/02/2024	**Piping Installed Date**	11/16/2016	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	04/02/2024	**Catastrophic L.D. Type 3.0**	Auto Dialer	**Piping Type**	U.S. Suction	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	04/02/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	04/02/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Teton County in the City of Fairfield

Location: MALMSTROM AFB H 1
US Hwy 89
Fairfield, MT 59436 Teton

System Facility ID:50-09052

Facility Code: 28885
Last Inspected On: 05/16/2024
Operating Permit Renewal Date: 09/22/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	341 CES CEANQ	**(406) 731-6188**	
Operator Contact:	Candace Ellsworth;Curtis Hester;William Smith	**(406) 731-6239;(406) 731-7128**	**candace.ellsworth@us.af.mil;william.smith@us.af.mil**

Owner/Operator: 341 CES CEANQ (406) 731-6188

Candace Ellsworth, UST Class A Operator	candace.ellsworth@us.af.mil
Candace Ellsworth, UST Class B Global Operator	candace.ellsworth@us.af.mil
Curtis Hester, UST Class A Operator	
Curtis Hester, UST Class B Global Operator	
William Smith, UST Class A Operator	william.smith@us.af.mil
William Smith, UST Class B Global Operator	william.smith@us.af.mil

Tank Number	07	**Tank Age**	19	**Tank Installed Date**	09/28/2006	**Tank Material Construction**	Steel Clad	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	5086	**Spill Test Date**	05/16/2024	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	05/16/2024	**Catastrophic L.D. Type 3.0**	Auto Dialer	**Piping Type**	U.S. Suction	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	07/31/2013	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	11/05/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	11/05/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				

Facility Summary in Teton County in the City of Fairfield

Location: MALMSTROM AFB H 9
Road 408
Fairfield, MT 59436 Teton

System Facility ID:50-09060

Facility Code: 28888
Last Inspected On: 04/04/2024
Operating Permit Renewal Date: 09/30/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	341 CES CEANQ	**(406) 731-6188**	
Operator Contact:	Candace Ellsworth;Curtis Hester;William Smith	**(406) 731-6239;(406) 731-7128**	**candace.ellsworth@us.af.mil;william.smith@us.af.mil**

Owner/Operator: 341 CES CEANQ (406) 731-6188

Candace Ellsworth, UST Class A Operator	candace.ellsworth@us.af.mil
Candace Ellsworth, UST Class B Global Operator	candace.ellsworth@us.af.mil
Curtis Hester, UST Class A Operator	
Curtis Hester, UST Class B Global Operator	
William Smith, UST Class A Operator	william.smith@us.af.mil
William Smith, UST Class B Global Operator	william.smith@us.af.mil

Tank Number	02	**Tank Age**	34	**Tank Installed Date**	09/01/1991	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	314	**Spill Test Date**	04/04/2024	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	04/04/2024	**Catastrophic L.D. Type 3.0**	Auto Dialer	**Piping Type**	U.S. Suction	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	04/04/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	04/04/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Teton County in the City of Fairfield

Location: MOUNTAIN VIEW COOP FAIRFIELD
219 Central Ave
Fairfield, MT 59436 Teton

System Facility ID:50-03596

Facility Code: 28796
Last Inspected On: 07/26/2022
Operating Permit Renewal Date: 09/27/2025

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Mountain View Coop Black Eagle **(406) 453-5900** **ddouglas@mountainviewcoop.com**

Operator Contact: Dave Douglas **(406) 750-6748** **ddouglas@mountainviewcoop.com**

Owner/Operator: Mountain View Coop Black Eagle (406) 453-5900 ddouglas@mountainviewcoop.com

Dave Douglas, UST Class A Operator ddouglas@mountainviewcoop.com

Nathan Pitcher, UST Class B Global Operator npitcher@mountainviewcoop.com

Tank Number	10	**Tank Age**	33	**Tank Installed Date**	12/01/1992	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	1235	**Spill Test Date**	07/12/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	04/05/2022	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**	07/12/2022	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/TLS-350				
Tank Number	11	**Tank Age**	33	**Tank Installed Date**	12/01/1992	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	1236	**Spill Test Date**	07/12/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	04/05/2022	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	07/12/2022	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	12	**Tank Age**	33	**Tank Installed Date**	12/01/1992	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm

Tag Number	1237	**Spill Test Date**	07/12/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	04/05/2022	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	07/12/2022	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/TLS-350				
Tank Number	13	**Tank Age**	27	**Tank Installed Date**	08/01/1998	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	1238	**Spill Test Date**	07/12/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	04/05/2022	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**	07/12/2022	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/TLS-350				
Tank Number	14	**Tank Age**	27	**Tank Installed Date**	08/01/1998	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	1239	**Spill Test Date**	07/12/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	04/05/2022	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	07/12/2022	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/TLS-350				
Tank Number	15	**Tank Age**	27	**Tank Installed Date**	08/01/1998	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	1240	**Spill Test Date**	07/12/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	04/05/2022	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	07/12/2022	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Teton County in the City of Fairfield

Location: MOUNTAIN VIEW COOP THE STORE
305 Central Ave
Fairfield, MT 59436 Teton

System Facility ID:50-11700

Facility Code: 28945
Last Inspected On: 09/13/2023
Operating Permit Renewal Date: 09/19/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Mountain View Coop Black Eagle	**(406) 453-5900**	**ddouglas@mountainviewcoop.com**
Operator Contact:	Charla Merja;David Douglas;Denna Lekan	**(406) 590-1235**	**ddouglas@mountainviewcoop.com;dennalekan@yahoo.com**

Owner/Operator: Mountain View Coop Black Eagle (406) 453-5900 ddouglas@mountainviewcoop.com

Charla Merja, UST Class A Operator	
Charla Merja, UST Class B Operator	
David Douglas, UST Class A Operator	ddouglas@mountainviewcoop.com
David Douglas, UST Class B Global Operator	ddouglas@mountainviewcoop.com
Denna Lekan, UST Class A Operator	dennalekan@yahoo.com
Denna Lekan, UST Class B Operator	dennalekan@yahoo.com
Nathan Pitcher, UST Class B Global Operator	npitcher@mountainviewcoop.com

Tank Number	01	**Tank Age**	35	**Tank Installed Date**	07/01/1990	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	2354	**Spill Test Date**	10/17/2023	**Piping Installed Date**	10/12/2023	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	10/12/2023	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	20000	**ATG Test Date**	01/30/2024	**Line Tightness Test Date**	03/05/2024	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	01/30/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	02	**Tank Age**	35	**Tank Installed Date**	07/01/1990	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	2355	**Spill Test Date**	10/17/2023	**Piping Installed Date**	10/12/2023	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	10/12/2023	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No

Capacity	20000	**ATG Test Date**	01/30/2024	**Line Tightness Test Date**	03/05/2024	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	01/30/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	03	**Tank Age**	35	**Tank Installed Date**	07/01/1990	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	2356	**Spill Test Date**	10/17/2023	**Piping Installed Date**	10/12/2023	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	10/12/2023	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	20000	**ATG Test Date**	01/30/2024	**Line Tightness Test Date**	03/05/2024	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	01/30/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Toole County in the City of Galata

Location: FRASER OIL INC GALATA
30342 US Hwy 2 & Galata Rd
Galata, MT 59444 Toole

System Facility ID:51-02311

Facility Code: 29035
Last Inspected On: 11/16/2023
Operating Permit Renewal Date: 03/17/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Fraser Oil Inc

Operator Contact: Cory Fraser **frasfuel@yahoo.com**

Owner/Operator: Fraser Oil Inc

Cory Fraser, UST Class A Operator frasfuel@yahoo.com
Cory Fraser, UST Class B Operator frasfuel@yahoo.com

Tank Number	03	**Tank Age**	33	**Tank Installed Date**	10/01/1992	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	1126	**Spill Test Date**	11/16/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	11/03/2020	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	1000	**ATG Test Date**	11/16/2023	**Line Tightness Test Date**	12/11/2008	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	11/16/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	04	**Tank Age**	33	**Tank Installed Date**	10/01/1992	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	1127	**Spill Test Date**	11/16/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	04/29/2021	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	1000	**ATG Test Date**	11/16/2023	**Line Tightness Test Date**	12/11/2008	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	11/16/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Toole County in the City of Shelby

Location: BTI CONOCO
Hwy 2
Shelby, MT 59474 Toole

System Facility ID:51-08629

Facility Code: 29119
Last Inspected On: 07/28/2023
Operating Permit Renewal Date: 11/27/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Ben Taylor Inc;Pat Simons;Simons Petroleum Inc;Unclaimed **(406) 434-2431** **bti@3rivers.net;simonspt@3rivers.net**

Operator Contact: David Emerson;City Service Valcon LLC **david.emerson@cityservicevalcon.com;tamara.noble@cityservicevalcon.com**

Owner/Operator: Ben Taylor Inc bti@3rivers.net

David Emerson, UST Class A Operator tamara.noble@cityservicevalcon.com

David Emerson, UST Class B Operator tamara.noble@cityservicevalcon.com

Tank Number	09	**Tank Age**	20	**Tank Installed Date**	05/27/2005	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve
Tag Number	5012	**Spill Test Date**	01/25/2024	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**	07/27/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	07/27/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	08	**Tank Age**	20	**Tank Installed Date**	05/27/2005	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve
Tag Number	5013	**Spill Test Date**	01/25/2024	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	5000	**ATG Test Date**	07/27/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	07/27/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Tank Number	07	**Tank Age**	20	**Tank Installed Date**	05/27/2005	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve
Tag Number	5014	**Spill Test Date**	01/25/2024	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**	07/27/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	07/27/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	10	**Tank Age**	20	**Tank Installed Date**	05/27/2005	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve
Tag Number	5015	**Spill Test Date**	01/25/2024	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	5000	**ATG Test Date**	07/27/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	07/27/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Toole County in the City of Shelby

Location: H AND R INC 6
101 E Main St
Shelby, MT 59474-2127 Toole

System Facility ID:51-06113

Facility Code: 29092
Last Inspected On: 11/15/2023
Operating Permit Renewal Date: 01/08/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Singh Inc	**(406) 868-2062**	**inder4030@yahoo.com**
Operator Contact:	Harinder Singh;Singh Inc	**(406) 868-2062;(406) 868-2062**	**inder4030@yahoo.com;inder4030@yahoo.com**

Owner/Operator: Singh Inc (406) 868-2062 inder4030@yahoo.com

Frank Kruse, UST Class B Operator wfkruse79@yahoo.com
Frank Kruse, UST Class B Operator wfkruse79@yahoo.com
Harinder Singh, UST Class A Operator inder4030@yahoo.com

Tank Number	06	**Tank Age**	36	**Tank Installed Date**	08/16/1989	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve
Tag Number	426	**Spill Test Date**	07/13/2023	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	03/12/2021	**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	07/31/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	06/06/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Number	07	**Tank Age**	36	**Tank Installed Date**	08/16/1989	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve
Tag Number	427	**Spill Test Date**	07/13/2023	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	03/12/2021	**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	07/31/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No

		Overfill Test Date	06/06/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Number	08	**Tank Age**	36	**Tank Installed Date**	08/16/1989	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve
Tag Number	428	**Spill Test Date**	12/08/2021	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	03/12/2021	**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	07/31/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	06/06/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Number	09	**Tank Age**	36	**Tank Installed Date**	08/16/1989	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve
Tag Number	429	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	03/12/2021	**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	07/31/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	06/06/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				

Facility Summary in Toole County in the City of Shelby

Location: NOONS FOOD STORE
602 W Roosevelt Hwy 2
Shelby, MT 59474 Toole

System Facility ID:51-00104

Facility Code: 28986
Last Inspected On: 04/24/2025
Operating Permit Renewal Date: 04/18/2028

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	MCP INC	**(406) 434-5882**	**mcpshelby@gmail.com**
Operator Contact:	Manjit Maan	**(209) 647-8034**	**mcpshelby@gmail.com**

Owner/Operator: MCP INC (406) 434-5882 mcpshelby@gmail.com

Manjit Maan, UST Class A Operator mcpshelby@gmail.com

Manjit Maan, UST Class B Operator mcpshelby@gmail.com

Tank Number	02	**Tank Age**	53	**Tank Installed Date**	02/18/1972	**Tank Material Construction**	Bare Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	3557	**Spill Test Date**	04/24/2025	**Piping Installed Date**	09/21/2006	**Tank Construction**		**Piping Construction**	Single Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**	04/24/2025	**Tank/Piping CP Test Date**	11/03/2020	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	04/24/2025	**Line Tightness Test Date**	11/12/2024	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	04/24/2025			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	01	**Tank Age**	53	**Tank Installed Date**	02/18/1972	**Tank Material Construction**	Bare Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	4382	**Spill Test Date**	05/07/2025	**Piping Installed Date**	09/21/2006	**Tank Construction**		**Piping Construction**	Single Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**	04/24/2025	**Tank/Piping CP Test Date**	11/03/2020	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	04/24/2025	**Line Tightness Test Date**	11/12/2024	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	04/24/2025			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	03	**Tank Age**	53	**Tank Installed Date**	02/18/1972	**Tank Material Construction**	Bare Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve

Tag Number	4383	**Spill Test Date**	04/24/2025	**Piping Installed Date**	09/21/2006	**Tank Construction**		**Piping Construction**	Single Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Diesel	**PLLD Test Date**	04/24/2025	**Tank/Piping CP Test Date**	11/03/2020	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	04/24/2025	**Line Tightness Test Date**	11/16/2024	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	04/24/2025			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Toole County in the City of Shelby

Location: TOWN PUMP INC SHELBY
1350 W Roosevelt Hwy
Shelby, MT 59474 Toole

System Facility ID:51-09749

Facility Code: 29136
Last Inspected On: 09/08/2024
Operating Permit Renewal Date: 08/06/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Shelby 1 Town Pump LLC	**(406) 497-6700**	**environmental@townpump.com**
Operator Contact:	Trent Biggers		**Trentb@townpump.com**

Owner/Operator:	Shelby 1 Town Pump LLC	(406) 497-6700	environmental@townpump.com
	Trent Biggers, UST Class A Operator		Trentb@townpump.com
	Trent Biggers, UST Class A Operator		Trentb@townpump.com
	Trent Biggers, UST Class B Global Operator		Trentb@townpump.com
	Trent Biggers, UST Class B Global Operator		Trentb@townpump.com

Tank Number	01	**Tank Age**	37	**Tank Installed Date**	09/07/1988	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve
Tag Number	2657	**Spill Test Date**	09/20/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	03/14/2024	**Sump Tightness Test Date**	09/20/2023	**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	09/20/2023	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	Yes
Capacity	12000	**ATG Test Date**	03/14/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	09/20/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Number	02	**Tank Age**	37	**Tank Installed Date**	09/07/1988	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	2658	**Spill Test Date**	09/20/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	03/14/2024	**Sump Tightness Test Date**	09/20/2023	**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	09/20/2023	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No

Capacity	12000	**ATG Test Date**	03/14/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	09/20/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Number	03	**Tank Age**	37	**Tank Installed Date**	09/07/1988	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve;Flapper Valve
Tag Number	2659	**Spill Test Date**	09/20/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	03/14/2024	**Sump Tightness Test Date**	09/20/2023	**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	09/20/2023	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	03/14/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	09/20/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Number	07	**Tank Age**	33	**Tank Installed Date**	08/01/1992	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve
Tag Number	2663	**Spill Test Date**	01/23/2024	**Piping Installed Date**	10/22/2012	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	03/14/2024	**Sump Tightness Test Date**	09/20/2023	**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Safe Suction	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	09/20/2023	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	03/14/2024	**Line Tightness Test Date**	04/01/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	09/20/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Number	08	**Tank Age**	26	**Tank Installed Date**	07/01/1999	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve
Tag Number	4248	**Spill Test Date**	09/20/2023	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	03/14/2024	**Sump Tightness Test Date**	09/20/2023	**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	11/27/2012	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	03/14/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No

		Overfill Test Date	09/20/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Number	04	**Tank Age**	37	**Tank Installed Date**	09/07/1988	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve
Tag Number	4291	**Spill Test Date**	09/20/2023	**Piping Installed Date**	10/22/2012	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	03/14/2024	**Sump Tightness Test Date**	09/20/2023	**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	09/20/2023	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	03/14/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	No
		Overfill Test Date	09/20/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Number	05	**Tank Age**	37	**Tank Installed Date**	09/07/1988	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve
Tag Number	4292	**Spill Test Date**	09/20/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	03/14/2024	**Sump Tightness Test Date**	09/20/2023	**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	09/20/2023	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	03/14/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	09/20/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Number	06	**Tank Age**	33	**Tank Installed Date**	08/01/1992	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	4293	**Spill Test Date**	01/03/2024	**Piping Installed Date**	10/22/2012	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	03/14/2024	**Sump Tightness Test Date**	09/20/2023	**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	11/27/2012	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	03/14/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	09/20/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				

Tank Number	09	**Tank Age**	24	**Tank Installed Date**	10/01/2001	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve
Tag Number	4413	**Spill Test Date**	09/20/2023	**Piping Installed Date**	10/22/2012	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	03/14/2024	**Sump Tightness Test Date**	09/20/2023	**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	11/27/2012	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	20000	**ATG Test Date**	03/14/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	No
		Overfill Test Date	09/20/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Number	10	**Tank Age**	13	**Tank Installed Date**	09/01/2012	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	
Tag Number	5416	**Spill Test Date**		**Piping Installed Date**	10/02/2012	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	10/18/2012	**Catastrophic L.D. Type 3.0**	Continuous Interstitial Monitoring	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	DEF (Not Regulated)	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Approved Remote Monitoring;Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Approved Remote Monitoring;Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	04/25/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	Yes
		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Number	11	**Tank Age**	0	**Tank Installed Date**		**Tank Material Construction**	Other	**Piping Material**	Steel	**Overfill Types**	
Tag Number	5862	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**		**Piping Type**	Not Listed	**CP Met Types**	
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Not Listed	**Primary Pipe Leak Detection**	Not Listed	**Vapor Recovery**	No
Capacity	150	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Not Listed	**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	12	**Tank Age**	0	**Tank Installed Date**		**Tank Material Construction**	Other	**Piping Material**	Steel	**Overfill Types**	
Tag Number	5874	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No

Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**		**Piping Type**	Not Listed	**CP Met Types**	
Product		**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Not Listed	**Primary Pipe Leak Detection**	Not Listed	**Vapor Recovery**	No
Capacity	150	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Not Listed	**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	13	**Tank Age**	0	**Tank Installed Date**		**Tank Material Construction**	Other	**Piping Material**	Steel	**Overfill Types**	
Tag Number	5890	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**		**Piping Type**	Not Listed	**CP Met Types**	
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Not Listed	**Primary Pipe Leak Detection**	Not Listed	**Vapor Recovery**	No
Capacity	150	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Not Listed	**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	19	**Tank Age**	1	**Tank Installed Date**	04/30/2024	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	6239	**Spill Test Date**	05/15/2024	**Piping Installed Date**	05/15/2024	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	05/15/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	04/29/2024	**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	Yes
Capacity	8000	**ATG Test Date**	05/15/2024	**Line Tightness Test Date**	05/15/2024	**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	05/15/2024			**ATG Type**					

Facility Summary in Toole County in the City of Sunburst

Location: TAYLORS BULK PLANT
55 Railroad Ave
Sunburst, MT 59482 Toole

System Facility ID:51-02025

Facility Code: 29031
Last Inspected On: 04/08/2022
Operating Permit Renewal Date: 06/22/2025

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Ben Taylor Inc **bti@3rivers.net**

Operator Contact: Scott Curry **scott.curry@btimontana.com**

Brian Robertson, UST Class B Operator	brian@kwsunburst.com
Brian Robertson, UST Class B Operator	brian@kwsunburst.com
Dan Gliko, UST Class B Operator	dglikojr@gmail.com
Dan Gliko, UST Class B Operator	dglikojr@gmail.com
Scott Curry, UST Class A Operator	scott.curry@btimontana.com

Tank Number	S6	**Tank Age**	26	**Tank Installed Date**	08/31/1999	**Tank Material Construction**	Unknown	**Piping Material**	Flexible Plastic	**Overfill Types**	
Tag Number	4137	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	Yes
Status	**Permanently Out of Use**	**MLLD Test Date**	04/08/2022	**Sump Tightness Test Date**	04/20/2016	**Catastrophic L.D. Type 3.0**	Continuous Interstitial Monitoring;Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	24000	**ATG Test Date**		**Line Tightness Test Date**	04/08/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	S7	**Tank Age**	26	**Tank Installed Date**	08/31/1999	**Tank Material Construction**	Unknown	**Piping Material**	Flexible Plastic	**Overfill Types**	
Tag Number	4138	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	Yes
Status	**Permanently Out of Use**	**MLLD Test Date**	04/08/2022	**Sump Tightness Test Date**	04/20/2016	**Catastrophic L.D. Type 3.0**	Continuous Interstitial Monitoring;Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	

Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	40000	**ATG Test Date**		**Line Tightness Test Date**	04/08/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	S8	**Tank Age**	26	**Tank Installed Date**	08/31/1999	**Tank Material Construction**	Unknown	**Piping Material**	Flexible Plastic	**Overfill Types**	
Tag Number	4139	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	Yes
Status	**Permanently Out of Use**	**MLLD Test Date**	04/08/2022	**Sump Tightness Test Date**	04/20/2016	**Catastrophic L.D. Type 3.0**	Continuous Interstitial Monitoring;Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Diesel, Dyed	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	40000	**ATG Test Date**		**Line Tightness Test Date**	04/08/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	S9	**Tank Age**	26	**Tank Installed Date**	08/31/1999	**Tank Material Construction**	Unknown	**Piping Material**	Flexible Plastic	**Overfill Types**	
Tag Number	4140	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	Yes
Status	**Permanently Out of Use**	**MLLD Test Date**	04/08/2022	**Sump Tightness Test Date**	04/20/2016	**Catastrophic L.D. Type 3.0**	Continuous Interstitial Monitoring;Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	40000	**ATG Test Date**		**Line Tightness Test Date**	04/08/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	S10	**Tank Age**	26	**Tank Installed Date**	08/31/1999	**Tank Material Construction**	Unknown	**Piping Material**	Flexible Plastic	**Overfill Types**	
Tag Number	4161	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	Yes
Status	**Permanently Out of Use**	**MLLD Test Date**	04/08/2022	**Sump Tightness Test Date**	04/20/2016	**Catastrophic L.D. Type 3.0**	Continuous Interstitial Monitoring;Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	

Product	Diesel, Dyed	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	3000	**ATG Test Date**		**Line Tightness Test Date**	04/08/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date				**ATG Type**					

Facility Summary in Toole County in the City of Sweet Grass

Location: DUTY FREE AMERICAS
60 3rd Ave
Sweet Grass, MT 59484-0249 Toole

System Facility ID:51-01377

Facility Code: 29016
Last Inspected On: 08/03/2023
Operating Permit Renewal Date: 09/06/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Duty Free America's Hollywood

Operator Contact: Chad Underdal **cunderdal@dutyfreeamericas.com**

Owner/Operator: Duty Free America's Hollywood

Chad Underdal, UST Class A Operator cunderdal@dutyfreeamericas.com
Chad Underdal, UST Class B Operator cunderdal@dutyfreeamericas.com
Kelsey Burley, UST Class B Operator store203@dutyfreeamericas.com

Tank Number	03	**Tank Age**	35	**Tank Installed Date**	01/01/1990	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	871	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**	04/17/2023	**Tank/Piping CP Test Date**	05/20/2024	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	15000	**ATG Test Date**	04/17/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	04/17/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	04	**Tank Age**	35	**Tank Installed Date**	01/01/1990	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	872	**Spill Test Date**	02/19/2024	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**	04/17/2023	**Tank/Piping CP Test Date**	10/10/2017	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	15000	**ATG Test Date**	04/17/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	02/19/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Toole County in the City of Sweet Grass

Location: SHORYA ENTERPRISES
510 2nd St
Sweet Grass, MT 59484 Toole

System Facility ID:51-12405

Facility Code: 29154
Last Inspected On: 03/18/2025
Operating Permit Renewal Date: 03/27/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Sunita Toora	**(408) 449-9333**	**pardeep.k51@yahoo.com**
Operator Contact:	Samantha Carney;Sunita Toora	**(406) 505-0320;(408) 449-9333**	**pardeep.k51@yahoo.com**

Owner/Operator: Sunita Toora (408) 449-9333 pardeep.k51@yahoo.com

Samantha Carney, UST Class A Operator pardeep.k51@yahoo.com
Samantha Carney, UST Class B Operator pardeep.k51@yahoo.com
Sunita Toora, UST Class A Operator pardeep.k51@yahoo.com
Sunita Toora, UST Class B Operator pardeep.k51@yahoo.com

Tank Number	01	**Tank Age**	34	**Tank Installed Date**	06/25/1991	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	2718	**Spill Test Date**	08/06/2024	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Single Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	04/04/2024	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	04/04/2024	**Line Tightness Test Date**	04/04/2024	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	04/04/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	02	**Tank Age**	34	**Tank Installed Date**	06/25/1991	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	2719	**Spill Test Date**	08/06/2024	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Single Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	04/04/2024	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	04/04/2024	**Line Tightness Test Date**	04/04/2024	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	04/04/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Treasure County in the City of Hysham

Location: FRIENDLY CORNER
718 Elliot Ave
Hysham, MT 59038 Treasure

System Facility ID:52-06316

Facility Code: 29186
Last Inspected On: 06/26/2024
Operating Permit Renewal Date: 09/29/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Cross Petroleum Services Billings **(406) 252-5519**

Operator Contact: Gregory Cross;R J Serpe;Timothy Fife **gcross@crosspetroleumservice.com;rlsrp@yahoo.com**

Owner/Operator: Cross Petroleum Services Billings (406) 252-5519

Greg Cross, UST Class A Operator	gcross@crosspetroleumservice.com
Greg Cross, UST Class A Operator	gcross@crosspetroleumservice.com
R J Serpe, UST Class A Operator	rlsrp@yahoo.com
R J Serpe, UST Class A Operator	rlsrp@yahoo.com
R J Serpe, UST Class B Global Operator	rlsrp@yahoo.com
R J Serpe, UST Class B Global Operator	rlsrp@yahoo.com
Shelli Thrower, UST Class B Operator	seves74@hotmail.com
Shelli Thrower, UST Class B Operator	seves74@hotmail.com
Timothy Fife, UST Class A Operator	
Timothy Fife, UST Class A Operator	

Tank Number	01	**Tank Age**	46	**Tank Installed Date**	08/01/1979	**Tank Material Construction**	Bare Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	1405	**Spill Test Date**	06/26/2024	**Piping Installed Date**		**Tank Construction**	Lined Interior/Impressed Current	**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	06/26/2024	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	06/26/2024	**Line Tightness Test Date**	03/24/2012	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	07/19/2024			**ATG Type**	Incon/TS-550 EVO				
Tank Number	02	**Tank Age**	46	**Tank Installed Date**	08/01/1979	**Tank Material Construction**	Bare Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	1406	**Spill Test Date**	06/26/2024	**Piping Installed Date**		**Tank Construction**	Lined Interior/Impressed Current	**Piping Construction**	None	**AST**	No

Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	06/26/2024	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	06/26/2024	**Line Tightness Test Date**	04/01/2012	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	07/19/2024			**ATG Type**	Incon/TS-550 EVO				
Tank Number	03	**Tank Age**	46	**Tank Installed Date**	08/01/1979	**Tank Material Construction**	Bare Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	1407	**Spill Test Date**	06/26/2024	**Piping Installed Date**		**Tank Construction**	Lined Interior/Impressed Current	**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	06/26/2024	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	3000	**ATG Test Date**	06/26/2024	**Line Tightness Test Date**	04/05/2012	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	07/19/2024			**ATG Type**	Incon/TS-550 EVO				

Facility Summary in Treasure County in the City of Hysham

Location: VALLEY FARMERS SUPPLY HYSHAM
121 Elliot Ave
Hysham, MT 59038 Treasure

System Facility ID:52-01905

Facility Code: 29169
Last Inspected On: 10/26/2023
Operating Permit Renewal Date: 02/27/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Valley Farmers Supply	**(406) 967-3100**	**sblack@vfarmers.com**
Operator Contact:	Scott Black	**(406) 967-3100**	**sblack@vfarmers.com**

Owner/Operator: Valley Farmers Supply (406) 967-3100 sblack@vfarmers.com

Earl Mitchell, UST Class B Operator	emitchell@vfarmers.com
Earl Mitchell, UST Class B Operator	emitchell@vfarmers.com
Scott Black, UST Class A Operator	sblack@vfarmers.com
Scott Black, UST Class A Operator	sblack@vfarmers.com
Scott Black, UST Class B Global Operator	sblack@vfarmers.com
Scott Black, UST Class B Global Operator	sblack@vfarmers.com
Shawn Hedges, UST Class B Operator	
Shawn Hedges, UST Class B Operator	
Sheryl Warren, UST Class B Operator	
Sheryl Warren, UST Class B Operator	

Tank Number	03	**Tank Age**	35	**Tank Installed Date**	07/01/1990	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	3144	**Spill Test Date**	10/26/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	10/26/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	1000	**ATG Test Date**	10/26/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	10/26/2023			**ATG Type**	Veeder Root/TLS-300				
Tank Number	04	**Tank Age**	35	**Tank Installed Date**	07/01/1990	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	3145	**Spill Test Date**	10/26/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Galvanic

Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	10/26/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	1000	**ATG Test Date**	10/26/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	10/26/2023			**ATG Type**	Veeder Root/TLS-300				

Facility Summary in Valley County in the City of Fort Peck

Location: ROCK CREEK MARINA
652 S Rock Creek Rd
Fort Peck, MT 59223-7001 Valley

System Facility ID:29-11049

Facility Code: 24936
Last Inspected On: 05/22/2025
Operating Permit Renewal Date: 10/08/2025

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Rock Creek Marina LLC **(406) 245-2560** **rockcreekmarina2023@gmail.com**

Operator Contact: David Frank **rockcreekmarina2023@gmail.com**

Owner/Operator: Rock Creek Marina LLC (406) 245-2560 rockcreekmarina2023@gmail.com

David Frank, UST Class A Operator rockcreekmarina2023@gmail.com

David Frank, UST Class B Operator rockcreekmarina2023@gmail.com

Tank Number	02	**Tank Age**	34	**Tank Installed Date**	05/01/1991	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	1846	**Spill Test Date**	09/09/2021	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	09/09/2021	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	07/20/2022	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	09/09/2021			**ATG Type**	Gilbarco/TLS-300				

Facility Summary in Valley County in the City of Fort Peck

Location: US ARMY CORPS OF ENGINEERS FORT PECK
Judith Rd
Fort Peck, MT 59223 Valley

System Facility ID:53-04612

Facility Code: 29268
Last Inspected On: 04/03/2024
Operating Permit Renewal Date: 08/28/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	US Army Corps of Engineers Fort Peck	**(406) 526-3411**	
Operator Contact:	Mary Nyquist;Seth Reedy;Thomas Grant	**(406) 526-3411;(406) 526-3431**	**mary.b.nyquist@usace.army.mil;seth.a.reedy@usace.army.mil;thomas.d.grant@usace.army.mil**

Owner/Operator: US Army Corps of Engineers Fort Peck (406) 526-3411

Mary Nyquist, UST Class A Operator	mary.b.nyquist@usace.army.mil
Mary Nyquist, UST Class B Operator	mary.b.nyquist@usace.army.mil
Seth Reedy, UST Class A Operator	seth.a.reedy@usace.army.mil
Seth Reedy, UST Class B Global Operator	seth.a.reedy@usace.army.mil
Seth Reedy, UST Class B Operator	seth.a.reedy@usace.army.mil
Thomas Grant, UST Class A Operator	thomas.d.grant@usace.army.mil
Thomas Grant, UST Class B Operator	thomas.d.grant@usace.army.mil

Tank Number	08	**Tank Age**	35	**Tank Installed Date**	06/01/1990	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	2154	**Spill Test Date**	04/03/2024	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	04/03/2024	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Auto Dialer;Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	04/03/2024	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	9000	**ATG Test Date**	04/03/2024	**Line Tightness Test Date**	04/03/2024	**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	04/03/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	09	**Tank Age**	35	**Tank Installed Date**	06/01/1990	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	2155	**Spill Test Date**	04/03/2024	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No

Status	**Currently in Use**	**MLLD Test Date**	04/03/2024	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Auto Dialer;Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	04/03/2024	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	2500	**ATG Test Date**	04/03/2024	**Line Tightness Test Date**	04/03/2024	**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	04/03/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	10	**Tank Age**	35	**Tank Installed Date**	06/01/1990	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	2156	**Spill Test Date**	04/03/2024	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	04/03/2024	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Auto Dialer;Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	04/03/2024	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	2500	**ATG Test Date**	04/03/2024	**Line Tightness Test Date**	04/03/2024	**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	04/03/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Valley County in the City of Frazer

Location: TRIBAL EXPRESS II
207 Main Ave
Frazer, MT 59225 Valley

System Facility ID:56-13890

Facility Code: 30564
Last Inspected On: 03/11/2025
Operating Permit Renewal Date: 03/17/2028

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Fort Peck Assiniboine and Sioux Tribes **(406) 768-5155**

Operator Contact: Lynette Adams **(406) 650-7774** **tribalexpress@yahoo.com**

Owner/Operator: Fort Peck Assiniboine and Sioux Tribes (406) 768-5155

Lynette Adams, UST Class A Operator tribalexpress@yahoo.com

Tank Number	01	**Tank Age**	28	**Tank Installed Date**	12/01/1997	**Tank Material Construction**	Steel Clad	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	6214	**Spill Test Date**	03/12/2025	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Manual Interstitial Monitoring	**Primary Pipe Leak Detection**	Deferred	**Vapor Recovery**	No
Capacity	1000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	03/12/2025			**ATG Type**					
Tank Number	02	**Tank Age**	28	**Tank Installed Date**	12/01/1997	**Tank Material Construction**	Steel Clad	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	6215	**Spill Test Date**	03/12/2025	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Manual Interstitial Monitoring	**Primary Pipe Leak Detection**	Deferred	**Vapor Recovery**	No
Capacity	2000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	03/12/2025			**ATG Type**					

Facility Summary in Valley County in the City of Glasgow

Location: AGLAND COOP GLASGOW
54197 US Hwy 2
Glasgow, MT 59230-1803 Valley

System Facility ID:53-03160

Facility Code: 29245
Last Inspected On: 02/26/2024
Operating Permit Renewal Date: 07/11/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Agland Coop Wolf Point	**(406) 653-1221**	**dave.williams@agland-coop.com**
Operator Contact:	Kory Hentges	**(406) 228-4641**	**kory.hentges@agland-coop.com**

Owner/Operator:	Agland Coop Wolf Point	(406) 653-1221	dave.williams@agland-coop.com
	Allen Richard, UST Class B Global Operator		allen.richard@agland-coop.com
	Allen Richard, UST Class B Global Operator		allen.richard@agland-coop.com
	Allen Richard, UST Class B Operator		allen.richard@agland-coop.com
	Allen Richard, UST Class B Operator		allen.richard@agland-coop.com
	Kory Hentges, UST Class A Operator		kory.hentges@agland-coop.com
	Kory Hentges, UST Class A Operator		kory.hentges@agland-coop.com
	Kory Hentges, UST Class B Operator		kory.hentges@agland-coop.com
	Kory Hentges, UST Class B Operator		kory.hentges@agland-coop.com
	Michael Pallvoda, UST Class B Operator		fuoilwp@nemont.net
	Michael Pallvoda, UST Class B Operator		fuoilwp@nemont.net
	Steven Long, UST Class B Operator		
	Steven Long, UST Class B Operator		

Tank Number	05	**Tank Age**	34	**Tank Installed Date**	05/01/1991	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	1574	**Spill Test Date**	02/26/2024	**Piping Installed Date**	08/31/2012	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	02/26/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**	05/17/2023	**Tank/Piping CP Test Date**	02/26/2024	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	05/17/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date	02/26/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	06	**Tank Age**	34	**Tank Installed Date**	05/01/1991	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve;High Level Alarm

Tag Number	1575	**Spill Test Date**	02/26/2024	**Piping Installed Date**	08/31/2012	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	02/26/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**	05/17/2023	**Tank/Piping CP Test Date**	02/26/2024	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	05/17/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date	02/26/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	07	**Tank Age**	34	**Tank Installed Date**	05/01/1991	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	1576	**Spill Test Date**	02/26/2024	**Piping Installed Date**	08/31/2012	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	02/26/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**	05/17/2023	**Tank/Piping CP Test Date**	02/26/2024	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	05/17/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date	02/26/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	08	**Tank Age**	34	**Tank Installed Date**	05/01/1991	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	1577	**Spill Test Date**	02/26/2024	**Piping Installed Date**	08/31/2012	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	02/26/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**	05/17/2023	**Tank/Piping CP Test Date**	02/26/2024	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**	05/17/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date	02/26/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	09	**Tank Age**	34	**Tank Installed Date**	05/01/1991	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	1578	**Spill Test Date**	02/26/2024	**Piping Installed Date**	08/31/2012	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	02/26/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Safe Suction	**CP Met Types**	Galvanic

Product	Diesel	**PLLD Test Date**	05/17/2023	**Tank/Piping CP Test Date**	02/26/2024	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	2000	**ATG Test Date**	05/17/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date	02/26/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	10	**Tank Age**	13	**Tank Installed Date**	10/01/2012	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	5391	**Spill Test Date**	02/26/2024	**Piping Installed Date**	08/31/2012	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	02/26/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	05/17/2023	**Tank/Piping CP Test Date**	02/26/2024	**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	20000	**ATG Test Date**	05/17/2023	**Line Tightness Test Date**	10/26/2012	**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	02/26/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350;Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Valley County in the City of Glasgow

Location: CIRCLE K STORE 2746281
108 1st Ave N
Glasgow, MT 59230 Valley

System Facility ID:53-09712

Facility Code: 29324
Last Inspected On: 07/25/2023
Operating Permit Renewal Date: 10/01/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Rocky Mountain Oil LLC	**(602) 728-8000**	**NT-ESS@Circlek.com**
Operator Contact:	Chuck Nyberg;Dean Townsend	**(952) 830-8722**	**dean.townsend@holidaycompanies.com**

Owner/Operator: Rocky Mountain Oil LLC (602) 728-8000 NT-ESS@Circlek.com

Brad Lee, UST Class B Global Operator	brad.lee@holidaycompanies.com
Brad Lee, UST Class B Global Operator	brad.lee@holidaycompanies.com
Chuck Nyberg, UST Class A Operator	
Dean Townsend, UST Class A Operator	dean.townsend@holidaycompanies.com
Dean Townsend, UST Class A Operator	dean.townsend@holidaycompanies.com
Dylan Imbrescia, UST Class B Operator	djimbrescia2715@gmail.com
Dylan Imbrescia, UST Class B Operator	djimbrescia2715@gmail.com
Greg Brewer, UST Class B Global Operator	greg.brewer@holidaycompanies.com
Greg Brewer, UST Class B Global Operator	greg.brewer@holidaycompanies.com
Jon Garcia, UST Class B Operator	jon.p.garcia89@gmail.com
Jon Garcia, UST Class B Operator	jon.p.garcia89@gmail.com
Travis Struckman, UST Class B Global Operator	travis.struckman@holidaycompanies.com
Travis Struckman, UST Class B Global Operator	travis.struckman@holidaycompanies.com

Tank Number	04	**Tank Age**	36	**Tank Installed Date**	08/01/1989	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve
Tag Number	4431	**Spill Test Date**	04/19/2022	**Piping Installed Date**	08/12/2008	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**	03/10/2020	**Tank/Piping CP Test Date**	03/10/2020	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	04/20/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Tank Number	01	**Tank Age**	39	**Tank Installed Date**	03/01/1986	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve;Flapper Valve
Tag Number	4432	**Spill Test Date**	04/10/2023	**Piping Installed Date**	08/12/2008	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**	04/10/2023	**Tank/Piping CP Test Date**	04/10/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	04/10/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	04/10/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	03	**Tank Age**	37	**Tank Installed Date**	04/15/1988	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve
Tag Number	4433	**Spill Test Date**		**Piping Installed Date**	08/12/2008	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Diesel	**PLLD Test Date**	03/10/2020	**Tank/Piping CP Test Date**	03/10/2020	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	04/20/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Valley County in the City of Glasgow

Location: EZZIES MIDTOWN
204 1st Ave N
Glasgow, MT 59230-1820 Valley

System Facility ID:53-05709

Facility Code: 29276
Last Inspected On: 10/25/2022
Operating Permit Renewal Date: 04/04/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Ezzies Wholesale Inc **bill@ezzies.com**

Operator Contact: Brandon Hoerster;Conor Moran;Ezzies Wholesale Inc **(406) 228-2713** **brandon@ezzies.com;conor@ezzies.com;bill@ezzies.com**

Owner/Operator: Ezzies Wholesale Inc bill@ezzies.com

Brandon Hoerster, UST Class A Operator	brandon@ezzies.com
Brandon Hoerster, UST Class A Operator	brandon@ezzies.com
Brandon Hoerster, UST Class B Operator	brandon@ezzies.com
Brandon Hoerster, UST Class B Operator	brandon@ezzies.com
Conor Moran, UST Class A Operator	bill@ezzies.com

Tank Number	05	**Tank Age**	25	**Tank Installed Date**	06/01/2000	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	4201	**Spill Test Date**	10/25/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**	07/13/2022	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	07/13/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350				
Tank Number	06	**Tank Age**	25	**Tank Installed Date**	06/01/2000	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	4202	**Spill Test Date**	10/25/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	04/02/2020	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	07/13/2022	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No

		Overfill Test Date	07/13/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Valley County in the City of Glasgow

Location: EZZIES WHOLESALE GLASGOW
1330 US Hwy 2 W
Glasgow, MT 59230 Valley

System Facility ID:53-10475

Facility Code: 29361
Last Inspected On: 12/14/2023
Operating Permit Renewal Date: 03/24/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Ezzies Wholesale Inc **bill@ezzies.com**

Operator Contact: Brandon Hoerster;Conor Moran;Ezzies Wholesale Inc **(406) 228-2713** **brandon@ezzies.com;conor@ezzies.com;bill@ezzies.com**

Owner/Operator: Ezzies Wholesale Inc bill@ezzies.com

Brandon Hoerster, UST Class A Operator	brandon@ezzies.com
Brandon Hoerster, UST Class A Operator	brandon@ezzies.com
Brandon Hoerster, UST Class B Global Operator	brandon@ezzies.com
Brandon Hoerster, UST Class B Global Operator	brandon@ezzies.com
Brandon Hoerster, UST Class B Operator	brandon@ezzies.com
Brandon Hoerster, UST Class B Operator	brandon@ezzies.com
Conor Moran, UST Class A Operator	bill@ezzies.com
Jarid Jensen, UST Class B Operator	jpjensen@hotmail.com
Jarid Jensen, UST Class B Operator	jpjensen@hotmail.com

Tank Number	07	**Tank Age**	23	**Tank Installed Date**	11/21/2002	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	4758	**Spill Test Date**	11/20/2023	**Piping Installed Date**	08/15/2012	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	11/20/2023	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	11/20/2023	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	11/20/2023	**Line Tightness Test Date**	11/20/2023	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	11/20/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	08	**Tank Age**	23	**Tank Installed Date**	11/21/2002	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	4759	**Spill Test Date**	11/20/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	11/20/2023	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible

Product	Diesel	**PLLD Test Date**	11/20/2023	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**	11/20/2023	**Line Tightness Test Date**	11/20/2023	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	11/20/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	09	**Tank Age**	23	**Tank Installed Date**	11/21/2002	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	4760	**Spill Test Date**	11/20/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	11/20/2023	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	11/20/2023	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**	11/20/2023	**Line Tightness Test Date**	11/20/2023	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	11/20/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	10	**Tank Age**	23	**Tank Installed Date**	11/21/2002	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	4761	**Spill Test Date**	11/20/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	11/20/2023	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	11/20/2023	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	11/20/2023	**Line Tightness Test Date**	11/20/2023	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	11/20/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	11	**Tank Age**	23	**Tank Installed Date**	11/21/2002	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	No Piping	**Overfill Types**	High Level Alarm
Tag Number	4762	**Spill Test Date**	11/20/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	02/27/2025	**Sump Tightness Test Date**	11/20/2023	**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	11/20/2023	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	11/20/2023	**Line Tightness Test Date**	11/20/2023	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No

		Overfill Test Date	11/20/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	12	**Tank Age**	23	**Tank Installed Date**	11/21/2002	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	4763	**Spill Test Date**	11/20/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	02/27/2025	**Sump Tightness Test Date**	11/20/2023	**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	11/20/2023	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	11/20/2023	**Line Tightness Test Date**	11/20/2023	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	11/20/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	13	**Tank Age**	23	**Tank Installed Date**	11/21/2002	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	4764	**Spill Test Date**	11/20/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	12/05/2023	**Sump Tightness Test Date**	11/20/2023	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	11/05/2020	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	20000	**ATG Test Date**	11/20/2023	**Line Tightness Test Date**	12/05/2023	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	11/20/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	14	**Tank Age**	23	**Tank Installed Date**	11/21/2002	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	4765	**Spill Test Date**	11/20/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	11/20/2023	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	11/20/2023	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	30000	**ATG Test Date**	11/20/2023	**Line Tightness Test Date**	11/20/2023	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	11/20/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Valley County in the City of Glasgow

Location: FRANCES MAHON DEACONESS HOSPITAL
621 3rd St S
Glasgow, MT 59230-2604 Valley

System Facility ID:53-05192

Facility Code: 29273
Last Inspected On: 05/17/2023
Operating Permit Renewal Date: 11/06/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Frances Mahon Deaconess Hospital **(406) 228-4351**

Operator Contact: David Nixdorf

Owner/Operator: Frances Mahon Deaconess Hospital (406) 228-4351

David Nixdorf, UST Class A Operator
Jeff Damboise, UST Class B Operator jeff.damboise@fmdh.org
Paul Sallee, UST Class B Operator dolby2070@gmail.com

Tank Number	03	**Tank Age**	30	**Tank Installed Date**	10/01/1995	**Tank Material Construction**	Steel Clad	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	1118	**Spill Test Date**	05/17/2023	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Auto Dialer	**Piping Type**	U.S. Suction	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	05/22/2013	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	3-Year Line Tightness Test	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	07/10/2024	**Line Tightness Test Date**	07/22/2020	**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	07/10/2024			**ATG Type**	Veeder Root/TLS-300				
Tank Number	04	**Tank Age**	30	**Tank Installed Date**	10/01/1995	**Tank Material Construction**	Steel Clad	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	1119	**Spill Test Date**	05/17/2023	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Auto Dialer	**Piping Type**	U.S. Suction	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	05/22/2013	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	3-Year Line Tightness Test	**Vapor Recovery**	No
Capacity	2000	**ATG Test Date**	07/10/2024	**Line Tightness Test Date**	05/17/2023	**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	07/10/2024			**ATG Type**	Veeder Root/TLS-300				

Facility Summary in Valley County in the City of Glasgow

Location: GLASGOW INTERNATIONAL AIRPORT
89 Airport Rd
Glasgow, MT 59230-2843 Valley

System Facility ID:53-03271

Facility Code: 29250
Last Inspected On: 04/04/2024
Operating Permit Renewal Date: 04/04/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Dave Reinhardt;Valley County Airport Commission	**(406) 228-8221**	**airport@valleycountymt.gov**
Operator Contact:	Lucas Locke;Manfreda Donovan;Robert Lipscomb	**(406) 230-2257;(406) 263-7010;(406) 293-2067**	**airport@valleycountymt.gov;irpilot@nemont.net;sevencarpileup1970@gmail.com**

Owner/Operator: Dave Reinhardt

Owner/Operator: Valley County Airport Commission

Lucas Locke, UST Class A Operator	airport@valleycountymt.gov
Lucas Locke, UST Class A Operator	airport@valleycountymt.gov
Lucas Locke, UST Class B Operator	airport@valleycountymt.gov
Lucas Locke, UST Class B Operator	airport@valleycountymt.gov
Manfreda Donovan, UST Class A Operator	sevencarpileup1970@gmail.com
Manfreda Donovan, UST Class A Operator	sevencarpileup1970@gmail.com
Manfreda Donovan, UST Class B Operator	sevencarpileup1970@gmail.com
Manfreda Donovan, UST Class B Operator	sevencarpileup1970@gmail.com
Robert Lipscomb, UST Class A Operator	irpilot@nemont.net
Robert Lipscomb, UST Class A Operator	irpilot@nemont.net
Robert Lipscomb, UST Class B Operator	irpilot@nemont.net
Robert Lipscomb, UST Class B Operator	irpilot@nemont.net

Tank Number	01	**Tank Age**	45	**Tank Installed Date**	01/01/1980	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Steel	**Overfill Types**	High Level Alarm
Tag Number	2726	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**	Lined Interior/Impressed Current	**Piping Construction**	None	**AST**	No
Status	**Temporarily Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Aviation Gas	**PLLD Test Date**		**Tank/Piping CP Test Date**	04/04/2024	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**		**Line Tightness Test Date**	08/09/2006	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					

Tank Number	02	**Tank Age**	44	**Tank Installed Date**	04/07/1981	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	No Piping	**Overfill Types**	High Level Alarm
Tag Number	2727	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**	Lined Interior/Impressed Current	**Piping Construction**	None	**AST**	No
Status	**Temporarily Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Not Listed	**CP Met Types**	Impressed Current
Product	Jet Fuel (Jet-A, Jet-A1, JP5)	**PLLD Test Date**		**Tank/Piping CP Test Date**	04/04/2024	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**		**Line Tightness Test Date**	08/09/2006	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					

Facility Summary in Valley County in the City of Glasgow

Location: LAKERIDGE LODGING AND BAIT SHOP
5990 MT Hwy 24 S
Glasgow, MT 59230-8822 Valley

System Facility ID:53-08383

Facility Code: 29312
Last Inspected On: 11/26/2024
Operating Permit Renewal Date: 05/04/2028

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Carrie Mindt;Team Lakeridge LLC	**(406) 526-3597**	**lakeridgefortpeck@gmail.com;lakeridgefortpek@gmail.com**

Operator Contact:	Carrie Mindt	**(406) 526-3597**	**lakeridgefortpeck@gmail.com**

Owner/Operator:	Carrie Mindt	(406) 526-3597	lakeridgefortpeck@gmail.com
Owner/Operator:	Team Lakeridge LLC	(406) 526-3597	lakeridgefortpeck@gmail.com
	Carrie Mindt, UST Class A Operator		lakeridgefortpeck@gmail.com
	Carrie Mindt, UST Class A Operator		lakeridgefortpeck@gmail.com
	Carrie Mindt, UST Class B Global Operator		lakeridgefortpeck@gmail.com
	Carrie Mindt, UST Class B Global Operator		lakeridgefortpeck@gmail.com
	Carrie Mindt, UST Class B Operator		lakeridgefortpeck@gmail.com
	Carrie Mindt, UST Class B Operator		lakeridgefortpeck@gmail.com

Tank Number	05	**Tank Age**	28	**Tank Installed Date**	05/15/1997	**Tank Material Construction**	Steel Clad	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	1509	**Spill Test Date**	04/16/2025	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Single Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	01/21/2013	**Primary Tank Leak Detection**	Manual Interstitial Monitoring	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	04/16/2025			**ATG Type**					
Tank Number	06	**Tank Age**	28	**Tank Installed Date**	05/15/1997	**Tank Material Construction**	Steel Clad	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	1510	**Spill Test Date**	11/25/2024	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Single Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	01/21/2013	**Primary Tank Leak Detection**	Manual Interstitial Monitoring	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	2000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No

		Overfill Test Date	11/25/2024			**ATG Type**					

Facility Summary in Valley County in the City of Glasgow

Location: TRAILSIDE GENERAL STORE GLASGOW
54271 Hwy 2 E
Glasgow, MT 59230 Valley

System Facility ID:53-07787

Facility Code: 29299
Last Inspected On: 07/25/2023
Operating Permit Renewal Date: 07/25/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Wayne Waarvik	**(406) 228-9528**	**wtwaarvik@nemont.net**
Operator Contact:	Wayne Waarvik	**(406) 228-9528**	**wtwaarvik@nemont.net**

Wayne Waarvik, UST Class A Operator wtwaarvik@nemont.net
Wayne Waarvik, UST Class B Global Operator wtwaarvik@nemont.net

Tank Number	03	**Tank Age**	34	**Tank Installed Date**	09/09/1991	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	
Tag Number	3873	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Single Walled	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	07/25/2023	**Primary Tank Leak Detection**	Inventory Reconciliation;Tank Tightness Testing	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	20000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	04	**Tank Age**	34	**Tank Installed Date**	09/09/1991	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	
Tag Number	3874	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Single Walled	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	07/25/2023	**Primary Tank Leak Detection**	Inventory Reconciliation;Tank Tightness Testing	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	20000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					

Facility Summary in Valley County in the City of Hinsdale

Location: RAIDERS QUICK STOP
842 1st Ave N
Hinsdale, MT 59241 Valley

System Facility ID:60-15298

Facility Code: 31002
Last Inspected On: 04/10/2023
Operating Permit Renewal Date: 10/11/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Ezzies Wholesale Inc **bill@ezzies.com**

Operator Contact: Brandon Hoerster;Conor Moran;Ezzies Wholesale Inc **(406) 228-2713** **brandon@ezzies.com;conor@ezzies.com;bill@ezzies.com**

Owner/Operator: Ezzies Wholesale Inc bill@ezzies.com

Brandon Hoerster, UST Class A Operator brandon@ezzies.com
Conor Moran, UST Class A Operator bill@ezzies.com
Nena Malmend, UST Class B Operator bill@ezzies.com

Tank Number	01	**Tank Age**	8	**Tank Installed Date**	04/10/2017	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	5716	**Spill Test Date**	07/22/2020	**Piping Installed Date**	04/12/2017	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	07/22/2020	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	2000	**ATG Test Date**		**Line Tightness Test Date**	07/05/2017	**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	07/22/2020			**ATG Type**	Incon/TS-550 EVO				
Tank Number	02	**Tank Age**	8	**Tank Installed Date**	04/10/2017	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	5717	**Spill Test Date**	07/22/2020	**Piping Installed Date**	04/12/2017	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	07/22/2020	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	Yes
Capacity	5000	**ATG Test Date**		**Line Tightness Test Date**	07/05/2017	**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	07/22/2020			**ATG Type**	Incon/TS-550 EVO				

Tank Number	03	**Tank Age**	8	**Tank Installed Date**	04/10/2017	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	5718	**Spill Test Date**	07/22/2020	**Piping Installed Date**	04/12/2017	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	07/22/2020	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	Yes
Capacity	2000	**ATG Test Date**		**Line Tightness Test Date**	07/05/2017	**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	07/22/2020			**ATG Type**	Incon/TS-550 EVO				
Tank Number	04	**Tank Age**	8	**Tank Installed Date**	04/10/2017	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	5727	**Spill Test Date**	07/22/2020	**Piping Installed Date**	04/12/2017	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	07/22/2020	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	2500	**ATG Test Date**		**Line Tightness Test Date**	07/05/2017	**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	07/22/2020			**ATG Type**	Incon/TS-550 EVO				

Facility Summary in Valley County in the City of Nashua

Location: AGLAND COOP NASHUA
810 Front St
Nashua, MT 59248 Valley

System Facility ID:53-10461

Facility Code: 29360
Last Inspected On: 06/15/2021
Operating Permit Renewal Date: 08/07/2024

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Agland Coop Wolf Point	**(406) 653-1221**	**dave.williams@agland-coop.com**
Operator Contact:	James Merideth		

Allen Richard, UST Class B Global Operator	allen.richard@agland-coop.com
Allen Richard, UST Class B Global Operator	allen.richard@agland-coop.com
Allen Richard, UST Class B Operator	allen.richard@agland-coop.com
Allen Richard, UST Class B Operator	allen.richard@agland-coop.com
James Merideth, UST Class A Operator	
James Merideth, UST Class A Operator	
James Merideth, UST Class B Global Operator	
James Merideth, UST Class B Global Operator	
Michael Pallvoda, UST Class B Operator	fuoilwp@nemont.net
Michael Pallvoda, UST Class B Operator	fuoilwp@nemont.net
Steven Long, UST Class B Operator	
Steven Long, UST Class B Operator	

Tank Number	05	**Tank Age**	35	**Tank Installed Date**	03/01/1990	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	937	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	06/15/2021	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco/EMC Basic				
Tank Number	06	**Tank Age**	35	**Tank Installed Date**	03/01/1990	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	938	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No

Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	06/15/2021	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco/EMC Basic				
Tank Number	07	**Tank Age**	35	**Tank Installed Date**	03/01/1990	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	939	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	06/15/2021	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco/EMC Basic				
Tank Number	08	**Tank Age**	35	**Tank Installed Date**	03/01/1990	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	940	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	06/15/2021	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco/EMC Basic				

Facility Summary in Valley County in the City of Opheim

Location: PRO COOP OPHEIM
45 S Main
Opheim, MT 59250 Valley

System Facility ID:53-07814

Facility Code: 29300
Last Inspected On: 11/09/2023
Operating Permit Renewal Date: 02/12/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Pro Coop Opheim **(406) 762-3231**

Operator Contact: Jason Nasby;Myron Redfield;Timothy Stenglein **(406) 762-3231** **jnasby@procoopag.com;mtstenglein@yahoo.com**

Owner/Operator: Pro Coop Opheim (406) 762-3231

Jason Nasby, UST Class A Operator	jnasby@procoopag.com
Jason Nasby, UST Class B Operator	jnasby@procoopag.com
Myron Redfield, UST Class A Operator	
Myron Redfield, UST Class B Operator	
Timothy Stenglein, UST Class A Operator	mtstenglein@yahoo.com
Timothy Stenglein, UST Class B Operator	mtstenglein@yahoo.com

Tank Number	04	**Tank Age**	32	**Tank Installed Date**	08/01/1993	**Tank Material Construction**	Steel Clad	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	1820	**Spill Test Date**	11/09/2023	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	11/19/2020	**Primary Tank Leak Detection**	Manual Interstitial Monitoring	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	2300	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	11/09/2023			**ATG Type**					
Tank Number	05	**Tank Age**	32	**Tank Installed Date**	08/01/1993	**Tank Material Construction**	Steel Clad	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	1821	**Spill Test Date**	11/09/2023	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Galvanic
Product	Gasohol/Ethanol	**PLLD Test Date**		**Tank/Piping CP Test Date**	11/19/2020	**Primary Tank Leak Detection**	Manual Interstitial Monitoring	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	3700	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No

		Overfill Test Date	11/09/2023			**ATG Type**					
Tank Number	06	**Tank Age**	32	**Tank Installed Date**	08/01/1993	**Tank Material Construction**	Steel Clad	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	1822	**Spill Test Date**	11/09/2023	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	11/19/2020	**Primary Tank Leak Detection**	Manual Interstitial Monitoring	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	2300	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	11/09/2023			**ATG Type**					
Tank Number	07	**Tank Age**	32	**Tank Installed Date**	08/01/1993	**Tank Material Construction**	Steel Clad	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	1823	**Spill Test Date**	11/09/2023	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	11/19/2020	**Primary Tank Leak Detection**	Manual Interstitial Monitoring	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	3700	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	11/09/2023			**ATG Type**					

Facility Summary in Valley County in the City of Saint Marie

Location: MT AVIATION RESEARCH BLDG CO BLDG 649A
Address Unavailable (DEQ_GEO_LOC_INFO : 44095)
Saint Marie, MT 59231 Valley

System Facility ID:53-12774

Facility Code: 29550
Last Inspected On: 07/19/2024
Operating Permit Renewal Date: 10/19/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Montana Aviation Research Co	**(406) 524-3777**

Operator Contact:	Brad Juntunen;Brian Mix;Darcel Wesen;Kenny Bryan;Kevin Wersal;Lynn Blatter;Michael Myrick;Preston Murch	**(406) 228-9584;(406) 263-1362;(406) 263-4591;(406) 263-6931;(406) 524-3777**	**darcel.d.wesen@boeing.com;marco787@nemont.net;marcomaintenance916@gmail.com;mm2000chevy@yahoo.com;shirleyblatter@yahoo.com;wersal5@hotmail.com**

Owner/Operator: Montana Aviation Research Co (406) 524-3777

Brad Juntunen, UST Class A Operator	marco787@nemont.net
Brad Juntunen, UST Class B Operator	marco787@nemont.net
Brian Mix, UST Class A Operator	marco787@nemont.net
Brian Mix, UST Class B Operator	marco787@nemont.net
Darcel Wesen, UST Class A Operator	darcel.d.wesen@boeing.com
Darcel Wesen, UST Class B Operator	darcel.d.wesen@boeing.com
Kenny Bryan, UST Class A Operator	marcomaintenance916@gmail.com
Kenny Bryan, UST Class B Global Operator	marcomaintenance916@gmail.com
Kenny Bryan, UST Class B Operator	marcomaintenance916@gmail.com
Kevin Wersal, UST Class A Operator	wersal5@hotmail.com
Kevin Wersal, UST Class B Operator	wersal5@hotmail.com
Lynn Blatter, UST Class A Operator	shirleyblatter@yahoo.com
Lynn Blatter, UST Class B Global Operator	shirleyblatter@yahoo.com
Michael Myrick, UST Class A Operator	mm2000chevy@yahoo.com
Michael Myrick, UST Class B Operator	mm2000chevy@yahoo.com
Preston Murch, UST Class A Operator	marco787@nemont.net
Preston Murch, UST Class B Operator	marco787@nemont.net

Tank Number	S4	**Tank Age**	31	**Tank Installed Date**	01/01/1994	**Tank Material Construction**	Bare Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	
Tag Number	2975	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	Yes
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Continuous Interstitial Monitoring	**Piping Type**	Pressurized	**CP Met Types**	
Product	Jet Fuel (Jet-A, Jet-A1, JP5)	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No

Capacity	50000	**ATG Test Date**	07/19/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	S5	**Tank Age**	31	**Tank Installed Date**	01/01/1994	**Tank Material Construction**	Bare Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	
Tag Number	2976	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	Yes
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Continuous Interstitial Monitoring	**Piping Type**	Pressurized	**CP Met Types**	
Product	Jet Fuel (Jet-A, Jet-A1, JP5)	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	50000	**ATG Test Date**	07/19/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Wheatland County in the City of Harlowton

Location: ENGINEERS DEPOT
102 2nd St NE
Harlowton, MT 59036-2910 Wheatland

System Facility ID:54-04934

Facility Code: 29584
Last Inspected On: 06/26/2024
Operating Permit Renewal Date: 10/31/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Dennis Whitmore	**(406) 651-5101**	**dwhitmore@gmconostores.com**
Operator Contact:	Savannah Truesdale;Shawn Truesdale;William Woods	**(406) 632-4630**	**savannahspiritleader@gmail.com;shawntruesdale59@gmail.com;wjwoods10@gmail.com**

Owner/Operator:	Dennis Whitmore	(406) 651-5101	dwhitmore@gmconostores.com
	Savannah Truesdale, UST Class A Operator		savannahspiritleader@gmail.com
	Savannah Truesdale, UST Class B Operator		savannahspiritleader@gmail.com
	Shawn Truesdale, UST Class A Operator		shawntruesdale59@gmail.com
	Shawn Truesdale, UST Class A Operator		shawntruesdale59@gmail.com
	Shawn Truesdale, UST Class B Operator		shawntruesdale59@gmail.com
	Shawn Truesdale, UST Class B Operator		shawntruesdale59@gmail.com
	William Woods, UST Class A Operator		wjwoods10@gmail.com
	William Woods, UST Class B Operator		wjwoods10@gmail.com

Tank Number	05	**Tank Age**	37	**Tank Installed Date**	11/17/1988	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	1045	**Spill Test Date**	06/26/2024	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	04/12/2024	**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	06/26/2024	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	04/12/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350				
Tank Number	06	**Tank Age**	37	**Tank Installed Date**	11/17/1988	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	1046	**Spill Test Date**	06/26/2024	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	06/26/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**	04/12/2024	**Tank/Piping CP Test Date**	06/26/2024	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No

Capacity	4000	**ATG Test Date**	04/12/2024	**Line Tightness Test Date**	04/29/2021	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	04/12/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350				
Tank Number	07	**Tank Age**	37	**Tank Installed Date**	11/17/1988	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	4342	**Spill Test Date**	06/26/2024	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	06/26/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**	04/12/2024	**Tank/Piping CP Test Date**	06/26/2024	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	04/12/2024	**Line Tightness Test Date**	04/29/2021	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	04/12/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350				
Tank Number	08	**Tank Age**	22	**Tank Installed Date**	07/17/2003	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	4850	**Spill Test Date**	06/26/2024	**Piping Installed Date**	08/17/2012	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	06/26/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**	04/12/2024	**Tank/Piping CP Test Date**	06/26/2024	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**	04/12/2024	**Line Tightness Test Date**	04/29/2021	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	04/12/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Wheatland County in the City of Harlowton

Location: MALMSTROM AFB K 1
US Hwy 191
Harlowton, MT 59036 Wheatland

System Facility ID:54-09085

Facility Code: 29612
Last Inspected On: 03/25/2025
Operating Permit Renewal Date: 08/21/2025

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: 341 CES CEANQ **(406) 731-6188**

Operator Contact: Candace Ellsworth;Curtis Hester;William Smith **(406) 731-6239;(406) 731-7128** **candace.ellsworth@us.af.mil;william.smith@us.af.mil**

Owner/Operator: 341 CES CEANQ (406) 731-6188

Candace Ellsworth, UST Class A Operator	candace.ellsworth@us.af.mil
Candace Ellsworth, UST Class B Global Operator	candace.ellsworth@us.af.mil
Curtis Hester, UST Class A Operator	
Curtis Hester, UST Class B Global Operator	
William Smith, UST Class A Operator	william.smith@us.af.mil
William Smith, UST Class B Global Operator	william.smith@us.af.mil

Tank Number	03	**Tank Age**	63	**Tank Installed Date**	05/02/1962	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	341	**Spill Test Date**	03/25/2022	**Piping Installed Date**		**Tank Construction**	Lined Interior/Impressed Current	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	03/25/2022	**Catastrophic L.D. Type 3.0**	Auto Dialer	**Piping Type**	U.S. Suction	**CP Met Types**	Impressed Current
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	01/09/2021	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	10/30/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	10/30/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				

Facility Summary in Wheatland County in the City of Harlowton

Location: MALMSTROM AFB K 10
US Hwy 12
Harlowton, MT 59036 Wheatland

System Facility ID:54-09094

Facility Code: 29621
Last Inspected On: 03/25/2025
Operating Permit Renewal Date: 07/31/2025

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: 341 CES CEANQ **(406) 731-6188**

Operator Contact: Candace Ellsworth;Curtis Hester;William Smith **(406) 731-6239;(406) 731-7128** **candace.ellsworth@us.af.mil;william.smith@us.af.mil**

Owner/Operator: 341 CES CEANQ (406) 731-6188

Candace Ellsworth, UST Class A Operator	candace.ellsworth@us.af.mil
Candace Ellsworth, UST Class B Global Operator	candace.ellsworth@us.af.mil
Curtis Hester, UST Class A Operator	
Curtis Hester, UST Class B Global Operator	
William Smith, UST Class A Operator	william.smith@us.af.mil
William Smith, UST Class B Global Operator	william.smith@us.af.mil

Tank Number	02	**Tank Age**	32	**Tank Installed Date**	06/01/1993	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	350	**Spill Test Date**	03/24/2022	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	03/24/2022	**Catastrophic L.D. Type 3.0**	Auto Dialer	**Piping Type**	U.S. Suction	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	03/24/2022	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	03/24/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Wheatland County in the City of Harlowton

Location: MALMSTROM AFB K 11
US Hwy 12
Harlowton, MT 59036 Wheatland

System Facility ID:54-09095

Facility Code: 29622
Last Inspected On: 03/25/2025
Operating Permit Renewal Date: 07/31/2025

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: 341 CES CEANQ **(406) 731-6188**

Operator Contact: Candace Ellsworth;Curtis Hester;William Smith **(406) 731-6239;(406) 731-7128** **candace.ellsworth@us.af.mil;william.smith@us.af.mil**

Owner/Operator: 341 CES CEANQ (406) 731-6188

Candace Ellsworth, UST Class A Operator	candace.ellsworth@us.af.mil
Candace Ellsworth, UST Class B Global Operator	candace.ellsworth@us.af.mil
Curtis Hester, UST Class A Operator	
Curtis Hester, UST Class B Global Operator	
William Smith, UST Class A Operator	william.smith@us.af.mil
William Smith, UST Class B Global Operator	william.smith@us.af.mil

Tank Number	02	**Tank Age**	32	**Tank Installed Date**	06/01/1993	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	351	**Spill Test Date**	03/24/2022	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	03/24/2022	**Catastrophic L.D. Type 3.0**	Auto Dialer	**Piping Type**	U.S. Suction	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	03/24/2022	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	03/24/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Wheatland County in the City of Harlowton

Location: MALMSTROM AFB K 2
US Hwy 191
Harlowton, MT 59036 Wheatland

System Facility ID:54-09086

Facility Code: 29613
Last Inspected On: 03/26/2025
Operating Permit Renewal Date: 08/21/2025

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: 341 CES CEANQ **(406) 731-6188**

Operator Contact: Candace Ellsworth;Curtis Hester;William Smith **(406) 731-6239;(406) 731-7128** **candace.ellsworth@us.af.mil;william.smith@us.af.mil**

Owner/Operator: 341 CES CEANQ (406) 731-6188

Candace Ellsworth, UST Class A Operator	candace.ellsworth@us.af.mil
Candace Ellsworth, UST Class B Global Operator	candace.ellsworth@us.af.mil
Curtis Hester, UST Class A Operator	
Curtis Hester, UST Class B Global Operator	
William Smith, UST Class A Operator	william.smith@us.af.mil
William Smith, UST Class B Global Operator	william.smith@us.af.mil

Tank Number	02	**Tank Age**	32	**Tank Installed Date**	06/01/1993	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	342	**Spill Test Date**	03/24/2022	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	03/24/2022	**Catastrophic L.D. Type 3.0**	Auto Dialer	**Piping Type**	U.S. Suction	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	03/24/2022	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	03/24/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Wheatland County in the City of Harlowton

Location: MALMSTROM AFB K 3
US Hwy 191
Harlowton, MT 59036 Wheatland

System Facility ID:54-09087

Facility Code: 29614
Last Inspected On: 03/25/2025
Operating Permit Renewal Date: 07/31/2028

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	341 CES CEANQ	**(406) 731-6188**	
Operator Contact:	Candace Ellsworth;Curtis Hester;Shannon Chouinard;Malmstrom A F B;William Smith	**(406) 731-6167;(406) 731-6239;(406) 731-7128**	**candace.ellsworth@us.af.mil;shannon.chouinard@us.af.mil;william.smith@us.af.mil**

Owner/Operator: 341 CES CEANQ (406) 731-6188

Candace Ellsworth, UST Class A Operator	candace.ellsworth@us.af.mil
Candace Ellsworth, UST Class B Global Operator	candace.ellsworth@us.af.mil
Curtis Hester, UST Class A Operator	
Curtis Hester, UST Class B Global Operator	
Shannon Chouinard, UST Class A Operator	shannon.chouinard@us.af.mil
Shannon Chouinard, UST Class B Operator	shannon.chouinard@us.af.mil
William Smith, UST Class A Operator	william.smith@us.af.mil
William Smith, UST Class B Global Operator	william.smith@us.af.mil

Tank Number	02	**Tank Age**	32	**Tank Installed Date**	06/01/1993	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	343	**Spill Test Date**	03/25/2025	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	03/25/2025	**Catastrophic L.D. Type 3.0**	Auto Dialer	**Piping Type**	U.S. Suction	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	03/25/2025	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	03/25/2025			**ATG Type**	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Wheatland County in the City of Harlowton

Location: MALMSTROM AFB K 4
US Hwy 12
Harlowton, MT 59036 Wheatland

System Facility ID:54-09088

Facility Code: 29615
Last Inspected On: 03/24/2025
Operating Permit Renewal Date: 07/31/2028

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	341 CES CEANQ	**(406) 731-6188**	
Operator Contact:	Candace Ellsworth;Curtis Hester;Shannon Chouinard;Malmstrom A F B;William Smith	**(406) 731-6167;(406) 731-6239;(406) 731-7128**	**candace.ellsworth@us.af.mil;shannon.chouinard@us.af.mil;william.smith@us.af.mil**

Owner/Operator: 341 CES CEANQ (406) 731-6188

Candace Ellsworth, UST Class A Operator	candace.ellsworth@us.af.mil
Candace Ellsworth, UST Class B Global Operator	candace.ellsworth@us.af.mil
Curtis Hester, UST Class A Operator	
Curtis Hester, UST Class B Global Operator	
Shannon Chouinard, UST Class A Operator	shannon.chouinard@us.af.mil
Shannon Chouinard, UST Class B Operator	shannon.chouinard@us.af.mil
William Smith, UST Class A Operator	william.smith@us.af.mil
William Smith, UST Class B Global Operator	william.smith@us.af.mil

Tank Number	02	**Tank Age**	32	**Tank Installed Date**	06/01/1993	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	344	**Spill Test Date**	03/24/2025	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	03/24/2025	**Catastrophic L.D. Type 3.0**	Auto Dialer	**Piping Type**	U.S. Suction	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	03/24/2025	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	03/24/2025			**ATG Type**	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Wheatland County in the City of Harlowton

Location: MALMSTROM AFB K 6
US Hwy 12
Harlowton, MT 59036 Wheatland

System Facility ID:54-09090

Facility Code: 29617
Last Inspected On: 03/24/2025
Operating Permit Renewal Date: 07/31/2025

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	341 CES CEANQ	**(406) 731-6188**	
Operator Contact:	Candace Ellsworth;Curtis Hester;Shannon Chouinard;Malmstrom A F B;William Smith	**(406) 731-6167;(406) 731-6239;(406) 731-7128**	**candace.ellsworth@us.af.mil;shannon.chouinard@us.af.mil;william.smith@us.af.mil**

Owner/Operator: 341 CES CEANQ (406) 731-6188

Candace Ellsworth, UST Class A Operator	candace.ellsworth@us.af.mil
Candace Ellsworth, UST Class B Global Operator	candace.ellsworth@us.af.mil
Curtis Hester, UST Class A Operator	
Curtis Hester, UST Class B Global Operator	
Shannon Chouinard, UST Class A Operator	shannon.chouinard@us.af.mil
Shannon Chouinard, UST Class B Operator	shannon.chouinard@us.af.mil
William Smith, UST Class A Operator	william.smith@us.af.mil
William Smith, UST Class B Global Operator	william.smith@us.af.mil

Tank Number	02	**Tank Age**	32	**Tank Installed Date**	06/01/1993	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	346	**Spill Test Date**	03/24/2025	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	03/24/2025	**Catastrophic L.D. Type 3.0**	Auto Dialer	**Piping Type**	U.S. Suction	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	03/24/2025	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	03/24/2025			**ATG Type**	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Wheatland County in the City of Harlowton

Location: MALMSTROM AFB K 8
US Hwy 191
Harlowton, MT 59036 Wheatland

System Facility ID:54-09092

Facility Code: 29619
Last Inspected On: 03/24/2025
Operating Permit Renewal Date: 07/31/2025

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: 341 CES CEANQ **(406) 731-6188**

Operator Contact: Candace Ellsworth;Curtis Hester;William Smith **(406) 731-6239;(406) 731-7128** **candace.ellsworth@us.af.mil;william.smith@us.af.mil**

Owner/Operator: 341 CES CEANQ (406) 731-6188

Candace Ellsworth, UST Class A Operator	candace.ellsworth@us.af.mil
Candace Ellsworth, UST Class B Global Operator	candace.ellsworth@us.af.mil
Curtis Hester, UST Class A Operator	
Curtis Hester, UST Class B Global Operator	
William Smith, UST Class A Operator	william.smith@us.af.mil
William Smith, UST Class B Global Operator	william.smith@us.af.mil

Tank Number	02	**Tank Age**	32	**Tank Installed Date**	06/01/1993	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	348	**Spill Test Date**	03/25/2022	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	03/25/2022	**Catastrophic L.D. Type 3.0**	Auto Dialer	**Piping Type**	U.S. Suction	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	03/25/2022	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	03/25/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Wheatland County in the City of Harlowton

Location: MALMSTROM AFB K 9
US Hwy 12
Harlowton, MT 59036 Wheatland

System Facility ID:54-09093

Facility Code: 29620
Last Inspected On: 03/25/2025
Operating Permit Renewal Date: 07/31/2025

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: 341 CES CEANQ **(406) 731-6188**

Operator Contact: Candace Ellsworth;Curtis Hester;William Smith **(406) 731-6239;(406) 731-7128** **candace.ellsworth@us.af.mil;william.smith@us.af.mil**

Owner/Operator: 341 CES CEANQ (406) 731-6188

Candace Ellsworth, UST Class A Operator	candace.ellsworth@us.af.mil
Candace Ellsworth, UST Class B Global Operator	candace.ellsworth@us.af.mil
Curtis Hester, UST Class A Operator	
Curtis Hester, UST Class B Global Operator	
William Smith, UST Class A Operator	william.smith@us.af.mil
William Smith, UST Class B Global Operator	william.smith@us.af.mil

Tank Number	02	**Tank Age**	32	**Tank Installed Date**	06/01/1993	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	349	**Spill Test Date**	03/24/2022	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	03/24/2022	**Catastrophic L.D. Type 3.0**	Auto Dialer	**Piping Type**	U.S. Suction	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	03/24/2022	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	03/24/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Wheatland County in the City of Harlowton

Location: OASIS BEVERAGE
1504 US Hwy 12 E
Harlowton, MT 59036 Wheatland

System Facility ID:54-11975

Facility Code: 29636
Last Inspected On: 11/16/2023
Operating Permit Renewal Date: 02/24/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Oasis Beverage, LLC	**(561) 693-8795**	**tracy@rayoasis.com**
Operator Contact:	Anita Leach		**raysport@mtintouch.net**

Owner/Operator:	Oasis Beverage, LLC	(561) 693-8795	tracy@rayoasis.com
	Anita Leach, UST Class A Operator		raysport@mtintouch.net
	Anita Leach, UST Class A Operator		raysport@mtintouch.net
	Anita Leach, UST Class B Operator		raysport@mtintouch.net
	Anita Leach, UST Class B Operator		raysport@mtintouch.net

Tank Number	01	**Tank Age**	41	**Tank Installed Date**	05/01/1984	**Tank Material Construction**	Bare Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	2362	**Spill Test Date**	11/16/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Diesel	**PLLD Test Date**	04/06/2023	**Tank/Piping CP Test Date**	04/28/2022	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	04/06/2023	**Line Tightness Test Date**	05/31/2020	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	04/06/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	02	**Tank Age**	41	**Tank Installed Date**	05/01/1984	**Tank Material Construction**	Bare Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	2363	**Spill Test Date**	11/16/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**	04/06/2023	**Tank/Piping CP Test Date**	04/28/2022	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	04/06/2023	**Line Tightness Test Date**	07/04/2020	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	04/06/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Tank Number	03	**Tank Age**	41	**Tank Installed Date**	01/01/1984	**Tank Material Construction**	Bare Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	2364	**Spill Test Date**	11/16/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**	04/06/2023	**Tank/Piping CP Test Date**	04/28/2022	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	04/06/2023	**Line Tightness Test Date**	05/29/2020	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	04/06/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Wheatland County in the City of Judith Gap

Location: JUDITH GAP OIL
302 High St
Judith Gap, MT 59453-7703 Wheatland

System Facility ID:54-07616

Facility Code: 29605
Last Inspected On: 01/31/2025
Operating Permit Renewal Date: 05/08/2028

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	David Miller	**(406) 632-4891**	**jgo@mtintouch.net**
Operator Contact:	Jeffery Miller		**jgo@mtitouch.net**

Owner/Operator:	David Miller	(406) 632-4891	jgo@mtintouch.net
	Jeffery Miller, UST Class A Operator		jgo@mtitouch.net
	Jeffery Miller, UST Class A Operator		jgo@mtitouch.net
	Kim Miller, UST Class B Operator		jgo@mtitouch.net

Tank Number	07	**Tank Age**	19	**Tank Installed Date**	10/02/2006	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	5089	**Spill Test Date**	01/31/2025	**Piping Installed Date**	08/23/2006	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	05/22/2024	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	05/22/2024	**Line Tightness Test Date**	07/17/2021	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	05/22/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	08	**Tank Age**	19	**Tank Installed Date**	10/02/2006	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	5090	**Spill Test Date**	01/31/2025	**Piping Installed Date**	08/23/2006	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	05/22/2024	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	5000	**ATG Test Date**	05/22/2024	**Line Tightness Test Date**	07/16/2021	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	05/22/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Tank Number	09	**Tank Age**	19	**Tank Installed Date**	10/02/2006	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	5091	**Spill Test Date**	01/31/2025	**Piping Installed Date**	08/23/2006	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	05/22/2024	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	05/22/2024	**Line Tightness Test Date**	07/17/2021	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	05/22/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	10	**Tank Age**	19	**Tank Installed Date**	10/02/2006	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	5092	**Spill Test Date**	01/31/2025	**Piping Installed Date**	08/23/2006	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	05/22/2024	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	5000	**ATG Test Date**	05/22/2024	**Line Tightness Test Date**	07/23/2021	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	05/22/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	11	**Tank Age**	19	**Tank Installed Date**	10/02/2006	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	5093	**Spill Test Date**	01/31/2025	**Piping Installed Date**	08/23/2006	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	05/22/2024	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	05/22/2024	**Line Tightness Test Date**	07/15/2021	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	05/22/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	12	**Tank Age**	19	**Tank Installed Date**	10/02/2006	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	5094	**Spill Test Date**	01/31/2025	**Piping Installed Date**	08/23/2006	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible

Product	Diesel	**PLLD Test Date**	05/22/2024	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	5000	**ATG Test Date**	05/22/2024	**Line Tightness Test Date**	07/21/2021	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	05/22/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Wheatland County in the City of Judith Gap

Location: MALMSTROM AFB L 1
US Hwy 191
Judith Gap, MT 59453 Wheatland

System Facility ID:14-09096

Facility Code: 20331
Last Inspected On: 03/27/2025
Operating Permit Renewal Date: 07/31/2028

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: 341 CES CEANQ **(406) 731-6188**

Operator Contact: Candace Ellsworth;Curtis Hester;William Smith **(406) 731-6239;(406) 731-7128** **candace.ellsworth@us.af.mil;william.smith@us.af.mil**

Owner/Operator: 341 CES CEANQ (406) 731-6188

Candace Ellsworth, UST Class A Operator	candace.ellsworth@us.af.mil
Candace Ellsworth, UST Class B Global Operator	candace.ellsworth@us.af.mil
Curtis Hester, UST Class A Operator	
Curtis Hester, UST Class B Global Operator	
William Smith, UST Class A Operator	william.smith@us.af.mil
William Smith, UST Class B Global Operator	william.smith@us.af.mil

Tank Number	01	**Tank Age**	63	**Tank Installed Date**	05/02/1962	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	186	**Spill Test Date**	03/27/2025	**Piping Installed Date**		**Tank Construction**	Lined Interior/Impressed Current	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	03/27/2025	**Catastrophic L.D. Type 3.0**	Auto Dialer	**Piping Type**	U.S. Suction	**CP Met Types**	Impressed Current
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	01/07/2021	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	03/27/2025	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	03/27/2025			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				

Facility Summary in Wheatland County in the City of Judith Gap

Location: MALMSTROM AFB L 3
Road 297
Judith Gap, MT 59453 Wheatland

System Facility ID:54-09098

Facility Code: 29623
Last Inspected On: 03/27/2025
Operating Permit Renewal Date: 08/07/2025

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: 341 CES CEANQ **(406) 731-6188**

Operator Contact: Candace Ellsworth;Curtis Hester;William Smith **(406) 731-6239;(406) 731-7128** **candace.ellsworth@us.af.mil;william.smith@us.af.mil**

Owner/Operator: 341 CES CEANQ (406) 731-6188

Candace Ellsworth, UST Class A Operator	candace.ellsworth@us.af.mil
Candace Ellsworth, UST Class B Global Operator	candace.ellsworth@us.af.mil
Curtis Hester, UST Class A Operator	
Curtis Hester, UST Class B Global Operator	
William Smith, UST Class A Operator	william.smith@us.af.mil
William Smith, UST Class B Global Operator	william.smith@us.af.mil

Tank Number	02	**Tank Age**	32	**Tank Installed Date**	06/01/1993	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	352	**Spill Test Date**	03/23/2022	**Piping Installed Date**	11/16/2016	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	03/23/2022	**Catastrophic L.D. Type 3.0**	Auto Dialer	**Piping Type**	U.S. Suction	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	03/23/2022	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	03/23/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Wheatland County in the City of Judith Gap

Location: MALMSTROM AFB L 4
Road 297
Judith Gap, MT 59453 Wheatland

System Facility ID:54-09099

Facility Code: 29624
Last Inspected On: 03/26/2025
Operating Permit Renewal Date: 08/07/2025

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: 341 CES CEANQ **(406) 731-6188**

Operator Contact: Candace Ellsworth;Curtis Hester;William Smith **(406) 731-6239;(406) 731-7128** **candace.ellsworth@us.af.mil;william.smith@us.af.mil**

Owner/Operator: 341 CES CEANQ (406) 731-6188

Candace Ellsworth, UST Class A Operator	candace.ellsworth@us.af.mil
Candace Ellsworth, UST Class B Global Operator	candace.ellsworth@us.af.mil
Curtis Hester, UST Class A Operator	
Curtis Hester, UST Class B Global Operator	
William Smith, UST Class A Operator	william.smith@us.af.mil
William Smith, UST Class B Global Operator	william.smith@us.af.mil

Tank Number	02	**Tank Age**	32	**Tank Installed Date**	06/10/1993	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	353	**Spill Test Date**	03/23/2022	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	03/23/2022	**Catastrophic L.D. Type 3.0**	Auto Dialer	**Piping Type**	U.S. Suction	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	03/23/2022	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	03/23/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Wheatland County in the City of Judith Gap

Location: MALMSTROM AFB L 5
Road 297
Judith Gap, MT 59453 Wheatland

System Facility ID:54-09100

Facility Code: 29625
Last Inspected On: 03/26/2025
Operating Permit Renewal Date: 08/07/2025

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: 341 CES CEANQ **(406) 731-6188**

Operator Contact: Candace Ellsworth;Curtis Hester;William Smith **(406) 731-6239;(406) 731-7128** **candace.ellsworth@us.af.mil;william.smith@us.af.mil**

Owner/Operator: 341 CES CEANQ (406) 731-6188

Candace Ellsworth, UST Class A Operator	candace.ellsworth@us.af.mil
Candace Ellsworth, UST Class B Global Operator	candace.ellsworth@us.af.mil
Curtis Hester, UST Class A Operator	
Curtis Hester, UST Class B Global Operator	
William Smith, UST Class A Operator	william.smith@us.af.mil
William Smith, UST Class B Global Operator	william.smith@us.af.mil

Tank Number	02	**Tank Age**	32	**Tank Installed Date**	06/01/1993	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	354	**Spill Test Date**	03/23/2022	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	03/23/2022	**Catastrophic L.D. Type 3.0**	Auto Dialer	**Piping Type**	U.S. Suction	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	03/23/2022	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	03/23/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Wheatland County in the City of Judith Gap

Location: MALMSTROM AFB L 6
Road 297
Judith Gap, MT 59453 Wheatland

System Facility ID:54-09101

Facility Code: 29626
Last Inspected On: 03/26/2025
Operating Permit Renewal Date: 08/07/2025

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: 341 CES CEANQ **(406) 731-6188**

Operator Contact: Candace Ellsworth;Curtis Hester;William Smith **(406) 731-6239;(406) 731-7128** **candace.ellsworth@us.af.mil;william.smith@us.af.mil**

Owner/Operator: 341 CES CEANQ (406) 731-6188

Candace Ellsworth, UST Class A Operator	candace.ellsworth@us.af.mil
Candace Ellsworth, UST Class B Global Operator	candace.ellsworth@us.af.mil
Curtis Hester, UST Class A Operator	
Curtis Hester, UST Class B Global Operator	
William Smith, UST Class A Operator	william.smith@us.af.mil
William Smith, UST Class B Global Operator	william.smith@us.af.mil

Tank Number	02	**Tank Age**	35	**Tank Installed Date**	03/26/1990	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	355	**Spill Test Date**	03/23/2022	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	03/23/2022	**Catastrophic L.D. Type 3.0**	Auto Dialer	**Piping Type**	U.S. Suction	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	03/23/2022	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	03/23/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Wheatland County in the City of Judith Gap

Location: MALMSTROM AFB L 7
US Hwy 191
Judith Gap, MT 59453 Wheatland

System Facility ID:54-09102

Facility Code: 29627
Last Inspected On: 03/26/2025
Operating Permit Renewal Date: 08/07/2025

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: 341 CES CEANQ **(406) 731-6188**

Operator Contact: Candace Ellsworth;Curtis Hester;William Smith **(406) 731-6239;(406) 731-7128** **candace.ellsworth@us.af.mil;william.smith@us.af.mil**

Owner/Operator: 341 CES CEANQ (406) 731-6188

Candace Ellsworth, UST Class A Operator	candace.ellsworth@us.af.mil
Candace Ellsworth, UST Class B Global Operator	candace.ellsworth@us.af.mil
Curtis Hester, UST Class A Operator	
Curtis Hester, UST Class B Global Operator	
William Smith, UST Class A Operator	william.smith@us.af.mil
William Smith, UST Class B Global Operator	william.smith@us.af.mil

Tank Number	02	**Tank Age**	32	**Tank Installed Date**	05/01/1993	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	356	**Spill Test Date**	03/24/2022	**Piping Installed Date**	11/16/2016	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	03/24/2022	**Catastrophic L.D. Type 3.0**	Auto Dialer	**Piping Type**	U.S. Suction	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	03/24/2022	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	03/24/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Wheatland County in the City of Judith Gap

Location: MALMSTROM AFB L 8
US Hwy 191
Judith Gap, MT 59453 Wheatland

System Facility ID:54-09103

Facility Code: 29628
Last Inspected On: 03/27/2025
Operating Permit Renewal Date: 08/07/2025

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: 341 CES CEANQ **(406) 731-6188**

Operator Contact: Candace Ellsworth;Curtis Hester;William Smith **(406) 731-6239;(406) 731-7128** **candace.ellsworth@us.af.mil;william.smith@us.af.mil**

Owner/Operator: 341 CES CEANQ (406) 731-6188

Candace Ellsworth, UST Class A Operator	candace.ellsworth@us.af.mil
Candace Ellsworth, UST Class B Global Operator	candace.ellsworth@us.af.mil
Curtis Hester, UST Class A Operator	
Curtis Hester, UST Class B Global Operator	
William Smith, UST Class A Operator	william.smith@us.af.mil
William Smith, UST Class B Global Operator	william.smith@us.af.mil

Tank Number	02	**Tank Age**	32	**Tank Installed Date**	05/01/1993	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	357	**Spill Test Date**	03/23/2022	**Piping Installed Date**	01/04/2016	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	03/23/2022	**Catastrophic L.D. Type 3.0**	Auto Dialer	**Piping Type**	U.S. Suction	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	03/23/2022	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	03/23/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Wheatland County in the City of Shawmut

Location: MALMSTROM AFB K 5
US Hwy 12
Shawmut, MT 59078 Wheatland

System Facility ID:54-09089

Facility Code: 29616
Last Inspected On: 03/24/2025
Operating Permit Renewal Date: 07/31/2028

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	341 CES CEANQ	**(406) 731-6188**	
Operator Contact:	Candace Ellsworth;Curtis Hester;Shannon Chouinard;Malmstrom A F B;William Smith	**(406) 731-6167;(406) 731-6239;(406) 731-7128**	**candace.ellsworth@us.af.mil;shannon.chouinard@us.af.mil;william.smith@us.af.mil**

Owner/Operator: 341 CES CEANQ (406) 731-6188

Candace Ellsworth, UST Class A Operator	candace.ellsworth@us.af.mil
Candace Ellsworth, UST Class B Global Operator	candace.ellsworth@us.af.mil
Curtis Hester, UST Class A Operator	
Curtis Hester, UST Class B Global Operator	
Shannon Chouinard, UST Class A Operator	shannon.chouinard@us.af.mil
Shannon Chouinard, UST Class B Operator	shannon.chouinard@us.af.mil
William Smith, UST Class A Operator	william.smith@us.af.mil
William Smith, UST Class B Global Operator	william.smith@us.af.mil

Tank Number	02	**Tank Age**	32	**Tank Installed Date**	06/09/1993	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	345	**Spill Test Date**	03/24/2025	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	03/24/2025	**Catastrophic L.D. Type 3.0**	Auto Dialer	**Piping Type**	U.S. Suction	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	03/24/2025	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	03/24/2025			**ATG Type**	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Wheatland County in the City of Shawmut

Location: MALMSTROM AFB K 7
US Hwy 12
Shawmut, MT 59078 Wheatland

System Facility ID:54-09091

Facility Code: 29618
Last Inspected On: 03/24/2025
Operating Permit Renewal Date: 07/31/2025

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	341 CES CEANQ	**(406) 731-6188**	
Operator Contact:	Candace Ellsworth;Curtis Hester;Shannon Chouinard;Malmstrom A F B;William Smith	**(406) 731-6167;(406) 731-6239;(406) 731-7128**	**candace.ellsworth@us.af.mil;shannon.chouinard@us.af.mil;william.smith@us.af.mil**

Owner/Operator: 341 CES CEANQ (406) 731-6188

Candace Ellsworth, UST Class A Operator	candace.ellsworth@us.af.mil
Candace Ellsworth, UST Class B Global Operator	candace.ellsworth@us.af.mil
Curtis Hester, UST Class A Operator	
Curtis Hester, UST Class B Global Operator	
Shannon Chouinard, UST Class A Operator	shannon.chouinard@us.af.mil
William Smith, UST Class A Operator	william.smith@us.af.mil
William Smith, UST Class B Global Operator	william.smith@us.af.mil

Tank Number	02	**Tank Age**	32	**Tank Installed Date**	06/01/1993	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	347	**Spill Test Date**	03/25/2022	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	03/25/2022	**Catastrophic L.D. Type 3.0**	Auto Dialer	**Piping Type**	U.S. Suction	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	03/25/2022	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	03/25/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Wibaux County in the City of Wibaux

Location: FIRST and LAST CHANCE 406, LLC
107 2nd Ave NE
Wibaux, MT 59353 Wibaux

System Facility ID:55-13559

Facility Code: 29677
Last Inspected On: 01/16/2023
Operating Permit Renewal Date: 05/22/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	First & Last Chance 406, LLC	**(406) 939-2547**	**clairesangha@gmail.com**
Operator Contact:	Tsering Sangha;First & Last Chance 406, LLC	**(406) 939-2547**	**clairesangha@gmail.com;clairesangha@gmail.com**

Owner/Operator: First & Last Chance 406, LLC (406) 939-2547 clairesangha@gmail.com

Tsering Sangha, UST Class A Operator clairesangha@gmail.com

Tsering Sangha, UST Class B Operator clairesangha@gmail.com

Tank Number	01	**Tank Age**	31	**Tank Installed Date**	11/01/1994	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	3258	**Spill Test Date**	12/06/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	12/06/2022	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**	12/06/2022	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	12/06/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-300				
Tank Number	02	**Tank Age**	31	**Tank Installed Date**	01/01/1994	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	3259	**Spill Test Date**	12/06/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	12/06/2022	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	12/06/2022	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	12/06/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-300				
Tank Number	03	**Tank Age**	31	**Tank Installed Date**	01/01/1994	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	3260	**Spill Test Date**	12/06/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No

Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	12/06/2022	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**	12/06/2022	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	12/06/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-300				
Tank Number	04	**Tank Age**	31	**Tank Installed Date**	01/01/1994	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	3261	**Spill Test Date**	12/06/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Galvanic
Product	Diesel, Dyed	**PLLD Test Date**		**Tank/Piping CP Test Date**	12/06/2022	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	12/06/2022	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	12/06/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-300				

Facility Summary in Wibaux County in the City of Wibaux

Location: WIBAUX COOP OIL CO
203 2nd Ave NW
Wibaux, MT 59353 Wibaux

System Facility ID:55-03348

Facility Code: 29656
Last Inspected On: 07/19/2022
Operating Permit Renewal Date: 10/23/2025

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Wibaux Coop Oil Co **(406) 795-2219**

Operator Contact: Donald Lauf **(406) 795-2219** **wibauxcoop@midrivers.com**

Owner/Operator: Wibaux Coop Oil Co (406) 795-2219

Donald Lauf, UST Class A Operator	wibauxcoop@midrivers.com
Donald Lauf, UST Class A Operator	wibauxcoop@midrivers.com
Donald Lauf, UST Class B Operator	wibauxcoop@midrivers.com
Donald Lauf, UST Class B Operator	wibauxcoop@midrivers.com

Tank Number	07	**Tank Age**	30	**Tank Installed Date**	06/01/1995	**Tank Material Construction**	Steel Clad	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	2267	**Spill Test Date**	07/19/2022	**Piping Installed Date**	11/09/2013	**Tank Construction**	Double-Walled	**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	06/11/2013	**Primary Tank Leak Detection**	Manual Interstitial Monitoring	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	5000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	07/19/2022			**ATG Type**					
Tank Number	08	**Tank Age**	30	**Tank Installed Date**	06/01/1995	**Tank Material Construction**	Steel Clad	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	2268	**Spill Test Date**	07/19/2022	**Piping Installed Date**	11/09/2013	**Tank Construction**	Double-Walled	**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	06/11/2013	**Primary Tank Leak Detection**	Manual Interstitial Monitoring	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	07/19/2022			**ATG Type**					
Tank Number	09	**Tank Age**	30	**Tank Installed Date**	06/01/1995	**Tank Material Construction**	Steel Clad	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve

Tag Number	2269	**Spill Test Date**	07/19/2022	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	06/11/2013	**Primary Tank Leak Detection**	Manual Interstitial Monitoring	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	07/19/2022			**ATG Type**					
Tank Number	10	**Tank Age**	30	**Tank Installed Date**	06/01/1995	**Tank Material Construction**	Steel Clad	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	2270	**Spill Test Date**	07/19/2022	**Piping Installed Date**	11/09/2013	**Tank Construction**	Double-Walled	**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	06/11/2013	**Primary Tank Leak Detection**	Manual Interstitial Monitoring	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	07/19/2022			**ATG Type**					
Tank Number	11	**Tank Age**	30	**Tank Installed Date**	06/01/1995	**Tank Material Construction**	Steel Clad	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	2271	**Spill Test Date**	07/19/2022	**Piping Installed Date**	11/09/2013	**Tank Construction**	Double-Walled	**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Galvanic
Product	Diesel, Dyed	**PLLD Test Date**		**Tank/Piping CP Test Date**	06/11/2013	**Primary Tank Leak Detection**	Manual Interstitial Monitoring	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	07/19/2022			**ATG Type**					

Facility Summary in Wibaux County in the City of Wibaux

Location: WIBAUX COUNTY UST
225 2nd Ave NW
Wibaux, MT 59353-0086 Wibaux

System Facility ID:55-02446

Facility Code: 29654
Last Inspected On: 07/19/2022
Operating Permit Renewal Date: 10/15/2025

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Wibaux County Shop

Operator Contact: Kim Bacon **(406) 796-2943**

Kim Bacon, UST Class A Operator
Kim Bacon, UST Class A Operator
Kim Bacon, UST Class B Operator
Kim Bacon, UST Class B Operator

Tank Number	04	**Tank Age**	30	**Tank Installed Date**	06/01/1995	**Tank Material Construction**	Steel Clad	**Piping Material**	Steel	**Overfill Types**	Flapper Valve
Tag Number	2272	**Spill Test Date**	07/19/2022	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	None	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	07/19/2022	**Primary Tank Leak Detection**	Manual Interstitial Monitoring	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	07/19/2022			**ATG Type**					
Tank Number	05	**Tank Age**	30	**Tank Installed Date**	06/01/1995	**Tank Material Construction**	Steel Clad	**Piping Material**	Steel	**Overfill Types**	Flapper Valve
Tag Number	2273	**Spill Test Date**	07/19/2022	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	None	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	07/19/2022	**Primary Tank Leak Detection**	Manual Interstitial Monitoring	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	07/19/2022			**ATG Type**					
Tank Number	06	**Tank Age**	30	**Tank Installed Date**	06/01/1995	**Tank Material Construction**	Steel Clad	**Piping Material**	Steel	**Overfill Types**	

Tag Number	2274	**Spill Test Date**	07/19/2022	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	None	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Galvanic
Product	Oil, Waste	**PLLD Test Date**		**Tank/Piping CP Test Date**	07/19/2022	**Primary Tank Leak Detection**	Manual Interstitial Monitoring	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	1000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					

Facility Summary in Yellowstone County in the City of Ballantine

Location: TIGER TOWN
2253 S 16th Rd
Ballantine, MT 59006 Yellowstone

System Facility ID:56-06325

Facility Code: 30099
Last Inspected On: 03/30/2023
Operating Permit Renewal Date: 07/10/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Carol Hayes	**(406) 967-2753**	**tigertownpatti@hotmail.com**
Operator Contact:	Carol Hayes	**(406) 967-2753**	**tigertownpatti@hotmail.com**

Owner/Operator: Carol Hayes (406) 967-2753 tigertownpatti@hotmail.com

Carol Hayes, UST Class A Operator tigertownpatti@hotmail.com
Carol Hayes, UST Class A Operator tigertownpatti@hotmail.com
Patti Anderson, UST Class B Operator tigertownpatti@hotmail.com
Patti Anderson, UST Class B Operator tigertownpatti@hotmail.com

Tank Number	10	**Tank Age**	33	**Tank Installed Date**	11/01/1992	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	3310	**Spill Test Date**	03/30/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	03/30/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	3000	**ATG Test Date**	03/30/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	03/30/2023			**ATG Type**	Incon/TS-1001				
Tank Number	11	**Tank Age**	33	**Tank Installed Date**	11/01/1992	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	3311	**Spill Test Date**	03/30/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	03/30/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	03/30/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	03/30/2023			**ATG Type**	Incon/TS-1001				
Tank Number	12	**Tank Age**	33	**Tank Installed Date**	11/01/1992	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve

Tag Number	3312	**Spill Test Date**	03/30/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	03/30/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	5000	**ATG Test Date**	03/30/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	03/30/2023			**ATG Type**	Incon/TS-1001				

Facility Summary in Yellowstone County in the City of Billings

Location: 3 GS CONVENIENCE CENTER E WICKS LANE
1221 Wicks Ln
Billings, MT 59105-4417 Yellowstone

System Facility ID:56-04957

Facility Code: 29954
Last Inspected On: 04/19/2023
Operating Permit Renewal Date: 09/12/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	SNG Inc 3		**office@3gsstores.com**
Operator Contact:	Bergundi Grosulak;Daniel Grosulak;John Grosulak;Kelly Groslack;Larry Groslack	**(406) 245-0161;(406) 670-2563;(406) 690-2993;(406) 850-8456**	**dan@3gsstores.com;johngrosulak@yahoo.com;office@3gsstores.com**

Owner/Operator: SNG Inc 3 office@3gsstores.com

Bergundi Grosulak, UST Class A Operator	office@3gsstores.com
Bergundi Grosulak, UST Class B Operator	office@3gsstores.com
Daniel Grosulak, UST Class A Operator	dan@3gsstores.com
Daniel Grosulak, UST Class B Operator	dan@3gsstores.com
John Grosulak, UST Class A Operator	johngrosulak@yahoo.com
John Grosulak, UST Class B Operator	johngrosulak@yahoo.com
Kelly Groslack, UST Class A Operator	
Kelly Groslack, UST Class B Operator	
Larry Groslack, UST Class A Operator	
Larry Groslack, UST Class B Operator	

Tank Number	03	**Tank Age**	11	**Tank Installed Date**	09/14/2014	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	5532	**Spill Test Date**		**Piping Installed Date**	12/17/2014	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	12/17/2014	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**		**Line Tightness Test Date**	12/17/2014	**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date				**ATG Type**	Incon/TS-550 EVO				
Tank Number	04	**Tank Age**	11	**Tank Installed Date**	09/14/2014	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	5533	**Spill Test Date**		**Piping Installed Date**	12/17/2014	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	12/17/2014	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible

Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**		**Line Tightness Test Date**	12/17/2014	**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date				**ATG Type**	Incon/TS-550 EVO				
Tank Number	05	**Tank Age**	11	**Tank Installed Date**	09/14/2014	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	5534	**Spill Test Date**		**Piping Installed Date**	12/17/2014	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	12/17/2014	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**		**Line Tightness Test Date**	12/17/2014	**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date				**ATG Type**	Incon/TS-550 EVO				

Facility Summary in Yellowstone County in the City of Billings

Location: 3 GS CONVENIENCE CENTER STATE AVE
4410 State Ave
Billings, MT 59101-5060 Yellowstone

System Facility ID:56-04946

Facility Code: 29946
Last Inspected On: 08/16/2022
Operating Permit Renewal Date: 11/05/2025

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	SNG Inc 3		**office@3gsstores.com**
Operator Contact:	Bergundi Grosulak;Daniel Grosulak;John Grosulak;Kelly Groslack;Larry Groslack	**(406) 245-0161;(406) 670-2563;(406) 690-2993;(406) 850-8456**	**dan@3gsstores.com;johngrosulak@yahoo.com;office@3gsstores.com**

Owner/Operator: SNG Inc 3 office@3gsstores.com

Bergundi Grosulak, UST Class A Operator	office@3gsstores.com
Bergundi Grosulak, UST Class B Operator	office@3gsstores.com
Daniel Grosulak, UST Class A Operator	dan@3gsstores.com
Daniel Grosulak, UST Class B Operator	dan@3gsstores.com
John Grosulak, UST Class A Operator	johngrosulak@yahoo.com
John Grosulak, UST Class B Operator	johngrosulak@yahoo.com
Kelly Groslack, UST Class A Operator	
Kelly Groslack, UST Class B Operator	
Larry Groslack, UST Class A Operator	
Larry Groslack, UST Class B Operator	

Tank Number	03	**Tank Age**	12	**Tank Installed Date**	04/01/2013	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	5400	**Spill Test Date**	08/16/2022	**Piping Installed Date**	10/24/2012	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	08/16/2022	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	08/16/2022	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	08/16/2022	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	08/16/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-450				
Tank Number	04	**Tank Age**	12	**Tank Installed Date**	04/01/2013	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	5401	**Spill Test Date**	08/16/2022	**Piping Installed Date**	10/24/2012	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	08/16/2022	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible

Product	Gasoline	**PLLD Test Date**	08/16/2022	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	08/16/2022	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	08/16/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-450				
Tank Number	05	**Tank Age**	12	**Tank Installed Date**	04/01/2013	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	5402	**Spill Test Date**	08/16/2022	**Piping Installed Date**	10/24/2012	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	08/16/2022	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	08/16/2022	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	08/16/2022	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	08/16/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-450				

Facility Summary in Yellowstone County in the City of Billings

Location: 3 Gs CONVENIENCE STORE #5
4106 State Ave
Billings, MT 59101-3550 Yellowstone

System Facility ID:56-05748

Facility Code: 30055
Last Inspected On: 08/03/2023
Operating Permit Renewal Date: 08/03/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	G & L Properties LLC	**(406) 670-0085**	**larry@3gsstores.com;office @3gsstores.com**
Operator Contact:	Bergundi Grosulak;Daniel Grosulak;John Grosulak;Kelly Groslack;Larry Groslack	**(406) 245-0161;(406) 670-2563;(406) 690-2993;(406) 850-8456**	**dan@3gsstores.com;johngrosulak@yahoo.com;office@3gsstores.com**

Owner/Operator: G & L Properties LLC	(406) 670-0085	larry@3gsstores.com;office @3gsstores.com
Bergundi Grosulak, UST Class A Operator		office@3gsstores.com
Bergundi Grosulak, UST Class A Operator		office@3gsstores.com
Bergundi Grosulak, UST Class B Operator		office@3gsstores.com
Bergundi Grosulak, UST Class B Operator		office@3gsstores.com
Daniel Grosulak, UST Class A Operator		dan@3gsstores.com
Daniel Grosulak, UST Class A Operator		dan@3gsstores.com
Daniel Grosulak, UST Class B Operator		dan@3gsstores.com
Daniel Grosulak, UST Class B Operator		dan@3gsstores.com
John Grosulak, UST Class A Operator		johngrosulak@yahoo.com
John Grosulak, UST Class A Operator		johngrosulak@yahoo.com
John Grosulak, UST Class B Operator		johngrosulak@yahoo.com
John Grosulak, UST Class B Operator		johngrosulak@yahoo.com
Kelly Groslack, UST Class A Operator		
Kelly Groslack, UST Class A Operator		
Kelly Groslack, UST Class B Operator		
Kelly Groslack, UST Class B Operator		
Larry Groslack, UST Class A Operator		
Larry Groslack, UST Class B Operator		

Tank Number	03	**Tank Age**	23	**Tank Installed Date**	08/23/2002	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	4714	**Spill Test Date**	08/03/2023	**Piping Installed Date**	05/13/2016	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	08/03/2023	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**	08/03/2023	**Tank/Piping CP Test Date**	08/03/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No

Capacity	9000	**ATG Test Date**	08/03/2023	**Line Tightness Test Date**	11/11/2020	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date	08/03/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	04	**Tank Age**	23	**Tank Installed Date**	08/23/2002	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	4715	**Spill Test Date**	08/03/2023	**Piping Installed Date**	05/13/2016	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	08/03/2023	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**	08/03/2023	**Tank/Piping CP Test Date**	08/03/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	3000	**ATG Test Date**	08/03/2023	**Line Tightness Test Date**	11/11/2020	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date	08/03/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Yellowstone County in the City of Billings

Location: 3 GS CONVENIENCE STORE #6
1425 US Hwy 87 E
Billings, MT 59101-6657 Yellowstone

System Facility ID:56-05086

Facility Code: 30004
Last Inspected On: 05/19/2023
Operating Permit Renewal Date: 11/07/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	G & L Properties LLC;Kelly Grosulak	**(406) 670-0085**	**larry@3gsstores.com;office @3gsstores.com**
Operator Contact:	Bergundi Grosulak;Daniel Grosulak;John Grosulak;Kelly Groslack;Larry Groslack	**(406) 245-0161;(406) 670-2563;(406) 690-2993;(406) 850-8456**	**dan@3gsstores.com;johngrosulak@yahoo.com;office@3gsstores.com**
Owner/Operator:	G & L Properties LLC	(406) 670-0085	larry@3gsstores.com;office @3gsstores.com
Owner/Operator:	Kelly Grosulak	(406) 670-0085	larry@3gsstores.com;office @3gsstores.com
	Bergundi Grosulak, UST Class A Operator		office@3gsstores.com
	Bergundi Grosulak, UST Class A Operator		office@3gsstores.com
	Bergundi Grosulak, UST Class B Operator		office@3gsstores.com
	Bergundi Grosulak, UST Class B Operator		office@3gsstores.com
	Daniel Grosulak, UST Class A Operator		dan@3gsstores.com
	Daniel Grosulak, UST Class A Operator		dan@3gsstores.com
	Daniel Grosulak, UST Class B Operator		dan@3gsstores.com
	Daniel Grosulak, UST Class B Operator		dan@3gsstores.com
	John Grosulak, UST Class A Operator		johngrosulak@yahoo.com
	John Grosulak, UST Class A Operator		johngrosulak@yahoo.com
	John Grosulak, UST Class B Operator		johngrosulak@yahoo.com
	John Grosulak, UST Class B Operator		johngrosulak@yahoo.com
	Kelly Groslack, UST Class A Operator		
	Kelly Groslack, UST Class A Operator		
	Kelly Groslack, UST Class B Operator		
	Kelly Groslack, UST Class B Operator		
	Larry Groslack, UST Class A Operator		
	Larry Groslack, UST Class B Operator		

Tank Number	04	**Tank Age**	8	**Tank Installed Date**	05/09/2017	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	5679	**Spill Test Date**	05/19/2023	**Piping Installed Date**	05/09/2017	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	01/07/2022	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible

Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	05/19/2023	**Line Tightness Test Date**	05/26/2020	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.1;ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	05/19/2023			**ATG Type**	Incon/TS-550 EVO				
Tank Number	05	**Tank Age**	8	**Tank Installed Date**	05/09/2017	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	5680	**Spill Test Date**	05/29/2023	**Piping Installed Date**	05/09/2017	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	01/07/2022	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	05/29/2023	**Line Tightness Test Date**	03/13/2020	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	05/29/2023			**ATG Type**	Incon/TS-550 EVO				
Tank Number	06	**Tank Age**	8	**Tank Installed Date**	05/09/2017	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	5681	**Spill Test Date**	05/29/2023	**Piping Installed Date**	05/09/2017	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	01/07/2022	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	05/29/2023	**Line Tightness Test Date**	05/24/2020	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	05/29/2023			**ATG Type**	Incon/TS-550 EVO				

Facility Summary in Yellowstone County in the City of Billings

Location: AIR TRAFFIC CONTROL TOWER
1907 Terminal Cir
Billings, MT 59105-1990 Yellowstone

System Facility ID:56-14127

Facility Code: 30768
Last Inspected On: 06/12/2025
Operating Permit Renewal Date: 10/21/2025

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Federal Aviation Admin Billings	**(406) 657-6455**	**evan.wolfe@faa.gov**
Operator Contact:	Craig Fitzgerald;Evan Wolfe;Kevonte Daniels	**(406) 598-6855;(406) 657-6981;(406) 670-1577**	**craig.fitzgerald@faa.gov;evan.wolfe@faa.gov;kevonte.a.daniels@faa.gov**

Owner/Operator: Federal Aviation Admin Billings (406) 657-6455 evan.wolfe@faa.gov

Craig Fitzgerald, UST Class A Operator	craig.fitzgerald@faa.gov
Craig Fitzgerald, UST Class B Global Operator	craig.fitzgerald@faa.gov
Evan Wolfe, UST Class A Operator	evan.wolfe@faa.gov
Evan Wolfe, UST Class B Global Operator	evan.wolfe@faa.gov
Kevonte Daniels, UST Class A Operator	kevonte.a.daniels@faa.gov
Kevonte Daniels, UST Class B Operator	kevonte.a.daniels@faa.gov

Tank Number	01	**Tank Age**	21	**Tank Installed Date**	12/09/2004	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	4976	**Spill Test Date**	10/21/2021	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	08/12/2021	**Catastrophic L.D. Type 3.0**	Continuous Interstitial Monitoring	**Piping Type**	U.S. Suction	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	07/28/2022	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	07/28/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350;Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Yellowstone County in the City of Billings

Location: ARCHIE COCHRANE MOTORS
2133 King Ave W
Billings, MT 59102-6420 Yellowstone

System Facility ID:56-00123

Facility Code: 29692
Last Inspected On: 12/15/2023
Operating Permit Renewal Date: 03/26/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Archie Cochrane Motors **(406) 656-1100**

Operator Contact: Chuck South **csouth@billingsford.com**

Owner/Operator: Archie Cochrane Motors (406) 656-1100

Chuck South, UST Class A Operator csouth@billingsford.com
Chuck South, UST Class B Operator csouth@billingsford.com

Tank Number	04	**Tank Age**	32	**Tank Installed Date**	08/01/1993	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	390	**Spill Test Date**	12/15/2023	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	12/15/2023	**Primary Tank Leak Detection**	Manual Interstitial Monitoring	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	2000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	12/15/2023			**ATG Type**					
Tank Number	05	**Tank Age**	32	**Tank Installed Date**	08/01/1993	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	391	**Spill Test Date**	12/15/2023	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	12/15/2023	**Primary Tank Leak Detection**	Manual Interstitial Monitoring	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	1000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	12/15/2023			**ATG Type**					

Facility Summary in Yellowstone County in the City of Billings

Location: AT AND T COMMUNICATIONS BILLINGS
3011 2nd Ave N
Billings, MT 59101-2028 Yellowstone

System Facility ID:56-05758

Facility Code: 30061
Last Inspected On: 08/26/2024
Operating Permit Renewal Date: 03/09/2028

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	AT and T Communications Inc	**(800) 566-9347**	
Operator Contact:	Daniel Donigian;David Klase;Gary Vantress;Gerald Eshbaugh;Philip Bunker;Richard Powell;Robert Pickens	**(214) 741-0476;(406) 208-5209;(509) 459-6211**	**bob.pickens@att.com;dd2575@att.com;dk9763@att.com;gvantress@att.com;je9391@att.com;pb2720@att.com;rp2463@att.com**

Owner/Operator: AT and T Communications Inc (800) 566-9347

Daniel Donigian, UST Class A Operator	dd2575@att.com
Daniel Donigian, UST Class A Operator	dd2575@att.com
Daniel Donigian, UST Class B Global Operator	dd2575@att.com
Daniel Donigian, UST Class B Global Operator	dd2575@att.com
David Klase, UST Class A Operator	dk9763@att.com
David Klase, UST Class B Operator	dk9763@att.com
Gary Vantress, UST Class A Operator	gvantress@att.com
Gary Vantress, UST Class A Operator	gvantress@att.com
Gary Vantress, UST Class B Operator	gvantress@att.com
Gary Vantress, UST Class B Operator	gvantress@att.com
Gerald Eshbaugh, UST Class A Operator	je9391@att.com
Gerald Eshbaugh, UST Class A Operator	je9391@att.com
Philip Bunker, UST Class A Operator	pb2720@att.com
Philip Bunker, UST Class A Operator	pb2720@att.com
Richard Powell, UST Class A Operator	rp2463@att.com
Richard Powell, UST Class A Operator	rp2463@att.com
Robert Pickens, UST Class A Operator	bob.pickens@att.com
Robert Pickens, UST Class A Operator	bob.pickens@att.com

Tank Number	03	**Tank Age**	31	**Tank Installed Date**	09/01/1994	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	399	**Spill Test Date**	08/26/2024	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	10/09/2024	**Catastrophic L.D. Type 3.0**	Auto Dialer;Continuous Interstitial Monitoring	**Piping Type**	U.S. Suction	**CP Met Types**	Galvanic

Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	08/26/2024	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	10/09/2024	**Line Tightness Test Date**	08/26/2024	**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	3-Year Line Tightness Test	**Energy Act**	No
		Overfill Test Date	08/26/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				

Facility Summary in Yellowstone County in the City of Billings

Location: BEACON AIR GROUP
1483 Aviation Place
Billings, MT 59105 Yellowstone

System Facility ID:00-32567

Facility Code: 32567
Last Inspected On: 04/05/2024
Operating Permit Renewal Date: 07/29/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Beacon Air Group	**(800) 700-5107**	**joel@beaconairgroup.com**
Operator Contact:	Joel Simmons	**(307) 382-3224**	**joel@beaconairgroup.com**

Owner/Operator: Beacon Air Group (800) 700-5107 joel@beaconairgroup.com

Joel Simmons, UST Class A Operator joel@beaconairgroup.com

Joel Simmons, UST Class B Operator joel@beaconairgroup.com

Tank Number	01	**Tank Age**	2	**Tank Installed Date**	10/11/2023	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Steel	**Overfill Types**	High Level Alarm
Tag Number	6216	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Single Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	12/21/2023	**Catastrophic L.D. Type 3.0**		**Piping Type**	U.S. Suction	**CP Met Types**	Non-corrodible
Product	Jet Fuel (Jet-A, Jet-A1, JP5)	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	30000	**ATG Test Date**	12/21/2023	**Line Tightness Test Date**	12/21/2023	**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	Yes
		Overfill Test Date	12/21/2023			**ATG Type**					
Tank Number	02	**Tank Age**	2	**Tank Installed Date**	10/11/2023	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Steel	**Overfill Types**	High Level Alarm
Tag Number	6217	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Single Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	12/21/2023	**Catastrophic L.D. Type 3.0**	Continuous Interstitial Monitoring	**Piping Type**	U.S. Suction	**CP Met Types**	Non-corrodible
Product	Jet Fuel (Jet-A, Jet-A1, JP5)	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	30000	**ATG Test Date**	12/21/2023	**Line Tightness Test Date**	12/21/2023	**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**		**Energy Act**	Yes
		Overfill Test Date	12/21/2023			**ATG Type**					

Tank Number	03	**Tank Age**	2	**Tank Installed Date**	10/11/2023	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Steel	**Overfill Types**	High Level Alarm
Tag Number	6218	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Single Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	12/21/2023	**Catastrophic L.D. Type 3.0**	Continuous Interstitial Monitoring	**Piping Type**	U.S. Suction	**CP Met Types**	
Product	Aviation Gas	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	12/21/2023	**Line Tightness Test Date**	12/21/2023	**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**		**Energy Act**	Yes
		Overfill Test Date	12/21/2023			**ATG Type**					

Facility Summary in Yellowstone County in the City of Billings

Location: BILLINGS DIGITAL AIRPORT SURVEILLANCE RADAR
1901 Terminal Cir
Billings, MT 59105-1990 Yellowstone

System Facility ID:56-14077

Facility Code: 30729
Last Inspected On: 12/18/2023
Operating Permit Renewal Date: 03/26/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Federal Aviation Admin Billings	**(406) 657-6455**	**evan.wolfe@faa.gov**
Operator Contact:	Dennis Schuelka;Evan Wolfe;Paul Henley	**(406) 225-2711;(406) 670-1577;(406) 855-1891**	**dennis.scheulka@faa.gov;evan.wolfe@faa.gov;paul.henley@faa.gov**

Owner/Operator: Federal Aviation Admin Billings (406) 657-6455 evan.wolfe@faa.gov

Dennis Schuelka, UST Class A Operator	dennis.scheulka@faa.gov
Dennis Schuelka, UST Class B Operator	dennis.scheulka@faa.gov
Evan Wolfe, UST Class A Operator	evan.wolfe@faa.gov
Evan Wolfe, UST Class B Global Operator	evan.wolfe@faa.gov
Paul Henley, UST Class A Operator	paul.henley@faa.gov

Tank Number	01	**Tank Age**	23	**Tank Installed Date**	12/30/2002	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	4780	**Spill Test Date**	10/10/2021	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	08/09/2021	**Catastrophic L.D. Type 3.0**	Continuous Interstitial Monitoring	**Piping Type**	U.S. Suction	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	3-Year Line Tightness Test	**Vapor Recovery**	No
Capacity	1000	**ATG Test Date**	05/04/2023	**Line Tightness Test Date**	08/12/2021	**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	08/12/2021			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Yellowstone County in the City of Billings

Location: BILLINGS FIRE STATION 1
2305 8th Ave N
Billings, MT 59101-1018 Yellowstone

System Facility ID:56-09739

Facility Code: 30317
Last Inspected On: 12/07/2023
Operating Permit Renewal Date: 12/07/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	City of Billings Fire Dept	**(406) 657-8423**	
Operator Contact:	Froilan Valdez;Kevonte Daniels;Tricia Mae;City of Billings Fire Dept	**(406) 598-6855;(406) 657-8420;(406) 657-8423**	**kevonte.a.daniels@faa.gov;maet@billingsmt.gov;valdezp@billingsmt.gov**

Owner/Operator: City of Billings Fire Dept (406) 657-8423

Froilan Valdez, UST Class A Operator	valdezp@billingsmt.gov
Froilan Valdez, UST Class B Global Operator	valdezp@billingsmt.gov
Kevonte Daniels, UST Class A Operator	kevonte.a.daniels@faa.gov
Kevonte Daniels, UST Class B Global Operator	kevonte.a.daniels@faa.gov
Tricia Mae, UST Class A Operator	maet@billingsmt.gov
Tricia Mae, UST Class B Operator	maet@billingsmt.gov

Tank Number	03	**Tank Age**	32	**Tank Installed Date**	12/01/1993	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	2728	**Spill Test Date**	12/07/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	12/07/2023	**Catastrophic L.D. Type 3.0**	Continuous Interstitial Monitoring	**Piping Type**	U.S. Suction	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	12/07/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	1035	**ATG Test Date**	12/07/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	12/07/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	04	**Tank Age**	32	**Tank Installed Date**	12/01/1993	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Copper	**Overfill Types**	High Level Alarm
Tag Number	2729	**Spill Test Date**	04/18/2024	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Secondary Containment Chase	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	12/07/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**		**Vapor Recovery**	No

Capacity	517	**ATG Test Date**	12/07/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	12/07/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Yellowstone County in the City of Billings

Location: BILLINGS FIRE STATION 2
501 S 28th St
Billings, MT 59101-4143 Yellowstone

System Facility ID:56-09740

Facility Code: 30318
Last Inspected On: 12/07/2023
Operating Permit Renewal Date: 12/07/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: City of Billings Fire Dept **(406) 657-8423**

Operator Contact: Froilan Valdez;Tricia Mae;City of Billings Fire Dept **(406) 657-8420;(406) 657-8423** **maet@billingsmt.gov;valdezp@billingsmt.gov**

Owner/Operator: City of Billings Fire Dept (406) 657-8423

Froilan Valdez, UST Class A Operator	valdezp@billingsmt.gov
Froilan Valdez, UST Class B Global Operator	valdezp@billingsmt.gov
Tricia Mae, UST Class A Operator	maet@billingsmt.gov
Tricia Mae, UST Class B Operator	maet@billingsmt.gov

Tank Number	03	**Tank Age**	35	**Tank Installed Date**	06/12/1990	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Steel	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	3699	**Spill Test Date**	12/07/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	12/07/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	1000	**ATG Test Date**	12/07/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	04/24/2024			**ATG Type**	Gilbarco/EMC Basic				
Tank Number	04	**Tank Age**	35	**Tank Installed Date**	06/12/1990	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Steel	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	3700	**Spill Test Date**	12/07/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	12/07/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	1000	**ATG Test Date**	12/07/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	04/24/2024			**ATG Type**	Gilbarco/EMC Basic				

Facility Summary in Yellowstone County in the City of Billings

Location: BILLINGS FIRE STATION 3
1928 17th St W
Billings, MT 59102-2907 Yellowstone

System Facility ID:56-09741

Facility Code: 30319
Last Inspected On: 12/07/2023
Operating Permit Renewal Date: 12/07/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: City of Billings Fire Dept **(406) 657-8423**

Operator Contact: Froilan Valdez;Tricia Mae;City of Billings Fire Dept **(406) 657-8420;(406) 657-8423** **maet@billingsmt.gov;valdezp@billingsmt.gov**

Owner/Operator: City of Billings Fire Dept (406) 657-8423

Froilan Valdez, UST Class A Operator	valdezp@billingsmt.gov
Froilan Valdez, UST Class B Global Operator	valdezp@billingsmt.gov
Tricia Mae, UST Class A Operator	maet@billingsmt.gov
Tricia Mae, UST Class B Operator	maet@billingsmt.gov

Tank Number	02	**Tank Age**	33	**Tank Installed Date**	03/01/1992	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	4297	**Spill Test Date**	12/07/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	12/07/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	500	**ATG Test Date**	12/07/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	12/07/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Yellowstone County in the City of Billings

Location: BILLINGS FIRE STATION 5
605 S 24th St W
Billings, MT 59102-6246 Yellowstone

System Facility ID:56-09742

Facility Code: 30320
Last Inspected On: 12/07/2023
Operating Permit Renewal Date: 12/07/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: City of Billings Fire Dept **(406) 657-8423**

Operator Contact: Froilan Valdez;Tricia Mae;City of Billings Fire Dept **(406) 657-8420;(406) 657-8423** **maet@billingsmt.gov;valdezp@billingsmt.gov**

Owner/Operator: City of Billings Fire Dept (406) 657-8423

Froilan Valdez, UST Class A Operator	valdezp@billingsmt.gov
Froilan Valdez, UST Class B Global Operator	valdezp@billingsmt.gov
Tricia Mae, UST Class A Operator	maet@billingsmt.gov
Tricia Mae, UST Class B Operator	maet@billingsmt.gov

Tank Number	04	**Tank Age**	32	**Tank Installed Date**	01/01/1993	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	2731	**Spill Test Date**	12/07/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	12/07/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	517	**ATG Test Date**	12/07/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	12/07/2023			**ATG Type**	Gilbarco-Veeder Root/Other				
Tank Number	05	**Tank Age**	32	**Tank Installed Date**	01/01/1993	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	2732	**Spill Test Date**	12/07/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	12/07/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	517	**ATG Test Date**	12/07/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	12/07/2023			**ATG Type**	Gilbarco-Veeder Root/Other				

Facility Summary in Yellowstone County in the City of Billings

Location: BILLINGS FIRE STATION 6
1601 St Andrews Dr
Billings, MT 59105-3863 Yellowstone

System Facility ID:56-09743

Facility Code: 30321
Last Inspected On: 12/07/2023
Operating Permit Renewal Date: 12/07/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: City of Billings Fire Dept **(406) 657-8423**

Operator Contact: Froilan Valdez;Tricia Mae;City of Billings Fire Dept **(406) 657-8420;(406) 657-8423** **maet@billingsmt.gov;valdezp@billingsmt.gov**

Owner/Operator: City of Billings Fire Dept (406) 657-8423

Froilan Valdez, UST Class A Operator	valdezp@billingsmt.gov
Froilan Valdez, UST Class B Global Operator	valdezp@billingsmt.gov
Tricia Mae, UST Class A Operator	maet@billingsmt.gov
Tricia Mae, UST Class B Operator	maet@billingsmt.gov

Tank Number	01	**Tank Age**	38	**Tank Installed Date**	10/19/1987	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	2733	**Spill Test Date**	12/07/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	12/07/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	500	**ATG Test Date**	12/07/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	04/24/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Yellowstone County in the City of Billings

Location: BILLINGS LOGAN INTERNATIONAL AIRPORT UST
1901 Terminal Cir Ste 216
Billings, MT 59105-1991 Yellowstone

System Facility ID:56-00909

Facility Code: 29743
Last Inspected On: 05/29/2025
Operating Permit Renewal Date: 09/04/2025

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Billings Logan International Airport;Mick McCarthy	**(406) 657-8482;(406) 657-8483**	**annink@ci.billings.mt.us;mccarthym@billingsmt.gov**
Operator Contact:	Shawn Gaalswyk	**(406) 794-5065**	**gaalswyks@billingsmt.gov**

Owner/Operator:	Billings Logan International Airport	(406) 657-8482	annink@ci.billings.mt.us
Owner/Operator:	Mick McCarthy	(406) 657-8482	annink@ci.billings.mt.us
	Colter Smith, UST Class B Operator		bosfire2008@yahoo.com
	Shawn Gaalswyk, UST Class A Operator		gaalswyks@billingsmt.gov
	Shawn Gaalswyk, UST Class B Operator		gaalswyks@billingsmt.gov

Tank Number	17	**Tank Age**	32	**Tank Installed Date**	10/01/1993	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	
Tag Number	4826	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Secondary Containment Chase	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Gravity Feed	**CP Met Types**	Galvanic
Product	Oil, Waste	**PLLD Test Date**		**Tank/Piping CP Test Date**	06/27/2022	**Primary Tank Leak Detection**	Manual Interstitial Monitoring	**Primary Pipe Leak Detection**	3-Year Line Tightness Test	**Vapor Recovery**	No
Capacity	500	**ATG Test Date**		**Line Tightness Test Date**	07/08/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	11	**Tank Age**	38	**Tank Installed Date**	01/01/1987	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	623	**Spill Test Date**	06/27/2022	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**		**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	06/27/2022	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	06/27/2022	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**		**Energy Act**	No

		Overfill Test Date	06/27/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	12	**Tank Age**	32	**Tank Installed Date**	10/01/1993	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	624	**Spill Test Date**	06/27/2022	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**	06/27/2022	**Tank/Piping CP Test Date**	06/27/2022	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	06/27/2022	**Line Tightness Test Date**	06/27/2022	**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	06/27/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	13	**Tank Age**	32	**Tank Installed Date**	10/01/1993	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	625	**Spill Test Date**	06/27/2022	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**	06/27/2022	**Tank/Piping CP Test Date**	06/27/2022	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	06/27/2022	**Line Tightness Test Date**	06/01/2022	**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	06/27/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Yellowstone County in the City of Billings

Location: BILLINGS METROPOLITAN TRANSIT
1705 Monad Rd
Billings, MT 59101-3234 Yellowstone

System Facility ID:56-09747

Facility Code: 30325
Last Inspected On: 08/09/2024
Operating Permit Renewal Date: 12/18/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	City of Billings MET Transit	**(406) 657-8219**	
Operator Contact:	John Bishop;Josh Smith;Billings Metropolitan Transit;Lindsay Gran;Rusty Logan	**(406) 657-8218;(406) 657-8219**	**granl@ci.billings.mt.us;rusty.l.logan@gmail.com;smithj@billingsmt.gov**

Owner/Operator: City of Billings MET Transit (406) 657-8219

John Bishop, UST Class A Operator	
John Bishop, UST Class A Operator	
Josh Smith, UST Class A Operator	smithj@billingsmt.gov
Josh Smith, UST Class B Operator	smithj@billingsmt.gov
Lindsay Gran, UST Class A Operator	granl@ci.billings.mt.us
Lindsay Gran, UST Class A Operator	granl@ci.billings.mt.us
Rick Pirami, UST Class B Operator	
Rick Pirami, UST Class B Operator	
Rusty Logan, UST Class A Operator	rusty.l.logan@gmail.com
Rusty Logan, UST Class A Operator	rusty.l.logan@gmail.com

Tank Number	04	**Tank Age**	22	**Tank Installed Date**	09/03/2003	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	4862	**Spill Test Date**	08/09/2024	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	08/09/2024	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	08/09/2024	**Line Tightness Test Date**	08/09/2024	**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	08/09/2024			**ATG Type**	Gilbarco/EMC Basic				
Tank Number	05	**Tank Age**	22	**Tank Installed Date**	09/03/2003	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	4863	**Spill Test Date**	08/09/2024	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	08/09/2024	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible

Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	08/09/2024	**Line Tightness Test Date**	08/09/2024	**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	08/09/2024			**ATG Type**	Gilbarco/EMC Basic				
Tank Number	03	**Tank Age**	42	**Tank Installed Date**	10/15/1983	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	635	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Gravity Feed	**CP Met Types**	Galvanic
Product	Oil, Waste	**PLLD Test Date**		**Tank/Piping CP Test Date**	08/09/2024	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	3-Year Line Tightness Test	**Vapor Recovery**	No
Capacity	2000	**ATG Test Date**	08/09/2024	**Line Tightness Test Date**	08/09/2024	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco/EMC Basic				

Facility Summary in Yellowstone County in the City of Billings

Location: BILLINGS REGIONAL LANDFILL
5240 Jellison Rd
Billings, MT 59101 Yellowstone

System Facility ID:56-09744

Facility Code: 30322
Last Inspected On: 07/01/2021
Operating Permit Renewal Date: 07/01/2024

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	City of Billings Solid Waste Division	**(406) 657-8240**	**lehnert@ci.billings.mt.us**
Operator Contact:	Margaret Pegues	**(406) 247-8633**	

Margaret Pegues, UST Class A Operator
Margaret Pegues, UST Class B Operator

Tank Number	01	**Tank Age**	39	**Tank Installed Date**	10/01/1986	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	630	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**	09/04/2018	**Catastrophic L.D. Type 3.0**	Continuous Interstitial Monitoring	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	07/01/2021	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	20000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**	Veeder Root/TLS-300				

Facility Summary in Yellowstone County in the City of Billings

Location: CARDLOCK #2
3520 1st Ave S
Billings, MT 59101 Yellowstone

System Facility ID:56-08324

Facility Code: 30262
Last Inspected On: 07/29/2022
Operating Permit Renewal Date: 12/24/2025

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	GM Petroleum Distributing Inc	**(406) 252-4661**	**dwhitmore@gmconostores.com**
Operator Contact:	Bill Grunstead;Jay Brookie;Laura Geffre;Roger Schmechel	**(406) 208-3147;(406) 252-4661**	**bgrunstead@gmpetroleum.com;jayb@cityservicevalcon.com;rogers@cityservicevalcon.com**

Owner/Operator: GM Petroleum Distributing Inc (406) 252-4661 dwhitmore@gmconostores.com

Bill Grunstead, UST Class A Operator	bgrunstead@gmpetroleum.com
Bill Grunstead, UST Class A Operator	bgrunstead@gmpetroleum.com
Jay Brookie, UST Class A Operator	jayb@cityservicevalcon.com
Jay Brookie, UST Class A Operator	jayb@cityservicevalcon.com
Jay Brookie, UST Class B Global Operator	jayb@cityservicevalcon.com
Jay Brookie, UST Class B Global Operator	jayb@cityservicevalcon.com
Laura Geffre, UST Class A Operator	
Laura Geffre, UST Class A Operator	
Laura Geffre, UST Class B Operator	
Laura Geffre, UST Class B Operator	
Roger Schmechel, UST Class A Operator	rogers@cityservicevalcon.com
Roger Schmechel, UST Class A Operator	rogers@cityservicevalcon.com
Roger Schmechel, UST Class B Operator	rogers@cityservicevalcon.com
Roger Schmechel, UST Class B Operator	rogers@cityservicevalcon.com

Tank Number	01	**Tank Age**	47	**Tank Installed Date**	05/06/1978	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Steel	**Overfill Types**	High Level Alarm
Tag Number	1179	**Spill Test Date**	07/18/2022	**Piping Installed Date**		**Tank Construction**	Lined Interior/Impressed Current	**Piping Construction**	Single Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Diesel	**PLLD Test Date**	07/18/2022	**Tank/Piping CP Test Date**	07/18/2022	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	07/18/2022	**Line Tightness Test Date**	03/21/2019	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	07/18/2022			**ATG Type**	Gilbarco/EMC Basic				

Tank Number	02	**Tank Age**	47	**Tank Installed Date**	05/06/1978	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Steel	**Overfill Types**	High Level Alarm
Tag Number	1180	**Spill Test Date**	07/18/2022	**Piping Installed Date**		**Tank Construction**	Lined Interior/Impressed Current	**Piping Construction**	Single Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Diesel	**PLLD Test Date**	07/18/2022	**Tank/Piping CP Test Date**	07/18/2022	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	07/18/2022	**Line Tightness Test Date**	03/24/2019	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	07/18/2022			**ATG Type**	Gilbarco/EMC Basic				
Tank Number	03	**Tank Age**	47	**Tank Installed Date**	05/06/1978	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Steel	**Overfill Types**	High Level Alarm
Tag Number	1181	**Spill Test Date**	07/18/2022	**Piping Installed Date**		**Tank Construction**	Lined Interior/Impressed Current	**Piping Construction**	Single Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**	07/18/2022	**Tank/Piping CP Test Date**	07/18/2022	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	07/18/2022	**Line Tightness Test Date**	03/21/2019	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	07/18/2022			**ATG Type**	Gilbarco/EMC Basic				

Facility Summary in Yellowstone County in the City of Billings

Location: CASEYS CORNER 10
3443 Central Ave
Billings, MT 59102 Yellowstone

System Facility ID:56-05085

Facility Code: 30003
Last Inspected On: 03/20/2025
Operating Permit Renewal Date: 06/14/2028

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Superpumper Inc **(701) 852-1194**

Operator Contact: Vern Patterson;Parkland USA Corporation **(701) 720-6649;(701) 852-1194** **vern.patterson@parklandusa.com;Jake.thomas@parklandusa.com**

Owner/Operator: Superpumper Inc (701) 852-1194

Curtis McBride, UST Class B Operator Jake.thomas@parklandusa.com
Vern Patterson, UST Class A Operator Jake.thomas@parklandusa.com
Vern Patterson, UST Class B Operator Jake.thomas@parklandusa.com

Tank Number	06	**Tank Age**	30	**Tank Installed Date**	05/01/1995	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	2007	**Spill Test Date**	01/17/2023	**Piping Installed Date**	05/06/2014	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	01/31/2020	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**	08/05/2024	**Tank/Piping CP Test Date**	03/20/2025	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	08/05/2024	**Line Tightness Test Date**	01/25/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date	03/20/2025			**ATG Type**	Veeder Root/TLS-450				
Tank Number	08	**Tank Age**	30	**Tank Installed Date**	05/01/1995	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	2009	**Spill Test Date**	08/11/2021	**Piping Installed Date**	05/06/2014	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	01/31/2020	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**	08/05/2024	**Tank/Piping CP Test Date**	03/20/2025	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**	08/05/2024	**Line Tightness Test Date**	01/17/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date	03/20/2025			**ATG Type**	Veeder Root/TLS-450				

Tank Number	07	**Tank Age**	30	**Tank Installed Date**	05/01/1995	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	4473	**Spill Test Date**	08/11/2021	**Piping Installed Date**	05/06/2014	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	01/31/2020	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**	08/05/2024	**Tank/Piping CP Test Date**	03/20/2025	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	08/05/2024	**Line Tightness Test Date**	02/14/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date	03/20/2025			**ATG Type**	Veeder Root/TLS-450				

Facility Summary in Yellowstone County in the City of Billings

Location: CASEYS CORNER 11
2347 Main St
Billings, MT 59105-4023 Yellowstone

System Facility ID:56-06593

Facility Code: 30118
Last Inspected On: 01/25/2023
Operating Permit Renewal Date: 04/25/2023

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Superpumper Inc **(701) 852-1194**

Operator Contact: Vern Patterson;Parkland USA Corporation **(701) 720-6649;(701) 852-1194** **vern.patterson@parklandusa.com;Jake.thomas@parklandusa.com**

Owner/Operator: Superpumper Inc (701) 852-1194

Curtis McBride, UST Class B Operator Jake.thomas@parklandusa.com
Vern Patterson, UST Class A Operator Jake.thomas@parklandusa.com
Vern Patterson, UST Class B Operator Jake.thomas@parklandusa.com

Tank Number	01	**Tank Age**	44	**Tank Installed Date**	10/01/1981	**Tank Material Construction**	Bare Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	459	**Spill Test Date**	03/24/2020	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Diesel	**PLLD Test Date**	01/24/2020	**Tank/Piping CP Test Date**	01/24/2020	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**		**Line Tightness Test Date**	10/14/2019	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	02	**Tank Age**	44	**Tank Installed Date**	10/01/1981	**Tank Material Construction**	Bare Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	460	**Spill Test Date**	03/24/2020	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**	01/24/2020	**Tank/Piping CP Test Date**	01/24/2020	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	20000	**ATG Test Date**		**Line Tightness Test Date**	10/15/2019	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Tank Number	03	**Tank Age**	44	**Tank Installed Date**	10/01/1981	**Tank Material Construction**	Bare Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	461	**Spill Test Date**	03/24/2020	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**	01/24/2020	**Tank/Piping CP Test Date**	01/24/2020	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	20000	**ATG Test Date**		**Line Tightness Test Date**	10/14/2019	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	04	**Tank Age**	3	**Tank Installed Date**	10/21/2022	**Tank Material Construction**	Steel Clad	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	6138	**Spill Test Date**	10/21/2022	**Piping Installed Date**	10/21/2022	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	10/21/2022	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	10/21/2022	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	Yes
Capacity	10000	**ATG Test Date**	10/21/2022	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	10/21/2022			**ATG Type**					
Tank Number	05	**Tank Age**	3	**Tank Installed Date**	10/21/2022	**Tank Material Construction**	Steel Clad	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	6139	**Spill Test Date**	10/21/2022	**Piping Installed Date**	10/21/2022	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	10/21/2022	**Catastrophic L.D. Type 3.0**		**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	10/21/2022	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**		**Vapor Recovery**	Yes
Capacity	10000	**ATG Test Date**	10/21/2022	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	Yes
		Overfill Test Date	10/21/2022			**ATG Type**					
Tank Number	06	**Tank Age**	0	**Tank Installed Date**		**Tank Material Construction**	Steel Clad	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	6140	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No

Capacity	6000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date				**ATG Type**					

Facility Summary in Yellowstone County in the City of Billings

Location: CASEYS CORNER 12
5550 US Hwy 312
Billings, MT 59105-4944 Yellowstone

System Facility ID:56-00062

Facility Code: 29688
Last Inspected On: 08/12/2022
Operating Permit Renewal Date: 11/28/2025

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Superpumper Inc **(701) 852-1194**

Operator Contact: Vern Patterson;Parkland USA Corporation **(701) 720-6649;(701) 852-1194** **vern.patterson@parklandusa.com;Jake.thomas@parklandusa.com**

Owner/Operator: Superpumper Inc (701) 852-1194

Curtis McBride, UST Class B Operator Jake.thomas@parklandusa.com
Vern Patterson, UST Class A Operator Jake.thomas@parklandusa.com
Vern Patterson, UST Class B Operator Jake.thomas@parklandusa.com

Tank Number	04	**Tank Age**	9	**Tank Installed Date**	06/30/2016	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	5653	**Spill Test Date**	08/12/2022	**Piping Installed Date**	06/30/2016	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	08/12/2022	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	12/17/2021	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	12/17/2021	**Line Tightness Test Date**	07/14/2019	**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	08/12/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350;Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	05	**Tank Age**	9	**Tank Installed Date**	06/30/2016	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	5654	**Spill Test Date**	08/12/2022	**Piping Installed Date**	06/30/2016	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	08/12/2022	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	12/17/2021	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	12/17/2021	**Line Tightness Test Date**	07/10/2019	**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes

		Overfill Test Date	08/12/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350;Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	06	**Tank Age**	9	**Tank Installed Date**	06/30/2016	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	5655	**Spill Test Date**	08/12/2022	**Piping Installed Date**	06/30/2016	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	08/12/2022	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	12/17/2021	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	12/17/2021	**Line Tightness Test Date**	07/12/2019	**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	08/12/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350;Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	07	**Tank Age**	9	**Tank Installed Date**	06/30/2016	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	5656	**Spill Test Date**	08/12/2022	**Piping Installed Date**	06/30/2016	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	08/12/2022	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel, Dyed	**PLLD Test Date**	12/17/2021	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	12/17/2021	**Line Tightness Test Date**	07/10/2019	**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	08/12/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350;Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Yellowstone County in the City of Billings

Location: CASEYS CORNER 7
2007 Blue Creek Rd
Billings, MT 59101 Yellowstone

System Facility ID:56-06595

Facility Code: 30120
Last Inspected On: 06/16/2023
Operating Permit Renewal Date: 06/16/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Superpumper Inc **(701) 852-1194**

Operator Contact: Vern Patterson;Parkland USA Corporation **(701) 720-6649;(701) 852-1194** **vern.patterson@parklandusa.com;Jake.thomas@parklandusa.com**

Owner/Operator: Superpumper Inc (701) 852-1194

Curtis McBride, UST Class B Operator Jake.thomas@parklandusa.com
Vern Patterson, UST Class A Operator Jake.thomas@parklandusa.com
Vern Patterson, UST Class B Operator Jake.thomas@parklandusa.com

Tank Number	03	**Tank Age**	33	**Tank Installed Date**	11/02/1992	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	466	**Spill Test Date**	05/30/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	05/30/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**	08/10/2023	**Line Tightness Test Date**	08/10/2023	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	08/04/2023			**ATG Type**	Veeder Root/TLS-300				
Tank Number	04	**Tank Age**	33	**Tank Installed Date**	11/02/1992	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	467	**Spill Test Date**	05/30/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	05/30/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	08/10/2023	**Line Tightness Test Date**	08/04/2023	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	08/10/2022			**ATG Type**	Veeder Root/TLS-350				
Tank Number	05	**Tank Age**	33	**Tank Installed Date**	11/02/1992	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve;High Level Alarm

Tag Number	468	**Spill Test Date**	05/30/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	05/30/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	08/10/2023	**Line Tightness Test Date**	08/04/2023	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	08/04/2023			**ATG Type**	Veeder Root/TLS-350				

Facility Summary in Yellowstone County in the City of Billings

Location: CASEYS CORNER 8
2816 Old Hardin Rd
Billings, MT 59101 Yellowstone

System Facility ID:56-06594

Facility Code: 30119
Last Inspected On: 09/22/2023
Operating Permit Renewal Date: 02/28/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Superpumper Inc **(701) 852-1194**

Operator Contact: Vern Patterson;Parkland USA Corporation **(701) 720-6649;(701) 852-1194** **vern.patterson@parklandusa.com;Jake.thomas@parklandusa.com**

Owner/Operator: Superpumper Inc (701) 852-1194

Curtis McBride, UST Class B Operator Jake.thomas@parklandusa.com
Vern Patterson, UST Class A Operator Jake.thomas@parklandusa.com
Vern Patterson, UST Class B Operator Jake.thomas@parklandusa.com

Tank Number	04	**Tank Age**	27	**Tank Installed Date**	05/01/1998	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	462	**Spill Test Date**	09/22/2023	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	08/04/2023	**Tank/Piping CP Test Date**	08/25/2011	**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	20000	**ATG Test Date**	08/04/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	08/04/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350				
Tank Number	05	**Tank Age**	27	**Tank Installed Date**	05/01/1998	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	463	**Spill Test Date**	09/22/2023	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	08/04/2023	**Tank/Piping CP Test Date**	08/25/2011	**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	08/04/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No

		Overfill Test Date	08/04/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350				
Tank Number	06	**Tank Age**	27	**Tank Installed Date**	05/01/1998	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	464	**Spill Test Date**	09/22/2023	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	08/04/2023	**Tank/Piping CP Test Date**	08/25/2011	**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	08/04/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	08/04/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350				
Tank Number	07	**Tank Age**	27	**Tank Installed Date**	05/01/1998	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	465	**Spill Test Date**	09/22/2023	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	08/04/2023	**Tank/Piping CP Test Date**	08/25/2011	**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	08/04/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	08/04/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Yellowstone County in the City of Billings

Location: CENTRAL TRANSPORT
6200 S Frontage Road
Billings, MT 59101 Yellowstone

System Facility ID:00-32500

Facility Code: 32500
Last Inspected On: 01/05/2023
Operating Permit Renewal Date: 04/01/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Crown Enterprises **(586) 467-1711** **relliott@centraltransport.com**

Operator Contact: Arin Jensen **ajensen@centraltransport.com**

Owner/Operator: Crown Enterprises (586) 467-1711 relliott@centraltransport.com

Arin Jensen, UST Class A Operator ajensen@centraltransport.com

Arin Jensen, UST Class B Operator ajensen@centraltransport.com

Tank Number	01	**Tank Age**	3	**Tank Installed Date**	09/01/2022	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	6097	**Spill Test Date**	08/16/2022	**Piping Installed Date**	09/01/2022	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	09/15/2022	**Sump Tightness Test Date**	08/16/2022	**Catastrophic L.D. Type 3.0**	Auto Dialer;Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	30000	**ATG Test Date**	09/15/2022	**Line Tightness Test Date**	09/15/2022	**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**		**Energy Act**	Yes
		Overfill Test Date	09/15/2022			**ATG Type**					
Tank Number	02	**Tank Age**	0	**Tank Installed Date**		**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	6098	**Spill Test Date**	08/16/2022	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	08/16/2022	**Catastrophic L.D. Type 3.0**		**Piping Type**	Pressurized	**CP Met Types**	
Product	DEF (Not Regulated)	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	09/15/2022	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	09/15/2022			**ATG Type**					

Facility Summary in Yellowstone County in the City of Billings

Location: CIRCLE K STORE 2746087
4041 Grand Ave
Billings, MT 59106-1731 Yellowstone

System Facility ID:56-13723

Facility Code: 30457
Last Inspected On: 05/02/2025
Operating Permit Renewal Date: 05/15/2028

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Rocky Mountain Oil LLC	**(602) 728-8000**	**NT-ESS@Circlek.com**
Operator Contact:	Chuck Nyberg;Kegan Krueger;Patrick Patnaude;Stephen Reckinger;Valeria Jeffries;Veronica Rivera	**(406) 321-0938;(952) 830-8028;(952) 830-8721;(952) 830-8722**	**ESS-WestCoast@circlek.com;kegan.krueger@holidaycompanies.com;patrick.patnaude@holidaycompanies.com;steve.reckinger@holidaycompanies.com;valeria.jeffries@holidaycompanies.com**

Owner/Operator: Rocky Mountain Oil LLC (602) 728-8000 NT-ESS@Circlek.com

Brad Lee, UST Class B Global Operator	brad.lee@holidaycompanies.com
Chuck Nyberg, UST Class A Operator	
Greg Hoffman, UST Class B Operator	exodus913@hotmail.com
Jeff Reed, UST Class B Global Operator	jeff.reed@holidaycompanies.com
Kegan Krueger, UST Class A Operator	kegan.krueger@holidaycompanies.com
Patrick Patnaude, UST Class A Operator	patrick.patnaude@holidaycompanies.com
Stephen Reckinger, UST Class A Operator	steve.reckinger@holidaycompanies.com
Valeria Jeffries, UST Class A Operator	valeria.jeffries@holidaycompanies.com
Veronica Rivera, UST Class A Operator	ESS-WestCoast@circlek.com
Veronica Rivera, UST Class B Global Operator	ESS-WestCoast@circlek.com

Tank Number	01	**Tank Age**	29	**Tank Installed Date**	06/01/1996	**Tank Material Construction**	Steel Clad	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	3062	**Spill Test Date**	08/27/2021	**Piping Installed Date**	11/18/2021	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	03/07/2025	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**	08/12/2024	**Tank/Piping CP Test Date**	07/11/2013	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	Yes
Capacity	8000	**ATG Test Date**	08/12/2024	**Line Tightness Test Date**	11/30/2021	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date	08/12/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	02	**Tank Age**	29	**Tank Installed Date**	06/01/1996	**Tank Material Construction**	Steel Clad	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	3063	**Spill Test Date**	08/27/2021	**Piping Installed Date**	11/18/2021	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No

Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	03/07/2025	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**	08/12/2024	**Tank/Piping CP Test Date**	07/11/2013	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	Yes
Capacity	8000	**ATG Test Date**	08/12/2024	**Line Tightness Test Date**	11/30/2021	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date	08/12/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	03	**Tank Age**	29	**Tank Installed Date**	06/01/1996	**Tank Material Construction**	Steel Clad	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	3064	**Spill Test Date**	08/27/2021	**Piping Installed Date**	11/18/2021	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	03/07/2025	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**	08/12/2024	**Tank/Piping CP Test Date**	07/11/2013	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	Yes
Capacity	8000	**ATG Test Date**	08/12/2024	**Line Tightness Test Date**	11/30/2021	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date	08/12/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	04	**Tank Age**	29	**Tank Installed Date**	06/01/1996	**Tank Material Construction**	Steel Clad	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	3065	**Spill Test Date**	08/27/2021	**Piping Installed Date**	11/18/2021	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	03/07/2025	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**	08/12/2024	**Tank/Piping CP Test Date**	07/11/2013	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	Yes
Capacity	8000	**ATG Test Date**	08/12/2024	**Line Tightness Test Date**	11/30/2021	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date	08/12/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	05	**Tank Age**	29	**Tank Installed Date**	06/01/1996	**Tank Material Construction**	Steel Clad	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	3066	**Spill Test Date**	08/27/2021	**Piping Installed Date**	11/18/2021	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	03/07/2025	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Diesel	**PLLD Test Date**	08/12/2024	**Tank/Piping CP Test Date**	07/11/2013	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No

Capacity	8000	**ATG Test Date**	08/12/2024	**Line Tightness Test Date**	11/30/2021	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date	08/12/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Yellowstone County in the City of Billings

Location: CIRCLE K STORE 2746108
790 S Billings Blvd
Billings, MT 59101-4709 Yellowstone

System Facility ID:56-13994

Facility Code: 30655
Last Inspected On: 10/29/2024
Operating Permit Renewal Date: 02/04/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Rocky Mountain Oil LLC	**(602) 728-8000**	**NT-ESS@Circlek.com**
Operator Contact:	Veronica Rivera		**ESS-WestCoast@circlek.com**

Owner/Operator:	Rocky Mountain Oil LLC	(602) 728-8000	NT-ESS@Circlek.com
	Courtney Sheriff, UST Class B Global Operator		cjsheriff@msn.com
	Courtney Sheriff, UST Class B Global Operator		cjsheriff@msn.com
	Jeff Reed, UST Class B Global Operator		jeff.reed@holidaycompanies.com
	Jeff Reed, UST Class B Global Operator		jeff.reed@holidaycompanies.com
	Veronica Rivera, UST Class A Operator		ESS-WestCoast@circlek.com
	Veronica Rivera, UST Class A Operator		ESS-WestCoast@circlek.com
	Veronica Rivera, UST Class B Global Operator		ESS-WestCoast@circlek.com
	Veronica Rivera, UST Class B Global Operator		ESS-WestCoast@circlek.com

Tank Number	01	**Tank Age**	24	**Tank Installed Date**	05/01/2001	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	4285	**Spill Test Date**	10/25/2022	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	12/03/2021	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	12/03/2021	**Line Tightness Test Date**	08/23/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	03/16/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350				
Tank Number	02	**Tank Age**	24	**Tank Installed Date**	05/04/2001	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	4286	**Spill Test Date**	03/16/2022	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	12/03/2021	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	Yes

Capacity	10000	**ATG Test Date**	12/03/2021	**Line Tightness Test Date**	02/28/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	03/16/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350				
Tank Number	03	**Tank Age**	24	**Tank Installed Date**	05/01/2001	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	4287	**Spill Test Date**	11/01/2022	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	12/03/2021	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	Yes
Capacity	10000	**ATG Test Date**	12/03/2021	**Line Tightness Test Date**	08/07/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	03/16/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350				
Tank Number	04	**Tank Age**	24	**Tank Installed Date**	05/01/2001	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	4288	**Spill Test Date**	10/25/2022	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	12/03/2021	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	Yes
Capacity	20000	**ATG Test Date**	12/03/2021	**Line Tightness Test Date**	06/22/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	03/16/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350				
Tank Number	06	**Tank Age**	2	**Tank Installed Date**	11/09/2023	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	6226	**Spill Test Date**	04/03/2024	**Piping Installed Date**	11/09/2023	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	04/03/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	20000	**ATG Test Date**	04/03/2024	**Line Tightness Test Date**	04/03/2024	**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	04/03/2024			**ATG Type**					
Tank Number	07	**Tank Age**	2	**Tank Installed Date**	11/09/2023	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	

Tag Number	6227	**Spill Test Date**		**Piping Installed Date**	11/09/2023	**Tank Construction**		**Piping Construction**		**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**		**Piping Type**	Pressurized	**CP Met Types**	
Product	DEF (Not Regulated)	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	Yes
		Overfill Test Date				**ATG Type**					

Facility Summary in Yellowstone County in the City of Billings

Location: CIRCLE K STORE 2746266
745 Grand Ave
Billings, MT 59101 Yellowstone

System Facility ID:56-08058

Facility Code: 30210
Last Inspected On: 03/05/2025
Operating Permit Renewal Date: 05/23/2028

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Rocky Mountain Oil LLC	**(602) 728-8000**	**NT-ESS@Circlek.com**
Operator Contact:	Veronica Rivera		**ESS-WestCoast@circlek.com**

Owner/Operator:	Rocky Mountain Oil LLC	(602) 728-8000	NT-ESS@Circlek.com
	Beth Podkowa, UST Class B Global Operator		bpodkowa78@gmail.com
	Jeff Reed, UST Class B Global Operator		jeff.reed@holidaycompanies.com
	Jeff Reed, UST Class B Global Operator		jeff.reed@holidaycompanies.com
	Veronica Rivera, UST Class A Operator		ESS-WestCoast@circlek.com
	Veronica Rivera, UST Class A Operator		ESS-WestCoast@circlek.com

Tank Number	05	**Tank Age**	30	**Tank Installed Date**	06/08/1995	**Tank Material Construction**	Steel Clad	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	3036	**Spill Test Date**	02/21/2025	**Piping Installed Date**	03/13/2019	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	03/25/2025	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	05/30/2024	**Tank/Piping CP Test Date**	07/29/2016	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	Yes
Capacity	12000	**ATG Test Date**	05/30/2024	**Line Tightness Test Date**	02/06/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date	05/30/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	06	**Tank Age**	30	**Tank Installed Date**	06/08/1995	**Tank Material Construction**	Steel Clad	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	3037	**Spill Test Date**	02/21/2025	**Piping Installed Date**	03/13/2019	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	03/25/2025	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	05/30/2024	**Tank/Piping CP Test Date**	07/29/2016	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	Yes
Capacity	8000	**ATG Test Date**	05/30/2024	**Line Tightness Test Date**	12/02/2021	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No

		Overfill Test Date	05/30/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	07	**Tank Age**	30	**Tank Installed Date**	06/08/1995	**Tank Material Construction**	Steel Clad	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	3038	**Spill Test Date**	02/21/2025	**Piping Installed Date**	03/13/2019	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	03/25/2025	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	05/30/2024	**Tank/Piping CP Test Date**	07/29/2016	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	Yes
Capacity	8000	**ATG Test Date**	05/30/2024	**Line Tightness Test Date**	02/02/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date	05/30/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	08	**Tank Age**	30	**Tank Installed Date**	06/08/1995	**Tank Material Construction**	Steel Clad	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	3039	**Spill Test Date**	02/21/2025	**Piping Installed Date**	03/13/2019	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	03/25/2025	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	05/30/2024	**Tank/Piping CP Test Date**	07/29/2016	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	05/30/2024	**Line Tightness Test Date**	02/02/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date	05/30/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Yellowstone County in the City of Billings

Location: CIRCLE K STORE 2746274
2620 6th Ave N
Billings, MT 59101 Yellowstone

System Facility ID:56-08062

Facility Code: 30211
Last Inspected On: 05/15/2025
Operating Permit Renewal Date: 04/15/2019

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Rocky Mountain Oil LLC	**(602) 728-8000**	**NT-ESS@Circlek.com**
Operator Contact:	Veronica Rivera		**ESS-WestCoast@circlek.com**

Owner/Operator: Rocky Mountain Oil LLC	(602) 728-8000	NT-ESS@Circlek.com
Jeff Reed, UST Class B Global Operator		jeff.reed@holidaycompanies.com
Jeff Reed, UST Class B Global Operator		jeff.reed@holidaycompanies.com
Jolene Edmisten, UST Class B Operator		joedmisten1984@gmail.com
Veronica Rivera, UST Class A Operator		ESS-WestCoast@circlek.com
Veronica Rivera, UST Class A Operator		ESS-WestCoast@circlek.com
Veronica Rivera, UST Class B Global Operator		ESS-WestCoast@circlek.com
Veronica Rivera, UST Class B Global Operator		ESS-WestCoast@circlek.com

Tank Number	01	**Tank Age**	59	**Tank Installed Date**	05/01/1966	**Tank Material Construction**	Bare Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	
Tag Number		**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**		**Piping Type**	Pressurized	**CP Met Types**	
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.1	**Primary Pipe Leak Detection**	Not Listed	**Vapor Recovery**	No
Capacity	56000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	04	**Tank Age**	30	**Tank Installed Date**	10/01/1995	**Tank Material Construction**	Steel Clad	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	3040	**Spill Test Date**	05/12/2022	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	05/16/2022	**Tank/Piping CP Test Date**	05/16/2022	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	Yes

Capacity	8000	**ATG Test Date**	05/16/2022	**Line Tightness Test Date**	12/06/2021	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	05/16/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	06	**Tank Age**	30	**Tank Installed Date**	10/01/1995	**Tank Material Construction**	Steel Clad	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	3042	**Spill Test Date**	05/12/2022	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	05/16/2022	**Tank/Piping CP Test Date**	05/16/2022	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	Yes
Capacity	10000	**ATG Test Date**	05/16/2022	**Line Tightness Test Date**	01/13/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	05/16/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	05	**Tank Age**	30	**Tank Installed Date**	10/01/1995	**Tank Material Construction**	Steel Clad	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	4399	**Spill Test Date**	05/12/2022	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	05/16/2022	**Tank/Piping CP Test Date**	05/16/2022	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	Yes
Capacity	8000	**ATG Test Date**	05/16/2022	**Line Tightness Test Date**	12/22/2021	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	05/16/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Yellowstone County in the City of Billings

Location: CIRCLE K STORE 2746275
105 Broadwater Ave
Billings, MT 59101 Yellowstone

System Facility ID:56-08063

Facility Code: 30212
Last Inspected On: 06/14/2023
Operating Permit Renewal Date: 11/06/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Rocky Mountain Oil LLC	**(602) 728-8000**	**NT-ESS@Circlek.com**
Operator Contact:	Chuck Nyberg;Kegan Krueger;Lisa Pedersen;Patrick Patnaude;Valeria Jeffries;Veronica Rivera;Holiday Stationstore 275	**(406) 321-0938;(612) 830-8891;(952) 830-8721;(952) 830-8722**	**ESS-WestCoast@circlek.com;kegan.krueger@holidaycompanies.com;patrick.patnaude@holidaycompanies.com;redline5@usadig.com;valeria.jeffries@holidaycompanies.com**

Owner/Operator: Rocky Mountain Oil LLC	(602) 728-8000	NT-ESS@Circlek.com
Brad Lee, UST Class B Global Operator		brad.lee@holidaycompanies.com
Brad Lee, UST Class B Global Operator		brad.lee@holidaycompanies.com
Chuck Nyberg, UST Class A Operator		
Jeff Reed, UST Class B Global Operator		jeff.reed@holidaycompanies.com
Jeff Reed, UST Class B Global Operator		jeff.reed@holidaycompanies.com
Kegan Krueger, UST Class A Operator		kegan.krueger@holidaycompanies.com
Kegan Krueger, UST Class A Operator		kegan.krueger@holidaycompanies.com
Lisa Pedersen, UST Class A Operator		redline5@usadig.com
Lisa Pedersen, UST Class A Operator		redline5@usadig.com
Lisa Pedersen, UST Class B Operator		redline5@usadig.com
Lisa Pedersen, UST Class B Operator		redline5@usadig.com
Patrick Patnaude, UST Class A Operator		patrick.patnaude@holidaycompanies.com
Patrick Patnaude, UST Class A Operator		patrick.patnaude@holidaycompanies.com
Valeria Jeffries, UST Class A Operator		valeria.jeffries@holidaycompanies.com
Veronica Rivera, UST Class A Operator		ESS-WestCoast@circlek.com
Veronica Rivera, UST Class A Operator		ESS-WestCoast@circlek.com
Veronica Rivera, UST Class B Global Operator		ESS-WestCoast@circlek.com
Veronica Rivera, UST Class B Global Operator		ESS-WestCoast@circlek.com
Veronica Rivera, UST Class B Operator		ESS-WestCoast@circlek.com
Veronica Rivera, UST Class B Operator		ESS-WestCoast@circlek.com

Tank Number	05	**Tank Age**	30	**Tank Installed Date**	07/13/1995	**Tank Material Construction**	Steel Clad	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	3043	**Spill Test Date**	01/30/2024	**Piping Installed Date**	03/12/2021	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	03/12/2021	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible

Product	Gasoline	**PLLD Test Date**	05/31/2023	**Tank/Piping CP Test Date**	06/28/2019	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	Yes
Capacity	8000	**ATG Test Date**	05/31/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date	05/31/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	06	**Tank Age**	30	**Tank Installed Date**	07/13/1995	**Tank Material Construction**	Steel Clad	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	3044	**Spill Test Date**	01/30/2024	**Piping Installed Date**	03/12/2021	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	03/12/2021	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	05/31/2023	**Tank/Piping CP Test Date**	06/28/2019	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	Yes
Capacity	8000	**ATG Test Date**	05/31/2023	**Line Tightness Test Date**	02/17/2019	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date	05/31/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	07	**Tank Age**	30	**Tank Installed Date**	07/13/1995	**Tank Material Construction**	Steel Clad	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	3045	**Spill Test Date**	02/16/2024	**Piping Installed Date**	03/12/2021	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	03/12/2021	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	05/31/2023	**Tank/Piping CP Test Date**	06/28/2019	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	Yes
Capacity	8000	**ATG Test Date**	05/31/2023	**Line Tightness Test Date**	03/16/2020	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date	05/31/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	08	**Tank Age**	30	**Tank Installed Date**	07/13/1995	**Tank Material Construction**	Steel Clad	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	3046	**Spill Test Date**	02/16/2024	**Piping Installed Date**	03/12/2021	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	03/12/2021	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	05/31/2023	**Tank/Piping CP Test Date**	06/28/2019	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	Yes
Capacity	8000	**ATG Test Date**	05/31/2023	**Line Tightness Test Date**	03/16/2020	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No

		Overfill Test Date	05/31/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	09	**Tank Age**	30	**Tank Installed Date**	07/13/1995	**Tank Material Construction**	Steel Clad	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	3047	**Spill Test Date**	02/16/2024	**Piping Installed Date**	03/12/2021	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	03/12/2021	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	05/31/2023	**Tank/Piping CP Test Date**	06/28/2020	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	05/31/2023	**Line Tightness Test Date**	01/14/2020	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date	05/31/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Yellowstone County in the City of Billings

Location: CIRCLE K STORE 2746280
1020 Main St
Billings, MT 59105-2544 Yellowstone

System Facility ID:56-09695

Facility Code: 30314
Last Inspected On: 11/10/2022
Operating Permit Renewal Date: 11/28/2025

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Rocky Mountain Oil LLC	**(602) 728-8000**	**NT-ESS@Circlek.com**
Operator Contact:	Chuck Nyberg;Patrick Patnaude;Valeria Jeffries;Veronica Rivera	**(952) 830-8721;(952) 830-8722**	**ESS-WestCoast@circlek.com;patrick.patnaude@holidaycompanies.com;valeria.jeffries@holidaycompanies.com**

Owner/Operator: Rocky Mountain Oil LLC (602) 728-8000 NT-ESS@Circlek.com

Brad Lee, UST Class B Global Operator	brad.lee@holidaycompanies.com
Chuck Nyberg, UST Class A Operator	
Jeff Reed, UST Class B Global Operator	jeff.reed@holidaycompanies.com
Patrick Patnaude, UST Class A Operator	patrick.patnaude@holidaycompanies.com
Valeria Jeffries, UST Class A Operator	valeria.jeffries@holidaycompanies.com
Veronica Rivera, UST Class A Operator	ESS-WestCoast@circlek.com
Veronica Rivera, UST Class B Global Operator	ESS-WestCoast@circlek.com

Tank Number	01	**Tank Age**	38	**Tank Installed Date**	04/01/1987	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Steel	**Overfill Types**	Flapper Valve
Tag Number	3048	**Spill Test Date**	07/02/2021	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	10/03/2013	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**	07/07/2022	**Tank/Piping CP Test Date**	07/28/2022	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	Yes
Capacity	12000	**ATG Test Date**	07/07/2022	**Line Tightness Test Date**	08/24/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	06/29/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	02	**Tank Age**	38	**Tank Installed Date**	04/01/1987	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Steel	**Overfill Types**	Flapper Valve
Tag Number	3049	**Spill Test Date**	07/02/2021	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	10/03/2013	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**	07/07/2022	**Tank/Piping CP Test Date**	07/28/2022	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	Yes

Capacity	12000	**ATG Test Date**	07/07/2022	**Line Tightness Test Date**	05/07/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	06/29/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	03	**Tank Age**	38	**Tank Installed Date**	04/01/1987	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Steel	**Overfill Types**	Flapper Valve
Tag Number	3050	**Spill Test Date**	12/08/2021	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	10/03/2013	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**	07/07/2022	**Tank/Piping CP Test Date**	07/28/2022	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	Yes
Capacity	8000	**ATG Test Date**	07/07/2022	**Line Tightness Test Date**	08/15/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	06/29/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	04	**Tank Age**	38	**Tank Installed Date**	04/01/1987	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Steel	**Overfill Types**	Flapper Valve
Tag Number	3051	**Spill Test Date**	07/02/2021	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	10/03/2013	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Diesel	**PLLD Test Date**	07/07/2022	**Tank/Piping CP Test Date**	07/28/2022	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	07/07/2022	**Line Tightness Test Date**	08/05/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	06/29/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Yellowstone County in the City of Billings

Location: CIRCLE K STORE 2746284
3226 Rosebud Dr
Billings, MT 59102-6017 Yellowstone

System Facility ID:56-09752

Facility Code: 30326
Last Inspected On: 02/09/2023
Operating Permit Renewal Date: 05/30/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Rocky Mountain Oil LLC	**(602) 728-8000**	**NT-ESS@Circlek.com**
Operator Contact:	Valeria Jeffries;Veronica Rivera		**ESS-WestCoast@circlek.com;valeria.jeffries@holidaycompanies.com**

Owner/Operator:	Rocky Mountain Oil LLC	(602) 728-8000	NT-ESS@Circlek.com
	Brad Lee, UST Class B Global Operator		brad.lee@holidaycompanies.com
	Brad Lee, UST Class B Global Operator		brad.lee@holidaycompanies.com
	Jeff Reed, UST Class B Global Operator		jeff.reed@holidaycompanies.com
	Jeff Reed, UST Class B Global Operator		jeff.reed@holidaycompanies.com
	Teddi Matzen, UST Class B Operator		NT-ESS@Circlek.com
	Valeria Jeffries, UST Class A Operator		valeria.jeffries@holidaycompanies.com
	Veronica Rivera, UST Class A Operator		ESS-WestCoast@circlek.com
	Veronica Rivera, UST Class A Operator		ESS-WestCoast@circlek.com
	Veronica Rivera, UST Class B Operator		ESS-WestCoast@circlek.com
	Veronica Rivera, UST Class B Operator		ESS-WestCoast@circlek.com

Tank Number	01	**Tank Age**	42	**Tank Installed Date**	11/05/1983	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Steel	**Overfill Types**	Flapper Valve
Tag Number	3052	**Spill Test Date**	11/10/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**	06/02/2022	**Tank/Piping CP Test Date**	06/25/2021	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	Yes
Capacity	10000	**ATG Test Date**	06/02/2022	**Line Tightness Test Date**	08/23/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.1	**Energy Act**	No
		Overfill Test Date	06/02/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	02	**Tank Age**	42	**Tank Installed Date**	11/05/1983	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Steel	**Overfill Types**	Flapper Valve
Tag Number	3053	**Spill Test Date**	11/10/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current

Product	Gasoline	**PLLD Test Date**	06/02/2022	**Tank/Piping CP Test Date**	06/25/2021	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	Yes
Capacity	10000	**ATG Test Date**	06/02/2022	**Line Tightness Test Date**	07/10/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.1	**Energy Act**	No
		Overfill Test Date	06/02/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	03	**Tank Age**	42	**Tank Installed Date**	11/05/1983	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Steel	**Overfill Types**	Flapper Valve
Tag Number	3054	**Spill Test Date**	11/10/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**	06/02/2022	**Tank/Piping CP Test Date**	06/25/2021	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	Yes
Capacity	6000	**ATG Test Date**	06/02/2022	**Line Tightness Test Date**	08/05/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.1	**Energy Act**	No
		Overfill Test Date	06/02/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Yellowstone County in the City of Billings

Location: CIRCLE K STORE 2746285
785 S 20th St W
Billings, MT 59102-6463 Yellowstone

System Facility ID:56-09753

Facility Code: 30327
Last Inspected On: 09/28/2023
Operating Permit Renewal Date: 09/28/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Rocky Mountain Oil LLC	**(602) 728-8000**	**NT-ESS@Circlek.com**
Operator Contact:	Veronica Rivera		**ESS-WestCoast@circlek.com**

Owner/Operator: Rocky Mountain Oil LLC (602) 728-8000 NT-ESS@Circlek.com

Jeff Reed, UST Class B Global Operator	jeff.reed@holidaycompanies.com
Jeff Reed, UST Class B Global Operator	jeff.reed@holidaycompanies.com
Leonard Slemp, UST Class B Global Operator	leonardslemp@gmail.com
Leonard Slemp, UST Class B Global Operator	leonardslemp@gmail.com
Veronica Rivera, UST Class A Operator	ESS-WestCoast@circlek.com
Veronica Rivera, UST Class A Operator	ESS-WestCoast@circlek.com

Tank Number	05	**Tank Age**	28	**Tank Installed Date**	04/01/1997	**Tank Material Construction**	Steel Clad	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve;High Level Alarm
Tag Number	3055	**Spill Test Date**	09/28/2023	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Gasoline	**PLLD Test Date**	09/28/2023	**Tank/Piping CP Test Date**	09/28/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	Yes
Capacity	8000	**ATG Test Date**	09/28/2023	**Line Tightness Test Date**	05/15/2020	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	09/28/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	06	**Tank Age**	28	**Tank Installed Date**	04/01/1997	**Tank Material Construction**	Steel Clad	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve;High Level Alarm
Tag Number	3056	**Spill Test Date**	09/28/2023	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Gasoline	**PLLD Test Date**	09/28/2023	**Tank/Piping CP Test Date**	09/28/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	Yes

Capacity	8000	**ATG Test Date**	09/28/2023	**Line Tightness Test Date**	05/15/2020	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	09/28/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	07	**Tank Age**	28	**Tank Installed Date**	04/01/1997	**Tank Material Construction**	Steel Clad	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve;High Level Alarm
Tag Number	3057	**Spill Test Date**	09/28/2023	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Gasoline	**PLLD Test Date**	09/28/2023	**Tank/Piping CP Test Date**	09/28/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	Yes
Capacity	8000	**ATG Test Date**	09/28/2023	**Line Tightness Test Date**	03/12/2020	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	09/28/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	08	**Tank Age**	28	**Tank Installed Date**	04/01/1997	**Tank Material Construction**	Steel Clad	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve;High Level Alarm
Tag Number	3058	**Spill Test Date**	03/29/2024	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Gasoline	**PLLD Test Date**	09/28/2023	**Tank/Piping CP Test Date**	09/28/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	Yes
Capacity	8000	**ATG Test Date**	09/28/2023	**Line Tightness Test Date**	03/28/2020	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	09/28/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	09	**Tank Age**	28	**Tank Installed Date**	04/01/1997	**Tank Material Construction**	Steel Clad	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve;High Level Alarm
Tag Number	3059	**Spill Test Date**	09/28/2023	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Diesel	**PLLD Test Date**	09/28/2023	**Tank/Piping CP Test Date**	09/28/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	09/28/2023	**Line Tightness Test Date**	03/28/2020	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	09/28/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Yellowstone County in the City of Billings

Location: CIRCLE K STORE 2746385
3551 Ember Ln
Billings, MT 59102 Yellowstone

System Facility ID:60-15065

Facility Code: 30837
Last Inspected On: 01/28/2025
Operating Permit Renewal Date: 05/20/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Rocky Mountain Oil LLC	**(602) 728-8000**	**NT-ESS@Circlek.com**
Operator Contact:	Patrick Patnaude;Valeria Jeffries;Veronica Rivera	**(952) 830-8721**	**ESS-WestCoast@circlek.com;patrick.patnaude@holidaycompanies.com;valeria.jeffries@holidaycompanies.com**

Owner/Operator: Rocky Mountain Oil LLC (602) 728-8000 NT-ESS@Circlek.com

Jeff Luedtke, UST Class B Global Operator	jeffry4941@yahoo.com
Jeff Reed, UST Class B Global Operator	jeff.reed@holidaycompanies.com
Patrick Patnaude, UST Class A Operator	patrick.patnaude@holidaycompanies.com
Valeria Jeffries, UST Class A Operator	valeria.jeffries@holidaycompanies.com
Veronica Rivera, UST Class A Operator	ESS-WestCoast@circlek.com
Veronica Rivera, UST Class B Global Operator	ESS-WestCoast@circlek.com

Tank Number	01	**Tank Age**	18	**Tank Installed Date**	12/11/2007	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve;Flapper Valve
Tag Number	5139	**Spill Test Date**	05/13/2021	**Piping Installed Date**	07/12/2007	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	05/16/2022	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	Yes
Capacity	20000	**ATG Test Date**	05/16/2022	**Line Tightness Test Date**	11/01/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	05/16/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	02	**Tank Age**	18	**Tank Installed Date**	12/11/2007	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve;Flapper Valve
Tag Number	5140	**Spill Test Date**	05/13/2021	**Piping Installed Date**	07/12/2007	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	05/16/2022	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	Yes

Capacity	12000	**ATG Test Date**	05/16/2022	**Line Tightness Test Date**	10/22/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	05/16/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	03	**Tank Age**	18	**Tank Installed Date**	12/11/2007	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve;Flapper Valve
Tag Number	5141	**Spill Test Date**	05/13/2021	**Piping Installed Date**	07/12/2007	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	05/16/2022	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	Yes
Capacity	8000	**ATG Test Date**	05/16/2022	**Line Tightness Test Date**	10/24/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	05/16/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	04	**Tank Age**	18	**Tank Installed Date**	12/11/2007	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve;Flapper Valve
Tag Number	5142	**Spill Test Date**	05/13/2021	**Piping Installed Date**	07/12/2007	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	05/16/2022	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	05/16/2022	**Line Tightness Test Date**	10/29/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	05/16/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	05	**Tank Age**	18	**Tank Installed Date**	12/11/2007	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve;Flapper Valve
Tag Number	5143	**Spill Test Date**	05/13/2021	**Piping Installed Date**	07/12/2007	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	05/16/2022	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	05/16/2022	**Line Tightness Test Date**	10/29/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	05/16/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Tank Number	06	**Tank Age**	1	**Tank Installed Date**	05/15/2024	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	6237	**Spill Test Date**	06/14/2024	**Piping Installed Date**	05/15/2024	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	06/14/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	20000	**ATG Test Date**	06/14/2024	**Line Tightness Test Date**	06/18/2024	**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	08/20/2024			**ATG Type**					
Tank Number	07	**Tank Age**	1	**Tank Installed Date**	05/15/2024	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	
Tag Number	6238	**Spill Test Date**		**Piping Installed Date**	08/01/2024	**Tank Construction**		**Piping Construction**		**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**		**Piping Type**	Pressurized	**CP Met Types**	
Product	DEF (Not Regulated)	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	Yes
		Overfill Test Date				**ATG Type**					

Facility Summary in Yellowstone County in the City of Billings

Location: CIRCLE K STORE 2746470
1212 Mullowney Ln
Billings, MT 59102 Yellowstone

System Facility ID:60-15327

Facility Code: 31023
Last Inspected On: 09/23/2022
Operating Permit Renewal Date: 12/17/2025

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Rocky Mountain Oil LLC	**(602) 728-8000**	**NT-ESS@Circlek.com**
Operator Contact:	Chuck Nyberg;Veronica Rivera	**(952) 830-8722**	**ESS-WestCoast@circlek.com**

Owner/Operator: Rocky Mountain Oil LLC (602) 728-8000 NT-ESS@Circlek.com

Chuck Nyberg, UST Class A Operator
Teddi Matzen, UST Class B Global Operator smoogo14@hotmail.com
Veronica Rivera, UST Class A Operator ESS-WestCoast@circlek.com
Veronica Rivera, UST Class B Global Operator ESS-WestCoast@circlek.com

Tank Number	01	**Tank Age**	7	**Tank Installed Date**	11/15/2018	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	5880	**Spill Test Date**	08/05/2021	**Piping Installed Date**	11/15/2018	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	08/05/2021	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	20000	**ATG Test Date**	08/04/2022	**Line Tightness Test Date**	07/28/2022	**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	08/19/2022			**ATG Type**	Incon/TS-550 EVO				
Tank Number	02	**Tank Age**	7	**Tank Installed Date**	11/15/2018	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	5881	**Spill Test Date**	08/05/2021	**Piping Installed Date**	11/15/2018	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	08/05/2021	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	08/04/2022	**Line Tightness Test Date**	07/28/2022	**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	08/19/2022			**ATG Type**	Incon/TS-550 EVO				

Tank Number	03	**Tank Age**	7	**Tank Installed Date**	11/15/2018	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	5882	**Spill Test Date**	08/05/2021	**Piping Installed Date**	11/15/2018	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	08/05/2021	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	08/04/2022	**Line Tightness Test Date**	07/28/2022	**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	08/19/2022			**ATG Type**	Incon/TS-550 EVO				
Tank Number	04	**Tank Age**	7	**Tank Installed Date**	11/15/2018	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	5883	**Spill Test Date**	08/05/2021	**Piping Installed Date**	11/15/2018	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	08/05/2021	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	08/04/2022	**Line Tightness Test Date**	07/28/2022	**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	08/19/2022			**ATG Type**	Incon/TS-550 EVO				

Facility Summary in Yellowstone County in the City of Billings

Location: CIRCLE K STORE 2746731
1280 Grand Ave
Billings, MT 59102 Yellowstone

System Facility ID:56-14090

Facility Code: 30741
Last Inspected On: 06/13/2024
Operating Permit Renewal Date: 10/01/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Rocky Mountain Oil LLC	**(602) 728-8000**	**NT-ESS@Circlek.com**
Operator Contact:	Chuck Nyberg;Patrick Patnaude;Valeria Jeffries;Veronica Rivera	**(952) 830-8721;(952) 830-8722**	**ESS-WestCoast@circlek.com;patrick.patnaude@holidaycompanies.com;valeria.jeffries@holidaycompanies.com**

Owner/Operator: Rocky Mountain Oil LLC (602) 728-8000 NT-ESS@Circlek.com

Brad Lee, UST Class B Operator	brad.lee@holidaycompanies.com
Chuck Nyberg, UST Class A Operator	
Jeff Reed, UST Class B Operator	jeff.reed@holidaycompanies.com
Patrick Patnaude, UST Class A Operator	patrick.patnaude@holidaycompanies.com
Valeria Jeffries, UST Class A Operator	valeria.jeffries@holidaycompanies.com
Veronica Rivera, UST Class A Operator	ESS-WestCoast@circlek.com
Veronica Rivera, UST Class B Operator	ESS-WestCoast@circlek.com

Tank Number	01	**Tank Age**	22	**Tank Installed Date**	06/24/2003	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	4844	**Spill Test Date**	06/13/2024	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	06/13/2024	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	15000	**ATG Test Date**	06/13/2024	**Line Tightness Test Date**	02/16/2021	**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	06/13/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	02	**Tank Age**	22	**Tank Installed Date**	06/24/2003	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	4845	**Spill Test Date**	06/13/2024	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	06/13/2024	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No

Capacity	10000	**ATG Test Date**	06/13/2024	**Line Tightness Test Date**	02/16/2021	**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	06/13/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	03	**Tank Age**	22	**Tank Installed Date**	06/24/2003	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	4846	**Spill Test Date**	06/13/2024	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	06/13/2024	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	5000	**ATG Test Date**	06/13/2024	**Line Tightness Test Date**	02/07/2021	**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	06/13/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Yellowstone County in the City of Billings

Location: CITY OF BILLINGS OPERATION CENTER
4848 Midland Rd
Billings, MT 59101 Yellowstone

System Facility ID:56-14118

Facility Code: 30759
Last Inspected On: 07/08/2022
Operating Permit Renewal Date: 12/10/2025

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: City of Billings Operation Center

Operator Contact: Corey Leonhardt;Mark Balter;Nick Westburg **balterm@billingsmt.gov;leonhardtc@billingsmt.gov;westburgn@billingsmt.gov**

Owner/Operator: City of Billings Operation Center

Corey Leonhardt, UST Class A Operator	leonhardtc@billingsmt.gov
Corey Leonhardt, UST Class B Global Operator	leonhardtc@billingsmt.gov
Mark Balter, UST Class A Operator	balterm@billingsmt.gov
Nick Westburg, UST Class A Operator	westburgn@billingsmt.gov
Nick Westburg, UST Class B Operator	westburgn@billingsmt.gov

Tank Number	01	**Tank Age**	21	**Tank Installed Date**	07/09/2004	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve;Flapper Valve
Tag Number	4935	**Spill Test Date**	07/08/2022	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	07/08/2022	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	07/08/2022	**Line Tightness Test Date**	01/21/2022	**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	11/28/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350;Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	02	**Tank Age**	21	**Tank Installed Date**	07/09/2004	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve;Flapper Valve
Tag Number	4936	**Spill Test Date**	07/08/2022	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible

Product	Diesel	**PLLD Test Date**	07/08/2022	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	07/08/2022	**Line Tightness Test Date**	01/25/2022	**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	11/28/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350;Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	03	**Tank Age**	21	**Tank Installed Date**	07/09/2004	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve;Flapper Valve
Tag Number	4937	**Spill Test Date**	07/08/2022	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	07/08/2022	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	5000	**ATG Test Date**	07/08/2022	**Line Tightness Test Date**	01/15/2022	**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	11/28/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350;Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	04	**Tank Age**	21	**Tank Installed Date**	07/09/2004	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve;Flapper Valve
Tag Number	4938	**Spill Test Date**	07/08/2022	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	07/08/2022	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	5000	**ATG Test Date**	07/08/2022	**Line Tightness Test Date**	01/13/2022	**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	11/28/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350;Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Yellowstone County in the City of Billings

Location: CITY OF BILLINGS PUBLIC WORKS DEPARTMENT
2251 Belknap Ave
Billings, MT 59101-5706 Yellowstone

System Facility ID:56-09746

Facility Code: 30324
Last Inspected On: 12/08/2023
Operating Permit Renewal Date: 03/14/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	City of Billings Public Works	**(406) 657-8335**	**diedrichl@ci.billings.mt.us**
Operator Contact:	Amanda Skewis;Scott Emerick	**(406) 657-8345**	**emericks@billingsmt.gov;skewisa@billingsmt.gov**

Owner/Operator: City of Billings Public Works (406) 657-8335 diedrichl@ci.billings.mt.us

Amanda Skewis, UST Class A Operator	skewisa@billingsmt.gov
Amanda Skewis, UST Class B Operator	skewisa@billingsmt.gov
Misty Gran, UST Class B Operator	granm@billingsmt.gov
Scott Emerick, UST Class A Operator	emericks@billingsmt.gov
Scott Emerick, UST Class B Operator	emericks@billingsmt.gov

Tank Number	04	**Tank Age**	35	**Tank Installed Date**	01/01/1990	**Tank Material Construction**	Steel Clad	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	631	**Spill Test Date**	12/08/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	12/08/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	10/06/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	12/08/2023			**ATG Type**	Gilbarco/EMC Basic				
Tank Number	05	**Tank Age**	35	**Tank Installed Date**	01/01/1990	**Tank Material Construction**	Steel Clad	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	632	**Spill Test Date**	12/08/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	12/08/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	10/06/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	12/08/2023			**ATG Type**	Gilbarco/EMC Basic				

Facility Summary in Yellowstone County in the City of Billings

Location: CITY SERVICE VALCON CARDLOCK 3
1004 4th Ave N
Billings, MT 59101 Yellowstone

System Facility ID:56-01290

Facility Code: 29764
Last Inspected On: 06/03/2022
Operating Permit Renewal Date: 08/16/2025

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: W G Properties LLC **(406) 651-5101**

Operator Contact: Roger Schmechel **(406) 208-3147** **rogers@cityservicevalcon.com**

Owner/Operator: W G Properties LLC (406) 651-5101

Roger Schmechel, UST Class A Operator	rogers@cityservicevalcon.com
Roger Schmechel, UST Class A Operator	rogers@cityservicevalcon.com
Roger Schmechel, UST Class B Global Operator	rogers@cityservicevalcon.com
Roger Schmechel, UST Class B Global Operator	rogers@cityservicevalcon.com

Tank Number	D-1	**Tank Age**	49	**Tank Installed Date**	02/04/1976	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	752	**Spill Test Date**	06/03/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	06/03/2022	**Catastrophic L.D. Type 3.0**	Continuous Interstitial Monitoring	**Piping Type**	Not Listed	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	07/08/2013	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	20000	**ATG Test Date**	06/03/2022	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	06/03/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	D-2	**Tank Age**	49	**Tank Installed Date**	01/01/1976	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	753	**Spill Test Date**	06/03/2022	**Piping Installed Date**	09/12/2003	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	06/03/2022	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel, Dyed	**PLLD Test Date**	05/27/2022	**Tank/Piping CP Test Date**	07/08/2013	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	20000	**ATG Test Date**	06/03/2022	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No

		Overfill Test Date	07/28/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	D-3	**Tank Age**	49	**Tank Installed Date**	02/04/1976	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	754	**Spill Test Date**	06/03/2022	**Piping Installed Date**	09/12/2003	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	06/03/2022	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	05/27/2022	**Tank/Piping CP Test Date**	07/08/2013	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	20000	**ATG Test Date**	06/03/2022	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	07/28/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	D-4	**Tank Age**	49	**Tank Installed Date**	02/04/1976	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	755	**Spill Test Date**	06/03/2022	**Piping Installed Date**	09/12/2003	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	06/03/2022	**Catastrophic L.D. Type 3.0**	Continuous Interstitial Monitoring	**Piping Type**	Not Listed	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	07/08/2013	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	20000	**ATG Test Date**	06/03/2022	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	07/28/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	D-5	**Tank Age**	49	**Tank Installed Date**	02/04/1976	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	756	**Spill Test Date**	06/03/2022	**Piping Installed Date**	09/12/2003	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	06/03/2022	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	05/27/2022	**Tank/Piping CP Test Date**	07/08/2013	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	20000	**ATG Test Date**	06/03/2022	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	07/29/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Yellowstone County in the City of Billings

Location: CONOMART SUPERSTORE 10
11 W Wicks Ln
Billings, MT 59105 Yellowstone

System Facility ID:56-05088

Facility Code: 30006
Last Inspected On: 09/20/2023
Operating Permit Renewal Date: 03/03/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Superpumper Inc **(701) 852-1194**

Operator Contact: Vern Patterson;Parkland USA Corporation **(701) 720-6649;(701) 852-1194** **vern.patterson@parklandusa.com;Jake.thomas@parklandusa.com**

Owner/Operator: Superpumper Inc (701) 852-1194

Curtis McBride, UST Class B Operator Jake.thomas@parklandusa.com
Vern Patterson, UST Class A Operator Jake.thomas@parklandusa.com
Vern Patterson, UST Class B Operator Jake.thomas@parklandusa.com

Tank Number	03	**Tank Age**	35	**Tank Installed Date**	11/16/1990	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	1154	**Spill Test Date**	09/20/2023	**Piping Installed Date**	12/15/2009	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	01/13/2022	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**	03/17/2023	**Tank/Piping CP Test Date**	09/20/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	03/17/2023	**Line Tightness Test Date**	09/03/2020	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date	03/17/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	04	**Tank Age**	35	**Tank Installed Date**	11/16/1990	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	1155	**Spill Test Date**	09/20/2023	**Piping Installed Date**	12/15/2009	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	01/13/2022	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**	03/17/2023	**Tank/Piping CP Test Date**	09/20/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	03/17/2023	**Line Tightness Test Date**	09/01/2020	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No

		Overfill Test Date	03/17/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	05	**Tank Age**	35	**Tank Installed Date**	11/16/1990	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	1156	**Spill Test Date**	09/20/2023	**Piping Installed Date**	12/15/2009	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	01/13/2022	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**	03/17/2023	**Tank/Piping CP Test Date**	09/20/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**	03/17/2023	**Line Tightness Test Date**	09/07/2020	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date	03/17/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Yellowstone County in the City of Billings

Location: CONOMART SUPERSTORE 10035-Billings
1219 Main St
Billings, MT 59105-2539 Yellowstone

System Facility ID:56-06948

Facility Code: 30138
Last Inspected On: 08/15/2023
Operating Permit Renewal Date: 08/15/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Beehive Property Holdings LLC	**(856) 298-1310**	**documents@beehivefuels.com**
Operator Contact:	Vern Patterson;Parkland USA Corporation	**(701) 720-6649;(701) 852-1194**	**vern.patterson@parklandusa.com;Jake.thomas@parklandusa.com**

Owner/Operator: Beehive Property Holdings LLC (856) 298-1310 documents@beehivefuels.com

Curtis McBride, UST Class B Operator Jake.thomas@parklandusa.com
Vern Patterson, UST Class A Operator Jake.thomas@parklandusa.com
Vern Patterson, UST Class B Operator Jake.thomas@parklandusa.com

Tank Number	01	**Tank Age**	49	**Tank Installed Date**	04/21/1976	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	3618	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**	Lined Interior/Impressed Current	**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**	10/06/2023	**Tank/Piping CP Test Date**	06/20/2020	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	10/06/2023	**Line Tightness Test Date**	09/16/2020	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	10/06/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	02	**Tank Age**	54	**Tank Installed Date**	04/22/1971	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	3619	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**	Lined Interior/Impressed Current	**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Diesel	**PLLD Test Date**	10/06/2023	**Tank/Piping CP Test Date**	06/20/2020	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	10/06/2023	**Line Tightness Test Date**	08/03/2020	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No

		Overfill Test Date	10/06/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	03	**Tank Age**	54	**Tank Installed Date**	04/22/1971	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	3620	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**	Lined Interior/Impressed Current	**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**	10/06/2023	**Tank/Piping CP Test Date**	06/20/2020	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	10/06/2023	**Line Tightness Test Date**	04/15/2020	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	10/06/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Yellowstone County in the City of Billings

Location: CONOMART SUPERSTORE 7
4903 Southgate Dr
Billings, MT 59101-4668 Yellowstone

System Facility ID:56-13808

Facility Code: 30495
Last Inspected On: 08/15/2022
Operating Permit Renewal Date: 12/31/2025

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Superpumper Inc **(701) 852-1194**

Operator Contact: Vern Patterson;Parkland USA Corporation **(701) 720-6649;(701) 852-1194** **vern.patterson@parklandusa.com;Jake.thomas@parklandusa.com**

Owner/Operator: Superpumper Inc (701) 852-1194

Curtis McBride, UST Class B Operator
Curtis McBride, UST Class B Operator
Curtis McBride, UST Class B Operator Jake.thomas@parklandusa.com
Vern Patterson, UST Class A Operator Jake.thomas@parklandusa.com
Vern Patterson, UST Class B Operator Jake.thomas@parklandusa.com

Tank Number	01	**Tank Age**	28	**Tank Installed Date**	12/05/1997	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	1182	**Spill Test Date**	12/29/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	06/01/2022	**Tank/Piping CP Test Date**	05/29/2013	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	06/01/2022	**Line Tightness Test Date**	08/09/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	06/01/2022			**ATG Type**	Gilbarco/EMC Basic				
Tank Number	02	**Tank Age**	28	**Tank Installed Date**	12/05/1997	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	1183	**Spill Test Date**	08/23/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	06/01/2022	**Tank/Piping CP Test Date**	05/29/2013	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	06/01/2022	**Line Tightness Test Date**	08/11/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No

		Overfill Test Date	06/01/2022			**ATG Type**	Gilbarco/EMC Basic				
Tank Number	03	**Tank Age**	27	**Tank Installed Date**	12/05/1998	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	1184	**Spill Test Date**	08/23/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	06/01/2022	**Tank/Piping CP Test Date**	05/29/2013	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	06/01/2022	**Line Tightness Test Date**	08/07/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	06/01/2022			**ATG Type**	Gilbarco/EMC Basic				

Facility Summary in Yellowstone County in the City of Billings

Location: COSTCO BILLINGS LOC 1644
3800 Zoo Drive
Billings, MT 59102 Yellowstone

System Facility ID:00-32511

Facility Code: 32511
Last Inspected On: 02/14/2024
Operating Permit Renewal Date: 04/23/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Costco Wholesale Corporation Seattle	**(425) 313-8100**	**gaslicenses@costco.com**
Operator Contact:	Keaton Leuthold;Lyssa Logan;Costco Wholesale;Shawn Kipp;Costco Wholesale	**(406) 652-8765;(406) 671-7789;(425) 251-6222;(406) 672-3253;(425) 251-6222**	**w069gas@costco.com;w069gas@costco.com;gaslicenses@costco.com**

Owner/Operator:	Costco Wholesale Corporation Seattle	(425) 313-8100	gaslicenses@costco.com
	Keaton Leuthold, UST Class A Operator		w069gas@costco.com
	Keaton Leuthold, UST Class A Operator		w069gas@costco.com
	Keaton Leuthold, UST Class B Operator		w069gas@costco.com
	Keaton Leuthold, UST Class B Operator		w069gas@costco.com
	Lyssa Logan, UST Class A Operator		gaslicenses@costco.com
	Lyssa Logan, UST Class B Operator		gaslicenses@costco.com
	Shawn Kipp, UST Class A Operator		gaslicenses@costco.com
	Shawn Kipp, UST Class B Operator		gaslicenses@costco.com

Tank Number	01	**Tank Age**	2	**Tank Installed Date**	10/12/2023	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	6141	**Spill Test Date**	10/02/2023	**Piping Installed Date**	10/12/2023	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	10/02/2023	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Gasoline	**PLLD Test Date**	10/02/2023	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	Yes
Capacity	40000	**ATG Test Date**	10/02/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.1	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	10/02/2023			**ATG Type**					
Tank Number	02	**Tank Age**	2	**Tank Installed Date**	10/12/2023	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	6142	**Spill Test Date**	10/02/2023	**Piping Installed Date**	10/12/2023	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	10/02/2023	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	

Product	Gasoline	**PLLD Test Date**	10/02/2023	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	Yes
Capacity	40000	**ATG Test Date**	10/02/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.1	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	10/02/2023			**ATG Type**					
Tank Number	03	**Tank Age**	2	**Tank Installed Date**	10/12/2023	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	6143	**Spill Test Date**	10/02/2023	**Piping Installed Date**	10/12/2023	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	10/02/2023	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Gasoline	**PLLD Test Date**	10/02/2023	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	Yes
Capacity	40000	**ATG Test Date**	10/02/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.1	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	10/02/2023			**ATG Type**					
Tank Number	04	**Tank Age**	2	**Tank Installed Date**	10/12/2023	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	6144	**Spill Test Date**	10/02/2023	**Piping Installed Date**	10/12/2023	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	10/02/2023	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Hazardous Substance	**PLLD Test Date**	10/02/2023	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	1500	**ATG Test Date**	10/02/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	10/02/2023			**ATG Type**					
Tank Number	05	**Tank Age**	2	**Tank Installed Date**	10/12/2023	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	6179	**Spill Test Date**	10/02/2023	**Piping Installed Date**	10/12/2023	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	10/02/2023	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Diesel	**PLLD Test Date**	10/02/2023	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	20000	**ATG Test Date**	10/02/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	10/02/2023			**ATG Type**					

Tank Number	06	**Tank Age**	2	**Tank Installed Date**	10/12/2023	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	6180	**Spill Test Date**	10/02/2023	**Piping Installed Date**	10/12/2023	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	10/02/2023	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Hazardous Substance	**PLLD Test Date**	10/02/2023	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	1500	**ATG Test Date**	10/02/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	10/02/2023			**ATG Type**					

Facility Summary in Yellowstone County in the City of Billings

Location: COSTCO WHOLESALE GASOLINE 69
2290 King Ave W
Billings, MT 59102 Yellowstone

System Facility ID:56-13953

Facility Code: 30621
Last Inspected On: 01/17/2022
Operating Permit Renewal Date: 04/01/2025

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Costco Wholesale	**(425) 251-6222**	**gaslicenses@costco.com**
Operator Contact:	Keaton Leuthold;Shawn Kipp	**(406) 652-8765;(406) 671-7789**	**w069gas@costco.com**

Keaton Leuthold, UST Class A Operator	w069gas@costco.com
Keaton Leuthold, UST Class A Operator	w069gas@costco.com
Keaton Leuthold, UST Class B Global Operator	w069gas@costco.com
Keaton Leuthold, UST Class B Global Operator	w069gas@costco.com
Keaton Leuthold, UST Class B Operator	w069gas@costco.com
Keaton Leuthold, UST Class B Operator	w069gas@costco.com
Shawn Kipp, UST Class A Operator	w069gas@costco.com
Shawn Kipp, UST Class B Operator	w069gas@costco.com

Tank Number	01	**Tank Age**	26	**Tank Installed Date**	10/01/1999	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	4109	**Spill Test Date**	06/07/2019	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**	09/20/2019	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	09/16/2021	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	Yes
Capacity	60000	**ATG Test Date**	09/16/2021	**Line Tightness Test Date**	09/16/2021	**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	09/16/2021			**ATG Type**	Gilbarco-Veeder Root/TLS-350;Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	02	**Tank Age**	26	**Tank Installed Date**	10/01/1999	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	4110	**Spill Test Date**	06/07/2019	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**	09/20/2019	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible

Product	Gasoline	**PLLD Test Date**	09/16/2021	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	Yes
Capacity	30000	**ATG Test Date**	09/16/2021	**Line Tightness Test Date**	09/16/2021	**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	09/16/2021			**ATG Type**	Gilbarco-Veeder Root/TLS-350;Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	03	**Tank Age**	26	**Tank Installed Date**	10/01/1999	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	4111	**Spill Test Date**	06/07/2019	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**	09/20/2019	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	09/16/2021	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	30000	**ATG Test Date**	09/16/2021	**Line Tightness Test Date**	09/16/2021	**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	09/16/2021			**ATG Type**	Gilbarco-Veeder Root/TLS-350;Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	S4	**Tank Age**	14	**Tank Installed Date**	04/01/2011	**Tank Material Construction**	Concrete	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	5354	**Spill Test Date**		**Piping Installed Date**	07/19/2012	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	Yes
Status	**Permanently Out of Use**	**MLLD Test Date**	09/16/2021	**Sump Tightness Test Date**	09/20/2019	**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Hazardous Substance	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	2400	**ATG Test Date**	09/16/2021	**Line Tightness Test Date**	09/16/2021	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	MLLD Line Tightness Testing	**Energy Act**	Yes
		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/TLS-350;Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Yellowstone County in the City of Billings

Location: DEACONESS BILLINGS CLINIC 9TH AVE
2800 10th Ave N
Billings, MT 59101-0703 Yellowstone

System Facility ID:56-02067

Facility Code: 29806
Last Inspected On: 04/26/2024
Operating Permit Renewal Date: 09/29/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Deaconess Clinic Billings	**(406) 657-4036**	**mgoplen@billingsclinic.org**
Operator Contact:	Dana Block;Deaconess Clinic Billings	**(406) 657-4036**	**dblock1@billingsclinic.org;mgoplen@billingsclinic.org**

Owner/Operator: Deaconess Clinic Billings (406) 657-4036 mgoplen@billingsclinic.org

Dana Block, UST Class A Operator mgoplen@billingsclinic.org

Dana Block, UST Class B Operator mgoplen@billingsclinic.org

Tank Number	02	**Tank Age**	33	**Tank Installed Date**	02/01/1992	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	826	**Spill Test Date**	03/28/2024	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	03/27/2025	**Catastrophic L.D. Type 3.0**	Auto Dialer	**Piping Type**	U.S. Suction	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	03/28/2024	**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	03/28/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	03/28/2024			**ATG Type**	Gilbarco-Veeder Root/Other				

Facility Summary in Yellowstone County in the City of Billings

Location: DONS CAR WASH
1433 Main St
Billings, MT 59105-1739 Yellowstone

System Facility ID:56-05755

Facility Code: 30058
Last Inspected On: 04/14/2023
Operating Permit Renewal Date: 10/14/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Automatic Car Wash Inc **donscarwashmt@gmail.com**

Operator Contact: Gene Carlson **(406) 248-2558** **donscarwashmt@gmail.com**

Owner/Operator: Automatic Car Wash Inc donscarwashmt@gmail.com

Gene Carlson, UST Class A Operator donscarwashmt@gmail.com

Gene Carlson, UST Class B Operator donscarwashmt@gmail.com

Tank Number	04	**Tank Age**	20	**Tank Installed Date**	11/10/2005	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve
Tag Number	5030	**Spill Test Date**	04/14/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**	03/10/2023	**Tank/Piping CP Test Date**	04/14/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	03/10/2023	**Line Tightness Test Date**	08/09/2020	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	04/14/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	05	**Tank Age**	20	**Tank Installed Date**	11/10/2005	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve
Tag Number	5031	**Spill Test Date**	04/14/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**	03/10/2023	**Tank/Piping CP Test Date**	04/14/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**	03/10/2023	**Line Tightness Test Date**	08/11/2020	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	04/14/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Tank Number	06	**Tank Age**	20	**Tank Installed Date**	11/10/2005	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve
Tag Number	5032	**Spill Test Date**	04/14/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**	03/10/2023	**Tank/Piping CP Test Date**	04/14/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**	03/10/2023	**Line Tightness Test Date**	08/11/2020	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	04/14/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Yellowstone County in the City of Billings

Location: DONS CAR WASH 1ST AVE
1924 1st Ave N
Billings, MT 59101-2443 Yellowstone

System Facility ID:56-06956

Facility Code: 30143
Last Inspected On: 09/27/2023
Operating Permit Renewal Date: 09/27/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Automatic Car Wash Inc		**donscarwashmt@gmail.com**
Operator Contact:	Eric Carlson;Gene Carlson	**(406) 248-2558;(406) 894-2373**	**donscarwashmt@gmail.com;donsxpress24@outlook.com**

Owner/Operator: Automatic Car Wash Inc — donscarwashmt@gmail.com

Dick Berg, UST Class B Operator	donscarwash@bresnan.net
Dick Berg, UST Class B Operator	donscarwash@bresnan.net
Eric Carlson, UST Class A Operator	donsxpress24@outlook.com
Eric Carlson, UST Class B Operator	donsxpress24@outlook.com
Gene Carlson, UST Class A Operator	donscarwashmt@gmail.com
Gene Carlson, UST Class B Global Operator	donscarwashmt@gmail.com
Gene Carlson, UST Class B Operator	donscarwashmt@gmail.com

Tank Number	05	**Tank Age**	37	**Tank Installed Date**	11/11/1988	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	412	**Spill Test Date**	09/27/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	09/27/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	03/10/2023	**Line Tightness Test Date**	10/12/2020	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	03/10/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	06	**Tank Age**	37	**Tank Installed Date**	11/11/1988	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	413	**Spill Test Date**	09/27/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	09/27/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No

Capacity	6000	**ATG Test Date**	03/10/2023	**Line Tightness Test Date**	10/12/2020	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	03/10/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	07	**Tank Age**	37	**Tank Installed Date**	11/11/1988	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	414	**Spill Test Date**	09/27/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	09/27/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**	03/10/2023	**Line Tightness Test Date**	10/12/2020	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	03/10/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Yellowstone County in the City of Billings

Location: DONS CAR WASH CENTRAL AVE
2343 Central Ave
Billings, MT 59102 Yellowstone

System Facility ID:56-05492

Facility Code: 30029
Last Inspected On: 11/07/2017
Operating Permit Renewal Date: 04/11/2019

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Automatic Car Wash Inc		**donscarwashmt@gmail.com**
Operator Contact:	Gene Carlson	**(406) 248-2558**	**donscarwashmt@gmail.com**

Gene Carlson, UST Class A Operator	donscarwashmt@gmail.com
Gene Carlson, UST Class B Operator	donscarwashmt@gmail.com
Jamie Gehring, UST Class B Operator	donscarwash@bresnan.net
Jamie Gehring, UST Class B Operator	donscarwash@bresnan.net

Tank Number	04	**Tank Age**	35	**Tank Installed Date**	05/01/1990	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	409	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	11/07/2017	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	20000	**ATG Test Date**		**Line Tightness Test Date**	04/17/2017	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD Line Tightness Testing	**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	06	**Tank Age**	35	**Tank Installed Date**	05/01/1990	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	411	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	11/07/2017	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**		**Line Tightness Test Date**	11/06/2017	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD Line Tightness Testing	**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Tank Number	05	**Tank Age**	35	**Tank Installed Date**	05/01/1990	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	4467	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	11/07/2017	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	20000	**ATG Test Date**		**Line Tightness Test Date**	11/06/2017	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD Line Tightness Testing	**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Yellowstone County in the City of Billings

Location: DONS CAR WASH GRAND AVE
1121 Grand Ave
Billings, MT 59101 Yellowstone

System Facility ID:56-05491

Facility Code: 30028
Last Inspected On: 09/27/2023
Operating Permit Renewal Date: 09/27/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Automatic Car Wash Inc		**donscarwashmt@gmail.com**
Operator Contact:	Gene Carlson	**(406) 248-2558**	**donscarwashmt@gmail.com**

Owner/Operator: Automatic Car Wash Inc — donscarwashmt@gmail.com

Duane Wiederrich, UST Class B Operator	dwiederrich62@icloud.com
Duane Wiederrich, UST Class B Operator	dwiederrich62@icloud.com
Gene Carlson, UST Class A Operator	donscarwashmt@gmail.com
Gene Carlson, UST Class B Operator	donscarwashmt@gmail.com
Keith Warford, UST Class B Operator	kwarford78@gmail.com
Keith Warford, UST Class B Operator	kwarford78@gmail.com

Tank Number	04	**Tank Age**	37	**Tank Installed Date**	05/04/1988	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	406	**Spill Test Date**	09/27/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**	03/10/2023	**Tank/Piping CP Test Date**	09/27/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	03/10/2023	**Line Tightness Test Date**	10/11/2020	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	03/10/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	05	**Tank Age**	37	**Tank Installed Date**	05/04/1988	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	407	**Spill Test Date**	09/27/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**	03/10/2023	**Tank/Piping CP Test Date**	09/27/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	03/10/2023	**Line Tightness Test Date**	10/11/2020	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No

		Overfill Test Date	03/10/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	06	**Tank Age**	37	**Tank Installed Date**	05/04/1988	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	408	**Spill Test Date**	09/27/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**	03/10/2023	**Tank/Piping CP Test Date**	09/27/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**	03/10/2023	**Line Tightness Test Date**	10/11/2020	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	03/10/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Yellowstone County in the City of Billings

Location: DONS EXPRESS CENTER
2344 Central Ave
Billings, MT 59102 Yellowstone

System Facility ID:56-05072

Facility Code: 29995
Last Inspected On: 04/05/2023
Operating Permit Renewal Date: 09/25/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Automatic Car Wash Inc		**donscarwashmt@gmail.com**
Operator Contact:	Eric Carlson;Gene Carlson	**(406) 248-2558;(406) 894-2373**	**donscarwashmt@gmail.com;donsxpress24@outlook.com**

Owner/Operator: Automatic Car Wash Inc — donscarwashmt@gmail.com

Eric Carlson, UST Class A Operator — donsxpress24@outlook.com
Eric Carlson, UST Class B Operator — donsxpress24@outlook.com
Gene Carlson, UST Class A Operator — donscarwashmt@gmail.com

Tank Number	05	**Tank Age**	31	**Tank Installed Date**	11/08/1994	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	2002	**Spill Test Date**	04/05/2023	**Piping Installed Date**	10/07/2016	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	04/05/2023	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**	03/10/2023	**Tank/Piping CP Test Date**	04/05/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	20000	**ATG Test Date**	03/10/2023	**Line Tightness Test Date**	02/23/2020	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	04/05/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	06	**Tank Age**	31	**Tank Installed Date**	11/08/1994	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	2003	**Spill Test Date**	04/05/2023	**Piping Installed Date**	10/07/2016	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	04/05/2023	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**	03/10/2023	**Tank/Piping CP Test Date**	04/05/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	03/10/2023	**Line Tightness Test Date**	03/19/2020	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	03/10/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Tank Number	07	**Tank Age**	31	**Tank Installed Date**	11/08/1994	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	2004	**Spill Test Date**	04/05/2023	**Piping Installed Date**	10/07/2016	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	04/05/2023	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**	03/10/2023	**Tank/Piping CP Test Date**	04/05/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	03/05/2023	**Line Tightness Test Date**	02/03/2020	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	03/10/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Yellowstone County in the City of Billings

Location: DONS EXPRESS CENTER 2
2324 Main St
Billings, MT 59105-4024 Yellowstone

System Facility ID:60-15096

Facility Code: 30856
Last Inspected On: 02/09/2023
Operating Permit Renewal Date: 04/20/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Automatic Car Wash Inc		**donscarwashmt@gmail.com**
Operator Contact:	Clinton Deyle;Dallas Amman;Gene Carlson	**(406) 248-2558;(406) 591-1913;(406) 694-3035**	**dallyrae725@gmail.com;donscarwashmt@gmail.com;keandeyle@gmail.com**

Owner/Operator: Automatic Car Wash Inc — donscarwashmt@gmail.com

Brad Wire, UST Class B Operator	donscarwashmt@gmail.com
Clinton Deyle, UST Class A Operator	keandeyle@gmail.com
Clinton Deyle, UST Class B Global Operator	keandeyle@gmail.com
Clinton Deyle, UST Class B Operator	keandeyle@gmail.com
Dallas Amman, UST Class A Operator	dallyrae725@gmail.com
Dallas Amman, UST Class B Global Operator	dallyrae725@gmail.com
Dallas Amman, UST Class B Operator	dallyrae725@gmail.com
Eric Carlson, UST Class B Operator	donsxpress24@outlook.com
Gene Carlson, UST Class A Operator	donscarwashmt@gmail.com
Gene Carlson, UST Class B Operator	donscarwashmt@gmail.com

Tank Number	01	**Tank Age**	17	**Tank Installed Date**	06/29/2008	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	5160	**Spill Test Date**	02/09/2023	**Piping Installed Date**	12/11/2007	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	02/09/2023	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	02/09/2023	**Line Tightness Test Date**	08/23/2019	**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	Yes
		Overfill Test Date	02/09/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350;Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	02	**Tank Age**	17	**Tank Installed Date**	06/29/2008	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm

Tag Number	5161	**Spill Test Date**	02/09/2023	**Piping Installed Date**	12/11/2007	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	02/09/2023	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	5000	**ATG Test Date**	02/09/2023	**Line Tightness Test Date**	08/23/2019	**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	Yes
		Overfill Test Date	02/09/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350;Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	03	**Tank Age**	17	**Tank Installed Date**	06/29/2008	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	5162	**Spill Test Date**	02/09/2023	**Piping Installed Date**	12/11/2007	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	02/09/2023	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	5000	**ATG Test Date**	02/09/2023	**Line Tightness Test Date**	08/25/2019	**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	Yes
		Overfill Test Date	02/09/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350;Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	04	**Tank Age**	17	**Tank Installed Date**	06/29/2008	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	5163	**Spill Test Date**	02/09/2023	**Piping Installed Date**	12/11/2007	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	02/09/2023	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	5000	**ATG Test Date**	02/09/2023	**Line Tightness Test Date**	08/25/2019	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	Yes
		Overfill Test Date	02/09/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350;Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Yellowstone County in the City of Billings

Location: DOWNTOWN CONOCO
2701 6th Ave N
Billings, MT 59101 Yellowstone

System Facility ID:56-06967

Facility Code: 30152
Last Inspected On: 11/25/2020
Operating Permit Renewal Date: 01/28/2024

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Billings Clinic	**(406) 657-4036**	**mgoplen@billingsclinic.org**
Operator Contact:	Jim Murphy;Mun Lee;Paul Murphy	**(406) 670-8112;(406) 697-9003;(406) 850-1920**	**dconoco1401@qwestoffice.net;munkjlee@gmail.com;pjmincorporated@gmail.com**

Jim Murphy, UST Class A Operator	dconoco1401@qwestoffice.net
Jim Murphy, UST Class A Operator	dconoco1401@qwestoffice.net
Jim Murphy, UST Class B Operator	dconoco1401@qwestoffice.net
Jim Murphy, UST Class B Operator	dconoco1401@qwestoffice.net
Mun Lee, UST Class A Operator	munkjlee@gmail.com
Mun Lee, UST Class A Operator	munkjlee@gmail.com
Mun Lee, UST Class B Operator	munkjlee@gmail.com
Mun Lee, UST Class B Operator	munkjlee@gmail.com
Paul Murphy, UST Class A Operator	pjmincorporated@gmail.com
Paul Murphy, UST Class A Operator	pjmincorporated@gmail.com
Paul Murphy, UST Class B Global Operator	pjmincorporated@gmail.com
Paul Murphy, UST Class B Global Operator	pjmincorporated@gmail.com

Tank Number	01	**Tank Age**	57	**Tank Installed Date**	04/22/1968	**Tank Material Construction**	Bare Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	3621	**Spill Test Date**	02/04/2021	**Piping Installed Date**		**Tank Construction**	Lined Interior/Impressed Current	**Piping Construction**	None	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**	09/02/2022	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**	01/29/2020	**Tank/Piping CP Test Date**	01/06/2020	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	32000	**ATG Test Date**	09/02/2022	**Line Tightness Test Date**	10/16/2017	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	09/02/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	02	**Tank Age**	55	**Tank Installed Date**	04/22/1970	**Tank Material Construction**	Bare Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm

Tag Number	3622	**Spill Test Date**	02/04/2021	**Piping Installed Date**		**Tank Construction**	Lined Interior/Impressed Current	**Piping Construction**	None	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**	09/02/2022	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Diesel	**PLLD Test Date**	01/29/2020	**Tank/Piping CP Test Date**	01/06/2020	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	24000	**ATG Test Date**	09/02/2022	**Line Tightness Test Date**	10/06/2017	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	09/02/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	03	**Tank Age**	51	**Tank Installed Date**	04/22/1974	**Tank Material Construction**	Bare Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	3623	**Spill Test Date**	02/04/2021	**Piping Installed Date**		**Tank Construction**	Lined Interior/Impressed Current	**Piping Construction**	None	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**	09/02/2022	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**	01/29/2020	**Tank/Piping CP Test Date**	01/06/2020	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	24000	**ATG Test Date**	09/02/2022	**Line Tightness Test Date**	10/13/2017	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	09/02/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Yellowstone County in the City of Billings

Location: EMERALD MART 2
3306 Rimrock Rd
Billings, MT 59102-0325 Yellowstone

System Facility ID:56-05090

Facility Code: 30008
Last Inspected On: 12/09/2022
Operating Permit Renewal Date: 02/24/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Vesta Ventures LLP **(406) 656-8402**

Operator Contact: Beverly Mundschenk **(406) 861-3952** **mcfinys@yahoo.com**

Owner/Operator: Vesta Ventures LLP (406) 656-8402

Beverly Mundschenk, UST Class A Operator mcfinys@yahoo.com

Tank Number	01	**Tank Age**	38	**Tank Installed Date**	11/30/1987	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	3681	**Spill Test Date**	12/09/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	12/09/2022	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	12/09/2022	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	12/09/2022	**Line Tightness Test Date**	12/09/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco/EMC Basic				
Tank Number	02	**Tank Age**	38	**Tank Installed Date**	11/30/1987	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	3682	**Spill Test Date**	12/09/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	12/09/2022	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	12/09/2022	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	12/09/2022	**Line Tightness Test Date**	12/09/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	12/21/2022			**ATG Type**	Gilbarco/EMC Basic				
Tank Number	03	**Tank Age**	38	**Tank Installed Date**	11/30/1987	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	3683	**Spill Test Date**	12/09/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No

Status	**Currently in Use**	**MLLD Test Date**	12/09/2022	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	12/09/2022	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	12/09/2022	**Line Tightness Test Date**	12/09/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	12/21/2022			**ATG Type**	Gilbarco/EMC Basic				

Facility Summary in Yellowstone County in the City of Billings

Location: FED EX FREIGHT
7107 Commercial Ave
Billings, MT 59101 Yellowstone

System Facility ID:60-15181

Facility Code: 30907
Last Inspected On: 11/28/2023
Operating Permit Renewal Date: 03/17/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: K W Billings LLC **(619) 435-1614**

Operator Contact: Adren Hillenburg;Chong Lee **(408) 654-3112** **chong.lee@fedex.com**

Owner/Operator: K W Billings LLC (619) 435-1614

Adren Hillenburg, UST Class A Operator	
Adren Hillenburg, UST Class B Global Operator	
Chong Lee, UST Class A Operator	chong.lee@fedex.com
Jon Schaffer, UST Class B Operator	jon.schaffer@fedex.com
Kevin Roberts, UST Class B Operator	2374742@fedex.com
Nick Haynes, UST Class B Operator	nicholas.haynes@fedex.com
Ted Carlson, UST Class B Operator	ted.carlson@fedex.com

Tank Number	01	**Tank Age**	14	**Tank Installed Date**	05/23/2011	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm;Positive Shutoff
Tag Number	5293	**Spill Test Date**	11/06/2023	**Piping Installed Date**	04/29/2011	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	11/28/2023	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	11/06/2023	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	20000	**ATG Test Date**	11/06/2023	**Line Tightness Test Date**	09/18/2020	**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	11/06/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350;Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Yellowstone County in the City of Billings

Location: FEDERAL EXPRESS BILL/ZBILL 591
3815 Hesper Rd
Billings, MT 59106 Yellowstone

System Facility ID:60-15209

Facility Code: 30929
Last Inspected On: 10/26/2022
Operating Permit Renewal Date: 01/17/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	FEDERAL EXPRESS CORPERATION	**(870) 715-6571**	**FEDEXTANKENV@FEDEX.COM**
Operator Contact:	Gaylyn Frosini;Mark Feasel;FedEx Ground Package System Inc;Peter Bushman;FedEx Ground Package System Inc	**(406) 606-2574**	**2991522@fedex.com;environmental@fedex.com;gaylyn.frosini@fedex.com;mark.feasel@fedex.com;environmental@fedex.com**
Owner/Operator:	FEDERAL EXPRESS CORPERATION	(870) 715-6571	FEDEXTANKENV@FEDEX.COM
	Derek Kouzmanoff, UST Class B Operator		derek.kouzmanoff@fedex.com
	Derek Kouzmanoff, UST Class B Operator		derek.kouzmanoff@fedex.com
	Gaylyn Frosini, UST Class A Operator		gaylyn.frosini@fedex.com
	Gaylyn Frosini, UST Class A Operator		gaylyn.frosini@fedex.com
	Mark Feasel, UST Class A Operator		environmental@fedex.com
	Mark Feasel, UST Class A Operator		environmental@fedex.com
	Mark Feasel, UST Class B Operator		mark.feasel@fedex.com
	Mark Feasel, UST Class B Operator		mark.feasel@fedex.com
	Peter Bushman, UST Class A Operator		environmental@fedex.com
	Peter Bushman, UST Class A Operator		environmental@fedex.com
	Peter Bushman, UST Class B Operator		environmental@fedex.com
	Peter Bushman, UST Class B Operator		environmental@fedex.com

Tank Number	01	**Tank Age**	12	**Tank Installed Date**	10/01/2013	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	5447	**Spill Test Date**	09/13/2021	**Piping Installed Date**	10/24/2013	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	09/22/2022	**Sump Tightness Test Date**	09/13/2021	**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	30000	**ATG Test Date**	09/22/2022	**Line Tightness Test Date**	09/22/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	Yes
		Overfill Test Date	09/22/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-450				
Tank Number	02	**Tank Age**	12	**Tank Installed Date**	10/01/2013	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve;High Level Alarm

Tag Number	5448	**Spill Test Date**	09/13/2021	**Piping Installed Date**	10/24/2013	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	09/22/2022	**Sump Tightness Test Date**	09/13/2021	**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	30000	**ATG Test Date**	09/22/2022	**Line Tightness Test Date**	09/22/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	Yes
		Overfill Test Date	09/22/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-450				
Tank Number	03	**Tank Age**	12	**Tank Installed Date**	10/01/2013	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Steel	**Overfill Types**	Ball Float Valve;Flapper Valve;High Level Alarm
Tag Number	5449	**Spill Test Date**	09/13/2021	**Piping Installed Date**	10/24/2013	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	09/13/2021	**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Non-corrodible
Product	Biodiesel B99	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	09/22/2022	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	Yes
		Overfill Test Date	09/22/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-450				
Tank Number	04	**Tank Age**	12	**Tank Installed Date**	10/01/2013	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**		**Overfill Types**	High Level Alarm
Tag Number	5450	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**		**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**		**Piping Type**		**CP Met Types**	Non-corrodible
Product	DEF (Not Regulated)	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	05	**Tank Age**	6	**Tank Installed Date**	08/21/2019	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	5930	**Spill Test Date**	09/13/2021	**Piping Installed Date**	08/21/2019	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	09/13/2021	**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Non-corrodible
Product	Hazardous Substance	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**		**Vapor Recovery**	No

Capacity	1500	**ATG Test Date**	09/22/2022	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	Yes
		Overfill Test Date	09/22/2022			**ATG Type**					

Facility Summary in Yellowstone County in the City of Billings

Location: FIRST INTERSTATE CENTER
401 N 31st St
Billings, MT 59101-1200 Yellowstone

System Facility ID:56-13766

Facility Code: 30460
Last Inspected On: 02/28/2025
Operating Permit Renewal Date: 06/01/2028

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Billings 401 LLC	**(406) 255-7100**	**unitedproperties@uprop.net**
Operator Contact:	Jerome Ries;Raymond Quenzer		**jries@uprop.net;rquenzer@uprop.net**

Owner/Operator: Billings 401 LLC (406) 255-7100 unitedproperties@uprop.net

Brad Zimmer, UST Class B Operator	unitedproperties@uprop.net
Jerome Ries, UST Class A Operator	jries@uprop.net
Jerome Ries, UST Class B Operator	jries@uprop.net
Jim Zimmer, UST Class B Operator	unitedproperties@uprop.net
Raymond Quenzer, UST Class A Operator	rquenzer@uprop.net
Raymond Quenzer, UST Class B Global Operator	rquenzer@uprop.net

Tank Number	02	**Tank Age**	27	**Tank Installed Date**	10/01/1998	**Tank Material Construction**	Steel Clad	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	3400	**Spill Test Date**	02/28/2025	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	02/28/2025	**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	U.S. Suction	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	01/16/2013	**Primary Tank Leak Detection**	Manual Interstitial Monitoring	**Primary Pipe Leak Detection**	Manual Interstitial Monitoring	**Vapor Recovery**	No
Capacity	560	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	02/28/2025			**ATG Type**					

Facility Summary in Yellowstone County in the City of Billings

Location: FLYING J INC BILLINGS
2775 Old Hardin Rd
Billings, MT 59101 Yellowstone

System Facility ID:56-12585

Facility Code: 30405
Last Inspected On: 04/02/2024
Operating Permit Renewal Date: 07/21/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Billings 7 Town Pump LLC **(406) 497-6700** **environmental@townpump.com**

Operator Contact: Trent Biggers **Trentb@townpump.com**

Owner/Operator: Billings 7 Town Pump LLC (406) 497-6700 environmental@townpump.com

Trent Biggers, UST Class A Operator Trentb@townpump.com
Trent Biggers, UST Class A Operator Trentb@townpump.com
Trent Biggers, UST Class B Global Operator Trentb@townpump.com
Trent Biggers, UST Class B Global Operator Trentb@townpump.com

Tank Number	01	**Tank Age**	34	**Tank Installed Date**	08/01/1991	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	1105	**Spill Test Date**	08/18/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Single Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	04/02/2024	**Tank/Piping CP Test Date**	11/29/2012	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	04/02/2024	**Line Tightness Test Date**	06/26/2007	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	08/18/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Number	04	**Tank Age**	34	**Tank Installed Date**	08/01/1991	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	1108	**Spill Test Date**	08/18/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	04/02/2024	**Tank/Piping CP Test Date**	11/29/2012	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	20000	**ATG Test Date**	04/02/2024	**Line Tightness Test Date**	06/26/2007	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No

		Overfill Test Date	08/18/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Number	05	**Tank Age**	34	**Tank Installed Date**	08/01/1991	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	1109	**Spill Test Date**	08/18/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	04/02/2024	**Tank/Piping CP Test Date**	11/29/2012	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	20000	**ATG Test Date**	04/02/2024	**Line Tightness Test Date**	06/26/2007	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	08/18/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Number	06	**Tank Age**	34	**Tank Installed Date**	08/01/1991	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	1110	**Spill Test Date**	09/07/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Single Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	04/02/2024	**Tank/Piping CP Test Date**	11/29/2012	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	20000	**ATG Test Date**	04/02/2024	**Line Tightness Test Date**	06/26/2007	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	08/18/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Number	02	**Tank Age**	34	**Tank Installed Date**	08/01/1991	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	4447	**Spill Test Date**	08/18/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	04/02/2024	**Tank/Piping CP Test Date**	11/29/2012	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	04/02/2024	**Line Tightness Test Date**	06/26/2007	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	08/18/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Number	03	**Tank Age**	34	**Tank Installed Date**	08/01/1991	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve

Tag Number	4448	**Spill Test Date**	08/18/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	04/02/2024	**Tank/Piping CP Test Date**	11/29/2012	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	04/02/2024	**Line Tightness Test Date**	06/26/2007	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	08/18/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Number	07	**Tank Age**	12	**Tank Installed Date**	08/01/2013	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	5425	**Spill Test Date**	09/07/2023	**Piping Installed Date**	06/25/2013	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	09/21/2020	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	04/02/2024	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**	04/02/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Statistical Inventory Reconciliation	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	Yes
		Overfill Test Date	09/07/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Number	08	**Tank Age**	12	**Tank Installed Date**	08/01/2013	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	
Tag Number	5426	**Spill Test Date**		**Piping Installed Date**	06/25/2013	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Other**	**MLLD Test Date**		**Sump Tightness Test Date**	10/04/2013	**Catastrophic L.D. Type 3.0**		**Piping Type**	Pressurized	**CP Met Types**	
Product	DEF (Not Regulated)	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Approved Remote Monitoring;Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	07/20/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring;Not Listed	**Energy Act**	Yes
		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Number	09	**Tank Age**	12	**Tank Installed Date**	08/01/2013	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve

Tag Number	5427	**Spill Test Date**	08/18/2023	**Piping Installed Date**	06/25/2013	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	09/21/2020	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	04/02/2024	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**	04/02/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Statistical Inventory Reconciliation	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	Yes
		Overfill Test Date	08/18/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				

Facility Summary in Yellowstone County in the City of Billings

Location: GAS N GO
800 Jackson St
Billings, MT 59101-5451 Yellowstone

System Facility ID:56-10866

Facility Code: 30363
Last Inspected On: 10/21/2022
Operating Permit Renewal Date: 01/04/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: JLG Inc **(510) 333-3310** **sherrywang116688@gmail.com**

Operator Contact:

Owner/Operator: JLG Inc (510) 333-3310 sherrywang116688@gmail.com

Lorraine Boyd, UST Class B Operator boydl4516@yahoo.com

Tank Number	01	**Tank Age**	41	**Tank Installed Date**	04/10/1984	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Steel	**Overfill Types**	Flapper Valve
Tag Number	4551	**Spill Test Date**	10/21/2022	**Piping Installed Date**		**Tank Construction**	Lined Interior/Impressed Current	**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	10/21/2022	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	12/21/2022			**ATG Type**					

Facility Summary in Yellowstone County in the City of Billings

Location: HEIGHTS CAR CARE
1320 Main St
Billings, MT 59105-1742 Yellowstone

System Facility ID:56-06960

Facility Code: 30146
Last Inspected On: 05/02/2022
Operating Permit Renewal Date: 05/02/2025

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Christan Automotive Repair Service LLC	**(406) 259-3709**	**joe.b@heights-carcare.com**
Operator Contact:	Joseph Borgstrom	**(406) 259-3709**	**joe.b@heights-carcare.com**

Joseph Borgstrom, UST Class A Operator	joe.b@heights-carcare.com
Joseph Borgstrom, UST Class A Operator	joe.b@heights-carcare.com
Joseph Borgstrom, UST Class B Global Operator	joe.b@heights-carcare.com
Joseph Borgstrom, UST Class B Global Operator	joe.b@heights-carcare.com

Tank Number	01	**Tank Age**	49	**Tank Installed Date**	04/21/1976	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	1164	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**	Lined Interior/Impressed Current	**Piping Construction**	None	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	05/02/2022	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	20000	**ATG Test Date**		**Line Tightness Test Date**	08/01/2016	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	02	**Tank Age**	49	**Tank Installed Date**	04/21/1976	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	1165	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**	Lined Interior/Impressed Current	**Piping Construction**	None	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	05/02/2022	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	20000	**ATG Test Date**		**Line Tightness Test Date**	08/01/2016	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No

		Overfill Test Date				**ATG Type**					
Tank Number	03	**Tank Age**	49	**Tank Installed Date**	04/21/1976	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	1166	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**	Lined Interior/Impressed Current	**Piping Construction**	None	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	05/02/2022	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**		**Line Tightness Test Date**	08/01/2016	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					

Facility Summary in Yellowstone County in the City of Billings

Location: JTL GROUP INC UST
1102 Shiloh Rd
Billings, MT 59106-2415 Yellowstone

System Facility ID:56-14001

Facility Code: 30662
Last Inspected On: 01/10/2025
Operating Permit Renewal Date: 05/23/2028

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: JTL Group Inc **(406) 655-2012**

Operator Contact: Brian Nickel;Dan Ottman **(406) 651-2476** **brian.nickel@kniferiver.com;dan.ottman@kniferiver.com**

Owner/Operator: JTL Group Inc (406) 655-2012

Brian Nickel, UST Class A Operator	brian.nickel@kniferiver.com
Brian Nickel, UST Class B Global Operator	brian.nickel@kniferiver.com
Brian Nickel, UST Class B Operator	brian.nickel@kniferiver.com
Dan Ottman, UST Class A Operator	dan.ottman@kniferiver.com
Dan Ottman, UST Class B Operator	dan.ottman@kniferiver.com

Tank Number	01	**Tank Age**	24	**Tank Installed Date**	04/01/2001	**Tank Material Construction**	Steel Clad	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	4397	**Spill Test Date**	01/10/2025	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	1958	**ATG Test Date**	02/10/2025	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	02/10/2025			**ATG Type**	Veeder Root/TLS-350				
Tank Number	02	**Tank Age**	24	**Tank Installed Date**	04/01/2001	**Tank Material Construction**	Steel Clad	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	4398	**Spill Test Date**	01/10/2025	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	01/10/2025	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	13019	**ATG Test Date**	01/10/2025	**Line Tightness Test Date**	10/27/2021	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	01/10/2025			**ATG Type**	Veeder Root/TLS-350				

Facility Summary in Yellowstone County in the City of Billings

Location: LEWIS AND CLARK MIDDLE SCHOOL
1315 Lewis Ave
Billings, MT 59102-4237 Yellowstone

System Facility ID:56-14070

Facility Code: 30722
Last Inspected On: 12/10/2019
Operating Permit Renewal Date: 03/30/2023

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Lewis and Clark Middle School **(406) 255-3778**

Operator Contact: Dennis Stellingwerf **stellingwerfd@billings.k12.mt.us**

Dennis Stellingwerf, UST Class A Operator stellingwerfd@billings.k12.mt.us
Timothy Schafft, UST Class B Global Operator schafft@billingsschools.org

Tank Number	01	**Tank Age**	21	**Tank Installed Date**	11/15/2004	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	4970	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**	12/10/2019	**Catastrophic L.D. Type 3.0**	Auto Dialer	**Piping Type**	U.S. Suction	**CP Met Types**	Galvanic
Product	Heating Oil	**PLLD Test Date**		**Tank/Piping CP Test Date**	12/10/2019	**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/ILS-350				

Facility Summary in Yellowstone County in the City of Billings

Location: LYNCH FLYING SERVICE
1691 Aviation Pl
Billings, MT 59105 Yellowstone

System Facility ID:56-07797

Facility Code: 30200
Last Inspected On: 05/03/2023
Operating Permit Renewal Date: 10/29/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Lynch Flying Service Inc	**(406) 252-0508**	
Operator Contact:	Aaron VanLuchene;Joel Simmons;Parker Heser;Robert McCullough;Warren Nemitz	**(307) 382-3224;(406) 247-8916;(406) 252-0508**	**joel@beaconairgroup.com;wnemitz@edwardsjetcenter.com**

Owner/Operator: Lynch Flying Service Inc (406) 252-0508

Aaron VanLuchene, UST Class A Operator	
Aaron VanLuchene, UST Class A Operator	
Aaron VanLuchene, UST Class B Global Operator	
Aaron VanLuchene, UST Class B Global Operator	
Joel Simmons, UST Class A Operator	joel@beaconairgroup.com
Joel Simmons, UST Class B Operator	joel@beaconairgroup.com
Parker Heser, UST Class A Operator	
Parker Heser, UST Class A Operator	
Parker Heser, UST Class B Global Operator	
Parker Heser, UST Class B Global Operator	
Robert McCullough, UST Class A Operator	wnemitz@edwardsjetcenter.com
Robert McCullough, UST Class A Operator	wnemitz@edwardsjetcenter.com
Robert McCullough, UST Class B Operator	wnemitz@edwardsjetcenter.com
Robert McCullough, UST Class B Operator	wnemitz@edwardsjetcenter.com
Warren Nemitz, UST Class A Operator	wnemitz@edwardsjetcenter.com
Warren Nemitz, UST Class A Operator	wnemitz@edwardsjetcenter.com
Warren Nemitz, UST Class B Global Operator	wnemitz@edwardsjetcenter.com
Warren Nemitz, UST Class B Global Operator	wnemitz@edwardsjetcenter.com

Tank Number	08	**Tank Age**	35	**Tank Installed Date**	10/25/1990	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	No Piping	**Overfill Types**	High Level Alarm
Tag Number	1563	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Galvanic
Product	Jet Fuel (Jet-A, Jet-A1, JP5)	**PLLD Test Date**		**Tank/Piping CP Test Date**	07/28/2022	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**		**Vapor Recovery**	No

Capacity	20000	**ATG Test Date**	05/04/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	09	**Tank Age**	35	**Tank Installed Date**	10/25/1990	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	No Piping	**Overfill Types**	High Level Alarm
Tag Number	1564	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Galvanic
Product	Jet Fuel (Jet-A, Jet-A1, JP5)	**PLLD Test Date**		**Tank/Piping CP Test Date**	07/28/2022	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	20000	**ATG Test Date**	05/04/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	10	**Tank Age**	35	**Tank Installed Date**	10/25/1990	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	No Piping	**Overfill Types**	High Level Alarm
Tag Number	1565	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Galvanic
Product	Jet Fuel (Jet-A, Jet-A1, JP5)	**PLLD Test Date**		**Tank/Piping CP Test Date**	07/28/2022	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	20000	**ATG Test Date**	05/04/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	11	**Tank Age**	35	**Tank Installed Date**	10/25/1990	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	No Piping	**Overfill Types**	High Level Alarm
Tag Number	1566	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Galvanic
Product	Aviation Gas	**PLLD Test Date**		**Tank/Piping CP Test Date**	07/28/2022	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	20000	**ATG Test Date**	05/04/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	12	**Tank Age**	35	**Tank Installed Date**	10/25/1990	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Steel	**Overfill Types**	High Level Alarm

Tag Number	1567	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Temporarily Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	07/28/2022	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	13	**Tank Age**	27	**Tank Installed Date**	06/26/1998	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	No Piping	**Overfill Types**	High Level Alarm
Tag Number	1568	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Galvanic
Product	Jet Fuel (Jet-A, Jet-A1, JP5)	**PLLD Test Date**		**Tank/Piping CP Test Date**	07/28/2022	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	20000	**ATG Test Date**	05/04/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	14	**Tank Age**	27	**Tank Installed Date**	06/26/1998	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	No Piping	**Overfill Types**	High Level Alarm
Tag Number	1569	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Galvanic
Product	Jet Fuel (Jet-A, Jet-A1, JP5)	**PLLD Test Date**		**Tank/Piping CP Test Date**	07/28/2022	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	20000	**ATG Test Date**	05/04/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	15	**Tank Age**	6	**Tank Installed Date**	05/01/2019	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	No Piping	**Overfill Types**	High Level Alarm
Tag Number	5909	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	05/22/2019	**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Non-corrodible
Product	Jet Fuel (Jet-A, Jet-A1, JP5)	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**		**Vapor Recovery**	No

Capacity	30000	**ATG Test Date**	05/04/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**		**Energy Act**	Yes
		Overfill Test Date				**ATG Type**					
Tank Number	16	**Tank Age**	6	**Tank Installed Date**	05/01/2019	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	No Piping	**Overfill Types**	High Level Alarm
Tag Number	5910	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	05/22/2019	**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**		**CP Met Types**	Non-corrodible
Product	Jet Fuel (Jet-A, Jet-A1, JP5)	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	30000	**ATG Test Date**	05/04/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**		**Energy Act**	Yes
		Overfill Test Date				**ATG Type**					

Facility Summary in Yellowstone County in the City of Billings

Location: LYNCH FLYING SERVICE INC
1482 Aviation Place
Billings, MT 59105 Yellowstone

System Facility ID:60-15100

Facility Code: 30859
Last Inspected On: 05/04/2023
Operating Permit Renewal Date: 10/15/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Edwards Jet Center;Paul Gatzemeier	**(406) 252-0508**	
Operator Contact:	Aaron VanLuchene;Joel Simmons;Parker Heser;Warren Nemitz	**(307) 382-3224;(406) 252-0508**	**joel@beaconairgroup.com;wnemitz@edwardsjetcenter.com**

Owner/Operator: Edwards Jet Center (406) 252-0508

Owner/Operator: Paul Gatzemeier (406) 252-0508

Aaron VanLuchene, UST Class A Operator	
Aaron VanLuchene, UST Class B Global Operator	
Joel Simmons, UST Class A Operator	joel@beaconairgroup.com
Joel Simmons, UST Class B Operator	joel@beaconairgroup.com
Parker Heser, UST Class A Operator	
Parker Heser, UST Class B Global Operator	
Warren Nemitz, UST Class A Operator	wnemitz@edwardsjetcenter.com
Warren Nemitz, UST Class B Global Operator	wnemitz@edwardsjetcenter.com

Tank Number	01	**Tank Age**	17	**Tank Installed Date**	02/25/2008	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	No Piping	**Overfill Types**	High Level Alarm
Tag Number	5172	**Spill Test Date**	07/20/2020	**Piping Installed Date**	02/22/2008	**Tank Construction**	Double-Walled	**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	07/28/2014	**Catastrophic L.D. Type 3.0**	Continuous Interstitial Monitoring	**Piping Type**	Not Listed	**CP Met Types**	Non-corrodible
Product	Jet Fuel (Jet-A, Jet-A1, JP5)	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	20000	**ATG Test Date**	05/04/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**		**Energy Act**	Yes
		Overfill Test Date	05/04/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	02	**Tank Age**	17	**Tank Installed Date**	02/25/2008	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	No Piping	**Overfill Types**	High Level Alarm
Tag Number	5173	**Spill Test Date**	07/20/2020	**Piping Installed Date**	02/22/2008	**Tank Construction**	Double-Walled	**Piping Construction**	None	**AST**	No

Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	07/28/2014	**Catastrophic L.D. Type 3.0**	Continuous Interstitial Monitoring	**Piping Type**	Not Listed	**CP Met Types**	Non-corrodible
Product	Jet Fuel (Jet-A, Jet-A1, JP5)	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	20000	**ATG Test Date**	05/04/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**		**Energy Act**	Yes
		Overfill Test Date	05/04/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	03	**Tank Age**	17	**Tank Installed Date**	02/25/2008	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	No Piping	**Overfill Types**	High Level Alarm
Tag Number	5174	**Spill Test Date**	05/04/2023	**Piping Installed Date**	02/22/2008	**Tank Construction**	Double-Walled	**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	07/28/2014	**Catastrophic L.D. Type 3.0**	Continuous Interstitial Monitoring	**Piping Type**	Not Listed	**CP Met Types**	Non-corrodible
Product	Aviation Gas	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	05/04/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**		**Energy Act**	Yes
		Overfill Test Date	05/04/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Yellowstone County in the City of Billings

Location: MARKET BASKET STORE
8014 S Frontage Rd
Billings, MT 59101 Yellowstone

System Facility ID:56-08286

Facility Code: 30228
Last Inspected On: 01/25/2023
Operating Permit Renewal Date: 04/22/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Town and Country Supply Association **(406) 628-6314**

Operator Contact: Kevin Wynia;Town and Country Supply Association;Wes Burley **(406) 256-1020;(406) 628-6314** **kwynia@tandcsupply.com**

Owner/Operator: Town and Country Supply Association (406) 628-6314

Kevin Wynia, UST Class A Operator kwynia@tandcsupply.com
Kevin Wynia, UST Class B Operator kwynia@tandcsupply.com
Wes Burley, UST Class A Operator

Tank Number	03	**Tank Age**	30	**Tank Installed Date**	10/06/1995	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	3314	**Spill Test Date**	07/11/2022	**Piping Installed Date**	08/25/2022	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	04/06/2022	**Sump Tightness Test Date**	07/11/2022	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	04/16/2021	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	07/11/2022	**Line Tightness Test Date**	08/01/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date	07/11/2022			**ATG Type**	Veeder Root/TLS-450PLUS				
Tank Number	04	**Tank Age**	30	**Tank Installed Date**	10/06/1995	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	3315	**Spill Test Date**	07/11/2022	**Piping Installed Date**	08/25/2022	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	04/06/2022	**Sump Tightness Test Date**	07/11/2022	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**	07/11/2022	**Tank/Piping CP Test Date**	04/16/2021	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	07/11/2022	**Line Tightness Test Date**	12/31/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date	07/11/2022			**ATG Type**	Veeder Root/TLS-450PLUS				

Tank Number	05	**Tank Age**	22	**Tank Installed Date**	11/28/2003	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	4945	**Spill Test Date**	07/11/2022	**Piping Installed Date**	08/25/2022	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	04/06/2022	**Sump Tightness Test Date**	07/11/2022	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**	07/11/2022	**Tank/Piping CP Test Date**	04/16/2021	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	07/11/2022	**Line Tightness Test Date**	08/24/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date	07/11/2022			**ATG Type**	Veeder Root/TLS-450PLUS				
Tank Number	06	**Tank Age**	3	**Tank Installed Date**	06/09/2022	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	6092	**Spill Test Date**	08/25/2022	**Piping Installed Date**	08/25/2022	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	08/25/2022	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	08/25/2022	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	Yes
Capacity	8000	**ATG Test Date**	08/25/2022	**Line Tightness Test Date**	08/25/2022	**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	08/25/2022			**ATG Type**					
Tank Number	07	**Tank Age**	3	**Tank Installed Date**	06/09/2022	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	6093	**Spill Test Date**		**Piping Installed Date**	08/25/2022	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	08/25/2022	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel, Dyed	**PLLD Test Date**	08/25/2022	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	08/25/2022	**Line Tightness Test Date**	08/26/2022	**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	08/25/2022			**ATG Type**					
Tank Number	08	**Tank Age**	3	**Tank Installed Date**	06/02/2022	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	6094	**Spill Test Date**	08/25/2022	**Piping Installed Date**	08/25/2022	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	08/25/2022	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible

Product	Diesel	**PLLD Test Date**	08/25/2022	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	08/25/2022	**Line Tightness Test Date**	08/25/2022	**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	08/25/2022			**ATG Type**					
Tank Number	09	**Tank Age**	3	**Tank Installed Date**	06/09/2022	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	
Tag Number	6095	**Spill Test Date**	08/25/2022	**Piping Installed Date**	08/25/2022	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**		**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	DEF (Not Regulated)	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	1000	**ATG Test Date**	08/25/2022	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					

Facility Summary in Yellowstone County in the City of Billings

Location: MCDONALD LIGHTHOUSE
3212 1st Ave S
Billings, MT 59101-3824 Yellowstone

System Facility ID:60-15027

Facility Code: 30811
Last Inspected On: 05/29/2018
Operating Permit Renewal Date: 07/01/2019

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Yellowstone Boys & Girls Ranch

Operator Contact: Dale Orth;Gregory Leeds **(406) 670-2012;(406) 672-8005** **gregl@ybgr.org**

Dale Orth, UST Class A Operator
Dale Orth, UST Class B Operator
Gregory Leeds, UST Class A Operator gregl@ybgr.org
Patrick Friesen, UST Class B Global Operator
Rick Kelum, UST Class B Operator

Tank Number	01	**Tank Age**	19	**Tank Installed Date**	02/06/2006	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	5072	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Continuous Interstitial Monitoring	**Piping Type**	U.S. Suction	**CP Met Types**	
Product	Heating Oil	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**		**Line Tightness Test Date**	06/04/2015	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date				**ATG Type**					

Facility Summary in Yellowstone County in the City of Billings

Location: MDOT BILLINGS
424 Morey St
Billings, MT 59101-4732 Yellowstone

System Facility ID:56-09501

Facility Code: 30307
Last Inspected On: 10/04/2022
Operating Permit Renewal Date: 10/17/2025

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	MDOT Helena	**(406) 444-6163**	**mmurolo@mt.gov**
Operator Contact:	Jason Marcum;MDOT Billings;Joe Radonich;Montana Dept of Transportation;Mike Murolo;Montana Dept of Transportation;Tracy Deeds;MDOT Helena;Walt Kerttula;Montana Dept of Transportation	**(406) 444-6151;(406) 444-7632;(406) 444-6163;(406) 444-7632;(406) 444-9204;(406) 444-7632;(406) 461-0769;(406) 444-6163;(406) 657-0252;(406) 252-4138**	**jmarcum@mt.gov;jradonich@mt.gov;jradonich@mt.gov;mmurolo@mt.gov;jradonich@mt.gov;tdeeds@mt.gov;mmurolo@mt.gov;wkerttula@mt.gov;jradonich@mt.gov**

Owner/Operator: MDOT Helena (406) 444-6163 mmurolo@mt.gov

Bradley Becker, UST Class B Global Operator	bbecker@mt.gov
Jason Marcum, UST Class A Operator	jmarcum@mt.gov
Jason Marcum, UST Class B Operator	jmarcum@mt.gov
Joe Radonich, UST Class A Operator	jradonich@mt.gov
Joe Radonich, UST Class B Global Operator	jradonich@mt.gov
John McCloskey, UST Class B Operator	jmccloskey@mt.gov
Mike Murolo, UST Class A Operator	jradonich@mt.gov
Tracy Deeds, UST Class A Operator	mmurolo@mt.gov
Walt Kerttula, UST Class A Operator	jradonich@mt.gov

Tank Number	06	**Tank Age**	32	**Tank Installed Date**	09/01/1993	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	2948	**Spill Test Date**	10/04/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	10/04/2022	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	10/04/2022	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	10/04/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	07	**Tank Age**	32	**Tank Installed Date**	09/01/1993	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	2949	**Spill Test Date**	10/04/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Galvanic

Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	10/04/2022	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	10/04/2022	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	10/04/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Yellowstone County in the City of Billings

Location: MERIDIAN AUTOMOTIVE SERVICE INC
1240 Ave C
Billings, MT 59102-3238 Yellowstone

System Facility ID:56-05077

Facility Code: 30000
Last Inspected On: 07/20/2023
Operating Permit Renewal Date: 07/20/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Meridian Automotive Service LLC **(406) 259-6922**

Operator Contact: Richard Skewis **(406) 256-1020** **skewis3@gmail.com**

Owner/Operator: Meridian Automotive Service LLC (406) 259-6922

Richard Skewis, UST Class A Operator	skewis3@gmail.com
Richard Skewis, UST Class A Operator	skewis3@gmail.com
Richard Skewis, UST Class B Operator	skewis3@gmail.com
Richard Skewis, UST Class B Operator	skewis3@gmail.com

Tank Number	05	**Tank Age**	31	**Tank Installed Date**	01/11/1994	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	3182	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Temporarily Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	07/20/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.1;Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	2000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco/EMC Basic				
Tank Number	06	**Tank Age**	31	**Tank Installed Date**	01/11/1994	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	3183	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Temporarily Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	07/20/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.1;Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No

		Overfill Test Date				**ATG Type**	Gilbarco/EMC Basic				
Tank Number	07	**Tank Age**	31	**Tank Installed Date**	01/11/1994	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	3184	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Temporarily Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	07/20/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.1;Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco/EMC Basic				

Facility Summary in Yellowstone County in the City of Billings

Location: MIDWEST MOTOR EXPRESS INC
214 Orchard Ln
Billings, MT 59101-4952 Yellowstone

System Facility ID:56-14075

Facility Code: 30727
Last Inspected On: 10/12/2023
Operating Permit Renewal Date: 10/12/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Midwest Motor Express **(406) 245-5938**

Operator Contact: Christopher Booth **(406) 245-5938** **cbooth@beaverheadcounty.org**

Owner/Operator: Midwest Motor Express (406) 245-5938

Christopher Booth, UST Class A Operator cbooth@beaverheadcounty.org
Christopher Booth, UST Class B Operator cbooth@beaverheadcounty.org

Tank Number	01	**Tank Age**	22	**Tank Installed Date**	01/09/2003	**Tank Material Construction**	Steel Clad	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	4782	**Spill Test Date**	10/12/2023	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	03/31/2023	**Sump Tightness Test Date**	10/15/2015	**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	20000	**ATG Test Date**	09/11/2023	**Line Tightness Test Date**	01/29/2021	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	10/12/2023			**ATG Type**	Veeder Root/TLS-4I, B, C				

Facility Summary in Yellowstone County in the City of Billings

Location: MONAD DANIELS CARDLOCK #4
275 Daniels St
Billings, MT 59101 Yellowstone

System Facility ID:56-09271

Facility Code: 30294
Last Inspected On: 12/17/2024
Operating Permit Renewal Date: 04/20/2028

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Monad Daniels LLC	**(406) 661-1112**	**dwhitmore@comconostores.com**
Operator Contact:	Bill Grunstead;Jay Brookie;Laura Geffre;Roger Schmechel	**(406) 208-3147;(406) 252-4661**	**bgrunstead@gmpetroleum.com;jayb@cityservicevalcon.com;rogers@cityservicevalcon.com**

Owner/Operator: Monad Daniels LLC (406) 661-1112 dwhitmore@comconostores.com

Bill Grunstead, UST Class A Operator	bgrunstead@gmpetroleum.com
Jay Brookie, UST Class A Operator	jayb@cityservicevalcon.com
Jay Brookie, UST Class B Global Operator	jayb@cityservicevalcon.com
Laura Geffre, UST Class A Operator	
Laura Geffre, UST Class B Operator	
Roger Schmechel, UST Class A Operator	rogers@cityservicevalcon.com
Roger Schmechel, UST Class B Operator	rogers@cityservicevalcon.com

Tank Number	01	**Tank Age**	32	**Tank Installed Date**	01/01/1993	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	4716	**Spill Test Date**	12/19/2024	**Piping Installed Date**	11/13/2008	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	01/26/2024	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	01/26/2024	**Line Tightness Test Date**	10/19/2021	**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	01/26/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	02	**Tank Age**	32	**Tank Installed Date**	01/01/1993	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	4717	**Spill Test Date**	12/19/2024	**Piping Installed Date**	11/13/2008	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	01/26/2024	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No

Capacity	8000	**ATG Test Date**	01/26/2024	**Line Tightness Test Date**	10/25/2021	**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	01/26/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Yellowstone County in the City of Billings

Location: MONTANA TRAILHEAD INN
5500 Midland Rd
Billings, MT 59101-6321 Yellowstone

System Facility ID:56-14103

Facility Code: 30746
Last Inspected On: 05/03/2022
Operating Permit Renewal Date: 06/22/2025

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Tropicana Inn Investments 2.0 LLC **(406) 248-7701**

Operator Contact: Gary Giangreco **(408) 691-9074** **giangreco_gary@yahoo.com**

Owner/Operator: Tropicana Inn Investments 2.0 LLC (406) 248-7701

Gary Giangreco, UST Class A Operator giangreco_gary@yahoo.com
Gary Giangreco, UST Class B Global Operator giangreco_gary@yahoo.com

Tank Number	02	**Tank Age**	21	**Tank Installed Date**	03/12/2004	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	4887	**Spill Test Date**	05/03/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Secondary Containment Chase	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	04/20/2016	**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	U.S. Suction	**CP Met Types**	Galvanic
Product	Diesel, Dyed	**PLLD Test Date**		**Tank/Piping CP Test Date**	05/03/2022	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	3-Year Line Tightness Test	**Vapor Recovery**	No
Capacity	500	**ATG Test Date**	05/03/2022	**Line Tightness Test Date**	05/03/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	05/03/2022			**ATG Type**	EMCO Electronics/EECO 1500				

Facility Summary in Yellowstone County in the City of Billings

Location: MSU FACILITY SERVICES BLDG
1500 University Dr
Billings, MT 59101-0245 Yellowstone

System Facility ID:56-00904

Facility Code: 29741
Last Inspected On: 07/23/2024
Operating Permit Renewal Date: 08/21/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Montana State University Billings	**(406) 657-2309**	**justin.rife@msubillings.edu**
Operator Contact:	Theodore Hoeschen;Montana State University Billings	**(406) 670-3103;(406) 657-2309**	**theodore.hoeschen@msubillings.edu;justin.rife@msubillings.edu**

Owner/Operator: Montana State University Billings (406) 657-2309 justin.rife@msubillings.edu

Theodore Hoeschen, UST Class A Operator justin.rife@msubillings.edu

Theodore Hoeschen, UST Class B Operator justin.rife@msubillings.edu

Tank Number	05	**Tank Age**	29	**Tank Installed Date**	09/01/1996	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	846	**Spill Test Date**	10/10/2024	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Deferred	**Vapor Recovery**	No
Capacity	1000	**ATG Test Date**	01/26/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	10/10/2024			**ATG Type**	Veeder Root/TLS-300				

Facility Summary in Yellowstone County in the City of Billings

Location: MT STATE WOMENS PRISON
701 S 27th St
Billings, MT 59101-4511 Yellowstone

System Facility ID:56-01757

Facility Code: 29788
Last Inspected On: 11/24/2023
Operating Permit Renewal Date: 04/04/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Montana State Womens Prison

Operator Contact: Joel Carlson;Michael Bangert **joel.carlson@mt.gov;michael.bangert@mt.gov**

Joel Carlson, UST Class A Operator	joel.carlson@mt.gov
Joel Carlson, UST Class B Operator	joel.carlson@mt.gov
Michael Bangert, UST Class A Operator	michael.bangert@mt.gov
Michael Bangert, UST Class B Operator	michael.bangert@mt.gov

Tank Number	02	**Tank Age**	20	**Tank Installed Date**	10/01/2005	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	5053	**Spill Test Date**	01/18/2023	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**	11/03/2023	**Catastrophic L.D. Type 3.0**	Auto Dialer	**Piping Type**	U.S. Suction	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	11/22/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	11/03/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	11/03/2023			**ATG Type**	Veeder Root/TLS-300				

Facility Summary in Yellowstone County in the City of Billings

Location: NORTHWESTERN ENERGY FACILITY
405 S 20th St W
Billings, MT 59102-6343 Yellowstone

System Facility ID:56-01188

Facility Code: 29758
Last Inspected On: 08/30/2023
Operating Permit Renewal Date: 12/09/2020

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Northwestern Energy Butte **(406) 655-2521** **beth.stimatz@northwestern.com**

Operator Contact: Brian Ranf;John Habeger **brian.ranf@northwestern.com;john.habeger@northwestern.com**

Owner/Operator: Northwestern Energy Butte (406) 655-2521 beth.stimatz@northwestern.com

Brian Ranf, UST Class A Operator brian.ranf@northwestern.com
Darren Brockel, UST Class B Global Operator darren.brockel@northwestern.com
Darren Brockel, UST Class B Global Operator darren.brockel@northwestern.com
John Habeger, UST Class A Operator john.habeger@northwestern.com
John Habeger, UST Class A Operator john.habeger@northwestern.com

Tank Number	04	**Tank Age**	0	**Tank Installed Date**		**Tank Material Construction**	Concrete	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	
Tag Number		**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Other**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Not Listed	**CP Met Types**	
Product	Oil/Water Separator	**PLLD Test Date**		**Tank/Piping CP Test Date**	12/18/2007	**Primary Tank Leak Detection**	Deferred	**Primary Pipe Leak Detection**	Deferred	**Vapor Recovery**	No
Capacity	800	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	3-1	**Tank Age**	45	**Tank Installed Date**	04/30/1980	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Steel	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	1683	**Spill Test Date**	11/06/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Impressed Current
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	09/06/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	08/29/2024	**Line Tightness Test Date**	10/05/2017	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	08/29/2024			**ATG Type**	Franklin Fueling Systems/EVO 600				

Tank Number	3-2	**Tank Age**	45	**Tank Installed Date**	04/30/1980	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Steel	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	1684	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Impressed Current
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	07/08/2020	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Deferred	**Vapor Recovery**	No
Capacity	2000	**ATG Test Date**	08/29/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	08/29/2024			**ATG Type**	Franklin Fueling Systems/EVO 600				
Tank Number	3-3	**Tank Age**	45	**Tank Installed Date**	04/30/1980	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Steel	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	1685	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	07/08/2020	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	07/08/2020	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	08/29/2024	**Line Tightness Test Date**	07/08/2020	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	08/29/2024			**ATG Type**	Franklin Fueling Systems/EVO 600				

Facility Summary in Yellowstone County in the City of Billings

Location: OLD DOMINION FREIGHT LINES
1030 Intermountain St
Billings, MT 59101 Yellowstone

System Facility ID:60-15216

Facility Code: 30935
Last Inspected On: 08/16/2023
Operating Permit Renewal Date: 09/19/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Old Dominion Freight Line;Robert Alexander **(336) 889-5000**

Operator Contact: Christopher Hauger;Old Dominion Freight Line **(406) 444-1415;(336) 889-5000** **Christopher.hauger@odfl.com**

Owner/Operator: Old Dominion Freight Line (336) 889-5000

Owner/Operator: Robert Alexander (336) 889-5000

Christopher Hauger, UST Class A Operator Christopher.hauger@odfl.com

Christopher Hauger, UST Class B Operator Christopher.hauger@odfl.com

Tank Number	S1	**Tank Age**	13	**Tank Installed Date**	10/01/2012	**Tank Material Construction**	Other	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	
Tag Number	5393	**Spill Test Date**		**Piping Installed Date**	10/05/2012	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	Yes
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	03/02/2022	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	15000	**ATG Test Date**		**Line Tightness Test Date**	09/01/2020	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	Yes
		Overfill Test Date				**ATG Type**					

Facility Summary in Yellowstone County in the City of Billings

Location: ON YOUR WAY 104
1031 N 24th St W
Billings, MT 59102-3807 Yellowstone

System Facility ID:56-05750

Facility Code: 30057
Last Inspected On: 10/04/2024
Operating Permit Renewal Date: 02/05/2028

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Harinder Singh;HRK Inc **(406) 868-2062;(406) 868-2062** **inder4030@yahoo.com**

Operator Contact:

Owner/Operator: Harinder Singh,HRK Inc (406) 868-2062 inder4030@yahoo.com

Tank Number	01	**Tank Age**	41	**Tank Installed Date**	09/01/1984	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	3720	**Spill Test Date**	04/26/2024	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**	04/26/2024	**Tank/Piping CP Test Date**	04/26/2024	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	04/26/2024	**Line Tightness Test Date**	03/01/2021	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	04/26/2024			**ATG Type**	Gilbarco/EMC Basic				
Tank Number	02	**Tank Age**	41	**Tank Installed Date**	09/01/1984	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	3721	**Spill Test Date**	10/04/2024	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**	04/03/2025	**Tank/Piping CP Test Date**	04/26/2024	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	04/26/2024	**Line Tightness Test Date**	03/01/2021	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	04/26/2024			**ATG Type**	Gilbarco/EMC Basic				

Facility Summary in Yellowstone County in the City of Billings

Location: ON YOUR WAY 105
942 Broadwater Ave
Billings, MT 59101 Yellowstone

System Facility ID:56-08671

Facility Code: 30281
Last Inspected On: 11/10/2023
Operating Permit Renewal Date: 11/10/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: HRK Inc **(406) 868-2062**

Operator Contact:

Owner/Operator: HRK Inc (406) 868-2062

Tank Number	04	**Tank Age**	32	**Tank Installed Date**	12/01/1993	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	3169	**Spill Test Date**	09/27/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	11/28/2023	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	09/27/2023	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**		**Line Tightness Test Date**	10/25/2017	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	09/27/2023			**ATG Type**					
Tank Number	05	**Tank Age**	32	**Tank Installed Date**	12/01/1993	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	3170	**Spill Test Date**	09/27/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	11/28/2023	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	09/27/2023	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**		**Line Tightness Test Date**	10/25/2017	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	09/27/2023			**ATG Type**					

Facility Summary in Yellowstone County in the City of Billings

Location: ON YOUR WAY 106
730 Lake Elmo Dr
Billings, MT 59105-3128 Yellowstone

System Facility ID:56-00063

Facility Code: 29689
Last Inspected On: 08/04/2023
Operating Permit Renewal Date: 01/08/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:

Operator Contact:

Tank Number	01	**Tank Age**	41	**Tank Installed Date**	12/20/1984	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	1871	**Spill Test Date**	08/04/2023	**Piping Installed Date**	02/03/2000	**Tank Construction**	Lined Interior/Impressed Current	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	08/04/2023	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	08/04/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	08/04/2023	**Line Tightness Test Date**	08/04/2023	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	08/04/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	02	**Tank Age**	41	**Tank Installed Date**	12/20/1984	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	1872	**Spill Test Date**	08/04/2023	**Piping Installed Date**	02/03/2000	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	08/04/2023	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	08/04/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	08/04/2023	**Line Tightness Test Date**	08/04/2023	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	08/04/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	03	**Tank Age**	41	**Tank Installed Date**	12/20/1984	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve

Tag Number	1873	**Spill Test Date**	08/04/2023	**Piping Installed Date**	02/03/2000	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	08/04/2023	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	08/04/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	08/04/2023	**Line Tightness Test Date**	08/04/2023	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	08/04/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Yellowstone County in the City of Billings

Location: ON YOUR WAY 107
702 S 27th St
Billings, MT 59101-4510 Yellowstone

System Facility ID:56-10797

Facility Code: 30360
Last Inspected On: 10/10/2024
Operating Permit Renewal Date: 10/10/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Indian Brothers LLC **(406) 759-5538** **chestersupermarket@gmail.com**

Operator Contact:

Owner/Operator: Indian Brothers LLC (406) 759-5538 chestersupermarket@gmail.com

Tank Number	04	**Tank Age**	27	**Tank Installed Date**	07/01/1998	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	4751	**Spill Test Date**	03/15/2021	**Piping Installed Date**	06/09/2010	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Temporarily Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**	01/04/2022	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	10/10/2024	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**		**Line Tightness Test Date**	07/18/2008	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date	03/15/2021			**ATG Type**	Veeder Root/TLS-300				
Tank Number	05	**Tank Age**	27	**Tank Installed Date**	07/01/1998	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	4752	**Spill Test Date**	03/15/2021	**Piping Installed Date**	06/09/2010	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Temporarily Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**	01/04/2022	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	10/10/2024	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**		**Line Tightness Test Date**	07/18/2008	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date	03/15/2021			**ATG Type**	Veeder Root/TLS-300				

Facility Summary in Yellowstone County in the City of Billings

Location: PACIFIC SUPPLY
600 Daniel St
Billings, MT 59101-3221 Yellowstone

System Facility ID:56-04965

Facility Code: 29960
Last Inspected On: 01/31/2023
Operating Permit Renewal Date: 01/31/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Pacific Coast Building Products Rancho Cordova **(916) 971-2301**

Operator Contact: Dennis Yonts;Kate Renner;Ryan Eklund **(406) 245-8876** **dennis.yonts@paccoast.com;kate.renner@paccoast.com;ryan.eklund@paccoast.com**

Owner/Operator: Pacific Coast Building Products Rancho Cordova (916) 971-2301

Dennis Yonts, UST Class A Operator	dennis.yonts@paccoast.com
Kate Renner, UST Class A Operator	kate.renner@paccoast.com
Kayla Wittman, UST Class B Operator	kayla.wittman@paccoast.com
Ryan Eklund, UST Class A Operator	ryan.eklund@paccoast.com
Ryan Eklund, UST Class B Operator	ryan.eklund@paccoast.com

Tank Number	03	**Tank Age**	32	**Tank Installed Date**	11/01/1993	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Steel	**Overfill Types**	Flapper Valve
Tag Number	4350	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Temporarily Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**	Franklin Fueling Systems/S940				

Facility Summary in Yellowstone County in the City of Billings

Location: PAR MONTANA BILLINGS PRODUCTS TERMINAL
607 Exxonmobil Rd
Billings, MT 59101 Yellowstone

System Facility ID:56-11335

Facility Code: 30374
Last Inspected On: 06/25/2024
Operating Permit Renewal Date: 10/13/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	PAR MONTANA	**(281) 899-4847**	**bmcfarland@parpacific.com**
Operator Contact:	Bry Joaillier Allen;Christopher Martin;Christy Minnis;James Vokral;Janie Lee;Jason Martin;Michael Bailey;Michael James;Robert Ochsenbein;Tyler Wattles	**(406) 413-8460;(406) 586-6927;(406) 657-5404;(435) 764-7049;(832) 624-7774;(832) 624-7876;(901) 302-8249**	**christy.n.minnis@exxonmobil.com;colt_ochsenbein@hotmail.com;jason.m.martin@exxonmobil.com;tyler.j.wattles@exxonmobil.com**

Owner/Operator:	PAR MONTANA	(281) 899-4847	bmcfarland@parpacific.com
	Bry Joaillier Allen, UST Class A Operator		
	Bry Joaillier Allen, UST Class B Global Operator		
	Christopher Martin, UST Class A Operator		
	Christopher Martin, UST Class B Operator		
	Christy Minnis, UST Class A Operator		christy.n.minnis@exxonmobil.com
	Christy Minnis, UST Class B Global Operator		christy.n.minnis@exxonmobil.com
	James Vokral, UST Class A Operator		
	James Vokral, UST Class B Global Operator		
	Janie Lee, UST Class A Operator		
	Janie Lee, UST Class B Global Operator		
	M Martin, UST Class A Operator		jason.m.martin@exxonmobil.com
	M Martin, UST Class B Global Operator		jason.m.martin@exxonmobil.com
	Michael Bailey, UST Class A Operator		
	Michael Bailey, UST Class B Global Operator		
	Michael James, UST Class A Operator		
	Michael James, UST Class B Global Operator		
	Robert Ochsenbein, UST Class A Operator		colt_ochsenbein@hotmail.com
	Robert Ochsenbein, UST Class B Global Operator		colt_ochsenbein@hotmail.com
	Tyler Wattles, UST Class A Operator		tyler.j.wattles@exxonmobil.com

Tank Number	S16	**Tank Age**	0	**Tank Installed Date**		**Tank Material Construction**	Bare Steel	**Piping Material**	Steel	**Overfill Types**	
Tag Number		**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Other**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**		**Piping Type**	Not Listed	**CP Met Types**	

Product	Oil/Water Separator	**PLLD Test Date**		**Tank/Piping CP Test Date**	10/03/2008	**Primary Tank Leak Detection**	Deferred	**Primary Pipe Leak Detection**	Deferred	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**		**Line Tightness Test Date**	11/10/2009	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	37	**Tank Age**	31	**Tank Installed Date**	10/01/1994	**Tank Material Construction**	Steel Clad	**Piping Material**	Steel	**Overfill Types**	High Level Alarm
Tag Number	2736	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Gravity Feed	**CP Met Types**	Impressed Current
Product	Mixture	**PLLD Test Date**		**Tank/Piping CP Test Date**	10/20/2020	**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	3-Year Line Tightness Test	**Vapor Recovery**	No
Capacity	3000	**ATG Test Date**	06/25/2024	**Line Tightness Test Date**	11/29/2023	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	06/25/2024			**ATG Type**					
Tank Number	S02	**Tank Age**	75	**Tank Installed Date**	01/01/1950	**Tank Material Construction**	Unknown	**Piping Material**	Steel - Terminal Piping	**Overfill Types**	
Tag Number	2738	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	Yes
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	12/21/2023	**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**	Terminal Piping Annual Line Test	**Vapor Recovery**	No
Capacity	197000	**ATG Test Date**		**Line Tightness Test Date**	11/19/2023	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	S13	**Tank Age**	75	**Tank Installed Date**	01/01/1950	**Tank Material Construction**	Unknown	**Piping Material**	Steel - Terminal Piping	**Overfill Types**	
Tag Number	2749	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	Yes
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	12/21/2023	**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**	Terminal Piping Annual Line Test	**Vapor Recovery**	No
Capacity	60000	**ATG Test Date**		**Line Tightness Test Date**	11/18/2023	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	S14	**Tank Age**	75	**Tank Installed Date**	01/01/1950	**Tank Material Construction**	Unknown	**Piping Material**	Steel - Terminal Piping	**Overfill Types**	
Tag Number	2750	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	Yes

Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	12/21/2024	**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**	Terminal Piping Annual Line Test	**Vapor Recovery**	No
Capacity	60000	**ATG Test Date**		**Line Tightness Test Date**	11/18/2023	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	S44	**Tank Age**	28	**Tank Installed Date**	05/01/1997	**Tank Material Construction**	Unknown	**Piping Material**	Steel	**Overfill Types**	
Tag Number	2751	**Spill Test Date**		**Piping Installed Date**	01/04/2017	**Tank Construction**		**Piping Construction**	Secondary Containment Chase	**AST**	Yes
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	06/25/2024	**Catastrophic L.D. Type 3.0**	Continuous Interstitial Monitoring	**Piping Type**	Pressurized	**CP Met Types**	
Product	Hazardous Substance	**PLLD Test Date**		**Tank/Piping CP Test Date**	10/03/2008	**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	15000	**ATG Test Date**		**Line Tightness Test Date**	11/10/2009	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	S45	**Tank Age**	28	**Tank Installed Date**	05/01/1997	**Tank Material Construction**	Unknown	**Piping Material**	Steel	**Overfill Types**	
Tag Number	2752	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	Yes
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	06/25/2024	**Catastrophic L.D. Type 3.0**	Continuous Interstitial Monitoring	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Hazardous Substance	**PLLD Test Date**		**Tank/Piping CP Test Date**	10/03/2008	**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**		**Line Tightness Test Date**	11/10/2009	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	S46	**Tank Age**	28	**Tank Installed Date**	05/01/1997	**Tank Material Construction**	Unknown	**Piping Material**	Steel	**Overfill Types**	
Tag Number	2753	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	Yes
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	06/25/2024	**Catastrophic L.D. Type 3.0**	Continuous Interstitial Monitoring	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Hazardous Substance	**PLLD Test Date**		**Tank/Piping CP Test Date**	10/03/2008	**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No

Capacity	12000	**ATG Test Date**		**Line Tightness Test Date**	11/10/2009	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	S47	**Tank Age**	28	**Tank Installed Date**	05/01/1997	**Tank Material Construction**	Unknown	**Piping Material**	Steel	**Overfill Types**	
Tag Number	2754	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	Yes
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	06/25/2024	**Catastrophic L.D. Type 3.0**	Continuous Interstitial Monitoring	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Hazardous Substance	**PLLD Test Date**		**Tank/Piping CP Test Date**	10/03/2008	**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**		**Line Tightness Test Date**	11/10/2009	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	S48	**Tank Age**	28	**Tank Installed Date**	05/01/1997	**Tank Material Construction**	Unknown	**Piping Material**	Steel	**Overfill Types**	
Tag Number	2755	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	Yes
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	06/25/2024	**Catastrophic L.D. Type 3.0**	Continuous Interstitial Monitoring	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Hazardous Substance	**PLLD Test Date**		**Tank/Piping CP Test Date**	10/03/2008	**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**		**Line Tightness Test Date**	11/10/2009	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	S49	**Tank Age**	28	**Tank Installed Date**	05/01/1997	**Tank Material Construction**	Unknown	**Piping Material**	Steel	**Overfill Types**	
Tag Number	2756	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	Yes
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	06/25/2024	**Catastrophic L.D. Type 3.0**	Continuous Interstitial Monitoring	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Hazardous Substance	**PLLD Test Date**		**Tank/Piping CP Test Date**	10/03/2008	**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**		**Line Tightness Test Date**	11/10/2009	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	S39	**Tank Age**	28	**Tank Installed Date**	05/01/1997	**Tank Material Construction**	Unknown	**Piping Material**	Steel	**Overfill Types**	

Tag Number	2758	**Spill Test Date**		**Piping Installed Date**	01/04/2017	**Tank Construction**		**Piping Construction**	Secondary Containment Chase	**AST**	Yes
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	06/25/2024	**Catastrophic L.D. Type 3.0**	Continuous Interstitial Monitoring	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Hazardous Substance	**PLLD Test Date**		**Tank/Piping CP Test Date**	10/03/2008	**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	15000	**ATG Test Date**		**Line Tightness Test Date**	11/10/2009	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	S40	**Tank Age**	28	**Tank Installed Date**	05/01/1997	**Tank Material Construction**	Unknown	**Piping Material**	Steel	**Overfill Types**	
Tag Number	2759	**Spill Test Date**		**Piping Installed Date**	01/04/2017	**Tank Construction**		**Piping Construction**	Secondary Containment Chase	**AST**	Yes
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	06/25/2024	**Catastrophic L.D. Type 3.0**	Continuous Interstitial Monitoring	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Hazardous Substance	**PLLD Test Date**		**Tank/Piping CP Test Date**	10/03/2008	**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	15000	**ATG Test Date**		**Line Tightness Test Date**	11/10/2009	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	S41	**Tank Age**	28	**Tank Installed Date**	05/01/1997	**Tank Material Construction**	Unknown	**Piping Material**	Steel	**Overfill Types**	
Tag Number	2760	**Spill Test Date**		**Piping Installed Date**	01/04/2017	**Tank Construction**		**Piping Construction**	Secondary Containment Chase	**AST**	Yes
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	06/25/2024	**Catastrophic L.D. Type 3.0**	Continuous Interstitial Monitoring	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Hazardous Substance	**PLLD Test Date**		**Tank/Piping CP Test Date**	10/03/2008	**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	15000	**ATG Test Date**		**Line Tightness Test Date**	11/10/2009	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	S42	**Tank Age**	28	**Tank Installed Date**	05/01/1997	**Tank Material Construction**	Unknown	**Piping Material**	Steel	**Overfill Types**	
Tag Number	2761	**Spill Test Date**		**Piping Installed Date**	01/04/2017	**Tank Construction**		**Piping Construction**	Secondary Containment Chase	**AST**	Yes

Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	06/25/2024	**Catastrophic L.D. Type 3.0**	Continuous Interstitial Monitoring	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Hazardous Substance	**PLLD Test Date**		**Tank/Piping CP Test Date**	10/03/2008	**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	15000	**ATG Test Date**		**Line Tightness Test Date**	11/10/2009	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	S43	**Tank Age**	28	**Tank Installed Date**	05/01/1997	**Tank Material Construction**	Unknown	**Piping Material**	Steel	**Overfill Types**	
Tag Number	2762	**Spill Test Date**		**Piping Installed Date**	01/04/2017	**Tank Construction**		**Piping Construction**	Secondary Containment Chase	**AST**	Yes
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	09/30/2021	**Catastrophic L.D. Type 3.0**	Continuous Interstitial Monitoring	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Hazardous Substance	**PLLD Test Date**		**Tank/Piping CP Test Date**	10/03/2008	**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	15000	**ATG Test Date**		**Line Tightness Test Date**	11/10/2009	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	S50	**Tank Age**	28	**Tank Installed Date**	05/01/1997	**Tank Material Construction**	Unknown	**Piping Material**	Steel	**Overfill Types**	
Tag Number	2763	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	Yes
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	06/25/2024	**Catastrophic L.D. Type 3.0**	Continuous Interstitial Monitoring	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Hazardous Substance	**PLLD Test Date**		**Tank/Piping CP Test Date**	10/03/2008	**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**		**Line Tightness Test Date**	11/10/2009	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	S34	**Tank Age**	73	**Tank Installed Date**	01/01/1952	**Tank Material Construction**	Unknown	**Piping Material**	Steel - Terminal Piping	**Overfill Types**	
Tag Number	2764	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	Yes
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	12/21/2023	**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**	Terminal Piping Annual Line Test	**Vapor Recovery**	No

Capacity	2959110	**ATG Test Date**		**Line Tightness Test Date**	11/18/2023	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	S35	**Tank Age**	73	**Tank Installed Date**	01/01/1952	**Tank Material Construction**	Unknown	**Piping Material**	Steel - Terminal Piping	**Overfill Types**	
Tag Number	2765	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	Yes
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	12/21/2023	**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**	Terminal Piping Annual Line Test	**Vapor Recovery**	No
Capacity	1784454	**ATG Test Date**		**Line Tightness Test Date**	11/18/2023	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	S36	**Tank Age**	73	**Tank Installed Date**	01/01/1952	**Tank Material Construction**	Unknown	**Piping Material**	Steel - Terminal Piping	**Overfill Types**	
Tag Number	2766	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	Yes
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	12/21/2023	**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**	Terminal Piping Annual Line Test	**Vapor Recovery**	No
Capacity	1749888	**ATG Test Date**		**Line Tightness Test Date**	11/18/2023	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					

Facility Summary in Yellowstone County in the City of Billings

Location: PEPSI COLA BOTTLING CO BILLINGS
344 Howard Ave
Billings, MT 59101-3039 Yellowstone

System Facility ID:56-08323

Facility Code: 30261
Last Inspected On: 02/08/2024
Operating Permit Renewal Date: 06/13/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Pepsi Cola Bottling Co **(406) 252-9355**

Operator Contact: Patrick Boehm **pboehm@bigskypepsi.com**

Owner/Operator: Pepsi Cola Bottling Co (406) 252-9355

Patrick Boehm, UST Class A Operator pboehm@bigskypepsi.com
Patrick Boehm, UST Class B Operator pboehm@bigskypepsi.com

Tank Number	03	**Tank Age**	35	**Tank Installed Date**	08/01/1990	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Steel	**Overfill Types**	Flapper Valve
Tag Number	1798	**Spill Test Date**	02/08/2024	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	02/08/2024	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	3000	**ATG Test Date**	02/08/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	02/08/2024			**ATG Type**	OPW/EECO 1500				

Facility Summary in Yellowstone County in the City of Billings

Location: POLY CONOCO
1704 Poly Dr
Billings, MT 59102-1729 Yellowstone

System Facility ID:56-04414

Facility Code: 29908
Last Inspected On: 01/10/2019
Operating Permit Renewal Date: 02/13/2022

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Morledge - Hampton Family LLC	**(406) 672-1044**	**dsmorledge@gmail.com**
Operator Contact:	Lawrence Sperry	**(406) 245-6944**	**sperryscue@earthlink.net**

Lawrence Sperry, UST Class A Operator	sperryscue@earthlink.net
Lawrence Sperry, UST Class A Operator	sperryscue@earthlink.net
Lawrence Sperry, UST Class B Operator	sperryscue@earthlink.net
Lawrence Sperry, UST Class B Operator	sperryscue@earthlink.net

Tank Number	05	**Tank Age**	27	**Tank Installed Date**	02/11/1998	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	4718	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	01/10/2019	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	20000	**ATG Test Date**		**Line Tightness Test Date**	01/09/2019	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco/EMC Basic				
Tank Number	06	**Tank Age**	27	**Tank Installed Date**	02/11/1998	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	4719	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	01/10/2019	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	14000	**ATG Test Date**		**Line Tightness Test Date**	01/08/2019	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco/EMC Basic				

Tank Number	07	**Tank Age**	27	**Tank Installed Date**	02/11/1998	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	4720	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	01/10/2019	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**		**Line Tightness Test Date**	01/09/2019	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco/EMC Basic				

Facility Summary in Yellowstone County in the City of Billings

Location: QWEST BILLINGS WEST CENTRAL OFFICE
3190 Central Ave
Billings, MT 59102-6606 Yellowstone

System Facility ID:56-08762

Facility Code: 30285
Last Inspected On: 10/03/2023
Operating Permit Renewal Date: 05/17/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Qwest Corporation/Century Link		**kevin.robison@centurylink.com**
Operator Contact:	Kevin Robison;Stephanie Miller;Thomas Pitts	**(206) 346-7532;(501) 680-8141;(801) 598-3020**	**kevin.robison@centurylink.com;Stephanie.miller@lumen.com**

Owner/Operator: Qwest Corporation/Century Link — kevin.robison@centurylink.com

Kevin Robison, UST Class A Operator	kevin.robison@centurylink.com
Kevin Robison, UST Class B Global Operator	kevin.robison@centurylink.com
Stephanie Miller, UST Class A Operator	Stephanie.miller@lumen.com
Stephanie Miller, UST Class B Global Operator	Stephanie.miller@lumen.com
Thomas Pitts, UST Class A Operator	
Thomas Pitts, UST Class B Global Operator	
Thomas Pitts, UST Class B Operator	

Tank Number	02	**Tank Age**	31	**Tank Installed Date**	11/01/1994	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	1733	**Spill Test Date**	10/03/2023	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Auto Dialer	**Piping Type**	U.S. Suction	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	08/20/2012	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	3-Year Line Tightness Test	**Vapor Recovery**	No
Capacity	1000	**ATG Test Date**	10/03/2023	**Line Tightness Test Date**	10/03/2023	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	10/03/2023			**ATG Type**	Veeder Root/TLS-300				

Facility Summary in Yellowstone County in the City of Billings

Location: REDDI ELECTRIC INC
1045 1/2 Central Ave
Billings, MT 59102-5821 Yellowstone

System Facility ID:56-06953

Facility Code: 30142
Last Inspected On: 06/19/2024
Operating Permit Renewal Date: 09/16/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Reddi Electric Inc **(406) 245-3141**

Operator Contact: Jordan Schmidt **reddischmidt@outlook.com**

Owner/Operator: Reddi Electric Inc (406) 245-3141

Jordan Schmidt, UST Class A Operator reddischmidt@outlook.com

Jordan Schmidt, UST Class B Operator reddischmidt@outlook.com

Tank Number	02	**Tank Age**	38	**Tank Installed Date**	01/10/1987	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	1837	**Spill Test Date**	06/19/2024	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	06/19/2024	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	560	**ATG Test Date**	06/19/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	06/19/2024			**ATG Type**	Veeder Root/TLS-300				

Facility Summary in Yellowstone County in the City of Billings

Location: RENTAL CAR WASH
3301 Overlook Dr
Billings, MT 59105 Yellowstone

System Facility ID:60-15179

Facility Code: 30905
Last Inspected On: 12/18/2023
Operating Permit Renewal Date: 03/24/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Billings Logan International Airport **(406) 657-8482** **annink@ci.billings.mt.us**

Operator Contact: Donald Kim Annin;Shawn Gaalswyk

Owner/Operator: Billings Logan International Airport (406) 657-8482 annink@ci.billings.mt.us

Dennis Couch, UST Class B Operator couchd@ci.billings.mt.us
Donald Kim Annin, UST Class A Operator
Shawn Gaalswyk, UST Class A Operator

Tank Number	01	**Tank Age**	14	**Tank Installed Date**	04/11/2011	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve
Tag Number	5288	**Spill Test Date**		**Piping Installed Date**	03/29/2011	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	04/07/2022	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	03/15/2024	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	20000	**ATG Test Date**	03/15/2024	**Line Tightness Test Date**	03/17/2023	**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	03/17/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350;Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Yellowstone County in the City of Billings

Location: SAINT VINCENT HOSPITAL AND HEALTH CENTER
1233 N 30th St
Billings, MT 59101-0127 Yellowstone

System Facility ID:56-02666

Facility Code: 29838
Last Inspected On: 01/20/2023
Operating Permit Renewal Date: 05/22/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Saint Vincent Hospital and Health Center	**(406) 237-3065**	
Operator Contact:	Christopher Tull;Saint Vincent Hospital and Health Center;Kevin Maddox;Noah Foley	**(406) 237-3065;(406) 690-3980**	**cmhtull@charter.net;kevin.maddox@imail2.org;noah.foley@imail2.org**

Owner/Operator: Saint Vincent Hospital and Health Center (406) 237-3065

Christopher Tull, UST Class A Operator	cmhtull@charter.net
Christopher Tull, UST Class A Operator	cmhtull@charter.net
Christopher Tull, UST Class B Operator	cmhtull@charter.net
Christopher Tull, UST Class B Operator	cmhtull@charter.net
Kevin Maddox, UST Class A Operator	kevin.maddox@imail2.org
Kevin Maddox, UST Class A Operator	kevin.maddox@imail2.org
Kevin Maddox, UST Class B Operator	kevin.maddox@imail2.org
Kevin Maddox, UST Class B Operator	kevin.maddox@imail2.org
Noah Foley, UST Class A Operator	noah.foley@imail2.org
Noah Foley, UST Class A Operator	noah.foley@imail2.org
Noah Foley, UST Class B Operator	noah.foley@imail2.org
Noah Foley, UST Class B Operator	noah.foley@imail2.org

Tank Number	07	**Tank Age**	9	**Tank Installed Date**	11/01/2016	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Positive Shutoff
Tag Number	5700	**Spill Test Date**		**Piping Installed Date**	11/01/2016	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	01/20/2023	**Catastrophic L.D. Type 3.0**	Continuous Interstitial Monitoring	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	20000	**ATG Test Date**		**Line Tightness Test Date**	11/14/2016	**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**		**Energy Act**	Yes
		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/TLS-350;Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Tank Number	08	**Tank Age**	9	**Tank Installed Date**	11/01/2016	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Positive Shutoff
Tag Number	5701	**Spill Test Date**		**Piping Installed Date**	11/01/2016	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	03/17/2020	**Catastrophic L.D. Type 3.0**	Continuous Interstitial Monitoring	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	20000	**ATG Test Date**		**Line Tightness Test Date**	11/14/2016	**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**		**Energy Act**	Yes
		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/TLS-350;Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Yellowstone County in the City of Billings

Location: SAMS CLUB
4420 King Ave E
Billings, MT 59101 Yellowstone

System Facility ID:60-15138

Facility Code: 30882
Last Inspected On: 12/20/2024
Operating Permit Renewal Date: 06/17/2028

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Sams West Inc	**(785) 550-8812**	**marie.brouhard@aptim.com**
Operator Contact:	Donald Elderbaum;Kevin Allen;Sandy Goff;Stacie Greer;Steven Hodge;Tyler Babb	**(406) 256-7277;(406) 698-0157;(513) 257-4034;(937) 543-9552**	**don_elderbaum@yahoo.com;skgreer.s07805.us@samsclub.com;slgoff.s04805.us@samsclub.com;steve@1stchoice-inc.com;tyler.babb@7g-enviro.com**

Owner/Operator:	Sams West Inc	(785) 550-8812	marie.brouhard@aptim.com
	Debbie Nette, UST Class B Operator		dmn000r.s04805.us@samsclub.com
	Donald Elderbaum, UST Class A Operator		don_elderbaum@yahoo.com
	Donald Elderbaum, UST Class B Global Operator		don_elderbaum@yahoo.com
	James Ray, UST Class B Global Operator		
	Johney Miller, UST Class B Global Operator		john.miller@7g-enviro.com
	Joseph Khan, UST Class B Operator		joseph@1stchoice-inc.com
	Kevin Allen, UST Class A Operator		
	Kevin Allen, UST Class B Global Operator		
	Rick Weaver, UST Class B Global Operator		
	Sandy Goff, UST Class A Operator		slgoff.s04805.us@samsclub.com
	Sandy Goff, UST Class B Global Operator		slgoff.s04805.us@samsclub.com
	Stacie Greer, UST Class A Operator		skgreer.s07805.us@samsclub.com
	Stacie Greer, UST Class B Operator		skgreer.s07805.us@samsclub.com
	Steven Hodge, UST Class A Operator		steve@1stchoice-inc.com
	Steven Hodge, UST Class B Global Operator		steve@1stchoice-inc.com
	Tyler Babb, UST Class A Operator		tyler.babb@7g-enviro.com

Tank Number	01	**Tank Age**	16	**Tank Installed Date**	09/08/2009	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	5210	**Spill Test Date**	04/18/2024	**Piping Installed Date**	05/20/2009	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	04/18/2024	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	Yes
Capacity	20000	**ATG Test Date**	04/18/2024	**Line Tightness Test Date**	04/18/2024	**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No

		Overfill Test Date	03/06/2025			**ATG Type**	Gilbarco-Veeder Root/TLS-450;Veeder Root/TLS-450				
Tank Number	02	**Tank Age**	16	**Tank Installed Date**	09/08/2009	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	5211	**Spill Test Date**	03/17/2022	**Piping Installed Date**	05/20/2009	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	03/17/2022	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	20000	**ATG Test Date**	03/17/2022	**Line Tightness Test Date**	03/17/2022	**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	03/17/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-450;Veeder Root/TLS-450				
Tank Number	03	**Tank Age**	16	**Tank Installed Date**	09/08/2009	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	5212	**Spill Test Date**	03/17/2022	**Piping Installed Date**	05/20/2009	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	03/17/2022	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	03/17/2022	**Line Tightness Test Date**	03/17/2022	**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	03/17/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-450;Veeder Root/TLS-450				
Tank Number	04	**Tank Age**	16	**Tank Installed Date**	09/08/2009	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	5213	**Spill Test Date**	03/17/2022	**Piping Installed Date**	05/20/2009	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	03/17/2022	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	03/17/2022	**Line Tightness Test Date**	03/17/2022	**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No

		Overfill Test Date	03/17/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-450;Veeder Root/TLS-450				

Facility Summary in Yellowstone County in the City of Billings

Location: SHORT STOP
804 Central Ave
Billings, MT 59102-5818 Yellowstone

System Facility ID:56-06609

Facility Code: 30126
Last Inspected On: 04/22/2022
Operating Permit Renewal Date: 04/22/2025

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Stockton Oil Co Billings **office@stocktonoil.com**

Operator Contact:

Owner/Operator: Stockton Oil Co Billings office@stocktonoil.com

Christopher Stockton, UST Class B Global Operator cstockton@stocktonoil.com
Joey McConnell , UST Class B Global Operator jmcconnell@stocktonoil.com
Joey McConnell , UST Class B Global Operator jmcconnell@stocktonoil.com
Joseph Stockton, UST Class B Global Operator jstockton@stocktonoil.com
Joseph Stockton, UST Class B Global Operator jstockton@stocktonoil.com

Tank Number	01	**Tank Age**	44	**Tank Installed Date**	03/26/1981	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	3754	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**	Lined Interior/Impressed Current	**Piping Construction**	None	**AST**	No
Status	**Temporarily Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	04/22/2022	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	02	**Tank Age**	44	**Tank Installed Date**	03/26/1981	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	3899	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**	Lined Interior/Impressed Current	**Piping Construction**	None	**AST**	No
Status	**Temporarily Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	04/22/2022	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No

Capacity	8000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	03	**Tank Age**	44	**Tank Installed Date**	03/26/1981	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	4920	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**	Lined Interior/Impressed Current	**Piping Construction**	None	**AST**	No
Status	**Temporarily Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	04/22/2022	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	04	**Tank Age**	44	**Tank Installed Date**	03/26/1981	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	4921	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**	Lined Interior/Impressed Current	**Piping Construction**	None	**AST**	No
Status	**Temporarily Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	04/22/2022	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					

Facility Summary in Yellowstone County in the City of Billings

Location: SKYVIEW HIGH SCHOOL DIST 2
1775 High Sierra Blvd
Billings, MT 59105 Yellowstone

System Facility ID:56-10585

Facility Code: 30356
Last Inspected On: 11/03/2021
Operating Permit Renewal Date: 12/10/2024

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Billings School District **(406) 247-3777**

Operator Contact: Megan Trevino **trevinom@billingsschools.org**

Megan Trevino, UST Class A Operator	trevinom@billingsschools.org
Megan Trevino, UST Class A Operator	trevinom@billingsschools.org
Michael Heinzman, UST Class B Global Operator	heinzman31@gmail.com
Michael Heinzman, UST Class B Global Operator	heinzman31@gmail.com

Tank Number	S1	**Tank Age**	38	**Tank Installed Date**	03/16/1987	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	448	**Spill Test Date**	11/03/2021	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**	11/03/2021	**Catastrophic L.D. Type 3.0**	Auto Dialer	**Piping Type**	U.S. Suction	**CP Met Types**	Galvanic
Product	Heating Oil	**PLLD Test Date**		**Tank/Piping CP Test Date**	11/03/2021	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	11/03/2021	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	11/04/2021			**ATG Type**	Veeder Root/TLS-300				

Facility Summary in Yellowstone County in the City of Billings

Location: STOCKTON OIL CO 4TH AVE N
1607 4th Ave N
Billings, MT 59101-1522 Yellowstone

System Facility ID:56-04839

Facility Code: 29940
Last Inspected On: 08/19/2022
Operating Permit Renewal Date: 08/19/2025

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Stockton Oil Co Billings **office@stocktonoil.com**

Operator Contact: Dan Stockton **dstockton@stocktonoil.com**

Christopher Stockton, UST Class B Global Operator	cstockton@stocktonoil.com
Dan Stockton, UST Class A Operator	dstockton@stocktonoil.com
Dan Stockton, UST Class B Global Operator	dstockton@stocktonoil.com
Joseph Stockton, UST Class B Global Operator	jstockton@stocktonoil.com
Joseph Stockton, UST Class B Global Operator	jstockton@stocktonoil.com

Tank Number	11	**Tank Age**	31	**Tank Installed Date**	07/01/1994	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	
Tag Number		**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**		**Piping Type**	Not Listed	**CP Met Types**	
Product	Oil/Water Separator	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Deferred	**Primary Pipe Leak Detection**	Deferred	**Vapor Recovery**	No
Capacity	2000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	01	**Tank Age**	45	**Tank Installed Date**	03/26/1980	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	1988	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**	Lined Interior/Impressed Current	**Piping Construction**	None	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	11/27/2019	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**		**Line Tightness Test Date**	11/27/2019	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No

		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	06	**Tank Age**	33	**Tank Installed Date**	04/01/1992	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	1989	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	11/27/2019	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**		**Line Tightness Test Date**	11/27/2019	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	07	**Tank Age**	33	**Tank Installed Date**	04/01/1992	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	1990	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	11/27/2019	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	16000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	08	**Tank Age**	33	**Tank Installed Date**	04/01/1992	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	1991	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	11/27/2019	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	16000	**ATG Test Date**		**Line Tightness Test Date**	11/26/2019	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	09	**Tank Age**	33	**Tank Installed Date**	04/01/1992	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	1992	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No

Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	11/27/2019	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	16000	**ATG Test Date**		**Line Tightness Test Date**	11/26/2019	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	10	**Tank Age**	33	**Tank Installed Date**	04/01/1992	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	1993	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	11/27/2019	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	16000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Yellowstone County in the City of Billings

Location: SUPERPUMPER 74
1240 S 27th St
Billings, MT 59101 Yellowstone

System Facility ID:56-00503

Facility Code: 29716
Last Inspected On: 05/16/2025
Operating Permit Renewal Date: 09/28/2025

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Superpumper Inc **(701) 852-1194**

Operator Contact: Vern Patterson;Parkland USA Corporation **(701) 720-6649;(701) 852-1194** **vern.patterson@parklandusa.com;Jake.thomas@parklandusa.com**

Owner/Operator: Superpumper Inc (701) 852-1194

Curtis McBride, UST Class B Operator Jake.thomas@parklandusa.com
Vern Patterson, UST Class A Operator Jake.thomas@parklandusa.com
Vern Patterson, UST Class B Operator Jake.thomas@parklandusa.com

Tank Number	04	**Tank Age**	27	**Tank Installed Date**	05/01/1998	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	1148	**Spill Test Date**	05/16/2025	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	05/16/2025	**Tank/Piping CP Test Date**	05/28/2013	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	05/16/2025	**Line Tightness Test Date**	05/19/2019	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	05/16/2025			**ATG Type**	Gilbarco/EMC				
Tank Number	05	**Tank Age**	27	**Tank Installed Date**	05/01/1998	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	1149	**Spill Test Date**	05/16/2025	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	06/01/2022	**Tank/Piping CP Test Date**	05/28/2013	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	05/16/2025	**Line Tightness Test Date**	12/09/2021	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	05/16/2025			**ATG Type**	Gilbarco/EMC				

Tank Number	06	**Tank Age**	27	**Tank Installed Date**	05/01/1998	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	1150	**Spill Test Date**	05/16/2025	**Piping Installed Date**	04/01/2015	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	04/01/2015	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	06/01/2022	**Tank/Piping CP Test Date**	05/28/2013	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	05/16/2025	**Line Tightness Test Date**	03/16/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date	05/16/2025			**ATG Type**	Gilbarco/EMC				

Facility Summary in Yellowstone County in the City of Billings

Location: SYSCO FOOD SERVICES OF MONTANA MONAD RD
1509 Monad Rd
Billings, MT 59101 Yellowstone

System Facility ID:56-03530

Facility Code: 29872
Last Inspected On: 01/27/2023
Operating Permit Renewal Date: 06/11/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Sysco Food Services of Montana **(406) 247-1131**

Operator Contact: Christopher Murphy;Jason O'Connor **(406) 200-4591** **jason.o'connor@sysco.com**

Owner/Operator: Sysco Food Services of Montana (406) 247-1131

Christopher Murphy, UST Class A Operator
Christopher Murphy, UST Class B Global Operator
Jason O'Connor, UST Class A Operator jason.o'connor@sysco.com
Jason O'Connor, UST Class B Operator jason.o'connor@sysco.com

Tank Number	04	**Tank Age**	18	**Tank Installed Date**	12/27/2007	**Tank Material Construction**	Unknown	**Piping Material**	Flexible Plastic	**Overfill Types**	
Tag Number	5144	**Spill Test Date**		**Piping Installed Date**	07/10/2007	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	Yes
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Diesel	**PLLD Test Date**	01/27/2023	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	01/27/2023	**Line Tightness Test Date**	12/06/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	05	**Tank Age**	18	**Tank Installed Date**	12/27/2007	**Tank Material Construction**	Unknown	**Piping Material**	Flexible Plastic	**Overfill Types**	
Tag Number	5145	**Spill Test Date**		**Piping Installed Date**	07/10/2007	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	Yes
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Diesel	**PLLD Test Date**	01/27/2023	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	01/27/2023	**Line Tightness Test Date**	12/29/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date				**ATG Type**					

Facility Summary in Yellowstone County in the City of Billings

Location: THE WAVE CAR WASH
858 S 29th St W
Billings, MT 59102-7449 Yellowstone

System Facility ID:56-13884

Facility Code: 30559
Last Inspected On: 05/29/2025
Operating Permit Renewal Date: 09/13/2025

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	The Wave and Rocky Toppers	**(406) 656-2781**	**twrtservice@twrt406.net**
Operator Contact:	Stacy Ott;Steven Ott	**(406) 656-2781**	**twrtservice@twrt406.net**

Owner/Operator: The Wave and Rocky Toppers (406) 656-2781 twrtservice@twrt406.net

Stacy Ott, UST Class A Operator twrtservice@twrt406.net
Stacy Ott, UST Class B Operator twrtservice@twrt406.net
Steven Ott, UST Class A Operator twrtservice@twrt406.net

Tank Number	01	**Tank Age**	27	**Tank Installed Date**	06/01/1998	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	3527	**Spill Test Date**	06/03/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**	06/03/2022	**Tank/Piping CP Test Date**	06/03/2022	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	06/03/2022	**Line Tightness Test Date**	04/21/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	06/03/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	02	**Tank Age**	27	**Tank Installed Date**	06/01/1998	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	3528	**Spill Test Date**	06/03/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**	06/03/2022	**Tank/Piping CP Test Date**	06/03/2022	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	06/03/2022	**Line Tightness Test Date**	04/19/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	06/03/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Yellowstone County in the City of Billings

Location: TOWN AND COUNTRY HILL TOP
523 Hilltop Rd
Billings, MT 59105-2374 Yellowstone

System Facility ID:56-13731

Facility Code: 30458
Last Inspected On: 07/08/2022
Operating Permit Renewal Date: 12/12/2025

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Town and Country Supply Association **(406) 628-6314**

Operator Contact: Karissa Lueck;Mark Heimbichner;Tammi Pritchett;Town and Country Supply Association **(406) 628-6314** **bummer1228@gmail.com;laurel@tandcsupply.com;mark@tandcsupply.com**

Owner/Operator: Town and Country Supply Association (406) 628-6314

Karissa Lueck, UST Class A Operator	laurel@tandcsupply.com
Karissa Lueck, UST Class B Operator	laurel@tandcsupply.com
Mark Heimbichner, UST Class A Operator	mark@tandcsupply.com
Tammi Pritchett, UST Class A Operator	bummer1228@gmail.com
Tammi Pritchett, UST Class B Operator	bummer1228@gmail.com

Tank Number	01	**Tank Age**	29	**Tank Installed Date**	07/01/1996	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	3419	**Spill Test Date**	07/08/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	01/24/2023	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**	07/08/2022	**Tank/Piping CP Test Date**	07/08/2022	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	07/08/2022	**Line Tightness Test Date**	05/09/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	07/08/2022			**ATG Type**	Gilbarco/EMC Basic				
Tank Number	02	**Tank Age**	29	**Tank Installed Date**	07/01/1996	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	3420	**Spill Test Date**	07/08/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	01/24/2023	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**	07/08/2022	**Tank/Piping CP Test Date**	07/08/2022	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	07/08/2022	**Line Tightness Test Date**	05/03/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No

		Overfill Test Date	07/08/2022			**ATG Type**	Gilbarco/EMC Basic				
Tank Number	03	**Tank Age**	11	**Tank Installed Date**	06/30/2014	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	5509	**Spill Test Date**	07/08/2022	**Piping Installed Date**	06/10/2014	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	01/24/2023	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	07/08/2022	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	07/08/2022	**Line Tightness Test Date**	05/03/2022	**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	07/08/2022			**ATG Type**	Gilbarco/EMC Basic;Gilbarco-Veeder Root/EMC Basic				

Facility Summary in Yellowstone County in the City of Billings

Location: TOWN PUMP BILLINGS 11
450 Main St
Billings, MT 59105 Yellowstone

System Facility ID:60-15297

Facility Code: 31001
Last Inspected On: 03/08/2024
Operating Permit Renewal Date: 07/21/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Billings 11 Town Pump LLC **(406) 497-6700** **environmental@townpump.com**

Operator Contact: Trent Biggers **Trentb@townpump.com**

Owner/Operator: Billings 11 Town Pump LLC (406) 497-6700 environmental@townpump.com

Trent Biggers, UST Class A Operator Trentb@townpump.com

Trent Biggers, UST Class B Operator Trentb@townpump.com

Tank Number	01	**Tank Age**	8	**Tank Installed Date**	09/12/2017	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	5709	**Spill Test Date**	10/05/2023	**Piping Installed Date**	09/12/2017	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	10/05/2023	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	03/08/2024	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	Yes
Capacity	25000	**ATG Test Date**	03/08/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Statistical Inventory Reconciliation	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	Yes
		Overfill Test Date	10/05/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-450				
Tank Number	02	**Tank Age**	8	**Tank Installed Date**	09/12/2017	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	5710	**Spill Test Date**	10/05/2023	**Piping Installed Date**	09/12/2017	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	10/05/2023	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	03/08/2024	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	Yes
Capacity	15000	**ATG Test Date**	03/08/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Statistical Inventory Reconciliation	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	Yes
		Overfill Test Date	10/05/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-450				

Tank Number	03	**Tank Age**	8	**Tank Installed Date**	09/12/2017	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	5711	**Spill Test Date**	10/05/2023	**Piping Installed Date**	09/12/2017	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	10/05/2023	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	03/08/2024	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	15000	**ATG Test Date**	03/08/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Statistical Inventory Reconciliation	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	Yes
		Overfill Test Date	10/05/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-450				
Tank Number	04	**Tank Age**	8	**Tank Installed Date**	09/12/2017	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	5712	**Spill Test Date**	10/05/2023	**Piping Installed Date**	09/12/2017	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	10/05/2023	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	03/08/2024	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	Yes
Capacity	7000	**ATG Test Date**	03/08/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Statistical Inventory Reconciliation	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	Yes
		Overfill Test Date	10/05/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-450				
Tank Number	05	**Tank Age**	8	**Tank Installed Date**	09/12/2017	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	5713	**Spill Test Date**	10/05/2023	**Piping Installed Date**	09/12/2017	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	10/05/2023	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	03/08/2024	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	7000	**ATG Test Date**	03/08/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Statistical Inventory Reconciliation	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	Yes
		Overfill Test Date	10/05/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-450				
Tank Number	06	**Tank Age**	8	**Tank Installed Date**	09/12/2017	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	5714	**Spill Test Date**	10/05/2023	**Piping Installed Date**	09/12/2017	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No

Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	10/05/2023	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel, Dyed	**PLLD Test Date**	03/08/2024	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	7000	**ATG Test Date**	03/08/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Statistical Inventory Reconciliation	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	Yes
		Overfill Test Date	10/05/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-450				
Tank Number	07	**Tank Age**	8	**Tank Installed Date**	09/12/2017	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	
Tag Number	5715	**Spill Test Date**		**Piping Installed Date**	09/12/2017	**Tank Construction**		**Piping Construction**		**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	06/19/2017	**Catastrophic L.D. Type 3.0**	Continuous Interstitial Monitoring	**Piping Type**	Pressurized	**CP Met Types**	
Product	DEF (Not Regulated)	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Approved Remote Monitoring;Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	7000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring;Not Listed	**Energy Act**	No
		Overfill Test Date				**ATG Type**					

Facility Summary in Yellowstone County in the City of Billings

Location: TOWN PUMP BILLINGS 12
3415 Grand Ave
Billings, MT 59102 Yellowstone

System Facility ID:60-15328

Facility Code: 31024
Last Inspected On: 01/25/2024
Operating Permit Renewal Date: 07/21/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Billings 12 Town Pump LLC **(406) 497-6700** **environmental@townpump.com**

Operator Contact: Trent Biggers **Trentb@townpump.com**

Owner/Operator: Billings 12 Town Pump LLC (406) 497-6700 environmental@townpump.com

Trent Biggers, UST Class A Operator Trentb@townpump.com

Trent Biggers, UST Class B Operator Trentb@townpump.com

Tank Number	01	**Tank Age**	6	**Tank Installed Date**	03/01/2019	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	5884	**Spill Test Date**	08/25/2023	**Piping Installed Date**	03/01/2019	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	08/25/2023	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	01/25/2024	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	Yes
Capacity	30000	**ATG Test Date**	01/25/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Statistical Inventory Reconciliation	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	Yes
		Overfill Test Date	08/25/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-450				
Tank Number	02	**Tank Age**	6	**Tank Installed Date**	06/27/2019	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	5885	**Spill Test Date**	08/25/2023	**Piping Installed Date**	06/27/2019	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	08/25/2023	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	01/25/2024	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	7000	**ATG Test Date**	01/25/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Statistical Inventory Reconciliation	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	Yes
		Overfill Test Date	08/25/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-450				

Tank Number	03	**Tank Age**	6	**Tank Installed Date**	06/27/2019	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	5886	**Spill Test Date**	09/19/2023	**Piping Installed Date**	06/27/2019	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	08/25/2023	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	01/25/2024	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	Yes
Capacity	15000	**ATG Test Date**	01/25/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Statistical Inventory Reconciliation	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	Yes
		Overfill Test Date	08/25/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Number	04	**Tank Age**	6	**Tank Installed Date**	06/27/2019	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	5887	**Spill Test Date**	08/25/2023	**Piping Installed Date**	06/27/2019	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	08/25/2023	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	01/25/2024	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	Yes
Capacity	7000	**ATG Test Date**	01/25/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Statistical Inventory Reconciliation	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	Yes
		Overfill Test Date	08/25/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-450				
Tank Number	05	**Tank Age**	6	**Tank Installed Date**	06/27/2019	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	5888	**Spill Test Date**	08/25/2023	**Piping Installed Date**	06/27/2019	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	08/25/2023	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	01/25/2024	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	7000	**ATG Test Date**	01/25/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Statistical Inventory Reconciliation	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	Yes
		Overfill Test Date	08/25/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-450				
Tank Number	06	**Tank Age**	6	**Tank Installed Date**	06/27/2019	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	5889	**Spill Test Date**	08/25/2023	**Piping Installed Date**	06/27/2019	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No

Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	08/25/2023	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	01/25/2024	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	20000	**ATG Test Date**	01/25/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Statistical Inventory Reconciliation	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	Yes
		Overfill Test Date	08/25/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-450				

Facility Summary in Yellowstone County in the City of Billings

Location: TOWN PUMP BILLINGS 13
3975 King Avenue West
Billings, MT 59102 Yellowstone

System Facility ID:00-32484

Facility Code: 32484
Last Inspected On: 03/08/2024
Operating Permit Renewal Date: 07/21/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Billings 13 RE, LLC **(406) 497-6700** **arnoldo@townpump.com**

Operator Contact: Trent Biggers **Trentb@townpump.com**

Owner/Operator: Billings 13 RE, LLC (406) 497-6700 arnoldo@townpump.com

Trent Biggers, UST Class A Operator Trentb@townpump.com

Trent Biggers, UST Class B Operator Trentb@townpump.com

Tank Number	01	**Tank Age**	3	**Tank Installed Date**	12/06/2022	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	6080	**Spill Test Date**	12/16/2022	**Piping Installed Date**	12/06/2022	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	12/16/2022	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	03/08/2024	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	Yes
Capacity	30000	**ATG Test Date**	03/08/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	Yes
		Overfill Test Date	12/16/2022			**ATG Type**					
Tank Number	02	**Tank Age**	3	**Tank Installed Date**	12/06/2022	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	6081	**Spill Test Date**	12/16/2022	**Piping Installed Date**	12/06/2022	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	12/15/2022	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Diesel, Dyed	**PLLD Test Date**	03/08/2024	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	03/08/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	Yes
		Overfill Test Date	12/15/2022			**ATG Type**					

Tank Number	03	**Tank Age**	3	**Tank Installed Date**	12/06/2022	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	6082	**Spill Test Date**	12/16/2022	**Piping Installed Date**	12/06/2022	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	12/15/2022	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Gasoline	**PLLD Test Date**	03/08/2024	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	Yes
Capacity	15000	**ATG Test Date**	03/08/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	Yes
		Overfill Test Date	12/15/2022			**ATG Type**					
Tank Number	04	**Tank Age**	3	**Tank Installed Date**	12/06/2022	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	6083	**Spill Test Date**	12/16/2022	**Piping Installed Date**	12/06/2022	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	12/15/2022	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Gasoline	**PLLD Test Date**	03/08/2024	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	Yes
Capacity	7000	**ATG Test Date**	03/08/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	Yes
		Overfill Test Date	12/15/2022			**ATG Type**					
Tank Number	05	**Tank Age**	3	**Tank Installed Date**	12/06/2022	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	6084	**Spill Test Date**	12/16/2022	**Piping Installed Date**	12/06/2022	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	12/15/2022	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Diesel	**PLLD Test Date**	03/08/2024	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	7000	**ATG Test Date**	03/08/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	Yes
		Overfill Test Date	12/15/2022			**ATG Type**					
Tank Number	06	**Tank Age**	3	**Tank Installed Date**	12/06/2022	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	6085	**Spill Test Date**	12/16/2022	**Piping Installed Date**	12/06/2022	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No

Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	12/15/2022	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Diesel	**PLLD Test Date**	03/08/2024	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	23000	**ATG Test Date**	03/08/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	Yes
		Overfill Test Date	12/15/2022			**ATG Type**					
Tank Number	07	**Tank Age**	3	**Tank Installed Date**	12/06/2022	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	
Tag Number	6086	**Spill Test Date**	12/16/2022	**Piping Installed Date**	12/06/2022	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Other**	**MLLD Test Date**		**Sump Tightness Test Date**	12/15/2022	**Catastrophic L.D. Type 3.0**		**Piping Type**	Pressurized	**CP Met Types**	
Product	DEF (Not Regulated)	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	12/15/2022	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	Yes
		Overfill Test Date				**ATG Type**					

Facility Summary in Yellowstone County in the City of Billings

Location: TOWN PUMP BILLINGS 8
3969 Grand Ave
Billings, MT 59102-7512 Yellowstone

System Facility ID:56-13741

Facility Code: 30459
Last Inspected On: 04/02/2024
Operating Permit Renewal Date: 07/21/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Billings 8 Town Pump LLC **(406) 497-6700** **environmental@townpump.com**

Operator Contact: Trent Biggers **Trentb@townpump.com**

Owner/Operator: Billings 8 Town Pump LLC (406) 497-6700 environmental@townpump.com

Trent Biggers, UST Class A Operator Trentb@townpump.com

Trent Biggers, UST Class B Global Operator Trentb@townpump.com

Tank Number	01	**Tank Age**	29	**Tank Installed Date**	09/01/1996	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	2013	**Spill Test Date**	08/24/2023	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	08/24/2023	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	04/02/2024	**Tank/Piping CP Test Date**	12/22/2011	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	04/02/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	08/24/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350				
Tank Number	02	**Tank Age**	29	**Tank Installed Date**	09/01/1996	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	2014	**Spill Test Date**	01/25/2024	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	08/24/2023	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	04/02/2024	**Tank/Piping CP Test Date**	12/22/2011	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	20000	**ATG Test Date**	04/02/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	08/24/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350				

Tank Number	03	**Tank Age**	29	**Tank Installed Date**	09/01/1996	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	2015	**Spill Test Date**	07/07/2021	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	08/24/2023	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	04/02/2024	**Tank/Piping CP Test Date**	12/22/2011	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	04/02/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	08/24/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350				
Tank Number	04	**Tank Age**	29	**Tank Installed Date**	09/01/1996	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	2016	**Spill Test Date**	01/25/2024	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	08/24/2023	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	04/02/2024	**Tank/Piping CP Test Date**	12/22/2011	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	04/02/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	01/25/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350				
Tank Number	05	**Tank Age**	29	**Tank Installed Date**	09/01/1996	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	2017	**Spill Test Date**	01/25/2024	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	08/24/2023	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel, Dyed	**PLLD Test Date**	04/02/2024	**Tank/Piping CP Test Date**	12/22/2011	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	04/02/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	08/24/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Yellowstone County in the City of Billings

Location: TOWN PUMP INC BILLINGS 1
1028 US Hwy 87 E
Billings, MT 59101-6658 Yellowstone

System Facility ID:56-00767

Facility Code: 29729
Last Inspected On: 03/11/2024
Operating Permit Renewal Date: 07/21/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Billings 1 Town Pump LLC **(406) 497-6700** **environmental@townpump.com**

Operator Contact: Trent Biggers **Trentb@townpump.com**

Owner/Operator: Billings 1 Town Pump LLC (406) 497-6700 environmental@townpump.com

Trent Biggers, UST Class A Operator Trentb@townpump.com
Trent Biggers, UST Class A Operator Trentb@townpump.com
Trent Biggers, UST Class B Global Operator Trentb@townpump.com
Trent Biggers, UST Class B Global Operator Trentb@townpump.com

Tank Number	07	**Tank Age**	29	**Tank Installed Date**	10/02/1996	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve
Tag Number	2665	**Spill Test Date**	11/07/2024	**Piping Installed Date**	07/11/2013	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	11/08/2023	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	03/11/2024	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	03/11/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Statistical Inventory Reconciliation	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	No
		Overfill Test Date	07/31/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350				
Tank Number	08	**Tank Age**	29	**Tank Installed Date**	10/02/1996	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve
Tag Number	2666	**Spill Test Date**	11/07/2024	**Piping Installed Date**	02/15/2013	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	11/08/2023	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	03/11/2024	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	03/11/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Statistical Inventory Reconciliation	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	Yes

		Overfill Test Date	07/31/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350				
Tank Number	09	**Tank Age**	29	**Tank Installed Date**	10/02/1996	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve
Tag Number	2667	**Spill Test Date**	07/31/2023	**Piping Installed Date**	02/15/2013	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	11/08/2023	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	03/11/2024	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	03/11/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Statistical Inventory Reconciliation	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	Yes
		Overfill Test Date	07/31/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350				
Tank Number	10	**Tank Age**	26	**Tank Installed Date**	02/01/1999	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve;Flapper Valve
Tag Number	3921	**Spill Test Date**	07/31/2023	**Piping Installed Date**	04/20/2011	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	11/08/2023	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel, Dyed	**PLLD Test Date**	03/11/2024	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**	03/11/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Statistical Inventory Reconciliation	**Secondary Pipe Leak Detection**		**Energy Act**	Yes
		Overfill Test Date	07/31/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350				
Tank Number	06	**Tank Age**	29	**Tank Installed Date**	10/02/1996	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve
Tag Number	4583	**Spill Test Date**	07/31/2023	**Piping Installed Date**	07/11/2013	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	11/08/2023	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	03/11/2024	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	03/11/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Statistical Inventory Reconciliation	**Secondary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Energy Act**	No
		Overfill Test Date	07/31/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Yellowstone County in the City of Billings

Location: TOWN PUMP INC BILLINGS 3
3150 King Ave W
Billings, MT 59102-6438 Yellowstone

System Facility ID:60-15023

Facility Code: 30809
Last Inspected On: 02/05/2024
Operating Permit Renewal Date: 07/21/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Billings 3 Town Pump LLC **(406) 497-6700** **environmental@townpump.com**

Operator Contact: Trent Biggers **Trentb@townpump.com**

Owner/Operator: Billings 3 Town Pump LLC (406) 497-6700 environmental@townpump.com

Trent Biggers, UST Class A Operator Trentb@townpump.com

Trent Biggers, UST Class B Global Operator Trentb@townpump.com

Tank Number	02	**Tank Age**	19	**Tank Installed Date**	04/01/2006	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve
Tag Number	5056	**Spill Test Date**	11/03/2023	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	02/05/2024	**Tank/Piping CP Test Date**	05/01/2006	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	02/05/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	11/03/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350				
Tank Number	03	**Tank Age**	19	**Tank Installed Date**	04/06/2006	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve
Tag Number	5057	**Spill Test Date**	05/24/2021	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	02/05/2024	**Tank/Piping CP Test Date**	05/01/2006	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	02/05/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/TLS-350				

Tank Number	04	**Tank Age**	19	**Tank Installed Date**	04/14/2006	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve
Tag Number	5058	**Spill Test Date**	05/24/2021	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	02/05/2024	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	02/05/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/TLS-350				
Tank Number	05	**Tank Age**	19	**Tank Installed Date**	04/06/2006	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve
Tag Number	5059	**Spill Test Date**	05/24/2021	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	02/05/2024	**Tank/Piping CP Test Date**	05/01/2006	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	02/05/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/TLS-350				
Tank Number	06	**Tank Age**	19	**Tank Installed Date**	04/06/2006	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve
Tag Number	5060	**Spill Test Date**	11/03/2023	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	02/05/2024	**Tank/Piping CP Test Date**	05/01/2006	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	02/05/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	11/03/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350				
Tank Number	01	**Tank Age**	19	**Tank Installed Date**	04/14/2006	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve
Tag Number	5062	**Spill Test Date**	11/03/2023	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No

Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	02/05/2024	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	20000	**ATG Test Date**	02/05/2024	**Line Tightness Test Date**	05/01/2006	**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	11/03/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Yellowstone County in the City of Billings

Location: TOWN PUMP INC BILLINGS 4
2711 N Frontage Rd
Billings, MT 59101-7327 Yellowstone

System Facility ID:60-15104

Facility Code: 30863
Last Inspected On: 02/05/2024
Operating Permit Renewal Date: 07/21/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Billings 4 Town Pump LLC **(406) 497-6700** **environmental@townpump.com**

Operator Contact: Trent Biggers **Trentb@townpump.com**

Owner/Operator: Billings 4 Town Pump LLC (406) 497-6700 environmental@townpump.com

Trent Biggers, UST Class A Operator Trentb@townpump.com

Trent Biggers, UST Class B Global Operator Trentb@townpump.com

Tank Number	01	**Tank Age**	17	**Tank Installed Date**	12/15/2008	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	5180	**Spill Test Date**	10/08/2023	**Piping Installed Date**	05/27/2008	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	05/06/2021	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	02/05/2024	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	30000	**ATG Test Date**	02/05/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	10/06/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-450				
Tank Number	02	**Tank Age**	17	**Tank Installed Date**	12/15/2008	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	5181	**Spill Test Date**	10/08/2023	**Piping Installed Date**	05/27/2008	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	05/06/2021	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	02/05/2024	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	30000	**ATG Test Date**	02/05/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	10/06/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-450				

Tank Number	03	**Tank Age**	17	**Tank Installed Date**	12/15/2008	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	5182	**Spill Test Date**	10/08/2023	**Piping Installed Date**	05/27/2008	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	05/06/2021	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	02/05/2024	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	30000	**ATG Test Date**	02/05/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	10/06/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-450				
Tank Number	04	**Tank Age**	17	**Tank Installed Date**	12/15/2008	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	5183	**Spill Test Date**	01/24/2024	**Piping Installed Date**	05/27/2008	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	05/06/2021	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	02/05/2024	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	Yes
Capacity	22000	**ATG Test Date**	02/05/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	10/06/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-450				
Tank Number	05	**Tank Age**	17	**Tank Installed Date**	12/18/2008	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	5184	**Spill Test Date**	10/08/2023	**Piping Installed Date**	05/27/2008	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	05/06/2021	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	02/05/2024	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	02/05/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	10/06/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-450				
Tank Number	06	**Tank Age**	17	**Tank Installed Date**	12/18/2008	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	5185	**Spill Test Date**	10/08/2023	**Piping Installed Date**	05/27/2008	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No

Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	05/06/2021	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	02/05/2024	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	Yes
Capacity	22000	**ATG Test Date**	02/05/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	10/06/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-450				
Tank Number	07	**Tank Age**	17	**Tank Installed Date**	12/15/2008	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	5186	**Spill Test Date**	05/06/2021	**Piping Installed Date**	05/27/2008	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	05/06/2021	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	07/06/2022	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	07/07/2022	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/;Gilbarco-Veeder Root/TLS-450				
Tank Number	08	**Tank Age**	16	**Tank Installed Date**	05/01/2009	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve
Tag Number	5353	**Spill Test Date**		**Piping Installed Date**	04/10/2012	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Other**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Continuous Interstitial Monitoring	**Piping Type**	Pressurized	**CP Met Types**	
Product	DEF (Not Regulated)	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	Yes
		Overfill Test Date				**ATG Type**					

Facility Summary in Yellowstone County in the City of Billings

Location: UNFI DISTRIBUTION COMPANY LLC - BILLINGS
1629 King Ave W
Billings, MT 59102-6448 Yellowstone

System Facility ID:56-06097

Facility Code: 30085
Last Inspected On: 04/01/2022
Operating Permit Renewal Date: 08/28/2025

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	UNFI DISTRIBUTION COMPANY LLC	**(503) 936-2348**	**ENVIRONMENTAL@UNFI.COM**
Operator Contact:	Jeffrey Lindell;Mike Frost;Scott Combs	**(406) 247-1523**	**jeff.a.lindell@supervalu.com**

Jeffrey Lindell, UST Class A Operator	jeff.a.lindell@supervalu.com
Jeffrey Lindell, UST Class A Operator	jeff.a.lindell@supervalu.com
John Beadle, UST Class B Operator	john.p.beadle@supervalu.com
John Beadle, UST Class B Operator	john.p.beadle@supervalu.com
Mike Frost, UST Class A Operator	
Mike Frost, UST Class A Operator	
Scott Combs, UST Class A Operator	
Scott Combs, UST Class A Operator	
Scott Combs, UST Class B Global Operator	
Scott Combs, UST Class B Global Operator	
Steve Schilling, UST Class B Operator	steve.j.schilling@supervalu.com
Steve Schilling, UST Class B Operator	steve.j.schilling@supervalu.com

Tank Number	04	**Tank Age**	27	**Tank Installed Date**	09/01/1998	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	1867	**Spill Test Date**	03/20/2020	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**	06/03/2016	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**	04/01/2022	**Tank/Piping CP Test Date**	09/24/2021	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	24000	**ATG Test Date**	04/01/2022	**Line Tightness Test Date**	04/01/2022	**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	04/01/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	05	**Tank Age**	27	**Tank Installed Date**	09/01/1998	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm

Tag Number	1868	**Spill Test Date**	03/20/2020	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**	06/03/2016	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**	04/01/2022	**Tank/Piping CP Test Date**	09/24/2021	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	20000	**ATG Test Date**	04/01/2022	**Line Tightness Test Date**	04/01/2022	**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	04/01/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Yellowstone County in the City of Billings

Location: UNITED PARCEL SERVICES BILLINGS
1830 Lampman Dr
Billings, MT 59102-6442 Yellowstone

System Facility ID:56-04542

Facility Code: 29919
Last Inspected On: 01/14/2025
Operating Permit Renewal Date: 03/22/2028

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	United Parcel Service Inc Seattle		**cdd6jxd@ups.com**
Operator Contact:	Erin Englert;Jonathan Dunbar;United Parcel Service Inc Seattle;Russell Stott	**(503) 978-7678**	**jstott@ups.com;jxdunbar@ups.com;cdd6jxd@ups.com**

Owner/Operator: United Parcel Service Inc Seattle cdd6jxd@ups.com

Erin Englert, UST Class A Operator	
Erin Englert, UST Class A Operator	
Erin Englert, UST Class B Operator	
Erin Englert, UST Class B Operator	
Jonathan Dunbar, UST Class A Operator	cdd6jxd@ups.com
Jonathan Dunbar, UST Class B Operator	cdd6jxd@ups.com
Russell Stott, UST Class A Operator	jstott@ups.com
Russell Stott, UST Class A Operator	jstott@ups.com
Russell Stott, UST Class B Operator	jstott@ups.com
Russell Stott, UST Class B Operator	jstott@ups.com

Tank Number	05	**Tank Age**	32	**Tank Installed Date**	07/20/1993	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	2183	**Spill Test Date**	04/05/2022	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	04/05/2022	**Sump Tightness Test Date**	04/05/2022	**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	04/05/2022	**Line Tightness Test Date**	04/05/2022	**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	04/05/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350;Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	06	**Tank Age**	32	**Tank Installed Date**	07/20/1993	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve

Tag Number	2184	**Spill Test Date**	04/05/2022	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	04/27/2021	**Sump Tightness Test Date**	04/05/2022	**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	Yes
Capacity	12000	**ATG Test Date**	04/05/2022	**Line Tightness Test Date**	04/27/2021	**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	04/05/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350;Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Yellowstone County in the City of Billings

Location: US FOODS INC. 9J - BILLINGS
802 Parkway Ln
Billings, MT 59101-4651 Yellowstone

System Facility ID:56-06132

Facility Code: 30089
Last Inspected On: 04/09/2025
Operating Permit Renewal Date: 06/16/2028

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	US Foods, Inc.	**(402) 212-5976**	**jill.tubbs@usfoods.com**
Operator Contact:	James Pavelka;US Foods. Inc, J9 - Billings;Jeff Brent;Rick Hansen;Rod Ostman;Stace Hovland	**(406) 238-7800;(406) 238-7810;(406) 696-0810;(406) 839-5990**	**james.pavelka@usfoods.com;jeff.brent@usfoods.com;jeff_brent@fsafood.com;rick_hansen@fsafood.com;rod_ostman@fsafood.com;stace_hovland@fsafood.com**

Owner/Operator: US Foods, Inc. (402) 212-5976 jill.tubbs@usfoods.com

David Lake, UST Class B Operator	david_lake@fsafood.com
David Lake, UST Class B Operator	david_lake@fsafood.com
James Pavelka, UST Class A Operator	jeff.brent@usfoods.com
James Pavelka, UST Class B Operator	jeff.brent@usfoods.com
Jeff Brent, UST Class A Operator	jeff_brent@fsafood.com
Jeff Brent, UST Class A Operator	jeff_brent@fsafood.com
Jeff Brent, UST Class B Operator	jeff_brent@fsafood.com
Jeff Brent, UST Class B Operator	jeff_brent@fsafood.com
Rick Hansen, UST Class A Operator	rick_hansen@fsafood.com
Rick Hansen, UST Class A Operator	rick_hansen@fsafood.com
Rod Ostman, UST Class A Operator	rod_ostman@fsafood.com
Rod Ostman, UST Class A Operator	rod_ostman@fsafood.com
Stace Hovland, UST Class A Operator	stace_hovland@fsafood.com
Stace Hovland, UST Class A Operator	stace_hovland@fsafood.com
Stace Hovland, UST Class B Global Operator	stace_hovland@fsafood.com
Stace Hovland, UST Class B Global Operator	stace_hovland@fsafood.com
Stace Hovland, UST Class B Operator	stace_hovland@fsafood.com
Stace Hovland, UST Class B Operator	stace_hovland@fsafood.com

Tank Number	05	**Tank Age**	32	**Tank Installed Date**	11/02/1993	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Steel	**Overfill Types**	High Level Alarm
Tag Number	1781	**Spill Test Date**	04/09/2025	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Single Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	06/19/2024	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**		**Vapor Recovery**	No

Capacity	12000	**ATG Test Date**	04/09/2025	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	04/09/2025			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Yellowstone County in the City of Billings

Location: USF REDDAWAY INC
833 Mullowney Ln
Billings, MT 59101-4654 Yellowstone

System Facility ID:56-01340

Facility Code: 29768
Last Inspected On: 11/29/2021
Operating Permit Renewal Date: 12/06/2024

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Halfway Holdings LLC **(406) 259-9360** **brian@billingsfarmhand.com**

Operator Contact:

Kimberly Allbright Heath, UST Class B Operator

Tank Number	03	**Tank Age**	32	**Tank Installed Date**	08/01/1993	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	3154	**Spill Test Date**	11/29/2021	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Single Walled	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	04/30/2021	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	40000	**ATG Test Date**	11/29/2021	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	11/29/2021			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Yellowstone County in the City of Billings

Location: WARRENS MARKET AND DELI INC
3189 King Ave W
Billings, MT 59102-7466 Yellowstone

System Facility ID:56-10075

Facility Code: 30344
Last Inspected On: 02/27/2020
Operating Permit Renewal Date: 02/27/2023

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Stockton Oil Co Billings		**office@stocktonoil.com**
Operator Contact:	Johnathon Harvey;Paul DiLorenzo	**(406) 371-1700;(406) 839-2399**	**deedlesgas@gmail.com;pj.dilorenzo@prodigy.net**

Christopher Stockton, UST Class B Global Operator	cstockton@stocktonoil.com
Johnathon Harvey, UST Class A Operator	deedlesgas@gmail.com
Johnathon Harvey, UST Class B Operator	deedlesgas@gmail.com
Joseph Stockton, UST Class B Global Operator	jstockton@stocktonoil.com
Paul DiLorenzo, UST Class A Operator	pj.dilorenzo@prodigy.net

Tank Number	01	**Tank Age**	38	**Tank Installed Date**	01/13/1987	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	3834	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Single Walled	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	02/28/2017	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing;Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	16000	**ATG Test Date**		**Line Tightness Test Date**	02/28/2017	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	02	**Tank Age**	38	**Tank Installed Date**	01/13/1987	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	3835	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Single Walled	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	02/28/2017	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing;Statistical Inventory Reconciliation	**Vapor Recovery**	No

Capacity	12000	**ATG Test Date**		**Line Tightness Test Date**	02/28/2017	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	03	**Tank Age**	38	**Tank Installed Date**	01/13/1987	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	3836	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Single Walled	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	02/28/2017	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing;Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**		**Line Tightness Test Date**	02/28/2017	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					

Facility Summary in Yellowstone County in the City of Billings

Location: WELLS FARGO BANK OPERATIONS CENTER
2324 Overland Ave
Billings, MT 59102-6401 Yellowstone

System Facility ID:56-13992

Facility Code: 30653
Last Inspected On: 11/28/2022
Operating Permit Renewal Date: 12/12/2025

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Wells Fargo Bank Billings Operations Center **(406) 655-7390**

Operator Contact: Timothy McCurdy **(406) 200-1778** **timothy.mccurdy@wellsfargo.com**

Owner/Operator: Wells Fargo Bank Billings Operations Center (406) 655-7390

Greg Amos, UST Class B Operator	gregory.l.amos@wellsfargo.com
Richard Brodston, UST Class B Operator	Richard.Brodston@wellsfargo.com
Stan Barr, UST Class B Global Operator	stan.r.barr@wellsfargo.com
Stan Barr, UST Class B Operator	stan.r.barr@wellsfargo.com
Timothy McCurdy, UST Class A Operator	timothy.mccurdy@wellsfargo.com
Trevor Mill, UST Class B Operator	trevor.mill@cbre.com

Tank Number	01	**Tank Age**	25	**Tank Installed Date**	09/01/2000	**Tank Material Construction**	Steel Clad	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	4279	**Spill Test Date**	11/18/2022	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	11/18/2022	**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	U.S. Suction	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	05/30/2008	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	3-Year Line Tightness Test	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	11/18/2022	**Line Tightness Test Date**	11/18/2022	**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	11/18/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	02	**Tank Age**	25	**Tank Installed Date**	09/01/2000	**Tank Material Construction**	Steel Clad	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	4280	**Spill Test Date**	11/18/2022	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	11/18/2022	**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	U.S. Suction	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	05/30/2008	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	3-Year Line Tightness Test	**Vapor Recovery**	No

Capacity	8000	**ATG Test Date**	11/18/2022	**Line Tightness Test Date**	11/18/2022	**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	11/18/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Yellowstone County in the City of Billings

Location: WELLS FARGO CENTER
175 N 27th St
Billings, MT Yellowstone

System Facility ID:56-13972

Facility Code: 30634
Last Inspected On: 08/07/2023
Operating Permit Renewal Date: 08/20/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: S F H II LLC **(406) 651-0603**

Operator Contact: John Schafnitz **(406) 651-0603** **js59102@hotmail.com**

Owner/Operator: S F H II LLC (406) 651-0603

John Schafnitz, UST Class A Operator js59102@hotmail.com
John Schafnitz, UST Class B Operator js59102@hotmail.com

Tank Number	02	**Tank Age**	25	**Tank Installed Date**	11/01/2000	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Copper	**Overfill Types**	Flapper Valve
Tag Number	4231	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Secondary Containment Chase	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	05/14/2020	**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	400	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**	Pneumercator/Other				

Facility Summary in Yellowstone County in the City of Billings

Location: WILD TORNADO
1225 Mullowney Ln
Billings, MT 59101-6301 Yellowstone

System Facility ID:56-06963

Facility Code: 30148
Last Inspected On: 09/16/2022
Operating Permit Renewal Date: 11/30/2025

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	OED LLC	**(406) 670-6097**	**DOUCETTE@BRESNAN.NET**
Operator Contact:	Jay Doucette;OED LLC	**(406) 670-6097;(406) 670-6097**	**DOUCETTE@BRESNAN.NET;DOUCETTE@BRESNAN.NET**

Owner/Operator: OED LLC (406) 670-6097 DOUCETTE@BRESNAN.NET

Jay Doucette, UST Class A Operator DOUCETTE@BRESNAN.NET

Jay Doucette, UST Class B Operator DOUCETTE@BRESNAN.NET

Tank Number	05	**Tank Age**	22	**Tank Installed Date**	05/09/2003	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	4836	**Spill Test Date**	01/14/2022	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Gasoline	**PLLD Test Date**	08/25/2022	**Tank/Piping CP Test Date**	08/25/2022	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	01/14/2022	**Line Tightness Test Date**	09/15/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	01/14/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350				
Tank Number	06	**Tank Age**	22	**Tank Installed Date**	05/09/2003	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	4837	**Spill Test Date**	01/14/2022	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Diesel	**PLLD Test Date**	08/25/2022	**Tank/Piping CP Test Date**	08/25/2022	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	01/14/2022	**Line Tightness Test Date**	09/13/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	01/14/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350				
Tank Number	07	**Tank Age**	22	**Tank Installed Date**	05/09/2003	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	4838	**Spill Test Date**	01/14/2022	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	None	**AST**	No

Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Gasoline	**PLLD Test Date**	08/25/2022	**Tank/Piping CP Test Date**	08/25/2022	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	01/14/2022	**Line Tightness Test Date**	09/13/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	01/14/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350				
Tank Number	08	**Tank Age**	22	**Tank Installed Date**	05/09/2003	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	4839	**Spill Test Date**	01/14/2022	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Diesel	**PLLD Test Date**	08/25/2022	**Tank/Piping CP Test Date**	08/25/2022	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	01/14/2022	**Line Tightness Test Date**	09/14/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	01/14/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Yellowstone County in the City of Billings

Location: WILSON DUNHAM SERVICE INC
2511 1st Ave S
Billings, MT 59101-4220 Yellowstone

System Facility ID:56-07756

Facility Code: 30197
Last Inspected On: 05/12/2017
Operating Permit Renewal Date: 06/03/2020

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Wilson Dunham Petroleum Supply

Operator Contact: Joan Erickson;William Dunham **(406) 252-0880;(406) 724-7335**

Owner/Operator: Wilson Dunham Petroleum Supply

Joan Erickson, UST Class A Operator
Joan Erickson, UST Class A Operator
Joan Erickson, UST Class B Operator
Joan Erickson, UST Class B Operator
William Dunham, UST Class A Operator
William Dunham, UST Class A Operator
William Dunham, UST Class B Global Operator
William Dunham, UST Class B Global Operator

Tank Number	05	**Tank Age**	35	**Tank Installed Date**	11/16/1990	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	2277	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Temporarily Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	05/12/2017	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Deferred	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	06	**Tank Age**	35	**Tank Installed Date**	11/16/1990	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	2278	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Temporarily Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	05/12/2017	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.1;ELLD 0.2	**Vapor Recovery**	No

Capacity	4000	**ATG Test Date**		**Line Tightness Test Date**	04/23/2017	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	07	**Tank Age**	35	**Tank Installed Date**	11/16/1990	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	2279	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Temporarily Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	05/12/2017	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.1;ELLD 0.2	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**		**Line Tightness Test Date**	04/23/2017	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	08	**Tank Age**	35	**Tank Installed Date**	11/16/1990	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	2280	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Temporarily Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	05/12/2017	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.1;ELLD 0.2	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**		**Line Tightness Test Date**	04/23/2017	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Yellowstone County in the City of Billings

Location: YELLOWSTONE COUNTY PUBLIC WORKS DEPT
3321 King Ave E
Billings, MT 59101 Yellowstone

System Facility ID:56-03658

Facility Code: 29878
Last Inspected On: 09/27/2018
Operating Permit Renewal Date: 09/29/2021

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Yellowstone County Public Works Dept	**(406) 256-6824**	
Operator Contact:	Greg Fisher	**(406) 208-0547**	**gfisher@co.yellowstone.mt.gov**

Greg Fisher, UST Class A Operator	gfisher@co.yellowstone.mt.gov
Greg Fisher, UST Class A Operator	gfisher@co.yellowstone.mt.gov
Greg Fisher, UST Class B Operator	gfisher@co.yellowstone.mt.gov
Greg Fisher, UST Class B Operator	gfisher@co.yellowstone.mt.gov

Tank Number	06	**Tank Age**	26	**Tank Installed Date**	06/01/1999	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	
Tag Number	4092	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Permanently Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**	09/27/2018	**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	U.S. Suction	**CP Met Types**	Galvanic
Product	Oil, Waste	**PLLD Test Date**		**Tank/Piping CP Test Date**	09/27/2018	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco/EMC Basic				

Facility Summary in Yellowstone County in the City of Billings

Location: ZIP TRIP 51
1544 Broadwater Ave
Billings, MT 59102-5002 Yellowstone

System Facility ID:56-00050

Facility Code: 29683
Last Inspected On: 02/14/2024
Operating Permit Renewal Date: 07/14/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	CHS Inc Spokane Valley	**(509) 535-7701**	**Donald.Widdicombe@chsinc.com**
Operator Contact:	Jim Alford;Sean Hurley	**(509) 535-7701;(509) 536-7418**	**jim.alford@chsinc.com;sean.hurley@chsinc.com**

Owner/Operator: CHS Inc Spokane Valley (509) 535-7701 Donald.Widdicombe@chsinc.com

Hannah Smith, UST Class B Operator	hannah.smith3@chsinc.com
Jim Alford, UST Class A Operator	jim.alford@chsinc.com
Jim Alford, UST Class A Operator	jim.alford@chsinc.com
Jim Alford, UST Class B Global Operator	jim.alford@chsinc.com
Jim Alford, UST Class B Global Operator	jim.alford@chsinc.com
Luci Tuttle, UST Class B Operator	Lucinda.Tuttle@chsinc.com
Sean Hurley, UST Class A Operator	sean.hurley@chsinc.com
Sean Hurley, UST Class A Operator	sean.hurley@chsinc.com

Tank Number	04	**Tank Age**	28	**Tank Installed Date**	10/30/1997	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	3074	**Spill Test Date**	10/10/2024	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	08/03/2023	**Tank/Piping CP Test Date**	02/23/2015	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	08/03/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	08/03/2023			**ATG Type**	Gilbarco/EMC Basic				
Tank Number	05	**Tank Age**	28	**Tank Installed Date**	10/30/1997	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	3075	**Spill Test Date**	02/14/2024	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	08/03/2023	**Tank/Piping CP Test Date**	02/23/2015	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No

Capacity	10000	**ATG Test Date**	08/03/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	08/03/2023			**ATG Type**	Gilbarco/EMC Basic				
Tank Number	06	**Tank Age**	28	**Tank Installed Date**	10/30/1997	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	3076	**Spill Test Date**	02/14/2024	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	08/03/2023	**Tank/Piping CP Test Date**	02/23/2015	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	15000	**ATG Test Date**	08/03/2023	**Line Tightness Test Date**	02/05/2018	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	08/03/2023			**ATG Type**	Gilbarco/EMC Basic				

Facility Summary in Yellowstone County in the City of Billings

Location: ZIP TRIP 52
1201 Central Ave
Billings, MT 59102-5528 Yellowstone

System Facility ID:56-08903

Facility Code: 30290
Last Inspected On: 01/29/2025
Operating Permit Renewal Date: 05/15/2028

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	CHS Inc Spokane Valley	**(509) 535-7701**	**Donald.Widdicombe@chsinc.com**
Operator Contact:	Jim Alford;Sean Hurley	**(509) 535-7701;(509) 536-7418**	**jim.alford@chsinc.com;sean.hurley@chsinc.com**

Owner/Operator: CHS Inc Spokane Valley (509) 535-7701 Donald.Widdicombe@chsinc.com

Hannah Smith, UST Class B Operator	hannah.smith3@chsinc.com
Jim Alford, UST Class A Operator	jim.alford@chsinc.com
Jim Alford, UST Class A Operator	jim.alford@chsinc.com
Jim Alford, UST Class B Global Operator	jim.alford@chsinc.com
Jim Alford, UST Class B Global Operator	jim.alford@chsinc.com
Luci Tuttle, UST Class B Operator	Lucinda.Tuttle@chsinc.com
Sean Hurley, UST Class A Operator	sean.hurley@chsinc.com
Sean Hurley, UST Class A Operator	sean.hurley@chsinc.com

Tank Number	06	**Tank Age**	15	**Tank Installed Date**	11/22/2010	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	5270	**Spill Test Date**	02/11/2025	**Piping Installed Date**	08/06/2010	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	01/29/2025	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	05/23/2024	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	15000	**ATG Test Date**	05/23/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	01/29/2025			**ATG Type**	Gilbarco-Veeder Root/TLS-350;Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	07	**Tank Age**	15	**Tank Installed Date**	11/22/2010	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	5271	**Spill Test Date**	02/11/2025	**Piping Installed Date**	08/06/2010	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	01/29/2025	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible

Product	Diesel	**PLLD Test Date**	05/23/2024	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	7000	**ATG Test Date**	05/23/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	01/29/2025			**ATG Type**	Gilbarco-Veeder Root/TLS-350;Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	08	**Tank Age**	15	**Tank Installed Date**	11/22/2010	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	5272	**Spill Test Date**	02/11/2025	**Piping Installed Date**	08/06/2010	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	01/29/2025	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	05/23/2024	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	05/23/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	01/29/2025			**ATG Type**	Gilbarco-Veeder Root/TLS-350;Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Yellowstone County in the City of Billings

Location: ZIP TRIP 53
2975 Grand Ave
Billings, MT 59102 Yellowstone

System Facility ID:56-13245

Facility Code: 30433
Last Inspected On: 02/14/2024
Operating Permit Renewal Date: 07/14/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	CHS Inc Spokane Valley	**(509) 535-7701**	**Donald.Widdicombe@chsinc.com**
Operator Contact:	Jim Alford;Sean Hurley	**(509) 535-7701;(509) 536-7418**	**jim.alford@chsinc.com;sean.hurley@chsinc.com**

Owner/Operator: CHS Inc Spokane Valley (509) 535-7701 Donald.Widdicombe@chsinc.com

Hannah Smith, UST Class B Operator	hannah.smith3@chsinc.com
Jim Alford, UST Class A Operator	jim.alford@chsinc.com
Jim Alford, UST Class B Global Operator	jim.alford@chsinc.com
Luci Tuttle, UST Class B Operator	Lucinda.Tuttle@chsinc.com
Sean Hurley, UST Class A Operator	sean.hurley@chsinc.com

Tank Number	01	**Tank Age**	32	**Tank Installed Date**	09/01/1993	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve
Tag Number	592	**Spill Test Date**	02/24/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Single Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**	08/03/2023	**Tank/Piping CP Test Date**	02/14/2024	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	08/03/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	08/03/2023			**ATG Type**	Gilbarco/EMC Basic				
Tank Number	02	**Tank Age**	32	**Tank Installed Date**	09/01/1993	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve
Tag Number	593	**Spill Test Date**	02/24/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**	08/03/2023	**Tank/Piping CP Test Date**	03/21/2025	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	08/03/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	08/03/2023			**ATG Type**	Gilbarco/EMC Basic				

Tank Number	03	**Tank Age**	32	**Tank Installed Date**	09/01/1993	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve
Tag Number	594	**Spill Test Date**	02/24/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**	08/03/2023	**Tank/Piping CP Test Date**	02/14/2024	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	08/03/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	08/03/2023			**ATG Type**	Gilbarco/EMC Basic				

Facility Summary in Yellowstone County in the City of Billings

Location: ZIP TRIP 54
151 Rosebud Ln
Billings, MT 59101-6503 Yellowstone

System Facility ID:56-08208

Facility Code: 30220
Last Inspected On: 04/04/2024
Operating Permit Renewal Date: 06/25/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	CHS Inc Spokane Valley	**(509) 535-7701**	**Donald.Widdicombe@chsinc.com**
Operator Contact:	Jim Alford;Sean Hurley	**(509) 535-7701;(509) 536-7418**	**jim.alford@chsinc.com;sean.hurley@chsinc.com**

Owner/Operator:	CHS Inc Spokane Valley	(509) 535-7701	Donald.Widdicombe@chsinc.com
	Hannah Smith, UST Class B Operator		hannah.smith3@chsinc.com
	Jim Alford, UST Class A Operator		jim.alford@chsinc.com
	Jim Alford, UST Class A Operator		jim.alford@chsinc.com
	Jim Alford, UST Class B Global Operator		jim.alford@chsinc.com
	Jim Alford, UST Class B Global Operator		jim.alford@chsinc.com
	Luci Tuttle, UST Class B Operator		Lucinda.Tuttle@chsinc.com
	Sean Hurley, UST Class A Operator		sean.hurley@chsinc.com
	Sean Hurley, UST Class A Operator		sean.hurley@chsinc.com

Tank Number	07	**Tank Age**	11	**Tank Installed Date**	09/01/2014	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	5525	**Spill Test Date**	09/01/2021	**Piping Installed Date**	11/03/2014	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	04/04/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	05/26/2023	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	17000	**ATG Test Date**	05/26/2023	**Line Tightness Test Date**	02/13/2015	**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	09/01/2021			**ATG Type**	Gilbarco-Veeder Root/TLS-450;Veeder Root/TLS-450				
Tank Number	08	**Tank Age**	11	**Tank Installed Date**	09/01/2014	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	5526	**Spill Test Date**	09/01/2021	**Piping Installed Date**	11/03/2014	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	04/04/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible

Product	Gasoline	**PLLD Test Date**	05/26/2023	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	05/26/2023	**Line Tightness Test Date**	02/13/2015	**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	09/01/2021			**ATG Type**	Gilbarco-Veeder Root/TLS-450;Veeder Root/TLS-450				
Tank Number	09	**Tank Age**	11	**Tank Installed Date**	09/01/2014	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	5527	**Spill Test Date**	09/01/2021	**Piping Installed Date**	11/03/2014	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	04/04/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	05/26/2023	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	17000	**ATG Test Date**	05/26/2023	**Line Tightness Test Date**	02/13/2015	**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	09/01/2021			**ATG Type**	Gilbarco-Veeder Root/TLS-450;Veeder Root/TLS-450				
Tank Number	10	**Tank Age**	11	**Tank Installed Date**	09/01/2014	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	5528	**Spill Test Date**	09/01/2021	**Piping Installed Date**	11/03/2014	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	04/04/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	05/26/2023	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	05/26/2023	**Line Tightness Test Date**	02/13/2015	**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	09/01/2021			**ATG Type**	Gilbarco-Veeder Root/TLS-450;Veeder Root/TLS-450				
Tank Number	11	**Tank Age**	11	**Tank Installed Date**	09/01/2014	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	5529	**Spill Test Date**	09/01/2021	**Piping Installed Date**	11/03/2014	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	04/04/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	05/26/2023	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No

Capacity	25000	**ATG Test Date**	05/26/2023	**Line Tightness Test Date**	02/13/2015	**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	09/01/2021			**ATG Type**	Gilbarco-Veeder Root/TLS-450;Veeder Root/TLS-450				
Tank Number	12	**Tank Age**	11	**Tank Installed Date**	09/01/2014	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	5530	**Spill Test Date**		**Piping Installed Date**	11/03/2014	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Other**	**MLLD Test Date**		**Sump Tightness Test Date**	11/01/2014	**Catastrophic L.D. Type 3.0**		**Piping Type**	Pressurized	**CP Met Types**	
Product	DEF (Not Regulated)	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Not Listed	**Energy Act**	No
		Overfill Test Date				**ATG Type**	Veeder Root/TLS-450				

Facility Summary in Yellowstone County in the City of Billings

Location: ZIP TRIP 55
236 Main St
Billings, MT 59105-3232 Yellowstone

System Facility ID:56-08904

Facility Code: 30291
Last Inspected On: 04/03/2024
Operating Permit Renewal Date: 07/11/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	CHS Inc Spokane Valley	**(509) 535-7701**	**Donald.Widdicombe@chsinc.com**
Operator Contact:	Jim Alford;Sean Hurley	**(509) 535-7701;(509) 536-7418**	**jim.alford@chsinc.com;sean.hurley@chsinc.com**

Owner/Operator: CHS Inc Spokane Valley (509) 535-7701 Donald.Widdicombe@chsinc.com

Hannah Smith, UST Class B Operator	hannah.smith3@chsinc.com
Jim Alford, UST Class A Operator	jim.alford@chsinc.com
Jim Alford, UST Class A Operator	jim.alford@chsinc.com
Jim Alford, UST Class B Operator	jim.alford@chsinc.com
Jim Alford, UST Class B Operator	jim.alford@chsinc.com
Luci Tuttle, UST Class B Operator	Lucinda.Tuttle@chsinc.com
Sean Hurley, UST Class A Operator	sean.hurley@chsinc.com
Sean Hurley, UST Class A Operator	sean.hurley@chsinc.com

Tank Number	01	**Tank Age**	43	**Tank Installed Date**	10/03/1982	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	589	**Spill Test Date**	04/03/2024	**Piping Installed Date**	10/13/2014	**Tank Construction**	Lined Interior/Impressed Current	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	04/03/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**	07/28/2023	**Tank/Piping CP Test Date**	04/03/2024	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	07/28/2023	**Line Tightness Test Date**	10/13/2014	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date	07/28/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	02	**Tank Age**	43	**Tank Installed Date**	10/03/1982	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	590	**Spill Test Date**	04/03/2024	**Piping Installed Date**	10/13/2014	**Tank Construction**	Lined Interior/Impressed Current	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	04/03/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current

Product	Gasoline	**PLLD Test Date**	07/28/2023	**Tank/Piping CP Test Date**	04/03/2024	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	07/28/2023	**Line Tightness Test Date**	10/13/2014	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date	07/28/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	03	**Tank Age**	43	**Tank Installed Date**	10/03/1982	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	591	**Spill Test Date**	04/03/2024	**Piping Installed Date**	10/13/2014	**Tank Construction**	Lined Interior/Impressed Current	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	04/03/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Diesel	**PLLD Test Date**	07/28/2023	**Tank/Piping CP Test Date**	04/03/2024	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	07/28/2023	**Line Tightness Test Date**	10/13/2014	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	No
		Overfill Test Date	07/28/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Yellowstone County in the City of Billings

Location: ZIP TRIP 56
16 Shiloh Rd
Billings, MT 59106 Yellowstone

System Facility ID:56-01664

Facility Code: 29782
Last Inspected On: 02/14/2024
Operating Permit Renewal Date: 07/09/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	CHS Inc Spokane Valley	**(509) 535-7701**	**Donald.Widdicombe@chsinc.com**
Operator Contact:	Jim Alford;Sean Hurley	**(509) 535-7701;(509) 536-7418**	**jim.alford@chsinc.com;sean.hurley@chsinc.com**

Owner/Operator: CHS Inc Spokane Valley (509) 535-7701 Donald.Widdicombe@chsinc.com

Hannah Smith, UST Class B Operator	hannah.smith3@chsinc.com
Jim Alford, UST Class A Operator	jim.alford@chsinc.com
Jim Alford, UST Class A Operator	jim.alford@chsinc.com
Jim Alford, UST Class B Operator	jim.alford@chsinc.com
Jim Alford, UST Class B Operator	jim.alford@chsinc.com
Luci Tuttle, UST Class B Operator	Lucinda.Tuttle@chsinc.com
Sean Hurley, UST Class A Operator	sean.hurley@chsinc.com
Sean Hurley, UST Class A Operator	sean.hurley@chsinc.com

Tank Number	01	**Tank Age**	41	**Tank Installed Date**	12/31/1984	**Tank Material Construction**	Bare Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	4344	**Spill Test Date**	10/05/2024	**Piping Installed Date**	04/13/1998	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Diesel	**PLLD Test Date**	08/03/2023	**Tank/Piping CP Test Date**	02/14/2024	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	08/03/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	08/03/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	02	**Tank Age**	41	**Tank Installed Date**	12/31/1984	**Tank Material Construction**	Bare Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	4345	**Spill Test Date**	10/05/2024	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current

Product	Gasoline	**PLLD Test Date**	08/03/2023	**Tank/Piping CP Test Date**	02/14/2024	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	08/03/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	08/03/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	03	**Tank Age**	36	**Tank Installed Date**	11/10/1989	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	4346	**Spill Test Date**	10/05/2024	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**	08/03/2023	**Tank/Piping CP Test Date**	02/14/2024	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	08/03/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	08/03/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Yellowstone County in the City of Billings

Location: ZIP TRIP 57
1046 N 27th St
Billings, MT 59101-0710 Yellowstone

System Facility ID:56-01665

Facility Code: 29783
Last Inspected On: 02/14/2024
Operating Permit Renewal Date: 07/11/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	CHS Inc Spokane Valley	**(509) 535-7701**	**Donald.Widdicombe@chsinc.com**
Operator Contact:	Jim Alford;Sean Hurley	**(509) 535-7701;(509) 536-7418**	**jim.alford@chsinc.com;sean.hurley@chsinc.com**

Owner/Operator: CHS Inc Spokane Valley (509) 535-7701 Donald.Widdicombe@chsinc.com

Hannah Smith, UST Class B Operator	hannah.smith3@chsinc.com
Jim Alford, UST Class A Operator	jim.alford@chsinc.com
Jim Alford, UST Class A Operator	jim.alford@chsinc.com
Jim Alford, UST Class B Operator	jim.alford@chsinc.com
Jim Alford, UST Class B Operator	jim.alford@chsinc.com
Luci Tuttle, UST Class B Operator	Lucinda.Tuttle@chsinc.com
Sean Hurley, UST Class A Operator	sean.hurley@chsinc.com
Sean Hurley, UST Class A Operator	sean.hurley@chsinc.com

Tank Number	03	**Tank Age**	27	**Tank Installed Date**	01/28/1998	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	3080	**Spill Test Date**	02/14/2024	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	07/28/2023	**Tank/Piping CP Test Date**	01/08/2009	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	15000	**ATG Test Date**	07/28/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	07/28/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	04	**Tank Age**	27	**Tank Installed Date**	01/28/1998	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	3081	**Spill Test Date**	02/14/2024	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible

Product	Gasoline	**PLLD Test Date**	07/28/2023	**Tank/Piping CP Test Date**	01/08/2009	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	07/28/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	07/28/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Yellowstone County in the City of Billings

Location: ZIP TRIP 58
610 Wicks Ln
Billings, MT 59105 Yellowstone

System Facility ID:56-08209

Facility Code: 30221
Last Inspected On: 01/05/2024
Operating Permit Renewal Date: 03/17/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	CHS Inc Spokane Valley	**(509) 535-7701**	**Donald.Widdicombe@chsinc.com**
Operator Contact:	Jim Alford;Sean Hurley	**(509) 535-7701;(509) 536-7418**	**jim.alford@chsinc.com;sean.hurley@chsinc.com**

Owner/Operator: CHS Inc Spokane Valley (509) 535-7701 Donald.Widdicombe@chsinc.com

Hannah Smith, UST Class B Operator	hannah.smith3@chsinc.com
Jim Alford, UST Class A Operator	jim.alford@chsinc.com
Jim Alford, UST Class A Operator	jim.alford@chsinc.com
Jim Alford, UST Class B Operator	jim.alford@chsinc.com
Jim Alford, UST Class B Operator	jim.alford@chsinc.com
Luci Tuttle, UST Class B Operator	Lucinda.Tuttle@chsinc.com
Sean Hurley, UST Class A Operator	sean.hurley@chsinc.com
Sean Hurley, UST Class A Operator	sean.hurley@chsinc.com

Tank Number	04	**Tank Age**	26	**Tank Installed Date**	01/01/1999	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	4256	**Spill Test Date**	09/03/2024	**Piping Installed Date**	11/20/2007	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	05/26/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	05/26/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	09/03/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	05	**Tank Age**	26	**Tank Installed Date**	01/01/1999	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	4257	**Spill Test Date**	09/03/2024	**Piping Installed Date**	11/20/2007	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic

Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	05/26/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	05/26/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	01/05/2024			**ATG Type**	Gilbarco/TLS-350				
Tank Number	06	**Tank Age**	26	**Tank Installed Date**	01/01/1999	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	4258	**Spill Test Date**	09/03/2024	**Piping Installed Date**	11/20/2007	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	05/26/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	5000	**ATG Test Date**	05/26/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	09/03/2024			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Yellowstone County in the City of Broadview

Location: BROADVIEW OASIS LLC
16437 Iowa Ave
Broadview, MT 59015 Yellowstone

System Facility ID:56-02373

Facility Code: 29819
Last Inspected On: 10/19/2023
Operating Permit Renewal Date: 02/24/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	BROADVIEW OASIS LLC	**(660) 998-5690**	**jody@raysoasis.com**
Operator Contact:	Jody McCloud	**(406) 672-1698**	**jody@raysoasis.com**

Owner/Operator: BROADVIEW OASIS LLC (660) 998-5690 jody@raysoasis.com

Jody McCloud, UST Class A Operator jody@raysoasis.com

Jody McCloud, UST Class B Operator jody@raysoasis.com

Tank Number	06	**Tank Age**	29	**Tank Installed Date**	05/01/1996	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	3410	**Spill Test Date**	10/19/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	08/03/2023	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	08/03/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	08/03/2023	**Line Tightness Test Date**	07/31/2020	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	08/02/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	07	**Tank Age**	29	**Tank Installed Date**	05/01/1996	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	3411	**Spill Test Date**	10/19/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	08/03/2023	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	08/03/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**	08/03/2023	**Line Tightness Test Date**	07/31/2020	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	08/02/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	08	**Tank Age**	29	**Tank Installed Date**	05/01/1996	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm

Tag Number	3412	**Spill Test Date**	10/19/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	08/03/2023	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	08/03/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	08/03/2023	**Line Tightness Test Date**	07/31/2020	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	08/02/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Yellowstone County in the City of Custer

Location: SURE STOP
523 2nd Ave
Custer, MT 59024 Yellowstone

System Facility ID:56-05291

Facility Code: 30014
Last Inspected On: 01/15/2025
Operating Permit Renewal Date: 04/30/2028

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Valley Farmers Supply **(406) 967-3100** **sblack@vfarmers.com**

Operator Contact:

Owner/Operator: Valley Farmers Supply (406) 967-3100 sblack@vfarmers.com

Trina Mcclure, UST Class B Operator twilson@vfarmers.com

Tank Number	S5	**Tank Age**	26	**Tank Installed Date**	07/01/1999	**Tank Material Construction**	Unknown	**Piping Material**	Flexible Plastic	**Overfill Types**	
Tag Number	4079	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	Yes
Status	**Currently in Use**	**MLLD Test Date**	11/04/2021	**Sump Tightness Test Date**	06/10/2016	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Diesel	**PLLD Test Date**	10/16/2024	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	5000	**ATG Test Date**	10/16/2024	**Line Tightness Test Date**	10/16/2024	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring;ELLD 0.1	**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	S6	**Tank Age**	26	**Tank Installed Date**	07/01/1999	**Tank Material Construction**	Unknown	**Piping Material**	Flexible Plastic	**Overfill Types**	
Tag Number	4080	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	Yes
Status	**Currently in Use**	**MLLD Test Date**	11/04/2021	**Sump Tightness Test Date**	06/10/2016	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Diesel	**PLLD Test Date**	10/16/2024	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	10/16/2024	**Line Tightness Test Date**	10/16/2024	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring;ELLD 0.1	**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	S7	**Tank Age**	26	**Tank Installed Date**	07/01/1999	**Tank Material Construction**	Unknown	**Piping Material**	Flexible Plastic	**Overfill Types**	

Tag Number	4081	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	Yes
Status	**Currently in Use**	**MLLD Test Date**	11/04/2021	**Sump Tightness Test Date**	06/10/2016	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Gasoline	**PLLD Test Date**	10/16/2024	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	10/16/2024	**Line Tightness Test Date**	10/16/2024	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring;ELLD 0.1	**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	S8	**Tank Age**	26	**Tank Installed Date**	07/01/1999	**Tank Material Construction**	Unknown	**Piping Material**	Flexible Plastic	**Overfill Types**	
Tag Number	4082	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	Yes
Status	**Currently in Use**	**MLLD Test Date**	11/04/2021	**Sump Tightness Test Date**	06/10/2016	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Gasoline	**PLLD Test Date**	10/16/2024	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	10/16/2024	**Line Tightness Test Date**	10/16/2024	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring;ELLD 0.1	**Energy Act**	No
		Overfill Test Date				**ATG Type**					

Facility Summary in Yellowstone County in the City of Huntley

Location: HUNTLEY EXPRESSWAY
135 Northern Ave
Huntley, MT 59037-9101 Yellowstone

System Facility ID:56-00627

Facility Code: 29722
Last Inspected On: 01/26/2023
Operating Permit Renewal Date: 06/26/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Set Five LLC Big Sky	**(406) 348-9209**	**setfive2@outlook.com**
Operator Contact:	Abigail Onstad;Greg Haines;William Woods	**(406) 590-2667**	**abigailo19962015@gmail.com;setfive01@outlook.com;wjwoods10@gmail.com**

Owner/Operator: Set Five LLC Big Sky (406) 348-9209 setfive2@outlook.com

Abigail Onstad, UST Class A Operator	abigailo19962015@gmail.com
Abigail Onstad, UST Class B Operator	abigailo19962015@gmail.com
Greg Haines, UST Class A Operator	setfive01@outlook.com
Greg Haines, UST Class A Operator	setfive01@outlook.com
Greg Haines, UST Class B Global Operator	setfive01@outlook.com
Greg Haines, UST Class B Global Operator	setfive01@outlook.com
William Woods, UST Class A Operator	wjwoods10@gmail.com
William Woods, UST Class B Operator	wjwoods10@gmail.com

Tank Number	03	**Tank Age**	27	**Tank Installed Date**	11/01/1998	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	3660	**Spill Test Date**	07/26/2022	**Piping Installed Date**	06/17/2008	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	01/26/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	5000	**ATG Test Date**	05/06/2022	**Line Tightness Test Date**	02/07/2020	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	05/06/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	04	**Tank Age**	27	**Tank Installed Date**	11/01/1998	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	3661	**Spill Test Date**	07/26/2022	**Piping Installed Date**	06/17/2008	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic

Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	01/26/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	5000	**ATG Test Date**	05/06/2022	**Line Tightness Test Date**	02/07/2020	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	05/06/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	05	**Tank Age**	27	**Tank Installed Date**	11/01/1998	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	3662	**Spill Test Date**	05/09/2022	**Piping Installed Date**	06/17/2008	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	01/26/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	05/06/2022	**Line Tightness Test Date**	02/07/2020	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	05/06/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Yellowstone County in the City of Laurel

Location: CONOMART SUPERSTORE 10038 - Laurel
519 W Main St
Laurel, MT 59044-2926 Yellowstone

System Facility ID:56-06965

Facility Code: 30150
Last Inspected On: 02/13/2024
Operating Permit Renewal Date: 06/03/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Beehive Property Holdings LLC	**(856) 298-1310**	**documents@beehivefuels.com**
Operator Contact:	Vern Patterson;Parkland USA Corporation	**(701) 720-6649;(701) 852-1194**	**vern.patterson@parklandusa.com;Jake.thomas@parklandusa.com**

Owner/Operator:	Beehive Property Holdings LLC	(856) 298-1310	documents@beehivefuels.com
	Curtis McBride, UST Class B Operator		Jake.thomas@parklandusa.com
	Vern Patterson, UST Class A Operator		Jake.thomas@parklandusa.com
	Vern Patterson, UST Class B Operator		Jake.thomas@parklandusa.com

Tank Number	04	**Tank Age**	30	**Tank Installed Date**	10/17/1995	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	1172	**Spill Test Date**	02/13/2024	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**	06/15/2023	**Tank/Piping CP Test Date**	06/15/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	06/15/2023	**Line Tightness Test Date**	01/08/2021	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	06/15/2023			**ATG Type**	Gilbarco/EMC Basic				
Tank Number	05	**Tank Age**	30	**Tank Installed Date**	10/17/1995	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	1173	**Spill Test Date**	02/13/2024	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**	06/15/2023	**Tank/Piping CP Test Date**	06/15/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	06/15/2023	**Line Tightness Test Date**	06/01/2021	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	06/15/2023			**ATG Type**	Gilbarco/EMC Basic				

Tank Number	06	**Tank Age**	30	**Tank Installed Date**	10/17/1995	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	1174	**Spill Test Date**	02/13/2024	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**	06/15/2023	**Tank/Piping CP Test Date**	06/15/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	06/15/2023	**Line Tightness Test Date**	06/01/2021	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	06/15/2023			**ATG Type**	Gilbarco/EMC Basic				

Facility Summary in Yellowstone County in the City of Laurel

Location: CONOMART SUPERSTORE 2
411 E 1st St
Laurel, MT 59044 Yellowstone

System Facility ID:56-06966

Facility Code: 30151
Last Inspected On: 02/13/2024
Operating Permit Renewal Date: 06/03/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Superpumper Inc **(701) 852-1194**

Operator Contact: Vern Patterson;Parkland USA Corporation **(701) 720-6649;(701) 852-1194** **vern.patterson@parklandusa.com;Jake.thomas@parklandusa.com**

Owner/Operator: Superpumper Inc (701) 852-1194

Curtis McBride, UST Class B Operator Jake.thomas@parklandusa.com
Vern Patterson, UST Class A Operator Jake.thomas@parklandusa.com

Tank Number	01	**Tank Age**	48	**Tank Installed Date**	04/22/1977	**Tank Material Construction**	Bare Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	1175	**Spill Test Date**	02/13/2024	**Piping Installed Date**		**Tank Construction**	Lined Interior/Impressed Current	**Piping Construction**	Single Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Diesel	**PLLD Test Date**	06/15/2023	**Tank/Piping CP Test Date**	06/15/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	06/15/2023	**Line Tightness Test Date**	05/22/2021	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	08/25/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	02	**Tank Age**	48	**Tank Installed Date**	04/22/1977	**Tank Material Construction**	Bare Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	1176	**Spill Test Date**	02/13/2024	**Piping Installed Date**		**Tank Construction**	Lined Interior/Impressed Current	**Piping Construction**	Single Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**	06/15/2023	**Tank/Piping CP Test Date**	06/15/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	06/15/2023	**Line Tightness Test Date**	05/24/2021	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	08/25/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Tank Number	03	**Tank Age**	48	**Tank Installed Date**	04/22/1977	**Tank Material Construction**	Bare Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	1177	**Spill Test Date**	02/13/2024	**Piping Installed Date**		**Tank Construction**	Lined Interior/Impressed Current	**Piping Construction**	Single Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**	06/15/2023	**Tank/Piping CP Test Date**	06/15/2023	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	06/15/2023	**Line Tightness Test Date**	05/24/2021	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	08/25/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Yellowstone County in the City of Laurel

Location: FASTLANE C STORES
815 E Main St
Laurel, MT 59044-2810 Yellowstone

System Facility ID:56-05083

Facility Code: 30002
Last Inspected On: 03/31/2023
Operating Permit Renewal Date: 09/25/2023

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: City Service Valcon LLC **tamara.noble@cityservicevalcon.com**

Operator Contact: Dan Foos **(406) 628-6204** **rlfoos54@gmail.com**

Owner/Operator: City Service Valcon LLC tamara.noble@cityservicevalcon.com

Dan Foos, UST Class A Operator rlfoos54@gmail.com
Dan Foos, UST Class B Operator rlfoos54@gmail.com
Rochelle Foos, UST Class B Operator rlfoos54@gmail.com
Rochelle Foos, UST Class B Operator rlfoos54@gmail.com

Tank Number	01	**Tank Age**	50	**Tank Installed Date**	10/01/1975	**Tank Material Construction**	Bare Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	3831	**Spill Test Date**	05/29/2020	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	05/29/2020	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**		**Line Tightness Test Date**	05/21/2020	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	05/29/2020			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	02	**Tank Age**	50	**Tank Installed Date**	10/01/1975	**Tank Material Construction**	Bare Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	3832	**Spill Test Date**	05/29/2020	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	05/29/2020	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	5200	**ATG Test Date**		**Line Tightness Test Date**	05/23/2020	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	05/29/2020			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Tank Number	03	**Tank Age**	50	**Tank Installed Date**	10/01/1975	**Tank Material Construction**	Bare Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	3833	**Spill Test Date**	05/29/2020	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	05/29/2020	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**		**Line Tightness Test Date**	05/19/2020	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	05/29/2020			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Yellowstone County in the City of Laurel

Location: FORMER LAUREL SERVICE CENTER
201 W Main St
Laurel, MT 59044-3108 Yellowstone

System Facility ID:56-01069

Facility Code: 29751
Last Inspected On: 03/24/2025
Operating Permit Renewal Date: 03/30/2028

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	H AND M CAPITAL LLC	**(406) 628-6330**	**ckinteriors1@hotmail.com**
Operator Contact:	Mike Jones;H AND M CAPITAL LLC	**(406) 628-6330**	**kcinteriors1@hotmail.com;ckinteriors1@hotmail.com**

Owner/Operator: H AND M CAPITAL LLC (406) 628-6330 ckinteriors1@hotmail.com

Mike Jones, UST Class A Operator ckinteriors1@hotmail.com

Mike Jones, UST Class B Operator ckinteriors1@hotmail.com

Tank Number	08	**Tank Age**	39	**Tank Installed Date**	04/29/1986	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	No Piping	**Overfill Types**	Flapper Valve
Tag Number	1808	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Temporarily Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	03/24/2025	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Deferred	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**		**Line Tightness Test Date**	08/08/2007	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	09	**Tank Age**	37	**Tank Installed Date**	04/28/1988	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	No Piping	**Overfill Types**	Flapper Valve
Tag Number	1809	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Temporarily Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	03/24/2025	**Primary Tank Leak Detection**	Not Listed	**Primary Pipe Leak Detection**	Not Listed	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**		**Line Tightness Test Date**	08/08/2007	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	10	**Tank Age**	38	**Tank Installed Date**	04/29/1987	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	No Piping	**Overfill Types**	Flapper Valve

Tag Number	1810	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Temporarily Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	03/24/2025	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Deferred	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**		**Line Tightness Test Date**	08/08/2006	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	11	**Tank Age**	37	**Tank Installed Date**	04/28/1988	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	No Piping	**Overfill Types**	Flapper Valve
Tag Number	1811	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Temporarily Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Safe Suction	**CP Met Types**	Impressed Current
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	03/24/2025	**Primary Tank Leak Detection**	Not Listed	**Primary Pipe Leak Detection**	Not Listed	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**		**Line Tightness Test Date**	08/08/2007	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	12	**Tank Age**	37	**Tank Installed Date**	04/28/1988	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	No Piping	**Overfill Types**	Flapper Valve
Tag Number	1812	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Temporarily Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Impressed Current
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	03/24/2025	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.1;Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Not Listed	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**		**Line Tightness Test Date**	08/08/2007	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	13	**Tank Age**	37	**Tank Installed Date**	04/28/1988	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	No Piping	**Overfill Types**	Flapper Valve
Tag Number	1813	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Temporarily Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Impressed Current
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	03/24/2025	**Primary Tank Leak Detection**	Not Listed	**Primary Pipe Leak Detection**	Not Listed	**Vapor Recovery**	No

Capacity	4000	**ATG Test Date**		**Line Tightness Test Date**	08/08/2007	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	14	**Tank Age**	37	**Tank Installed Date**	04/28/1988	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	No Piping	**Overfill Types**	Flapper Valve
Tag Number	1814	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Temporarily Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	03/24/2025	**Primary Tank Leak Detection**	Not Listed	**Primary Pipe Leak Detection**	Not Listed	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**		**Line Tightness Test Date**	08/08/2007	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date				**ATG Type**					
Tank Number	15	**Tank Age**	27	**Tank Installed Date**	11/15/1998	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	No Piping	**Overfill Types**	Flapper Valve
Tag Number	1815	**Spill Test Date**		**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Temporarily Out of Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	03/24/2025	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Deferred	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**		**Line Tightness Test Date**	08/08/2007	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	MLLD Line Tightness Testing	**Energy Act**	No
		Overfill Test Date				**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Yellowstone County in the City of Laurel

Location: LAUREL 406 AERO LLC
3900 Fox Rd
Laurel, MT 59044 Yellowstone

System Facility ID:56-13474

Facility Code: 30443
Last Inspected On: 08/01/2024
Operating Permit Renewal Date: 01/27/2028

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	LAUREL 406 AERO LLC	**(406) 698-4829**	**bretnsa@aol.com**
Operator Contact:	Arlene Lauer;Tom Boyce;LAUREL 406 AERO LLC	**(406) 672-0991;(425) 330-5823;(406) 698-4829**	**lauerarlene@yahoo.com;yellowstoneaircraft@yahoo.com;bretnsa@aol.com**

Owner/Operator: LAUREL 406 AERO LLC (406) 698-4829 bretnsa@aol.com

Arlene Lauer, UST Class A Operator lauerarlene@yahoo.com
Elliot Whitcomb, UST Class B Operator aerotech406@gmail.com
Tom Boyce, UST Class A Operator bretnsa@aol.com
Tom Boyce, UST Class B Global Operator bretnsa@aol.com

Tank Number	01	**Tank Age**	31	**Tank Installed Date**	06/01/1994	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	4295	**Spill Test Date**	08/01/2024	**Piping Installed Date**	07/28/2006	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	10/11/2023	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Aviation Gas	**PLLD Test Date**		**Tank/Piping CP Test Date**	08/01/2024	**Primary Tank Leak Detection**	Manual Interstitial Monitoring	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	7000	**ATG Test Date**		**Line Tightness Test Date**	10/11/2023	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	08/01/2024			**ATG Type**					
Tank Number	02	**Tank Age**	31	**Tank Installed Date**	06/01/1994	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	4296	**Spill Test Date**	08/01/2024	**Piping Installed Date**	07/28/2006	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Not Required	**Piping Type**	Safe Suction	**CP Met Types**	Galvanic
Product	Aviation Gas	**PLLD Test Date**		**Tank/Piping CP Test Date**	08/01/2024	**Primary Tank Leak Detection**	Manual Interstitial Monitoring	**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	3000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	08/01/2024			**ATG Type**					

Facility Summary in Yellowstone County in the City of Laurel

Location: LAUREL CENEX C STORE
315 S 1st Ave
Laurel, MT 59044-3303 Yellowstone

System Facility ID:56-08161

Facility Code: 30215
Last Inspected On: 08/09/2022
Operating Permit Renewal Date: 12/27/2025

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Town and Country Supply Association **(406) 628-6314**

Operator Contact: Danielle Keyser;Town and Country Supply Association;Makayla Rawson;Town and Country Supply Association;Wesley Burley **(406) 232-3520;(406) 628-6314** **dkeyser@tandcsupply.com;raw043@yahoo.com;wburley@tandcsupply.com**

Owner/Operator: Town and Country Supply Association (406) 628-6314

Danielle Keyser, UST Class A Operator	dkeyser@tandcsupply.com
Danielle Keyser, UST Class B Operator	dkeyser@tandcsupply.com
Makayla Rawson, UST Class A Operator	raw043@yahoo.com
Makayla Rawson, UST Class B Operator	raw043@yahoo.com
Wesley Burley, UST Class A Operator	wburley@tandcsupply.com
Wesley Burley, UST Class A Operator	wburley@tandcsupply.com

Tank Number	05	**Tank Age**	30	**Tank Installed Date**	05/22/1995	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	1523	**Spill Test Date**	12/28/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**	08/09/2022	**Tank/Piping CP Test Date**	08/09/2022	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	08/09/2022	**Line Tightness Test Date**	04/09/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.1	**Energy Act**	No
		Overfill Test Date	01/16/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	06	**Tank Age**	30	**Tank Installed Date**	05/22/1995	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	1524	**Spill Test Date**	07/09/2021	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**	08/09/2022	**Tank/Piping CP Test Date**	08/09/2022	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	08/09/2022	**Line Tightness Test Date**	03/14/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.1	**Energy Act**	No

		Overfill Test Date	01/16/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	07	**Tank Age**	30	**Tank Installed Date**	05/22/1995	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	1525	**Spill Test Date**	07/09/2021	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Gasoline	**PLLD Test Date**	08/09/2022	**Tank/Piping CP Test Date**	08/09/2022	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	08/09/2022	**Line Tightness Test Date**	07/16/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.1	**Energy Act**	No
		Overfill Test Date	01/16/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	08	**Tank Age**	30	**Tank Installed Date**	05/22/1995	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	1526	**Spill Test Date**	07/09/2021	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**	08/09/2022	**Tank/Piping CP Test Date**	08/09/2022	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**	08/09/2022	**Line Tightness Test Date**	04/13/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.1	**Energy Act**	No
		Overfill Test Date	01/16/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	09	**Tank Age**	30	**Tank Installed Date**	05/22/1995	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	1527	**Spill Test Date**	12/28/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Galvanic
Product	Diesel	**PLLD Test Date**	08/09/2022	**Tank/Piping CP Test Date**	08/09/2022	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**	08/09/2022	**Line Tightness Test Date**	02/18/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.1	**Energy Act**	No
		Overfill Test Date	01/16/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Yellowstone County in the City of Laurel

Location: LAUREL TRAVEL CENTER
11360 S Frontage Rd
Laurel, MT 59044 Yellowstone

System Facility ID:56-00626

Facility Code: 29721
Last Inspected On: 07/12/2022
Operating Permit Renewal Date: 12/31/2025

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	TA Operating LLC	**(440) 808-7406**	**kgelske@ta-petro.com**
Operator Contact:	Mike Rathbone;Renee Andrews	**(406) 927-9658**	**pcmstore.ta261@tatravelcenters.com;reneejandrews@yahoo.com**

Owner/Operator: TA Operating LLC (440) 808-7406 kgelske@ta-petro.com

Mike Rathbone, UST Class A Operator	pcmstore.ta261@tatravelcenters.com
Mike Rathbone, UST Class A Operator	pcmstore.ta261@tatravelcenters.com
Renee Andrews, UST Class A Operator	reneejandrews@yahoo.com
Renee Andrews, UST Class A Operator	reneejandrews@yahoo.com
Renee Andrews, UST Class B Operator	reneejandrews@yahoo.com
Renee Andrews, UST Class B Operator	reneejandrews@yahoo.com
Tammy Wieting, UST Class B Global Operator	pcmstore.ta261@tatravelcenters.com

Tank Number	01	**Tank Age**	57	**Tank Installed Date**	05/02/1968	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Steel	**Overfill Types**	High Level Alarm
Tag Number	1791	**Spill Test Date**	07/12/2022	**Piping Installed Date**		**Tank Construction**	Lined Interior/Impressed Current	**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	07/12/2022	**Sump Tightness Test Date**	08/18/2016	**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	10/20/2022	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**	07/12/2022	**Line Tightness Test Date**	07/12/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	07/12/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Number	02	**Tank Age**	57	**Tank Installed Date**	05/02/1968	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Steel	**Overfill Types**	High Level Alarm
Tag Number	1792	**Spill Test Date**	07/12/2022	**Piping Installed Date**		**Tank Construction**	Lined Interior/Impressed Current	**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	07/12/2022	**Sump Tightness Test Date**	08/18/2016	**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	10/20/2022	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No

Capacity	10000	**ATG Test Date**	07/12/2022	**Line Tightness Test Date**	07/12/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	07/12/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Number	03	**Tank Age**	57	**Tank Installed Date**	05/02/1968	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Steel	**Overfill Types**	High Level Alarm
Tag Number	1793	**Spill Test Date**	07/12/2022	**Piping Installed Date**		**Tank Construction**	Lined Interior/Impressed Current	**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	07/12/2022	**Sump Tightness Test Date**	08/18/2016	**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	10/20/2022	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	07/12/2022	**Line Tightness Test Date**	07/12/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	07/12/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Number	04	**Tank Age**	57	**Tank Installed Date**	05/02/1968	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	1794	**Spill Test Date**	07/12/2022	**Piping Installed Date**	08/17/2016	**Tank Construction**	Lined Interior/Impressed Current	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	07/12/2022	**Sump Tightness Test Date**	07/12/2022	**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	10/20/2022	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	07/12/2022	**Line Tightness Test Date**	07/12/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	MLLD Line Tightness Testing	**Energy Act**	No
		Overfill Test Date	07/12/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Number	05	**Tank Age**	54	**Tank Installed Date**	05/03/1971	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	1795	**Spill Test Date**	07/12/2022	**Piping Installed Date**	05/10/2023	**Tank Construction**	Lined Interior/Impressed Current	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	05/10/2023	**Sump Tightness Test Date**	07/12/2022	**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	10/20/2022	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	07/12/2022	**Line Tightness Test Date**	07/12/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	MLLD Line Tightness Testing	**Energy Act**	No

		Overfill Test Date	07/12/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Number	06	**Tank Age**	57	**Tank Installed Date**	05/02/1968	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	1796	**Spill Test Date**	08/26/2022	**Piping Installed Date**	08/17/2016	**Tank Construction**	Lined Interior/Impressed Current	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	07/12/2022	**Sump Tightness Test Date**	07/12/2022	**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	10/20/2022	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	07/12/2022	**Line Tightness Test Date**	10/19/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	MLLD Line Tightness Testing	**Energy Act**	No
		Overfill Test Date	07/12/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Number	07	**Tank Age**	57	**Tank Installed Date**	05/02/1968	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	1797	**Spill Test Date**	07/12/2022	**Piping Installed Date**	08/17/2016	**Tank Construction**	Lined Interior/Impressed Current	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	07/12/2022	**Sump Tightness Test Date**	07/12/2022	**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	10/20/2022	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	07/12/2022	**Line Tightness Test Date**	07/12/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	MLLD Line Tightness Testing	**Energy Act**	No
		Overfill Test Date	07/12/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Number	10	**Tank Age**	9	**Tank Installed Date**	04/01/2016	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	
Tag Number	5649	**Spill Test Date**		**Piping Installed Date**	08/17/2016	**Tank Construction**		**Piping Construction**		**AST**	No
Status	**Other**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**		**Piping Type**	Not Listed	**CP Met Types**	
Product	DEF (Not Regulated)	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Not Listed	**Primary Pipe Leak Detection**	Not Listed	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Not Listed	**Energy Act**	No
		Overfill Test Date				**ATG Type**					

Facility Summary in Yellowstone County in the City of Laurel

Location: TOWN AND COUNTRY SUPPLY LAUREL ASSN
800 E Main St
Laurel, MT 59044-2866 Yellowstone

System Facility ID:56-04497

Facility Code: 29916
Last Inspected On: 08/09/2022
Operating Permit Renewal Date: 12/14/2025

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Town and Country Supply Association **(406) 628-6314**

Operator Contact: Amber Larson;Karissa Lueck;Wesley Burley **(406) 232-3520;(406) 628-6314** **alarson@tandcsupply.com;laurel@tandcsupply.com;wburley@tandcsupply.com**

Owner/Operator: Town and Country Supply Association (406) 628-6314

Amber Larson, UST Class A Operator	alarson@tandcsupply.com
Amber Larson, UST Class B Operator	alarson@tandcsupply.com
Karissa Lueck, UST Class A Operator	laurel@tandcsupply.com
Wesley Burley, UST Class A Operator	wburley@tandcsupply.com
Wesley Burley, UST Class A Operator	wburley@tandcsupply.com

Tank Number	08	**Tank Age**	35	**Tank Installed Date**	02/12/1990	**Tank Material Construction**	Steel Clad	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	1518	**Spill Test Date**	08/09/2021	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	08/09/2022	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	09/06/2016	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	08/09/2022	**Line Tightness Test Date**	08/09/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	08/09/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	10	**Tank Age**	35	**Tank Installed Date**	02/12/1990	**Tank Material Construction**	Steel Clad	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	1520	**Spill Test Date**	08/09/2021	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	08/09/2022	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	09/06/2016	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	08/09/2022	**Line Tightness Test Date**	08/09/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No

		Overfill Test Date	08/09/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	12	**Tank Age**	35	**Tank Installed Date**	02/12/1990	**Tank Material Construction**	Steel Clad	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	4470	**Spill Test Date**	08/09/2021	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	08/09/2022	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**		**Tank/Piping CP Test Date**	09/06/2016	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	2000	**ATG Test Date**	08/09/2022	**Line Tightness Test Date**	08/09/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	08/09/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	11	**Tank Age**	35	**Tank Installed Date**	02/12/1990	**Tank Material Construction**	Steel Clad	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	4471	**Spill Test Date**	08/09/2021	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	08/09/2022	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Diesel, Dyed	**PLLD Test Date**		**Tank/Piping CP Test Date**	08/09/2022	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	2000	**ATG Test Date**	08/09/2022	**Line Tightness Test Date**	08/09/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	08/09/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	09	**Tank Age**	35	**Tank Installed Date**	02/12/1990	**Tank Material Construction**	Steel Clad	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	4472	**Spill Test Date**	08/09/2021	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	08/09/2022	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Mechanical Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**	08/09/2022	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	MLLD Line Tightness Testing	**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	08/09/2022	**Line Tightness Test Date**	08/09/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	08/09/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Yellowstone County in the City of Laurel

Location: TOWN AND COUNTRY WEST MAIN
801 W Main St
Laurel, MT 59044 Yellowstone

System Facility ID:60-15264

Facility Code: 30978
Last Inspected On: 12/05/2022
Operating Permit Renewal Date: 02/14/2026

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Town and Country Supply Association **(406) 628-6314**

Operator Contact: Lacey Anest;Makayla Rawson;Wes Burley;Town and Country Supply Association **(406) 256-1020;(406) 628-6314** **lanest@tandcsupply.com;raw043@yahoo.com**

Owner/Operator: Town and Country Supply Association (406) 628-6314

Lacey Anest, UST Class A Operator	lanest@tandcsupply.com
Lacey Anest, UST Class B Operator	lanest@tandcsupply.com
Makayla Rawson, UST Class A Operator	raw043@yahoo.com
Makayla Rawson, UST Class B Operator	raw043@yahoo.com
Wes Burley, UST Class A Operator	

Tank Number	01	**Tank Age**	9	**Tank Installed Date**	10/19/2016	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	5611	**Spill Test Date**	10/27/2022	**Piping Installed Date**	10/19/2016	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	10/28/2022	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel, Dyed	**PLLD Test Date**	10/27/2022	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	15000	**ATG Test Date**	10/27/2022	**Line Tightness Test Date**	11/07/2022	**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	10/27/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350;Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	02	**Tank Age**	9	**Tank Installed Date**	10/19/2016	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	5612	**Spill Test Date**	10/27/2022	**Piping Installed Date**	10/19/2016	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	10/28/2022	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	10/27/2022	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No

Capacity	10000	**ATG Test Date**	10/27/2022	**Line Tightness Test Date**	11/03/2022	**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	10/27/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350;Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	03	**Tank Age**	9	**Tank Installed Date**	10/19/2016	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	5613	**Spill Test Date**	10/27/2022	**Piping Installed Date**	10/19/2016	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	10/28/2022	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	10/27/2022	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	15000	**ATG Test Date**	10/27/2022	**Line Tightness Test Date**	11/03/2022	**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	10/27/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350;Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	04	**Tank Age**	9	**Tank Installed Date**	10/19/2016	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	5614	**Spill Test Date**	10/27/2022	**Piping Installed Date**	10/19/2016	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	10/28/2022	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	10/27/2022	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	10/27/2022	**Line Tightness Test Date**	11/16/2022	**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	10/27/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350;Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	05	**Tank Age**	9	**Tank Installed Date**	10/19/2016	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	5615	**Spill Test Date**	10/27/2022	**Piping Installed Date**	10/19/2016	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	10/28/2022	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	10/27/2022	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No

Capacity	10000	**ATG Test Date**	10/27/2022	**Line Tightness Test Date**	11/05/2022	**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	10/27/2022			**ATG Type**	Gilbarco-Veeder Root/TLS-350;Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	06	**Tank Age**	9	**Tank Installed Date**	10/19/2016	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Positive Shutoff
Tag Number	5616	**Spill Test Date**		**Piping Installed Date**	10/19/2016	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Other**	**MLLD Test Date**		**Sump Tightness Test Date**	10/07/2016	**Catastrophic L.D. Type 3.0**		**Piping Type**	Pressurized	**CP Met Types**	
Product	DEF (Not Regulated)	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Not Listed	**Primary Pipe Leak Detection**	Not Listed	**Vapor Recovery**	No
Capacity	1000	**ATG Test Date**		**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Not Listed	**Energy Act**	No
		Overfill Test Date				**ATG Type**					

Facility Summary in Yellowstone County in the City of Laurel

Location: TOWN PUMP INC LAUREL 1
312 S 1st Ave
Laurel, MT 59044 Yellowstone

System Facility ID:56-08710

Facility Code: 30282
Last Inspected On: 03/06/2024
Operating Permit Renewal Date: 07/21/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Laurel 1 Town Pump LLC	**(406) 497-6700**	**environmental@townpump.com**
Operator Contact:	Trent Biggers		**Trentb@townpump.com**

Owner/Operator:	Laurel 1 Town Pump LLC	(406) 497-6700	environmental@townpump.com
	Trent Biggers, UST Class A Operator		Trentb@townpump.com
	Trent Biggers, UST Class A Operator		Trentb@townpump.com
	Trent Biggers, UST Class B Global Operator		Trentb@townpump.com
	Trent Biggers, UST Class B Global Operator		Trentb@townpump.com

Tank Number	01	**Tank Age**	51	**Tank Installed Date**	04/14/1974	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Steel	**Overfill Types**	Flapper Valve
Tag Number	2668	**Spill Test Date**	09/05/2023	**Piping Installed Date**		**Tank Construction**	Lined Interior/Impressed Current	**Piping Construction**	Single Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	08/25/2022	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Diesel	**PLLD Test Date**	07/14/2022	**Tank/Piping CP Test Date**	11/22/2022	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	06/27/2024	**Line Tightness Test Date**	08/25/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	08/16/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Number	02	**Tank Age**	51	**Tank Installed Date**	04/14/1974	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Steel	**Overfill Types**	Flapper Valve
Tag Number	2669	**Spill Test Date**	08/16/2023	**Piping Installed Date**		**Tank Construction**	Lined Interior/Impressed Current	**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	08/25/2022	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**	07/14/2022	**Tank/Piping CP Test Date**	08/16/2023	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No

Capacity	8000	**ATG Test Date**	06/27/2024	**Line Tightness Test Date**	08/25/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	08/16/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Number	03	**Tank Age**	51	**Tank Installed Date**	04/14/1974	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Steel	**Overfill Types**	Flapper Valve
Tag Number	2670	**Spill Test Date**	09/05/2023	**Piping Installed Date**		**Tank Construction**	Lined Interior/Impressed Current	**Piping Construction**	Single Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	08/25/2022	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**	07/14/2022	**Tank/Piping CP Test Date**	11/22/2022	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	8000	**ATG Test Date**	06/27/2024	**Line Tightness Test Date**	08/25/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	08/16/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Number	05	**Tank Age**	45	**Tank Installed Date**	04/14/1980	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve
Tag Number	2672	**Spill Test Date**	11/22/2022	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**	09/28/2022	**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Gasoline	**PLLD Test Date**	08/25/2022	**Tank/Piping CP Test Date**	08/16/2023	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	06/27/2024	**Line Tightness Test Date**	09/28/2022	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	08/16/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Number	04	**Tank Age**	45	**Tank Installed Date**	04/14/1980	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Ball Float Valve;Flapper Valve
Tag Number	4589	**Spill Test Date**	08/16/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Diesel	**PLLD Test Date**	07/14/2022	**Tank/Piping CP Test Date**	08/16/2023	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	06/27/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No

		Overfill Test Date	08/16/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Number	07	**Tank Age**	24	**Tank Installed Date**	06/01/2001	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve
Tag Number	4590	**Spill Test Date**	08/16/2023	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	07/14/2022	**Tank/Piping CP Test Date**	11/18/2014	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	5000	**ATG Test Date**	06/27/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	08/16/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Number	08	**Tank Age**	24	**Tank Installed Date**	06/01/2001	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve
Tag Number	4591	**Spill Test Date**	09/05/2023	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	07/14/2022	**Tank/Piping CP Test Date**	11/18/2014	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	06/27/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	08/16/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Number	09	**Tank Age**	24	**Tank Installed Date**	06/01/2001	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve
Tag Number	4592	**Spill Test Date**	08/16/2023	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	07/14/2022	**Tank/Piping CP Test Date**	11/18/2014	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	5000	**ATG Test Date**	06/27/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	08/16/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				

Tank Number	10	**Tank Age**	24	**Tank Installed Date**	06/01/2001	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve
Tag Number	4593	**Spill Test Date**	09/05/2023	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	07/14/2022	**Tank/Piping CP Test Date**	11/18/2014	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	06/27/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	08/16/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Number	11	**Tank Age**	24	**Tank Installed Date**	08/25/2001	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Ball Float Valve
Tag Number	4594	**Spill Test Date**	09/05/2023	**Piping Installed Date**		**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	07/14/2022	**Tank/Piping CP Test Date**	11/18/2014	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	15000	**ATG Test Date**	06/27/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**	Continuous Interstitial Monitoring	**Secondary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Energy Act**	No
		Overfill Test Date	08/16/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Number	06	**Tank Age**	38	**Tank Installed Date**	04/01/1987	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Galvanized Steel	**Overfill Types**	Ball Float Valve;Flapper Valve
Tag Number	4603	**Spill Test Date**	09/05/2023	**Piping Installed Date**		**Tank Construction**		**Piping Construction**	Single Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Impressed Current
Product	Diesel	**PLLD Test Date**	07/14/2022	**Tank/Piping CP Test Date**	11/22/2022	**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	06/27/2024	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	08/16/2023			**ATG Type**	Gilbarco-Veeder Root/TLS-450PLUS				

Facility Summary in Yellowstone County in the City of Laurel

Location: TOWN PUMP OF LAUREL #3
704 1st Ave
Laurel, MT 59044-2100 Yellowstone

System Facility ID:60-15061

Facility Code: 30833
Last Inspected On: 03/06/2024
Operating Permit Renewal Date: 07/21/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact: Laurel 3 Town Pump LLC **(406) 497-6700** **environmental@townpump.com**

Operator Contact: Trent Biggers;Town Pump **Trentb@townpump.com;environmental@townpump.com**

Owner/Operator: Laurel 3 Town Pump LLC (406) 497-6700 environmental@townpump.com

Trent Biggers, UST Class A Operator environmental@townpump.com

Trent Biggers, UST Class B Operator environmental@townpump.com

Tank Number	01	**Tank Age**	18	**Tank Installed Date**	03/28/2007	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	5105	**Spill Test Date**	08/16/2023	**Piping Installed Date**	10/25/2006	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	05/14/2021	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	03/06/2024	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**	03/06/2024	**Line Tightness Test Date**	05/07/2014	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	08/16/2023			**ATG Type**					
Tank Number	02	**Tank Age**	18	**Tank Installed Date**	03/28/2007	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm
Tag Number	5106	**Spill Test Date**	08/16/2023	**Piping Installed Date**	10/25/2006	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	05/14/2021	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	03/06/2024	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**	03/06/2024	**Line Tightness Test Date**	05/11/2014	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	08/16/2023			**ATG Type**					
Tank Number	03	**Tank Age**	18	**Tank Installed Date**	03/28/2007	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	High Level Alarm

Tag Number	5107	**Spill Test Date**	08/16/2023	**Piping Installed Date**	10/25/2006	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	05/14/2021	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	03/06/2024	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Statistical Inventory Reconciliation	**Primary Pipe Leak Detection**	Statistical Inventory Reconciliation	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	03/06/2024	**Line Tightness Test Date**	05/13/2014	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	08/16/2023			**ATG Type**					

Facility Summary in Yellowstone County in the City of Pompeys Pillar

Location: BAYER TRUCKING BILLINGS TERMINAL
2722 Fly Creek road
Pompeys Pillar, MT 59064 Yellowstone

System Facility ID:00-32533

Facility Code: 32533
Last Inspected On: 07/19/2024
Operating Permit Renewal Date: 07/19/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	JMBAY Holdings, LLC	**(320) 254-3651**	**accounting@bayerbuilt.com**
Operator Contact:	Cole Bright;JMBAY Holdings, LLC	**(320) 254-3651**	**cbright@bayerbuilt.com;accounting@bayerbuilt.com**

Owner/Operator: JMBAY Holdings, LLC (320) 254-3651 accounting@bayerbuilt.com

Cole Bright, UST Class A Operator accounting@bayerbuilt.com

Cole Bright, UST Class B Operator accounting@bayerbuilt.com

Tank Number	01	**Tank Age**	2	**Tank Installed Date**	10/16/2023	**Tank Material Construction**	Fiberglass Reinforced Plastic	**Piping Material**	Flexible Plastic	**Overfill Types**	Flapper Valve;High Level Alarm
Tag Number	6194	**Spill Test Date**	04/02/2024	**Piping Installed Date**	01/08/2024	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	04/02/2024	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Diesel	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Continuous Interstitial Monitoring	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	12000	**ATG Test Date**	04/02/2024	**Line Tightness Test Date**	04/02/2024	**Secondary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	04/02/2024			**ATG Type**					
Tank Number	02	**Tank Age**	2	**Tank Installed Date**	10/16/2023	**Tank Material Construction**	Cathodically Protected Steel	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	6195	**Spill Test Date**	04/02/2024	**Piping Installed Date**	01/08/2024	**Tank Construction**	Double-Walled	**Piping Construction**	Double Walled	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	04/02/2024	**Catastrophic L.D. Type 3.0**		**Piping Type**	Safe Suction	**CP Met Types**	Galvanic
Product	DEF (Not Regulated)	**PLLD Test Date**		**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**		**Primary Pipe Leak Detection**		**Vapor Recovery**	No
Capacity	4000	**ATG Test Date**	04/02/2024	**Line Tightness Test Date**	04/02/2024	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	Yes
		Overfill Test Date	04/02/2024			**ATG Type**					

Facility Summary in Yellowstone County in the City of Worden

Location: VALLEY FARMERS SUPPLY
1545 Northern Ave
Worden, MT 59088-2215 Yellowstone

System Facility ID:56-02326

Facility Code: 29815
Last Inspected On: 10/26/2023
Operating Permit Renewal Date: 02/27/2027

Note: **Inspection is due 90 days before the Operating Permit Renewal Date.**

Owner Operator Contact:	Valley Farmers Supply	**(406) 967-3100**	**sblack@vfarmers.com**
Operator Contact:	Scott Black	**(406) 967-3100**	**sblack@vfarmers.com**

Owner/Operator: Valley Farmers Supply (406) 967-3100 sblack@vfarmers.com

Scott Black, UST Class A Operator sblack@vfarmers.com
Scott Black, UST Class A Operator sblack@vfarmers.com
Scott Black, UST Class B Global Operator sblack@vfarmers.com
Scott Black, UST Class B Global Operator sblack@vfarmers.com

Tank Number	04	**Tank Age**	34	**Tank Installed Date**	11/01/1991	**Tank Material Construction**	Steel Clad	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	1006	**Spill Test Date**		**Piping Installed Date**	02/15/2007	**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	09/11/2020	**Tank/Piping CP Test Date**	09/16/2011	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**		**Line Tightness Test Date**	05/29/2020	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	03/31/2021			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Tank Number	05	**Tank Age**	34	**Tank Installed Date**	11/01/1991	**Tank Material Construction**	Steel Clad	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	1007	**Spill Test Date**		**Piping Installed Date**	02/15/2007	**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Gasoline	**PLLD Test Date**	09/11/2020	**Tank/Piping CP Test Date**	09/16/2011	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	6000	**ATG Test Date**		**Line Tightness Test Date**	05/27/2020	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	03/31/2021			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Tank Number	06	**Tank Age**	34	**Tank Installed Date**	11/01/1991	**Tank Material Construction**	Steel Clad	**Piping Material**	Fiberglass Reinforced Plastic	**Overfill Types**	Flapper Valve
Tag Number	1008	**Spill Test Date**		**Piping Installed Date**	02/15/2007	**Tank Construction**		**Piping Construction**	None	**AST**	No
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**		**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	Non-corrodible
Product	Diesel	**PLLD Test Date**	09/11/2020	**Tank/Piping CP Test Date**	09/16/2011	**Primary Tank Leak Detection**	Automatic Tank Gauging 0.2	**Primary Pipe Leak Detection**	ELLD 0.2	**Vapor Recovery**	No
Capacity	3000	**ATG Test Date**		**Line Tightness Test Date**	05/21/2017	**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**		**Energy Act**	No
		Overfill Test Date	03/31/2021			**ATG Type**	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Number	S7	**Tank Age**	2	**Tank Installed Date**	05/30/2023	**Tank Material Construction**	Other	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	6149	**Spill Test Date**		**Piping Installed Date**	05/30/2023	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	Yes
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	05/30/2023	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Diesel, Dyed	**PLLD Test Date**	05/30/2023	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Deferred	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	05/30/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	05/30/2023			**ATG Type**					
Tank Number	S8	**Tank Age**	2	**Tank Installed Date**	05/30/2023	**Tank Material Construction**	Other	**Piping Material**	Flexible Plastic	**Overfill Types**	High Level Alarm
Tag Number	6150	**Spill Test Date**		**Piping Installed Date**	05/30/2023	**Tank Construction**		**Piping Construction**	Double Walled	**AST**	Yes
Status	**Currently in Use**	**MLLD Test Date**		**Sump Tightness Test Date**	05/30/2023	**Catastrophic L.D. Type 3.0**	Electronic Line Leak Detector	**Piping Type**	Pressurized	**CP Met Types**	
Product	Diesel	**PLLD Test Date**	05/30/2023	**Tank/Piping CP Test Date**		**Primary Tank Leak Detection**	Deferred	**Primary Pipe Leak Detection**	Continuous Interstitial Monitoring	**Vapor Recovery**	No
Capacity	10000	**ATG Test Date**	05/30/2023	**Line Tightness Test Date**		**Secondary Tank Leak Detection**		**Secondary Pipe Leak Detection**	ELLD 0.2	**Energy Act**	Yes
		Overfill Test Date	05/30/2023			**ATG Type**					