

Facility Summary in Beaverhead County in the City of Dell

Location: DELL AIRPORT CANYON RANCH
 Dell Airport
 Dell, MT 59724 Beaverhead

System Facility ID:01-09843

Facility Code: 17682
 Last Inspected On: 12/21/2023
 Operating Permit Renewal Date: 12/26/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Montana Dept of Transportation

(406) 444-7632

jradonich@mt.gov

Operator Contact: Joe Radonich

(406) 444-9204

jradonich@mt.gov

Owner/Operator: Montana Dept of Transportation

(406) 444-7632

jradonich@mt.gov

Joe Radonich, UST Class A Operator

jradonich@mt.gov

Joe Radonich, UST Class B Global Operator

jradonich@mt.gov

| | | | | | | | | | | | |
|--------------------|-------------------------------|---------------------------|----|---------------------------------|------------|--------------------------------------|--------------------------------|---------------------------------|-----------|-----------------------|------------------|
| Tank Code | 01 | Tank Age | 37 | Tank Installed Date | 06/13/1989 | Tank Material | Cathodically Protected Steel | Piping Material | No Piping | Overfill Types | High Level Alarm |
| Tag Number | 516 | Spill Test Date | | Piping Installed Date | | Tank Construction | Double-Walled | Piping Construction | None | AST | No |
| Tank Status | Temporarily Out of Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Not Required | Piping Type | | CP Met Types | Galvanic |
| Product | Jet Fuel (Jet-A, Jet-A1, JP5) | PLLD Test Date | | Tank/Piping CP Test Date | 12/21/2023 | Primary Tank Leak Detection | Manual Interstitial Monitoring | Primary Pipe Detection | | Vapor Recovery | No |
| Capacity | 10000 | ATG Test Date | | Line Tightness Test Date | | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | No |
| | | Overfill Test Date | | | | ATG Type | | | | | |

Facility Summary in Beaverhead County in the City of Dell

Location: DELL MERC
24 Main St
Dell, MT 59724 Beaverhead

System Facility ID:01-01523

Facility Code: 17476
Last Inspected On: 07/14/2023
Operating Permit Renewal Date: 08/20/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Bear Paw Inc (307) 871-5947 cjshopper2017@outlook.com

Operator Contact: Chad Mussard (307) 871-5947

Owner/Operator: Bear Paw Inc (307) 871-5947 cjshopper2017@outlook.com

Chad Mussard, UST Class A Operator

Chad Mussard, UST Class B Operator

| | | | | | | | | | | | |
|--------------------|------------------|---------------------------|------------|---------------------------------|------------|--------------------------------------|---|---------------------------------|------------------------------------|-----------------------|-----------------------------------|
| Tank Code | 04 | Tank Age | 21 | Tank Installed Date | 10/06/2005 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Flexible Plastic | Overfill Types | Ball Float Valve;High Level Alarm |
| Tag Number | 5045 | Spill Test Date | 09/09/2021 | Piping Installed Date | | Tank Construction | | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | 01/10/2024 | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Mechanical Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Gasoline | PLLD Test Date | | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | MLLD Line Tightness Testing | Vapor Recovery | No |
| Capacity | 10000 | ATG Test Date | 01/10/2024 | Line Tightness Test Date | 12/28/2022 | Secondary Tank Leak Detection | | Secondary Pipe Detection | Continuous Interstitial Monitoring | Energy Act | No |
| | | Overfill Test Date | 01/10/2024 | | | ATG Type | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | | | |
| Tank Code | 05 | Tank Age | 21 | Tank Installed Date | 10/06/2005 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Flexible Plastic | Overfill Types | Ball Float Valve;High Level Alarm |
| Tag Number | 5046 | Spill Test Date | 09/09/2021 | Piping Installed Date | | Tank Construction | | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | 01/10/2024 | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Mechanical Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Diesel | PLLD Test Date | | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | MLLD Line Tightness Testing | Vapor Recovery | No |
| Capacity | 5000 | ATG Test Date | 01/10/2024 | Line Tightness Test Date | 12/28/2022 | Secondary Tank Leak Detection | | Secondary Pipe Detection | Continuous Interstitial Monitoring | Energy Act | No |

| | | | | | | | | | | |
|--------------------|------------------|---------------------------|------------|---------------------------------|------------|--------------------------------------|---|---------------------------------|------------------------------------|-----------------------|
| | | Overfill Test Date | 01/10/2024 | | | ATG Type | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | | |
| Tank Code | 06 | Tank Age | 21 | Tank Installed Date | 10/06/2005 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Flexible Plastic | Overfill Types |
| Tag Number | 5047 | Spill Test Date | 12/01/2021 | Piping Installed Date | | Tank Construction | | Piping Construction | Double Walled | AST |
| Tank Status | Currently in Use | MLLD Test Date | 01/10/2024 | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Mechanical Line Leak Detector | Piping Type | Pressurized | CP Met Types |
| Product | Diesel | PLLD Test Date | | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | MLLD Line Tightness Testing | Vapor Recovery |
| Capacity | 10000 | ATG Test Date | 01/10/2024 | Line Tightness Test Date | 12/28/2022 | Secondary Tank Leak Detection | | Secondary Pipe Detection | Continuous Interstitial Monitoring | Energy Act |
| | | Overfill Test Date | 01/10/2024 | | | ATG Type | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | | |
| Tank Code | 07 | Tank Age | 21 | Tank Installed Date | 10/06/2005 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Flexible Plastic | Overfill Types |
| Tag Number | 5048 | Spill Test Date | 09/09/2021 | Piping Installed Date | | Tank Construction | | Piping Construction | Double Walled | AST |
| Tank Status | Currently in Use | MLLD Test Date | 01/10/2024 | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Mechanical Line Leak Detector | Piping Type | Pressurized | CP Met Types |
| Product | Gasoline | PLLD Test Date | | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | MLLD Line Tightness Testing | Vapor Recovery |
| Capacity | 8000 | ATG Test Date | 01/10/2024 | Line Tightness Test Date | 12/28/2022 | Secondary Tank Leak Detection | | Secondary Pipe Detection | Continuous Interstitial Monitoring | Energy Act |
| | | Overfill Test Date | 01/10/2024 | | | ATG Type | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | | |

Facility Summary in Beaverhead County in the City of Dillon

Location: COUNTY COURTHOUSE
2 S Pacific St
Dillon, MT 59725-4000 Beaverhead

System Facility ID:01-05668

Facility Code: 17574
Last Inspected On: 12/22/2025
Operating Permit Renewal Date: 05/04/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Beaverhead County Clerk

(406) 683-5245

croffice@beaverheadcountymt.gov

Operator Contact: Shonna Graham;Beaverhead County

(406) 596-1740

sgraham@beaverheadcountymt.gov

Owner/Operator: Beaverhead County Clerk

(406) 683-5245

croffice@beaverheadcountymt.gov

Shonna Graham, UST Class A Operator

sgraham@beaverheadcountymt.gov

Shonna Graham, UST Class B Operator

sgraham@beaverheadcountymt.gov

| | | | | | | | | | | | |
|--------------------|------------------------|---------------------------|------------|---------------------------------|------------|--------------------------------------|------------------------------|---------------------------------|--------------|-----------------------|---------------|
| Tank Code | 02 | Tank Age | 33 | Tank Installed Date | 02/01/1993 | Tank Material | Cathodically Protected Steel | Piping Material | Steel | Overfill Types | Flapper Valve |
| Tag Number | 421 | Spill Test Date | 03/01/2022 | Piping Installed Date | | Tank Construction | Double-Walled | Piping Construction | None | AST | No |
| Tank Status | Temporarily Out of Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Not Required | Piping Type | Safe Suction | CP Met Types | Galvanic |
| Product | Gasoline | PLLD Test Date | | Tank/Piping CP Test Date | 06/07/2023 | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | | Vapor Recovery | No |
| Capacity | 2000 | ATG Test Date | 03/01/2022 | Line Tightness Test Date | 03/01/2008 | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | No |
| | | Overfill Test Date | | | | ATG Type | Veeder Root/TLS-250 | | | | |

Facility Summary in Beaverhead County in the City of Dillon

Location: DIETRICH COLLEGE EXXON UST
636 S Atlantic St
Dillon, MT 59725-2725 Beaverhead

System Facility ID:01-05401

Facility Code: 17564
Last Inspected On: 09/10/2025
Operating Permit Renewal Date: 09/10/2028

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: TJ and Megan Dietrich (406) 683-0070 dietrichcollegeautorepair@gmail.com

Operator Contact: Timothy Dietrich (404) 925-1600 tdietrich55@gmail.com

Owner/Operator: TJ and Megan Dietrich (406) 683-0070 dietrichcollegeautorepair@gmail.com

Timothy Dietrich, UST Class A Operator tdietrich55@gmail.com

Timothy Dietrich, UST Class B Global Operator tdietrich55@gmail.com

| | | | | | | | | | | | |
|-------------|------------------------|--------------------|----|--------------------------|------------|-------------------------------|---|--------------------------|-------------------------------|----------------|---------------|
| Tank Code | 04 | Tank Age | 32 | Tank Installed Date | 07/01/1994 | Tank Material | Cathodically Protected Steel | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | Flapper Valve |
| Tag Number | 3226 | Spill Test Date | | Piping Installed Date | | Tank Construction | | Piping Construction | None | AST | No |
| Tank Status | Temporarily Out of Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Not Required | Piping Type | Safe Suction | CP Met Types | Galvanic |
| Product | Gasoline | PLLD Test Date | | Tank/Piping CP Test Date | 09/10/2025 | Primary Tank Leak Detection | Inventory Reconciliation;Tank Tightness Testing | Primary Pipe Detection | | Vapor Recovery | No |
| Capacity | 10000 | ATG Test Date | | Line Tightness Test Date | | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | No |
| | | Overfill Test Date | | | | ATG Type | | | | | |
| Tank Code | 05 | Tank Age | 32 | Tank Installed Date | 07/01/1994 | Tank Material | Cathodically Protected Steel | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | Flapper Valve |
| Tag Number | 3227 | Spill Test Date | | Piping Installed Date | | Tank Construction | | Piping Construction | None | AST | No |
| Tank Status | Temporarily Out of Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Not Required | Piping Type | Safe Suction | CP Met Types | Galvanic |
| Product | Gasoline | PLLD Test Date | | Tank/Piping CP Test Date | 09/10/2025 | Primary Tank Leak Detection | Inventory Reconciliation;Tank Tightness Testing | Primary Pipe Detection | | Vapor Recovery | No |
| Capacity | 6000 | ATG Test Date | | Line Tightness Test Date | | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | No |
| | | Overfill Test Date | | | | ATG Type | | | | | |

Facility Summary in Beaverhead County in the City of Dillon

Location: DILLON AIRPORT
2400 Airport Rd
Dillon, MT 59725-9500 Beaverhead

System Facility ID: 56-13894

Facility Code: 30568
Last Inspected On: 01/24/2024
Operating Permit Renewal Date: 03/04/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Beaverhead County Clerk

(406) 683-5245

croffice@beaverheadcountymt.gov

Operator Contact: Shonna Graham; Beaverhead County

(406) 596-1740

sgraham@beaverheadcountymt.gov

Owner/Operator: Beaverhead County Clerk

(406) 683-5245

croffice@beaverheadcountymt.gov

Shonna Graham, UST Class A Operator

sgraham@beaverheadcountymt.gov

Shonna Graham, UST Class B Operator

sgraham@beaverheadcountymt.gov

| | | | | | | | | | | | |
|--------------------|-------------------------------|---------------------------|------------|---------------------------------|------------|--------------------------------------|----------------------------------|---------------------------------|-----------------------------|-----------------------|-------------------|
| Tank Code | 01 | Tank Age | 44 | Tank Installed Date | 04/01/1982 | Tank Material | Bare Steel | Piping Material | Steel | Overfill Types | Flapper Valve |
| Tag Number | 3995 | Spill Test Date | 01/24/2024 | Piping Installed Date | | Tank Construction | | Piping Construction | None | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | 01/24/2024 | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Mechanical Line Leak Detector | Piping Type | Pressurized | CP Met Types | Impressed Current |
| Product | Jet Fuel (Jet-A, Jet-A1, JP5) | PLLD Test Date | | Tank/Piping CP Test Date | 01/24/2024 | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | MLLD Line Tightness Testing | Vapor Recovery | No |
| Capacity | 12000 | ATG Test Date | 01/24/2024 | Line Tightness Test Date | 01/24/2024 | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | No |
| | | Overfill Test Date | 01/24/2024 | | | ATG Type | Gilbarco/EMC Basic | | | | |
| Tank Code | 02 | Tank Age | 44 | Tank Installed Date | 04/01/1982 | Tank Material | Cathodically Protected Steel | Piping Material | Steel | Overfill Types | Flapper Valve |
| Tag Number | 3996 | Spill Test Date | 01/24/2024 | Piping Installed Date | | Tank Construction | Lined Interior/Impressed Current | Piping Construction | None | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | 01/24/2024 | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Mechanical Line Leak Detector | Piping Type | Pressurized | CP Met Types | Impressed Current |
| Product | Aviation Gas | PLLD Test Date | | Tank/Piping CP Test Date | 01/24/2024 | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | MLLD Line Tightness Testing | Vapor Recovery | No |
| Capacity | 12000 | ATG Test Date | 01/24/2024 | Line Tightness Test Date | 01/24/2024 | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | No |
| | | Overfill Test Date | 01/24/2024 | | | ATG Type | Gilbarco/EMC Basic | | | | |

Facility Summary in Beaverhead County in the City of Dillon

Location: ROCKY MOUNTAIN SUPPLY INC DILLON
700 N Montana St
Dillon, MT 59725-3357 Beaverhead

System Facility ID:01-10034

Facility Code: 17685
Last Inspected On: 05/11/2023
Operating Permit Renewal Date: 09/06/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Rocky Mountain Supply Inc

(406) 388-4009

billballiet@rmsi.coop

Operator Contact: Jason Rorabaugh

(406) 388-6116

jasonrorabaugh@rmsi.coop

Owner/Operator: Rocky Mountain Supply Inc

(406) 388-4009

billballiet@rmsi.coop

Jason Rorabaugh, UST Class A Operator

jasonrorabaugh@rmsi.coop

Perry Shank, UST Class B Operator

billballiet@rmsi.coop

Tari Eaves, UST Class B Operator

rockymtnsupply@hotmail.com

| | | | | | | | | | | | |
|--------------------|------------------|---------------------------|------------|---------------------------------|------------|--------------------------------------|----------------------------------|---------------------------------|------------------------------------|-----------------------|--------------------------------|
| Tank Code | 01 | Tank Age | 45 | Tank Installed Date | 01/12/1981 | Tank Material | Cathodically Protected Steel | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | Flapper Valve;High Level Alarm |
| Tag Number | 3900 | Spill Test Date | 05/10/2023 | Piping Installed Date | 03/01/2017 | Tank Construction | Lined Interior/Impressed Current | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | 05/10/2023 | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Impressed Current |
| Product | Diesel | PLLD Test Date | 10/13/2022 | Tank/Piping CP Test Date | 10/07/2021 | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery | No |
| Capacity | 12000 | ATG Test Date | 10/13/2022 | Line Tightness Test Date | 06/07/2017 | Secondary Tank Leak Detection | | Secondary Pipe Detection | ELLD 0.2 | Energy Act | No |
| | | Overfill Test Date | 10/13/2022 | | | ATG Type | Veeder Root/TLS-450PLUS | | | | |
| Tank Code | 02 | Tank Age | 45 | Tank Installed Date | 01/12/1981 | Tank Material | Cathodically Protected Steel | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | Flapper Valve;High Level Alarm |
| Tag Number | 3901 | Spill Test Date | 05/07/2020 | Piping Installed Date | 03/01/2017 | Tank Construction | Lined Interior/Impressed Current | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Impressed Current |
| Product | Diesel | PLLD Test Date | 10/09/2019 | Tank/Piping CP Test Date | 10/03/2018 | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery | No |
| Capacity | 12000 | ATG Test Date | | Line Tightness Test Date | 06/08/2017 | Secondary Tank Leak Detection | | Secondary Pipe Detection | ELLD 0.2 | Energy Act | No |

| | | | | | | | | | | |
|-------------|------------------|--------------------|------------|--------------------------|------------|-------------------------------|----------------------------------|--------------------------|------------------------------------|----------------|
| | | Overfill Test Date | 05/07/2020 | | | ATG Type | Veeder Root/TLS-450PLUS | | | |
| Tank Code | 03 | Tank Age | 45 | Tank Installed Date | 01/12/1981 | Tank Material | Cathodically Protected Steel | Piping Material | Flexible Plastic | Overfill Types |
| Tag Number | 3902 | Spill Test Date | 05/07/2020 | Piping Installed Date | 03/01/2017 | Tank Construction | Lined Interior/Impressed Current | Piping Construction | Double Walled | AST |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types |
| Product | Diesel | PLLD Test Date | 10/09/2019 | Tank/Piping CP Test Date | 10/03/2018 | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery |
| Capacity | 12000 | ATG Test Date | | Line Tightness Test Date | 06/08/2017 | Secondary Tank Leak Detection | | Secondary Pipe Detection | ELLD 0.2 | Energy Act |
| | | Overfill Test Date | 05/07/2020 | | | ATG Type | Veeder Root/TLS-450PLUS | | | |
| Tank Code | 04 | Tank Age | 45 | Tank Installed Date | 01/12/1981 | Tank Material | Cathodically Protected Steel | Piping Material | Fiberglass Reinforced Plastic | Overfill Types |
| Tag Number | 3903 | Spill Test Date | 05/07/2020 | Piping Installed Date | 03/01/2017 | Tank Construction | Lined Interior/Impressed Current | Piping Construction | Double Walled | AST |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types |
| Product | Diesel | PLLD Test Date | 10/09/2019 | Tank/Piping CP Test Date | 10/03/2018 | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery |
| Capacity | 12000 | ATG Test Date | | Line Tightness Test Date | 06/07/2017 | Secondary Tank Leak Detection | | Secondary Pipe Detection | ELLD 0.2 | Energy Act |
| | | Overfill Test Date | 05/07/2020 | | | ATG Type | Veeder Root/TLS-450PLUS | | | |
| Tank Code | 05 | Tank Age | 45 | Tank Installed Date | 01/12/1981 | Tank Material | Cathodically Protected Steel | Piping Material | Fiberglass Reinforced Plastic | Overfill Types |
| Tag Number | 3904 | Spill Test Date | 05/07/2020 | Piping Installed Date | 03/01/2017 | Tank Construction | Lined Interior/Impressed Current | Piping Construction | Double Walled | AST |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types |
| Product | Diesel | PLLD Test Date | 10/09/2019 | Tank/Piping CP Test Date | 10/03/2018 | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery |
| Capacity | 12000 | ATG Test Date | | Line Tightness Test Date | 06/07/2017 | Secondary Tank Leak Detection | | Secondary Pipe Detection | ELLD 0.2 | Energy Act |
| | | Overfill Test Date | 05/07/2020 | | | ATG Type | Veeder Root/TLS-450PLUS | | | |

| | | | | | | | | | | | |
|-------------|------------------|--------------------|------------|--------------------------|------------|-------------------------------|--|--------------------------|------------------------------------|----------------|--------------------------------|
| Tank Code | 09 | Tank Age | 28 | Tank Installed Date | 12/01/1998 | Tank Material | Steel Clad | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | Flapper Valve;High Level Alarm |
| Tag Number | 3905 | Spill Test Date | 05/07/2020 | Piping Installed Date | 04/26/2023 | Tank Construction | Double-Walled | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Gasoline | PLLD Test Date | 10/09/2019 | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery | No |
| Capacity | 12000 | ATG Test Date | | Line Tightness Test Date | 04/18/2017 | Secondary Tank Leak Detection | Continuous Interstitial Monitoring | Secondary Pipe Detection | ELLD 0.2 | Energy Act | No |
| | | Overfill Test Date | 05/07/2020 | | | ATG Type | Gilbarco-Veeder Root/TLS-450PLUS;Veeder Root/TLS-450PLUS | | | | |
| Tank Code | 10 | Tank Age | 28 | Tank Installed Date | 12/01/1998 | Tank Material | Steel Clad | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | Flapper Valve;High Level Alarm |
| Tag Number | 3906 | Spill Test Date | 05/07/2020 | Piping Installed Date | 03/01/2017 | Tank Construction | Double-Walled | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Gasoline | PLLD Test Date | 10/09/2019 | Tank/Piping CP Test Date | 08/22/2017 | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery | No |
| Capacity | 4100 | ATG Test Date | | Line Tightness Test Date | 04/18/2017 | Secondary Tank Leak Detection | Continuous Interstitial Monitoring | Secondary Pipe Detection | ELLD 0.2 | Energy Act | No |
| | | Overfill Test Date | 05/07/2020 | | | ATG Type | Gilbarco-Veeder Root/TLS-450PLUS;Veeder Root/TLS-450PLUS | | | | |
| Tank Code | 11 | Tank Age | 28 | Tank Installed Date | 12/01/1998 | Tank Material | Steel Clad | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | Flapper Valve;High Level Alarm |
| Tag Number | 3907 | Spill Test Date | 05/07/2020 | Piping Installed Date | 03/01/2017 | Tank Construction | Double-Walled | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Gasoline | PLLD Test Date | 10/09/2019 | Tank/Piping CP Test Date | 08/22/2017 | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery | No |
| Capacity | 7900 | ATG Test Date | | Line Tightness Test Date | 04/18/2017 | Secondary Tank Leak Detection | Continuous Interstitial Monitoring | Secondary Pipe Detection | ELLD 0.2 | Energy Act | No |

| | | | | | | | | | | |
|--------------------|---------------------|---------------------------|------------|---------------------------------|------------|--------------------------------------|--|---------------------------------|------------------------------------|-----------------------|
| | | Overfill Test Date | 05/07/2020 | | | ATG Type | Gilbarco-Veeder Root/TLS-450PLUS;Veeder Root/TLS-450PLUS | | | |
| Tank Code | 12 | Tank Age | 9 | Tank Installed Date | 04/18/2017 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Fiberglass Reinforced Plastic | Overfill Types |
| Tag Number | 5738 | Spill Test Date | 05/07/2020 | Piping Installed Date | 03/01/2017 | Tank Construction | Double-Walled | Piping Construction | Double Walled | AST |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types |
| Product | Diesel | PLLD Test Date | 10/09/2020 | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Continuous Interstitial Monitoring | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery |
| Capacity | 12000 | ATG Test Date | | Line Tightness Test Date | 06/08/2017 | Secondary Tank Leak Detection | Automatic Tank Gauging 0.2 | Secondary Pipe Detection | ELLD 0.2 | Energy Act |
| | | Overfill Test Date | 05/07/2020 | | | ATG Type | Gilbarco-Veeder Root/TLS-450PLUS;Veeder Root/TLS-450PLUS | | | |
| Tank Code | 13 | Tank Age | 9 | Tank Installed Date | 04/18/2017 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Flexible Plastic | Overfill Types |
| Tag Number | 5739 | Spill Test Date | 05/07/2020 | Piping Installed Date | 04/26/2023 | Tank Construction | Double-Walled | Piping Construction | Double Walled | AST |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types |
| Product | Gasoline | PLLD Test Date | 10/09/2019 | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Continuous Interstitial Monitoring | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery |
| Capacity | 12000 | ATG Test Date | | Line Tightness Test Date | 04/19/2017 | Secondary Tank Leak Detection | Automatic Tank Gauging 0.2 | Secondary Pipe Detection | ELLD 0.2 | Energy Act |
| | | Overfill Test Date | 05/07/2020 | | | ATG Type | Gilbarco-Veeder Root/TLS-450PLUS;Veeder Root/TLS-450PLUS | | | |
| Tank Code | 14 | Tank Age | 9 | Tank Installed Date | 04/18/2017 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Fiberglass Reinforced Plastic | Overfill Types |
| Tag Number | 5740 | Spill Test Date | | Piping Installed Date | 03/01/2017 | Tank Construction | | Piping Construction | | AST |
| Tank Status | Other | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | | Piping Type | Pressurized | CP Met Types |
| Product | DEF (Not Regulated) | PLLD Test Date | | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Continuous Interstitial Monitoring | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery |

| | | | | | | | | | | | |
|-----------------|------|---------------------------|--|---------------------------------|--|--------------------------------------|--|----------------------------------|------------|-------------------|----|
| Capacity | 6000 | ATG Test Date | | Line Tightness Test Date | | Secondary Tank Leak Detection | | Secondary Pipe Detection | Not Listed | Energy Act | No |
| | | Overfill Test Date | | | | ATG Type | | Gilbarco-Veeder Root/TLS-450PLUS | | | |

Facility Summary in Beaverhead County in the City of Dillon

Location: SAFEWAY 1581 DILLON
760 Vine St.
Dillon, MT 59725-3315 Beaverhead

System Facility ID: 56-13989

Facility Code: 30650
Last Inspected On: 05/19/2025
Operating Permit Renewal Date: 11/05/2028

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Safeway Stores Inc

(425) 201-6301

Operator Contact: Jesse Wees; Martha Scott; Albertsons - Safeway; Rachel Jones (208) 395-3269; (208) 412-2233

jesse.wees@albertsons.com; mscot17@safeway.com; page.rost@albertsons.com; rachel.jones@albertsons.com

Owner/Operator: Safeway Stores Inc

(425) 201-6301

Jesse Wees, UST Class A Operator
Martha Scott, UST Class A Operator
Martha Scott, UST Class B Operator
Page Rost, UST Class B Global Operator
Rachel Jones, UST Class A Operator
Rachel Jones, UST Class B Global Operator
Shanna Sunderlin, UST Class B Global Operator

jesse.wees@albertsons.com
page.rost@albertsons.com
page.rost@albertsons.com
page.rost@albertsons.com
rachel.jones@albertsons.com
rachel.jones@albertsons.com

| | | | | | | | | | | | |
|--------------------|------------------|---------------------------|------------|---------------------------------|------------|--------------------------------------|------------------------------------|---------------------------------|------------------------------------|-----------------------|---------------------------------|
| Tank Code | 01 | Tank Age | 26 | Tank Installed Date | 10/09/2000 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | Flapper Valve; High Level Alarm |
| Tag Number | 4222 | Spill Test Date | 07/16/2024 | Piping Installed Date | 04/22/2022 | Tank Construction | Double-Walled | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Gasoline | PLLD Test Date | 05/19/2025 | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Continuous Interstitial Monitoring | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery | No |
| Capacity | 20000 | ATG Test Date | 05/19/2025 | Line Tightness Test Date | | Secondary Tank Leak Detection | | Secondary Pipe Detection | ELLD 0.2 | Energy Act | No |
| | | Overfill Test Date | 05/19/2025 | | | ATG Type | Gilbarco-Veeder Root/TLS-450 | | | | |
| Tank Code | 02 | Tank Age | 26 | Tank Installed Date | 10/01/2000 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | Flapper Valve; High Level Alarm |
| Tag Number | 4223 | Spill Test Date | 07/16/2024 | Piping Installed Date | 04/22/2022 | Tank Construction | Double-Walled | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | 07/16/2024 | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |

| | | | | | | | | | | | |
|-------------|------------------|--------------------|------------|--------------------------|------------|-------------------------------|------------------------------------|--------------------------|------------------------------------|----------------|--------------------------------|
| Product | Gasoline | PLL Test Date | 05/19/2025 | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Continuous Interstitial Monitoring | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery | No |
| Capacity | 10000 | ATG Test Date | 05/19/2025 | Line Tightness Test Date | | Secondary Tank Leak Detection | | Secondary Pipe Detection | ELLD 0.2 | Energy Act | No |
| | | Overfill Test Date | 05/19/2025 | | | ATG Type | Gilbarco-Veeder Root/TLS-450 | | | | |
| Tank Code | 03 | Tank Age | 26 | Tank Installed Date | 10/01/2000 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | Flapper Valve;High Level Alarm |
| Tag Number | 4224 | Spill Test Date | 07/16/2024 | Piping Installed Date | 04/22/2022 | Tank Construction | Double-Walled | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | 07/16/2024 | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Diesel | PLL Test Date | 05/19/2025 | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Continuous Interstitial Monitoring | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery | No |
| Capacity | 10000 | ATG Test Date | 05/19/2025 | Line Tightness Test Date | | Secondary Tank Leak Detection | | Secondary Pipe Detection | ELLD 0.2 | Energy Act | No |
| | | Overfill Test Date | 05/19/2025 | | | ATG Type | Gilbarco-Veeder Root/TLS-350 | | | | |

Facility Summary in Beaverhead County in the City of Dillon

Location: SPEEDY SINGHS INC
4055 Rebich Ln
Dillon, MT 59725 Beaverhead

System Facility ID:01-13101

Facility Code: 17715
Last Inspected On: 02/02/2024
Operating Permit Renewal Date: 03/03/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: SPEEDY SINGHS INC

(406) 683-6404

GATEWAYTRUCKSTOP@GMAIL.COM

Operator Contact:

Owner/Operator: SPEEDY SINGHS INC

(406) 683-6404

GATEWAYTRUCKSTOP@GMAIL.COM

| | | | | | | | | | | | |
|--------------------|------------------|---------------------------|------------|---------------------------------|------------|--------------------------------------|---|---------------------------------|------------------------------------|-----------------------|---------------|
| Tank Code | 01 | Tank Age | 33 | Tank Installed Date | 07/01/1993 | Tank Material | Cathodically Protected Steel | Piping Material | Flexible Plastic | Overfill Types | Flapper Valve |
| Tag Number | 4634 | Spill Test Date | 02/02/2024 | Piping Installed Date | 03/12/2009 | Tank Construction | | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | 10/05/2023 | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Mechanical Line Leak Detector | Piping Type | Pressurized | CP Met Types | Galvanic |
| Product | Gasoline | PLLD Test Date | | Tank/Piping CP Test Date | 03/13/2024 | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | MLLD Line Tightness Testing | Vapor Recovery | No |
| Capacity | 8000 | ATG Test Date | 10/05/2023 | Line Tightness Test Date | 10/05/2023 | Secondary Tank Leak Detection | | Secondary Pipe Detection | Continuous Interstitial Monitoring | Energy Act | No |
| | | Overfill Test Date | 04/03/2024 | | | ATG Type | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | | | |
| Tank Code | 02 | Tank Age | 33 | Tank Installed Date | 07/01/1993 | Tank Material | Cathodically Protected Steel | Piping Material | Flexible Plastic | Overfill Types | Flapper Valve |
| Tag Number | 4635 | Spill Test Date | 04/03/2024 | Piping Installed Date | 03/12/2009 | Tank Construction | | Piping Construction | None | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | 10/05/2023 | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Mechanical Line Leak Detector | Piping Type | Pressurized | CP Met Types | Galvanic |
| Product | Gasoline | PLLD Test Date | | Tank/Piping CP Test Date | 03/13/2024 | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | MLLD Line Tightness Testing | Vapor Recovery | No |
| Capacity | 8000 | ATG Test Date | 10/05/2023 | Line Tightness Test Date | 10/05/2023 | Secondary Tank Leak Detection | | Secondary Pipe Detection | Continuous Interstitial Monitoring | Energy Act | No |
| | | Overfill Test Date | 04/03/2024 | | | ATG Type | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | | | |

| | | | | | | | | | | | |
|-------------|------------------|--------------------|------------|--------------------------|------------|-------------------------------|---|--------------------------|-------------------------------|----------------|---------------|
| Tank Code | 03 | Tank Age | 33 | Tank Installed Date | 07/01/1993 | Tank Material | Cathodically Protected Steel | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | Flapper Valve |
| Tag Number | 4636 | Spill Test Date | 04/03/2024 | Piping Installed Date | | Tank Construction | | Piping Construction | None | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | 10/05/2023 | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Mechanical Line Leak Detector | Piping Type | Pressurized | CP Met Types | Galvanic |
| Product | Diesel | PLLD Test Date | | Tank/Piping CP Test Date | 03/13/2024 | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | MLLD Line Tightness Testing | Vapor Recovery | No |
| Capacity | 8000 | ATG Test Date | 10/05/2023 | Line Tightness Test Date | 10/05/2023 | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | No |
| | | Overfill Test Date | 04/03/2024 | | | ATG Type | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | | | |
| Tank Code | 04 | Tank Age | 33 | Tank Installed Date | 07/01/1993 | Tank Material | Cathodically Protected Steel | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | Flapper Valve |
| Tag Number | 4637 | Spill Test Date | 02/02/2024 | Piping Installed Date | | Tank Construction | | Piping Construction | None | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | 10/05/2023 | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Mechanical Line Leak Detector | Piping Type | Pressurized | CP Met Types | Galvanic |
| Product | Diesel | PLLD Test Date | | Tank/Piping CP Test Date | 03/13/2024 | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | MLLD Line Tightness Testing | Vapor Recovery | No |
| Capacity | 8000 | ATG Test Date | 10/05/2023 | Line Tightness Test Date | 04/18/2024 | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | No |
| | | Overfill Test Date | 04/03/2024 | | | ATG Type | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | | | |
| Tank Code | 05 | Tank Age | 33 | Tank Installed Date | 07/01/1993 | Tank Material | Cathodically Protected Steel | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | Flapper Valve |
| Tag Number | 4638 | Spill Test Date | 04/03/2024 | Piping Installed Date | | Tank Construction | | Piping Construction | None | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | 10/05/2023 | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Mechanical Line Leak Detector | Piping Type | Pressurized | CP Met Types | Galvanic |
| Product | Diesel | PLLD Test Date | | Tank/Piping CP Test Date | 03/13/2024 | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | MLLD Line Tightness Testing | Vapor Recovery | No |
| Capacity | 8000 | ATG Test Date | 10/05/2023 | Line Tightness Test Date | 10/05/2023 | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | No |
| | | Overfill Test Date | 04/03/2024 | | | ATG Type | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | | | |

Facility Summary in Beaverhead County in the City of Dillon

Location: THE MINI INC
410 N Montana St
Dillon, MT 59725 Beaverhead

System Facility ID:01-01215

Facility Code: 17471
Last Inspected On: 09/10/2024
Operating Permit Renewal Date: 10/13/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Jeff Dubose;The Mini Inc

(406) 683-6168

theminiinc@hotmail.com

Operator Contact: Lori DuBose

(406) 638-6168

theminiinc@hotmail.com

Owner/Operator: Jeff Dubose

(406) 683-6168

Owner/Operator: The Mini Inc

(406) 683-6168

Lori DuBose, UST Class A Operator

Lori DuBose, UST Class B Operator

theminiinc@hotmail.com

theminiinc@hotmail.com

| | | | | | | | | | | | |
|--------------------|------------------|---------------------------|------------|---------------------------------|------------|--------------------------------------|----------------------------------|---------------------------------|------------------------------------|-----------------------|----------------|
| Tank Code | 04 | Tank Age | 28 | Tank Installed Date | 05/06/1998 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Flexible Plastic | Overfill Types | Flapper Valve |
| Tag Number | 3088 | Spill Test Date | 11/04/2024 | Piping Installed Date | | Tank Construction | | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Gasoline | PLLD Test Date | 05/21/2024 | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | ELLD 0.2 | Vapor Recovery | No |
| Capacity | 12000 | ATG Test Date | 09/10/2024 | Line Tightness Test Date | 05/05/2021 | Secondary Tank Leak Detection | | Secondary Pipe Detection | Continuous Interstitial Monitoring | Energy Act | No |
| | | Overfill Test Date | 09/10/2024 | | | ATG Type | Gilbarco-Veeder Root/TLS-450PLUS | | | | |
| Tank Code | 05 | Tank Age | 28 | Tank Installed Date | 05/06/1998 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Flexible Plastic | Overfill Types | Flapper Valve |
| Tag Number | 3089 | Spill Test Date | 09/11/2024 | Piping Installed Date | | Tank Construction | | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Gasoline | PLLD Test Date | 05/21/2024 | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | ELLD 0.2 | Vapor Recovery | No |
| Capacity | 6000 | ATG Test Date | 09/10/2024 | Line Tightness Test Date | 04/28/2021 | Secondary Tank Leak Detection | | Secondary Pipe Detection | Continuous Interstitial Monitoring | Energy Act | No |
| | | Overfill Test Date | 09/10/2024 | | | ATG Type | Gilbarco-Veeder Root/TLS-450 | | | | |

| | | | | | | | | | | | |
|-------------|------------------|--------------------|------------|--------------------------|------------|-------------------------------|-------------------------------|--------------------------|------------------------------------|----------------|----------------|
| Tank Code | 06 | Tank Age | 28 | Tank Installed Date | 05/06/1998 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Flexible Plastic | Overfill Types | Flapper Valve |
| Tag Number | 3090 | Spill Test Date | 09/10/2024 | Piping Installed Date | | Tank Construction | | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Diesel | PLLD Test Date | 05/21/2024 | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery | No |
| Capacity | 5000 | ATG Test Date | 09/10/2024 | Line Tightness Test Date | 04/13/2022 | Secondary Tank Leak Detection | | Secondary Pipe Detection | ELLD 0.2 | Energy Act | No |
| | | Overfill Test Date | 09/10/2024 | | | ATG Type | Gilbarco-Veeder Root/TLS-450 | | | | |

Facility Summary in Beaverhead County in the City of Dillon

Location: TOWN PUMP INC DILLON 1
101 E Helena St
Dillon, MT 59725 Beaverhead

System Facility ID:01-08695

Facility Code: 17673
Last Inspected On: 05/20/2025
Operating Permit Renewal Date: 09/22/2028

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Dillon 1 Town Pump LLC

(406) 497-6700

environmental@townpump.com

Operator Contact: Trent Biggers

Trentb@townpump.com

Owner/Operator: Dillon 1 Town Pump LLC

(406) 497-6700

environmental@townpump.com

Trent Biggers, UST Class A Operator

Trent Biggers, UST Class B Global Operator

Trentb@townpump.com

Trentb@townpump.com

| | | | | | | | | | | | |
|--------------------|------------------|---------------------------|------------|---------------------------------|------------|--------------------------------------|--------------------------------------|---------------------------------|--------------------------------------|-----------------------|--------------------------------|
| Tank Code | 01 | Tank Age | 65 | Tank Installed Date | 04/14/1961 | Tank Material | Cathodically Protected Steel | Piping Material | Flexible Plastic | Overfill Types | Ball Float Valve;Flapper Valve |
| Tag Number | 4794 | Spill Test Date | 11/09/2024 | Piping Installed Date | 10/19/2002 | Tank Construction | Lined Interior/Impressed Current | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Impressed Current |
| Product | Diesel | PLLD Test Date | 05/20/2025 | Tank/Piping CP Test Date | 07/26/2024 | Primary Tank Leak Detection | Statistical Inventory Reconciliation | Primary Pipe Detection | Statistical Inventory Reconciliation | Vapor Recovery | No |
| Capacity | 12000 | ATG Test Date | 05/20/2025 | Line Tightness Test Date | | Secondary Tank Leak Detection | | Secondary Pipe Detection | Continuous Interstitial Monitoring | Energy Act | No |
| | | Overfill Test Date | 11/09/2024 | | | ATG Type | Gilbarco-Veeder Root/TLS-450PLUS | | | | |
| Tank Code | 04 | Tank Age | 40 | Tank Installed Date | 01/01/1986 | Tank Material | Cathodically Protected Steel | Piping Material | Flexible Plastic | Overfill Types | Ball Float Valve;Flapper Valve |
| Tag Number | 4795 | Spill Test Date | 11/09/2024 | Piping Installed Date | | Tank Construction | | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Impressed Current |
| Product | Gasoline | PLLD Test Date | 05/20/2025 | Tank/Piping CP Test Date | 07/26/2024 | Primary Tank Leak Detection | Statistical Inventory Reconciliation | Primary Pipe Detection | Statistical Inventory Reconciliation | Vapor Recovery | No |

| | | | | | | | | | | | |
|--------------------|------------------|---------------------------|------------|---------------------------------|------------|--------------------------------------|--------------------------------------|---------------------------------|--------------------------------------|-----------------------|--------------------------------|
| Capacity | 10000 | ATG Test Date | 05/20/2025 | Line Tightness Test Date | | Secondary Tank Leak Detection | | Secondary Pipe Detection | Continuous Interstitial Monitoring | Energy Act | No |
| | | Overfill Test Date | 11/09/2024 | | | ATG Type | Gilbarco-Veeder Root/TLS-450PLUS | | | | |
| Tank Code | 05 | Tank Age | 40 | Tank Installed Date | 01/01/1986 | Tank Material | Cathodically Protected Steel | Piping Material | Flexible Plastic | Overfill Types | Ball Float Valve;Flapper Valve |
| Tag Number | 4796 | Spill Test Date | 11/09/2024 | Piping Installed Date | | Tank Construction | | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Impressed Current |
| Product | Gasoline | PLLD Test Date | 05/20/2025 | Tank/Piping CP Test Date | 07/26/2024 | Primary Tank Leak Detection | Statistical Inventory Reconciliation | Primary Pipe Detection | Statistical Inventory Reconciliation | Vapor Recovery | No |
| Capacity | 12000 | ATG Test Date | 05/20/2025 | Line Tightness Test Date | | Secondary Tank Leak Detection | | Secondary Pipe Detection | Continuous Interstitial Monitoring | Energy Act | No |
| | | Overfill Test Date | 11/09/2024 | | | ATG Type | Gilbarco-Veeder Root/TLS-450PLUS | | | | |

Facility Summary in Beaverhead County in the City of Dillon

Location: TOWN PUMP OF DILLON 2
635 N Montana St
Dillon, MT 59725 Beaverhead

System Facility ID:01-08696

Facility Code: 17674
Last Inspected On: 06/16/2025
Operating Permit Renewal Date: 09/19/2028

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Dillon 2 Town Pump LLC

(406) 497-6700

environmental@townpump.com

Operator Contact: Trent Biggers

Trentb@townpump.com

Owner/Operator: Dillon 2 Town Pump LLC

(406) 497-6700

environmental@townpump.com

Trent Biggers, UST Class A Operator

Trent Biggers, UST Class B Global Operator

Trentb@townpump.com

Trentb@townpump.com

| | | | | | | | | | | | |
|--------------------|------------------|---------------------------|------------|---------------------------------|------------|--------------------------------------|--------------------------------------|---------------------------------|--------------------------------------|-----------------------|----------------|
| Tank Code | 07 | Tank Age | 36 | Tank Installed Date | 09/10/1990 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | Flapper Valve |
| Tag Number | 2372 | Spill Test Date | 11/15/2024 | Piping Installed Date | | Tank Construction | | Piping Construction | None | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Diesel | PLLD Test Date | 05/20/2025 | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Statistical Inventory Reconciliation | Primary Pipe Detection | Statistical Inventory Reconciliation | Vapor Recovery | No |
| Capacity | 12000 | ATG Test Date | 05/20/2025 | Line Tightness Test Date | | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | No |
| | | Overfill Test Date | 07/26/2024 | | | ATG Type | Gilbarco-Veeder Root/TLS-450 | | | | |
| Tank Code | 08 | Tank Age | 36 | Tank Installed Date | 09/10/1990 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | Flapper Valve |
| Tag Number | 2373 | Spill Test Date | 11/15/2024 | Piping Installed Date | | Tank Construction | | Piping Construction | None | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Diesel | PLLD Test Date | 05/20/2025 | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Statistical Inventory Reconciliation | Primary Pipe Detection | Statistical Inventory Reconciliation | Vapor Recovery | No |
| Capacity | 12000 | ATG Test Date | 05/20/2025 | Line Tightness Test Date | | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | No |
| | | Overfill Test Date | 07/26/2024 | | | ATG Type | Gilbarco-Veeder Root/TLS-450 | | | | |
| Tank Code | 09 | Tank Age | 36 | Tank Installed Date | 09/10/1990 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | Flapper Valve |

| | | | | | | | | | | | |
|-------------|------------------|--------------------|------------|--------------------------|------------|-------------------------------|--------------------------------------|--------------------------|--------------------------------------|----------------|------------------|
| Tag Number | 2374 | Spill Test Date | 11/15/2024 | Piping Installed Date | | Tank Construction | | Piping Construction | None | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Gasoline | PLLD Test Date | 05/20/2025 | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Statistical Inventory Reconciliation | Primary Pipe Detection | Statistical Inventory Reconciliation | Vapor Recovery | No |
| Capacity | 12000 | ATG Test Date | 05/20/2025 | Line Tightness Test Date | | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | No |
| | | Overfill Test Date | 07/26/2024 | | | ATG Type | Gilbarco-Veeder Root/TLS-450 | | | | |
| Tank Code | 10 | Tank Age | 36 | Tank Installed Date | 09/10/1990 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | Flapper Valve |
| Tag Number | 2375 | Spill Test Date | 11/15/2024 | Piping Installed Date | | Tank Construction | | Piping Construction | None | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Gasoline | PLLD Test Date | 05/20/2025 | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Statistical Inventory Reconciliation | Primary Pipe Detection | Statistical Inventory Reconciliation | Vapor Recovery | No |
| Capacity | 12000 | ATG Test Date | 05/20/2025 | Line Tightness Test Date | | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | No |
| | | Overfill Test Date | 09/11/2024 | | | ATG Type | Gilbarco-Veeder Root/TLS-450 | | | | |
| Tank Code | 11 | Tank Age | 36 | Tank Installed Date | 09/10/1990 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | Flapper Valve |
| Tag Number | 2376 | Spill Test Date | 11/15/2024 | Piping Installed Date | | Tank Construction | | Piping Construction | None | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Gasoline | PLLD Test Date | 05/20/2025 | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Statistical Inventory Reconciliation | Primary Pipe Detection | Statistical Inventory Reconciliation | Vapor Recovery | No |
| Capacity | 12000 | ATG Test Date | 05/20/2025 | Line Tightness Test Date | | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | No |
| | | Overfill Test Date | 11/15/2024 | | | ATG Type | Gilbarco-Veeder Root/TLS-450 | | | | |
| Tank Code | 14 | Tank Age | 25 | Tank Installed Date | 08/20/2001 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | Ball Float Valve |
| Tag Number | 4356 | Spill Test Date | 07/26/2024 | Piping Installed Date | | Tank Construction | Double-Walled | Piping Construction | None | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Gasoline | PLLD Test Date | 05/20/2025 | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Statistical Inventory Reconciliation | Primary Pipe Detection | Statistical Inventory Reconciliation | Vapor Recovery | No |

| | | | | | | | | | | | |
|-------------|------------------|--------------------|------------|--------------------------|------------|-------------------------------|--------------------------------------|--------------------------|--------------------------------------|----------------|------------------|
| Capacity | 10000 | ATG Test Date | 05/20/2025 | Line Tightness Test Date | | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | No |
| | | Overfill Test Date | 07/26/2024 | | | ATG Type | Gilbarco-Veeder Root/TLS-450 | | | | |
| Tank Code | 15 | Tank Age | 25 | Tank Installed Date | 08/20/2001 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | Ball Float Valve |
| Tag Number | 4357 | Spill Test Date | 07/26/2024 | Piping Installed Date | | Tank Construction | Double-Walled | Piping Construction | None | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Diesel, Dyed | PLLD Test Date | 05/20/2025 | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Statistical Inventory Reconciliation | Primary Pipe Detection | Statistical Inventory Reconciliation | Vapor Recovery | No |
| Capacity | 5000 | ATG Test Date | 05/20/2025 | Line Tightness Test Date | | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | No |
| | | Overfill Test Date | 07/26/2024 | | | ATG Type | Gilbarco-Veeder Root/TLS-450 | | | | |
| Tank Code | 13 | Tank Age | 27 | Tank Installed Date | 05/01/1999 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Flexible Plastic | Overfill Types | Ball Float Valve |
| Tag Number | 4541 | Spill Test Date | 11/15/2024 | Piping Installed Date | 11/14/2024 | Tank Construction | Double-Walled | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Diesel | PLLD Test Date | 05/20/2025 | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Statistical Inventory Reconciliation | Primary Pipe Detection | Statistical Inventory Reconciliation | Vapor Recovery | No |
| Capacity | 5000 | ATG Test Date | 05/20/2025 | Line Tightness Test Date | 11/16/2024 | Secondary Tank Leak Detection | | Secondary Pipe Detection | Continuous Interstitial Monitoring | Energy Act | No |
| | | Overfill Test Date | 11/15/2024 | | | ATG Type | Gilbarco-Veeder Root/TLS-450 | | | | |

Facility Summary in Beaverhead County in the City of Jackson

Location: CIRCLE S RANCH
30300 MT Hwy 278
Jackson, MT 59736-9700 Beaverhead

System Facility ID:01-07024

Facility Code: 17626
Last Inspected On: 10/01/2025
Operating Permit Renewal Date: 12/15/2028

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: David Schuett (406) 660-4281 d.schuett@frontlineag.com

Operator Contact: David Schuett (406) 660-4281 d.schuett@frontlineag.com

Owner/Operator: David Schuett (406) 660-4281 d.schuett@frontlineag.com

David Schuett, UST Class A Operator d.schuett@frontlineag.com

| Tank Code | S1 | Tank Age | 46 | Tank Installed Date | 02/12/1980 <th>Tank Material</th> <td>Bare Steel</td> <th>Piping Material</th> <td>Steel</td> <th>Overfill Types</th> | Tank Material | Bare Steel | Piping Material | Steel | Overfill Types |
|-------------|-------------------------|--------------------|------------|--------------------------|--|-------------------------------|----------------------------|--------------------------|------------------|----------------|
| Tag Number | | Spill Test Date | | Piping Installed Date | | Tank Construction | | Piping Construction | | AST |
| Tank Status | Deregulated under SB386 | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | | Piping Type | Not Listed | CP Met Types |
| Product | Gasoline | PLLD Test Date | | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Not Listed | Primary Pipe Detection | Not Listed | Vapor Recovery |
| Capacity | 2000 | ATG Test Date | | Line Tightness Test Date | | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act |
| | | Overfill Test Date | | | | ATG Type | | | | No |
| Tank Code | 05 | Tank Age | 29 | Tank Installed Date | 07/01/1997 <th>Tank Material</th> <td>Steel Clad</td> <th>Piping Material</th> <td>Flexible Plastic</td> <th>Overfill Types</th> | Tank Material | Steel Clad | Piping Material | Flexible Plastic | Overfill Types |
| Tag Number | 4228 | Spill Test Date | 10/01/2025 | Piping Installed Date | | Tank Construction | Double-Walled | Piping Construction | Double Walled | AST |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Not Required | Piping Type | Safe Suction | CP Met Types |
| Product | Diesel | PLLD Test Date | | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | | Vapor Recovery |
| Capacity | 1000 | ATG Test Date | 10/01/2025 | Line Tightness Test Date | | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act |
| | | Overfill Test Date | 10/01/2025 | | | ATG Type | Other/Other | | | No |
| Tank Code | 06 | Tank Age | 29 | Tank Installed Date | 07/01/1997 <th>Tank Material</th> <td>Steel Clad</td> <th>Piping Material</th> <td>Flexible Plastic</td> <th>Overfill Types</th> | Tank Material | Steel Clad | Piping Material | Flexible Plastic | Overfill Types |
| Tag Number | 4229 | Spill Test Date | 10/01/2025 | Piping Installed Date | | Tank Construction | Double-Walled | Piping Construction | Double Walled | AST |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Not Required | Piping Type | Safe Suction | CP Met Types |

| | | | | | | | | | | | |
|----------|----------|--------------------|------------|--------------------------|--|-------------------------------|----------------------------|--------------------------|--|----------------|----|
| Product | Gasoline | PLL D Test Date | | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | | Vapor Recovery | No |
| Capacity | 1000 | ATG Test Date | 10/01/2025 | Line Tightness Test Date | | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | No |
| | | Overfill Test Date | 10/01/2025 | | | ATG Type | Other/Other | | | | |

Facility Summary in Beaverhead County in the City of Lima

Location: LIMA SCHOOL DIST 12 INC
1 N Harrison St
Lima, MT 59739 Beaverhead

System Facility ID:01-07158

Facility Code: 17665
Last Inspected On: 12/21/2023
Operating Permit Renewal Date: 01/17/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: School Dist 12 Lima

(406) 276-3571

rkluesner@limaschoolmt.org

Operator Contact:

Owner/Operator: School Dist 12 Lima

(406) 276-3571

rkluesner@limaschoolmt.org

| | | | | | | | | | | | |
|--------------------|------------------|---------------------------|------------|---------------------------------|------------|--------------------------------------|------------------------------------|---------------------------------|------------------------------------|-----------------------|---------------|
| Tank Code | 03 | Tank Age | 34 | Tank Installed Date | 06/01/1992 | Tank Material | Cathodically Protected Steel | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | Flapper Valve |
| Tag Number | 1535 | Spill Test Date | 12/21/2023 | Piping Installed Date | | Tank Construction | Double-Walled | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Not Required | Piping Type | U.S. Suction | CP Met Types | Galvanic |
| Product | Diesel | PLLD Test Date | | Tank/Piping CP Test Date | 07/27/2020 | Primary Tank Leak Detection | Continuous Interstitial Monitoring | Primary Pipe Detection | 3-Year Line Tightness Test | Vapor Recovery | No |
| Capacity | 10000 | ATG Test Date | | Line Tightness Test Date | 12/21/2023 | Secondary Tank Leak Detection | Automatic Tank Gauging 0.2 | Secondary Pipe Detection | Continuous Interstitial Monitoring | Energy Act | No |
| | | Overfill Test Date | 12/21/2023 | | | ATG Type | Gilbarco-Veeder Root/ILS-250 | | | | |

Facility Summary in Beaverhead County in the City of Lima

Location: RALPHS EXXON
114 S Harrison St
Lima, MT 59739 Beaverhead

System Facility ID:01-00671

Facility Code: 17463
Last Inspected On: 04/23/2025
Operating Permit Renewal Date: 09/21/2028

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Ralphs C-Store Inc

(406) 925-1081

jdt.ralphs@gmail.com

Operator Contact: Branden Thornton;Justin Thornton

branden.t@mail.com;jdt1986@comcast.net

Owner/Operator: Ralphs C-Store Inc

(406) 925-1081

jdt.ralphs@gmail.com

Branden Thornton, UST Class A Operator

Branden Thornton, UST Class B Global Operator

Justin Thornton, UST Class A Operator

Justin Thornton, UST Class B Global Operator

| | | | | | | | | | | | |
|-------------|------------------|--------------------|------------|--------------------------|------------|-------------------------------|-------------------------------|--------------------------|------------------------------------|----------------|------------------|
| Tank Code | 07 | Tank Age | 28 | Tank Installed Date | 09/01/1998 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Flexible Plastic | Overfill Types | Ball Float Valve |
| Tag Number | 2078 | Spill Test Date | 12/11/2024 | Piping Installed Date | | Tank Construction | | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | 04/10/2025 | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Gasoline | PLLD Test Date | 04/23/2025 | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | ELLD 0.2 | Vapor Recovery | No |
| Capacity | 8000 | ATG Test Date | 04/10/2025 | Line Tightness Test Date | | Secondary Tank Leak Detection | | Secondary Pipe Detection | Continuous Interstitial Monitoring | Energy Act | No |
| | | Overfill Test Date | 10/14/2021 | | | ATG Type | Gilbarco/TLS-350 | | | | |
| Tank Code | 08 | Tank Age | 28 | Tank Installed Date | 09/01/1998 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Flexible Plastic | Overfill Types | Ball Float Valve |
| Tag Number | 2079 | Spill Test Date | 12/11/2024 | Piping Installed Date | | Tank Construction | | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | 04/10/2025 | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Gasoline | PLLD Test Date | 04/23/2025 | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | ELLD 0.2 | Vapor Recovery | No |
| Capacity | 4000 | ATG Test Date | 04/10/2025 | Line Tightness Test Date | | Secondary Tank Leak Detection | | Secondary Pipe Detection | Continuous Interstitial Monitoring | Energy Act | No |
| | | Overfill Test Date | 04/10/2025 | | | ATG Type | Gilbarco/TLS-350 | | | | |

| | | | | | | | | | | |
|-------------|------------------|--------------------|------------|--------------------------|------------|-------------------------------|-------------------------------|--------------------------|------------------------------------|----------------|
| Tank Code | S9 | Tank Age | 9 | Tank Installed Date | 11/14/2017 | Tank Material | Aboveground Tank | Piping Material | Flexible Plastic | Overfill Types |
| Tag Number | 5783 | Spill Test Date | | Piping Installed Date | 09/01/2017 | Tank Construction | | Piping Construction | Double Walled | AST |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | 04/10/2025 | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types |
| Product | Diesel | PLLD Test Date | 04/10/2025 | Tank/Piping CP Test Date | | Primary Tank Leak Detection | | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery |
| Capacity | 10000 | ATG Test Date | 04/23/2025 | Line Tightness Test Date | 11/14/2017 | Secondary Tank Leak Detection | | Secondary Pipe Detection | ELLD 0.2 | Energy Act |
| | | Overfill Test Date | | | | ATG Type | | | | No |

Facility Summary in Beaverhead County in the City of Wisdom

Location: PINTLER STATION
318 MT Hwy 43
Wisdom, MT 59761-0175 Beaverhead

System Facility ID:01-02173

Facility Code: 17490
Last Inspected On: 06/08/2023
Operating Permit Renewal Date: 07/30/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Chancy Campbell (406) 689-3239 ccfordman74@gmail.com

Operator Contact: Sheila Campbell scrappinann7874@gmail.com

Owner/Operator: Chancy Campbell (406) 689-3239 ccfordman74@gmail.com

Sheila Campbell, UST Class A Operator
Sheila Campbell, UST Class B Operator scrappinann7874@gmail.com
scrappinann7874@gmail.com

| | | | | | | | | | | | |
|--------------------|------------------|---------------------------|------------|---------------------------------|------------|--------------------------------------|--------------------------------------|---------------------------------|--------------|-----------------------|-------------------|
| Tank Code | 01 | Tank Age | 41 | Tank Installed Date | 03/10/1985 | Tank Material | Cathodically Protected Steel | Piping Material | Steel | Overfill Types | Flapper Valve |
| Tag Number | 3323 | Spill Test Date | 07/20/2023 | Piping Installed Date | | Tank Construction | Lined Interior/Impressed Current | Piping Construction | None | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Not Required | Piping Type | Safe Suction | CP Met Types | Impressed Current |
| Product | Gasoline | PLLD Test Date | | Tank/Piping CP Test Date | 06/08/2023 | Primary Tank Leak Detection | Statistical Inventory Reconciliation | Primary Pipe Detection | | Vapor Recovery | No |
| Capacity | 2000 | ATG Test Date | | Line Tightness Test Date | 05/03/2005 | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | No |
| | | Overfill Test Date | 07/20/2023 | | | ATG Type | | | | | |
| Tank Code | 02 | Tank Age | 41 | Tank Installed Date | 03/10/1985 | Tank Material | Cathodically Protected Steel | Piping Material | Steel | Overfill Types | Flapper Valve |
| Tag Number | 3324 | Spill Test Date | 06/08/2023 | Piping Installed Date | | Tank Construction | Lined Interior/Impressed Current | Piping Construction | None | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Not Required | Piping Type | Safe Suction | CP Met Types | Impressed Current |
| Product | Gasoline | PLLD Test Date | | Tank/Piping CP Test Date | 06/08/2023 | Primary Tank Leak Detection | Statistical Inventory Reconciliation | Primary Pipe Detection | | Vapor Recovery | No |
| Capacity | 1000 | ATG Test Date | | Line Tightness Test Date | 05/03/2005 | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | No |
| | | Overfill Test Date | 07/20/2023 | | | ATG Type | | | | | |

Facility Summary in Beaverhead County in the City of Wise River

Location: WISE RIVER MERCANTILE
65221 Hwy 43
Wise River, MT 59762 Beaverhead

System Facility ID:01-02080

Facility Code: 17487
Last Inspected On: 04/24/2025
Operating Permit Renewal Date: 10/13/2028

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: JimCon Inc (406) 832-3271

Operator Contact: Connie Holland (406) 832-3271 Connieholland49@gmail.com

Owner/Operator: JimCon Inc (406) 832-3271

Connie Holland, UST Class A Operator
Connie Holland, UST Class B Operator
Laura Delaney, UST Class B Global Operator

Connieholland49@gmail.com
Connieholland49@gmail.com

| | | | | | | | | | | | |
|-------------|------------------|--------------------|------------|--------------------------|------------|-------------------------------|-------------------------------|--------------------------|-------------------------------|----------------|----------------|
| Tank Code | 03 | Tank Age | 28 | Tank Installed Date | 06/01/1998 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | Flapper Valve |
| Tag Number | 1224 | Spill Test Date | 05/21/2024 | Piping Installed Date | | Tank Construction | | Piping Construction | None | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Not Required | Piping Type | Safe Suction | CP Met Types | Non-corrodible |
| Product | Gasoline | PLLD Test Date | | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | | Vapor Recovery | No |
| Capacity | 2000 | ATG Test Date | 04/24/2025 | Line Tightness Test Date | | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | No |
| | | Overfill Test Date | 11/09/2021 | | | ATG Type | Gilbarco/EMC Basic | | | | |