

Facility Summary in Big Horn County in the City of Crow Agency

Location: CROW NATION EXPRESS
US Hwy 212 & I-90
Crow Agency, MT 59022 Big Horn

Legacy ID:02-10867

Facility ID: 17827
Last Inspected On: 12/18/2020
Operating Permit Renewal Date: 01/06/2024

Owner Operator Contact: Crow Tribe of Indians;Michael Stockton;Stockton
Family Limited Partnership

4062456376;4066382400

Operator Contact: John Wilson

4066382400

Owner/Operator: Crow Tribe of Indians

John Wilson, UST Class A Operator

John Wilson, UST Class B Global Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
05	21	02/01/2000	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve
4174	No		Double-Walled	Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline		12/21/2011	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring;ELLD 0.2	No
10,000		08/02/2015	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
06	21	02/01/2000	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve
4175	No		Double-Walled	Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline		12/21/2011	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring;ELLD 0.2	No
6,000		08/02/2015	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
07	21	02/01/2000	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve
4176	No		Double-Walled	Double Walled	Yes

Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline		12/21/2011	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring; ELLD 0.2	No
4,000		08/02/2015	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
08	21	02/01/2000	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve
4177	No		Double-Walled	Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel		12/21/2011	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring; ELLD 0.2	No
6,000		08/02/2015	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
09	21	02/01/2000	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve
4178	No		Double-Walled	Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel		12/21/2011	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring; ELLD 0.2	No
4,000		08/02/2015	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No

Facility Summary in Big Horn County in the City of Crow Agency

Location: LITTLE BIG HORN CAMP
I-90 & US Hwy 212
Crow Agency, MT 59022 Big Horn

Legacy ID:02-08937

Facility ID: 17812
Last Inspected On: 06/16/2016
Operating Permit Renewal Date:

Owner Operator Contact: Pryor LLC;R Mische;Little Bighorn Camp

4066382232;4066382232;4066382870

Operator Contact: R Mische

4066382232

Owner/Operator: Pryor LLC

R Mische, UST Class A Operator

R Mische, UST Class B Global Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act

03	22	01/01/1999	Steel Clad	Fiberglass Reinforced Plastic	Flapper Valve
3919	No		Double-Walled	None	Yes
Temporarily Out of Use			Not Required	Safe Suction	Galvanic
Gasoline		09/13/2010	Continuous Interstitial Monitoring	Not Listed	No
8,000					No
04	22	01/01/1999	Steel Clad	Fiberglass Reinforced Plastic	Flapper Valve
3920	No		Double-Walled	None	Yes
Temporarily Out of Use			Not Required	Safe Suction	Galvanic
Gasoline		09/13/2010	Continuous Interstitial Monitoring	Not Listed	No
12,000					No

Facility Summary in Big Horn County in the City of Crow Agency

Location: TEEPEE SERVICE INC
6959 E Makawasha Ave
Crow Agency, MT 59022-0280 Big Horn

Legacy ID:02-07334

Facility ID: 17799
Last Inspected On: 01/09/2019
Operating Permit Renewal Date: 07/22/2022

Owner Operator Contact: N/A ZZZ - TBL_OWN : 1012;Teepee Service Inc;Teepee Service Inc

4066382269

Operator Contact: James Watt

Owner/Operator: Teepee Service Inc

James Watt, UST Class A Operator

James Watt, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
07	26	07/03/1995	Steel Clad	Flexible Plastic	High Level Alarm
2097	No		Double-Walled	Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	
Gasoline		04/16/2013	Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	Continuous Interstitial Monitoring;ELLD 0.1;ELLD 0.2	No
12,000			Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
08	26	07/03/1995	Steel Clad	Flexible Plastic	High Level Alarm
2098	No		Double-Walled	Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	
Gasoline		04/16/2013	Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	Continuous Interstitial Monitoring;ELLD 0.1;ELLD 0.2	No
8,000			Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No

Facility Summary in Big Horn County in the City of Fort Smith

Location: BIGHORN CANYON MAINTENANCE FACILITY
 5th Ave B
 Fort Smith, MT 59035 Big Horn

Legacy ID:02-09815

Facility ID: 17820
Last Inspected On: 03/10/2021
Operating Permit Renewal Date: 03/21/2024

Owner Operator Contact: National Park Service Yellowtail

4066663311

Operator Contact: Jesse Macklin;Kelly Peacock;Lyndon Driftwood;William Snell **4066663310;4066663312**

Owner/Operator: National Park Service Yellowtail

- Jesse Macklin, UST Class A Operator
- Jesse Macklin, UST Class B Global Operator
- Jesse Macklin, UST Class B Operator
- Kelly Peacock, UST Class A Operator
- Kelly Peacock, UST Class B Operator
- Lyndon Driftwood, UST Class A Operator
- Lyndon Driftwood, UST Class B Global Operator
- Norman Griffin, UST Class B Operator
- Roger Watson, UST Class B Global Operator
- William Snell, UST Class A Operator
- William Snell, UST Class B Global Operator
- William Snell, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
05	33	01/01/1988	Cathodically Protected Steel	Fiberglass	Ball Float Valve;High Level Alarm
1745	No	10/16/2017	Double-Walled	Double Walled	Yes
Currently in Use		10/16/2017	Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		11/05/2015	Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	Continuous Interstitial Monitoring;MLLD Line Tightness Testing	No
2,000		10/19/2017	Veeder Root/TLS-300		No
06	33	01/01/1988	Cathodically Protected Steel	Fiberglass	Ball Float Valve;High Level Alarm
1746	No	10/16/2017	Double-Walled	Double Walled	Yes

Currently in Use	10/16/2017	Mechanical Line Leak Detector	Pressurized	Galvanic
Diesel	11/05/2015	Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	Continuous Interstitial Monitoring;MLLD Line Tightness Testing	No
2,000	10/19/2017	Veeder Root/TLS-300		No

Facility Summary in Big Horn County in the City of Fort Smith

Location: OK A BEH MARINA
5 Ave B
Fort Smith, MT 59035 Big Horn

Legacy ID:56-13877

Facility ID: 30554
Last Inspected On: 05/08/2021
Operating Permit Renewal Date: 05/11/2024

Owner Operator Contact: National Park Service Yellowtail **4066663311**

Operator Contact: Christian Fighter;Jaris Pretty Paint;Kelly Peacock;Marvin Stewart;Shawn Backbone;Tristan Stewart **4066835313**

Owner/Operator: National Park Service Yellowtail

- Christian Fighter, UST Class A Operator
- Christian Fighter, UST Class B Operator
- Jaris Pretty Paint, UST Class A Operator
- Kelly Peacock, UST Class A Operator
- Kelly Peacock, UST Class B Operator
- Marvin Stewart, UST Class A Operator
- Marvin Stewart, UST Class B Operator
- Shawn Backbone, UST Class A Operator
- Tristan Stewart, UST Class A Operator
- Tristan Stewart, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
07	31	05/14/1990	Cathodically Protected Steel	Flexible Plastic	Flapper Valve
1747	No	06/22/2016	Double-Walled	Double Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		11/05/2015	Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	Continuous Interstitial Monitoring;MLLD Line Tightness Testing	No
2,000		05/29/2016	Gilbarco-Veeder Root/TLS- 300;Veeder Root/TLS-300		No

Facility Summary in Big Horn County in the City of Fort Smith

Location: YELLOWTAIL MARKET
Park Dale Ct
Fort Smith, MT 59035 Big Horn

Legacy ID:02-05862

Facility ID: 17785
Last Inspected On: 07/08/2021
Operating Permit Renewal Date: 10/20/2024

Owner Operator Contact: Steve Stoltz;Yellowtail Market;Terri Stoltz;Yellowtail Market **4066662333**

Operator Contact: John Wilson **4066382400**

Owner/Operator: Crow Tribe of Indians

John Wilson, UST Class A Operator

John Wilson, UST Class B Global Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
03	23	03/01/1998	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve
1210	No			None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		04/27/2018	Automatic Tank Gauging 0.2	ELLD 0.1;ELLD 0.2	No
8,000		03/05/2018	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
04	23	03/01/1998	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve
1211	No			None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		04/27/2018	Automatic Tank Gauging 0.2	ELLD 0.1;ELLD 0.2	No
8,000		03/05/2018	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No

Facility Summary in Big Horn County in the City of Garryowen

Location: GARRYOWEN CONOCO
200 Town Hall
Garryowen, MT 59031 Big Horn

Legacy ID:02-03284

Facility ID: 17761
Last Inspected On: 09/03/2021
Operating Permit Renewal Date: 10/25/2021

Owner Operator Contact: Chris Kortland;Historical Land Preservation Co

Operator Contact: Chris Kortlander **4066794444**

Owner/Operator: Neda LLC

Chris Kortlander, UST Class A Operator
 Petra Pretty On Top, UST Class B Global Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
01	25	06/21/1996	Steel Clad	Flexible Plastic	Flapper Valve
3392	No		Double-Walled	Secondary Containment Chase	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		07/29/2008	Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	Continuous Interstitial Monitoring;ELLD 0.2;ELLD Line Tightness Testing	No
8,000		10/15/2018	Veeder Root/TLS-300		No
02	25	06/21/1996	Steel Clad	Flexible Plastic	Flapper Valve
3393	No		Double-Walled	Secondary Containment Chase	Yes
Currently in Use		06/11/2013	Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		07/29/2008	Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	Continuous Interstitial Monitoring;ELLD 0.2;ELLD Line Tightness Testing	No
12,000		10/15/2018	Veeder Root/TLS-300		No

Facility Summary in Big Horn County in the City of Hardin

Location: BAIRS TRUCK STOP HARDIN
 315 13th St W
 Hardin, MT 59034-1006 Big Horn

Legacy ID:02-05752

Facility ID: 17781
Last Inspected On: 01/09/2019
Operating Permit Renewal Date: 06/01/2022

Owner Operator Contact: Damon Borden;Alsaker Corp Spokane

5095341502

Operator Contact: Arthur Jemerigbe;Paul Dallas;Rocco Cooper;Sara Dibble

4066651237;4066909416

Owner/Operator: Hardin Truck Stop LLC

Arthur Jemerigbe, UST Class A Operator
 Arthur Jemerigbe, UST Class B Operator
 Lynn Peterson, UST Class B Operator

Paul Dallas, UST Class A Operator
 Paul Dallas, UST Class B Operator
 Rocco Cooper, UST Class A Operator
 Rocco Cooper, UST Class B Global Operator
 Sara Dibble, UST Class A Operator
 Sara Dibble, UST Class B Global Operator
 Sara Dibble, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
01	52	04/25/1969	Bare Steel	Fiberglass Reinforced Plastic	Flapper Valve
3894	No			None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Impressed Current
Diesel		12/14/2018	Statistical Inventory Reconciliation	Statistical Inventory Reconciliation	No
10,000		02/07/2013			No
03	42	04/26/1979	Bare Steel	Fiberglass Reinforced Plastic	Flapper Valve
3895	No			None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Impressed Current
Gasoline		12/14/2018	Statistical Inventory Reconciliation	Statistical Inventory Reconciliation	No
10,000		01/04/2013			No
04	52	04/25/1969	Bare Steel	Fiberglass Reinforced Plastic	Flapper Valve
3896	No			None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Impressed Current
Gasoline		12/14/2018	Statistical Inventory Reconciliation	Statistical Inventory Reconciliation	No
6,000		01/04/2013			No

Facility Summary in Big Horn County in the City of Hardin

Location: BIG HORN COUNTY COMMUNITY SERVICE FACILITY
809 N Custer Ave
Hardin, MT 59034-1311 Big Horn

Legacy ID:02-10287

Facility ID: 17825
Last Inspected On: 01/08/2021
Operating Permit Renewal Date: 01/17/2024

Owner Operator Contact: Big Horn County Health Dept;Candy Wells;Big Horn County Commissioners **4066658720**

Operator Contact: Craig Taft **4066658724**

Owner/Operator: Big Horn County Health Dept

Craig Taft, UST Class A Operator
Craig Taft, UST Class B Global Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
02	23	11/01/1998	Steel Clad	Flexible Plastic	Flapper Valve
443	No		Double-Walled	Double Walled	Yes
Currently in Use			Not Required	Safe Suction	Non-corrodible
Diesel		12/21/2011	Manual Interstitial Monitoring	Deferred;Manual Interstitial Monitoring	No
2,000					No

Facility Summary in Big Horn County in the City of Hardin

Location: DOLLIES CONVENIENCE STORE
804 3rd St W
Hardin, MT 59034-1606 Big Horn

Legacy ID:02-00061

Facility ID: 17730
Last Inspected On: 03/15/2019
Operating Permit Renewal Date: 06/17/2019

Owner Operator Contact: Robert Greer

Operator Contact: Chetan Patel;Megan Ashinhurst **6055171140**

Owner/Operator: Jagadish LLC

Owner/Operator: Susan Greer

Chetan Patel, UST Class A Operator
Chetan Patel, UST Class B Operator
Constance Weigand, UST Class B Operator

Corri Duncan, UST Class B Operator
Megan Ashinhurst, UST Class A Operator
Megan Ashinhurst, UST Class B Global Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
01	37	12/20/1984	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve
4463	No			None	Yes
Temporarily Out of Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		01/16/2015	Automatic Tank Gauging 0.1;Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	No
10,000		01/21/2015	Veeder Root/TLS-300		No
03	19	12/16/2002	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve
4773	No			None	Yes
Temporarily Out of Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		01/16/2015	Automatic Tank Gauging 0.1;Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	No
4,000		01/21/2015	Veeder Root/TLS-300		No

Facility Summary in Big Horn County in the City of Hardin

Location: GOOD 2 GO STORES LLC
1600 N Crawford Ave
Hardin, MT 59034 Big Horn

Legacy ID:02-00538

Facility ID: 17731
Last Inspected On: 08/02/2019
Operating Permit Renewal Date: 12/11/2022

Owner Operator Contact: Brad Hinze;Q and H Inc;Brad Hinze;WY MT Investment Company **3078992012;3078992012;3075277575**

Operator Contact: Brad Hinze;Kenneth Knight;Zack Shields **3078992012;7025753191**

Owner/Operator: #8 Hardin Montana Property LLC

Brad Hinze, UST Class A Operator
Brad Hinze, UST Class B Global Operator
Kenneth Knight, UST Class A Operator
Zack Shields, UST Class A Operator

Zack Shields, UST Class B Global Operator

Zack Shields, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
03	47	04/12/1974	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve
3789	No			Double Walled	Yes
Currently in Use		04/16/2010	Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline		08/28/2007	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring; ELLD 0.1; ELLD 0.2	No
6,000		07/31/2010	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
04	47	04/12/1974	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve
3790	No			Double Walled	Yes
Currently in Use		04/16/2010	Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline		08/08/2007	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring; ELLD 0.1; ELLD 0.2	No
6,000		07/31/2010	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
05	47	04/12/1974	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve
3791	No			Double Walled	Yes
Currently in Use		04/16/2010	Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel		08/28/2007	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring; ELLD 0.1; ELLD 0.2	No
6,000		07/31/2010	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
06	47	04/12/1974	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve
3792	No			Double Walled	Yes

Currently in Use	04/16/2010	Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline	09/07/2007	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring; ELLD 0.1; ELLD 0.2	No
6,000	07/31/2010	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No

Facility Summary in Big Horn County in the City of Hardin

Location: HARDIN C STORE
1223 N Crawford Ave
Hardin, MT 59034-1009 Big Horn

Legacy ID:02-13635

Facility ID: 17852
Last Inspected On: 08/20/2019
Operating Permit Renewal Date: 12/10/2022

Owner Operator Contact: Town and Country Supply Association

4066286314

Operator Contact:

Owner/Operator: Town and Country Supply Association

Cathy Culp, UST Class B Global Operator
Melanie Hale, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
01	26	07/01/1995	Cathodically Protected Steel	Flexible Plastic	High Level Alarm
927	No			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		09/06/2016	Automatic Tank Gauging 0.2	ELLD 0.1; ELLD 0.2	No
16,000		09/02/2010	Gilbarco/EMC Basic		No
02	26	07/01/1995	Cathodically Protected Steel	Flexible Plastic	High Level Alarm
928	No			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		09/06/2016	Automatic Tank Gauging 0.2	ELLD 0.1; ELLD 0.2	No
16,000		09/02/2010	Gilbarco/EMC Basic		No

03	26	07/01/1995	Cathodically Protected Steel	Flexible Plastic	High Level Alarm
929	No			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		09/06/2016	Automatic Tank Gauging 0.2	ELLD 0.1;ELLD 0.2	No
16,000		09/02/2010	Gilbarco/EMC Basic		No
04	26	07/01/1995	Cathodically Protected Steel	Flexible Plastic	High Level Alarm
930	No			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		09/06/2016	Automatic Tank Gauging 0.2	ELLD 0.1;ELLD 0.2	No
10,000		09/02/2010	Gilbarco/EMC Basic		No
05	26	07/01/1995	Cathodically Protected Steel	Flexible Plastic	High Level Alarm
931	No			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		09/06/2016	Automatic Tank Gauging 0.2	ELLD 0.1;ELLD 0.2	No
6,000		09/02/2010	Gilbarco/EMC Basic		No

Facility Summary in Big Horn County in the City of Hardin

Location: L and B LAST STOP
531 E Railway St
Hardin, MT 59034-1903 Big Horn

Legacy ID:02-05856

Facility ID: 17783
Last Inspected On: 10/12/2021
Operating Permit Renewal Date: 10/13/2024

Owner Operator Contact: Gary and Lynette VanDersloot;Lynette VanDersloot **4066653414**

Operator Contact: Lynette VanDersloot **4066653414**

Owner/Operator: Gary and Lynette VanDersloot

Lynette VanDersloot, UST Class A Operator
Lynette VanDersloot, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected

Status	Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types	
Product	Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery	
Capacity	Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act	
03	22	01/01/1999	Steel Clad	Fiberglass	Flapper Valve
3915	No		Double-Walled	None	Yes
Currently in Use			Not Required	Safe Suction	
Gasoline	05/29/2013		Manual Interstitial Monitoring	Deferred	No
4,000					No
04	22	01/01/1999	Steel Clad	Fiberglass	Flapper Valve
3916	No		Double-Walled	None	Yes
Currently in Use			Not Required	Safe Suction	
Gasoline	05/29/2013		Manual Interstitial Monitoring	Deferred	No
2,000					No

Facility Summary in Big Horn County in the City of Hardin

Location: LOVES TRAVEL STOP #679
1270 N State Hwy 47
Hardin, MT 59034 Big Horn

Legacy ID:60-15284

Facility ID: 30991
Last Inspected On: 11/11/2020
Operating Permit Renewal Date: 12/04/2023

Owner Operator Contact: Loves Travel Stops and Country Stores Inc

Operator Contact: Clayton Hahn;Ted Parrish

2816659425;6155809096

Owner/Operator: Loves Travel Stops and Country Stores Inc

Clayton Hahn, UST Class A Operator
Ted Parrish, UST Class A Operator
Ted Parrish, UST Class B Global Operator
Willie Berry, UST Class B Global Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status	Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types	
Product	Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery	

Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
01	4	05/27/2017	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm;Positive Shutoff
5658	No	06/05/2017	Double-Walled	Double Walled	Yes
Currently in Use		10/01/2016	Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Continuous Interstitial Monitoring	Continuous Interstitial Monitoring	No
20,000			Incon/TS-5000 EVO		Yes
02	4	05/27/2017	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm;Positive Shutoff
5659	No	06/05/2017	Double-Walled	Double Walled	Yes
Currently in Use		10/01/2016	Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Continuous Interstitial Monitoring	Continuous Interstitial Monitoring	No
12,000			Incon/TS-5000 EVO		Yes
03	4	05/27/2017	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm;Positive Shutoff
5660	No	06/05/2017	Double-Walled	Double Walled	Yes
Currently in Use		10/01/2016	Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Continuous Interstitial Monitoring	Continuous Interstitial Monitoring	No
8,000			Incon/TS-5000 EVO		Yes
04	4	05/27/2017	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm;Positive Shutoff
5661	No	06/05/2017	Double-Walled	Double Walled	Yes
Currently in Use		10/01/2016	Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel			Continuous Interstitial Monitoring	Continuous Interstitial Monitoring	No
30,000			Incon/TS-5000 EVO		Yes
05	4	05/27/2017	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm;Positive Shutoff
5662	No	06/05/2017	Double-Walled	Double Walled	Yes

Currently in Use		10/01/2016	Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel			Continuous Interstitial Monitoring	Continuous Interstitial Monitoring	No
30,000			Incon/TS-5000 EVO		Yes
06	4	05/27/2017	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm;Positive Shutoff
5663	No	06/05/2017	Double-Walled	Double Walled	Yes
Currently in Use		10/01/2016	Electronic Line Leak Detector	Pressurized	Non-corrodible
Biodiesel, <=B20			Continuous Interstitial Monitoring	Continuous Interstitial Monitoring	No
20,000			Incon/TS-5000 EVO		Yes

Facility Summary in Big Horn County in the City of Hardin

Location: MATOVICH OIL CO INC
900 4th St W
Hardin, MT 59034 Big Horn

Legacy ID:02-13423

Facility ID: 17850
Last Inspected On: 10/15/2020
Operating Permit Renewal Date: 03/05/2024

Owner Operator Contact: Jon Matovich;Matovich Oil Co Inc;Matovich Oil Co Inc **4066651400;4066651400;4066651400**

Operator Contact: Jon Matovich **4066651400**

Owner/Operator: Matovich Oil Co Inc

Jon Matovich, UST Class A Operator
Jon Matovich, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
01	27	05/24/1994	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
1580	No			None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		11/09/2017	Automatic Tank Gauging 0.2	ELLD 0.1;ELLD 0.2	No
2,000		09/18/2017	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No

02	27	05/24/1994	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
1581	No			None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		11/09/2017	Automatic Tank Gauging 0.2	ELLD 0.1;ELLD 0.2	No
2,000		09/18/2017	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
03	27	05/24/1994	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
1582	No			None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		11/09/2017	Automatic Tank Gauging 0.2	ELLD 0.1;ELLD 0.2	No
4,000		08/31/2017	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
04	27	05/24/1994	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
1583	No			None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		11/09/2017	Automatic Tank Gauging 0.2	ELLD 0.1;ELLD 0.2	No
4,000		08/31/2017	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No

Facility Summary in Big Horn County in the City of Hardin

Location: TOWN AND COUNTRY SUPPLY #48
225 W Railroad St
Hardin, MT 59034 Big Horn

Legacy ID:02-01403

Facility ID: 17744
Last Inspected On: 08/20/2019
Operating Permit Renewal Date: 12/10/2022

Owner Operator Contact: Town and Country Supply Association

4066286314

Operator Contact: Leonard Zier;Steven Shelton

4063200055

Owner/Operator: Town and Country Supply Association

Connie Roundtree, UST Class B Global Operator
Leonard Zier, UST Class A Operator
Steven Shelton, UST Class A Operator
Steven Shelton, UST Class B Global Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
-----------	-----	-----------	----------------------------	-----------------	----------------

Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
S6	31	06/01/1990	Bare Steel	Fiberglass Reinforced Plastic	
923	Yes			None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	
Gasoline			Deferred	MLLD Line Tightness Testing	No
6,000		08/18/2016			No
S7	31	06/01/1990	Bare Steel	Fiberglass Reinforced Plastic	
924	Yes			None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	
Diesel			Deferred	MLLD Line Tightness Testing	No
6,000		08/18/2016			No
S8	31	06/01/1990	Bare Steel	Fiberglass Reinforced Plastic	
925	Yes			None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	
Gasoline			Deferred	MLLD Line Tightness Testing	No
6,000		08/18/2016			No
S9	31	06/01/1990	Bare Steel	Fiberglass Reinforced Plastic	
926	Yes			None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	
Diesel			Deferred	MLLD Line Tightness Testing	No
6,000		08/18/2016			No

Facility Summary in Big Horn County in the City of Hardin

Location: TOWN PUMP INC HARDIN
1010 N Crawford Ave
Hardin, MT 59034-1217 Big Horn

Legacy ID:02-08703

Facility ID: 17811
Last Inspected On: 06/07/2021
Operating Permit Renewal Date: 09/08/2024

Owner Operator Contact: Don Edmisten;Town Pump Inc Hardin PTRCB
1221;Town Pump Inc Hardin Org 22334

4064976700;4064976948

Operator Contact: Trent Biggers

Owner/Operator: Hardin 1 Town Pump LLC

Trent Biggers, UST Class A Operator

Trent Biggers, UST Class B Global Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
01	37	10/01/1984	Cathodically Protected Steel	Flexible Plastic	Flapper Valve
2377	No			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		11/20/2014	Approved Remote Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
12,000			Gilbarco-Veeder Root/TLS-350		No
02	37	10/01/1984	Cathodically Protected Steel	Flexible Plastic	Flapper Valve
2378	No			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		11/20/2014	Approved Remote Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
12,000			Gilbarco-Veeder Root/TLS-350		No
03	37	10/01/1984	Cathodically Protected Steel	Flexible Plastic	Flapper Valve

2379	No			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Diesel		11/20/2014	Approved Remote Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
12,000			Gilbarco-Veeder Root/TLS-350		No
04	40	04/14/1981	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve
2380	No		Lined Interior/Impressed Current	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Diesel		11/20/2014	Approved Remote Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Statistical Inventory Reconciliation	No
10,000			Gilbarco-Veeder Root/TLS-350		No
05	44	01/01/1977	Cathodically Protected Steel	Steel	Flapper Valve
2381	No		Lined Interior/Impressed Current	Single Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		11/20/2014	Approved Remote Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Statistical Inventory Reconciliation	No
6,000			Gilbarco-Veeder Root/TLS-350		No
06	21	05/01/2000	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4362	No		Double-Walled	Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel		12/14/2009	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
10,000			Gilbarco-Veeder Root/TLS-350		No
07	21	05/01/2000	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve

4363	No		Double-Walled	Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel		12/14/2009	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
5,000			Gilbarco-Veeder Root/TLS-350		No
08	21	05/01/2000	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve
4364	No		Double-Walled	Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel		12/14/2009	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
10,000			Gilbarco-Veeder Root/TLS-350		No

Facility Summary in Big Horn County in the City of Hardin

Location: WAGNER TRAVEL SHOPPE EXPRESS STOP
1424 N Crawford Ave
Hardin, MT 59034-1008 Big Horn

Legacy ID:02-04841

Facility ID: 17774
Last Inspected On: 10/13/2020
Operating Permit Renewal Date:

Owner Operator Contact: Dan Stockton;Stockton Oil Co Billings;Stockton Oil Co Billings

Operator Contact: Michael Stockton

4062456376

Owner/Operator: Stockton Oil Co Billings

Christopher Stockton, UST Class B Global Operator
Joseph Stockton, UST Class B Global Operator
Michael Stockton, UST Class A Operator
Michael Stockton, UST Class B Global Operator
Sue Nutgens, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
07	31	01/01/1990	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve;Flapper Valve

2231	No			None	Yes
Temporarily Out of Use			Mechanical Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Automatic Tank Gauging 0.1;Automatic Tank Gauging 0.2;Statistical Inventory Reconciliation	MLLD Line Tightness Testing	No
10,000		05/26/2011			No
08	31	01/01/1990	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve;Flapper Valve
2232	No			None	Yes
Temporarily Out of Use			Mechanical Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Automatic Tank Gauging 0.1;Automatic Tank Gauging 0.2;Statistical Inventory Reconciliation	MLLD Line Tightness Testing	No
10,000		05/26/2011			No
09	31	01/01/1990	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve;Flapper Valve
2233	No			None	Yes
Temporarily Out of Use			Mechanical Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Automatic Tank Gauging 0.1;Automatic Tank Gauging 0.2;Statistical Inventory Reconciliation	MLLD Line Tightness Testing	No
6,000		05/26/2011			No
S4	42	04/03/1979	Bare Steel	Fiberglass Reinforced Plastic	
2234	Yes			None	Yes
Temporarily Out of Use			Mechanical Line Leak Detector	Pressurized	
Diesel			Deferred	MLLD Line Tightness Testing	No
14,000		05/26/2011			No
S5	42	04/03/1979	Bare Steel	Fiberglass Reinforced Plastic	

2235	Yes			None	Yes
Temporarily Out of Use			Mechanical Line Leak Detector	Pressurized	
Diesel			Deferred	MLLD Line Tightness Testing	No
14,000		05/26/2011			No
S6	42	04/03/1979	Bare Steel	Fiberglass Reinforced Plastic	
2236	Yes			None	Yes
Temporarily Out of Use			Mechanical Line Leak Detector	Pressurized	
Diesel			Deferred	MLLD Line Tightness Testing	No
14,000		05/26/2011			No

Facility Summary in Big Horn County in the City of Lodge Grass

Location: FARMERS UNION OIL CO LODGE GRASS
 US Hwy 87
 Lodge Grass, MT 59050-0560 Big Horn

Legacy ID:02-09976

Facility ID: 17822
Last Inspected On: 03/03/2021
Operating Permit Renewal Date: 07/20/2024

Owner Operator Contact: Farmers Union Oil Co Lodge Grass;Roy Neal;Farmers Union Oil Co Lodge Grass **4066382505**

Operator Contact: Debra Edwards;Farmers Union Oil Co Lodge Grass

Owner/Operator: Farmers Union Oil Co Lodge Grass

- Alvin Edwards, UST Class B Operator
- Darin BigMedicine, UST Class B Operator
- Debra Edwards, UST Class A Operator
- Debra Edwards, UST Class B Operator
- Lorene Flatmouth, UST Class B Operator
- Merla Mullenberg, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act

09	23	12/01/1998	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve
----	----	------------	------------------------------	-------------------------------	---------------

3603	No			None	Yes
Currently in Use		05/09/2007	Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		02/12/2018	Automatic Tank Gauging 0.2	ELLD 0.1;ELLD 0.2	No
10,000		10/28/2017	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
10	23	12/01/1998	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve
3604	No			None	Yes
Currently in Use		05/09/2007	Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		02/12/2018	Automatic Tank Gauging 0.2	ELLD 0.1;ELLD 0.2	No
4,000		10/30/2017	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
11	23	12/01/1998	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve
3605	No			None	Yes
Currently in Use		05/09/2007	Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		02/12/2018	Automatic Tank Gauging 0.2	ELLD 0.1;ELLD 0.2	No
4,000		10/28/2017	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No

Facility Summary in Big Horn County in the City of Lodge Grass

Location: LODGE GRASS SCHOOL DIST 27
124 N George St
Lodge Grass, MT 59050 Big Horn

Legacy ID:02-10772

Facility ID: 17826
Last Inspected On: 11/19/2020
Operating Permit Renewal Date: 11/19/2020

Owner Operator Contact: School Dist 27 Lodge Grass

4066392304

Operator Contact: Leroy Wallace

Owner/Operator: School Dist 27 Lodge Grass

Donald Gardner, UST Class B Global Operator
Leroy Wallace, UST Class A Operator
Leroy Wallace, UST Class B Operator
Steve Amyotte, UST Class B Global Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
02	36	04/04/1985	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve
4361	No			Double Walled	Yes
Temporarily Out of Use		10/20/2006	Not Required	Safe Suction	Non-corrodible
Diesel		10/17/2011	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring;Deferred	No
8,000			Veeder Root/TLS-300		No

Facility Summary in Big Horn County in the City of Lodge Grass

Location: OUR LADY OF LORETTO CHURCH
Harding Ave & Helen St
Lodge Grass, MT 59050 Big Horn

Legacy ID:02-09970

Facility ID: 17821
Last Inspected On: 11/19/2020
Operating Permit Renewal Date: 02/11/2024

Owner Operator Contact: Our Lady of Loretto Church

3129950702

Operator Contact: Michael Dorn;Tien Dinh

Owner/Operator: Our Lady of Loretto Church

Michael Dorn, UST Class A Operator
Michael Dorn, UST Class B Operator
Tien Dinh, UST Class A Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
S2	31	07/23/1990	Cathodically Protected Steel	Copper	High Level Alarm
1778	No			PVC	Yes
Currently in Use			Not Required	U.S. Suction	Galvanic
Heating Oil		11/22/2017	Automatic Tank Gauging 0.2	3-Year Line Tightness Test	No
3,000		11/22/2017	Gilbarco/EMC Basic		No

Facility Summary in Big Horn County in the City of Pryor

Location: PLENTY COUPS HIGH SCHOOL
1 High School Ln
Pryor, MT 59066-0229 Big Horn

Legacy ID:02-01131

Facility ID: 17735
Last Inspected On: 03/19/2021
Operating Permit Renewal Date: 08/26/2024

Owner Operator Contact: Plenty Coups High School

4062597329

Operator Contact: Craig Cliff;Plenty Coups High School

4062597329

Owner/Operator: Plenty Coups High School

Craig Cliff, UST Class A Operator

Craig Cliff, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
05	23	06/01/1998	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve
1824	No			None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic

Gasoline	04/25/2018	Automatic Tank Gauging 0.2	Deferred	No	
1,000		Veeder Root/TLS-300		No	
06	23	06/01/1998	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve
1825	No		None	Yes	
Currently in Use		Not Required	Safe Suction	Galvanic	
Diesel	04/25/2018	Automatic Tank Gauging 0.2	Deferred	No	
2,000		Veeder Root/TLS-300		No	

Facility Summary in Big Horn County in the City of Pryor

Location: PRYOR SELF SERVICE
704 Mak Pua Ave
Pryor, MT 59066 Big Horn

Legacy ID:02-10164

Facility ID: 17823
Last Inspected On: 03/12/2020
Operating Permit Renewal Date: 05/16/2023

Owner Operator Contact: William Hoffman

Operator Contact: William Hoffman

Owner/Operator: William Hoffman

William Hoffman, UST Class A Operator
William Hoffman, UST Class B Global Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
03	23	10/01/1998	Steel Clad	Flexible Plastic	Flapper Valve
1389	No		Double-Walled	None	Yes
Currently in Use			Not Required	Safe Suction	Non-corrodible
Gasoline	02/04/2011	Manual Interstitial Monitoring	Deferred	No	
2,000				No	

Facility Summary in Big Horn County in the City of Pryor

Location: SAINT CHARLES MISSION
29 Pryor Gap Rd
Pryor, MT 59066 Big Horn

Legacy ID:56-04505

Facility ID: 29917
Last Inspected On: 06/17/2021
Operating Permit Renewal Date: 10/09/2024

Owner Operator Contact: St Labre Indian School

4067844500

Operator Contact: Dana Davis;Leney Mcnac

Owner/Operator: St Labre Indian School

Dana Davis, UST Class A Operator
Dana Davis, UST Class B Global Operator
Leney Mcnac, UST Class A Operator
Leney Mcnac, UST Class B Global Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
02	31	08/20/1990	Cathodically Protected Steel	Steel	Flapper Valve
1958	No			None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Gasoline		09/24/2018	Automatic Tank Gauging 0.2	Deferred	No
1,000			Gilbarco/EMC Basic		No

Facility Summary in Big Horn County in the City of Saint Xavier

Location: PRETTY EAGLE SCHOOL
1 mi W of St Xavier
Saint Xavier, MT 59075-0257 Big Horn

Legacy ID:02-04504

Facility ID: 17768
Last Inspected On: 06/17/2021
Operating Permit Renewal Date: 10/09/2024

Owner Operator Contact:

4067844500

Operator Contact: Dana Davis;Leney Mcnac

Owner/Operator: St Labre Indian School

Dana Davis, UST Class A Operator
Dana Davis, UST Class B Global Operator
Leney Mcnac, UST Class A Operator
Leney Mcnac, UST Class B Global Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
03	31	04/01/1990	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve
1956	No			None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Gasoline		09/21/2018	Automatic Tank Gauging 0.2	Not Listed	No
1,000			Gilbarco-Veeder Root/TLS-350		No
S4	31	04/01/1990	Cathodically Protected Steel	Flexible Plastic	Flapper Valve
3672	No			Double Walled	Yes
Temporarily Out of Use			Continuous Interstitial Monitoring	U.S. Suction	Galvanic
Heating Oil		09/21/2018	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring;MLLD Line Tightness Testing	No
10,000		11/05/2013	Gilbarco-Veeder Root/TLS-350		No

Facility Summary in Big Horn County in the City of Wyola

Location: WYOLA ELEMENTARY SCHOOL
1 Mondell Ave
Wyola, MT 59089 Big Horn

Legacy ID:02-13762

Facility ID: 17853
Last Inspected On: 06/06/2019
Operating Permit Renewal Date: 07/12/2022

Owner Operator Contact: School Dist 29 Wyola

4063432722

Operator Contact: Bradford Crooked Arm

Owner/Operator: School Dist 29 Wyola

Bradford Crooked Arm, UST Class A Operator
Bradford Crooked Arm, UST Class B Global Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types

Product	Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery	
Capacity	Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act	
02	22	07/01/1999	Cathodically Protected Steel	Steel	Flapper Valve
4370	No			Double Walled	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Diesel	06/14/2016		Automatic Tank Gauging 0.2	Deferred	No
1,000			Veeder Root/TLS-300		No