

Facility Summary in Big Horn County in the City of Crow Agency

Location: CROW NATION EXPRESS  
US Hwy 212 & I-90  
Crow Agency, MT 59022 Big Horn

System Facility ID:02-10867

Facility Code: 17827  
Last Inspected On: 12/19/2023  
Operating Permit Renewal Date: 01/06/2024

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Becky Wilson;Crow Tribe of Indians4066382059;4066796339

Operator Contact: John Wilson4066382400

Owner/Operator: Becky Wilson

Owner/Operator: Crow Tribe of Indians

John Wilson, UST Class A Operator  
John Wilson, UST Class B Global Operator

Tank Code	05	Tank Age	24	Tank Installed Date	02/01/2000	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	4174	Spill Test Date	12/18/2020	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	12/21/2011	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	10000	ATG Test Date		Line Tightness Test Date	08/02/2015	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	12/18/2020			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	06	Tank Age	24	Tank Installed Date	02/01/2000	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	4175	Spill Test Date	12/18/2020	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	12/21/2011	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	6000	ATG Test Date		Line Tightness Test Date	08/02/2015	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No

		Overfill Test Date	12/18/2020			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	07	Tank Age	24	Tank Installed Date	02/01/2000	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	4176	Spill Test Date	12/18/2020	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	12/21/2011	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	4000	ATG Test Date		Line Tightness Test Date	08/02/2015	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	12/18/2020			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	08	Tank Age	24	Tank Installed Date	02/01/2000	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	4177	Spill Test Date	12/18/2020	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	12/21/2011	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	6000	ATG Test Date		Line Tightness Test Date	08/02/2015	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	12/18/2020			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	09	Tank Age	24	Tank Installed Date	02/01/2000	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	4178	Spill Test Date	12/18/2020	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	12/21/2011	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	4000	ATG Test Date		Line Tightness Test Date	08/02/2015	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	12/18/2020			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Big Horn County in the City of Crow Agency

Location: TEEPEE SERVICE INC  
6959 E Makawasha Ave  
Crow Agency, MT 59022-0280 Big Horn

System Facility ID:02-07334

Facility Code: 17799  
Last Inspected On: 05/09/2022  
Operating Permit Renewal Date: 07/22/2025

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Teepee Service Inc4066382269

Operator Contact: James Watt

Owner/Operator: Teepee Service Inc

James Watt, UST Class A Operator

James Watt, UST Class B Operator

Tank Code	07	Tank Age	29	Tank Installed Date	07/03/1995	Tank Material	Steel Clad	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	2097	Spill Test Date	05/09/2022	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	05/09/2022	Tank/Piping CP Test Date	04/16/2013	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	12000	ATG Test Date	05/09/2022	Line Tightness Test Date	03/06/2022	Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	05/09/2022			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	08	Tank Age	29	Tank Installed Date	07/03/1995	Tank Material	Steel Clad	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	2098	Spill Test Date	05/09/2022	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	05/09/2022	Tank/Piping CP Test Date	04/16/2013	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	8000	ATG Test Date	05/09/2022	Line Tightness Test Date	02/18/2022	Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	05/09/2022			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Big Horn County in the City of Fort Smith

Location: BIGHORN CANYON MAINTENANCE FACILITY (NPS)  
5th Ave B  
Fort Smith, MT 59035 Big Horn

System Facility ID:02-09815

Facility Code: 17820  
Last Inspected On: 03/10/2021  
Operating Permit Renewal Date: 03/21/2024

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: National Park Service Yellowtail

Operator Contact: Jesse Macklin;Kelly Peacock;Lyndon Driftwood;William Snell 4066663310;4066663312

Owner/Operator: National Park Service Yellowtail

- Jesse Macklin, UST Class A Operator
- Jesse Macklin, UST Class B Global Operator
- Jesse Macklin, UST Class B Operator
- Kelly Peacock, UST Class A Operator
- Kelly Peacock, UST Class B Operator
- Lyndon Driftwood, UST Class A Operator
- Lyndon Driftwood, UST Class B Global Operator
- Norman Griffin, UST Class B Operator
- Roger Watson, UST Class B Global Operator
- William Snell, UST Class A Operator
- William Snell, UST Class B Global Operator
- William Snell, UST Class B Operator

Tank Code	05	Tank Age	36	Tank Installed Date	01/01/1988	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass	Overfill Types	Ball Float Valve;High Level Alarm
Tag Number	1745	Spill Test Date	06/15/2023	Piping Installed Date	10/16/2017	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	03/10/2021	Sump Tightness Test Date	10/16/2017	Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	07/26/2019	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	2000	ATG Test Date		Line Tightness Test Date	03/10/2021	Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	MLLD Line Tightness Testing	Energy Act	No
		Overfill Test Date	06/15/2023			ATG Type	Veeder Root/TLS-300				

Tank Code	06	Tank Age	36	Tank Installed Date	01/01/1988	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass	Overfill Types	Ball Float Valve;High Level Alarm
Tag Number	1746	Spill Test Date	06/15/2023	Piping Installed Date	10/16/2017	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	03/10/2021	Sump Tightness Test Date	10/16/2017	Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	07/26/2019	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	2000	ATG Test Date		Line Tightness Test Date	03/10/2021	Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	MLLD Line Tightness Testing	Energy Act	No
		Overfill Test Date	06/15/2023			ATG Type	Veeder Root/TLS-300				

Facility Summary in Big Horn County in the City of Fort Smith

Location: OK A BEH MARINA  
5 Ave B  
Fort Smith, MT 59035 Big Horn

System Facility ID:56-13877

Facility Code: 30554  
Last Inspected On: 05/08/2021  
Operating Permit Renewal Date: 05/26/2022

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: National Park Service Yellowtail

Operator Contact: Christian Fighter;Jaris Pretty Paint;Kelly Peacock;Marvin Stewart;Shawn Backbone;Tristan Stewart 4066835313

Owner/Operator: National Park Service Yellowtail

- Christian Fighter, UST Class A Operator
- Christian Fighter, UST Class B Operator
- Jaris Pretty Paint, UST Class A Operator
- Kelly Peacock, UST Class A Operator
- Kelly Peacock, UST Class B Operator
- Marvin Stewart, UST Class A Operator
- Marvin Stewart, UST Class B Operator
- Shawn Backbone, UST Class A Operator
- Tristan Stewart, UST Class A Operator
- Tristan Stewart, UST Class B Operator

Tank Code	07	Tank Age	34	Tank Installed Date	05/14/1990	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	1747	Spill Test Date	06/14/2023	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	06/02/2021	Sump Tightness Test Date	06/22/2016	Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	07/19/2020	Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	2000	ATG Test Date		Line Tightness Test Date	06/02/2021	Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-300;Veeder Root/TLS-300				

Facility Summary in Big Horn County in the City of Fort Smith

Location: YELLOWTAIL MARKET  
Park Dale Ct  
Fort Smith, MT 59035 Big Horn

System Facility ID:02-05862

Facility Code: 17785  
Last Inspected On: 07/08/2021  
Operating Permit Renewal Date: 10/20/2024

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Crow Tribe of Indians4066382059

Operator Contact: John Wilson4066382400

Owner/Operator: Crow Tribe of Indians

John Wilson, UST Class A Operator  
John Wilson, UST Class B Global Operator

Tank Code	03	Tank Age	26	Tank Installed Date	03/01/1998	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	1210	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date	07/08/2021	Tank/Piping CP Test Date	07/08/2021	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	8000	ATG Test Date		Line Tightness Test Date	03/04/2021	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	04	Tank Age	26	Tank Installed Date	03/01/1998	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	1211	Spill Test Date	08/19/2021	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date	07/08/2021	Tank/Piping CP Test Date	07/08/2021	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	8000	ATG Test Date		Line Tightness Test Date	03/04/2021	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Big Horn County in the City of Garryowen

Location: GARRYOWEN CONOCO  
200 Town Hall  
Garryowen, MT 59031 Big Horn

Facility Code: 17761  
Last Inspected On: 10/15/2021  
System Facility ID:02-03284  
Operating Permit Renewal Date: 10/25/2021

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Neda LLC 4066382020

Operator Contact: Chris Kortlander 4066794444

Owner/Operator: Neda LLC

Chris Kortlander, UST Class A Operator  
Petra Pretty On Top, UST Class B Global Operator

Tank Code	01	Tank Age	28	Tank Installed Date	06/21/1996	Tank Material	Steel Clad	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	3392	Spill Test Date		Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Secondary Containment Chase	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	07/29/2008	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	8000	ATG Test Date		Line Tightness Test Date	10/15/2018	Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date				ATG Type	Veeder Root/TLS-300				
Tank Code	02	Tank Age	28	Tank Installed Date	06/21/1996	Tank Material	Steel Clad	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	3393	Spill Test Date		Piping Installed Date	06/11/2013	Tank Construction	Double-Walled	Piping Construction	Secondary Containment Chase	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	07/29/2008	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	12000	ATG Test Date		Line Tightness Test Date	10/15/2018	Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date				ATG Type	Veeder Root/TLS-300				



Facility Summary in Big Horn County in the City of Hardin

Location: BIG HORN COUNTY COMMUNITY SERVICE FACILITY  
809 N Custer Ave  
Hardin, MT 59034-1311 Big Horn

System Facility ID:02-10287

Facility Code: 17825  
Last Inspected On: 01/08/2021  
Operating Permit Renewal Date: 01/17/2024

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Big Horn County Health Dept

Operator Contact: Craig Taft 4066658724

Owner/Operator: Big Horn County Health Dept

Craig Taft, UST Class A Operator  
Craig Taft, UST Class B Global Operator

Tank Code	02	Tank Age	26	Tank Installed Date	11/01/1998	Tank Material	Steel Clad	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	443	Spill Test Date		Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Permanently Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	12/21/2011	Primary Tank Leak Detection	Manual Interstitial Monitoring	Primary Pipe Detection		Vapor Recovery	No
Capacity	2000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					

Facility Summary in Big Horn County in the City of Hardin

Location: DOLLIES CONVENIENCE STORE  
804 3rd St W  
Hardin, MT 59034-1606 Big Horn

System Facility ID:02-00061

Facility Code: 17730  
Last Inspected On: 12/16/2022  
Operating Permit Renewal Date: 12/16/2025

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Jagadish LLC;Susan Greer 4066651424

Operator Contact: Chetan Patel;Megan Ashinhurst 6055171140

Owner/Operator: Jagadish LLC

Owner/Operator: Susan Greer

- Chetan Patel, UST Class A Operator
- Chetan Patel, UST Class B Operator
- Constance Weigand, UST Class B Operator
- Corri Duncan, UST Class B Operator
- Megan Ashinhurst, UST Class A Operator
- Megan Ashinhurst, UST Class B Global Operator

Tank Code	01	Tank Age	40	Tank Installed Date	12/20/1984	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	4463	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	Single Walled	AST	No
Tank Status	Temporarily Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	12/16/2022	Primary Tank Leak Detection	Automatic Tank Gauging 0.1;Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	10000	ATG Test Date		Line Tightness Test Date	01/21/2015	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type	Veeder Root/TLS-300				
Tank Code	03	Tank Age	22	Tank Installed Date	12/16/2002	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	4773	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Temporarily Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic

Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	12/16/2022	Primary Tank Leak Detection	Automatic Tank Gauging 0.1;Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	4000	ATG Test Date		Line Tightness Test Date	01/21/2015	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type	Veeder Root/TLS-300				

Facility Summary in Big Horn County in the City of Hardin

Location: FORMER BAIRS TRUCK STOP HARDIN  
315 13th St W  
Hardin, MT 59034-1006 Big Horn

System Facility ID:02-05752

Facility Code: 17781  
Last Inspected On: 03/09/2022  
Operating Permit Renewal Date: 06/01/2025

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Hardin 2 RE2 LLC4064976700

Operator Contact: Trent Biggers;Town Pump

Owner/Operator: Hardin 2 RE2 LLC

Trent Biggers, UST Class A Operator  
Trent Biggers, UST Class B Operator

Tank Code	01	Tank Age	55	Tank Installed Date	04/25/1969	Tank Material	Bare Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	3894	Spill Test Date	08/31/2020	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Temporarily Out of Use	MLLD Test Date	08/13/2018	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	03/09/2022	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	20000	ATG Test Date		Line Tightness Test Date	02/07/2013	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	08/31/2020			ATG Type					
Tank Code	03	Tank Age	45	Tank Installed Date	04/26/1979	Tank Material	Bare Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	3895	Spill Test Date	06/20/2022	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Temporarily Out of Use	MLLD Test Date	08/13/2018	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	03/09/2022	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	20000	ATG Test Date		Line Tightness Test Date	01/04/2013	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	06/20/2022			ATG Type					
Tank Code	04	Tank Age	55	Tank Installed Date	04/25/1969	Tank Material	Bare Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve

Tag Number	3896	Spill Test Date	08/31/2020	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Temporarily Out of Use	MLLD Test Date	08/13/2018	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	03/09/2022	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	12000	ATG Test Date		Line Tightness Test Date	01/04/2013	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	06/20/2022			ATG Type					

Facility Summary in Big Horn County in the City of Hardin

Location: GOOD 2 GO STORES LLC  
1600 N Crawford Ave  
Hardin, MT 59034 Big Horn

System Facility ID:02-00538

Facility Code: 17731  
Last Inspected On: 08/08/2022  
Operating Permit Renewal Date: 12/11/2025

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: #8 Hardin Montana Property LLC2085236582

Operator Contact: Amy Packard;Good 2 Go Stores LLC;Garry Wells;Good 2 Go Stores LLC;Jeanette Nette;Good 2 Go Stores LLC;Lisa Yates;Good 2 Go Stores LLC2084171590

Owner/Operator: #8 Hardin Montana Property LLC

Amy Packard, UST Class A Operator  
Amy Packard, UST Class B Operator  
Garry Wells, UST Class A Operator  
Garry Wells, UST Class B Operator  
Jeanette Nette, UST Class A Operator  
Jeanette Nette, UST Class B Operator  
Lisa Yates, UST Class A Operator  
Lisa Yates, UST Class B Operator

Tank Code	03	Tank Age	50	Tank Installed Date	04/12/1974	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	3789	Spill Test Date	08/08/2022	Piping Installed Date	04/16/2010	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	08/12/2020	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	05/09/2022	Tank/Piping CP Test Date	08/28/2007	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	6000	ATG Test Date	08/08/2022	Line Tightness Test Date	07/26/2022	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	10/24/2022			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	04	Tank Age	50	Tank Installed Date	04/12/1974	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	3790	Spill Test Date	08/08/2022	Piping Installed Date	04/16/2010	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	08/12/2020	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible

Product	Gasoline	PLLD Test Date	05/09/2022	Tank/Piping CP Test Date	08/08/2007	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	6000	ATG Test Date	08/08/2022	Line Tightness Test Date	04/24/2022	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	08/08/2022			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	05	Tank Age	50	Tank Installed Date	04/12/1974	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	3791	Spill Test Date	08/08/2022	Piping Installed Date	04/16/2010	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	08/12/2020	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	05/09/2022	Tank/Piping CP Test Date	08/28/2007	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	6000	ATG Test Date	08/08/2022	Line Tightness Test Date	03/08/2022	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	08/08/2022			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	06	Tank Age	50	Tank Installed Date	04/12/1974	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	3792	Spill Test Date	08/08/2022	Piping Installed Date	04/16/2010	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	08/12/2020	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	05/09/2022	Tank/Piping CP Test Date	09/07/2007	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	6000	ATG Test Date	08/08/2022	Line Tightness Test Date	07/26/2022	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	08/08/2022			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Big Horn County in the City of Hardin

Location: HARDIN C STORE  
1223 N Crawford Ave  
Hardin, MT 59034-1009 Big Horn

Facility Code: 17852  
Last Inspected On: 08/08/2022  
System Facility ID:02-13635  
Operating Permit Renewal Date: 12/10/2025

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Town and Country Supply Association 4066286314

Operator Contact: Wes Burley 4062561020

Owner/Operator: Town and Country Supply Association

Jennifer Reinhardt, UST Class B Global Operator  
Melanie Hale, UST Class B Operator  
Wes Burley, UST Class A Operator

Tank Code	01	Tank Age	29	Tank Installed Date	07/01/1995	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	927	Spill Test Date	08/08/2022	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date	08/08/2022	Tank/Piping CP Test Date	08/08/2022	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	16000	ATG Test Date	08/08/2022	Line Tightness Test Date	08/04/2022	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	08/08/2022			ATG Type	Gilbarco/EMC Basic				
Tank Code	02	Tank Age	29	Tank Installed Date	07/01/1995	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	928	Spill Test Date	08/08/2022	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date	08/08/2022	Tank/Piping CP Test Date	08/08/2022	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	16000	ATG Test Date	08/08/2022	Line Tightness Test Date	08/07/2022	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	08/08/2022			ATG Type	Gilbarco/EMC Basic				
Tank Code	03	Tank Age	29	Tank Installed Date	07/01/1995	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm



Tag Number	929	Spill Test Date	08/08/2022	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date	08/08/2022	Tank/Piping CP Test Date	08/08/2022	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	16000	ATG Test Date	08/08/2022	Line Tightness Test Date	07/30/2022	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	08/08/2022			ATG Type	Gilbarco/EMC Basic				
Tank Code	04	Tank Age	29	Tank Installed Date	07/01/1995	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	930	Spill Test Date	08/08/2022	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Diesel, Dyed	PLLD Test Date	08/08/2022	Tank/Piping CP Test Date	08/08/2022	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	10000	ATG Test Date	08/08/2022	Line Tightness Test Date	07/30/2022	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	08/08/2022			ATG Type	Gilbarco/EMC Basic				
Tank Code	05	Tank Age	29	Tank Installed Date	07/01/1995	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	931	Spill Test Date	08/08/2022	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date	08/08/2022	Tank/Piping CP Test Date	08/08/2022	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	6000	ATG Test Date	08/08/2022	Line Tightness Test Date	07/20/2022	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	08/08/2022			ATG Type	Gilbarco/EMC Basic				

Facility Summary in Big Horn County in the City of Hardin

Location: L and B LAST STOP  
531 E Railway St  
Hardin, MT 59034-1903 Big Horn

System Facility ID:02-05856

Facility Code: 17783  
Last Inspected On: 10/12/2021  
Operating Permit Renewal Date: 10/13/2024

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact:	Gary and Lynette VanDersloot	4066653414
Operator Contact:	Lynette VanDersloot	4066653414

Owner/Operator: Gary and Lynette VanDersloot

Lynette VanDersloot, UST Class A Operator  
Lynette VanDersloot, UST Class B Operator

Tank Code	03	Tank Age	25	Tank Installed Date	01/01/1999	Tank Material	Steel Clad	Piping Material	Fiberglass	Overfill Types	Flapper Valve
Tag Number	3915	Spill Test Date	04/25/2022	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	05/29/2013	Primary Tank Leak Detection	Manual Interstitial Monitoring	Primary Pipe Detection		Vapor Recovery	No
Capacity	4000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	04/25/2022			ATG Type					
Tank Code	04	Tank Age	25	Tank Installed Date	01/01/1999	Tank Material	Steel Clad	Piping Material	Fiberglass	Overfill Types	Flapper Valve
Tag Number	3916	Spill Test Date	04/25/2022	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	05/29/2013	Primary Tank Leak Detection	Manual Interstitial Monitoring	Primary Pipe Detection		Vapor Recovery	No
Capacity	2000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	04/25/2022			ATG Type					

Facility Summary in Big Horn County in the City of Hardin

Location: LOVES TRAVEL STOP #679  
1270 N State Hwy 47  
Hardin, MT 59034 Big Horn

Facility Code: 30991  
Last Inspected On: 06/30/2023  
System Facility ID:60-15284  
Operating Permit Renewal Date: 12/04/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Loves Travel Stops and Country Stores Inc2816559425

Operator Contact: Ted Parrish;Zach Moore6155809096

Owner/Operator: Loves Travel Stops and Country Stores Inc

Ted Parrish, UST Class A Operator  
Ted Parrish, UST Class B Global Operator  
Zach Moore, UST Class A Operator  
Zach Moore, UST Class B Global Operator

Tank Code	01	Tank Age	7	Tank Installed Date	05/27/2017	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm;Positive Shutoff
Tag Number	5658	Spill Test Date	08/08/2023	Piping Installed Date	10/01/2016	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	11/01/2020	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	20000	ATG Test Date	07/01/2023	Line Tightness Test Date	06/29/2023	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	Yes
		Overfill Test Date				ATG Type	Incon/TS-5000 EVO				
Tank Code	02	Tank Age	7	Tank Installed Date	05/27/2017	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm;Positive Shutoff
Tag Number	5659	Spill Test Date		Piping Installed Date	10/01/2016	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	11/01/2020	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	12000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	Yes

		Overfill Test Date				ATG Type	Incon/TS-5000 EVO				
Tank Code	03	Tank Age	7	Tank Installed Date	05/27/2017	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm;Positive Shutoff
Tag Number	5660	Spill Test Date		Piping Installed Date	10/01/2016	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	11/01/2020	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	8000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	Yes
		Overfill Test Date				ATG Type	Incon/TS-5000 EVO				
Tank Code	04	Tank Age	7	Tank Installed Date	05/27/2017	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm;Positive Shutoff
Tag Number	5661	Spill Test Date		Piping Installed Date	10/01/2016	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	11/01/2020	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	30000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	Yes
		Overfill Test Date				ATG Type	Incon/TS-5000 EVO				
Tank Code	05	Tank Age	7	Tank Installed Date	05/27/2017	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm;Positive Shutoff
Tag Number	5662	Spill Test Date		Piping Installed Date	10/01/2016	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	11/01/2020	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	30000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	Yes
		Overfill Test Date				ATG Type	Incon/TS-5000 EVO				
Tank Code	06	Tank Age	7	Tank Installed Date	05/27/2017	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm;Positive Shutoff

Tag Number	5663	Spill Test Date		Piping Installed Date	10/01/2016	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	11/01/2020	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Biodiesel, <=B20	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	20000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	Yes
		Overfill Test Date				ATG Type	Incon/TS-5000 EVO				
Tank Code	07	Tank Age	7	Tank Installed Date	05/27/2017	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	
Tag Number	5664	Spill Test Date		Piping Installed Date	10/01/2016	Tank Construction		Piping Construction		AST	No
Tank Status	Other	MLLD Test Date		Sump Tightness Test Date	06/05/2017	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	DEF (Not Regulated)	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	ELLD 0.2;ELLD Line Tightness Testing	Vapor Recovery	No
Capacity	20000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring;Not Listed	Energy Act	No
		Overfill Test Date				ATG Type					

Facility Summary in Big Horn County in the City of Hardin

Location: MATOVICH OIL CO INC  
900 4th St W  
Hardin, MT 59034 Big Horn

Facility Code: 17850  
Last Inspected On: 11/22/2023  
System Facility ID:02-13423  
Operating Permit Renewal Date: 03/05/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Matovich Oil Co Inc4066651400

Operator Contact: Jon Matovich4066651400

Owner/Operator: Matovich Oil Co Inc

Jon Matovich, UST Class A Operator  
Jon Matovich, UST Class B Operator

Tank Code	01	Tank Age	30	Tank Installed Date	05/24/1994	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	1580	Spill Test Date	11/22/2023	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date	11/22/2023	Tank/Piping CP Test Date	11/22/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	2000	ATG Test Date	11/22/2023	Line Tightness Test Date	09/24/2020	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	11/22/2023			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	02	Tank Age	30	Tank Installed Date	05/24/1994	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	1581	Spill Test Date	11/22/2023	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date	11/22/2023	Tank/Piping CP Test Date	11/22/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	2000	ATG Test Date	11/22/2023	Line Tightness Test Date	09/16/2020	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	11/22/2023			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	03	Tank Age	30	Tank Installed Date	05/24/1994	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm

Tag Number	1582	Spill Test Date	11/22/2023	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date	11/22/2023	Tank/Piping CP Test Date	11/22/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	4000	ATG Test Date	11/22/2023	Line Tightness Test Date	09/02/2020	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	11/22/2023			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	04	Tank Age	30	Tank Installed Date	05/24/1994	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	1583	Spill Test Date	11/22/2023	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date	11/22/2023	Tank/Piping CP Test Date	11/22/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	4000	ATG Test Date	11/22/2023	Line Tightness Test Date	09/26/2020	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	11/22/2023			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Big Horn County in the City of Hardin

Location: TOWN AND COUNTRY SUPPLY #48  
225 W Railroad St  
Hardin, MT 59034 Big Horn

System Facility ID:02-01403

Facility Code: 17744  
Last Inspected On: 08/29/2022  
Operating Permit Renewal Date: 12/10/2025

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Town and Country Supply Association4066286314

Operator Contact: Wes Burley;Town and Country Supply Association4062561020;4066286314

Owner/Operator: Town and Country Supply Association

Connie Roundtree, UST Class B Global Operator  
Jennifer Reinhardt, UST Class B Global Operator  
Wes Burley, UST Class A Operator

Tank Code	S6	Tank Age	34	Tank Installed Date	06/01/1990	Tank Material	Bare Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	
Tag Number	923	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	Yes
Tank Status	Currently in Use	MLLD Test Date	08/08/2022	Sump Tightness Test Date	08/08/2022	Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Diesel, Dyed	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Deferred	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	6000	ATG Test Date		Line Tightness Test Date	08/08/2022	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					
Tank Code	S7	Tank Age	34	Tank Installed Date	06/01/1990	Tank Material	Bare Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	
Tag Number	924	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	Yes
Tank Status	Currently in Use	MLLD Test Date	08/08/2022	Sump Tightness Test Date	08/08/2022	Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Deferred	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	6000	ATG Test Date		Line Tightness Test Date	08/08/2022	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					
Tank Code	S8	Tank Age	34	Tank Installed Date	06/01/1990	Tank Material	Bare Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	
Tag Number	925	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	Yes



Tank Status	Currently in Use	MLLD Test Date	08/08/2022	Sump Tightness Test Date	08/08/2022	Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Deferred	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	6000	ATG Test Date		Line Tightness Test Date	08/08/2022	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					
Tank Code	S9	Tank Age	34	Tank Installed Date	06/01/1990	Tank Material	Bare Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	
Tag Number	926	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	Yes
Tank Status	Temporarily Out of Use	MLLD Test Date	08/20/2019	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Deferred	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	6000	ATG Test Date		Line Tightness Test Date	08/20/2019	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					

Facility Summary in Big Horn County in the City of Hardin

Location: TOWN PUMP INC HARDIN  
1010 N Crawford Ave  
Hardin, MT 59034-1217 Big Horn

System Facility ID:02-08703

Facility Code: 17811  
Last Inspected On: 03/07/2024  
Operating Permit Renewal Date: 09/08/2024

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Hardin 1 Town Pump LLC4064976700

Operator Contact: Trent Biggers

Owner/Operator: Hardin 1 Town Pump LLC

Trent Biggers, UST Class A Operator  
Trent Biggers, UST Class B Global Operator

Tank Code	01	Tank Age	40	Tank Installed Date	10/01/1984	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	2377	Spill Test Date	06/07/2021	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date	07/20/2022	Tank/Piping CP Test Date	06/07/2021	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	12000	ATG Test Date	07/20/2022	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	02	Tank Age	40	Tank Installed Date	10/01/1984	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	2378	Spill Test Date	06/07/2021	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date	07/20/2022	Tank/Piping CP Test Date	06/07/2021	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	12000	ATG Test Date	07/20/2022	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-350				

Tank Code	03	Tank Age	40	Tank Installed Date	10/01/1984	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	2379	Spill Test Date	06/07/2021	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Diesel	PLLD Test Date	07/20/2022	Tank/Piping CP Test Date	06/07/2021	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	12000	ATG Test Date	07/20/2022	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	04	Tank Age	43	Tank Installed Date	04/14/1981	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	2380	Spill Test Date	08/18/2021	Piping Installed Date		Tank Construction	Lined Interior/Impressed Current	Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Diesel	PLLD Test Date	07/20/2022	Tank/Piping CP Test Date	06/07/2021	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	10000	ATG Test Date	07/20/2022	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	05	Tank Age	47	Tank Installed Date	01/01/1977	Tank Material	Cathodically Protected Steel	Piping Material	Steel	Overfill Types	Flapper Valve
Tag Number	2381	Spill Test Date	12/20/2023	Piping Installed Date		Tank Construction	Lined Interior/Impressed Current	Piping Construction	Single Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	08/05/2022	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date	07/20/2022	Tank/Piping CP Test Date	06/07/2021	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	6000	ATG Test Date	07/20/2022	Line Tightness Test Date	08/05/2022	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	06	Tank Age	24	Tank Installed Date	05/01/2000	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	4362	Spill Test Date	08/18/2021	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No

Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	07/20/2022	Tank/Piping CP Test Date	12/05/2018	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	10000	ATG Test Date	07/20/2022	Line Tightness Test Date		Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	07	Tank Age	24	Tank Installed Date	05/01/2000	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	4363	Spill Test Date	06/07/2021	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	07/20/2022	Tank/Piping CP Test Date	12/14/2009	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	5000	ATG Test Date	07/20/2022	Line Tightness Test Date		Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	08	Tank Age	24	Tank Installed Date	05/01/2000	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	4364	Spill Test Date	06/07/2021	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	07/20/2022	Tank/Piping CP Test Date	12/14/2009	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	10000	ATG Test Date	07/20/2022	Line Tightness Test Date		Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	08/18/2021			ATG Type	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Big Horn County in the City of Hardin

Location: WAGNER TRAVEL SHOPPE EXPRESS STOP  
1424 N Crawford Ave  
Hardin, MT 59034-1008 Big Horn

System Facility ID:02-04841

Facility Code: 17774  
Last Inspected On: 07/12/2023  
Operating Permit Renewal Date: 07/12/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Stockton Oil Co Billings 4062456376

Operator Contact:

Owner/Operator: Stockton Oil Co Billings

Christopher Stockton, UST Class B Global Operator  
Joseph Stockton, UST Class B Global Operator  
Sue Nutgens, UST Class B Operator

Tank Code	07	Tank Age	34	Tank Installed Date	01/01/1990	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve;Flapper Valve
Tag Number	2231	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Temporarily Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.1;Automatic Tank Gauging 0.2;Statistical Inventory Reconciliation	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	10000	ATG Test Date		Line Tightness Test Date	05/26/2011	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					
Tank Code	08	Tank Age	34	Tank Installed Date	01/01/1990	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve;Flapper Valve
Tag Number	2232	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Temporarily Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible

Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.1;Automatic Tank Gauging 0.2;Statistical Inventory Reconciliation	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	10000	ATG Test Date		Line Tightness Test Date	05/26/2011	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					
Tank Code	09	Tank Age	34	Tank Installed Date	01/01/1990	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve;Flapper Valve
Tag Number	2233	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Temporarily Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.1;Automatic Tank Gauging 0.2;Statistical Inventory Reconciliation	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	6000	ATG Test Date		Line Tightness Test Date	05/26/2011	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					
Tank Code	S4	Tank Age	45	Tank Installed Date	04/03/1979	Tank Material	Bare Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	
Tag Number	2234	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	Yes
Tank Status	Temporarily Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Deferred	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	14000	ATG Test Date		Line Tightness Test Date	05/26/2011	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					
Tank Code	S5	Tank Age	45	Tank Installed Date	04/03/1979	Tank Material	Bare Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	
Tag Number	2235	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	Yes
Tank Status	Temporarily Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Deferred	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	14000	ATG Test Date		Line Tightness Test Date	05/26/2011	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No

		Overfill Test Date				ATG Type					
Tank Code	S6	Tank Age	45	Tank Installed Date	04/03/1979	Tank Material	Bare Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	
Tag Number	2236	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	Yes
Tank Status	Temporarily Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Deferred	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	14000	ATG Test Date		Line Tightness Test Date	05/26/2011	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					

Facility Summary in Big Horn County in the City of Lodge Grass

Location: FARMERS UNION OIL CO LODGE GRASS  
US Hwy 87  
Lodge Grass, MT 59050-0560 Big Horn

System Facility ID:02-09976

Facility Code: 17822  
Last Inspected On: 03/02/2024  
Operating Permit Renewal Date: 07/20/2024

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact:	Farmers Union Oil Co Lodge Grass
Operator Contact:	Debra Edwards;Farmers Union Oil Co Lodge Grass

Owner/Operator: Farmers Union Oil Co Lodge Grass

Alvin Edwards, UST Class B Operator  
Darin BigMedicine, UST Class B Operator  
Debra Edwards, UST Class A Operator  
Debra Edwards, UST Class B Operator  
Lorene Flatmouth, UST Class B Operator  
Merla Mullenberg, UST Class B Operator

Tank Code	09	Tank Age	26	Tank Installed Date	12/01/1998	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	3603	Spill Test Date		Piping Installed Date	05/09/2007	Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date	05/11/2020	Tank/Piping CP Test Date	02/03/2021	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	10000	ATG Test Date		Line Tightness Test Date	03/03/2021	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	10	Tank Age	26	Tank Installed Date	12/01/1998	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	3604	Spill Test Date	10/03/2019	Piping Installed Date	05/09/2007	Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date	05/11/2020	Tank/Piping CP Test Date	02/03/2021	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	4000	ATG Test Date		Line Tightness Test Date	03/03/2021	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No



		Overfill Test Date	10/03/2019			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	11	Tank Age	26	Tank Installed Date	12/01/1998	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	3605	Spill Test Date	10/03/2019	Piping Installed Date	05/09/2007	Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date	05/11/2020	Tank/Piping CP Test Date	02/03/2021	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	4000	ATG Test Date		Line Tightness Test Date	03/03/2021	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	10/03/2019			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Big Horn County in the City of Lodge Grass

Location: LODGE GRASS SCHOOL DIST 27  
124 N George St  
Lodge Grass, MT 59050 Big Horn

System Facility ID:02-10772

Facility Code: 17826  
Last Inspected On: 03/15/2024  
Operating Permit Renewal Date: 11/19/2023

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact:	School Dist 27 Lodge Grass	4066392304
Operator Contact:	Leroy Wallace	

Owner/Operator: School Dist 27 Lodge Grass

Donald Gardner, UST Class B Global Operator  
Leroy Wallace, UST Class A Operator  
Leroy Wallace, UST Class B Operator  
Steve Amyotte, UST Class B Global Operator

Tank Code	02	Tank Age	39	Tank Installed Date	04/04/1985	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	4361	Spill Test Date		Piping Installed Date	10/20/2006	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Temporarily Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	10/17/2011	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Deferred	Vapor Recovery	No
Capacity	8000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date				ATG Type	Veeder Root/TLS-300				

Facility Summary in Big Horn County in the City of Lodge Grass

Location: OUR LADY OF LORETTO CHURCH  
Harding Ave & Helen St  
Lodge Grass, MT 59050 Big Horn

System Facility ID:02-09970

Facility Code: 17821  
Last Inspected On: 11/03/2023  
Operating Permit Renewal Date: 02/11/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Our Lady of Loretto Church3129950702

Operator Contact: Michael Dorn;Tien Dinh

Owner/Operator: Our Lady of Loretto Church

Michael Dorn, UST Class A Operator  
Michael Dorn, UST Class B Operator  
Tien Dinh, UST Class A Operator  
Tien Dinh, UST Class B Operator

Tank Code	S2	Tank Age	34	Tank Installed Date	07/23/1990	Tank Material	Cathodically Protected Steel	Piping Material	Copper	Overfill Types	High Level Alarm
Tag Number	1778	Spill Test Date	11/03/2023	Piping Installed Date		Tank Construction		Piping Construction	PVC	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	U.S. Suction	CP Met Types	Galvanic
Product	Heating Oil	PLLD Test Date		Tank/Piping CP Test Date	11/03/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	3-Year Line Tightness Test	Vapor Recovery	No
Capacity	3000	ATG Test Date	11/03/2023	Line Tightness Test Date	11/03/2023	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	11/03/2023			ATG Type	Gilbarco/EMC Basic				

Facility Summary in Big Horn County in the City of Pryor

Location: PLENTY COUPS HIGH SCHOOL  
1 High School Ln  
Pryor, MT 59066-0229 Big Horn

System Facility ID:02-01131

Facility Code: 17735  
Last Inspected On: 03/19/2021  
Operating Permit Renewal Date: 08/26/2024

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Plenty Coups High School4062597329

Operator Contact: Craig Cliff;Plenty Coups High School4064227289;4062597329

Owner/Operator: Plenty Coups High School

Craig Cliff, UST Class A Operator  
Craig Cliff, UST Class B Operator

Tank Code	05	Tank Age	26	Tank Installed Date	06/01/1998	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	1824	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	03/19/2021	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection		Vapor Recovery	No
Capacity	1000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type	Veeder Root/TLS-300				
Tank Code	06	Tank Age	26	Tank Installed Date	06/01/1998	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	1825	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	03/19/2021	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection		Vapor Recovery	No
Capacity	2000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type	Veeder Root/TLS-300				

Facility Summary in Big Horn County in the City of Pryor

Location: PRYOR SELF SERVICE  
704 Mak Pua Ave  
Pryor, MT 59066 Big Horn

System Facility ID:02-10164

Facility Code: 17823  
Last Inspected On: 02/10/2023  
Operating Permit Renewal Date: 05/16/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: William Hoffman

Operator Contact: William Hoffman

Owner/Operator: William Hoffman

William Hoffman, UST Class A Operator  
William Hoffman, UST Class B Global Operator

Tank Code	03	Tank Age	26	Tank Installed Date	10/01/1998	Tank Material	Steel Clad	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	1389	Spill Test Date	02/10/2023	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	02/04/2011	Primary Tank Leak Detection	Manual Interstitial Monitoring	Primary Pipe Detection		Vapor Recovery	No
Capacity	2000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	02/10/2023			ATG Type					

Facility Summary in Big Horn County in the City of Pryor

Location: SAINT CHARLES MISSION  
29 Pryor Gap Rd  
Pryor, MT 59066 Big Horn

System Facility ID:56-04505

Facility Code: 29917  
Last Inspected On: 06/17/2021  
Operating Permit Renewal Date: 10/09/2024

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: St Labre Indian School 4067844994

Operator Contact: Dana Davis;Leney Mcnac

Owner/Operator: St Labre Indian School

Dana Davis, UST Class A Operator  
Dana Davis, UST Class B Global Operator  
Leney Mcnac, UST Class A Operator  
Leney Mcnac, UST Class B Global Operator

Tank Code	02	Tank Age	34	Tank Installed Date	08/20/1990	Tank Material	Cathodically Protected Steel	Piping Material	Steel	Overfill Types	Flapper Valve
Tag Number	1958	Spill Test Date	06/17/2021	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	06/17/2021	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection		Vapor Recovery	No
Capacity	1000	ATG Test Date	06/17/2021	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco/EMC Basic				

Facility Summary in Big Horn County in the City of Saint Xavier

Location: PRETTY EAGLE SCHOOL  
1 mi W of St Xavier  
Saint Xavier, MT 59075-0257 Big Horn

System Facility ID:02-04504

Facility Code: 17768  
Last Inspected On: 06/17/2021  
Operating Permit Renewal Date: 10/09/2024

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: St Labre Indian School	4067844994
Operator Contact: Dana Davis;Leney Mcnac	

Owner/Operator: St Labre Indian School

Dana Davis, UST Class A Operator  
Dana Davis, UST Class B Global Operator  
Leney Mcnac, UST Class A Operator  
Leney Mcnac, UST Class B Global Operator

Tank Code	03	Tank Age	34	Tank Installed Date	04/01/1990	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	1956	Spill Test Date	06/17/2021	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	06/17/2021	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection		Vapor Recovery	No
Capacity	1000	ATG Test Date	06/17/2021	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	06/17/2021			ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	S4	Tank Age	34	Tank Installed Date	04/01/1990	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	3672	Spill Test Date	06/17/2021	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Temporarily Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Continuous Interstitial Monitoring	Piping Type	U.S. Suction	CP Met Types	Galvanic
Product	Heating Oil	PLLD Test Date		Tank/Piping CP Test Date	06/17/2021	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring;MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	10000	ATG Test Date	06/17/2021	Line Tightness Test Date	11/05/2013	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No

		Overfill Test Date	06/17/2021			ATG Type	Gilbarco-Veeder Root/TLS-350				
--	--	--------------------	------------	--	--	----------	---------------------------------	--	--	--	--



Facility Summary in Big Horn County in the City of Wyola

Location: WYOLA ELEMENTARY SCHOOL  
1 Mondell Ave  
Wyola, MT 59089 Big Horn

System Facility ID:02-13762

Facility Code: 17853  
Last Inspected On: 07/12/2022  
Operating Permit Renewal Date: 07/12/2025

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: School Dist 29 Wyola4063432722

Operator Contact: Bradford Crooked Arm

Owner/Operator: School Dist 29 Wyola

Bradford Crooked Arm, UST Class A Operator

Bradford Crooked Arm, UST Class B Global Operator

Tank Code	02	Tank Age	25	Tank Installed Date	07/01/1999	Tank Material	Cathodically Protected Steel	Piping Material	Steel	Overfill Types	Flapper Valve
Tag Number	4370	Spill Test Date	07/12/2022	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	06/24/2022	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection		Vapor Recovery	No
Capacity	1000	ATG Test Date	07/12/2022	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	07/12/2022			ATG Type	Veeder Root/TLS-300				