

**Facility Summary in Big Horn County in the City of Crow Agency**

**Location:** CROW NATION EXPRESS  
42 Hospital Loop  
Crow Agency, MT 59022 Big Horn

System Facility ID:02-10867

**Facility Code:** 17827  
**Last Inspected On:** 12/19/2023  
**Operating Permit Renewal Date:** 01/06/2024

**Note: Inspection is due 90 days before the Operating Permit Renewal Date.**

**Owner Operator Contact:** Becky Wilson;Crow Tribe of Indians

**(406) 638-2059;(406) 679-6339**

**becky.wilson@crow-nsn.gov**

**Operator Contact:**

**Owner/Operator:** Becky Wilson

(406) 679-6339

becky.wilson@crow-nsn.gov

**Owner/Operator:** Crow Tribe of Indians

(406) 679-6339

becky.wilson@crow-nsn.gov

<b>Tank Code</b>	05	<b>Tank Age</b>	26	<b>Tank Installed Date</b>	02/01/2000	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	4174	<b>Spill Test Date</b>	12/18/2020	<b>Piping Installed Date</b>		<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>	12/21/2011	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	ELLD 0.2	<b>Vapor Recovery</b>	No
<b>Capacity</b>	10000	<b>ATG Test Date</b>		<b>Line Tightness Test Date</b>	08/02/2015	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	12/18/2020			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
<b>Tank Code</b>	06	<b>Tank Age</b>	26	<b>Tank Installed Date</b>	02/01/2000	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	4175	<b>Spill Test Date</b>	12/18/2020	<b>Piping Installed Date</b>		<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>	12/21/2011	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	ELLD 0.2	<b>Vapor Recovery</b>	No
<b>Capacity</b>	6000	<b>ATG Test Date</b>		<b>Line Tightness Test Date</b>	08/02/2015	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	12/18/2020			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

<b>Tank Code</b>	07	<b>Tank Age</b>	26	<b>Tank Installed Date</b>	02/01/2000	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	4176	<b>Spill Test Date</b>	12/18/2020	<b>Piping Installed Date</b>		<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>	12/21/2011	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	ELLD 0.2	<b>Vapor Recovery</b>	No
<b>Capacity</b>	4000	<b>ATG Test Date</b>		<b>Line Tightness Test Date</b>	08/02/2015	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	12/18/2020			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
<b>Tank Code</b>	08	<b>Tank Age</b>	26	<b>Tank Installed Date</b>	02/01/2000	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	4177	<b>Spill Test Date</b>	12/18/2020	<b>Piping Installed Date</b>		<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Diesel	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>	12/21/2011	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	ELLD 0.2	<b>Vapor Recovery</b>	No
<b>Capacity</b>	6000	<b>ATG Test Date</b>		<b>Line Tightness Test Date</b>	08/02/2015	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	12/18/2020			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
<b>Tank Code</b>	09	<b>Tank Age</b>	26	<b>Tank Installed Date</b>	02/01/2000	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	4178	<b>Spill Test Date</b>	12/18/2020	<b>Piping Installed Date</b>		<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Diesel	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>	12/21/2011	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	ELLD 0.2	<b>Vapor Recovery</b>	No
<b>Capacity</b>	4000	<b>ATG Test Date</b>		<b>Line Tightness Test Date</b>	08/02/2015	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	12/18/2020			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

**Facility Summary in Big Horn County in the City of Crow Agency**

**Location:** TEEPEE SERVICE INC  
6959 E Makawasha Ave  
Crow Agency, MT 59022-0280 Big Horn

System Facility ID:02-07334

**Facility Code:** 17799  
**Last Inspected On:** 04/09/2025  
**Operating Permit Renewal Date:** 07/22/2028

**Note: Inspection is due 90 days before the Operating Permit Renewal Date.**

**Owner Operator Contact:** Teepee Service Inc

**(406) 638-2269**

**Operator Contact:** James Watt

**2teepee@nemont.net**

**Owner/Operator:** Teepee Service Inc

**(406) 638-2269**

James Watt, UST Class A Operator

2teepee@nemont.net

James Watt, UST Class B Operator

2teepee@nemont.net

<b>Tank Code</b>	07	<b>Tank Age</b>	31	<b>Tank Installed Date</b>	07/03/1995	<b>Tank Material</b>	Steel Clad	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	High Level Alarm
<b>Tag Number</b>	2097	<b>Spill Test Date</b>	04/09/2025	<b>Piping Installed Date</b>		<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>	04/09/2025	<b>Tank/Piping CP Test Date</b>	04/16/2013	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	ELLD 0.2	<b>Vapor Recovery</b>	No
<b>Capacity</b>	12000	<b>ATG Test Date</b>	04/09/2025	<b>Line Tightness Test Date</b>	03/06/2022	<b>Secondary Tank Leak Detection</b>	Continuous Interstitial Monitoring	<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	04/09/2025			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
<b>Tank Code</b>	08	<b>Tank Age</b>	31	<b>Tank Installed Date</b>	07/03/1995	<b>Tank Material</b>	Steel Clad	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	High Level Alarm
<b>Tag Number</b>	2098	<b>Spill Test Date</b>	04/09/2025	<b>Piping Installed Date</b>		<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>	04/09/2025	<b>Tank/Piping CP Test Date</b>	04/16/2013	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	ELLD 0.2	<b>Vapor Recovery</b>	No
<b>Capacity</b>	8000	<b>ATG Test Date</b>	04/09/2025	<b>Line Tightness Test Date</b>	02/18/2022	<b>Secondary Tank Leak Detection</b>	Continuous Interstitial Monitoring	<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	04/09/2025			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

**Facility Summary in Big Horn County in the City of Fort Smith**

**Location:** BIGHORN CANYON MAINTENANCE FACILITY (NPS)  
5th Ave B  
Fort Smith, MT 59035 Big Horn

System Facility ID:02-09815

**Facility Code:** 17820  
**Last Inspected On:** 03/10/2021  
**Operating Permit Renewal Date:** 03/21/2024

**Note: Inspection is due 90 days before the Operating Permit Renewal Date.**

**Owner Operator Contact:** National Park Service Yellowtail

**Operator Contact:** Jesse Macklin;Kelly Peacock;Lyndon Driftwood;William Snell (406) 666-3310;(406) 666-3312

kelly\_peacock@nps.gov;lyndon\_driftwood@nps.gov

**Owner/Operator:** National Park Service Yellowtail

Jesse Macklin, UST Class A Operator  
Jesse Macklin, UST Class B Global Operator  
Jesse Macklin, UST Class B Operator  
Kelly Peacock, UST Class A Operator  
Kelly Peacock, UST Class B Operator  
Lyndon Driftwood, UST Class A Operator  
Lyndon Driftwood, UST Class B Global Operator  
Norman Griffin, UST Class B Operator  
Roger Watson, UST Class B Global Operator  
William Snell, UST Class A Operator  
William Snell, UST Class B Global Operator  
William Snell, UST Class B Operator

kelly\_peacock@nps.gov  
kelly\_peacock@nps.gov  
lyndon\_driftwood@nps.gov  
lyndon\_driftwood@nps.gov

<b>Tank Code</b>	05	<b>Tank Age</b>	38	<b>Tank Installed Date</b>	01/01/1988	<b>Tank Material</b>	Cathodically Protected Steel	<b>Piping Material</b>	Fiberglass	<b>Overfill Types</b>	Ball Float Valve;High Level Alarm
<b>Tag Number</b>	1745	<b>Spill Test Date</b>	06/15/2023	<b>Piping Installed Date</b>	10/16/2017	<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>	03/10/2021	<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Mechanical Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Galvanic
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>	07/26/2019	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	No
<b>Capacity</b>	2000	<b>ATG Test Date</b>		<b>Line Tightness Test Date</b>	03/10/2021	<b>Secondary Tank Leak Detection</b>	Continuous Interstitial Monitoring	<b>Secondary Pipe Detection</b>	MLLD Line Tightness Testing	<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	06/15/2023			<b>ATG Type</b>	Veeder Root/TLS-300				

<b>Tank Code</b>	06	<b>Tank Age</b>	38	<b>Tank Installed Date</b>	01/01/1988	<b>Tank Material</b>	Cathodically Protected Steel	<b>Piping Material</b>	Fiberglass	<b>Overfill Types</b>	Ball Float Valve; High Level Alarm
<b>Tag Number</b>	1746	<b>Spill Test Date</b>	06/15/2023	<b>Piping Installed Date</b>	10/16/2017	<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>	03/10/2021	<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Mechanical Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Galvanic
<b>Product</b>	Diesel	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>	07/26/2019	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	No
<b>Capacity</b>	2000	<b>ATG Test Date</b>		<b>Line Tightness Test Date</b>	03/10/2021	<b>Secondary Tank Leak Detection</b>	Continuous Interstitial Monitoring	<b>Secondary Pipe Detection</b>	MLLD Line Tightness Testing	<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	06/15/2023			<b>ATG Type</b>	Veeder Root/TLS-300				

**Facility Summary in Big Horn County in the City of Fort Smith**

**Location:** OK A BEH MARINA  
5 Ave B  
Fort Smith, MT 59035 Big Horn

System Facility ID:56-13877

**Facility Code:** 30554  
**Last Inspected On:** 05/08/2021  
**Operating Permit Renewal Date:** 05/26/2022

**Note: Inspection is due 90 days before the Operating Permit Renewal Date.**

**Owner Operator Contact:** National Park Service Yellowtail

**Operator Contact:** Christian Fighter;Jaris Pretty Paint;Kelly Peacock;Marvin Stewart;Shawn Backbone;Tristan Stewart

**(406) 683-5313**

**fighterchristian117@gmail.com;jpretypaint01@gmail.com;kelly\_peacock@nps.gov;shawnbackbone78@gmail.com;tristantoddstewart@gmail.com**

**Owner/Operator:** National Park Service Yellowtail

Christian Fighter, UST Class A Operator  
Christian Fighter, UST Class B Operator  
Jaris Pretty Paint, UST Class A Operator  
Kelly Peacock, UST Class A Operator  
Kelly Peacock, UST Class B Operator  
Marvin Stewart, UST Class A Operator  
Marvin Stewart, UST Class B Operator  
Shawn Backbone, UST Class A Operator  
Tristan Stewart, UST Class A Operator  
Tristan Stewart, UST Class B Operator

fighterchristian117@gmail.com  
fighterchristian117@gmail.com  
jpretypaint01@gmail.com  
kelly\_peacock@nps.gov  
kelly\_peacock@nps.gov  
  
shawnbackbone78@gmail.com  
tristantoddstewart@gmail.com  
tristantoddstewart@gmail.com

<b>Tank Code</b>	07	<b>Tank Age</b>	36	<b>Tank Installed Date</b>	05/14/1990	<b>Tank Material</b>	Cathodically Protected Steel	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	1747	<b>Spill Test Date</b>	06/14/2023	<b>Piping Installed Date</b>		<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>	06/02/2021	<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Mechanical Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Galvanic
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>	07/19/2020	<b>Primary Tank Leak Detection</b>	Continuous Interstitial Monitoring	<b>Primary Pipe Detection</b>	MLLD Line Tightness Testing	<b>Vapor Recovery</b>	No
<b>Capacity</b>	2000	<b>ATG Test Date</b>		<b>Line Tightness Test Date</b>	06/02/2021	<b>Secondary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Secondary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Energy Act</b>	No
		<b>Overfill Test Date</b>				<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-300;Veeder Root/TLS-300				

**Facility Summary in Big Horn County in the City of Fort Smith**

**Location:** YELLOWTAIL MARKET  
Park Dale Ct  
Fort Smith, MT 59035 Big Horn

System Facility ID:02-05862

**Facility Code:** 17785  
**Last Inspected On:** 10/03/2024  
**Operating Permit Renewal Date:** 10/20/2027

**Note: Inspection is due 90 days before the Operating Permit Renewal Date.**

**Owner Operator Contact:** Crow Tribe of Indians (406) 638-2059

**Operator Contact:** Becky Wilson;John Wilson (406) 638-2400;(406) 679-6339 becky.wilson@crow-nsn.gov

**Owner/Operator:** Crow Tribe of Indians (406) 638-2059

Becky Wilson, UST Class A Operator  
Becky Wilson, UST Class B Operator  
John Wilson, UST Class A Operator  
John Wilson, UST Class B Global Operator

becky.wilson@crow-nsn.gov  
becky.wilson@crow-nsn.gov

<b>Tank Code</b>	03	<b>Tank Age</b>	28	<b>Tank Installed Date</b>	03/01/1998	<b>Tank Material</b>	Cathodically Protected Steel	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	1210	<b>Spill Test Date</b>	10/03/2024	<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	None	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Galvanic
<b>Product</b>	Diesel	<b>PLLD Test Date</b>	01/10/2025	<b>Tank/Piping CP Test Date</b>	10/03/2024	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	ELLD 0.2	<b>Vapor Recovery</b>	No
<b>Capacity</b>	8000	<b>ATG Test Date</b>	10/03/2024	<b>Line Tightness Test Date</b>	03/04/2021	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	01/10/2025			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
<b>Tank Code</b>	04	<b>Tank Age</b>	28	<b>Tank Installed Date</b>	03/01/1998	<b>Tank Material</b>	Cathodically Protected Steel	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	1211	<b>Spill Test Date</b>	10/03/2024	<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	Single Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Galvanic
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>	01/10/2025	<b>Tank/Piping CP Test Date</b>	10/03/2024	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	ELLD 0.2	<b>Vapor Recovery</b>	No
<b>Capacity</b>	8000	<b>ATG Test Date</b>	10/03/2024	<b>Line Tightness Test Date</b>	03/04/2021	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	01/10/2025			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

**Facility Summary in Big Horn County in the City of Garryowen**

**Location:** GARRYOWEN CONOCO  
200 Town Hall  
Garryowen, MT 59031 Big Horn

System Facility ID:02-03284

**Facility Code:** 17761  
**Last Inspected On:** 10/15/2021  
**Operating Permit Renewal Date:** 10/25/2021

**Note: Inspection is due 90 days before the Operating Permit Renewal Date.**

**Owner Operator Contact:** Crow Tribe of Indians;The Crow Tribe (406) 638-2059;(406) 697-4765 marvin.stops@crow-nsn.gov

**Operator Contact:** Chris Kortlander (406) 679-4444 chris@historicalrarities.com

**Owner/Operator:** Crow Tribe of Indians (406) 638-2059

**Owner/Operator:** The Crow Tribe (406) 638-2059

Chris Kortlander, UST Class A Operator

chris@historicalrarities.com

Petra Pretty On Top, UST Class B Global Operator

<b>Tank Code</b>	01	<b>Tank Age</b>	30	<b>Tank Installed Date</b>	06/21/1996	<b>Tank Material</b>	Steel Clad	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	3392	<b>Spill Test Date</b>		<b>Piping Installed Date</b>		<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	Secondary Containment Chase	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Galvanic
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>	07/29/2008	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	ELLD 0.2	<b>Vapor Recovery</b>	No
<b>Capacity</b>	8000	<b>ATG Test Date</b>		<b>Line Tightness Test Date</b>	10/15/2018	<b>Secondary Tank Leak Detection</b>	Continuous Interstitial Monitoring	<b>Secondary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Energy Act</b>	No
		<b>Overfill Test Date</b>				<b>ATG Type</b>	Veeder Root/TLS-300				
<b>Tank Code</b>	02	<b>Tank Age</b>	30	<b>Tank Installed Date</b>	06/21/1996	<b>Tank Material</b>	Steel Clad	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	3393	<b>Spill Test Date</b>		<b>Piping Installed Date</b>	06/11/2013	<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	Secondary Containment Chase	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Galvanic
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>	07/29/2008	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	No
<b>Capacity</b>	12000	<b>ATG Test Date</b>		<b>Line Tightness Test Date</b>	10/15/2018	<b>Secondary Tank Leak Detection</b>	Continuous Interstitial Monitoring	<b>Secondary Pipe Detection</b>	ELLD 0.2	<b>Energy Act</b>	No

---

	<b>Overfill Test Date</b>		<b>ATG Type</b>	Veeder Root/TLS-300			
--	---------------------------	--	-----------------	---------------------	--	--	--

---

### Facility Summary in Big Horn County in the City of Hardin

**Location:** DOLLIES CONVENIENCE STORE  
804 3rd St W  
Hardin, MT 59034-1606 Big Horn

System Facility ID:02-00061

**Facility Code:** 17730  
**Last Inspected On:** 12/16/2025  
**Operating Permit Renewal Date:** 12/16/2028

**Note: Inspection is due 90 days before the Operating Permit Renewal Date.**

**Owner Operator Contact:** Nandini LLC

**(405) 209-4047**

**harry@shyamllc.com**

**Operator Contact:** Megan Ashinhurst

**Owner/Operator:** Nandini LLC

**(405) 209-4047**

**harry@shyamllc.com**

Constance Weigand, UST Class B Operator  
Corri Duncan, UST Class B Operator  
Megan Ashinhurst, UST Class A Operator  
Megan Ashinhurst, UST Class B Global Operator

**corriduncan@aol.com**

<b>Tank Code</b>	01	<b>Tank Age</b>	42	<b>Tank Installed Date</b>	12/20/1984	<b>Tank Material</b>	Cathodically Protected Steel	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	4463	<b>Spill Test Date</b>		<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	Single Walled	<b>AST</b>	No
<b>Tank Status</b>	Temporarily Out of Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Mechanical Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Galvanic
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>	09/16/2025	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.1; Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	MLLD Line Tightness Testing	<b>Vapor Recovery</b>	No
<b>Capacity</b>	10000	<b>ATG Test Date</b>		<b>Line Tightness Test Date</b>	01/21/2015	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>				<b>ATG Type</b>	Veeder Root/TLS-300				
<b>Tank Code</b>	03	<b>Tank Age</b>	24	<b>Tank Installed Date</b>	12/16/2002	<b>Tank Material</b>	Cathodically Protected Steel	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	4773	<b>Spill Test Date</b>		<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	None	<b>AST</b>	No
<b>Tank Status</b>	Temporarily Out of Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Mechanical Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Galvanic
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>	09/16/2025	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.1; Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	MLLD Line Tightness Testing	<b>Vapor Recovery</b>	No
<b>Capacity</b>	4000	<b>ATG Test Date</b>		<b>Line Tightness Test Date</b>	01/21/2015	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No

---

	<b>Overfill Test Date</b>		<b>ATG Type</b>	Veeder Root/TLS-300			
--	---------------------------	--	-----------------	---------------------	--	--	--

### Facility Summary in Big Horn County in the City of Hardin

**Location:** GOOD 2 GO STORES 808  
1600 N Crawford Ave  
Hardin, MT 59034 Big Horn

System Facility ID:02-00538

**Facility Code:** 17731  
**Last Inspected On:** 05/14/2025  
**Operating Permit Renewal Date:** 12/11/2028

**Note: Inspection is due 90 days before the Operating Permit Renewal Date.**

<b>Owner Operator Contact:</b> 8 Hardin Montana Property LLC	(208) 523-6582	gary.brown@southforkpm.com
<b>Operator Contact:</b> Amy Packard;Good 2 Go Stores LLC;Garry Wells;Good 2 Go Stores LLC;Jeanette Nette;Good 2 Go Stores LLC;Lisa Yates;Good 2 Go Stores LLC	(208) 417-1590	gdubb350@gmail.com;licensing@good2gostores.com;jnetty1970@gmail.com;licensing@good2gostores.com;lisa.yates@good2go.com;licensing@good2gostores.com;store218@good2gostores.com;licensing@good2gostores.com

<b>Owner/Operator:</b> 8 Hardin Montana Property LLC	(208) 523-6582	gary.brown@southforkpm.com
Amy Packard, UST Class A Operator Amy Packard, UST Class B Operator Garry Wells, UST Class A Operator Garry Wells, UST Class B Operator Jeanette Nette, UST Class A Operator Jeanette Nette, UST Class B Operator Lisa Yates, UST Class A Operator Lisa Yates, UST Class B Operator		licensing@good2gostores.com licensing@good2gostores.com licensing@good2gostores.com licensing@good2gostores.com licensing@good2gostores.com licensing@good2gostores.com licensing@good2gostores.com licensing@good2gostores.com

<b>Tank Code</b>	03	<b>Tank Age</b>	52	<b>Tank Installed Date</b>	04/12/1974	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	3789	<b>Spill Test Date</b>	05/14/2025	<b>Piping Installed Date</b>	04/16/2010	<b>Tank Construction</b>		<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	05/08/2025	<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>	05/14/2025	<b>Tank/Piping CP Test Date</b>	08/28/2007	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	No
<b>Capacity</b>	6000	<b>ATG Test Date</b>	05/14/2025	<b>Line Tightness Test Date</b>	07/26/2022	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>	ELLD 0.2	<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	05/14/2025			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
<b>Tank Code</b>	04	<b>Tank Age</b>	52	<b>Tank Installed Date</b>	04/12/1974	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	3790	<b>Spill Test Date</b>	05/14/2025	<b>Piping Installed Date</b>	04/16/2010	<b>Tank Construction</b>		<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	05/08/2025	<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible

<b>Product</b>	Gasoline	<b>PLLD Test Date</b>	05/14/2025	<b>Tank/Piping CP Test Date</b>	08/08/2007	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	No
<b>Capacity</b>	6000	<b>ATG Test Date</b>	05/14/2025	<b>Line Tightness Test Date</b>	04/24/2022	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>	ELLD 0.2	<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	05/14/2025			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
<b>Tank Code</b>	05	<b>Tank Age</b>	52	<b>Tank Installed Date</b>	04/12/1974	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	3791	<b>Spill Test Date</b>	05/14/2025	<b>Piping Installed Date</b>	04/16/2010	<b>Tank Construction</b>		<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	05/08/2025	<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Diesel	<b>PLLD Test Date</b>	05/14/2025	<b>Tank/Piping CP Test Date</b>	08/28/2007	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	No
<b>Capacity</b>	6000	<b>ATG Test Date</b>	05/14/2025	<b>Line Tightness Test Date</b>	03/08/2022	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>	ELLD 0.2	<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	05/14/2025			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
<b>Tank Code</b>	06	<b>Tank Age</b>	52	<b>Tank Installed Date</b>	04/12/1974	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	3792	<b>Spill Test Date</b>	05/14/2025	<b>Piping Installed Date</b>	04/16/2010	<b>Tank Construction</b>		<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	05/08/2025	<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>	05/14/2025	<b>Tank/Piping CP Test Date</b>	09/07/2007	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	No
<b>Capacity</b>	6000	<b>ATG Test Date</b>	05/14/2025	<b>Line Tightness Test Date</b>	07/26/2022	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>	ELLD 0.2	<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	05/14/2025			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

### Facility Summary in Big Horn County in the City of Hardin

**Location:** HARDIN C STORE  
1223 N Crawford Ave  
Hardin, MT 59034-1009 Big Horn

System Facility ID:02-13635

**Facility Code:** 17852  
**Last Inspected On:** 08/26/2025  
**Operating Permit Renewal Date:** 12/10/2028

**Note: Inspection is due 90 days before the Operating Permit Renewal Date.**

**Owner Operator Contact:** Town and Country Supply Association

**wburley@tandcsupply.com**

**Operator Contact:** Wes Burley

**(406) 256-1020**

**Owner/Operator:** Town and Country Supply Association

wburley@tandcsupply.com

Melanie Hale, UST Class B Operator

mhale@tandcsupply.com

Wes Burley, UST Class A Operator

<b>Tank Code</b>	01	<b>Tank Age</b>	31	<b>Tank Installed Date</b>	07/01/1995	<b>Tank Material</b>	Cathodically Protected Steel	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	High Level Alarm
<b>Tag Number</b>	927	<b>Spill Test Date</b>	08/08/2025	<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Galvanic
<b>Product</b>	Diesel	<b>PLLD Test Date</b>	08/08/2025	<b>Tank/Piping CP Test Date</b>	08/08/2025	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	ELLD 0.2	<b>Vapor Recovery</b>	No
<b>Capacity</b>	16000	<b>ATG Test Date</b>	08/08/2025	<b>Line Tightness Test Date</b>	08/04/2022	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	08/08/2025			<b>ATG Type</b>	Gilbarco/EMC Basic				
<b>Tank Code</b>	02	<b>Tank Age</b>	31	<b>Tank Installed Date</b>	07/01/1995	<b>Tank Material</b>	Cathodically Protected Steel	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	High Level Alarm
<b>Tag Number</b>	928	<b>Spill Test Date</b>	08/08/2025	<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Galvanic
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>	08/08/2025	<b>Tank/Piping CP Test Date</b>	08/08/2025	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	ELLD 0.2	<b>Vapor Recovery</b>	No
<b>Capacity</b>	16000	<b>ATG Test Date</b>	08/08/2025	<b>Line Tightness Test Date</b>	08/07/2022	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	08/08/2025			<b>ATG Type</b>	Gilbarco/EMC Basic				
<b>Tank Code</b>	03	<b>Tank Age</b>	31	<b>Tank Installed Date</b>	07/01/1995	<b>Tank Material</b>	Cathodically Protected Steel	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	High Level Alarm
<b>Tag Number</b>	929	<b>Spill Test Date</b>	08/08/2025	<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	Double Walled	<b>AST</b>	No

<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Galvanic
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>	08/08/2025	<b>Tank/Piping CP Test Date</b>	08/08/2025	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	ELLD 0.2	<b>Vapor Recovery</b>	No
<b>Capacity</b>	16000	<b>ATG Test Date</b>	08/08/2025	<b>Line Tightness Test Date</b>	07/30/2022	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	08/08/2025			<b>ATG Type</b>	Gilbarco/EMC Basic				
<b>Tank Code</b>	04	<b>Tank Age</b>	31	<b>Tank Installed Date</b>	07/01/1995	<b>Tank Material</b>	Cathodically Protected Steel	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	High Level Alarm
<b>Tag Number</b>	930	<b>Spill Test Date</b>	08/08/2025	<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Galvanic
<b>Product</b>	Diesel, Dyed	<b>PLLD Test Date</b>	08/08/2025	<b>Tank/Piping CP Test Date</b>	08/08/2025	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	ELLD 0.2	<b>Vapor Recovery</b>	No
<b>Capacity</b>	10000	<b>ATG Test Date</b>	08/08/2025	<b>Line Tightness Test Date</b>	07/30/2022	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	08/08/2025			<b>ATG Type</b>	Gilbarco/EMC Basic				
<b>Tank Code</b>	05	<b>Tank Age</b>	31	<b>Tank Installed Date</b>	07/01/1995	<b>Tank Material</b>	Cathodically Protected Steel	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	High Level Alarm
<b>Tag Number</b>	931	<b>Spill Test Date</b>	08/08/2025	<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Galvanic
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>	08/08/2025	<b>Tank/Piping CP Test Date</b>	08/08/2025	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	ELLD 0.2	<b>Vapor Recovery</b>	No
<b>Capacity</b>	6000	<b>ATG Test Date</b>	08/08/2025	<b>Line Tightness Test Date</b>	07/20/2022	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	08/08/2025			<b>ATG Type</b>	Gilbarco/EMC Basic				

**Facility Summary in Big Horn County in the City of Hardin**

**Location:** L and B LAST STOP  
531 E Railway St  
Hardin, MT 59034-1903 Big Horn

System Facility ID:02-05856

**Facility Code:** 17783  
**Last Inspected On:** 04/17/2024  
**Operating Permit Renewal Date:** 10/13/2027

**Note: Inspection is due 90 days before the Operating Permit Renewal Date.**

**Owner Operator Contact:** Gary and Lynette VanDersloot (406) 665-3414

**Operator Contact:** Lynette VanDersloot (406) 665-3414 laststop531@gmail.com

**Owner/Operator:** Gary and Lynette VanDersloot (406) 665-3414

Lynette VanDersloot, UST Class A Operator  
Lynette VanDersloot, UST Class B Operator

laststop531@gmail.com  
laststop531@gmail.com

<b>Tank Code</b>	03	<b>Tank Age</b>	27	<b>Tank Installed Date</b>	01/01/1999	<b>Tank Material</b>	Steel Clad	<b>Piping Material</b>	Fiberglass	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	3915	<b>Spill Test Date</b>	04/17/2024	<b>Piping Installed Date</b>		<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	None	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Not Required	<b>Piping Type</b>	Safe Suction	<b>CP Met Types</b>	
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>	05/29/2013	<b>Primary Tank Leak Detection</b>	Manual Interstitial Monitoring	<b>Primary Pipe Detection</b>		<b>Vapor Recovery</b>	No
<b>Capacity</b>	4000	<b>ATG Test Date</b>		<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	10/03/2024			<b>ATG Type</b>					
<b>Tank Code</b>	04	<b>Tank Age</b>	27	<b>Tank Installed Date</b>	01/01/1999	<b>Tank Material</b>	Steel Clad	<b>Piping Material</b>	Fiberglass	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	3916	<b>Spill Test Date</b>	04/17/2024	<b>Piping Installed Date</b>		<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	None	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Not Required	<b>Piping Type</b>	Safe Suction	<b>CP Met Types</b>	
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>	05/29/2013	<b>Primary Tank Leak Detection</b>	Manual Interstitial Monitoring	<b>Primary Pipe Detection</b>		<b>Vapor Recovery</b>	No
<b>Capacity</b>	2000	<b>ATG Test Date</b>		<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	04/17/2024			<b>ATG Type</b>					

### Facility Summary in Big Horn County in the City of Hardin

**Location:** LOVES TRAVEL STOP HARDIN #679  
1270 N State Hwy 47  
Hardin, MT 59034 Big Horn

System Facility ID:60-15284

**Facility Code:** 30991  
**Last Inspected On:** 06/30/2023  
**Operating Permit Renewal Date:** 12/04/2026

**Note: Inspection is due 90 days before the Operating Permit Renewal Date.**

**Owner Operator Contact:** Loves Travel Stops and Country Stores Inc (281) 655-9425 environmental@loves.com

**Operator Contact:** Eric Bennett;Loves Travel Stops and Country Stores Inc;Ted Parrish (405) 779-3768;(281) 655-9425;(615) 580-9096 environmental@loves.com;environmental@loves.com;tparrish@mfieldservices.com

**Owner/Operator:** Loves Travel Stops and Country Stores Inc (281) 655-9425 environmental@loves.com  
Eric Bennett, UST Class A Operator environmental@loves.com  
Eric Bennett, UST Class B Operator environmental@loves.com  
Ted Parrish, UST Class A Operator tparrish@mfieldservices.com  
Ted Parrish, UST Class B Global Operator tparrish@mfieldservices.com

<b>Tank Code</b>	01	<b>Tank Age</b>	9	<b>Tank Installed Date</b>	05/27/2017	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	High Level Alarm;Positive Shutoff
<b>Tag Number</b>	5658	<b>Spill Test Date</b>	08/08/2023	<b>Piping Installed Date</b>	10/01/2016	<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	08/08/2023	<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Continuous Interstitial Monitoring	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	No
<b>Capacity</b>	20000	<b>ATG Test Date</b>	07/01/2023	<b>Line Tightness Test Date</b>	06/29/2023	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	Yes
		<b>Overfill Test Date</b>				<b>ATG Type</b>	Incon/TS-5000 EVO				
<b>Tank Code</b>	02	<b>Tank Age</b>	9	<b>Tank Installed Date</b>	05/27/2017	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	High Level Alarm;Positive Shutoff
<b>Tag Number</b>	5659	<b>Spill Test Date</b>		<b>Piping Installed Date</b>	10/01/2016	<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Continuous Interstitial Monitoring	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	No
<b>Capacity</b>	12000	<b>ATG Test Date</b>		<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	Yes

		<b>Overfill Test Date</b>				<b>ATG Type</b>	Incon/TS-5000 EVO				
<b>Tank Code</b>	03	<b>Tank Age</b>	9	<b>Tank Installed Date</b>	05/27/2017	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	High Level Alarm;Positive Shutoff
<b>Tag Number</b>	5660	<b>Spill Test Date</b>		<b>Piping Installed Date</b>	10/01/2016	<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Continuous Interstitial Monitoring	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	No
<b>Capacity</b>	8000	<b>ATG Test Date</b>		<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	Yes
		<b>Overfill Test Date</b>				<b>ATG Type</b>	Incon/TS-5000 EVO				
<b>Tank Code</b>	04	<b>Tank Age</b>	9	<b>Tank Installed Date</b>	05/27/2017	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	High Level Alarm;Positive Shutoff
<b>Tag Number</b>	5661	<b>Spill Test Date</b>		<b>Piping Installed Date</b>	10/01/2016	<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Diesel	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Continuous Interstitial Monitoring	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	No
<b>Capacity</b>	30000	<b>ATG Test Date</b>		<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	Yes
		<b>Overfill Test Date</b>				<b>ATG Type</b>	Incon/TS-5000 EVO				
<b>Tank Code</b>	05	<b>Tank Age</b>	9	<b>Tank Installed Date</b>	05/27/2017	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	High Level Alarm;Positive Shutoff
<b>Tag Number</b>	5662	<b>Spill Test Date</b>		<b>Piping Installed Date</b>	10/01/2016	<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Diesel	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Continuous Interstitial Monitoring	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	No
<b>Capacity</b>	30000	<b>ATG Test Date</b>		<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	Yes
		<b>Overfill Test Date</b>				<b>ATG Type</b>	Incon/TS-5000 EVO				
<b>Tank Code</b>	06	<b>Tank Age</b>	9	<b>Tank Installed Date</b>	05/27/2017	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	High Level Alarm;Positive Shutoff

<b>Tag Number</b>	5663	<b>Spill Test Date</b>		<b>Piping Installed Date</b>	10/01/2016	<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Biodiesel, <=B20	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Continuous Interstitial Monitoring	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	No
<b>Capacity</b>	20000	<b>ATG Test Date</b>		<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	Yes
		<b>Overfill Test Date</b>				<b>ATG Type</b>	Incon/TS-5000 EVO				
<b>Tank Code</b>	07	<b>Tank Age</b>	9	<b>Tank Installed Date</b>	05/27/2017	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	
<b>Tag Number</b>	5664	<b>Spill Test Date</b>		<b>Piping Installed Date</b>	10/01/2016	<b>Tank Construction</b>		<b>Piping Construction</b>		<b>AST</b>	No
<b>Tank Status</b>	Other	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	
<b>Product</b>	DEF (Not Regulated)	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Continuous Interstitial Monitoring	<b>Primary Pipe Detection</b>	ELLD 0.2;ELLD Line Tightness Testing	<b>Vapor Recovery</b>	No
<b>Capacity</b>	20000	<b>ATG Test Date</b>		<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>	Continuous Interstitial Monitoring;Not Listed	<b>Energy Act</b>	No
		<b>Overfill Test Date</b>				<b>ATG Type</b>					

### Facility Summary in Big Horn County in the City of Hardin

**Location:** MATOVICH OIL CO INC  
900 4th St W  
Hardin, MT 59034 Big Horn

System Facility ID:02-13423

**Facility Code:** 17850  
**Last Inspected On:** 11/22/2023  
**Operating Permit Renewal Date:** 03/05/2027

**Note: Inspection is due 90 days before the Operating Permit Renewal Date.**

---

**Owner Operator Contact:** Matovich Oil Co Inc (406) 665-1400 [cwittmato@yahoo.com](mailto:cwittmato@yahoo.com)

---

**Operator Contact:** Jon Matovich (406) 665-1400 [cwittmato@yahoo.com](mailto:cwittmato@yahoo.com)

---

**Owner/Operator:** Matovich Oil Co Inc (406) 665-1400 [cwittmato@yahoo.com](mailto:cwittmato@yahoo.com)  
 Jon Matovich, UST Class A Operator [cwittmato@yahoo.com](mailto:cwittmato@yahoo.com)  
 Jon Matovich, UST Class B Operator [cwittmato@yahoo.com](mailto:cwittmato@yahoo.com)

<b>Tank Code</b>	01	<b>Tank Age</b>	32	<b>Tank Installed Date</b>	05/24/1994	<b>Tank Material</b>	Cathodically Protected Steel	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	High Level Alarm
<b>Tag Number</b>	1580	<b>Spill Test Date</b>	11/22/2023	<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	None	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Galvanic
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>	11/22/2023	<b>Tank/Piping CP Test Date</b>	11/22/2023	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	ELLD 0.2	<b>Vapor Recovery</b>	No
<b>Capacity</b>	2000	<b>ATG Test Date</b>	11/22/2023	<b>Line Tightness Test Date</b>	09/24/2020	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	11/22/2023			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
<b>Tank Code</b>	02	<b>Tank Age</b>	32	<b>Tank Installed Date</b>	05/24/1994	<b>Tank Material</b>	Cathodically Protected Steel	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	High Level Alarm
<b>Tag Number</b>	1581	<b>Spill Test Date</b>	11/22/2023	<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	None	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Galvanic
<b>Product</b>	Diesel	<b>PLLD Test Date</b>	11/22/2023	<b>Tank/Piping CP Test Date</b>	11/22/2023	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	ELLD 0.2	<b>Vapor Recovery</b>	No
<b>Capacity</b>	2000	<b>ATG Test Date</b>	11/22/2023	<b>Line Tightness Test Date</b>	09/16/2020	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	11/22/2023			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
<b>Tank Code</b>	03	<b>Tank Age</b>	32	<b>Tank Installed Date</b>	05/24/1994	<b>Tank Material</b>	Cathodically Protected Steel	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	High Level Alarm

<b>Tag Number</b>	1582	<b>Spill Test Date</b>	11/22/2023	<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	None	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Galvanic
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>	11/22/2023	<b>Tank/Piping CP Test Date</b>	11/22/2023	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	ELLD 0.2	<b>Vapor Recovery</b>	No
<b>Capacity</b>	4000	<b>ATG Test Date</b>	11/22/2023	<b>Line Tightness Test Date</b>	09/02/2020	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	11/22/2023			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
<b>Tank Code</b>	04	<b>Tank Age</b>	32	<b>Tank Installed Date</b>	05/24/1994	<b>Tank Material</b>	Cathodically Protected Steel	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	High Level Alarm
<b>Tag Number</b>	1583	<b>Spill Test Date</b>	11/22/2023	<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	None	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Galvanic
<b>Product</b>	Diesel	<b>PLLD Test Date</b>	11/22/2023	<b>Tank/Piping CP Test Date</b>	03/28/2024	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	ELLD 0.2	<b>Vapor Recovery</b>	No
<b>Capacity</b>	4000	<b>ATG Test Date</b>	11/22/2023	<b>Line Tightness Test Date</b>	09/26/2020	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	11/22/2023			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

### Facility Summary in Big Horn County in the City of Hardin

**Location:** TOWN AND COUNTRY SUPPLY #48  
225 W Railroad St  
Hardin, MT 59034 Big Horn

System Facility ID:02-01403

**Facility Code:** 17744  
**Last Inspected On:** 08/26/2025  
**Operating Permit Renewal Date:** 12/10/2028

**Note: Inspection is due 90 days before the Operating Permit Renewal Date.**

**Owner Operator Contact:** Town and Country Supply Association

wburley@tandcsupply.com

**Operator Contact:** Steven Shelton;Wes Burley;Town and Country Supply Association

(406) 256-1020;(406) 967-3100

sshelton@tandcsupply.com;wburley@tandcsupply.com

**Owner/Operator:** Town and Country Supply Association

wburley@tandcsupply.com

Connie Roundtree, UST Class B Global Operator  
Steven Shelton, UST Class A Operator  
Steven Shelton, UST Class B Global Operator  
Wes Burley, UST Class A Operator

croundtree@tandcsupply.com  
sshelton@tandcsupply.com  
sshelton@tandcsupply.com  
wburley@tandcsupply.com

<b>Tank Code</b>	S6	<b>Tank Age</b>	36	<b>Tank Installed Date</b>	06/01/1990	<b>Tank Material</b>	Bare Steel	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	
<b>Tag Number</b>	923	<b>Spill Test Date</b>		<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	None	<b>AST</b>	Yes
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>	08/08/2025	<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Mechanical Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	
<b>Product</b>	Diesel, Dyed	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Deferred	<b>Primary Pipe Detection</b>	MLLD Line Tightness Testing	<b>Vapor Recovery</b>	No
<b>Capacity</b>	6000	<b>ATG Test Date</b>		<b>Line Tightness Test Date</b>	08/08/2025	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>				<b>ATG Type</b>					
<b>Tank Code</b>	S7	<b>Tank Age</b>	36	<b>Tank Installed Date</b>	06/01/1990	<b>Tank Material</b>	Bare Steel	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	
<b>Tag Number</b>	924	<b>Spill Test Date</b>		<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	None	<b>AST</b>	Yes
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>	08/08/2025	<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Mechanical Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	
<b>Product</b>	Diesel	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Deferred	<b>Primary Pipe Detection</b>	MLLD Line Tightness Testing	<b>Vapor Recovery</b>	No
<b>Capacity</b>	6000	<b>ATG Test Date</b>		<b>Line Tightness Test Date</b>	08/08/2025	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>				<b>ATG Type</b>					
<b>Tank Code</b>	S8	<b>Tank Age</b>	36	<b>Tank Installed Date</b>	06/01/1990	<b>Tank Material</b>	Bare Steel	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	

<b>Tag Number</b>	925	<b>Spill Test Date</b>		<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	None	<b>AST</b>	Yes
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>	08/08/2025	<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Mechanical Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Deferred	<b>Primary Pipe Detection</b>	MLLD Line Tightness Testing	<b>Vapor Recovery</b>	No
<b>Capacity</b>	6000	<b>ATG Test Date</b>		<b>Line Tightness Test Date</b>	08/08/2025	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>				<b>ATG Type</b>					
<b>Tank Code</b>	S9	<b>Tank Age</b>	36	<b>Tank Installed Date</b>	06/01/1990	<b>Tank Material</b>	Bare Steel	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	
<b>Tag Number</b>	926	<b>Spill Test Date</b>		<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	None	<b>AST</b>	Yes
<b>Tank Status</b>	Temporarily Out of Use	<b>MLLD Test Date</b>	08/20/2019	<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Mechanical Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	
<b>Product</b>	Diesel	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Deferred	<b>Primary Pipe Detection</b>	MLLD Line Tightness Testing	<b>Vapor Recovery</b>	No
<b>Capacity</b>	6000	<b>ATG Test Date</b>		<b>Line Tightness Test Date</b>	08/20/2019	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>				<b>ATG Type</b>					

### Facility Summary in Big Horn County in the City of Hardin

**Location:** TOWN PUMP INC HARDIN  
1010 N Crawford Ave  
Hardin, MT 59034-1217 Big Horn

System Facility ID:02-08703

**Facility Code:** 17811  
**Last Inspected On:** 03/07/2024  
**Operating Permit Renewal Date:** 09/08/2027

**Note: Inspection is due 90 days before the Operating Permit Renewal Date.**

---

**Owner Operator Contact:** Hardin 1 Town Pump LLC (406) 497-6700 environmental@townpump.com

---

**Operator Contact:** Trent Biggers Trentb@townpump.com

---

**Owner/Operator:** Hardin 1 Town Pump LLC (406) 497-6700 environmental@townpump.com

Trent Biggers, UST Class A Operator

Trentb@townpump.com

Trent Biggers, UST Class B Global Operator

Trentb@townpump.com

<b>Tank Code</b>	01	<b>Tank Age</b>	42	<b>Tank Installed Date</b>	10/01/1984	<b>Tank Material</b>	Cathodically Protected Steel	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	2377	<b>Spill Test Date</b>	06/07/2021	<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Impressed Current
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>	07/20/2022	<b>Tank/Piping CP Test Date</b>	08/29/2023	<b>Primary Tank Leak Detection</b>	Statistical Inventory Reconciliation	<b>Primary Pipe Detection</b>	Statistical Inventory Reconciliation	<b>Vapor Recovery</b>	No
<b>Capacity</b>	12000	<b>ATG Test Date</b>	07/20/2022	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Energy Act</b>	No
		<b>Overfill Test Date</b>				<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-350				
<b>Tank Code</b>	02	<b>Tank Age</b>	42	<b>Tank Installed Date</b>	10/01/1984	<b>Tank Material</b>	Cathodically Protected Steel	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	2378	<b>Spill Test Date</b>	06/07/2021	<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Impressed Current
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>	07/20/2022	<b>Tank/Piping CP Test Date</b>	08/29/2023	<b>Primary Tank Leak Detection</b>	Statistical Inventory Reconciliation	<b>Primary Pipe Detection</b>	Statistical Inventory Reconciliation	<b>Vapor Recovery</b>	No
<b>Capacity</b>	12000	<b>ATG Test Date</b>	07/20/2022	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Energy Act</b>	No
		<b>Overfill Test Date</b>				<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-350				

<b>Tank Code</b>	03	<b>Tank Age</b>	42	<b>Tank Installed Date</b>	10/01/1984	<b>Tank Material</b>	Cathodically Protected Steel	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	2379	<b>Spill Test Date</b>	06/07/2021	<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Impressed Current
<b>Product</b>	Diesel	<b>PLLD Test Date</b>	07/20/2022	<b>Tank/Piping CP Test Date</b>	08/29/2024	<b>Primary Tank Leak Detection</b>	Statistical Inventory Reconciliation	<b>Primary Pipe Detection</b>	Statistical Inventory Reconciliation	<b>Vapor Recovery</b>	No
<b>Capacity</b>	12000	<b>ATG Test Date</b>	07/20/2022	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Energy Act</b>	No
		<b>Overfill Test Date</b>				<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-350				
<b>Tank Code</b>	04	<b>Tank Age</b>	45	<b>Tank Installed Date</b>	04/14/1981	<b>Tank Material</b>	Cathodically Protected Steel	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	2380	<b>Spill Test Date</b>	08/18/2021	<b>Piping Installed Date</b>		<b>Tank Construction</b>	Lined Interior/Impressed Current	<b>Piping Construction</b>	None	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Impressed Current
<b>Product</b>	Diesel	<b>PLLD Test Date</b>	07/20/2022	<b>Tank/Piping CP Test Date</b>	08/29/2023	<b>Primary Tank Leak Detection</b>	Statistical Inventory Reconciliation	<b>Primary Pipe Detection</b>	Statistical Inventory Reconciliation	<b>Vapor Recovery</b>	No
<b>Capacity</b>	10000	<b>ATG Test Date</b>	07/20/2022	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>				<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-350				
<b>Tank Code</b>	05	<b>Tank Age</b>	49	<b>Tank Installed Date</b>	01/01/1977	<b>Tank Material</b>	Cathodically Protected Steel	<b>Piping Material</b>	Steel	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	2381	<b>Spill Test Date</b>	09/10/2025	<b>Piping Installed Date</b>		<b>Tank Construction</b>	Lined Interior/Impressed Current	<b>Piping Construction</b>	Single Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>	08/05/2022	<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Mechanical Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Impressed Current
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>	07/20/2022	<b>Tank/Piping CP Test Date</b>	08/29/2023	<b>Primary Tank Leak Detection</b>	Statistical Inventory Reconciliation	<b>Primary Pipe Detection</b>	Statistical Inventory Reconciliation	<b>Vapor Recovery</b>	No
<b>Capacity</b>	6000	<b>ATG Test Date</b>	07/20/2022	<b>Line Tightness Test Date</b>	08/05/2022	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>				<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-350				
<b>Tank Code</b>	06	<b>Tank Age</b>	26	<b>Tank Installed Date</b>	05/01/2000	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Ball Float Valve
<b>Tag Number</b>	4362	<b>Spill Test Date</b>	08/18/2021	<b>Piping Installed Date</b>		<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No

<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Diesel	<b>PLLD Test Date</b>	07/20/2022	<b>Tank/Piping CP Test Date</b>	12/05/2018	<b>Primary Tank Leak Detection</b>	Statistical Inventory Reconciliation	<b>Primary Pipe Detection</b>	Statistical Inventory Reconciliation	<b>Vapor Recovery</b>	No
<b>Capacity</b>	10000	<b>ATG Test Date</b>	07/20/2022	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>	Continuous Interstitial Monitoring	<b>Secondary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Energy Act</b>	No
		<b>Overfill Test Date</b>				<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-350				
<b>Tank Code</b>	07	<b>Tank Age</b>	26	<b>Tank Installed Date</b>	05/01/2000	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Ball Float Valve
<b>Tag Number</b>	4363	<b>Spill Test Date</b>	06/07/2021	<b>Piping Installed Date</b>		<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Diesel	<b>PLLD Test Date</b>	07/20/2022	<b>Tank/Piping CP Test Date</b>	12/14/2009	<b>Primary Tank Leak Detection</b>	Statistical Inventory Reconciliation	<b>Primary Pipe Detection</b>	Statistical Inventory Reconciliation	<b>Vapor Recovery</b>	No
<b>Capacity</b>	5000	<b>ATG Test Date</b>	07/20/2022	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>	Continuous Interstitial Monitoring	<b>Secondary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Energy Act</b>	No
		<b>Overfill Test Date</b>				<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-350				
<b>Tank Code</b>	08	<b>Tank Age</b>	26	<b>Tank Installed Date</b>	05/01/2000	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	4364	<b>Spill Test Date</b>	06/07/2021	<b>Piping Installed Date</b>		<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Diesel	<b>PLLD Test Date</b>	07/20/2022	<b>Tank/Piping CP Test Date</b>	12/14/2009	<b>Primary Tank Leak Detection</b>	Statistical Inventory Reconciliation	<b>Primary Pipe Detection</b>	Statistical Inventory Reconciliation	<b>Vapor Recovery</b>	No
<b>Capacity</b>	10000	<b>ATG Test Date</b>	07/20/2022	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>	Continuous Interstitial Monitoring	<b>Secondary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	08/18/2021			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-350				

**Facility Summary in Big Horn County in the City of Hardin**

**Location:** WAGNER TRAVEL SHOPPE EXPRESS STOP  
1424 N Crawford Ave  
Hardin, MT 59034-1008 Big Horn

System Facility ID:02-04841

**Facility Code:** 17774  
**Last Inspected On:** 02/25/2026  
**Operating Permit Renewal Date:** 07/12/2026

**Note: Inspection is due 90 days before the Operating Permit Renewal Date.**

**Owner Operator Contact:** Stockton Oil Co Billings

**(406) 245-6376**

**office@stocktonoil.com**

**Operator Contact:**

**Owner/Operator:** Stockton Oil Co Billings

**(406) 245-6376**

**office@stocktonoil.com**

Christopher Stockton, UST Class B Global Operator  
Joseph Stockton, UST Class B Global Operator  
Sue Nutgens, UST Class B Operator

cstockton@stocktonoil.com  
jstockton@stocktonoil.com  
jmconnell@stocktonoil.com

<b>Tank Code</b>	07	<b>Tank Age</b>	36	<b>Tank Installed Date</b>	01/01/1990	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	Ball Float Valve;Flapper Valve
<b>Tag Number</b>	2231	<b>Spill Test Date</b>		<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	None	<b>AST</b>	No
<b>Tank Status</b>	Temporarily Out of Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Mechanical Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.1;Automatic Tank Gauging 0.2;Statistical Inventory Reconciliation	<b>Primary Pipe Detection</b>	MLLD Line Tightness Testing	<b>Vapor Recovery</b>	No
<b>Capacity</b>	10000	<b>ATG Test Date</b>		<b>Line Tightness Test Date</b>	05/26/2011	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>				<b>ATG Type</b>					
<b>Tank Code</b>	08	<b>Tank Age</b>	36	<b>Tank Installed Date</b>	01/01/1990	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	Ball Float Valve;Flapper Valve
<b>Tag Number</b>	2232	<b>Spill Test Date</b>		<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	None	<b>AST</b>	No
<b>Tank Status</b>	Temporarily Out of Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Mechanical Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible

<b>Product</b>	Gasoline	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.1;Automatic Tank Gauging 0.2;Statistical Inventory Reconciliation	<b>Primary Pipe Detection</b>	MLLD Line Tightness Testing	<b>Vapor Recovery</b>	No
<b>Capacity</b>	10000	<b>ATG Test Date</b>		<b>Line Tightness Test Date</b>	05/26/2011	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>				<b>ATG Type</b>					
<b>Tank Code</b>	09	<b>Tank Age</b>	36	<b>Tank Installed Date</b>	01/01/1990	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	Ball Float Valve;Flapper Valve
<b>Tag Number</b>	2233	<b>Spill Test Date</b>		<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	None	<b>AST</b>	No
<b>Tank Status</b>	Temporarily Out of Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Mechanical Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.1;Automatic Tank Gauging 0.2;Statistical Inventory Reconciliation	<b>Primary Pipe Detection</b>	MLLD Line Tightness Testing	<b>Vapor Recovery</b>	No
<b>Capacity</b>	6000	<b>ATG Test Date</b>		<b>Line Tightness Test Date</b>	05/26/2011	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>				<b>ATG Type</b>					
<b>Tank Code</b>	S4	<b>Tank Age</b>	47	<b>Tank Installed Date</b>	04/03/1979	<b>Tank Material</b>	Bare Steel	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	
<b>Tag Number</b>	2234	<b>Spill Test Date</b>		<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	Single Walled	<b>AST</b>	Yes
<b>Tank Status</b>	Temporarily Out of Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Mechanical Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	
<b>Product</b>	Diesel	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Deferred	<b>Primary Pipe Detection</b>	MLLD Line Tightness Testing	<b>Vapor Recovery</b>	No
<b>Capacity</b>	14000	<b>ATG Test Date</b>		<b>Line Tightness Test Date</b>	05/26/2011	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>				<b>ATG Type</b>					
<b>Tank Code</b>	S5	<b>Tank Age</b>	47	<b>Tank Installed Date</b>	04/03/1979	<b>Tank Material</b>	Bare Steel	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	
<b>Tag Number</b>	2235	<b>Spill Test Date</b>		<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	None	<b>AST</b>	Yes
<b>Tank Status</b>	Temporarily Out of Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Mechanical Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	
<b>Product</b>	Diesel	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Deferred	<b>Primary Pipe Detection</b>	MLLD Line Tightness Testing	<b>Vapor Recovery</b>	No
<b>Capacity</b>	14000	<b>ATG Test Date</b>		<b>Line Tightness Test Date</b>	05/26/2011	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No

		<b>Overfill Test Date</b>			<b>ATG Type</b>						
<b>Tank Code</b>	S6	<b>Tank Age</b>	47	<b>Tank Installed Date</b>	04/03/1979	<b>Tank Material</b>	Bare Steel	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	
<b>Tag Number</b>	2236	<b>Spill Test Date</b>		<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	None	<b>AST</b>	Yes
<b>Tank Status</b>	Temporarily Out of Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Mechanical Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	
<b>Product</b>	Diesel	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Deferred	<b>Primary Pipe Detection</b>	MLLD Line Tightness Testing	<b>Vapor Recovery</b>	No
<b>Capacity</b>	14000	<b>ATG Test Date</b>		<b>Line Tightness Test Date</b>	05/26/2011	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>				<b>ATG Type</b>					

**Facility Summary in Big Horn County in the City of Lodge Grass**

**Location:** FARMERS UNION OIL CO LODGE GRASS  
US Hwy 87  
Lodge Grass, MT 59050-0560 Big Horn

System Facility ID:02-09976

**Facility Code:** 17822  
**Last Inspected On:** 03/02/2024  
**Operating Permit Renewal Date:** 07/20/2027

**Note: Inspection is due 90 days before the Operating Permit Renewal Date.**

**Owner Operator Contact:** Farmers Union Oil Co Lodge Grass

**Operator Contact:** Debra Edwards;Farmers Union Oil Co Lodge Grass

**2FUOC@NEMONT.NET**

**Owner/Operator:** Farmers Union Oil Co Lodge Grass

Alvin Edwards, UST Class B Operator  
Darin BigMedicine, UST Class B Operator  
Debra Edwards, UST Class A Operator  
Debra Edwards, UST Class B Operator  
Lorene Flatmouth, UST Class B Operator  
Merla Mullenberg, UST Class B Operator

alvinbedwards78@yahoo.com  
dbigmedicine@facebook.com  
2FUOC@NEMONT.NET  
2FUOC@NEMONT.NET  
  
mmullenberg@hotmail.com

<b>Tank Code</b>	09	<b>Tank Age</b>	28	<b>Tank Installed Date</b>	12/01/1998	<b>Tank Material</b>	Cathodically Protected Steel	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	3603	<b>Spill Test Date</b>	02/29/2024	<b>Piping Installed Date</b>	05/09/2007	<b>Tank Construction</b>		<b>Piping Construction</b>	None	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Galvanic
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>	05/09/2024	<b>Tank/Piping CP Test Date</b>	02/29/2024	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	ELLD 0.2	<b>Vapor Recovery</b>	No
<b>Capacity</b>	10000	<b>ATG Test Date</b>	05/09/2024	<b>Line Tightness Test Date</b>	03/03/2021	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	02/29/2024			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
<b>Tank Code</b>	10	<b>Tank Age</b>	28	<b>Tank Installed Date</b>	12/01/1998	<b>Tank Material</b>	Cathodically Protected Steel	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	3604	<b>Spill Test Date</b>	02/29/2024	<b>Piping Installed Date</b>	05/09/2007	<b>Tank Construction</b>		<b>Piping Construction</b>	None	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Galvanic
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>	05/09/2024	<b>Tank/Piping CP Test Date</b>	02/29/2024	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	ELLD 0.2	<b>Vapor Recovery</b>	No
<b>Capacity</b>	4000	<b>ATG Test Date</b>	05/09/2024	<b>Line Tightness Test Date</b>	03/03/2021	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No

		<b>Overfill Test Date</b>	02/29/2024			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
<b>Tank Code</b>	11	<b>Tank Age</b>	28	<b>Tank Installed Date</b>	12/01/1998	<b>Tank Material</b>	Cathodically Protected Steel	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	3605	<b>Spill Test Date</b>	02/29/2024	<b>Piping Installed Date</b>	05/09/2007	<b>Tank Construction</b>		<b>Piping Construction</b>	None	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Galvanic
<b>Product</b>	Diesel	<b>PLLD Test Date</b>	05/09/2024	<b>Tank/Piping CP Test Date</b>	02/29/2024	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	ELLD 0.2	<b>Vapor Recovery</b>	No
<b>Capacity</b>	4000	<b>ATG Test Date</b>	05/09/2024	<b>Line Tightness Test Date</b>	03/03/2021	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	02/29/2024			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

**Facility Summary in Big Horn County in the City of Lodge Grass**

**Location:** LODGE GRASS SCHOOL DIST 27  
124 N George St  
Lodge Grass, MT 59050 Big Horn

System Facility ID:02-10772

**Facility Code:** 17826  
**Last Inspected On:** 03/15/2024  
**Operating Permit Renewal Date:** 03/15/2027

**Note: Inspection is due 90 days before the Operating Permit Renewal Date.**

**Owner Operator Contact:** School Dist 27 Lodge Grass

**(406) 639-2304**

**Operator Contact:**

**Owner/Operator:** School Dist 27 Lodge Grass

(406) 639-2304

Donald Gardner, UST Class B Global Operator  
Leroy Wallace, UST Class B Operator  
Steve Amyotte, UST Class B Operator

donald.gardner@lodgegrass.k12.mt.us

steve.amyotte@lodgegrass.k12.mt.us

<b>Tank Code</b>	02	<b>Tank Age</b>	41	<b>Tank Installed Date</b>	04/04/1985	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	4361	<b>Spill Test Date</b>		<b>Piping Installed Date</b>	10/20/2006	<b>Tank Construction</b>		<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Temporarily Out of Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Not Required	<b>Piping Type</b>	Safe Suction	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Diesel	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>	10/17/2011	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	Deferred	<b>Vapor Recovery</b>	No
<b>Capacity</b>	8000	<b>ATG Test Date</b>		<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Energy Act</b>	No
		<b>Overfill Test Date</b>				<b>ATG Type</b>	Veeder Root/TLS-300				

**Facility Summary in Big Horn County in the City of Lodge Grass**

**Location:** OUR LADY OF LORETTO CHURCH  
Harding Ave & Helen St  
Lodge Grass, MT 59050 Big Horn

System Facility ID:02-09970

**Facility Code:** 17821  
**Last Inspected On:** 11/03/2023  
**Operating Permit Renewal Date:** 02/11/2027

**Note: Inspection is due 90 days before the Operating Permit Renewal Date.**

**Owner Operator Contact:** Our Lady of Loretto Church (312) 995-0702

**Operator Contact:** Michael Dorn;Tien Dinh brmikedorn@gmail.com;tientxd@gmail.com

**Owner/Operator:** Our Lady of Loretto Church (312) 995-0702

Michael Dorn, UST Class A Operator  
Michael Dorn, UST Class B Operator  
Tien Dinh, UST Class A Operator  
Tien Dinh, UST Class B Operator

brmikedorn@gmail.com  
brmikedorn@gmail.com  
tientxd@gmail.com  
tientxd@gmail.com

<b>Tank Code</b>	S2	<b>Tank Age</b>	36	<b>Tank Installed Date</b>	07/23/1990	<b>Tank Material</b>	Cathodically Protected Steel	<b>Piping Material</b>	Copper	<b>Overfill Types</b>	High Level Alarm
<b>Tag Number</b>	1778	<b>Spill Test Date</b>	11/03/2023	<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	PVC	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Not Required	<b>Piping Type</b>	U.S. Suction	<b>CP Met Types</b>	Galvanic
<b>Product</b>	Heating Oil	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>	11/03/2023	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	3-Year Line Tightness Test	<b>Vapor Recovery</b>	No
<b>Capacity</b>	3000	<b>ATG Test Date</b>	11/03/2023	<b>Line Tightness Test Date</b>	11/03/2023	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	11/03/2023			<b>ATG Type</b>	Gilbarco/EMC Basic				

**Facility Summary in Big Horn County in the City of Pryor**

**Location:** PLENTY COUPS HIGH SCHOOL  
1 High School Ln  
Pryor, MT 59066-0229 Big Horn

System Facility ID:02-01131

**Facility Code:** 17735  
**Last Inspected On:** 07/03/2024  
**Operating Permit Renewal Date:** 08/26/2027

**Note: Inspection is due 90 days before the Operating Permit Renewal Date.**

**Owner Operator Contact:** Plenty Coups High School (406) 259-7329

**Operator Contact:** Craig Cliff;Plenty Coups High School (406) 422-7289;(406) 259-7329 craigcliff@pryorstaff.org

**Owner/Operator:** Plenty Coups High School (406) 259-7329

Craig Cliff, UST Class A Operator  
Craig Cliff, UST Class B Operator

craigcliff@pryorstaff.org  
craigcliff@pryorstaff.org

<b>Tank Code</b>	05	<b>Tank Age</b>	28	<b>Tank Installed Date</b>	06/01/1998	<b>Tank Material</b>	Cathodically Protected Steel	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	1824	<b>Spill Test Date</b>	07/03/2024	<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	None	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Not Required	<b>Piping Type</b>	Safe Suction	<b>CP Met Types</b>	Galvanic
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>	07/02/2024	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>		<b>Vapor Recovery</b>	No
<b>Capacity</b>	1000	<b>ATG Test Date</b>	07/17/2025	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	07/03/2024			<b>ATG Type</b>	Veeder Root/TLS-300				
<b>Tank Code</b>	06	<b>Tank Age</b>	28	<b>Tank Installed Date</b>	06/01/1998	<b>Tank Material</b>	Cathodically Protected Steel	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	1825	<b>Spill Test Date</b>	07/03/2024	<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	None	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Not Required	<b>Piping Type</b>	Safe Suction	<b>CP Met Types</b>	Galvanic
<b>Product</b>	Diesel	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>	07/02/2024	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>		<b>Vapor Recovery</b>	No
<b>Capacity</b>	2000	<b>ATG Test Date</b>	07/17/2025	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	07/03/2024			<b>ATG Type</b>	Veeder Root/TLS-300				

**Facility Summary in Big Horn County in the City of Pryor**

**Location:** PRYOR SELF SERVICE  
704 Mak Pua Ave  
Pryor, MT 59066 Big Horn

System Facility ID:02-10164

**Facility Code:** 17823  
**Last Inspected On:** 02/12/2026  
**Operating Permit Renewal Date:** 05/16/2029

**Note: Inspection is due 90 days before the Operating Permit Renewal Date.**

**Owner Operator Contact:** William Hoffman

**Operator Contact:** William Hoffman

**Owner/Operator:** William Hoffman

William Hoffman, UST Class A Operator

William Hoffman, UST Class B Global Operator

<b>Tank Code</b>	03	<b>Tank Age</b>	28	<b>Tank Installed Date</b>	10/01/1998	<b>Tank Material</b>	Steel Clad	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	1389	<b>Spill Test Date</b>	02/12/2026	<b>Piping Installed Date</b>		<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	None	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Not Required	<b>Piping Type</b>	Safe Suction	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>	02/04/2011	<b>Primary Tank Leak Detection</b>	Manual Interstitial Monitoring	<b>Primary Pipe Detection</b>		<b>Vapor Recovery</b>	No
<b>Capacity</b>	2000	<b>ATG Test Date</b>		<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	02/12/2026			<b>ATG Type</b>					

**Facility Summary in Big Horn County in the City of Pryor**

**Location:** SAINT CHARLES MISSION  
29 Pryor Gap Rd  
Pryor, MT 59066 Big Horn

System Facility ID:56-04505

**Facility Code:** 29917  
**Last Inspected On:** 05/09/2024  
**Operating Permit Renewal Date:** 10/09/2027

**Note: Inspection is due 90 days before the Operating Permit Renewal Date.**

**Owner Operator Contact:** St Labre Indian School (406) 784-4994 STLMAINTINV@STLABRE.ORG

**Operator Contact:** Dana Davis;Leney Mcnac ddavis@stlabre.org;lmcnac@stlabre.org

**Owner/Operator:** St Labre Indian School (406) 784-4994 STLMAINTINV@STLABRE.ORG

Dana Davis, UST Class A Operator	ddavis@stlabre.org
Dana Davis, UST Class B Global Operator	ddavis@stlabre.org
Leney Mcnac, UST Class A Operator	lmcnac@stlabre.org
Leney Mcnac, UST Class B Global Operator	lmcnac@stlabre.org

<b>Tank Code</b>	02	<b>Tank Age</b>	36	<b>Tank Installed Date</b>	08/20/1990	<b>Tank Material</b>	Cathodically Protected Steel	<b>Piping Material</b>	Steel	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	1958	<b>Spill Test Date</b>	05/09/2024	<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	None	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Not Required	<b>Piping Type</b>	Safe Suction	<b>CP Met Types</b>	Galvanic
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>	05/09/2024	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>		<b>Vapor Recovery</b>	No
<b>Capacity</b>	1000	<b>ATG Test Date</b>	05/09/2024	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	05/09/2024			<b>ATG Type</b>	Gilbarco/EMC Basic				

**Facility Summary in Big Horn County in the City of Saint Xavier**

**Location:** PRETTY EAGLE SCHOOL  
1 mi W of St Xavier  
Saint Xavier, MT 59075-0257 Big Horn

System Facility ID:02-04504

**Facility Code:** 17768  
**Last Inspected On:** 05/09/2024  
**Operating Permit Renewal Date:** 10/09/2027

**Note: Inspection is due 90 days before the Operating Permit Renewal Date.**

**Owner Operator Contact:** St Labre Indian School (406) 784-4994 STLMAINTINV@STLABRE.ORG

**Operator Contact:** Dana Davis;Leney Mcnac ddavis@stlabre.org;lmcnac@stlabre.org

**Owner/Operator:** St Labre Indian School (406) 784-4994 STLMAINTINV@STLABRE.ORG

Dana Davis, UST Class A Operator	ddavis@stlabre.org
Dana Davis, UST Class B Global Operator	ddavis@stlabre.org
Leney Mcnac, UST Class A Operator	lmcnac@stlabre.org
Leney Mcnac, UST Class B Global Operator	lmcnac@stlabre.org

<b>Tank Code</b>	03	<b>Tank Age</b>	36	<b>Tank Installed Date</b>	04/01/1990	<b>Tank Material</b>	Cathodically Protected Steel	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	1956	<b>Spill Test Date</b>	07/17/2024	<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	None	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Not Required	<b>Piping Type</b>	Safe Suction	<b>CP Met Types</b>	Galvanic
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>	05/09/2024	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>		<b>Vapor Recovery</b>	No
<b>Capacity</b>	1000	<b>ATG Test Date</b>	05/09/2024	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	05/09/2024			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-350				
<b>Tank Code</b>	S4	<b>Tank Age</b>	36	<b>Tank Installed Date</b>	04/01/1990	<b>Tank Material</b>	Cathodically Protected Steel	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	3672	<b>Spill Test Date</b>	06/17/2021	<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Temporarily Out of Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Continuous Interstitial Monitoring	<b>Piping Type</b>	U.S. Suction	<b>CP Met Types</b>	Galvanic
<b>Product</b>	Heating Oil	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>	05/09/2024	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring;MLLD Line Tightness Testing	<b>Vapor Recovery</b>	No
<b>Capacity</b>	10000	<b>ATG Test Date</b>	06/17/2021	<b>Line Tightness Test Date</b>	11/05/2013	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No

	<b>Overfill Test Date</b>	06/17/2021						
--	---------------------------	------------	--	--	--	--	--	--

			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-350				
--	--	--	-----------------	---------------------------------	--	--	--	--

**Facility Summary in Big Horn County in the City of Wyola**

**Location:** WYOLA ELEMENTARY SCHOOL  
1 Mondell Ave  
Wyola, MT 59089 Big Horn

System Facility ID:02-13762

**Facility Code:** 17853  
**Last Inspected On:** 05/02/2025  
**Operating Permit Renewal Date:** 07/12/2028

**Note: Inspection is due 90 days before the Operating Permit Renewal Date.**

**Owner Operator Contact:** School Dist 29 Wyola

**(406) 343-2722**

**Operator Contact:** Bradford Crooked Arm

**bradfordcrookedarm@gmail.com**

**Owner/Operator:** School Dist 29 Wyola

**(406) 343-2722**

Bradford Crooked Arm, UST Class A Operator

bradfordcrookedarm@gmail.com

Bradford Crooked Arm, UST Class B Global Operator

bradfordcrookedarm@gmail.com

<b>Tank Code</b>	02	<b>Tank Age</b>	27	<b>Tank Installed Date</b>	07/01/1999	<b>Tank Material</b>	Cathodically Protected Steel	<b>Piping Material</b>	Steel	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	4370	<b>Spill Test Date</b>	05/02/2025	<b>Piping Installed Date</b>	07/01/1999	<b>Tank Construction</b>		<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Not Required	<b>Piping Type</b>	Safe Suction	<b>CP Met Types</b>	Galvanic
<b>Product</b>	Diesel	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>	05/02/2025	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>		<b>Vapor Recovery</b>	No
<b>Capacity</b>	1000	<b>ATG Test Date</b>	05/02/2025	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	05/02/2025			<b>ATG Type</b>	Veeder Root/TLS-300				