

Facility Summary in Blaine County in the City of Chinook

Location: CHS BIG SKY CHINOOK
135 1st St
Chinook, MT 59523 Blaine

Legacy ID:03-10274

Facility ID: 17941
Last Inspected On: 01/07/2019
Operating Permit Renewal Date: 05/07/2022

Owner Operator Contact: Ryan Lammers;CHS - Milk River

4062652275

Operator Contact: Nick Ramberg;Steve Kleinjan;Suzanne Skoyen

4063572280

Owner/Operator: CHS Inc Inver Grove Heights

Don Cornell, UST Class B Operator
Nick Ramberg, UST Class A Operator
Nick Ramberg, UST Class B Global Operator
Steve Kleinjan, UST Class A Operator
Steve Kleinjan, UST Class B Global Operator
Steve Kleinjan, UST Class B Operator
Suzanne Skoyen, UST Class A Operator
Suzanne Skoyen, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
11	26	04/01/1995	Steel Clad	Flexible Plastic	Ball Float Valve
962	No	06/07/2013	Double-Walled	Double Walled	Yes
Currently in Use		03/09/2013	Continuous Interstitial Monitoring;Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		12/18/2012	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring	No
10,000			Gilbarco-Veeder Root/TLS-450		Yes
12	26	04/01/1995	Steel Clad	Flexible Plastic	Ball Float Valve
963	No	05/16/2016	Double-Walled	Double Walled	Yes
Currently in Use		03/09/2013	Continuous Interstitial Monitoring;Electronic Line Leak Detector	Pressurized	Galvanic

Gasoline		12/18/2012	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring	No
10,000			Gilbarco-Veeder Root/TLS-450		Yes
13	26	04/01/1995	Steel Clad	Flexible Plastic	Ball Float Valve
964	No	05/16/2016	Double-Walled	Double Walled	Yes
Currently in Use		03/09/2013	Continuous Interstitial Monitoring;Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		12/18/2012	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring	No
20,000			Gilbarco-Veeder Root/TLS-450		Yes
14	26	04/01/1995	Steel Clad	Flexible Plastic	Ball Float Valve
965	No	05/16/2016	Double-Walled	Double Walled	Yes
Currently in Use		03/09/2013	Continuous Interstitial Monitoring;Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		12/18/2012	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring	No
12,000			Gilbarco-Veeder Root/TLS-450		Yes
15	26	04/01/1995	Steel Clad	Flexible Plastic	Ball Float Valve
966	No	05/16/2016	Double-Walled	Double Walled	Yes
Currently in Use		03/09/2013	Continuous Interstitial Monitoring;Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		12/18/2012	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring	No
12,000			Gilbarco-Veeder Root/TLS-450		Yes
16	26	04/01/1995	Steel Clad	Flexible Plastic	Ball Float Valve
967	No	05/16/2016	Double-Walled	Double Walled	Yes
Currently in Use		03/09/2013	Continuous Interstitial Monitoring;Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		12/18/2012	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring	No

12,000			Gilbarco-Veeder Root/TLS-450		Yes
17	26	04/01/1995	Steel Clad	Flexible Plastic	Ball Float Valve
968	No	05/16/2016	Double-Walled	Double Walled	Yes
Currently in Use		03/09/2013	Continuous Interstitial Monitoring;Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		12/18/2012	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring;ELLD 0.2	No
12,000			Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		Yes

Facility Summary in Blaine County in the City of Chinook

Location: EZZIES WHOLESALE INC CHINOOK
40450 US Hwy 2
Chinook, MT 59523 Blaine

Legacy ID:03-07801

Facility ID: 17922
Last Inspected On: 05/11/2021
Operating Permit Renewal Date: 10/30/2024

Owner Operator Contact: Ezzies Wholesale Inc;Lawrence Poulton;Ezzies Wholesale Inc

4066542331

Operator Contact: David Skiff

4066542331

Owner/Operator: Ezzies Wholesale Inc

- David Skiff, UST Class A Operator
- David Skiff, UST Class B Global Operator
- David Skiff, UST Class B Operator
- Durwin Williams, UST Class B Operator
- Shannon Partridge, UST Class B Operator
- Sherry Ortner, UST Class B Operator
- Trisha Huestis, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
06	9	05/01/2012	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
5332	No		Double-Walled	Double Walled	Yes
Currently in Use		09/22/2011	Electronic Line Leak Detector	Pressurized	Non-corrodible

Diesel			Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	Continuous Interstitial Monitoring;ELLD 0.1;ELLD 0.2	No
10,000		03/13/2018	Gilbarco-Veeder Root/TLS- 350;Gilbarco-Veeder Root/TLS- 350/Gilbarco EMC		Yes
07	9	05/01/2012	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
5333	No		Double-Walled	Double Walled	Yes
Currently in Use		09/22/2011	Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel			Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	Continuous Interstitial Monitoring;ELLD 0.1;ELLD 0.2	No
5,000		09/03/2018	Gilbarco-Veeder Root/TLS- 350;Gilbarco-Veeder Root/TLS- 350/Gilbarco EMC		Yes
08	9	05/01/2012	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
5334	No		Double-Walled	Double Walled	Yes
Currently in Use		09/22/2011	Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel			Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	Continuous Interstitial Monitoring;ELLD 0.1;ELLD 0.2	No
10,000		07/09/2018	Gilbarco-Veeder Root/TLS- 350;Gilbarco-Veeder Root/TLS- 350/Gilbarco EMC		Yes
09	9	05/01/2012	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
5335	No		Double-Walled	Double Walled	Yes
Currently in Use		09/22/2011	Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	Continuous Interstitial Monitoring;ELLD 0.1;ELLD 0.2	No
5,000		07/09/2018	Gilbarco-Veeder Root/TLS- 350;Gilbarco-Veeder Root/TLS- 350/Gilbarco EMC		Yes
10	9	05/01/2012	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
5336	No		Double-Walled	Double Walled	Yes
Currently in Use		09/22/2011	Electronic Line Leak Detector	Pressurized	Non-corrodible

Gasoline			Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	Continuous Interstitial Monitoring;ELLD 0.1;ELLD 0.2	No
15,000		07/13/2018	Gilbarco-Veeder Root/TLS- 350;Gilbarco-Veeder Root/TLS- 350/Gilbarco EMC		Yes
11	9	05/01/2012	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
5337	No		Double-Walled	Double Walled	Yes
Currently in Use		09/22/2011	Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel			Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	Continuous Interstitial Monitoring;ELLD 0.1;ELLD 0.2	No
15,000		08/08/2018	Gilbarco-Veeder Root/TLS- 350;Gilbarco-Veeder Root/TLS- 350/Gilbarco EMC		Yes

Facility Summary in Blaine County in the City of Chinook

Location: TOWN PUMP CHINOOK
108 New York St
Chinook, MT 59523 Blaine

Legacy ID:03-08688

Facility ID: 17932
Last Inspected On: 07/24/2020
Operating Permit Renewal Date: 04/01/2022

Owner Operator Contact: Don Edmisten;Town Pump Inc Chinook

4064976948;4064976700

Operator Contact: Daniel Sampson

Daniel Sampson, UST Class A Operator
Daniel Sampson, UST Class B Global Operator
Don Edmisten, UST Class B Global Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
06	28	01/01/1993	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve;Flapper Valve
2382	No			Double Walled	Yes
Currently in Use		10/03/2012	Electronic Line Leak Detector	Pressurized	Non-corrodible

Diesel		11/28/2012	Approved Remote Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
12,000		11/03/2006	Gilbarco-Veeder Root/TLS-350		No
08	28	01/01/1993	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve;Flapper Valve
2384	No			Double Walled	Yes
Currently in Use		10/03/2012	Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline		11/28/2012	Approved Remote Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
12,000		11/03/2006	Gilbarco-Veeder Root/TLS-350		No
09	28	01/01/1993	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve;Flapper Valve
2385	No			Double Walled	Yes
Currently in Use		10/03/2012	Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline		11/28/2012	Approved Remote Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
12,000		11/03/2006	Gilbarco-Veeder Root/TLS-350		No
10	20	06/01/2001	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4354	No		Double-Walled	Double Walled	Yes
Currently in Use		10/03/2012	Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel			Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
10,000		11/05/2006	Gilbarco-Veeder Root/TLS-350		No
11	20	06/01/2001	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4355	No		Double-Walled	Double Walled	Yes
Currently in Use		10/03/2012	Electronic Line Leak Detector	Pressurized	Non-corrodible

Diesel			Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
5,000		11/05/2006	Gilbarco-Veeder Root/TLS-350		No
07	28	01/01/1993	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve;Flapper Valve
4462	No			Double Walled	Yes
Currently in Use		10/03/2012	Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel		11/28/2012	Approved Remote Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
12,000		11/03/2006	Gilbarco-Veeder Root/TLS-350		No
13	0		Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve
5914	No		Double-Walled	Double Walled	No
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Yes
6,000					Yes

Facility Summary in Blaine County in the City of Harlem

Location: E Z MART
42485 US Hwy 2
Harlem, MT 59526 Blaine

Legacy ID:03-05982

Facility ID: 17896
Last Inspected On: 01/28/2019
Operating Permit Renewal Date: 07/09/2022

Owner Operator Contact: E Z Mart

4063532335

Operator Contact: Deb Newman;Douglas McCracken

4063532335

Owner/Operator: E Z Mart

Deb Newman, UST Class A Operator
Deb Newman, UST Class B Operator
Douglas McCracken, UST Class A Operator
Douglas McCracken, UST Class B Operator
Lorna Chavez, UST Class B Global Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
-----------	-----	-----------	----------------------------	-----------------	----------------

Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
04	28	08/01/1993	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
3265	No			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		03/23/2016	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring; ELLD 0.1; ELLD 0.2	No
12,000		07/10/2009	Gilbarco/EMC Basic		No
05	28	08/01/1993	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
3266	No			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		03/23/2016	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring; ELLD 0.1; ELLD 0.2	No
12,000		12/23/2016	Gilbarco/EMC Basic		No
06	28	08/01/1993	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
3267	No			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		03/23/2016	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring; ELLD 0.1; ELLD 0.2	No
12,000		07/10/2009	Gilbarco/EMC Basic		No
07	28	08/01/1993	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
3268	No			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel, Dyed		03/23/2016	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring; ELLD 0.1; ELLD 0.2	No
12,000		07/10/2009	Gilbarco/EMC Basic		No

08	28	08/01/1993	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
3269	No			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		03/23/2016	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring; ELLD 0.1; ELLD 0.2	No
12,000		07/10/2009	Gilbarco/EMC Basic		No

Facility Summary in Blaine County in the City of Harlem

Location: FORT BELKNAP KWIKSTOP
148 Assinboine Ave
Harlem, MT 59526 Blaine

Legacy ID:03-09729

Facility ID: 17939
Last Inspected On: 11/04/2020
Operating Permit Renewal Date: 03/10/2024

Owner Operator Contact:

Operator Contact: David Skiff

4066542331

Owner/Operator: Fort Belknap Indian Community

David Skiff, UST Class A Operator
David Skiff, UST Class B Global Operator
David Skiff, UST Class B Operator
Raymond Gone, UST Class B Operator
Valerie Blackcrow, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
01	33	08/02/1988	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve
3820	No			None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		12/04/2017	Automatic Tank Gauging 0.2	ELLD 0.1; ELLD 0.2	No
10,000		06/04/2017	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
02	33	08/02/1988	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve

3821	No			None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		12/04/2017	Automatic Tank Gauging 0.2	ELLD 0.1;ELLD 0.2	No
10,000		06/09/2017	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
03	33	08/02/1988	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve
3822	No			None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		12/04/2017	Automatic Tank Gauging 0.2	ELLD 0.1;ELLD 0.2	No
6,000		11/23/2017	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
04	33	08/02/1988	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve
3823	No			None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		12/04/2017	Automatic Tank Gauging 0.2	ELLD 0.1;ELLD 0.2	No
10,000		11/27/2017	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No

Facility Summary in Blaine County in the City of Hays

Location: VALLEY GROCERY 2
US Hwy 66
Hays, MT 59527 Blaine

Legacy ID:03-07987

Facility ID: 17925
Last Inspected On:
Operating Permit Renewal Date:

Owner Operator Contact: Caroline and Harley Brown

4063532828

Operator Contact:

Owner/Operator: Caroline and Harley Brown

Owner/Operator: Harley Brown

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
06	45	05/08/1976	Bare Steel	Steel	
	No				No
Temporarily Out of Use				Not Listed	
Diesel			Not Listed	Not Listed	No
2,000					No

Facility Summary in Blaine County in the City of Turner

Location: CHS BIG SKY TURNER
US Hwy 241
Turner, MT 59542 Blaine

Legacy ID:56-13805

Facility ID: 30492
Last Inspected On: 04/22/2020
Operating Permit Renewal Date: 06/21/2023

Owner Operator Contact: CHS Inc Inver Grove Heights

8002323639

Operator Contact: Nick Ramberg;Steve Kleinjan

4063572280

Owner/Operator: CHS Inc Inver Grove Heights

- Don Cornell, UST Class B Operator
- Nick Ramberg, UST Class A Operator
- Nick Ramberg, UST Class B Global Operator
- Steve Kleinjan, UST Class A Operator
- Steve Kleinjan, UST Class B Global Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
S5	24	08/14/1997	Unknown	Flexible Plastic	
3606	Yes	05/05/2017		Double Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	
Diesel			Not Listed	Continuous Interstitial Monitoring;MLLD Line Tightness Testing	No
6,000					No
S6	24	08/14/1997	Unknown	Flexible Plastic	
3607	Yes	05/05/2017		Double Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	
Diesel			Not Listed	Continuous Interstitial Monitoring	No
6,000					No
S1	24	08/14/1997	Unknown	Flexible Plastic	
969	Yes	05/05/2017		Double Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	
Gasoline			Not Listed	Continuous Interstitial Monitoring;MLLD Line Tightness Testing	No
10,000					No
S2	24	08/14/1997	Unknown	Flexible Plastic	
970	Yes	05/05/2017		Double Walled	Yes

Currently in Use			Mechanical Line Leak Detector	Pressurized	
Diesel			Not Listed	Continuous Interstitial Monitoring;MLLD Line Tightness Testing	No
10,000					No
S3	24	08/14/1997	Unknown	Flexible Plastic	
971	Yes	05/05/2017		Double Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	
Gasoline			Not Listed	Continuous Interstitial Monitoring;MLLD Line Tightness Testing	No
10,000					No
S4	24	08/14/1997	Unknown	Flexible Plastic	
972	Yes	05/05/2017		Double Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	
Diesel			Not Listed	Continuous Interstitial Monitoring	No
6,000					No

Facility Summary in Blaine County in the City of Turner

Location: EZZIES TURNER BULK PLANT
30153 Turner Road
Turner, MT 59542 Blaine

Legacy ID:60-15345

Facility ID: 32423
Last Inspected On: 02/26/2021
Operating Permit Renewal Date: 04/25/2024

Owner Operator Contact: Ezzies Wholesale Inc

Operator Contact: David Skiff

4066542331

Owner/Operator: Ezzies Wholesale Inc

David Jones, UST Class B Operator
David Skiff, UST Class A Operator
David Skiff, UST Class B Global Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types

Product	Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity	Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
1	0	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve;High Level Alarm
5972	No	Double-Walled	Double Walled	No
Currently in Use		Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline		Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	Continuous Interstitial Monitoring;ELLD 0.1;ELLD 0.2	Yes
8,000				Yes
2	0	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve;High Level Alarm
5973	No	Double-Walled	Double Walled	No
Currently in Use		Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline		Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	Continuous Interstitial Monitoring;ELLD 0.1;ELLD 0.2	Yes
4,000				Yes
3	0	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve;High Level Alarm
5974	No	Double-Walled	Double Walled	No
Currently in Use		Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel		Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	Continuous Interstitial Monitoring;ELLD 0.1;ELLD 0.2	No
8,000				Yes
4	0	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve;High Level Alarm
5975	No	Double-Walled	Double Walled	No
Currently in Use		Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel		Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	Continuous Interstitial Monitoring;ELLD 0.1;ELLD 0.2	No
4,000				Yes

5	0	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve;High Level Alarm
5976	No	Double-Walled	Double Walled	No
Currently in Use		Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel		Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	Continuous Interstitial Monitoring;ELLD 0.1;ELLD 0.2	No
8,000				Yes
6	0	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve;High Level Alarm
5977	No	Double-Walled	Double Walled	No
Currently in Use		Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel		Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	Continuous Interstitial Monitoring;ELLD 0.1;ELLD 0.2	No
4,000				Yes