

Facility Summary in Broadwater County in the City of Townsend

Location: ROCKY MOUNTAIN SUPPLY INC TOWNSEND
310 S Front St
Townsend, MT 59644-2518 Broadwater

Legacy ID:04-07862

Facility ID: 18051
Last Inspected On: 12/12/2018
Operating Permit Renewal Date: 04/15/2022

Owner Operator Contact: Brad Gjermo;Rocky Mountain Supply Inc;Rocky Mountain Supply Inc

4063884009

Operator Contact: Jason Rorabaugh

4063884008

Owner/Operator: Rocky Mountain Supply Inc

Jason Rorabaugh, UST Class A Operator

Robert Michael, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
10	26	04/01/1995	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve
4298	No			None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		12/12/2018	Automatic Tank Gauging 0.2	ELLD 0.1;ELLD 0.2	No
4,000		11/20/2018	Veeder Root/TLS-450		No
08	26	04/01/1995	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve
4299	No			None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		12/12/2018	Automatic Tank Gauging 0.2	ELLD 0.1;ELLD 0.2	No
4,000		11/14/2018	Veeder Root/TLS-450		No
09	26	04/01/1995	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve
4300	No			None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic

Diesel		12/12/2018	Automatic Tank Gauging 0.2	ELLD 0.1;ELLD 0.2	No
8,000		11/16/2018	Veeder Root/TLS-450		No
07	26	04/01/1995	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve
4301	No			None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		12/12/2018	Automatic Tank Gauging 0.2	ELLD 0.1;ELLD 0.2	No
8,000		11/22/2018	Veeder Root/TLS-450		No
11	9	08/01/2012	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve
5382	No	11/07/2012	Double-Walled	Double Walled	Yes
Currently in Use		07/27/2012	Electronic Line Leak Detector	Pressurized	
Gasoline			Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	Continuous Interstitial Monitoring;ELLD 0.1;ELLD 0.2	No
12,000			Veeder Root/TLS-450		Yes
12	9	08/01/2012	Fiberglass Reinforced Plastic	Flexible Plastic	Positive Shutoff
5383	No	11/07/2012	Double-Walled	Double Walled	Yes
Currently in Use		07/27/2012	Electronic Line Leak Detector	Pressurized	
Diesel			Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	Continuous Interstitial Monitoring;ELLD 0.1;ELLD 0.2	No
12,000			Veeder Root/TLS-450		Yes

Facility Summary in Broadwater County in the City of Townsend

Location: TOWN PUMP INC TOWNSEND
202 N Front St
Townsend, MT 59644-2202 Broadwater

Legacy ID:04-03456

Facility ID: 17999
Last Inspected On: 07/07/2021
Operating Permit Renewal Date: 10/27/2024

Owner Operator Contact: Don Edmisten;Town Pump Townsend Inc

4064976948;4064976700

Operator Contact: Trent Biggers

Owner/Operator: Townsend 1 Town Pump LLC

Trent Biggers, UST Class A Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
07	26	03/15/1995	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve;Flapper Valve
2386	No		Double-Walled	Double Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Approved Remote Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Yes
10,000		07/16/2015	Gilbarco-Veeder Root/TLS-350		No
08	26	03/15/1995	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve;Flapper Valve
2387	No		Double-Walled	Double Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Non-corrodible
Diesel			Approved Remote Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
10,000		07/16/2015	Gilbarco-Veeder Root/TLS-350		No
09	26	03/15/1995	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve;Flapper Valve
2388	No		Double-Walled	Double Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Approved Remote Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Yes
12,000		07/16/2015	Gilbarco-Veeder Root/TLS-350		No
10	26	03/15/1995	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve;Flapper Valve

2389	No		Double-Walled	Double Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Approved Remote Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Yes
12,000		07/16/2015	Gilbarco-Veeder Root/TLS-350		No
11	8	07/01/2013	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
5428	No	08/15/2013	Double-Walled	Double Walled	Yes
Currently in Use		06/28/2013	Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel			Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
6,000			Gilbarco-Veeder Root/TLS-350		Yes
12	8	07/01/2013	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
5429	No	08/15/2013	Double-Walled	Double Walled	Yes
Currently in Use		06/28/2013	Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel			Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
6,000			Gilbarco-Veeder Root/TLS-350		Yes

Facility Summary in Broadwater County in the City of Winston

Location: WINSTON STORE
6473 US Hwy 287
Winston, MT 59647 Broadwater

Legacy ID:04-00280

Facility ID: 17957
Last Inspected On: 06/28/2020
Operating Permit Renewal Date:

Owner Operator Contact: Allen Brewer

4062275597

Operator Contact: Allen Brewer

4062277080

Owner/Operator: Allen Brewer

Allen Brewer, UST Class A Operator
Allen Brewer, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
-----------	-----	-----------	----------------------------	-----------------	----------------

Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
03	28	09/01/1993	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve
3152	No			None	Yes
Temporarily Out of Use			Not Required	Safe Suction	Galvanic
Gasoline		07/17/2017	Automatic Tank Gauging 0.1;Automatic Tank Gauging 0.2	Not Listed	No
1,000					No
04	28	09/01/1993	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve
3153	No			None	Yes
Temporarily Out of Use			Not Required	Safe Suction	Galvanic
Diesel		07/17/2017	Automatic Tank Gauging 0.1;Automatic Tank Gauging 0.2	Not Listed	No
1,000					No