

Facility Summary in Carbon County in the City of Belfry

Location: SALTAS BIG COUNTRY GARAGE
322 Broadway Avenue
Belfry, MT 59008 Carbon

System Facility ID:05-02954

Facility Code: 18153
Last Inspected On: 05/09/2025
Operating Permit Renewal Date: 05/08/2028

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Stephen Salta (702) 496-8356 eviesalta@gmail.com

Operator Contact: Stephen Salta (702) 496-8356 eviesalta@gmail.com

Owner/Operator: Stephen Salta (702) 496-8356 eviesalta@gmail.com

Stephen Salta, UST Class A Operator

eviesalta@gmail.com

Stephen Salta, UST Class B Global Operator

eviesalta@gmail.com

Tank Code	S8	Tank Age	33	Tank Installed Date	05/01/1993	Tank Material	Bare Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	
Tag Number	449	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	Yes
Tank Status	Temporarily Out of Use	MLLD Test Date	01/09/2019	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection		Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	1000	ATG Test Date		Line Tightness Test Date	01/09/2019	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					
Tank Code	S9	Tank Age	33	Tank Installed Date	05/01/1993	Tank Material	Bare Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	
Tag Number	450	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	Yes
Tank Status	Temporarily Out of Use	MLLD Test Date	01/09/2019	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection		Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	1000	ATG Test Date		Line Tightness Test Date	01/09/2019	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					

Facility Summary in Carbon County in the City of Bridger

Location: ESSENTIAL FUELS
US Highway 310
Bridger, MT 59014 Carbon

System Facility ID:00-32519

Facility Code: 32519
Last Inspected On: 11/08/2024
Operating Permit Renewal Date: 11/08/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Eric Reichert (308) 633-3595

Operator Contact: Paul Moe (406) 425-3848 paul.moe29@gmail.com

Owner/Operator: Eric Reichert (308) 633-3595

Paul Moe, UST Class A Operator
Paul Moe, UST Class B Operator

paul.moe29@gmail.com
paul.moe29@gmail.com

Tank Code	01	Tank Age	3	Tank Installed Date	08/01/2023	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	6163	Spill Test Date	04/02/2024	Piping Installed Date	08/01/2023	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	15000	ATG Test Date	05/14/2024	Line Tightness Test Date	05/22/2024	Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	05/14/2024			ATG Type					
Tank Code	02	Tank Age	3	Tank Installed Date	08/01/2023	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	6164	Spill Test Date	04/02/2024	Piping Installed Date	08/01/2023	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Diesel, Dyed	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	10000	ATG Test Date	05/14/2024	Line Tightness Test Date	05/22/2024	Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	05/14/2024			ATG Type					
Tank Code	03	Tank Age	3	Tank Installed Date	08/01/2023	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve

Tag Number	6165	Spill Test Date	04/02/2024	Piping Installed Date	08/01/2023	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	Yes
Capacity	25000	ATG Test Date	05/14/2024	Line Tightness Test Date	05/22/2024	Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	05/14/2024			ATG Type					
Tank Code	04	Tank Age	3	Tank Installed Date	08/01/2023	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	
Tag Number	6166	Spill Test Date		Piping Installed Date	08/01/2023	Tank Construction		Piping Construction		AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0		Piping Type	Pressurized	CP Met Types	
Product	DEF (Not Regulated)	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection		Primary Pipe Detection		Vapor Recovery	No
Capacity	8000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	Yes
		Overfill Test Date				ATG Type					
Tank Code	05	Tank Age	3	Tank Installed Date	08/01/2023	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	6167	Spill Test Date	04/02/2024	Piping Installed Date	08/01/2023	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	12000	ATG Test Date	05/14/2024	Line Tightness Test Date	05/22/2024	Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	05/14/2024			ATG Type					
Tank Code	06	Tank Age	3	Tank Installed Date	08/01/2023	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	6168	Spill Test Date	04/02/2024	Piping Installed Date	08/01/2023	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	20000	ATG Test Date	05/14/2024	Line Tightness Test Date	05/22/2024	Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	05/14/2024			ATG Type					

Facility Summary in Carbon County in the City of Bridger

Location: TOWN AND COUNTRY SUPPLY BRIDGER
209 N Main St
Bridger, MT 59014 Carbon

System Facility ID:05-04498

Facility Code: 18171
Last Inspected On: 11/29/2023
Operating Permit Renewal Date: 05/03/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Town and Country Supply Association

wburley@tandcsupply.com

Operator Contact: Landon Van Valkenburgh;Town and Country Supply Association;Steven Shelton;Wesley Burley

(406) 967-3100

ivanvalkenburgh@tandcsupply.onmicrosoft.com;wburley@tandcsupply.com;sshelton@tandcsupply.com;wburley@tandcsupply.com

Owner/Operator: Town and Country Supply Association

wburley@tandcsupply.com

Landon Van Valkenburgh, UST Class A Operator
Landon Van Valkenburgh, UST Class B Operator
Melvin Hanley, UST Class B Operator
Steven Shelton, UST Class A Operator
Steven Shelton, UST Class B Global Operator
Wesley Burley, UST Class A Operator

wburley@tandcsupply.com
wburley@tandcsupply.com
wburley@tandcsupply.com
sshelton@tandcsupply.com
sshelton@tandcsupply.com
wburley@tandcsupply.com

Tank Code	06	Tank Age	36	Tank Installed Date	05/18/1990	Tank Material	Steel Clad	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	1515	Spill Test Date	11/29/2023	Piping Installed Date	08/13/2010	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	07/21/2021	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	07/13/2023	Tank/Piping CP Test Date	11/29/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	4000	ATG Test Date	07/13/2023	Line Tightness Test Date	04/22/2018	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	11/29/2023			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	07	Tank Age	36	Tank Installed Date	05/18/1990	Tank Material	Steel Clad	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	1516	Spill Test Date	11/29/2023	Piping Installed Date	08/13/2010	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	07/21/2021	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	07/13/2023	Tank/Piping CP Test Date	11/29/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No

Capacity	4000	ATG Test Date	07/13/2023	Line Tightness Test Date	04/22/2018	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	11/29/2023			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	08	Tank Age	36	Tank Installed Date	05/18/1990	Tank Material	Steel Clad	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	1517	Spill Test Date	11/29/2023	Piping Installed Date	08/13/2010	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	07/21/2021	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	07/13/2023	Tank/Piping CP Test Date	11/29/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	4000	ATG Test Date	07/13/2023	Line Tightness Test Date	04/20/2018	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	11/29/2023			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	09	Tank Age	23	Tank Installed Date	07/01/2003	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	4849	Spill Test Date	03/26/2024	Piping Installed Date	08/13/2010	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	07/21/2021	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date	07/13/2023	Tank/Piping CP Test Date	11/29/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	2000	ATG Test Date	07/13/2023	Line Tightness Test Date	04/20/2018	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	03/26/2024			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Carbon County in the City of Joliet

Location: CARBON COUNTY DIST 2 SHOP
201 State St
Joliet, MT 59041 Carbon

System Facility ID:05-01853

Facility Code: 18140
Last Inspected On: 10/17/2024
Operating Permit Renewal Date: 02/23/2028

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Carbon County Road Dist (406) 446-1595

Operator Contact: Tim Blair;Carbon County Road Dist (406) 672-0724;(406) 446-1595 tblair@co.carbon.mt.us

Owner/Operator: Carbon County Road Dist (406) 446-1595

Tim Blair, UST Class A Operator tblair@co.carbon.mt.us
Tim Blair, UST Class B Global Operator tblair@co.carbon.mt.us

Tank Code	03	Tank Age	34	Tank Installed Date	01/30/1992	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	518	Spill Test Date	10/17/2024	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	10/17/2024	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection		Vapor Recovery	No
Capacity	1000	ATG Test Date	10/17/2024	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	10/17/2024			ATG Type	Gilbarco/EMC Basic				
Tank Code	04	Tank Age	34	Tank Installed Date	01/30/1992	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	519	Spill Test Date	10/17/2024	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	10/17/2024	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection		Vapor Recovery	No
Capacity	1000	ATG Test Date	10/17/2024	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	10/17/2024			ATG Type	Gilbarco/EMC Basic				

Facility Summary in Carbon County in the City of Joliet

Location: CONOMART 80178
110 E Front St
Joliet, MT 59041 Carbon

System Facility ID:05-05577

Facility Code: 18186
Last Inspected On: 01/07/2026
Operating Permit Renewal Date: 04/22/2029

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Parkland USA Corporation

jake.thomas@sunoco.com

Operator Contact: Jake Thomas;Parkland USA Corporation

jake.thomas@sunoco.com;jake.thomas@sunoco.com

Owner/Operator: Parkland USA Corporation

jake.thomas@sunoco.com

Jake Thomas, UST Class A Operator
Jake Thomas, UST Class B Operator

jake.thomas@sunoco.com
jake.thomas@sunoco.com

Tank Code	03	Tank Age	39	Tank Installed Date	02/22/1987	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	3925	Spill Test Date	01/07/2026	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date	01/07/2026	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	01/07/2026	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	4000	ATG Test Date	01/07/2026	Line Tightness Test Date	01/07/2026	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	01/07/2026			ATG Type	Gilbarco/EMC Basic				
Tank Code	04	Tank Age	38	Tank Installed Date	02/22/1988	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	3926	Spill Test Date	01/07/2026	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date	01/07/2026	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Diesel, Dyed	PLLD Test Date		Tank/Piping CP Test Date	01/07/2026	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	1500	ATG Test Date	01/07/2026	Line Tightness Test Date	01/07/2026	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	01/07/2026			ATG Type	Gilbarco/EMC Basic				
Tank Code	05	Tank Age	38	Tank Installed Date	02/22/1988	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	3927	Spill Test Date	03/25/2026	Piping Installed Date		Tank Construction		Piping Construction	Single Walled	AST	No

Tank Status	Currently in Use	MLLD Test Date	01/07/2026	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	01/07/2026	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	2500	ATG Test Date	01/07/2026	Line Tightness Test Date	01/07/2026	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	03/27/2026			ATG Type	Gilbarco/EMC Basic				
Tank Code	06	Tank Age	27	Tank Installed Date	02/01/1999	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	3928	Spill Test Date	01/07/2026	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date	01/07/2026	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	01/07/2026	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	8000	ATG Test Date	01/07/2026	Line Tightness Test Date	01/07/2026	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	01/07/2026			ATG Type	Gilbarco/EMC Basic				

Facility Summary in Carbon County in the City of Joliet

Location: JOLIET SCHOOL DIST 7
 131 N Main St
 Joliet, MT 59041 Carbon

System Facility ID:05-05353

Facility Code: 18183
Last Inspected On: 01/07/2026
Operating Permit Renewal Date: 01/07/2029

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: School Dist 7 Joliet

Operator Contact: Samuel Smith

ssmith@joliet.k12.mt.us

Owner/Operator: School Dist 7 Joliet

Samuel Smith, UST Class A Operator
 Samuel Smith, UST Class B Operator

ssmith@joliet.k12.mt.us
ssmith@joliet.k12.mt.us

Tank Code	02	Tank Age	27	Tank Installed Date	07/01/1999	Tank Material	Steel Clad	Piping Material	Steel	Overfill Types	Flapper Valve
Tag Number	4091	Spill Test Date	01/07/2026	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Manual Interstitial Monitoring	Primary Pipe Detection		Vapor Recovery	No
Capacity	1000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	01/07/2026			ATG Type					

Facility Summary in Carbon County in the City of Joliet

Location: ROCKVALE TRAVEL PLAZA UST
4293 US Hwy 310
Joliet, MT 59041 Carbon

System Facility ID:05-07633

Facility Code: 18210
Last Inspected On: 08/10/2023
Operating Permit Renewal Date: 08/13/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Thomas McNew;Tom McNew

tom.mcnew59041@gmail.com

Operator Contact: Thomas McNew

tom.mcnew59041@gmail.com

Owner/Operator: Thomas McNew

tom.mcnew59041@gmail.com

Owner/Operator: Tom McNew

tom.mcnew59041@gmail.com

Thomas McNew, UST Class A Operator

tom.mcnew59041@gmail.com

Thomas McNew, UST Class B Global Operator

tom.mcnew59041@gmail.com

Tank Code	06	Tank Age	27	Tank Installed Date	07/01/1999	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	4112	Spill Test Date	08/10/2023	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date	01/25/2023	Tank/Piping CP Test Date	08/10/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	12000	ATG Test Date	01/25/2023	Line Tightness Test Date	02/25/2023	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	01/25/2023			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	07	Tank Age	27	Tank Installed Date	07/01/1999	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	4113	Spill Test Date	08/10/2023	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date	01/25/2023	Tank/Piping CP Test Date	08/10/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	10000	ATG Test Date	01/25/2023	Line Tightness Test Date	08/04/2023	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	01/25/2023			ATG Type	Gilbarco/EMC Basic				

Tank Code	08	Tank Age	27	Tank Installed Date	07/01/1999	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	4114	Spill Test Date	08/10/2023	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date	01/25/2023	Tank/Piping CP Test Date	08/10/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	10000	ATG Test Date	01/25/2023	Line Tightness Test Date	08/08/2023	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	01/25/2023			ATG Type	Gilbarco/EMC Basic				

Facility Summary in Carbon County in the City of Joliet

Location: TOWN OF JOLIET
 116 S Main St
 Joliet, MT 59041 Carbon

System Facility ID:05-00189

Facility Code: 18119
Last Inspected On: 02/25/2026
Operating Permit Renewal Date: 05/16/2029

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Town of Joliet (406) 962-3567 townofjoliet@gmail.com

Operator Contact: Dale Limberhand lockedout2001@yahoo.com

Owner/Operator: Town of Joliet (406) 962-3567 townofjoliet@gmail.com

Dale Limberhand, UST Class A Operator lockedout2001@yahoo.com
 Dale Limberhand, UST Class B Operator lockedout2001@yahoo.com

Tank Code	02	Tank Age	29	Tank Installed Date	09/01/1997	Tank Material	Steel Clad	Piping Material	Steel	Overfill Types	Flapper Valve
Tag Number	2127	Spill Test Date	02/25/2026	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	02/25/2026	Primary Tank Leak Detection	Manual Interstitial Monitoring	Primary Pipe Detection		Vapor Recovery	No
Capacity	560	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	02/25/2026			ATG Type					

Facility Summary in Carbon County in the City of Red Lodge

Location: 6 ASSISTED LLC
600 21st St W
Red Lodge, MT 59068 Carbon

System Facility ID:05-09926

Facility Code: 18235
Last Inspected On: 10/02/2017
Operating Permit Renewal Date: 10/02/2020

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: 6 Assisted LLC Jamaica (917) 635-8856

Operator Contact: Bob Miner

minerb@beartoothhospital.org

Owner/Operator: 6 Assisted LLC Jamaica (917) 635-8856

Bob Miner, UST Class A Operator

minerb@beartoothhospital.org

Tank Code	02	Tank Age	28	Tank Installed Date	10/08/1998	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	3103	Spill Test Date		Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Temporarily Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	08/04/2010	Primary Tank Leak Detection	Not Listed	Primary Pipe Detection	Not Listed	Vapor Recovery	No
Capacity	1000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					

Facility Summary in Carbon County in the City of Red Lodge

Location: CENEX ZIP TRIP 74
902 N Broadway Ave
Red Lodge, MT 59068 Carbon

System Facility ID:56-13935

Facility Code: 30605
Last Inspected On: 01/14/2025
Operating Permit Renewal Date: 05/15/2028

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: CHS Inc Spokane Valley (509) 535-7701 jim.alford@chsinc.com

Operator Contact: Jim Alford;Sean Hurley (509) 535-7701;(509) 536-7418 jim.alford@chsinc.com;sean.hurley@chsinc.com

Owner/Operator: CHS Inc Spokane Valley (509) 535-7701 jim.alford@chsinc.com

Hannah Smith, UST Class B Operator hannah.smith3@chsinc.com
 Jim Alford, UST Class A Operator jim.alford@chsinc.com
 Jim Alford, UST Class B Operator jim.alford@chsinc.com
 Luci Tuttle, UST Class B Operator Lucinda.Tuttle@chsinc.com
 Sean Hurley, UST Class A Operator sean.hurley@chsinc.com

Tank Code	05	Tank Age	11	Tank Installed Date	04/10/2015	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	5566	Spill Test Date	01/14/2025	Piping Installed Date	04/10/2015	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	07/14/2020	Catastrophic L.D Type 3.0	Auto Dialer;Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	06/19/2025	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	15000	ATG Test Date	06/19/2025	Line Tightness Test Date	04/13/2015	Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	06/19/2025			ATG Type	Gilbarco-Veeder Root/TLS-350;Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	06	Tank Age	11	Tank Installed Date	04/10/2015	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	5567	Spill Test Date	01/14/2025	Piping Installed Date	04/10/2015	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No

Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	07/14/2020	Catastrophic L.D Type 3.0	Auto Dialer;Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	06/19/2025	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	8000	ATG Test Date	06/19/2025	Line Tightness Test Date	04/13/2015	Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	06/19/2025			ATG Type	Gilbarco-Veeder Root/TLS-350;Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	07	Tank Age	11	Tank Installed Date	04/10/2015	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	5568	Spill Test Date	01/14/2025	Piping Installed Date	04/10/2015	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	07/14/2020	Catastrophic L.D Type 3.0	Auto Dialer;Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	06/19/2025	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	7000	ATG Test Date	06/19/2025	Line Tightness Test Date	04/13/2015	Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	06/19/2025			ATG Type	Gilbarco-Veeder Root/TLS-350;Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	08	Tank Age	11	Tank Installed Date	04/10/2015	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	5569	Spill Test Date	01/14/2025	Piping Installed Date	04/10/2015	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	07/14/2020	Catastrophic L.D Type 3.0	Auto Dialer;Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel, Dyed	PLLD Test Date	06/19/2025	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	4000	ATG Test Date	06/19/2025	Line Tightness Test Date	04/13/2015	Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes

		Overfill Test Date	06/19/2025			ATG Type	Gilbarco-Veeder Root/TLS- 350;Gilbarco- Veeder Root/TLS- 350/Gilbarco EMC				
--	--	---------------------------	------------	--	--	-----------------	---	--	--	--	--

Facility Summary in Carbon County in the City of Red Lodge

Location: CIRCLE 17
1022 S Adams Ave
Red Lodge, MT 59068-9578 Carbon

System Facility ID:05-09748

Facility Code: 18233
Last Inspected On: 11/29/2023
Operating Permit Renewal Date: 03/05/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Circle 17 LLC;Mackenzie Alexander (406) 425-0395 circle17@outlook.com

Operator Contact: Mackenzie Alexander;Stephen Alexander (406) 425-0395;(406) 425-3997 circle17@outlook.com;madcap91@live.com

Owner/Operator: Circle 17 LLC (406) 425-0395 circle17@outlook.com
Owner/Operator: Mackenzie Alexander (406) 425-0395 circle17@outlook.com
 Mackenzie Alexander, UST Class A Operator circle17@outlook.com
 Mackenzie Alexander, UST Class B Operator circle17@outlook.com
 Stephen Alexander, UST Class A Operator madcap91@live.com
 Stephen Alexander, UST Class B Operator madcap91@live.com

Tank Code	04	Tank Age	30	Tank Installed Date	07/01/1996	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	3389	Spill Test Date	11/29/2023	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date	03/17/2023	Tank/Piping CP Test Date	11/29/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	8000	ATG Test Date	03/17/2023	Line Tightness Test Date	02/01/2021	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	03/17/2023			ATG Type	Gilbarco/EMC Basic				
Tank Code	05	Tank Age	30	Tank Installed Date	07/01/1996	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	3390	Spill Test Date	11/29/2023	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date	03/17/2023	Tank/Piping CP Test Date	11/29/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	4000	ATG Test Date	03/17/2023	Line Tightness Test Date	02/03/2021	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	03/17/2023			ATG Type	Gilbarco/EMC Basic				

Facility Summary in Carbon County in the City of Red Lodge

Location: TOWN PUMP OF RED LODGE
710 N Broadway
Red Lodge, MT 59068 Carbon

System Facility ID:60-15212

Facility Code: 30932
Last Inspected On: 02/29/2024
Operating Permit Renewal Date: 08/09/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Red Lodge 1 Town Pump LLC

(406) 497-6700

environmental@townpump.com

Operator Contact: Trent Biggers

Trentb@townpump.com

Owner/Operator: Red Lodge 1 Town Pump LLC

(406) 497-6700

environmental@townpump.com

Trent Biggers, UST Class A Operator

Trentb@townpump.com

Trent Biggers, UST Class B Global Operator

Trentb@townpump.com

Tank Code	01	Tank Age	13	Tank Installed Date	01/16/2013	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	5377	Spill Test Date	08/23/2023	Piping Installed Date	01/16/2013	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	08/23/2023	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	02/29/2024	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	Yes
Capacity	20000	ATG Test Date	06/05/2024	Line Tightness Test Date		Secondary Tank Leak Detection	Statistical Inventory Reconciliation	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	Yes
		Overfill Test Date	08/23/2023			ATG Type	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Code	02	Tank Age	13	Tank Installed Date	01/16/2013	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	5378	Spill Test Date	08/23/2023	Piping Installed Date	01/16/2013	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	08/23/2023	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	02/29/2024	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	14000	ATG Test Date	06/05/2024	Line Tightness Test Date		Secondary Tank Leak Detection	Statistical Inventory Reconciliation	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	Yes

		Overfill Test Date	08/23/2023			ATG Type	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Code	03	Tank Age	13	Tank Installed Date	01/16/2013	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	5379	Spill Test Date	08/23/2023	Piping Installed Date	01/16/2013	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	08/23/2023	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	02/29/2024	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	6000	ATG Test Date	06/05/2024	Line Tightness Test Date		Secondary Tank Leak Detection	Statistical Inventory Reconciliation	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	Yes
		Overfill Test Date	08/23/2023			ATG Type	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Code	04	Tank Age	13	Tank Installed Date	01/16/2013	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	5380	Spill Test Date	06/14/2021	Piping Installed Date	01/16/2013	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	07/19/2022	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	12000	ATG Test Date	06/05/2024	Line Tightness Test Date		Secondary Tank Leak Detection	Statistical Inventory Reconciliation	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	Yes
		Overfill Test Date	06/14/2021			ATG Type	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Code	05	Tank Age	13	Tank Installed Date	01/16/2013	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	5381	Spill Test Date	08/03/2021	Piping Installed Date	01/16/2013	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	07/19/2022	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	8000	ATG Test Date	06/05/2024	Line Tightness Test Date		Secondary Tank Leak Detection	Statistical Inventory Reconciliation	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	Yes
		Overfill Test Date	06/14/2021			ATG Type	Gilbarco-Veeder Root/TLS-450PLUS				

Tank Code	06	Tank Age	9	Tank Installed Date	05/23/2017	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	5800	Spill Test Date	06/14/2021	Piping Installed Date	05/23/2017	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	07/19/2022	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	Yes
Capacity	6000	ATG Test Date	06/05/2024	Line Tightness Test Date		Secondary Tank Leak Detection	Statistical Inventory Reconciliation	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	Yes
		Overfill Test Date	06/14/2021			ATG Type	Gilbarco-Veeder Root/TLS-450PLUS				

Facility Summary in Carbon County in the City of Roberts

Location: Y STOP C STORE INC
4 Cooney Rd
Roberts, MT 59070 Carbon

System Facility ID:05-06599

Facility Code: 18197
Last Inspected On: 08/23/2023
Operating Permit Renewal Date: 02/20/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Melton Enterprises Inc (406) 426-0135 robertsystop@aol.com

Operator Contact: Rodney Melton robertsystop@aol.com

Owner/Operator: Melton Enterprises Inc (406) 426-0135 robertsystop@aol.com

Rodney Melton, UST Class A Operator robertsystop@aol.com
Rodney Melton, UST Class B Operator robertsystop@aol.com

Tank Code	05	Tank Age	34	Tank Installed Date	06/20/1992	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	3329	Spill Test Date	07/28/2023	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Temporarily Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	07/28/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection		Vapor Recovery	No
Capacity	5000	ATG Test Date	07/28/2023	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	07/28/2023			ATG Type	Veeder Root/TLS-300				
Tank Code	06	Tank Age	34	Tank Installed Date	06/20/1992	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	3330	Spill Test Date	07/28/2023	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Temporarily Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	07/28/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection		Vapor Recovery	No
Capacity	3000	ATG Test Date	07/28/2023	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	07/28/2023			ATG Type	Veeder Root/TLS-300				
Tank Code	07	Tank Age	34	Tank Installed Date	06/20/1992	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	3331	Spill Test Date	07/28/2023	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No

Tank Status	Temporarily Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	07/28/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection		Vapor Recovery	No
Capacity	3000	ATG Test Date	07/28/2023	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	07/28/2023			ATG Type	Veeder Root/TLS-300				
Tank Code	08	Tank Age	34	Tank Installed Date	06/20/1992	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	3332	Spill Test Date	07/28/2023	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Temporarily Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	07/28/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection		Vapor Recovery	No
Capacity	5000	ATG Test Date	07/28/2023	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	07/28/2023			ATG Type	Veeder Root/TLS-300				