

Facility Summary in Carbon County in the City of Belfry

Location: BLACKS SERVICE STATION
332 Broadway Ave
Belfry, MT 59008 Carbon

Legacy ID:05-02954

Facility ID: 18153
Last Inspected On: 01/09/2019
Operating Permit Renewal Date: 06/08/2022

Owner Operator Contact: Earl Black;Earl Black;Blacks Bulk Service

4066643289

Operator Contact: Louise Black

4066643289

Owner/Operator: Earl Black

Louise Black, UST Class A Operator

Louise Black, UST Class B Global Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
S8	28	05/01/1993	Bare Steel	Fiberglass Reinforced Plastic	
449	Yes			None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	
Diesel			Deferred	MLLD Line Tightness Testing	No
1,000		01/09/2019			No
S9	28	05/01/1993	Bare Steel	Fiberglass Reinforced Plastic	
450	Yes			None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	
Gasoline			Deferred	MLLD Line Tightness Testing	No
1,000		01/09/2019			No

Facility Summary in Carbon County in the City of Bridger

Location: TOWN and COUNTRY SUPPLY BRIDGER
209 N Main St
Bridger, MT 59014 Carbon

Legacy ID:05-04498

Facility ID: 18171
Last Inspected On: 02/05/2021
Operating Permit Renewal Date: 05/03/2024

Owner Operator Contact: Town and Country Supply Association;Wes
Burley;Town and Country Supply Association

4066286314;4066286314;4066286314

Operator Contact: Steven Shelton;Wesley Burley

4062323520;4063200055

Owner/Operator: Town and Country Supply Association

Crystal Schober, UST Class B Operator

Steven Shelton, UST Class A Operator

Wesley Burley, UST Class A Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
06	31	05/18/1990	Steel Clad	Fiberglass Reinforced Plastic	Flapper Valve
1515	No			Double Walled	Yes
Currently in Use		08/13/2010	Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel		06/14/2012	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring;ELLD 0.2	No
4,000		04/22/2018	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
07	31	05/18/1990	Steel Clad	Fiberglass Reinforced Plastic	Flapper Valve
1516	No			Double Walled	Yes
Currently in Use		08/13/2010	Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline		06/14/2012	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring;ELLD 0.2	No
4,000		04/22/2018	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
08	31	05/18/1990	Steel Clad	Fiberglass Reinforced Plastic	Flapper Valve
1517	No			Double Walled	Yes
Currently in Use		08/13/2010	Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline		06/14/2012	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring;ELLD 0.2	No

4,000		04/20/2018	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
09	18	07/01/2003	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve
4849	No		Double-Walled	Double Walled	Yes
Currently in Use		08/13/2010	Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		04/19/2018	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring; ELLD 0.2	No
2,000		04/20/2018	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No

Facility Summary in Carbon County in the City of Joliet

Location: CARBON COUNTY DIST 2 SHOP
201 State St
Joliet, MT 59041 Carbon

Legacy ID:05-01853

Facility ID: 18140
Last Inspected On: 10/18/2018
Operating Permit Renewal Date: 02/23/2022

Owner Operator Contact: Carbon County Road Dist;John Prinkki;Carbon County Road Dist **4064461595**

Operator Contact: Shawn Maines **4064461595**

Owner/Operator: Carbon County Road Dist

Jerrid Bergum, UST Class B Global Operator
Shawn Maines, UST Class A Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
03	29	01/30/1992	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve
518	No			None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Gasoline		10/18/2018	Automatic Tank Gauging 0.2	Deferred	No
1,000			Gilbarco/EMC Basic		No
04	29	01/30/1992	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve
519	No			None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Diesel		10/18/2018	Automatic Tank Gauging 0.2	Deferred	No
1,000			Gilbarco/EMC Basic		No

Facility Summary in Carbon County in the City of Joliet

Location: COUNTRY CORNER JOLIET
110 E Front Ave
Joliet, MT 59041 Carbon

Legacy ID:05-05577

Facility ID: 18186
Last Inspected On: 01/03/2020
Operating Permit Renewal Date: 04/22/2023

Owner Operator Contact: Phillis Lloyd;Country Corner Convenience Store;Superpumper Inc

Operator Contact: Justin Franjevic

4068551749

Owner/Operator: Superpumper Inc

Justin Franjevic, UST Class A Operator
 Katherine Narland, UST Class B Operator
 Stacy Shalosky, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status	Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types	
Product	Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery	
Capacity	Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act	
03	34	02/22/1987	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve
3925	No			None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		01/19/2017	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	No
4,000		04/18/2016	Gilbarco/EMC Basic		No
04	33	02/22/1988	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve
3926	No			None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		01/19/2017	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	No
1,500		04/18/2016	Gilbarco/EMC Basic		No
05	33	02/22/1988	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve
3927	No			None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Diesel		01/19/2017	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	No

2,500		04/18/2016	Gilbarco/EMC Basic		No
06	22	02/01/1999	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve
3928	No			None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Diesel		01/19/2017	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	No
8,000		04/18/2016	Gilbarco/EMC Basic		No

Facility Summary in Carbon County in the City of Joliet

Location: JOLIET SCHOOL DIST 7
131 N Main St
Joliet, MT 59041 Carbon

Legacy ID:05-05353

Facility ID: 18183
Last Inspected On: 02/25/2020
Operating Permit Renewal Date: 06/25/2023

Owner Operator Contact: School Dist 7 Joliet

4069623541

Operator Contact: Dale Limberhand;Flint Salo

Owner/Operator: School Dist 7 Joliet

Dale Limberhand, UST Class A Operator
Dale Limberhand, UST Class B Operator
Flint Salo, UST Class A Operator
Flint Salo, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
02	22	07/01/1999	Steel Clad	Steel	Flapper Valve
4091	No		Double-Walled	None	Yes
Currently in Use			Not Required	Safe Suction	Non-corrodible
Diesel			Manual Interstitial Monitoring	Deferred	No
1,000					No

Facility Summary in Carbon County in the City of Joliet

Location: TOWN OF JOLIET
116 S Main St
Joliet, MT 59041 Carbon

Legacy ID:05-00189

Facility ID: 18119
Last Inspected On: 03/12/2020
Operating Permit Renewal Date: 05/16/2023

Owner Operator Contact: Town of Joliet

4069623567

Operator Contact: Dale Limberhand

Owner/Operator: Town of Joliet

Dale Limberhand, UST Class A Operator
Dale Limberhand, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
02	24	09/01/1997	Steel Clad	Steel	Flapper Valve
2127	No		Double-Walled	None	Yes
Currently in Use			Not Required	Safe Suction	
Gasoline		03/01/2017	Manual Interstitial Monitoring	Deferred	No
560					No

Facility Summary in Carbon County in the City of Red Lodge

Location: 6 ASSISTED LLC
600 21st St W
Red Lodge, MT 59068 Carbon

Legacy ID:05-09926

Facility ID: 18235
Last Inspected On: 10/02/2017
Operating Permit Renewal Date: 11/05/2013

Owner Operator Contact: 6 Assisted LLC Jamaica

6463808748

Operator Contact: Bob Miner

Owner/Operator: 6 Assisted LLC Jamaica

Bob Miner, UST Class A Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery

Capacity	Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act	
02	23	10/08/1998	Cathodically Protected Steel	Flexible Plastic	Flapper Valve
3103	No		Double-Walled	Double Walled	Yes
Temporarily Out of Use			Not Required	Safe Suction	Galvanic
Diesel	08/04/2010		Not Listed	Not Listed	No
1,000					No

Facility Summary in Carbon County in the City of Red Lodge

Location: CENEX ZIP TRIP 74
902 N Broadway Ave
Red Lodge, MT 59068 Carbon

Legacy ID:56-13935

Facility ID: 30605
Last Inspected On: 06/12/2019
Operating Permit Renewal Date: 11/30/2022

Owner Operator Contact: CHS Inc Spokane Valley;Jim Alford;CHS Inc - Spokane

5095367418

Operator Contact: Jim Alford;Julie Lindgren;Sean Hurley

4064463123;5095357701;5095367418

Owner/Operator: CHS Inc Spokane Valley

- Jim Alford, UST Class A Operator
- Jim Alford, UST Class B Global Operator
- Julie Lindgren, UST Class A Operator
- Julie Lindgren, UST Class B Operator
- Lisa Morefield, UST Class B Operator
- Robert Hays, UST Class B Operator
- Sean Hurley, UST Class A Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity	Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act	
05	6	04/10/2015	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm;Positive Shutoff
5566	No	03/12/2015	Double-Walled	Double Walled	Yes
Currently in Use		04/10/2015	Electronic Line Leak Detector	Pressurized	Non-corrodible

Gasoline			Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	Continuous Interstitial Monitoring;ELLD 0.2	No
15,000		04/13/2015	Gilbarco-Veeder Root/TLS- 350;Gilbarco-Veeder Root/TLS- 350/Gilbarco EMC		Yes
06	6	04/10/2015	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm;Positive Shutoff
5567	No	03/12/2015	Double-Walled	Double Walled	Yes
Currently in Use		04/10/2015	Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel			Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	Continuous Interstitial Monitoring;ELLD 0.2	No
8,000		04/13/2015	Gilbarco-Veeder Root/TLS- 350;Gilbarco-Veeder Root/TLS- 350/Gilbarco EMC		Yes
07	6	04/10/2015	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm;Positive Shutoff
5568	No	03/12/2015	Double-Walled	Double Walled	Yes
Currently in Use		04/10/2015	Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	Continuous Interstitial Monitoring;ELLD 0.2	No
7,000		04/13/2015	Gilbarco-Veeder Root/TLS- 350;Gilbarco-Veeder Root/TLS- 350/Gilbarco EMC		Yes
08	6	04/10/2015	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm;Positive Shutoff
5569	No	03/12/2015	Double-Walled	Double Walled	Yes
Currently in Use		04/10/2015	Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel			Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	Continuous Interstitial Monitoring;ELLD 0.2	No
4,000		04/13/2015	Gilbarco-Veeder Root/TLS- 350;Gilbarco-Veeder Root/TLS- 350/Gilbarco EMC		Yes

Facility Summary in Carbon County in the City of Red Lodge

Location: CIRCLE 17
1022 S Adams Ave
Red Lodge, MT 59068-9578 Carbon

Legacy ID:05-09748

Facility ID: 18233
Last Inspected On: 02/25/2021
Operating Permit Renewal Date: 03/05/2024

Owner Operator Contact: Circle 17 LLC;Joel Lindgren;Rockin J Inc;Julie Lindgren;Rockin J Inc

4063286248;4064250395;4064463123;4063286248

Operator Contact: Mackenzie Alexander;Stephen Alexander

4064250395;4064253997

Owner/Operator: Circle 17 LLC

Owner/Operator: Mackenzie Alexander

Mackenzie Alexander, UST Class A Operator
Mackenzie Alexander, UST Class B Operator
Stephen Alexander, UST Class A Operator
Stephen Alexander, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
04	25	07/01/1996	Cathodically Protected Steel	Flexible Plastic	High Level Alarm
3389	No		Double-Walled	Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		10/02/2017	Automatic Tank Gauging 0.2	ELLD 0.1;ELLD 0.2	No
8,000		07/26/2017	Gilbarco/EMC Basic		No
05	25	07/01/1996	Cathodically Protected Steel	Flexible Plastic	High Level Alarm
3390	No		Double-Walled	Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		10/02/2017	Automatic Tank Gauging 0.2	ELLD 0.1;ELLD 0.2	No
4,000		07/26/2017	Gilbarco/EMC Basic		No

Facility Summary in Carbon County in the City of Red Lodge

Location: TOWN PUMP OF RED LODGE
 710 N Broadway
 Red Lodge, MT 59068 Carbon

Legacy ID:60-15212

Facility ID: 30932
Last Inspected On: 08/07/2021
Operating Permit Renewal Date: 08/09/2024

Owner Operator Contact:

Operator Contact: Trent Biggers

Owner/Operator: Red Lodge 1 Town Pump LLC

Trent Biggers, UST Class A Operator
 Trent Biggers, UST Class B Global Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
01	8	01/16/2013	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve
5377	No		Double-Walled	Double Walled	Yes
Currently in Use		01/16/2013	Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Yes
20,000			Gilbarco-Veeder Root/TLS-350		Yes
02	8	01/16/2013	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve
5378	No		Double-Walled	Double Walled	Yes
Currently in Use		01/16/2013	Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
14,000			Gilbarco-Veeder Root/TLS-350		Yes
03	8	01/16/2013	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve
5379	No		Double-Walled	Double Walled	Yes

Currently in Use		01/16/2013	Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel			Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
6,000			Gilbarco-Veeder Root/TLS-350		Yes
04	8	01/16/2013	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve
5380	No		Double-Walled	Double Walled	Yes
Currently in Use		01/16/2013	Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel			Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
12,000			Gilbarco-Veeder Root/TLS-350		Yes
05	8	01/16/2013	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve
5381	No		Double-Walled	Double Walled	Yes
Currently in Use		01/16/2013	Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel			Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
8,000			Gilbarco-Veeder Root/TLS-350		Yes
06	4	05/23/2017	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve
5800	No	04/27/2018	Double-Walled	Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Yes
6,000			Gilbarco-Veeder Root/TLS-350		Yes

Facility Summary in Carbon County in the City of Roberts

Location: Y STOP C STORE INC
 4 Cooney Rd
 Roberts, MT 59070 Carbon

Legacy ID:05-06599

Facility ID: 18197
Last Inspected On: 02/15/2021
Operating Permit Renewal Date: 02/20/2024

Owner Operator Contact: Melton Enterprises Inc

Operator Contact: Rodney Melton

Owner/Operator: Melton Enterprises Inc

Rodney Melton, UST Class A Operator
 Rodney Melton, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
05	29	06/20/1992	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
3329	No			None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Diesel		02/13/2018	Automatic Tank Gauging 0.2	Deferred	No
5,000			Veeder Root/TLS-300		No
06	29	06/20/1992	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
3330	No			None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Gasoline		02/13/2018	Automatic Tank Gauging 0.2	Deferred	No
3,000			Veeder Root/TLS-300		No
07	29	06/20/1992	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
3331	No			None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Diesel		02/13/2018	Automatic Tank Gauging 0.2	Deferred	No

3,000			Veeder Root/TLS-300		No
08	29	06/20/1992	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
3332	No			None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Gasoline		02/13/2018	Automatic Tank Gauging 0.2	Deferred	No
5,000			Veeder Root/TLS-300		No

Facility Summary in Carbon County in the City of Silesia

Location: ROCKVALE TRAVEL PLAZA UST
4293 US Hwy 310
Silesia, MT 59041 Carbon

Legacy ID:05-07633

Facility ID: 18210
Last Inspected On: 07/22/2020
Operating Permit Renewal Date: 08/13/2023

Owner Operator Contact: Thomas McNew;Thomas McNew;Rockvale Travel Plaza

Operator Contact: Thomas McNew

Owner/Operator: Thomas McNew

Owner/Operator: Tom McNew

Thomas McNew, UST Class A Operator

Thomas McNew, UST Class B Global Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
06	22	07/01/1999	Cathodically Protected Steel	Flexible Plastic	High Level Alarm
4112	No	12/10/2014		Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		01/02/2018	Automatic Tank Gauging 0.2	ELLD 0.2	No
12,000		07/13/2016	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
07	22	07/01/1999	Cathodically Protected Steel	Flexible Plastic	High Level Alarm

4113	No	12/10/2014		Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		01/02/2018	Automatic Tank Gauging 0.2	ELLD 0.2	No
10,000		07/13/2016	Gilbarco/EMC Basic		No
08	22	07/01/1999	Cathodically Protected Steel	Flexible Plastic	High Level Alarm
4114	No	12/10/2014		Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		01/02/2018	Automatic Tank Gauging 0.2	ELLD 0.2	No
10,000		07/13/2016	Gilbarco/EMC Basic		No