

Facility Summary in Carter County in the City of Alzada

Location: B AND J CONVENIENCE STORE
 US Hwy 212 & Hwy 326
 Alzada, MT 59311 Carter

System Facility ID:56-13910

Facility Code: 30580
Last Inspected On: 09/16/2024
Operating Permit Renewal Date: 09/17/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: B AND JS CONVENIENCE STORE LLC (406) 853-4312 tlhendrickson.tt@gmail.com

Operator Contact: Traci Tarno;William Walker (406) 828-4400 pook5451@yahoo.com;tlhendrickson.tt@gmail.com

Owner/Operator: B AND JS CONVENIENCE STORE LLC (406) 853-4312 tlhendrickson.tt@gmail.com
 Janet Walker, UST Class B Global Operator pook5451@yahoo.com
 Traci Tarno, UST Class A Operator tlhendrickson.tt@gmail.com
 Traci Tarno, UST Class B Operator tlhendrickson.tt@gmail.com
 William Walker, UST Class A Operator pook5451@yahoo.com

Tank Code	01	Tank Age	28	Tank Installed Date	12/01/1998	Tank Material	Steel Clad	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	3564	Spill Test Date	10/12/2022	Piping Installed Date	10/06/2022	Tank Construction	Double-Walled	Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	8000	ATG Test Date	12/01/2022	Line Tightness Test Date	12/01/2022	Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	10/12/2022			ATG Type	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Code	02	Tank Age	28	Tank Installed Date	12/01/1998	Tank Material	Steel Clad	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	3565	Spill Test Date	10/12/2022	Piping Installed Date	10/06/2022	Tank Construction	Double-Walled	Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	Yes
Capacity	4000	ATG Test Date	12/01/2022	Line Tightness Test Date	12/01/2022	Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act	No

		Overfill Test Date	10/12/2022			ATG Type	Gilbarco-Veeder Root/TLS- 450PLUS				
Tank Code	03	Tank Age	4	Tank Installed Date	09/15/2022	Tank Material	Steel Clad	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	6114	Spill Test Date	10/12/2022	Piping Installed Date	10/06/2022	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	Yes
Capacity	10000	ATG Test Date	12/01/2022	Line Tightness Test Date	12/01/2022	Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	12/12/2022			ATG Type					

Facility Summary in Carter County in the City of Ekalaka

Location: FRUIT SERVICE AND REPAIR INC SR 323
31 MT Hwy 323
Ekalaka, MT 59324 Carter

System Facility ID:06-03234

Facility Code: 18280
Last Inspected On: 03/04/2024
Operating Permit Renewal Date: 08/17/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Fruit Service and Repair Inc

(406) 775-6541

Operator Contact: Troy Fruit

fruit@midrivers.com

Owner/Operator: Fruit Service and Repair Inc

(406) 775-6541

Mikel Fruit, UST Class B Operator
Troy Fruit, UST Class A Operator

mjfruit@midrivers.com
fruit@midrivers.com

Tank Code	07	Tank Age	28	Tank Installed Date	04/01/1998	Tank Material	Steel Clad	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	1135	Spill Test Date	03/04/2024	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Manual Interstitial Monitoring	Primary Pipe Detection		Vapor Recovery	No
Capacity	4590	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	03/04/2024			ATG Type					
Tank Code	08	Tank Age	28	Tank Installed Date	04/01/1998	Tank Material	Steel Clad	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	1136	Spill Test Date	03/04/2024	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Manual Interstitial Monitoring	Primary Pipe Detection		Vapor Recovery	No
Capacity	2365	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	03/04/2024			ATG Type					
Tank Code	09	Tank Age	28	Tank Installed Date	04/01/1998	Tank Material	Steel Clad	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	1137	Spill Test Date	03/04/2024	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No

Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Manual Interstitial Monitoring	Primary Pipe Detection		Vapor Recovery	No
Capacity	9627	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	03/04/2024			ATG Type					
Tank Code	06	Tank Age	28	Tank Installed Date	04/01/1998	Tank Material	Steel Clad	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	3617	Spill Test Date	03/04/2024	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Manual Interstitial Monitoring	Primary Pipe Detection		Vapor Recovery	No
Capacity	5565	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	03/04/2024			ATG Type					

Facility Summary in Carter County in the City of Ekalaka

Location: T AND M STANDARD LLC
40 Main St
Ekalaka, MT 59324 Carter

System Facility ID:06-01681

Facility Code: 18270
Last Inspected On: 03/04/2024
Operating Permit Renewal Date: 08/17/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: T & M STANDARD LLC;Troy Fruit (406) 775-6541 fruit@midrivers.com

Operator Contact: Troy Fruit fruit@midrivers.com

Owner/Operator: T & M STANDARD LLC (406) 775-6541 fruit@midrivers.com

Owner/Operator: Troy Fruit (406) 775-6541 fruit@midrivers.com

Mikel Fruit, UST Class B Operator mjfruit@midrivers.com

Troy Fruit, UST Class A Operator fruit@midrivers.com

Tank Code	03	Tank Age	36	Tank Installed Date	04/26/1990	Tank Material	Steel Clad	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	1132	Spill Test Date	03/04/2024	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Manual Interstitial Monitoring	Primary Pipe Detection		Vapor Recovery	No
Capacity	1000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	03/04/2024			ATG Type					
Tank Code	04	Tank Age	36	Tank Installed Date	04/26/1990	Tank Material	Steel Clad	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	1133	Spill Test Date	03/04/2024	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Manual Interstitial Monitoring	Primary Pipe Detection		Vapor Recovery	No
Capacity	1000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	03/04/2024			ATG Type					
Tank Code	05	Tank Age	36	Tank Installed Date	04/26/1990	Tank Material	Steel Clad	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve

Tag Number	1134	Spill Test Date	03/04/2024	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Manual Interstitial Monitoring	Primary Pipe Detection		Vapor Recovery	No
Capacity	1000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	03/04/2024			ATG Type					