

Facility Summary in Cascade County in the City of Belt

Location: BELT PUBLIC SCHOOLS DIST 29 UST
1 Church St
Belt, MT 59412 Cascade

Legacy ID:07-04613

Facility ID: 18537
Last Inspected On: 04/29/2020
Operating Permit Renewal Date: 08/04/2023

Owner Operator Contact: School Dist 29 Belt

4062773351

Operator Contact: Kathleen Prody

Owner/Operator: School Dist 29 Belt

April Wells, UST Class B Operator
Kathleen Prody, UST Class A Operator

| Tank Code | Age | Installed | Tank Material Construction | Piping Material | Overfill Types |
|------------------|-----|-----------------------|------------------------------|------------------------------------|------------------|
| Tag # | AST | Sump Tightness | Secondary Option | Secondary Option | Spill Protected |
| Status | | Piping Installed Date | Catastrophic L.D. Type 3.0 | Piping Type | CP Met Types |
| Product | | Tank/Pipe CP | Tank Detection | Primary Pipe Detection | Vapor Recovery |
| Capacity | | Line Tightness | ATG Type | Secondary Pipe Detection | Energy Act |
| S3 | 33 | 10/01/1988 | Cathodically Protected Steel | Flexible Plastic | Positive Shutoff |
| 422 | No | 04/04/2017 | | Double Walled | Yes |
| Currently in Use | | | Not Required | U.S. Suction | Galvanic |
| Heating Oil | | 03/29/2017 | Automatic Tank Gauging 0.2 | Continuous Interstitial Monitoring | No |
| 10,000 | | | Incon/TS-1000 | | No |

Facility Summary in Cascade County in the City of Belt

Location: BELT VALLEY GROCERY
65 Castner St
Belt, MT 59412 Cascade

Legacy ID:07-13653

Facility ID: 19054
Last Inspected On: 10/14/2019
Operating Permit Renewal Date: 11/29/2022

Owner Operator Contact: Harry L Throckmorton

4062773523

Operator Contact: Reed Throckmorton

4062773523

Owner/Operator: Harry L Throckmorton

Reed Throckmorton, UST Class A Operator
Reed Throckmorton, UST Class B Operator

| Tank Code | Age | Installed | Tank Material Construction | Piping Material | Overfill Types |
|-----------|-----|----------------|----------------------------|------------------|-----------------|
| Tag # | AST | Sump Tightness | Secondary Option | Secondary Option | Spill Protected |

| Status | Piping Installed Date | Catastrophic L.D. Type 3.0 | Piping Type | CP Met Types | |
|------------------|-----------------------|---|------------------------------------|------------------|------------------|
| Product | Tank/Pipe CP | Tank Detection | Primary Pipe Detection | Vapor Recovery | |
| Capacity | Line Tightness | ATG Type | Secondary Pipe Detection | Energy Act | |
| 01 | 26 | 10/01/1995 | Fiberglass Reinforced Plastic | Flexible Plastic | High Level Alarm |
| 4468 | No | 11/28/2016 | | Double Walled | Yes |
| Currently in Use | | Continuous Interstitial Monitoring; Mechanical Line Leak Detector | Pressurized | | Non-corrodible |
| Gasoline | | Automatic Tank Gauging 0.2 | Continuous Interstitial Monitoring | | No |
| 6,000 | | OPW/EECO 1500 | | | No |
| 02 | 26 | 10/01/1995 | Fiberglass Reinforced Plastic | Flexible Plastic | High Level Alarm |
| 4469 | No | 11/28/2016 | | Double Walled | Yes |
| Currently in Use | | Continuous Interstitial Monitoring; Mechanical Line Leak Detector | Pressurized | | Non-corrodible |
| Gasoline | | Automatic Tank Gauging 0.2 | Continuous Interstitial Monitoring | | No |
| 6,000 | | OPW/EECO 1500 | | | No |

Facility Summary in Cascade County in the City of Belt

Location: MALMSTROM AFB A 10
US Hwy 87/89
Belt, MT 59412 Cascade

Legacy ID:07-08984

Facility ID: 18745
Last Inspected On: 05/24/2020
Operating Permit Renewal Date: 10/07/2023

Owner Operator Contact:

Operator Contact: Candace Ellsworth;Curtis Hester;William Smith **4067316239;4067317128**

Owner/Operator: 341 CES CEANQ

- Candace Ellsworth, UST Class A Operator
- Candace Ellsworth, UST Class B Global Operator
- Curtis Hester, UST Class A Operator
- Curtis Hester, UST Class B Global Operator
- William Smith, UST Class A Operator
- William Smith, UST Class B Global Operator

| Tank Code | Age | Installed | Tank Material Construction | Piping Material | Overfill Types |
|-----------|-----|----------------|----------------------------|------------------|-----------------|
| Tag # | AST | Sump Tightness | Secondary Option | Secondary Option | Spill Protected |

| Status | Piping Installed Date | Catastrophic L.D. Type 3.0 | Piping Type | CP Met Types | |
|------------------|-----------------------|------------------------------------|------------------------------------|-------------------------------|--------------------------------|
| Product | Tank/Pipe CP | Tank Detection | Primary Pipe Detection | Vapor Recovery | |
| Capacity | Line Tightness | ATG Type | Secondary Pipe Detection | Energy Act | |
| 02 | 29 | 05/01/1992 | Fiberglass Reinforced Plastic | Fiberglass Reinforced Plastic | Flapper Valve;High Level Alarm |
| 115 | No | 06/27/2017 | Double-Walled | Double Walled | Yes |
| Currently in Use | | Auto Dialer | U.S. Suction | Non-corrodible | |
| Diesel | | Continuous Interstitial Monitoring | Continuous Interstitial Monitoring | No | |
| 4,000 | | Gilbarco-Veeder Root/TLS-350 | | No | |

Facility Summary in Cascade County in the City of Belt

Location: MALMSTROM AFB A 11
US Hwy 87/89
Belt, MT 59412 Cascade

Legacy ID:07-08985

Facility ID: 18746
Last Inspected On: 05/24/2020
Operating Permit Renewal Date: 09/25/2023

Owner Operator Contact:

Operator Contact: Candace Ellsworth;Curtis Hester;William Smith **4067316239;4067317128**

Owner/Operator: 341 CES CEANQ

- Candace Ellsworth, UST Class A Operator
- Candace Ellsworth, UST Class B Global Operator
- Curtis Hester, UST Class A Operator
- Curtis Hester, UST Class B Global Operator
- William Smith, UST Class A Operator
- William Smith, UST Class B Global Operator

| Tank Code | Age | Installed | Tank Material Construction | Piping Material | Overfill Types |
|------------------|-----------------------|----------------------------|-------------------------------|-------------------------------|--------------------------------|
| Tag # | AST | Sump Tightness | Secondary Option | Secondary Option | Spill Protected |
| Status | Piping Installed Date | Catastrophic L.D. Type 3.0 | Piping Type | CP Met Types | |
| Product | Tank/Pipe CP | Tank Detection | Primary Pipe Detection | Vapor Recovery | |
| Capacity | Line Tightness | ATG Type | Secondary Pipe Detection | Energy Act | |
| 02 | 29 | 05/01/1992 | Fiberglass Reinforced Plastic | Fiberglass Reinforced Plastic | Flapper Valve;High Level Alarm |
| 116 | No | 06/07/2017 | Double-Walled | Double Walled | Yes |
| Currently in Use | | Auto Dialer | U.S. Suction | Non-corrodible | |

| | | | |
|--------|------------------------------------|------------------------------------|----|
| Diesel | Continuous Interstitial Monitoring | Continuous Interstitial Monitoring | No |
| 4,000 | Gilbarco-Veeder Root/TLS-350 | | No |

Facility Summary in Cascade County in the City of Belt

Location: MALMSTROM AFB A 2
US Hwy 87/89
Belt, MT 59412 Cascade

Legacy ID:07-08976

Facility ID: 18739
Last Inspected On: 05/24/2020
Operating Permit Renewal Date: 10/07/2023

Owner Operator Contact:

| | |
|---|---|
| Operator Contact: Candace Ellsworth;Curtis Hester;James Leigland;William Smith | 4067316239;4067317128;4068993635 |
|---|---|

Owner/Operator: 341 CES CEANQ

- Candace Ellsworth, UST Class A Operator
- Candace Ellsworth, UST Class B Global Operator
- Curtis Hester, UST Class A Operator
- Curtis Hester, UST Class B Global Operator
- James Leigland, UST Class A Operator
- James Leigland, UST Class B Operator
- Mark Johnson, UST Class B Global Operator
- William Smith, UST Class A Operator
- William Smith, UST Class B Global Operator

| Tank Code | Age | Installed | Tank Material Construction | Piping Material | Overfill Types |
|------------------|------------|------------------------------|------------------------------------|------------------------------------|--------------------------------|
| Tag # | AST | Sump Tightness | Secondary Option | Secondary Option | Spill Protected |
| Status | | Piping Installed Date | Catastrophic L.D. Type 3.0 | Piping Type | CP Met Types |
| Product | | Tank/Pipe CP | Tank Detection | Primary Pipe Detection | Vapor Recovery |
| Capacity | | Line Tightness | ATG Type | Secondary Pipe Detection | Energy Act |
| 02 | 29 | 06/01/1992 | Fiberglass Reinforced Plastic | Fiberglass Reinforced Plastic | Flapper Valve;High Level Alarm |
| 109 | No | 06/27/2017 | Double-Walled | Double Walled | Yes |
| Currently in Use | | | Auto Dialer | U.S. Suction | Non-corrodible |
| Diesel | | | Continuous Interstitial Monitoring | Continuous Interstitial Monitoring | No |
| 4,000 | | | Gilbarco-Veeder Root/TLS-350 | | No |

Facility Summary in Cascade County in the City of Black Eagle

Location: BLACK EAGLE SERVICE CENTER
1501 N River Rd
Black Eagle, MT 59414 Cascade

Legacy ID:07-01190

Facility ID: 18380
Last Inspected On: 08/16/2019
Operating Permit Renewal Date: 01/28/2023

Owner Operator Contact: Michael Larson;Montana Power Company
Butte;Northwestern Energy Rocker

4066552521;4067236519;8884672669

Operator Contact: John Habeger

Owner/Operator: Northwestern Energy Rocker

Charles Roth, UST Class B Operator
John Habeger, UST Class A Operator
Michael Broderick, UST Class B Global Operator

| Tank Code | Age | Installed | Tank Material Construction | Piping Material | Overfill Types |
|------------------|-----|-----------------------|-------------------------------|-------------------------------|------------------|
| Tag # | AST | Sump Tightness | Secondary Option | Secondary Option | Spill Protected |
| Status | | Piping Installed Date | Catastrophic L.D. Type 3.0 | Piping Type | CP Met Types |
| Product | | Tank/Pipe CP | Tank Detection | Primary Pipe Detection | Vapor Recovery |
| Capacity | | Line Tightness | ATG Type | Secondary Pipe Detection | Energy Act |
| 04 | 30 | 12/01/1991 | Fiberglass Reinforced Plastic | Fiberglass Reinforced Plastic | High Level Alarm |
| 1676 | No | | | None | Yes |
| Currently in Use | | | Not Required | Safe Suction | Non-corrodible |
| Gasoline | | | Automatic Tank Gauging 0.2 | Deferred | No |
| 2,086 | | | Veeder Root/TLS-300 | | No |
| 05 | 30 | 12/01/1991 | Fiberglass Reinforced Plastic | Fiberglass Reinforced Plastic | High Level Alarm |
| 1677 | No | | | None | Yes |
| Currently in Use | | | Not Required | Safe Suction | Non-corrodible |
| Diesel | | | Automatic Tank Gauging 0.2 | Deferred | No |
| 2,086 | | | Veeder Root/TLS-300 | | No |

Facility Summary in Cascade County in the City of Black Eagle

Location: MOUNTAIN VIEW CO-OP
1105 Smelter Ave NE
Black Eagle, MT 59414 Cascade

Legacy ID:60-15312

Facility ID: 31011
Last Inspected On: 01/08/2019
Operating Permit Renewal Date: 03/19/2022

Owner Operator Contact: Mountain View Coop Black Eagle

4064535900

Operator Contact: David Douglas

Owner/Operator: Mountain View Coop Black Eagle

David Douglas, UST Class A Operator

David Douglas, UST Class B Global Operator

Foster Sensibaugh, UST Class B Global Operator

John Barnes, UST Class B Global Operator

| Tank Code | Age | Installed | Tank Material Construction | Piping Material | Overfill Types |
|------------------|-----|-----------------------|------------------------------------|--|-----------------------------------|
| Tag # | AST | Sump Tightness | Secondary Option | Secondary Option | Spill Protected |
| Status | | Piping Installed Date | Catastrophic L.D. Type 3.0 | Piping Type | CP Met Types |
| Product | | Tank/Pipe CP | Tank Detection | Primary Pipe Detection | Vapor Recovery |
| Capacity | | Line Tightness | ATG Type | Secondary Pipe Detection | Energy Act |
| 01 | 4 | 10/10/2017 | Steel Clad | Flexible Plastic | High Level Alarm;Positive Shutoff |
| 5773 | No | 12/05/2017 | Double-Walled | Double Walled | Yes |
| Currently in Use | | 09/17/2017 | Electronic Line Leak Detector | Pressurized | |
| Diesel | | | Continuous Interstitial Monitoring | Continuous Interstitial Monitoring;ELLD 0.1;ELLD 0.2 | No |
| 30,000 | | | | | Yes |
| 02 | 4 | 10/10/2017 | Steel Clad | Flexible Plastic | High Level Alarm;Positive Shutoff |
| 5774 | No | 12/05/2017 | Double-Walled | Double Walled | Yes |
| Currently in Use | | 09/17/2017 | Electronic Line Leak Detector | Pressurized | |
| Diesel | | | Continuous Interstitial Monitoring | Continuous Interstitial Monitoring;ELLD 0.1;ELLD 0.2 | No |
| 15,000 | | | | | Yes |
| 03 | 4 | 10/10/2017 | Steel Clad | Flexible Plastic | High Level Alarm;Positive Shutoff |
| 5775 | No | 12/05/2017 | Double-Walled | Double Walled | Yes |
| Currently in Use | | 09/17/2017 | Electronic Line Leak Detector | Pressurized | |
| Diesel | | | Continuous Interstitial Monitoring | Continuous Interstitial Monitoring;ELLD 0.1;ELLD 0.2 | No |
| 10,000 | | | | | Yes |

| | | | | | |
|------------------|----|------------|------------------------------------|--|-----------------------------------|
| 05 | 4 | 10/10/2017 | Steel Clad | Flexible Plastic | High Level Alarm;Positive Shutoff |
| 5777 | No | 12/05/2017 | Double-Walled | Double Walled | Yes |
| Currently in Use | | 09/17/2017 | Electronic Line Leak Detector | Pressurized | |
| Diesel | | | Continuous Interstitial Monitoring | Continuous Interstitial Monitoring;ELLD 0.1;ELLD 0.2 | No |
| 12,000 | | | | | Yes |
| 06 | 4 | 10/10/2017 | Steel Clad | Flexible Plastic | High Level Alarm;Positive Shutoff |
| 5778 | No | 12/05/2017 | Double-Walled | Double Walled | Yes |
| Currently in Use | | 09/17/2017 | Electronic Line Leak Detector | Pressurized | |
| Gasoline | | | Continuous Interstitial Monitoring | Continuous Interstitial Monitoring;ELLD 0.1;ELLD 0.2 | No |
| 8,000 | | | | | Yes |
| 07 | 4 | 10/10/2017 | Steel Clad | Flexible Plastic | High Level Alarm;Positive Shutoff |
| 5779 | No | 12/05/2017 | Double-Walled | Double Walled | Yes |
| Currently in Use | | 09/17/2017 | Electronic Line Leak Detector | Pressurized | |
| Gasoline | | | Continuous Interstitial Monitoring | Continuous Interstitial Monitoring;ELLD 0.1;ELLD 0.2 | No |
| 10,000 | | | | | Yes |

Facility Summary in Cascade County in the City of Black Eagle

Location: MOUNTAIN VIEW COOP BLACK EAGLE
2200 Old Havre Hwy
Black Eagle, MT 59414-1043 Cascade

Legacy ID:07-04232

Facility ID: 18509
Last Inspected On: 07/11/2019
Operating Permit Renewal Date: 08/04/2022

Owner Operator Contact: Mark Freund;Mountain View Coop Great Falls;Mountain View Coop Black Eagle

4064535900

Operator Contact: Dan Morano;Judy Statham;Pat Trainor

8008233276

Owner/Operator: Mountain View Coop Black Eagle

Dan Morano, UST Class A Operator
Judy Statham, UST Class A Operator
Pat Trainor, UST Class A Operator
Pat Trainor, UST Class B Global Operator

| Tank Code | Age | Installed | Tank Material Construction | Piping Material | Overfill Types |
|-----------|-----|-----------|----------------------------|-----------------|----------------|
|-----------|-----|-----------|----------------------------|-----------------|----------------|

| Tag # | AST | Sump Tightness | Secondary Option | Secondary Option | Spill Protected |
|------------------|-----|-----------------------|---|--------------------------|------------------|
| Status | | Piping Installed Date | Catastrophic L.D. Type 3.0 | Piping Type | CP Met Types |
| Product | | Tank/Pipe CP | Tank Detection | Primary Pipe Detection | Vapor Recovery |
| Capacity | | Line Tightness | ATG Type | Secondary Pipe Detection | Energy Act |
| 07 | 24 | 12/02/1997 | Fiberglass Reinforced Plastic | No Piping | High Level Alarm |
| 1015 | No | | | None | Yes |
| Currently in Use | | | Not Required | Pressurized | Non-corrodible |
| Gasoline | | | Automatic Tank Gauging 0.2 | Deferred | Yes |
| 12,000 | | | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | No |
| 08 | 24 | 12/02/1997 | Fiberglass Reinforced Plastic | No Piping | High Level Alarm |
| 1016 | No | | | None | Yes |
| Currently in Use | | 09/19/2007 | Not Required | Pressurized | Non-corrodible |
| Diesel | | | Automatic Tank Gauging 0.2 | Deferred | No |
| 12,000 | | | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | No |
| 09 | 24 | 12/02/1997 | Fiberglass Reinforced Plastic | No Piping | High Level Alarm |
| 1017 | No | | | None | Yes |
| Currently in Use | | | Not Required | Pressurized | Non-corrodible |
| Gasoline | | | Automatic Tank Gauging 0.2 | Deferred | Yes |
| 4,000 | | | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | No |
| 10 | 24 | 12/02/1997 | Fiberglass Reinforced Plastic | No Piping | High Level Alarm |
| 1018 | No | | | None | Yes |
| Currently in Use | | | Not Required | Pressurized | Non-corrodible |
| Diesel | | | Automatic Tank Gauging 0.2 | Deferred | No |
| 4,000 | | | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | No |

| | | | | | |
|------------------|----|------------|---|-------------|------------------|
| 11 | 24 | 12/02/1997 | Fiberglass Reinforced Plastic | No Piping | High Level Alarm |
| 1019 | No | | | None | Yes |
| Currently in Use | | | Not Required | Pressurized | Non-corrodible |
| Diesel | | | Automatic Tank Gauging 0.2 | Deferred | No |
| 4,000 | | | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | No |
| 12 | 24 | 12/02/1997 | Fiberglass Reinforced Plastic | No Piping | High Level Alarm |
| 1020 | No | | | None | Yes |
| Currently in Use | | | Not Required | Pressurized | Non-corrodible |
| Diesel | | | Automatic Tank Gauging 0.2 | Deferred | No |
| 4,000 | | | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | No |

Facility Summary in Cascade County in the City of Black Eagle

Location: MOUNTAIN VIEW COOP GREAT FALLS
1000 Smelter Ave NE
Black Eagle, MT 59414-1018 Cascade

Legacy ID:07-00004

Facility ID: 18320
Last Inspected On: 05/06/2019
Operating Permit Renewal Date: 08/04/2022

Owner Operator Contact: Mark Freund;Mountain View Coop Great Falls;Mountain View Coop Black Eagle

4064535900

Operator Contact: David Douglas;Kila Moore

4064535900

Owner/Operator: Mountain View Coop Black Eagle

- David Douglas, UST Class A Operator
- David Douglas, UST Class B Global Operator
- Gary Boysun, UST Class B Operator
- Jasmin Nguyen, UST Class B Global Operator
- Jasmin Nguyen, UST Class B Operator
- John Malley, UST Class B Operator
- Kila Moore, UST Class A Operator

| Tank Code | Age | Installed | Tank Material Construction | Piping Material | Overfill Types |
|-----------|-----|-----------------------|----------------------------|--------------------------|-----------------|
| Tag # | AST | Sump Tightness | Secondary Option | Secondary Option | Spill Protected |
| Status | | Piping Installed Date | Catastrophic L.D. Type 3.0 | Piping Type | CP Met Types |
| Product | | Tank/Pipe CP | Tank Detection | Primary Pipe Detection | Vapor Recovery |
| Capacity | | Line Tightness | ATG Type | Secondary Pipe Detection | Energy Act |

| | | | | | |
|------------------|----|------------|---|-------------------------------|------------------|
| 07 | 26 | 11/01/1995 | Fiberglass Reinforced Plastic | Fiberglass Reinforced Plastic | High Level Alarm |
| 1009 | No | | | None | Yes |
| Currently in Use | | | Electronic Line Leak Detector | Pressurized | Non-corrodible |
| Gasoline | | | Automatic Tank Gauging 0.2 | ELLD 0.1;ELLD 0.2 | No |
| 12,000 | | | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | No |
| 08 | 26 | 11/01/1995 | Fiberglass Reinforced Plastic | Fiberglass Reinforced Plastic | High Level Alarm |
| 1010 | No | | | None | Yes |
| Currently in Use | | | Electronic Line Leak Detector | Pressurized | Non-corrodible |
| Gasoline | | | Automatic Tank Gauging 0.2 | ELLD 0.1;ELLD 0.2 | No |
| 12,000 | | | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | No |
| 09 | 26 | 11/01/1995 | Fiberglass Reinforced Plastic | Fiberglass Reinforced Plastic | High Level Alarm |
| 1011 | No | | | None | Yes |
| Currently in Use | | | Electronic Line Leak Detector | Pressurized | Non-corrodible |
| Diesel | | | Automatic Tank Gauging 0.2 | ELLD 0.1;ELLD 0.2 | No |
| 12,000 | | | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | No |
| 10 | 26 | 11/01/1995 | Fiberglass Reinforced Plastic | Fiberglass Reinforced Plastic | High Level Alarm |
| 1012 | No | | | None | Yes |
| Currently in Use | | | Electronic Line Leak Detector | Pressurized | Non-corrodible |
| Diesel | | | Automatic Tank Gauging 0.2 | ELLD 0.1;ELLD 0.2 | No |
| 12,000 | | | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | No |
| 11 | 26 | 11/01/1995 | Fiberglass Reinforced Plastic | Fiberglass Reinforced Plastic | High Level Alarm |
| 1013 | No | | | None | Yes |
| Currently in Use | | | Electronic Line Leak Detector | Pressurized | Non-corrodible |

| | | | | | |
|------------------------|----|------------|---|---|------------------|
| Diesel | | | Automatic Tank Gauging 0.2 | ELLD 0.1;ELLD 0.2 | No |
| 12,000 | | | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | No |
| 12 | 26 | 11/01/1995 | Fiberglass Reinforced Plastic | Fiberglass Reinforced Plastic | High Level Alarm |
| 1014 | No | | | None | Yes |
| Temporarily Out of Use | | | Electronic Line Leak Detector | U.S. Suction | |
| Diesel | | | Automatic Tank Gauging 0.2 | ELLD 0.1;ELLD 0.2;ELLD Line Tightness Testing | No |
| 12,000 | | | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | No |

Facility Summary in Cascade County in the City of Cascade

Location: 468 MARKET
130 1st St N
Cascade, MT 59421-8353 Cascade

Legacy ID:07-04148

Facility ID: 18505
Last Inspected On: 06/24/2019
Operating Permit Renewal Date: 09/20/2022

Owner Operator Contact: DTK Foods Inc

Operator Contact: Irene Strandell;Wesley Seabolt

4064682252;4067812060

Owner/Operator: DTK Foods Inc

Irene Strandell, UST Class A Operator
Irene Strandell, UST Class B Operator
Wesley Seabolt, UST Class A Operator
Wesley Seabolt, UST Class B Global Operator

| Tank Code | Age | Installed | Tank Material Construction | Piping Material | Overfill Types |
|------------------|-----|-----------------------|-------------------------------|-----------------------------|------------------|
| Tag # | AST | Sump Tightness | Secondary Option | Secondary Option | Spill Protected |
| Status | | Piping Installed Date | Catastrophic L.D. Type 3.0 | Piping Type | CP Met Types |
| Product | | Tank/Pipe CP | Tank Detection | Primary Pipe Detection | Vapor Recovery |
| Capacity | | Line Tightness | ATG Type | Secondary Pipe Detection | Energy Act |
| 04 | 24 | 05/01/1997 | Fiberglass Reinforced Plastic | Flexible Plastic | High Level Alarm |
| 1490 | No | 08/08/2016 | | Double Walled | Yes |
| Currently in Use | | | Mechanical Line Leak Detector | Pressurized | Non-corrodible |
| Gasoline | | | Automatic Tank Gauging 0.2 | MLLD Line Tightness Testing | No |
| 12,000 | | | Gilbarco/EMC Basic | | No |

| | | | | | |
|------------------|----|------------|-------------------------------|-----------------------------|------------------|
| 05 | 24 | 05/01/1997 | Fiberglass Reinforced Plastic | Flexible Plastic | High Level Alarm |
| 1491 | No | 08/08/2016 | | Double Walled | Yes |
| Currently in Use | | | Mechanical Line Leak Detector | Pressurized | Non-corrodible |
| Gasoline | | | Automatic Tank Gauging 0.2 | MLLD Line Tightness Testing | No |
| 6,000 | | | Gilbarco/EMC Basic | | No |
| 06 | 24 | 05/01/1997 | Fiberglass Reinforced Plastic | Flexible Plastic | High Level Alarm |
| 1492 | No | 08/08/2016 | | Double Walled | Yes |
| Currently in Use | | | Mechanical Line Leak Detector | Pressurized | Non-corrodible |
| Diesel | | | Automatic Tank Gauging 0.2 | MLLD Line Tightness Testing | No |
| 5,000 | | | Gilbarco/EMC Basic | | No |
| 07 | 24 | 05/01/1997 | Fiberglass Reinforced Plastic | Flexible Plastic | High Level Alarm |
| 1493 | No | 08/08/2016 | | Double Walled | Yes |
| Currently in Use | | | Mechanical Line Leak Detector | Pressurized | Non-corrodible |
| Diesel | | | Automatic Tank Gauging 0.2 | MLLD Line Tightness Testing | No |
| 6,000 | | | Gilbarco/EMC Basic | | No |
| 08 | 24 | 05/01/1997 | Fiberglass Reinforced Plastic | Flexible Plastic | High Level Alarm |
| 1494 | No | 08/08/2016 | | Double Walled | Yes |
| Currently in Use | | | Mechanical Line Leak Detector | Pressurized | Non-corrodible |
| Gasoline | | | Automatic Tank Gauging 0.2 | MLLD Line Tightness Testing | No |
| 5,000 | | | Gilbarco/EMC Basic | | No |

Facility Summary in Cascade County in the City of Cascade

Location: MALMSTROM AFB G 3
I-15
Cascade, MT 59421 Cascade

Legacy ID:07-09043

Facility ID: 18748
Last Inspected On: 06/14/2021
Operating Permit Renewal Date: 09/22/2024

Owner Operator Contact:

Operator Contact: Candace Ellsworth;Curtis Hester;William Smith

4067316239;4067317128

Owner/Operator: 341 CES CEANQ

Candace Ellsworth, UST Class A Operator
Candace Ellsworth, UST Class B Global Operator
Curtis Hester, UST Class A Operator
Curtis Hester, UST Class B Global Operator
William Smith, UST Class A Operator
William Smith, UST Class B Global Operator

| Tank Code | Age | Installed | Tank Material Construction | Piping Material | Overfill Types |
|------------------|-----|-----------------------|------------------------------------|------------------------------------|--------------------------------|
| Tag # | AST | Sump Tightness | Secondary Option | Secondary Option | Spill Protected |
| Status | | Piping Installed Date | Catastrophic L.D. Type 3.0 | Piping Type | CP Met Types |
| Product | | Tank/Pipe CP | Tank Detection | Primary Pipe Detection | Vapor Recovery |
| Capacity | | Line Tightness | ATG Type | Secondary Pipe Detection | Energy Act |
| 02 | 32 | 06/21/1989 | Fiberglass Reinforced Plastic | Fiberglass Reinforced Plastic | Flapper Valve;High Level Alarm |
| 118 | No | 04/25/2018 | Double-Walled | Double Walled | Yes |
| Currently in Use | | | Auto Dialer | U.S. Suction | Non-corrodible |
| Diesel | | | Continuous Interstitial Monitoring | Continuous Interstitial Monitoring | No |
| 4,000 | | | Gilbarco-Veeder Root/TLS-350 | | No |

Facility Summary in Cascade County in the City of Cascade

Location: MALMSTROM AFB G 4
I-15
Cascade, MT 59421 Cascade

Legacy ID:07-09044

Facility ID: 18749
Last Inspected On: 06/14/2021
Operating Permit Renewal Date: 09/22/2024

Owner Operator Contact:

Operator Contact: Candace Ellsworth;Curtis Hester;William Smith

4067316239;4067317128

Owner/Operator: 341 CES CEANQ

Candace Ellsworth, UST Class A Operator
Candace Ellsworth, UST Class B Global Operator
Curtis Hester, UST Class A Operator
Curtis Hester, UST Class B Global Operator
William Smith, UST Class A Operator
William Smith, UST Class B Global Operator

| Tank Code | Age | Installed | Tank Material Construction | Piping Material | Overfill Types |
|------------------|-----|-----------------------|------------------------------------|------------------------------------|--------------------------------|
| Tag # | AST | Sump Tightness | Secondary Option | Secondary Option | Spill Protected |
| Status | | Piping Installed Date | Catastrophic L.D. Type 3.0 | Piping Type | CP Met Types |
| Product | | Tank/Pipe CP | Tank Detection | Primary Pipe Detection | Vapor Recovery |
| Capacity | | Line Tightness | ATG Type | Secondary Pipe Detection | Energy Act |
| 02 | 29 | 05/01/1992 | Fiberglass Reinforced Plastic | Flexible Plastic | Flapper Valve;High Level Alarm |
| 119 | No | 04/25/2018 | Double-Walled | Double Walled | Yes |
| Currently in Use | | 11/16/2016 | Auto Dialer | U.S. Suction | Non-corrodible |
| Diesel | | | Continuous Interstitial Monitoring | Continuous Interstitial Monitoring | No |
| 4,000 | | | Gilbarco-Veeder Root/TLS-350 | | No |

Facility Summary in Cascade County in the City of Cascade

Location: MALMSTROM AFB G 5
I-15
Cascade, MT 59421 Cascade

Legacy ID:07-09045

Facility ID: 18750
Last Inspected On: 06/14/2021
Operating Permit Renewal Date: 09/22/2024

Owner Operator Contact:

Operator Contact: Candace Ellsworth;Curtis Hester;William Smith **4067316239;4067317128**

Owner/Operator: 341 CES CEANQ

Candace Ellsworth, UST Class A Operator
Candace Ellsworth, UST Class B Global Operator
Curtis Hester, UST Class A Operator
Curtis Hester, UST Class B Global Operator
William Smith, UST Class A Operator
William Smith, UST Class B Global Operator

| Tank Code | Age | Installed | Tank Material Construction | Piping Material | Overfill Types |
|-----------|-----|-----------------------|-------------------------------|--------------------------|--------------------------------|
| Tag # | AST | Sump Tightness | Secondary Option | Secondary Option | Spill Protected |
| Status | | Piping Installed Date | Catastrophic L.D. Type 3.0 | Piping Type | CP Met Types |
| Product | | Tank/Pipe CP | Tank Detection | Primary Pipe Detection | Vapor Recovery |
| Capacity | | Line Tightness | ATG Type | Secondary Pipe Detection | Energy Act |
| 02 | 29 | 05/01/1992 | Fiberglass Reinforced Plastic | Flexible Plastic | Flapper Valve;High Level Alarm |

| | | | | | |
|------------------|----|------------|------------------------------------|------------------------------------|----------------|
| 120 | No | 04/25/2018 | Double-Walled | Double Walled | Yes |
| Currently in Use | | 05/17/2017 | Auto Dialer | U.S. Suction | Non-corrodible |
| Diesel | | | Continuous Interstitial Monitoring | Continuous Interstitial Monitoring | No |
| 4,000 | | 05/17/2017 | Gilbarco-Veeder Root/TLS-350 | | No |

Facility Summary in Cascade County in the City of Cascade

Location: MALMSTROM AFB I 1
Hwy 330
Cascade, MT 59421 Cascade

Legacy ID:07-09063

Facility ID: 18755
Last Inspected On: 06/11/2021
Operating Permit Renewal Date: 09/22/2024

Owner Operator Contact:

Operator Contact: Candace Ellsworth;Curtis Hester;William Smith **4067316239;4067317128**

Owner/Operator: 341 CES CEANQ

- Candace Ellsworth, UST Class A Operator
- Candace Ellsworth, UST Class B Global Operator
- Curtis Hester, UST Class A Operator
- Curtis Hester, UST Class B Global Operator
- William Smith, UST Class A Operator
- William Smith, UST Class B Global Operator

| Tank Code | Age | Installed | Tank Material Construction | Piping Material | Overfill Types |
|------------------|-----|-----------------------|---|------------------------------------|--------------------------------|
| Tag # | AST | Sump Tightness | Secondary Option | Secondary Option | Spill Protected |
| Status | | Piping Installed Date | Catastrophic L.D. Type 3.0 | Piping Type | CP Met Types |
| Product | | Tank/Pipe CP | Tank Detection | Primary Pipe Detection | Vapor Recovery |
| Capacity | | Line Tightness | ATG Type | Secondary Pipe Detection | Energy Act |
| 01 | 59 | 06/02/1962 | Cathodically Protected Steel | Flexible Plastic | Flapper Valve;High Level Alarm |
| 125 | No | 04/23/2018 | Lined Interior/Impressed Current | Double Walled | Yes |
| Currently in Use | | | Auto Dialer | U.S. Suction | Impressed Current |
| Diesel | | 04/30/2018 | Automatic Tank Gauging 0.2 | Continuous Interstitial Monitoring | No |
| 12,000 | | | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | No |

Facility Summary in Cascade County in the City of Cascade

Location: MALMSTROM AFB I 3
Road 330
Cascade, MT 59421 Cascade

Legacy ID:07-09065

Facility ID: 18757
Last Inspected On: 06/11/2021
Operating Permit Renewal Date: 09/22/2024

Owner Operator Contact:

Operator Contact: Candace Ellsworth;Curtis Hester;William Smith

4067316239;4067317128

Owner/Operator: 341 CES CEANQ

Candace Ellsworth, UST Class A Operator
Candace Ellsworth, UST Class B Global Operator
Curtis Hester, UST Class A Operator
Curtis Hester, UST Class B Global Operator
William Smith, UST Class A Operator
William Smith, UST Class B Global Operator

| Tank Code | Age | Installed | Tank Material Construction | Piping Material | Overfill Types |
|------------------|-----|-----------------------|------------------------------------|------------------------------------|--------------------------------|
| Tag # | AST | Sump Tightness | Secondary Option | Secondary Option | Spill Protected |
| Status | | Piping Installed Date | Catastrophic L.D. Type 3.0 | Piping Type | CP Met Types |
| Product | | Tank/Pipe CP | Tank Detection | Primary Pipe Detection | Vapor Recovery |
| Capacity | | Line Tightness | ATG Type | Secondary Pipe Detection | Energy Act |
| 02 | 30 | 10/01/1991 | Fiberglass Reinforced Plastic | Fiberglass Reinforced Plastic | Flapper Valve;High Level Alarm |
| 127 | No | 04/23/2018 | Double-Walled | Double Walled | Yes |
| Currently in Use | | | Auto Dialer | U.S. Suction | Non-corrodible |
| Diesel | | | Continuous Interstitial Monitoring | Continuous Interstitial Monitoring | No |
| 4,000 | | | Gilbarco-Veeder Root/TLS-350 | | No |

Facility Summary in Cascade County in the City of Cascade

Location: MALMSTROM AFB I 4
Road 330
Cascade, MT 59421 Cascade

Legacy ID:07-09066

Facility ID: 18758
Last Inspected On: 06/11/2021
Operating Permit Renewal Date: 09/22/2024

Owner Operator Contact:

Operator Contact: Candace Ellsworth;Curtis Hester;William Smith

4067316239;4067317128

Owner/Operator: 341 CES CEANQ

Candace Ellsworth, UST Class A Operator
Candace Ellsworth, UST Class B Global Operator
Curtis Hester, UST Class A Operator

Curtis Hester, UST Class B Global Operator
 William Smith, UST Class A Operator
 William Smith, UST Class B Global Operator

| Tank Code | Age | Installed | Tank Material Construction | Piping Material | Overfill Types |
|------------------|-----|-----------------------|------------------------------------|------------------------------------|--------------------------------|
| Tag # | AST | Sump Tightness | Secondary Option | Secondary Option | Spill Protected |
| Status | | Piping Installed Date | Catastrophic L.D. Type 3.0 | Piping Type | CP Met Types |
| Product | | Tank/Pipe CP | Tank Detection | Primary Pipe Detection | Vapor Recovery |
| Capacity | | Line Tightness | ATG Type | Secondary Pipe Detection | Energy Act |
| 02 | 30 | 10/01/1991 | Fiberglass Reinforced Plastic | Fiberglass Reinforced Plastic | Flapper Valve;High Level Alarm |
| 128 | No | 04/23/2018 | Double-Walled | Double Walled | Yes |
| Currently in Use | | | Auto Dialer | U.S. Suction | Non-corrodible |
| Diesel | | | Continuous Interstitial Monitoring | Continuous Interstitial Monitoring | No |
| 4,000 | | | Gilbarco-Veeder Root/TLS-350 | | No |

Facility Summary in Cascade County in the City of Cascade

Location: MALMSTROM AFB I 5
 Road 330
 Cascade, MT 59421 Cascade

Legacy ID:07-09067

Facility ID: 18759
Last Inspected On: 06/11/2021
Operating Permit Renewal Date: 09/22/2024

Owner Operator Contact:

Operator Contact: Candace Ellsworth;Curtis Hester;William Smith **4067316239;4067317128**

Owner/Operator: 341 CES CEANQ

Candace Ellsworth, UST Class A Operator
 Candace Ellsworth, UST Class B Global Operator
 Curtis Hester, UST Class A Operator
 Curtis Hester, UST Class B Global Operator
 William Smith, UST Class A Operator
 William Smith, UST Class B Global Operator

| Tank Code | Age | Installed | Tank Material Construction | Piping Material | Overfill Types |
|-----------|-----|-----------------------|----------------------------|------------------------|-----------------|
| Tag # | AST | Sump Tightness | Secondary Option | Secondary Option | Spill Protected |
| Status | | Piping Installed Date | Catastrophic L.D. Type 3.0 | Piping Type | CP Met Types |
| Product | | Tank/Pipe CP | Tank Detection | Primary Pipe Detection | Vapor Recovery |

| Capacity | Line Tightness | ATG Type | Secondary Pipe Detection | Energy Act | |
|------------------|----------------|------------------------------------|------------------------------------|-------------------------------|--------------------------------|
| 02 | 30 | 10/01/1991 | Fiberglass Reinforced Plastic | Fiberglass Reinforced Plastic | Flapper Valve;High Level Alarm |
| 129 | No | 04/25/2018 | Double-Walled | Double Walled | Yes |
| Currently in Use | | Auto Dialer | U.S. Suction | Non-corrodible | |
| Diesel | | Continuous Interstitial Monitoring | Continuous Interstitial Monitoring | No | |
| 4,000 | | Gilbarco-Veeder Root/TLS-350 | | No | |

Facility Summary in Cascade County in the City of Cascade

Location: MALMSTROM AFB I 6
I-15
Cascade, MT 59421 Cascade

Legacy ID:07-09068

Facility ID: 18760
Last Inspected On: 06/11/2021
Operating Permit Renewal Date: 09/22/2024

Owner Operator Contact:

Operator Contact: Candace Ellsworth;Curtis Hester;William Smith **4067316239;4067317128**

Owner/Operator: 341 CES CEANQ

Candace Ellsworth, UST Class A Operator
Candace Ellsworth, UST Class B Global Operator
Curtis Hester, UST Class A Operator
Curtis Hester, UST Class B Global Operator
William Smith, UST Class A Operator
William Smith, UST Class B Global Operator

| Tank Code | Age | Installed | Tank Material Construction | Piping Material | Overfill Types |
|------------------|----------------|------------------------------------|------------------------------------|-------------------------------|--------------------------------|
| Tag # | AST | Sump Tightness | Secondary Option | Secondary Option | Spill Protected |
| Status | | Piping Installed Date | Catastrophic L.D. Type 3.0 | Piping Type | CP Met Types |
| Product | | Tank/Pipe CP | Tank Detection | Primary Pipe Detection | Vapor Recovery |
| Capacity | Line Tightness | ATG Type | Secondary Pipe Detection | Energy Act | |
| 02 | 29 | 05/01/1992 | Fiberglass Reinforced Plastic | Fiberglass Reinforced Plastic | Flapper Valve;High Level Alarm |
| 130 | No | 04/25/2018 | Double-Walled | Double Walled | Yes |
| Currently in Use | | Auto Dialer | U.S. Suction | Non-corrodible | |
| Diesel | | Continuous Interstitial Monitoring | Continuous Interstitial Monitoring | No | |
| 4,000 | | Gilbarco-Veeder Root/TLS-350 | | No | |

Facility Summary in Cascade County in the City of Cascade

Location: OLSON FARM
430 Klock Rd
Cascade, MT 59421-8014 Cascade

Legacy ID:07-04520

Facility ID: 18528
Last Inspected On: 01/28/2021
Operating Permit Renewal Date: 03/07/2024

Owner Operator Contact: Cory Olson

Operator Contact: Cory Olson

Owner/Operator: Cory Olson

Owner/Operator: Orin Olson

Cory Olson, UST Class A Operator

Cory Olson, UST Class B Operator

| Tank Code | Age | Installed | Tank Material Construction | Piping Material | Overfill Types |
|------------------|-----|-----------------------|---|--|-----------------|
| Tag # | AST | Sump Tightness | Secondary Option | Secondary Option | Spill Protected |
| Status | | Piping Installed Date | Catastrophic L.D. Type 3.0 | Piping Type | CP Met Types |
| Product | | Tank/Pipe CP | Tank Detection | Primary Pipe Detection | Vapor Recovery |
| Capacity | | Line Tightness | ATG Type | Secondary Pipe Detection | Energy Act |
| 02 | 22 | 04/01/1999 | Cathodically Protected Steel | Flexible Plastic | Flapper Valve |
| 4053 | No | | | Double Walled | Yes |
| Currently in Use | | | Mechanical Line Leak Detector | Pressurized | Galvanic |
| Gasoline | | 01/18/2018 | Automatic Tank Gauging 0.2 | Continuous Interstitial Monitoring;MLLD Line Tightness Testing | No |
| 6,000 | | 01/18/2018 | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | No |

Facility Summary in Cascade County in the City of Fort Shaw

Location: MALMSTROM AFB H 6
MT Hwy 21
Fort Shaw, MT 59443 Cascade

Legacy ID:07-09057

Facility ID: 18753
Last Inspected On: 06/07/2021
Operating Permit Renewal Date: 09/22/2024

Owner Operator Contact:

Operator Contact: Candace Ellsworth;Curtis Hester;William Smith

4067316239;4067317128

Owner/Operator: 341 CES CEANQ

Candace Ellsworth, UST Class A Operator

Candace Ellsworth, UST Class B Global Operator

Curtis Hester, UST Class A Operator

Curtis Hester, UST Class B Global Operator
 William Smith, UST Class A Operator
 William Smith, UST Class B Global Operator

| Tank Code | Age | Installed | Tank Material Construction | Piping Material | Overfill Types |
|------------------|-----|-----------------------|------------------------------------|------------------------------------|--------------------------------|
| Tag # | AST | Sump Tightness | Secondary Option | Secondary Option | Spill Protected |
| Status | | Piping Installed Date | Catastrophic L.D. Type 3.0 | Piping Type | CP Met Types |
| Product | | Tank/Pipe CP | Tank Detection | Primary Pipe Detection | Vapor Recovery |
| Capacity | | Line Tightness | ATG Type | Secondary Pipe Detection | Energy Act |
| 02 | 30 | 09/01/1991 | Fiberglass Reinforced Plastic | Fiberglass Reinforced Plastic | Flapper Valve;High Level Alarm |
| 123 | No | 05/17/2018 | Double-Walled | Double Walled | Yes |
| Currently in Use | | | Auto Dialer | U.S. Suction | Non-corrodible |
| Diesel | | | Continuous Interstitial Monitoring | Continuous Interstitial Monitoring | No |
| 4,000 | | | Gilbarco-Veeder Root/TLS-350 | | No |

Facility Summary in Cascade County in the City of Fort Shaw

Location: MALMSTROM AFB I 08
 MT Hwy 21
 Fort Shaw, MT 59443 Cascade

Legacy ID:07-10840

Facility ID: 18856
Last Inspected On: 06/11/2021
Operating Permit Renewal Date: 09/22/2024

Owner Operator Contact:

Operator Contact: Candace Ellsworth;Curtis Hester;William Smith **4067316239;4067317128**

Owner/Operator: 341 CES CEANQ

Candace Ellsworth, UST Class A Operator
 Candace Ellsworth, UST Class B Global Operator
 Curtis Hester, UST Class A Operator
 Curtis Hester, UST Class B Global Operator
 Kyle Topp, UST Class B Operator
 William Hoffmeister, UST Class B Operator
 William Smith, UST Class A Operator
 William Smith, UST Class B Global Operator

| Tank Code | Age | Installed | Tank Material Construction | Piping Material | Overfill Types |
|-----------|-----|-----------------------|----------------------------|------------------|-----------------|
| Tag # | AST | Sump Tightness | Secondary Option | Secondary Option | Spill Protected |
| Status | | Piping Installed Date | Catastrophic L.D. Type 3.0 | Piping Type | CP Met Types |

| Product | Tank/Pipe CP | Tank Detection | Primary Pipe Detection | Vapor Recovery | |
|------------------|----------------|------------------------------------|------------------------------------|-------------------------------|--------------------------------|
| Capacity | Line Tightness | ATG Type | Secondary Pipe Detection | Energy Act | |
| 01 | 32 | 09/26/1989 | Fiberglass Reinforced Plastic | Fiberglass Reinforced Plastic | Flapper Valve;High Level Alarm |
| 152 | No | 04/24/2018 | Double-Walled | Double Walled | Yes |
| Currently in Use | | Auto Dialer | U.S. Suction | Non-corrodible | |
| Diesel | | Continuous Interstitial Monitoring | Continuous Interstitial Monitoring | No | |
| 4,000 | | Gilbarco-Veeder Root/TLS-350 | | No | |

Facility Summary in Cascade County in the City of Fort Shaw

Location: MALMSTROM AFB I 9
 MT Hwy 21
 Fort Shaw, MT 59443 Cascade

Legacy ID:07-09071

Facility ID: 18763
Last Inspected On: 06/11/2021
Operating Permit Renewal Date: 09/22/2024

Owner Operator Contact:

Operator Contact: Candace Ellsworth;Curtis Hester;William Smith **4067316239;4067317128**

Owner/Operator: 341 CES CEANQ

- Candace Ellsworth, UST Class A Operator
- Candace Ellsworth, UST Class B Global Operator
- Curtis Hester, UST Class A Operator
- Curtis Hester, UST Class B Global Operator
- William Smith, UST Class A Operator
- William Smith, UST Class B Global Operator

| Tank Code | Age | Installed | Tank Material Construction | Piping Material | Overfill Types |
|------------------|----------------|-----------------------|------------------------------------|------------------------------------|--------------------------------|
| Tag # | AST | Sump Tightness | Secondary Option | Secondary Option | Spill Protected |
| Status | | Piping Installed Date | Catastrophic L.D. Type 3.0 | Piping Type | CP Met Types |
| Product | Tank/Pipe CP | Tank Detection | Primary Pipe Detection | Vapor Recovery | |
| Capacity | Line Tightness | ATG Type | Secondary Pipe Detection | Energy Act | |
| 02 | 30 | 10/01/1991 | Fiberglass Reinforced Plastic | Flexible Plastic | Flapper Valve;High Level Alarm |
| 132 | No | 04/24/2018 | Double-Walled | Double Walled | Yes |
| Currently in Use | | 11/16/2016 | Auto Dialer | U.S. Suction | Non-corrodible |
| Diesel | | | Continuous Interstitial Monitoring | Continuous Interstitial Monitoring | No |

4,000

Gilbarco-Veeder Root/TLS-350

No

Facility Summary in Cascade County in the City of Great Falls

Location: 15TH STREET SERVICE
1501 10th Ave S
Great Falls, MT 59405-2625 Cascade

Legacy ID:07-07573

Facility ID: 18672
Last Inspected On: 12/08/2020
Operating Permit Renewal Date: 03/27/2024

Owner Operator Contact: Gary Maki

4064532070

Operator Contact: Gary Maki

4064532070

Owner/Operator: Gary Maki

Gary Maki, UST Class A Operator
Gary Maki, UST Class B Operator

| Tank Code | Age | Installed | Tank Material Construction | Piping Material | Overfill Types |
|------------------|-----|-----------------------|---|--------------------------|-----------------|
| Tag # | AST | Sump Tightness | Secondary Option | Secondary Option | Spill Protected |
| Status | | Piping Installed Date | Catastrophic L.D. Type 3.0 | Piping Type | CP Met Types |
| Product | | Tank/Pipe CP | Tank Detection | Primary Pipe Detection | Vapor Recovery |
| Capacity | | Line Tightness | ATG Type | Secondary Pipe Detection | Energy Act |
| 05 | 32 | 01/16/1989 | Steel Clad | Steel | Flapper Valve |
| 3824 | No | | | None | Yes |
| Currently in Use | | | Electronic Line Leak Detector | Pressurized | |
| Gasoline | | 12/19/2017 | Automatic Tank Gauging 0.2 | ELLD 0.2 | No |
| 6,000 | | 12/13/2011 | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | No |
| 06 | 32 | 01/16/1989 | Steel Clad | Steel | Flapper Valve |
| 3825 | No | | | None | Yes |
| Currently in Use | | | Electronic Line Leak Detector | Pressurized | |
| Gasoline | | 12/19/2017 | Automatic Tank Gauging 0.2 | ELLD 0.2 | No |
| 4,000 | | 12/13/2011 | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | No |
| 07 | 32 | 01/16/1989 | Steel Clad | Steel | Flapper Valve |
| 3826 | No | | | None | Yes |

| | | | | | |
|------------------|----|------------|---|-------------|---------------|
| Currently in Use | | | Electronic Line Leak Detector | Pressurized | |
| Gasoline | | 12/19/2017 | Automatic Tank Gauging 0.2 | ELLD 0.2 | No |
| 4,000 | | 12/13/2011 | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | No |
| 08 | 32 | 01/16/1989 | Steel Clad | Steel | Flapper Valve |
| 3827 | No | | | None | Yes |
| Currently in Use | | | Electronic Line Leak Detector | Pressurized | |
| Diesel | | 12/19/2017 | Automatic Tank Gauging 0.2 | ELLD 0.2 | No |
| 4,000 | | 12/13/2011 | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | No |

Facility Summary in Cascade County in the City of Great Falls

Location: BENEFIS HEALTH CARE EAST CAMPUS UST
1101 26th St S
Great Falls, MT 59405-5161 Cascade

Legacy ID:07-06552

Facility ID: 18631
Last Inspected On: 09/07/2020
Operating Permit Renewal Date: 09/08/2023

Owner Operator Contact: Benefis Healthcare;James Holcomb

4062663186;4064555135

Operator Contact: Kim Frank;Louis D'Antuono;Mike Battleson;Troy England

Owner/Operator: Benefis Healthcare

- Kim Frank, UST Class A Operator
- Kim Frank, UST Class B Operator
- Louis D'Antuono, UST Class A Operator
- Louis D'Antuono, UST Class B Operator
- Mike Battleson, UST Class A Operator
- Mike Battleson, UST Class B Operator
- Troy England, UST Class A Operator
- Troy England, UST Class B Global Operator

| Tank Code | Age | Installed | Tank Material Construction | Piping Material | Overfill Types |
|-----------------|------------|------------------------------|-----------------------------------|---------------------------------|------------------------|
| Tag # | AST | Sump Tightness | Secondary Option | Secondary Option | Spill Protected |
| Status | | Piping Installed Date | Catastrophic L.D. Type 3.0 | Piping Type | CP Met Types |
| Product | | Tank/Pipe CP | Tank Detection | Primary Pipe Detection | Vapor Recovery |
| Capacity | | Line Tightness | ATG Type | Secondary Pipe Detection | Energy Act |

| | | | | | |
|----|----|------------|----------|------------------|--|
| S3 | 20 | 03/30/2001 | Concrete | Flexible Plastic | |
|----|----|------------|----------|------------------|--|

| | | | | | |
|-------------------------------|-----|------------|-------------------------------|------------------------------------|--------------------------------|
| 4584 | Yes | 09/07/2017 | Double-Walled | Double Walled | No |
| Currently in Use | | | Auto Dialer | Pressurized | |
| Diesel | | 12/12/2005 | Deferred | Continuous Interstitial Monitoring | No |
| 20,000 | | | | | No |
| 04 | 13 | 08/22/2008 | Fiberglass Reinforced Plastic | Steel | Flapper Valve;High Level Alarm |
| 5190 | No | | Double-Walled | None | Yes |
| Currently in Use | | 06/17/2008 | Not Required | Safe Suction | Non-corrodible |
| Jet Fuel (Jet-A, Jet-A1, JP5) | | | Automatic Tank Gauging 0.2 | Deferred | No |
| 2,500 | | | Veeder Root/TLS-300 | | No |

Facility Summary in Cascade County in the City of Great Falls

Location: BENEFIS HEALTH CARE WEST CAMPUS
500 15th Ave S
Great Falls, MT 59405-4304 Cascade

Legacy ID:07-03298

Facility ID: 18480
Last Inspected On: 10/30/2020
Operating Permit Renewal Date: 01/29/2024

Owner Operator Contact: Benefis Healthcare

4064555135

Operator Contact: Kim Frank;Louis D'Antuono;Scott Kincaid;Troy England **4068689675**

Owner/Operator: Benefis Healthcare

- Kim Frank, UST Class A Operator
- Kim Frank, UST Class B Operator
- Louis D'Antuono, UST Class A Operator
- Louis D'Antuono, UST Class B Operator
- Scott Kincaid, UST Class A Operator
- Scott Kincaid, UST Class B Operator
- Troy England, UST Class A Operator
- Troy England, UST Class B Global Operator

| Tank Code | Age | Installed | Tank Material Construction | Piping Material | Overfill Types |
|-----------|-----|-----------------------|----------------------------|--------------------------|-----------------|
| Tag # | AST | Sump Tightness | Secondary Option | Secondary Option | Spill Protected |
| Status | | Piping Installed Date | Catastrophic L.D. Type 3.0 | Piping Type | CP Met Types |
| Product | | Tank/Pipe CP | Tank Detection | Primary Pipe Detection | Vapor Recovery |
| Capacity | | Line Tightness | ATG Type | Secondary Pipe Detection | Energy Act |

| | | | | | |
|----|----|------------|-------------------------------|------------------|---------------|
| 05 | 25 | 07/01/1996 | Fiberglass Reinforced Plastic | Flexible Plastic | Flapper Valve |
|----|----|------------|-------------------------------|------------------|---------------|

| | | | | | |
|------------------|----|------------|---|------------------------------------|----------------|
| 3401 | No | 09/07/2017 | | Double Walled | Yes |
| Currently in Use | | | Auto Dialer | U.S. Suction | Non-corrodible |
| Diesel | | | Automatic Tank Gauging 0.1;Automatic Tank Gauging 0.2 | Continuous Interstitial Monitoring | No |
| 2,000 | | | EMCO Electronics/EECO 1500 | | No |
| 06 | 22 | 05/01/1999 | Fiberglass Reinforced Plastic | Flexible Plastic | Flapper Valve |
| 4003 | No | 09/07/2017 | | Double Walled | Yes |
| Currently in Use | | | Auto Dialer | U.S. Suction | Non-corrodible |
| Diesel | | | Automatic Tank Gauging 0.1;Automatic Tank Gauging 0.2 | Continuous Interstitial Monitoring | No |
| 15,000 | | | EMCO Electronics/EECO 1500 | | No |

Facility Summary in Cascade County in the City of Great Falls

Location: BEST OIL DISTRIBUTING INC
5401 River Dr N
Great Falls, MT 59405-1081 Cascade

Legacy ID:07-05852

Facility ID: 18596
Last Inspected On: 01/27/2021
Operating Permit Renewal Date: 04/11/2024

Owner Operator Contact: Best Oil Distributing Inc;Donald Wheeler

4064530971;4064945557

Operator Contact: Jeff Slininger;Thomas Schimerowski

4065484353

Owner/Operator: Best Oil Distributing Inc

Brian McNeil, UST Class B Operator
Eddie Parker, UST Class B Operator
Jeff Slininger, UST Class A Operator
Thomas Schimerowski, UST Class A Operator

| Tank Code | Age | Installed | Tank Material Construction | Piping Material | Overfill Types |
|-----------|-----|-----------------------|-------------------------------|-------------------------------|------------------|
| Tag # | AST | Sump Tightness | Secondary Option | Secondary Option | Spill Protected |
| Status | | Piping Installed Date | Catastrophic L.D. Type 3.0 | Piping Type | CP Met Types |
| Product | | Tank/Pipe CP | Tank Detection | Primary Pipe Detection | Vapor Recovery |
| Capacity | | Line Tightness | ATG Type | Secondary Pipe Detection | Energy Act |
| 01 | 40 | 05/01/1981 | Fiberglass Reinforced Plastic | Fiberglass Reinforced Plastic | High Level Alarm |
| 1254 | No | | | None | Yes |

| | | | | | |
|------------------|----|------------|---|-------------------------------|------------------|
| Currently in Use | | 07/27/2007 | Electronic Line Leak Detector | Pressurized | Non-corrodible |
| Diesel | | | Automatic Tank Gauging 0.2 | ELLD 0.2 | No |
| 15,000 | | 06/04/2003 | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | No |
| 02 | 40 | 05/01/1981 | Fiberglass Reinforced Plastic | Fiberglass Reinforced Plastic | High Level Alarm |
| 1255 | No | | | None | Yes |
| Currently in Use | | 07/27/2007 | Electronic Line Leak Detector | Pressurized | Non-corrodible |
| Diesel | | | Automatic Tank Gauging 0.2 | ELLD 0.2 | No |
| 15,000 | | 05/03/2002 | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | No |
| 03 | 40 | 05/01/1981 | Fiberglass Reinforced Plastic | Fiberglass Reinforced Plastic | High Level Alarm |
| 1256 | No | | | None | Yes |
| Currently in Use | | 07/27/2007 | Electronic Line Leak Detector | Pressurized | Non-corrodible |
| Diesel | | | Automatic Tank Gauging 0.2 | ELLD 0.2 | No |
| 15,000 | | 07/01/2001 | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | No |
| 04 | 40 | 05/01/1981 | Fiberglass Reinforced Plastic | Fiberglass Reinforced Plastic | High Level Alarm |
| 1257 | No | | | None | Yes |
| Currently in Use | | 07/27/2007 | Electronic Line Leak Detector | Pressurized | Non-corrodible |
| Diesel | | | Automatic Tank Gauging 0.2 | ELLD 0.2 | No |
| 15,000 | | 05/29/2003 | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | No |
| 07 | 23 | 04/01/1998 | Fiberglass Reinforced Plastic | Fiberglass Reinforced Plastic | High Level Alarm |
| 1258 | No | | | None | Yes |
| Currently in Use | | 07/27/2007 | Electronic Line Leak Detector | Pressurized | Non-corrodible |
| Gasoline | | | Automatic Tank Gauging 0.2 | ELLD 0.2 | No |
| 8,000 | | 07/20/2001 | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | No |

| | | | | | |
|------------------|----|------------|---|-------------------------------|------------------|
| 08 | 23 | 04/01/1998 | Fiberglass Reinforced Plastic | Fiberglass Reinforced Plastic | High Level Alarm |
| 1259 | No | | | None | Yes |
| Currently in Use | | 07/27/2007 | Electronic Line Leak Detector | Pressurized | Non-corrodible |
| Gasoline | | | Automatic Tank Gauging 0.2 | ELLD 0.2 | No |
| 8,000 | | 09/24/2004 | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | No |

Facility Summary in Cascade County in the City of Great Falls

Location: BISON FORD
500 10th Ave S
Great Falls, MT 59405-4047 Cascade

Legacy ID:07-00077

Facility ID: 18324
Last Inspected On: 07/23/2021
Operating Permit Renewal Date: 11/05/2024

Owner Operator Contact: Bison Motors;Richard Olson;Bison Motor Company **4067272552**

Operator Contact: Ryan Christensen

Owner/Operator: Bison Motors

Ryan Christensen, UST Class A Operator
Ryan Christensen, UST Class B Operator

| Tank Code | Age | Installed | Tank Material Construction | Piping Material | Overfill Types |
|------------------|-----|-----------------------|-------------------------------|----------------------------|-----------------|
| Tag # | AST | Sump Tightness | Secondary Option | Secondary Option | Spill Protected |
| Status | | Piping Installed Date | Catastrophic L.D. Type 3.0 | Piping Type | CP Met Types |
| Product | | Tank/Pipe CP | Tank Detection | Primary Pipe Detection | Vapor Recovery |
| Capacity | | Line Tightness | ATG Type | Secondary Pipe Detection | Energy Act |
| 07 | 33 | 08/05/1988 | Fiberglass Reinforced Plastic | Flexible Plastic | |
| 3908 | No | 04/10/2013 | | Double Walled | Yes |
| Currently in Use | | | Not Required | U.S. Suction | Non-corrodible |
| Oil, Waste | | | Automatic Tank Gauging 0.2 | 3-Year Line Tightness Test | No |
| 3,000 | | 10/31/2018 | Other/ | | No |
| 08 | 33 | 08/05/1988 | Fiberglass Reinforced Plastic | Flexible Plastic | |
| 4303 | No | 04/10/2013 | | Double Walled | Yes |
| Currently in Use | | | Not Required | U.S. Suction | Non-corrodible |

| | | | |
|------------|----------------------------|----------------------------|----|
| Oil, Waste | Automatic Tank Gauging 0.2 | 3-Year Line Tightness Test | No |
| 1,000 | 10/31/2018 | | No |

Facility Summary in Cascade County in the City of Great Falls

Location: CARLS AUTOCARE INC
2300 10th Ave S
Great Falls, MT 59405-2968 Cascade

Legacy ID:07-00621

Facility ID: 18355
Last Inspected On: 03/04/2021
Operating Permit Renewal Date: 03/18/2024

Owner Operator Contact: Carl Halcro

4067611342

Operator Contact: Carl Halcro

4067611342

Owner/Operator: Carl Halcro

Carl Halcro, UST Class A Operator
Paul Halcro, UST Class B Operator

| Tank Code | Age | Installed | Tank Material Construction | Piping Material | Overfill Types |
|------------------|-----|-----------------------|-------------------------------|-------------------------------|------------------|
| Tag # | AST | Sump Tightness | Secondary Option | Secondary Option | Spill Protected |
| Status | | Piping Installed Date | Catastrophic L.D. Type 3.0 | Piping Type | CP Met Types |
| Product | | Tank/Pipe CP | Tank Detection | Primary Pipe Detection | Vapor Recovery |
| Capacity | | Line Tightness | ATG Type | Secondary Pipe Detection | Energy Act |
| 05 | 35 | 01/27/1986 | Steel Clad | Fiberglass Reinforced Plastic | High Level Alarm |
| 1264 | No | | | None | Yes |
| Currently in Use | | | Mechanical Line Leak Detector | Pressurized | |
| Gasoline | | 09/23/2014 | Automatic Tank Gauging 0.2 | MLLD Line Tightness Testing | No |
| 8,000 | | 02/24/2017 | Veeder Root/TLS-250 | | No |
| 06 | 35 | 01/27/1986 | Steel Clad | Fiberglass Reinforced Plastic | High Level Alarm |
| 1265 | No | | | None | Yes |
| Currently in Use | | | Mechanical Line Leak Detector | Pressurized | |
| Diesel | | 09/23/2014 | Automatic Tank Gauging 0.2 | MLLD Line Tightness Testing | No |
| 6,000 | | 02/24/2017 | Veeder Root/TLS-250 | | No |
| 07 | 35 | 01/27/1986 | Steel Clad | Fiberglass Reinforced Plastic | High Level Alarm |

| 1266 | No | | None | Yes |
|------------------|------------|--|-------------------------------|-----------------------------|
| Currently in Use | | | Mechanical Line Leak Detector | Pressurized |
| Gasoline | 09/23/2014 | | Automatic Tank Gauging 0.2 | MLLD Line Tightness Testing |
| 6,000 | 02/24/2017 | | Veeder Root/TLS-250 | No |

Facility Summary in Cascade County in the City of Great Falls

Location: CASCADE COUNTY SHERIFFS OFFICE
3800 Ulm N Frontage Rd
Great Falls, MT 59404-5574 Cascade

Legacy ID:07-13772

Facility ID: 19066
Last Inspected On: 08/31/2020
Operating Permit Renewal Date: 09/12/2023

Owner Operator Contact: Cascade County Sheriffs/Adult Detention

4064546834

Operator Contact: William Mintsiveris;Cascade County Sheriffs/Adult Detention

4067811293;4064546834

Owner/Operator: Cascade County Sheriffs/Adult Detention

William Mintsiveris, UST Class A Operator
William Mintsiveris, UST Class B Global Operator
William Mintsiveris, UST Class B Operator

| Tank Code | Age | Installed | Tank Material Construction | Piping Material | Overfill Types |
|------------------------|-----|-----------------------|------------------------------------|---|-----------------|
| Tag # | AST | Sump Tightness | Secondary Option | Secondary Option | Spill Protected |
| Status | | Piping Installed Date | Catastrophic L.D. Type 3.0 | Piping Type | CP Met Types |
| Product | | Tank/Pipe CP | Tank Detection | Primary Pipe Detection | Vapor Recovery |
| Capacity | | Line Tightness | ATG Type | Secondary Pipe Detection | Energy Act |
| 02 | 24 | 05/06/1997 | Cathodically Protected Steel | Flexible Plastic | |
| 4489 | No | | Double-Walled | Double Walled | Yes |
| Currently in Use | | | Not Required | U.S. Suction | Galvanic |
| Oil, Waste | | 10/11/2017 | Continuous Interstitial Monitoring | 3-Year Line Tightness Test;Continuous Interstitial Monitoring | No |
| 600 | | 09/02/2014 | | | No |
| S1 | 24 | 05/06/1997 | Unknown | Flexible Plastic | Flapper Valve |
| 537 | Yes | 09/02/2014 | | Double Walled | Yes |
| Temporarily Out of Use | | | Continuous Interstitial Monitoring | Pressurized | |
| Diesel | | | Deferred | Continuous Interstitial Monitoring | No |
| 2,000 | | | | | No |

Facility Summary in Cascade County in the City of Great Falls

Location: CITY MOTOR CO INC
3900 10th Ave S
Great Falls, MT 59405-3648 Cascade

Legacy ID:07-05853

Facility ID: 18597
Last Inspected On: 02/04/2020
Operating Permit Renewal Date: 07/01/2023

Owner Operator Contact: City Motors

4067614900

Operator Contact: Ken Myers

Owner/Operator: City Motors

Casey Oneill, UST Class B Operator
Ken Myers, UST Class A Operator
Ken Myers, UST Class B Operator

| Tank Code | Age | Installed | Tank Material Construction | Piping Material | Overfill Types |
|------------------|-----|-----------------------|-------------------------------|-------------------------------------|--------------------------------|
| Tag # | AST | Sump Tightness | Secondary Option | Secondary Option | Spill Protected |
| Status | | Piping Installed Date | Catastrophic L.D. Type 3.0 | Piping Type | CP Met Types |
| Product | | Tank/Pipe CP | Tank Detection | Primary Pipe Detection | Vapor Recovery |
| Capacity | | Line Tightness | ATG Type | Secondary Pipe Detection | Energy Act |
| 06 | 32 | 09/01/1989 | Fiberglass Reinforced Plastic | Fiberglass Reinforced Plastic | Flapper Valve;High Level Alarm |
| 2365 | No | | | None | Yes |
| Currently in Use | | | Mechanical Line Leak Detector | Pressurized | Non-corrodible |
| Gasoline | | | Automatic Tank Gauging 0.2 | MLLD Line Tightness Testing | No |
| 3,000 | | 02/16/2017 | EMCO Electronics/EECO 1500 | | No |
| 07 | 32 | 09/01/1989 | Fiberglass Reinforced Plastic | Fiberglass Reinforced Plastic | High Level Alarm |
| 2366 | No | | | None | Yes |
| Currently in Use | | | Not Required | U.S. Suction | Non-corrodible |
| Oil, Waste | | | Automatic Tank Gauging 0.2 | 3-Year Line Tightness Test;Deferred | No |
| 3,000 | | 02/16/2017 | EMCO Electronics/EECO 1500 | | No |

Facility Summary in Cascade County in the City of Great Falls

Location: FEDERAL AVIATION ADMIN AIRWAY TERMINAL
2830 Airport Ave A
Great Falls, MT 59404-5544 Cascade

Legacy ID:07-02558

Facility ID: 18445
Last Inspected On: 03/11/2021
Operating Permit Renewal Date: 03/26/2024

Owner Operator Contact: Federal Aviation Admin Great Falls

4067888041

Operator Contact: Joe Konesky

Owner/Operator: Federal Aviation Admin Great Falls

Joe Konesky, UST Class A Operator
 Joe Konesky, UST Class B Global Operator

| Tank Code | Age | Installed | Tank Material Construction | Piping Material | Overfill Types |
|------------------|-----|-----------------------|----------------------------|----------------------------|-----------------|
| Tag # | AST | Sump Tightness | Secondary Option | Secondary Option | Spill Protected |
| Status | | Piping Installed Date | Catastrophic L.D. Type 3.0 | Piping Type | CP Met Types |
| Product | | Tank/Pipe CP | Tank Detection | Primary Pipe Detection | Vapor Recovery |
| Capacity | | Line Tightness | ATG Type | Secondary Pipe Detection | Energy Act |
| S2 | 24 | 07/31/1997 | Unknown | Flexible Plastic | |
| 1048 | Yes | 05/07/2012 | | Double Walled | Yes |
| Currently in Use | | | Not Required | U.S. Suction | |
| Diesel | | | Deferred | 3-Year Line Tightness Test | No |
| 1,500 | | 10/18/2017 | | | No |

Facility Summary in Cascade County in the City of Great Falls

Location: FEDERAL AVIATION ADMIN ARSR 4
 Bootlegger Rdg
 Great Falls, MT 59401 Cascade

Legacy ID:07-13710

Facility ID: 19056
Last Inspected On: 03/25/2021
Operating Permit Renewal Date: 06/15/2024

Owner Operator Contact: Federal Aviation Admin Great Falls

4067888041

Operator Contact: Joe Konesky

Owner/Operator: Federal Aviation Admin Great Falls

Joe Konesky, UST Class A Operator
 Joe Konesky, UST Class B Global Operator

| Tank Code | Age | Installed | Tank Material Construction | Piping Material | Overfill Types |
|-----------|-----|-----------------------|----------------------------|--------------------------|-----------------|
| Tag # | AST | Sump Tightness | Secondary Option | Secondary Option | Spill Protected |
| Status | | Piping Installed Date | Catastrophic L.D. Type 3.0 | Piping Type | CP Met Types |
| Product | | Tank/Pipe CP | Tank Detection | Primary Pipe Detection | Vapor Recovery |
| Capacity | | Line Tightness | ATG Type | Secondary Pipe Detection | Energy Act |
| S1 | 25 | 04/01/1996 | Unknown | Flexible Plastic | |
| 4564 | Yes | 06/09/2015 | | Double Walled | Yes |

| | | | |
|------------------|--|------------------------------------|----|
| Currently in Use | Auto Dialer;Continuous Interstitial Monitoring | Pressurized | |
| Diesel | Deferred | Continuous Interstitial Monitoring | No |
| 2,000 | | | No |

Facility Summary in Cascade County in the City of Great Falls

Location: GAS N SHOP
101 Smelter Ave NE
Great Falls, MT 59404 Cascade

Legacy ID:07-05851

Facility ID: 18595
Last Inspected On: 12/09/2020
Operating Permit Renewal Date: 03/27/2024

Owner Operator Contact: Muhar LLC

4066246912

Operator Contact: Gurinderbir Muhar;Harinder Singh

4068682062;4086609884

Owner/Operator: Muhar LLC

Owner/Operator: Sandeep Muhar

- Frank Kruse, UST Class B Operator
- Gurinderbir Muhar, UST Class A Operator
- Gurinderbir Muhar, UST Class B Global Operator
- Harinder Singh, UST Class A Operator
- Sandeep Muhar, UST Class B Global Operator

| Tank Code | Age | Installed | Tank Material Construction | Piping Material | Overfill Types |
|------------------|-----|-----------------------|---|-------------------------------|------------------|
| Tag # | AST | Sump Tightness | Secondary Option | Secondary Option | Spill Protected |
| Status | | Piping Installed Date | Catastrophic L.D. Type 3.0 | Piping Type | CP Met Types |
| Product | | Tank/Pipe CP | Tank Detection | Primary Pipe Detection | Vapor Recovery |
| Capacity | | Line Tightness | ATG Type | Secondary Pipe Detection | Energy Act |
| 06 | 33 | 07/21/1988 | Steel Clad | Fiberglass Reinforced Plastic | High Level Alarm |
| 1251 | No | | | None | Yes |
| Currently in Use | | | Not Required | Safe Suction | Non-corrodible |
| Gasoline | | | Automatic Tank Gauging 0.2 | Deferred | No |
| 4,000 | | 02/28/2006 | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | No |
| 07 | 33 | 07/21/1988 | Steel Clad | Fiberglass Reinforced Plastic | High Level Alarm |
| 1252 | No | | | None | Yes |

| | | | | | |
|------------------|----|------------|---|-------------------------------|------------------|
| Currently in Use | | | Electronic Line Leak Detector | Pressurized | Non-corrodible |
| Gasoline | | | Automatic Tank Gauging 0.2 | ELLD 0.1;ELLD 0.2 | No |
| 4,000 | | 09/18/2017 | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | No |
| 08 | 33 | 07/21/1988 | Steel Clad | Fiberglass Reinforced Plastic | High Level Alarm |
| 1253 | No | | | None | Yes |
| Currently in Use | | | Electronic Line Leak Detector | Pressurized | Non-corrodible |
| Gasoline | | | Automatic Tank Gauging 0.2 | ELLD 0.1;ELLD 0.2 | No |
| 4,000 | | 09/20/2017 | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | No |

Facility Summary in Cascade County in the City of Great Falls

Location: Gas N Shop #3
1001 34 Ave. NE
Great Falls, MT 59404 Cascade

Legacy ID:07-05008

Facility ID: 18552
Last Inspected On: 06/03/2019
Operating Permit Renewal Date: 06/30/2022

Owner Operator Contact: Gas N Shop Inc;Ronald Eli;Valley Country Store Inc **4066609884;4069653960;4069653962**

Operator Contact:

Owner/Operator: Gas N Shop Inc

Sandeep Muhar, UST Class B Operator

| Tank Code | Age | Installed | Tank Material Construction | Piping Material | Overfill Types |
|------------------|-----|-----------------------|-------------------------------|-------------------------------|------------------|
| Tag # | AST | Sump Tightness | Secondary Option | Secondary Option | Spill Protected |
| Status | | Piping Installed Date | Catastrophic L.D. Type 3.0 | Piping Type | CP Met Types |
| Product | | Tank/Pipe CP | Tank Detection | Primary Pipe Detection | Vapor Recovery |
| Capacity | | Line Tightness | ATG Type | Secondary Pipe Detection | Energy Act |
| 05 | 24 | 04/01/1997 | Fiberglass Reinforced Plastic | Fiberglass Reinforced Plastic | High Level Alarm |
| 2208 | No | | | None | Yes |
| Currently in Use | | | Electronic Line Leak Detector | Pressurized | Non-corrodible |
| Gasoline | | | Automatic Tank Gauging 0.2 | ELLD 0.1;ELLD 0.2 | No |
| 10,000 | | 01/20/2010 | Gilbarco/EMC Basic | | No |

| | | | | | |
|------------------|----|------------|-------------------------------|-------------------------------|------------------|
| 06 | 24 | 04/01/1997 | Fiberglass Reinforced Plastic | Fiberglass Reinforced Plastic | High Level Alarm |
| 2209 | No | | | None | Yes |
| Currently in Use | | | Electronic Line Leak Detector | Pressurized | Non-corrodible |
| Gasoline | | | Automatic Tank Gauging 0.2 | ELLD 0.1;ELLD 0.2 | No |
| 4,000 | | 01/20/2010 | Gilbarco/EMC Basic | | No |
| 07 | 24 | 04/01/1997 | Fiberglass Reinforced Plastic | Fiberglass Reinforced Plastic | High Level Alarm |
| 2210 | No | | | None | Yes |
| Currently in Use | | | Electronic Line Leak Detector | Pressurized | Non-corrodible |
| Diesel | | | Automatic Tank Gauging 0.2 | ELLD 0.1;ELLD 0.2 | No |
| 4,000 | | 01/20/2010 | Gilbarco/EMC Basic | | No |

Facility Summary in Cascade County in the City of Great Falls

Location: GAS N SHOP 2
101 Truman Ave
Great Falls, MT 59404-6210 Cascade

Legacy ID:07-00097

Facility ID: 18333
Last Inspected On: 12/09/2020
Operating Permit Renewal Date: 03/13/2024

Owner Operator Contact: Robert Moss;Thriftway Marketing Corp - Former Gasamat of MT;Sandeep Muhar

4086246912;5053265571

Operator Contact: Gurinderbir Muhar;Perry Joyce

4086609884

Owner/Operator: Kevin Joyce

Owner/Operator: Sandeep Muhar

- Gurinderbir Muhar, UST Class A Operator
- Gurinderbir Muhar, UST Class B Global Operator
- Kevin Joyce, UST Class B Global Operator
- Maureen Pettis, UST Class B Operator
- Perry Joyce, UST Class A Operator
- Sandeep Muhar, UST Class B Global Operator

| Tank Code | Age | Installed | Tank Material Construction | Piping Material | Overfill Types |
|-----------|-----|-----------------------|----------------------------|------------------------|-----------------|
| Tag # | AST | Sump Tightness | Secondary Option | Secondary Option | Spill Protected |
| Status | | Piping Installed Date | Catastrophic L.D. Type 3.0 | Piping Type | CP Met Types |
| Product | | Tank/Pipe CP | Tank Detection | Primary Pipe Detection | Vapor Recovery |

| Capacity | Line Tightness | ATG Type | Secondary Pipe Detection | Energy Act | |
|------------------|----------------|------------|-------------------------------|--|------------------|
| 04 | 31 | 03/04/1990 | Fiberglass Reinforced Plastic | Flexible Plastic | Ball Float Valve |
| 3545 | No | | | Double Walled | Yes |
| Currently in Use | | | Electronic Line Leak Detector | Pressurized | Non-corrodible |
| Gasoline | | 02/14/2005 | Automatic Tank Gauging 0.2 | Continuous Interstitial Monitoring; ELLD 0.1; ELLD 0.2 | No |
| 10,000 | | 12/19/2017 | Veeder Root/TLS-450 | | No |
| 05 | 31 | 03/04/1990 | Fiberglass Reinforced Plastic | Flexible Plastic | Flapper Valve |
| 3546 | No | | | Double Walled | Yes |
| Currently in Use | | | Electronic Line Leak Detector | Pressurized | Non-corrodible |
| Diesel | | 02/14/2005 | Automatic Tank Gauging 0.2 | Continuous Interstitial Monitoring; ELLD 0.1; ELLD 0.2 | No |
| 10,000 | | 12/19/2017 | Veeder Root/TLS-450 | | No |
| 06 | 31 | 03/04/1990 | Fiberglass Reinforced Plastic | Flexible Plastic | Flapper Valve |
| 3547 | No | | | Double Walled | Yes |
| Currently in Use | | | Electronic Line Leak Detector | Pressurized | Non-corrodible |
| Gasoline | | 02/14/2005 | Automatic Tank Gauging 0.2 | Continuous Interstitial Monitoring; ELLD 0.1; ELLD 0.2 | No |
| 10,000 | | 12/19/2017 | Veeder Root/TLS-450 | | No |

Facility Summary in Cascade County in the City of Great Falls

Location: GENERAL DISTRIBUTING CO INC
430 17th Ave NE
Great Falls, MT 59404-1936 Cascade

Legacy ID:07-00081

Facility ID: 18325
Last Inspected On: 06/25/2020
Operating Permit Renewal Date: 08/05/2017

Owner Operator Contact: General Distributing Co Inc

4064541351

Operator Contact: Sean Kelley

4064541351

Owner/Operator: General Distributing Co Inc

Sean Kelley, UST Class A Operator
Sean Kelley, UST Class B Global Operator

| Tank Code | Age | Installed | Tank Material Construction | Piping Material | Overfill Types |
|-----------|-----|-----------|----------------------------|-----------------|----------------|
|-----------|-----|-----------|----------------------------|-----------------|----------------|

| Tag # | AST | Sump Tightness | Secondary Option | Secondary Option | Spill Protected |
|------------------------|-----|-----------------------|--------------------------------------|--------------------------|-----------------|
| Status | | Piping Installed Date | Catastrophic L.D. Type 3.0 | Piping Type | CP Met Types |
| Product | | Tank/Pipe CP | Tank Detection | Primary Pipe Detection | Vapor Recovery |
| Capacity | | Line Tightness | ATG Type | Secondary Pipe Detection | Energy Act |
| 01 | 43 | 02/14/1978 | Fiberglass Reinforced Plastic | Flexible Plastic | Flapper Valve |
| 1206 | No | | | None | Yes |
| Temporarily Out of Use | | | Not Required | Safe Suction | |
| Gasoline | | | Statistical Inventory Reconciliation | Deferred | No |
| 2,000 | | | | | No |
| 02 | 43 | 02/14/1978 | Fiberglass Reinforced Plastic | Flexible Plastic | Flapper Valve |
| 1207 | No | | | None | Yes |
| Temporarily Out of Use | | | Not Required | Safe Suction | |
| Gasoline | | | Statistical Inventory Reconciliation | Deferred | No |
| 4,000 | | | | | No |
| 03 | 43 | 02/14/1978 | Fiberglass Reinforced Plastic | Flexible Plastic | Flapper Valve |
| 1208 | No | | | None | Yes |
| Temporarily Out of Use | | | Not Required | Safe Suction | |
| Diesel | | | Statistical Inventory Reconciliation | Deferred | No |
| 6,000 | | | | | No |

Facility Summary in Cascade County in the City of Great Falls

Location: GREAT FALLS FIRE STATION 1 GREAT FALLS
105 9th St S
Great Falls, MT 59401-3715 Cascade

Legacy ID:07-00680

Facility ID: 18359
Last Inspected On: 01/02/2019
Operating Permit Renewal Date: 01/10/2022

Owner Operator Contact: City of Great Falls;N/A ZZZ - TBL_OWN : 184;City of Great Falls **4067711258**

Operator Contact: Dale Calvert;Doug Alm **4067711401**

Owner/Operator: City of Great Falls

Dale Calvert, UST Class A Operator
 Doug Alm, UST Class A Operator
 Doug Alm, UST Class B Global Operator
 Doug Alm, UST Class B Operator

| Tank Code | Age | Installed | Tank Material Construction | Piping Material | Overfill Types |
|------------------------|-----|-----------------------|-------------------------------|-------------------------------|------------------|
| Tag # | AST | Sump Tightness | Secondary Option | Secondary Option | Spill Protected |
| Status | | Piping Installed Date | Catastrophic L.D. Type 3.0 | Piping Type | CP Met Types |
| Product | | Tank/Pipe CP | Tank Detection | Primary Pipe Detection | Vapor Recovery |
| Capacity | | Line Tightness | ATG Type | Secondary Pipe Detection | Energy Act |
| 03 | 30 | 04/22/1991 | Fiberglass Reinforced Plastic | Fiberglass Reinforced Plastic | High Level Alarm |
| 636 | No | | | None | Yes |
| Temporarily Out of Use | | | Mechanical Line Leak Detector | Pressurized | |
| Diesel | | 07/30/2013 | Automatic Tank Gauging 0.2 | MLLD Line Tightness Testing | No |
| 2,086 | | 02/11/2016 | Veeder Root/TLS-450 | | No |
| 04 | 30 | 04/22/1991 | Fiberglass Reinforced Plastic | Fiberglass Reinforced Plastic | High Level Alarm |
| 637 | No | | | None | Yes |
| Temporarily Out of Use | | | Mechanical Line Leak Detector | Pressurized | |
| Diesel | | 07/30/2013 | Automatic Tank Gauging 0.2 | MLLD Line Tightness Testing | No |
| 2,086 | | 02/11/2016 | Veeder Root/TLS-450 | | No |
| 05 | 30 | 04/22/1991 | Fiberglass Reinforced Plastic | Fiberglass Reinforced Plastic | High Level Alarm |
| 638 | No | | | None | Yes |
| Temporarily Out of Use | | | Mechanical Line Leak Detector | Pressurized | |
| Gasoline | | 07/30/2013 | Automatic Tank Gauging 0.2 | MLLD Line Tightness Testing | No |
| 10,000 | | 02/11/2016 | Veeder Root/TLS-450 | | No |

Facility Summary in Cascade County in the City of Great Falls

Location: GREAT FALLS FLYING J
 3715 31st St SW
 Great Falls, MT 59404-4700 Cascade

Legacy ID:56-14148

Facility ID: 30784
Last Inspected On: 06/24/2019
Operating Permit Renewal Date: 04/09/2022

Owner Operator Contact:

Operator Contact: Charles Armstrong

4064976947

Owner/Operator: Great Falls 6 Town Pump LLC

Charles Armstrong, UST Class A Operator
 Charles Armstrong, UST Class B Global Operator
 Don Edmisten, UST Class B Global Operator

| Tank Code | Age | Installed | Tank Material Construction | Piping Material | Overfill Types |
|------------------|-----|-----------------------|--|--|------------------|
| Tag # | AST | Sump Tightness | Secondary Option | Secondary Option | Spill Protected |
| Status | | Piping Installed Date | Catastrophic L.D. Type 3.0 | Piping Type | CP Met Types |
| Product | | Tank/Pipe CP | Tank Detection | Primary Pipe Detection | Vapor Recovery |
| Capacity | | Line Tightness | ATG Type | Secondary Pipe Detection | Energy Act |
| 01 | 16 | 02/25/2005 | Fiberglass Reinforced Plastic | Fiberglass Reinforced Plastic | Ball Float Valve |
| 4956 | No | | Double-Walled | Double Walled | Yes |
| Currently in Use | | | Electronic Line Leak Detector;Mechanical Line Leak Detector | Pressurized | |
| Diesel | | | Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation | Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation | No |
| 20,000 | | 02/29/2016 | | | No |
| 02 | 16 | 02/25/2005 | Fiberglass Reinforced Plastic | Fiberglass Reinforced Plastic | Ball Float Valve |
| 4957 | No | | Double-Walled | Double Walled | Yes |
| Currently in Use | | | Electronic Line Leak Detector;Mechanical Line Leak Detector | Pressurized | |
| Diesel | | | Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation | Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation | No |
| 20,000 | | 02/24/2016 | | | No |

| | | | | | |
|------------------|----|------------|--|--|------------------|
| 03 | 16 | 02/25/2005 | Fiberglass Reinforced Plastic | Fiberglass Reinforced Plastic | Ball Float Valve |
| 4958 | No | | Double-Walled | Double Walled | Yes |
| Currently in Use | | | Electronic Line Leak Detector;Mechanical Line Leak Detector | Pressurized | |
| Gasoline | | | Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation | Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation | No |
| 20,000 | | 02/24/2016 | | | No |
| 04 | 16 | 01/25/2005 | Fiberglass Reinforced Plastic | Fiberglass Reinforced Plastic | Ball Float Valve |
| 4959 | No | | Double-Walled | Double Walled | Yes |
| Currently in Use | | | Electronic Line Leak Detector;Mechanical Line Leak Detector | Pressurized | |
| Gasoline | | | Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation | Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation | No |
| 12,000 | | 02/23/2016 | | | No |

Facility Summary in Cascade County in the City of Great Falls

Location: GREAT FALLS INTERNATIONAL AIRPORT FUEL FARM 1
1931 Airport Ct
Great Falls, MT 59404-5599 Cascade

Legacy ID:07-10676

Facility ID: 18828
Last Inspected On: 09/19/2019
Operating Permit Renewal Date: 10/11/2019

Owner Operator Contact: Dwight Holman;Holman Aviation Co;Great Falls International Airport

4067880200;4064537613

Operator Contact: Chris Houghton;Christopher Upchurch;Jeremy Hill;Kent Funyak;Michael Novak;Mike Cunningham;Rod Hall

4067273404;4067993189

Owner/Operator: Great Falls International Airport

- Chris Houghton, UST Class A Operator
- Chris Houghton, UST Class B Operator
- Christopher Upchurch, UST Class A Operator
- Christopher Upchurch, UST Class B Operator
- Jeremy Hill, UST Class A Operator
- Jeremy Hill, UST Class B Operator
- Kent Funyak, UST Class A Operator
- Kent Funyak, UST Class B Operator
- LeeRoy Bollich, UST Class B Operator

Michael Novak, UST Class A Operator
 Michael Novak, UST Class B Global Operator
 Michael Sullivan, UST Class B Global Operator
 Mike Cunningham, UST Class A Operator
 Mike Cunningham, UST Class B Operator
 Rod Hall, UST Class A Operator
 Rod Hall, UST Class B Operator

| Tank Code | Age | Installed | Tank Material Construction | Piping Material | Overfill Types |
|-------------------------------|-----|-----------------------|---|--------------------------|------------------|
| Tag # | AST | Sump Tightness | Secondary Option | Secondary Option | Spill Protected |
| Status | | Piping Installed Date | Catastrophic L.D. Type 3.0 | Piping Type | CP Met Types |
| Product | | Tank/Pipe CP | Tank Detection | Primary Pipe Detection | Vapor Recovery |
| Capacity | | Line Tightness | ATG Type | Secondary Pipe Detection | Energy Act |
| 10 | 26 | 11/01/1995 | Fiberglass Reinforced Plastic | No Piping | High Level Alarm |
| 3749 | No | | | None | Yes |
| Currently in Use | | | Not Required | U.S. Suction | |
| Jet Fuel (Jet-A, Jet-A1, JP5) | | 08/31/2006 | Automatic Tank Gauging 0.2 | Deferred | No |
| 20,000 | | | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | No |
| 11 | 26 | 11/01/1995 | Fiberglass Reinforced Plastic | No Piping | High Level Alarm |
| 3750 | No | | | None | Yes |
| Currently in Use | | | Not Required | U.S. Suction | |
| Aviation Gas | | 08/31/2006 | Automatic Tank Gauging 0.2 | | No |
| 20,000 | | | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | No |

Facility Summary in Cascade County in the City of Great Falls

Location: GREAT FALLS SINCLAIR
 620 57th St S
 Great Falls, MT 59405-3940 Cascade

Legacy ID:07-02087

Facility ID: 18422
Last Inspected On: 03/31/2021
Operating Permit Renewal Date: 02/26/2024

Owner Operator Contact: David Sowko;Sinclair Oil Corp Sunlight Ranch;Set Five LLC Harlowtown **3037619201;4066324630**

Operator Contact: Derek Richardson;Greg Haines;William Raaen **4062319465;4065902667;4067500090**

Owner/Operator: Set Five LLC Harlowtown

Derek Richardson, UST Class A Operator
 Derek Richardson, UST Class B Global Operator
 Greg Haines, UST Class A Operator
 Greg Haines, UST Class B Operator
 Mitzi McIntosh, UST Class B Operator
 NayOmie Bean, UST Class B Global Operator
 Norm Jensen, UST Class B Operator
 Roberta Gresham, UST Class B Operator
 Thomas Ohagan, UST Class B Global Operator
 William Raaen, UST Class A Operator
 William Raaen, UST Class B Operator

| Tank Code | Age | Installed | Tank Material Construction | Piping Material | Overfill Types |
|------------------------|-----|-----------------------|---|-------------------------------|-------------------|
| Tag # | AST | Sump Tightness | Secondary Option | Secondary Option | Spill Protected |
| Status | | Piping Installed Date | Catastrophic L.D. Type 3.0 | Piping Type | CP Met Types |
| Product | | Tank/Pipe CP | Tank Detection | Primary Pipe Detection | Vapor Recovery |
| Capacity | | Line Tightness | ATG Type | Secondary Pipe Detection | Energy Act |
| 01 | 43 | 04/04/1978 | Bare Steel | Fiberglass Reinforced Plastic | High Level Alarm |
| 1933 | No | | | None | Yes |
| Temporarily Out of Use | | 04/29/1998 | Mechanical Line Leak Detector | Pressurized | Impressed Current |
| Diesel | | 09/05/2017 | Automatic Tank Gauging 0.2 | MLLD Line Tightness Testing | No |
| 8,000 | | 09/05/2017 | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | No |
| 02 | 43 | 04/04/1978 | Bare Steel | Fiberglass Reinforced Plastic | High Level Alarm |
| 1934 | No | | | None | Yes |
| Temporarily Out of Use | | 04/29/1998 | Mechanical Line Leak Detector | Pressurized | Impressed Current |
| Gasoline | | 09/05/2017 | Automatic Tank Gauging 0.2 | MLLD Line Tightness Testing | No |
| 8,000 | | 09/05/2017 | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | No |
| 03 | 43 | 04/04/1978 | Bare Steel | Fiberglass Reinforced Plastic | High Level Alarm |
| 1935 | No | | | None | Yes |

| | | | | |
|------------------------|------------|---|-----------------------------|-------------------|
| Temporarily Out of Use | 04/29/1998 | Mechanical Line Leak Detector | Pressurized | Impressed Current |
| Gasoline | 09/05/2017 | Automatic Tank Gauging 0.2 | MLLD Line Tightness Testing | No |
| 12,000 | 09/05/2017 | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | No |

Facility Summary in Cascade County in the City of Great Falls

Location: GREAT FALLS TRANSIT DISTRICT
3905 N Star Blvd
Great Falls, MT 59405-1036 Cascade

Legacy ID:07-05346

Facility ID: 18560
Last Inspected On: 03/21/2019
Operating Permit Renewal Date: 06/02/2022

Owner Operator Contact: Great Falls Transit District;N/A ZZZ - TBL_OWN :
436;Great Falls Transit District

Operator Contact: Jack Hoffman;James Helgeson

Owner/Operator: Great Falls Transit District

Jack Hoffman, UST Class A Operator
Jack Hoffman, UST Class B Global Operator
James Helgeson, UST Class A Operator
James Helgeson, UST Class B Operator

| Tank Code | Age | Installed | Tank Material Construction | Piping Material | Overfill Types |
|------------------|-----|-----------------------|---|-------------------------------|------------------|
| Tag # | AST | Sump Tightness | Secondary Option | Secondary Option | Spill Protected |
| Status | | Piping Installed Date | Catastrophic L.D. Type 3.0 | Piping Type | CP Met Types |
| Product | | Tank/Pipe CP | Tank Detection | Primary Pipe Detection | Vapor Recovery |
| Capacity | | Line Tightness | ATG Type | Secondary Pipe Detection | Energy Act |
| 01 | 36 | 05/06/1985 | Fiberglass Reinforced Plastic | Fiberglass Reinforced Plastic | Positive Shutoff |
| 1233 | No | | | None | Yes |
| Currently in Use | | | Electronic Line Leak Detector | Pressurized | |
| Diesel | | | Automatic Tank Gauging 0.2 | ELLD 0.1;ELLD 0.2 | No |
| 12,380 | | 02/21/2007 | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | No |
| 02 | 36 | 05/06/1985 | Fiberglass Reinforced Plastic | Fiberglass Reinforced Plastic | |
| 1234 | No | | | None | Yes |
| Currently in Use | | | Not Required | Gravity Feed | |

| | | | | |
|------------|------------|---|----------------------------|----|
| Oil, Waste | | Automatic Tank Gauging 0.2 | 3-Year Line Tightness Test | No |
| 1,000 | 02/26/2016 | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | No |

Facility Summary in Cascade County in the City of Great Falls

Location: H and R #1
3200 10th Ave S
Great Falls, MT 59405 Cascade

Legacy ID:07-00092

Facility ID: 18331
Last Inspected On: 10/07/2019
Operating Permit Renewal Date: 11/20/2022

Owner Operator Contact: Dirk Cooper;Hi Noon Petroleum Missoula

4065420384

Operator Contact: Harinder Singh;Rajinder Singh

4067614791;4068682062

Owner/Operator: Singh Inc

Frank Kruse, UST Class B Global Operator
Frank Kruse, UST Class B Operator
Harinder Singh, UST Class A Operator
Rajinder Singh, UST Class A Operator

| Tank Code | Age | Installed | Tank Material Construction | Piping Material | Overfill Types |
|------------------|-----|-----------------------|---|-------------------------------|-------------------|
| Tag # | AST | Sump Tightness | Secondary Option | Secondary Option | Spill Protected |
| Status | | Piping Installed Date | Catastrophic L.D. Type 3.0 | Piping Type | CP Met Types |
| Product | | Tank/Pipe CP | Tank Detection | Primary Pipe Detection | Vapor Recovery |
| Capacity | | Line Tightness | ATG Type | Secondary Pipe Detection | Energy Act |
| 01 | 51 | 12/31/1970 | Cathodically Protected Steel | Fiberglass Reinforced Plastic | Flapper Valve |
| 3839 | No | | Lined Interior/Impressed Current | None | Yes |
| Currently in Use | | | Electronic Line Leak Detector | Pressurized | Impressed Current |
| Gasoline | | 09/10/2015 | Automatic Tank Gauging 0.1 | ELLD 0.1;ELLD 0.2 | No |
| 10,000 | | 06/15/2013 | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | No |
| 02 | 51 | 12/31/1970 | Cathodically Protected Steel | Fiberglass Reinforced Plastic | Flapper Valve |
| 3840 | No | | Lined Interior/Impressed Current | None | Yes |
| Currently in Use | | | Electronic Line Leak Detector | Pressurized | Impressed Current |
| Gasoline | | 09/10/2015 | Automatic Tank Gauging 0.1 | ELLD 0.1;ELLD 0.2 | No |
| 10,000 | | 06/15/2013 | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | No |

| | | | | | |
|------------------|----|------------|---|-------------------------------|-------------------|
| 03 | 51 | 12/31/1970 | Cathodically Protected Steel | Fiberglass Reinforced Plastic | Flapper Valve |
| 4440 | No | | Lined Interior/Impressed Current | None | Yes |
| Currently in Use | | | Electronic Line Leak Detector | Pressurized | Impressed Current |
| Diesel | | 09/10/2015 | Automatic Tank Gauging 0.1 | ELLD 0.1;ELLD 0.2 | No |
| 10,000 | | 06/15/2013 | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | No |

Facility Summary in Cascade County in the City of Great Falls

Location: H and R #2
1300 12th Ave S
Great Falls, MT 59405 Cascade

Legacy ID:07-00082

Facility ID: 18326
Last Inspected On: 12/08/2020
Operating Permit Renewal Date: 05/29/2024

Owner Operator Contact: Harinder Singh;H and R Inc

4068682062;4068682062

Operator Contact: Harinder Singh;Rajinder Singh

4067614791;4068682062

Owner/Operator: Singh Inc

Frank Kruse, UST Class B Global Operator
Frank Kruse, UST Class B Operator
Harinder Singh, UST Class A Operator
Rajinder Singh, UST Class A Operator

| Tank Code | Age | Installed | Tank Material Construction | Piping Material | Overfill Types |
|------------------|-----|-----------------------|---|---|------------------|
| Tag # | AST | Sump Tightness | Secondary Option | Secondary Option | Spill Protected |
| Status | | Piping Installed Date | Catastrophic L.D. Type 3.0 | Piping Type | CP Met Types |
| Product | | Tank/Pipe CP | Tank Detection | Primary Pipe Detection | Vapor Recovery |
| Capacity | | Line Tightness | ATG Type | Secondary Pipe Detection | Energy Act |
| 03 | 10 | 11/01/2011 | Fiberglass Reinforced Plastic | Flexible Plastic | Ball Float Valve |
| 5339 | No | | Double-Walled | Double Walled | Yes |
| Currently in Use | | 10/11/2011 | Electronic Line Leak Detector | Pressurized | Non-corrodible |
| Gasoline | | 09/13/2010 | Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring | Continuous Interstitial Monitoring;ELLD 0.1;ELLD 0.2 | No |
| 10,000 | | 09/13/2010 | Gilbarco/TLS-350;Gilbarco- Veeder Root/TLS-350 | | Yes |
| 04 | 10 | 11/01/2011 | Fiberglass Reinforced Plastic | Flexible Plastic | Ball Float Valve |
| 5340 | No | | Double-Walled | Double Walled | Yes |
| Currently in Use | | 10/11/2011 | Electronic Line Leak Detector | Pressurized | Non-corrodible |
| Gasoline | | 09/13/2010 | Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring | Continuous Interstitial Monitoring;ELLD 0.1;ELLD 0.2 | No |
| 10,000 | | 09/13/2010 | Gilbarco/TLS-350;Gilbarco- Veeder Root/TLS-350 | | Yes |

Facility Summary in Cascade County in the City of Great Falls

Location: H and R #4
 5600 3rd Ave S
 Great Falls, MT 59405-1726 Cascade

Legacy ID:07-00090

Facility ID: 18330
Last Inspected On: 01/06/2020
Operating Permit Renewal Date: 03/14/2023

Owner Operator Contact: Robert Moss;Thriftway Marketing Corp - Former Gasamat of MT

5053265571

Operator Contact: Harinder Singh;Rajinder Singh

4067614791;4068682062

Owner/Operator: Singh Inc

Frank Kruse, UST Class B Global Operator
 Frank Kruse, UST Class B Operator
 Harinder Singh, UST Class A Operator
 Rajinder Singh, UST Class A Operator

| Tank Code | Age | Installed | Tank Material Construction | Piping Material | Overfill Types |
|------------------|-----|-----------------------|---|---|-------------------|
| Tag # | AST | Sump Tightness | Secondary Option | Secondary Option | Spill Protected |
| Status | | Piping Installed Date | Catastrophic L.D. Type 3.0 | Piping Type | CP Met Types |
| Product | | Tank/Pipe CP | Tank Detection | Primary Pipe Detection | Vapor Recovery |
| Capacity | | Line Tightness | ATG Type | Secondary Pipe Detection | Energy Act |
| 03 | 51 | 12/31/1970 | Cathodically Protected Steel | Flexible Plastic | Flapper Valve |
| 3838 | No | | Lined Interior/Impressed Current | Double Walled | Yes |
| Currently in Use | | | Electronic Line Leak Detector | Pressurized | Impressed Current |
| Gasoline | | 09/14/2016 | Automatic Tank Gauging 0.2 | Continuous Interstitial Monitoring;ELLD 0.2 | No |
| 10,000 | | | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | No |
| 01 | 51 | 12/31/1970 | Cathodically Protected Steel | Flexible Plastic | Flapper Valve |
| 4439 | No | | Lined Interior/Impressed Current | Double Walled | Yes |
| Currently in Use | | | Electronic Line Leak Detector | Pressurized | Impressed Current |
| Gasoline | | 09/14/2016 | Automatic Tank Gauging 0.2 | Continuous Interstitial Monitoring;ELLD 0.2 | No |
| 10,000 | | | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | No |

Facility Summary in Cascade County in the City of Great Falls

Location: H and R INC #5
 3601 10th Ave S
 Great Falls, MT 59405 Cascade

Legacy ID:07-03973

Facility ID: 18494
Last Inspected On: 12/08/2020
Operating Permit Renewal Date: 03/27/2024

Owner Operator Contact: Donald Wheeler

4064945557

Operator Contact: Harinder Singh;Rajinder Singh

4067614791;4068682062

Owner/Operator: Singh Inc

Frank Kruse, UST Class B Global Operator

Frank Kruse, UST Class B Operator

Harinder Singh, UST Class A Operator

Rajinder Singh, UST Class A Operator

| Tank Code | Age | Installed | Tank Material Construction | Piping Material | Overfill Types |
|------------------|-----|-----------------------|---|--------------------------|------------------|
| Tag # | AST | Sump Tightness | Secondary Option | Secondary Option | Spill Protected |
| Status | | Piping Installed Date | Catastrophic L.D. Type 3.0 | Piping Type | CP Met Types |
| Product | | Tank/Pipe CP | Tank Detection | Primary Pipe Detection | Vapor Recovery |
| Capacity | | Line Tightness | ATG Type | Secondary Pipe Detection | Energy Act |
| 06 | 30 | 06/01/1991 | Fiberglass Reinforced Plastic | Flexible Plastic | High Level Alarm |
| 1248 | No | | | None | Yes |
| Currently in Use | | | Electronic Line Leak Detector | Pressurized | Non-corrodible |
| Gasoline | | | Automatic Tank Gauging 0.2 | ELLD 0.1;ELLD 0.2 | No |
| 10,000 | | 07/08/2017 | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | No |
| 07 | 30 | 06/01/1991 | Fiberglass Reinforced Plastic | Flexible Plastic | High Level Alarm |
| 1249 | No | | | None | Yes |
| Currently in Use | | | Electronic Line Leak Detector | Pressurized | Non-corrodible |
| Diesel | | | Automatic Tank Gauging 0.2 | ELLD 0.1;ELLD 0.2 | No |
| 10,000 | | 09/28/2017 | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | No |
| 08 | 30 | 06/01/1991 | Fiberglass Reinforced Plastic | Flexible Plastic | High Level Alarm |
| 1250 | No | | | None | Yes |
| Currently in Use | | | Electronic Line Leak Detector | Pressurized | Non-corrodible |
| Gasoline | | | Automatic Tank Gauging 0.2 | ELLD 0.1;ELLD 0.2 | No |

10,000

07/16/2017

Gilbarco-Veeder Root/TLS-350/Gilbarco EMC

No

Facility Summary in Cascade County in the City of Great Falls

Location: HALL TRANSIT CO
2620 Upper River Rd
Great Falls, MT 59405-7231 Cascade

Legacy ID:07-06402

Facility ID: 18626
Last Inspected On: 10/30/2020
Operating Permit Renewal Date: 08/06/2023

Owner Operator Contact: Hall Transit Co

Operator Contact:

Owner/Operator: Darlene Cashman

Owner/Operator: Hall Transit Co

| Tank Code | Age | Installed | Tank Material Construction | Piping Material | Overfill Types |
|------------------------|-----|-----------------------|---|-------------------------------|------------------|
| Tag # | AST | Sump Tightness | Secondary Option | Secondary Option | Spill Protected |
| Status | | Piping Installed Date | Catastrophic L.D. Type 3.0 | Piping Type | CP Met Types |
| Product | | Tank/Pipe CP | Tank Detection | Primary Pipe Detection | Vapor Recovery |
| Capacity | | Line Tightness | ATG Type | Secondary Pipe Detection | Energy Act |
| 02 | 30 | 11/01/1991 | Fiberglass Reinforced Plastic | Fiberglass Reinforced Plastic | High Level Alarm |
| 1268 | No | | | None | Yes |
| Temporarily Out of Use | | | Mechanical Line Leak Detector | Pressurized | |
| Diesel | | 05/24/2017 | Automatic Tank Gauging 0.2 | MLLD Line Tightness Testing | No |
| 6,000 | | 05/24/2017 | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | No |

Facility Summary in Cascade County in the City of Great Falls

Location: HOLIDAY STATION STORE 59
601 Northwest Bypass
Great Falls, MT 59404-2480 Cascade

Legacy ID:07-13729

Facility ID: 19059
Last Inspected On: 09/22/2020
Operating Permit Renewal Date: 12/04/2023

Owner Operator Contact:

Operator Contact: Brent Johnson;Chuck Nyberg;Dean Townsend;Veronica Rivera

9528308722

Owner/Operator: Rocky Mountain Oil Co Inc

Brad Lee, UST Class B Operator
Brent Johnson, UST Class A Operator
Brent Johnson, UST Class B Global Operator

Christopher Magis, UST Class B Global Operator
 Chuck Nyberg, UST Class A Operator
 Dean Townsend, UST Class A Operator
 Garrett Lapp, UST Class B Global Operator
 Greg Brewer, UST Class B Global Operator
 Travis Struckman, UST Class B Global Operator
 Veronica Rivera, UST Class A Operator
 Veronica Rivera, UST Class B Global Operator

| Tank Code | Age | Installed | Tank Material Construction | Piping Material | Overfill Types |
|------------------|-----|-----------------------|---|--|--------------------------------|
| Tag # | AST | Sump Tightness | Secondary Option | Secondary Option | Spill Protected |
| Status | | Piping Installed Date | Catastrophic L.D. Type 3.0 | Piping Type | CP Met Types |
| Product | | Tank/Pipe CP | Tank Detection | Primary Pipe Detection | Vapor Recovery |
| Capacity | | Line Tightness | ATG Type | Secondary Pipe Detection | Energy Act |
| 01 | 25 | 07/17/1996 | Fiberglass Reinforced Plastic | Flexible Plastic | Flapper Valve;High Level Alarm |
| 3359 | No | | | Double Walled | Yes |
| Currently in Use | | | Electronic Line Leak Detector | Pressurized | Non-corrodible |
| Gasoline | | 11/06/2012 | Automatic Tank Gauging 0.2 | Continuous Interstitial Monitoring;ELLD 0.1;ELLD 0.2 | Yes |
| 12,000 | | 05/25/2017 | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | No |
| 02 | 25 | 07/17/1996 | Fiberglass Reinforced Plastic | Flexible Plastic | Flapper Valve;High Level Alarm |
| 3360 | No | | | Double Walled | Yes |
| Currently in Use | | | Electronic Line Leak Detector | Pressurized | Non-corrodible |
| Gasoline | | 11/06/2012 | Automatic Tank Gauging 0.2 | Continuous Interstitial Monitoring;ELLD 0.1;ELLD 0.2 | Yes |
| 8,000 | | 05/21/2017 | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | No |
| 03 | 25 | 07/17/1996 | Fiberglass Reinforced Plastic | Flexible Plastic | Flapper Valve;High Level Alarm |
| 3361 | No | | | Double Walled | Yes |
| Currently in Use | | | Electronic Line Leak Detector | Pressurized | Non-corrodible |
| Diesel | | 11/06/2012 | Automatic Tank Gauging 0.2 | Continuous Interstitial Monitoring;ELLD 0.1;ELLD 0.2 | No |

8,000

05/17/2017

Gilbarco-Veeder Root/TLS-350/Gilbarco EMC

No

Facility Summary in Cascade County in the City of Great Falls

Location: HOLIDAY STATIONSTORE 10
1601 Fox Farm Rd
Great Falls, MT 59404-3338 Cascade

Legacy ID:07-09914

Facility ID: 18792
Last Inspected On: 09/09/2020
Operating Permit Renewal Date: 12/04/2023

Owner Operator Contact: Bary Moore;Moore Oil Inc Thompson Falls

4068273498;4068274314

Operator Contact: Brent Johnson;Chuck Nyberg;Dean Townsend

9528308722

Owner/Operator: Rocky Mountain Oil Co Inc

- Brad Lee, UST Class B Global Operator
- Brent Johnson, UST Class A Operator
- Brent Johnson, UST Class B Global Operator
- Casey Jambretz, UST Class B Global Operator
- Chuck Nyberg, UST Class A Operator
- Dean Townsend, UST Class A Operator
- Greg Brewer, UST Class B Global Operator
- Travis Struckman, UST Class B Global Operator

| Tank Code | Age | Installed | Tank Material Construction | Piping Material | Overfill Types |
|------------------|-----|------------|---|-------------------|-----------------------------------|
| 06 | 23 | 06/16/1998 | Fiberglass Reinforced Plastic | Flexible Plastic | Ball Float Valve;High Level Alarm |
| 1697 | No | | | Double Walled | Yes |
| Currently in Use | | | Electronic Line Leak Detector | Pressurized | Non-corrodible |
| Gasoline | | | Automatic Tank Gauging 0.2 | ELLD 0.1;ELLD 0.2 | Yes |
| 15,000 | | 08/29/2017 | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | No |
| 07 | 23 | 06/16/1998 | Fiberglass Reinforced Plastic | Flexible Plastic | Ball Float Valve;High Level Alarm |
| 1698 | No | | | Double Walled | Yes |
| Currently in Use | | | Electronic Line Leak Detector | Pressurized | Non-corrodible |

| | | | | | |
|------------------|----|------------|---|--------------------------------------|-----------------------------------|
| Gasoline | | | Automatic Tank Gauging 0.2 | ELLD 0.1;ELLD 0.2 | Yes |
| 8,000 | | 08/09/2017 | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | No |
| 08 | 23 | 06/16/1998 | Fiberglass Reinforced Plastic | Flexible Plastic | Ball Float Valve;High Level Alarm |
| 1699 | No | | | Double Walled | Yes |
| Currently in Use | | | Electronic Line Leak Detector | Pressurized | Non-corrodible |
| Diesel | | | Automatic Tank Gauging 0.2 | ELLD 0.2;ELLD Line Tightness Testing | No |
| 6,000 | | 08/28/2017 | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | No |

Facility Summary in Cascade County in the City of Great Falls

Location: HOLIDAY STATIONSTORE 273
1020 15th St. N
Great Falls, MT 59401-1238 Cascade

Legacy ID:07-08069

Facility ID: 18687
Last Inspected On: 09/09/2020
Operating Permit Renewal Date: 12/04/2023

Owner Operator Contact: Camie Pederson;Rocky Mountain Oil LLC - Env Director;Rocky Mountain Oil LLC

9528308700;9528308899

Operator Contact: Chuck Nyberg;Dean Townsend

9528308722

Owner/Operator: Rocky Mountain Oil Co Inc

- Brad Lee, UST Class B Global Operator
- Candice Ferguson, UST Class B Global Operator
- Candice Ferguson, UST Class B Operator
- Christopher Magis, UST Class B Global Operator
- Chuck Nyberg, UST Class A Operator
- Dean Townsend, UST Class A Operator
- Greg Brewer, UST Class B Global Operator
- Travis Struckman, UST Class B Global Operator

| Tank Code | Age | Installed | Tank Material Construction | Piping Material | Overfill Types |
|-------------|-----|-----------------------|----------------------------|--------------------------|-----------------|
| Tag # | AST | Sump Tightness | Secondary Option | Secondary Option | Spill Protected |
| Status | | Piping Installed Date | Catastrophic L.D. Type 3.0 | Piping Type | CP Met Types |
| Product | | Tank/Pipe CP | Tank Detection | Primary Pipe Detection | Vapor Recovery |
| Capacity | | Line Tightness | ATG Type | Secondary Pipe Detection | Energy Act |
| 04 | 23 | 05/15/1998 | Steel Clad | Flexible Plastic | Flapper Valve |
| 2995 | No | | Double-Walled | Double Walled | Yes |

| | | | | | |
|------------------|----|------------|---|--|-------------------|
| Currently in Use | | | Electronic Line Leak Detector | Pressurized | Impressed Current |
| Gasoline | | 09/16/2009 | Automatic Tank Gauging 0.2 | Continuous Interstitial Monitoring; ELLD 0.1; ELLD 0.2 | No |
| 8,000 | | 04/06/2017 | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | No |
| 05 | 23 | 05/15/1998 | Steel Clad | Flexible Plastic | Flapper Valve |
| 2996 | No | | Double-Walled | Double Walled | Yes |
| Currently in Use | | | Electronic Line Leak Detector | Pressurized | Impressed Current |
| Gasoline | | 09/16/2009 | Automatic Tank Gauging 0.2 | Continuous Interstitial Monitoring; ELLD 0.1; ELLD 0.2 | No |
| 8,000 | | 08/21/2017 | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | No |
| 06 | 23 | 05/15/1998 | Steel Clad | Flexible Plastic | Flapper Valve |
| 2997 | No | | Double-Walled | Double Walled | Yes |
| Currently in Use | | | Electronic Line Leak Detector | Pressurized | Impressed Current |
| Gasoline | | 09/16/2009 | Automatic Tank Gauging 0.2 | Continuous Interstitial Monitoring; ELLD 0.1; ELLD 0.2 | No |
| 8,000 | | 08/21/2017 | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | No |

Facility Summary in Cascade County in the City of Great Falls

Location: HOLIDAY STATIONSTORE 724
2260 10th Ave S
Great Falls, MT 59405 Cascade

Legacy ID:56-13975

Facility ID: 30637
Last Inspected On: 06/25/2019
Operating Permit Renewal Date: 03/30/2022

Owner Operator Contact:

Operator Contact: Chuck Nyberg;Dean Townsend;Veronica Rivera **9528308722**

Owner/Operator: Rocky Mountain Oil Co Inc

- Brad Lee, UST Class B Global Operator
- Chuck Nyberg, UST Class A Operator
- Dean Townsend, UST Class A Operator
- Garrett Lapp, UST Class B Global Operator
- Greg Brewer, UST Class B Global Operator
- Travis Struckman, UST Class B Global Operator
- Veronica Rivera, UST Class A Operator
- Veronica Rivera, UST Class B Global Operator

| Tank Code | Age | Installed | Tank Material Construction | Piping Material | Overfill Types |
|------------------|-----|-----------------------|---|---|-----------------------------------|
| Tag # | AST | Sump Tightness | Secondary Option | Secondary Option | Spill Protected |
| Status | | Piping Installed Date | Catastrophic L.D. Type 3.0 | Piping Type | CP Met Types |
| Product | | Tank/Pipe CP | Tank Detection | Primary Pipe Detection | Vapor Recovery |
| Capacity | | Line Tightness | ATG Type | Secondary Pipe Detection | Energy Act |
| 01 | 21 | 10/01/2000 | Fiberglass Reinforced Plastic | Flexible Plastic | Ball Float Valve;High Level Alarm |
| 4219 | No | | Double-Walled | Double Walled | Yes |
| Currently in Use | | | Electronic Line Leak Detector | Pressurized | |
| Gasoline | | | Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring | Continuous Interstitial Monitoring;ELLD 0.2;ELLD Line Tightness Testing | No |
| 15,000 | | 07/20/2018 | Gilbarco-Veeder Root/TLS- 350/Gilbarco EMC | | No |
| 02 | 21 | 10/01/2000 | Fiberglass Reinforced Plastic | Flexible Plastic | Ball Float Valve;High Level Alarm |
| 4220 | No | | Double-Walled | Double Walled | Yes |
| Currently in Use | | | Electronic Line Leak Detector | Pressurized | |
| Gasoline | | | Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring | Continuous Interstitial Monitoring;ELLD 0.2;ELLD Line Tightness Testing | No |
| 10,000 | | 07/20/2018 | Gilbarco-Veeder Root/TLS- 350/Gilbarco EMC | | No |

Facility Summary in Cascade County in the City of Great Falls

Location: HOLIDAY STATIONSTORE 730
1428 3rd St NW
Great Falls, MT 59404-1928 Cascade

Legacy ID:56-13970

Facility ID: 30632
Last Inspected On: 06/25/2019
Operating Permit Renewal Date: 03/30/2022

Owner Operator Contact:

Operator Contact: Chuck Nyberg;Dean Townsend;Veronica Rivera

9528308722

Owner/Operator: Rocky Mountain Oil Co Inc

- Bailey Bushaw, UST Class B Global Operator
- Brad Lee, UST Class B Global Operator
- Chuck Nyberg, UST Class A Operator
- Dean Townsend, UST Class A Operator
- Garrett Lapp, UST Class B Global Operator
- Greg Brewer, UST Class B Global Operator

Travis Struckman, UST Class B Global Operator
 Veronica Rivera, UST Class A Operator
 Veronica Rivera, UST Class B Global Operator

| Tank Code | Age | Installed | Tank Material Construction | Piping Material | Overfill Types |
|------------------|-----|-----------------------|---|---|-----------------------------------|
| Tag # | AST | Sump Tightness | Secondary Option | Secondary Option | Spill Protected |
| Status | | Piping Installed Date | Catastrophic L.D. Type 3.0 | Piping Type | CP Met Types |
| Product | | Tank/Pipe CP | Tank Detection | Primary Pipe Detection | Vapor Recovery |
| Capacity | | Line Tightness | ATG Type | Secondary Pipe Detection | Energy Act |
| 01 | 21 | 07/07/2000 | Fiberglass Reinforced Plastic | Flexible Plastic | Ball Float Valve;High Level Alarm |
| 4203 | No | | Double-Walled | Double Walled | Yes |
| Currently in Use | | | Electronic Line Leak Detector | Pressurized | |
| Gasoline | | | Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring | Continuous Interstitial Monitoring;ELLD 0.1;ELLD 0.2 | No |
| 15,000 | | 10/29/2018 | Veeder Root/TLS-450 | | No |
| 02 | 21 | 07/07/2000 | Fiberglass Reinforced Plastic | Flexible Plastic | Ball Float Valve;High Level Alarm |
| 4204 | No | | Double-Walled | Double Walled | Yes |
| Currently in Use | | | Electronic Line Leak Detector | Pressurized | |
| Gasoline | | | Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring | Continuous Interstitial Monitoring;ELLD 0.1;ELLD 0.2 | No |
| 10,000 | | 06/14/2018 | Veeder Root/TLS-450 | | No |

Facility Summary in Cascade County in the City of Great Falls

Location: KEITHS COUNTRY STORE
 1621 10th Ave S
 Great Falls, MT 59405 Cascade

Legacy ID:07-01418

Facility ID: 18394
Last Inspected On: 09/29/2020
Operating Permit Renewal Date: 12/02/2023

Owner Operator Contact: David Keith

4068622578

Operator Contact: David Keith;Theresa Keith

4068622578

Owner/Operator: Keiths Country Store

Anna Dion, UST Class B Operator
 David Keith, UST Class A Operator
 David Keith, UST Class B Operator

| Tank Code | Age | Installed | Tank Material Construction | Piping Material | Overfill Types |
|------------------|-----|-----------------------|---|-------------------------------|--------------------------------|
| Tag # | AST | Sump Tightness | Secondary Option | Secondary Option | Spill Protected |
| Status | | Piping Installed Date | Catastrophic L.D. Type 3.0 | Piping Type | CP Met Types |
| Product | | Tank/Pipe CP | Tank Detection | Primary Pipe Detection | Vapor Recovery |
| Capacity | | Line Tightness | ATG Type | Secondary Pipe Detection | Energy Act |
| 03 | 22 | 04/01/1999 | Fiberglass Reinforced Plastic | Fiberglass Reinforced Plastic | Flapper Valve;High Level Alarm |
| 3988 | No | | | None | Yes |
| Currently in Use | | | Electronic Line Leak Detector | Pressurized | Non-corrodible |
| Diesel | | | Automatic Tank Gauging 0.2 | ELLD 0.1;ELLD 0.2 | No |
| 6,000 | | 04/19/2017 | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | No |
| 04 | 22 | 04/01/1999 | Fiberglass Reinforced Plastic | Fiberglass Reinforced Plastic | Flapper Valve;High Level Alarm |
| 3989 | No | | | None | Yes |
| Currently in Use | | | Electronic Line Leak Detector | Pressurized | Non-corrodible |
| Gasoline | | | Automatic Tank Gauging 0.2 | ELLD 0.1;ELLD 0.2 | No |
| 8,000 | | 05/15/2017 | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | No |
| 05 | 22 | 04/01/1999 | Fiberglass Reinforced Plastic | Fiberglass Reinforced Plastic | Flapper Valve;High Level Alarm |
| 3990 | No | | | None | Yes |
| Currently in Use | | | Electronic Line Leak Detector | Pressurized | Non-corrodible |
| Gasoline | | | Automatic Tank Gauging 0.2 | ELLD 0.1;ELLD 0.2 | No |
| 12,000 | | 04/19/2017 | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | No |

Facility Summary in Cascade County in the City of Great Falls

Location: KERNAGHANS SERVICE 8TH AVE N
1507 8th Ave N
Great Falls, MT 59401-1749 Cascade

Legacy ID:07-04508

Facility ID: 18524
Last Inspected On: 10/07/2019
Operating Permit Renewal Date: 10/26/2022

Owner Operator Contact: James Kernaghan

4064529505

Operator Contact: Jeff Rearden

Owner/Operator: James Kernaghan

Bob Burns, UST Class B Operator

Jeff Rearden, UST Class A Operator

Steve Monaco, UST Class B Operator

| Tank Code | Age | Installed | Tank Material Construction | Piping Material | Overfill Types |
|------------------|-----|------------|---|-------------------------------|------------------|
| 03 | 32 | 07/28/1989 | Steel Clad | Fiberglass Reinforced Plastic | High Level Alarm |
| 1473 | No | | | None | Yes |
| Currently in Use | | | Electronic Line Leak Detector | Pressurized | Non-corrodible |
| Gasoline | | | Automatic Tank Gauging 0.2 | ELLD 0.1;ELLD 0.2 | No |
| 7,500 | | | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | No |
| 04 | 32 | 07/28/1989 | Steel Clad | Fiberglass Reinforced Plastic | High Level Alarm |
| 1474 | No | | | None | Yes |
| Currently in Use | | | Electronic Line Leak Detector | Pressurized | Non-corrodible |
| Gasoline | | | Automatic Tank Gauging 0.2 | ELLD 0.1;ELLD 0.2 | No |
| 5,000 | | | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | No |
| 05 | 32 | 07/28/1989 | Steel Clad | Fiberglass Reinforced Plastic | High Level Alarm |
| 1475 | No | | | None | Yes |
| Currently in Use | | | Electronic Line Leak Detector | Pressurized | Non-corrodible |
| Gasoline | | | Automatic Tank Gauging 0.2 | ELLD 0.1;ELLD 0.2 | No |
| 7,500 | | | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | No |

| | | | | | |
|------------------|----|------------|---|-------------------------------|------------------|
| 06 | 32 | 07/28/1989 | Steel Clad | Fiberglass Reinforced Plastic | High Level Alarm |
| 1476 | No | | | None | Yes |
| Currently in Use | | | Electronic Line Leak Detector | Pressurized | Non-corrodible |
| Gasoline | | | Automatic Tank Gauging 0.2 | ELLD 0.1;ELLD 0.2 | No |
| 8,000 | | | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | No |
| 07 | 32 | 07/28/1989 | Steel Clad | Fiberglass Reinforced Plastic | High Level Alarm |
| 1477 | No | | | None | Yes |
| Currently in Use | | | Electronic Line Leak Detector | Pressurized | Non-corrodible |
| Diesel | | | Automatic Tank Gauging 0.1 | ELLD 0.1;ELLD 0.2 | No |
| 4,000 | | | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | No |
| 08 | 32 | 07/28/1989 | Steel Clad | Fiberglass Reinforced Plastic | High Level Alarm |
| 1478 | No | | | None | Yes |
| Currently in Use | | | Electronic Line Leak Detector | Pressurized | Non-corrodible |
| Diesel | | | Automatic Tank Gauging 0.1 | ELLD 0.1;ELLD 0.2 | No |
| 8,000 | | | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | No |
| 09 | 39 | 07/29/1982 | Fiberglass Reinforced Plastic | Fiberglass Reinforced Plastic | High Level Alarm |
| 1479 | No | | | None | Yes |
| Currently in Use | | | Electronic Line Leak Detector | Pressurized | Non-corrodible |
| Diesel | | | Automatic Tank Gauging 0.1 | ELLD 0.1;ELLD 0.2 | No |
| 2,500 | | | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | No |

Facility Summary in Cascade County in the City of Great Falls

Location: KERNAGHANS SERVICE 9TH AVE N
1504 9th Ave N
Great Falls, MT 59401-1301 Cascade

Legacy ID:07-04509

Facility ID: 18525
Last Inspected On: 08/10/2020
Operating Permit Renewal Date: 09/03/2023

Owner Operator Contact: James Kernaghan

4064529505

Operator Contact: Jeff Rearden

Owner/Operator: James Kernaghan

Bob Burns, UST Class B Operator

Dennis Albrecht, UST Class B Operator

Jeff Rearden, UST Class A Operator

Steve Monaco, UST Class B Operator

| Tank Code | Age | Installed | Tank Material Construction | Piping Material | Overfill Types |
|------------------|-----|-----------------------|---|--------------------------|------------------|
| Tag # | AST | Sump Tightness | Secondary Option | Secondary Option | Spill Protected |
| Status | | Piping Installed Date | Catastrophic L.D. Type 3.0 | Piping Type | CP Met Types |
| Product | | Tank/Pipe CP | Tank Detection | Primary Pipe Detection | Vapor Recovery |
| Capacity | | Line Tightness | ATG Type | Secondary Pipe Detection | Energy Act |
| 05 | 23 | 05/23/1998 | Cathodically Protected Steel | Flexible Plastic | High Level Alarm |
| 1480 | No | | | Double Walled | Yes |
| Currently in Use | | | Electronic Line Leak Detector | Pressurized | Galvanic |
| Gasoline | | 09/03/2014 | Automatic Tank Gauging 0.2 | ELLD 0.1;ELLD 0.2 | No |
| 2,000 | | | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | No |
| 06 | 23 | 05/23/1998 | Cathodically Protected Steel | Flexible Plastic | High Level Alarm |
| 1481 | No | | | Double Walled | Yes |
| Currently in Use | | | Electronic Line Leak Detector | Pressurized | Galvanic |
| Gasoline | | 09/03/2014 | Automatic Tank Gauging 0.2 | ELLD 0.1;ELLD 0.2 | No |
| 1,000 | | | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | No |
| 07 | 23 | 05/23/1998 | Cathodically Protected Steel | Flexible Plastic | High Level Alarm |
| 1482 | No | | | Double Walled | Yes |
| Currently in Use | | | Electronic Line Leak Detector | Pressurized | Galvanic |
| Diesel | | 09/03/2014 | Automatic Tank Gauging 0.2 | ELLD 0.1;ELLD 0.2 | No |
| 2,000 | | | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | No |

| | | | | | |
|------------------|----|------------|---|-------------------|------------------|
| 08 | 23 | 05/23/1998 | Cathodically Protected Steel | Flexible Plastic | High Level Alarm |
| 1483 | No | | | Double Walled | Yes |
| Currently in Use | | | Electronic Line Leak Detector | Pressurized | Galvanic |
| Diesel | | 09/03/2014 | Automatic Tank Gauging 0.2 | ELLD 0.1;ELLD 0.2 | No |
| 3,500 | | | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | No |
| 09 | 23 | 05/23/1998 | Cathodically Protected Steel | Flexible Plastic | High Level Alarm |
| 1484 | No | | | Double Walled | Yes |
| Currently in Use | | | Electronic Line Leak Detector | Pressurized | Galvanic |
| Diesel | | 09/03/2014 | Automatic Tank Gauging 0.2 | ELLD 0.1;ELLD 0.2 | No |
| 1,500 | | | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | No |

Facility Summary in Cascade County in the City of Great Falls

Location: LITHIA BUICK GMC
26 9th St S
Great Falls, MT 59401-3757 Cascade

Legacy ID:07-10262

Facility ID: 18808
Last Inspected On: 03/31/2020
Operating Permit Renewal Date:

Owner Operator Contact: Lithia Real Estate Inc Great Falls

Operator Contact: Mark McCarthy

Owner/Operator: Lithia Real Estate Inc Great Falls

Dan Noland, UST Class B Operator
Mark McCarthy, UST Class A Operator
Mark McCarthy, UST Class B Global Operator

| Tank Code | Age | Installed | Tank Material Construction | Piping Material | Overfill Types |
|-----------|-----|-----------------------|----------------------------|--------------------------|-----------------|
| Tag # | AST | Sump Tightness | Secondary Option | Secondary Option | Spill Protected |
| Status | | Piping Installed Date | Catastrophic L.D. Type 3.0 | Piping Type | CP Met Types |
| Product | | Tank/Pipe CP | Tank Detection | Primary Pipe Detection | Vapor Recovery |
| Capacity | | Line Tightness | ATG Type | Secondary Pipe Detection | Energy Act |

| | | | | | |
|------------|----|------------|-------------------------------|-------------------------------|---------------|
| 01 | 45 | 01/27/1976 | Fiberglass Reinforced Plastic | Fiberglass Reinforced Plastic | Flapper Valve |
| 430 | No | | | None | Yes |

| | | | |
|------------------------|--------------------------------------|--------------|----------------|
| Temporarily Out of Use | Not Required | Safe Suction | Non-corrodible |
| Gasoline | Statistical Inventory Reconciliation | Deferred | No |
| 1,998 | | | No |

Facility Summary in Cascade County in the City of Great Falls

Location: LOAF 'N JUG #765
3726 2nd Ave N
Great Falls, MT 59401-3010 Cascade

Legacy ID:07-03920

Facility ID: 18493
Last Inspected On: 06/25/2019
Operating Permit Renewal Date: 08/13/2022

Owner Operator Contact: Elena Lau;Mini Mart Inc dba Loaf N Jug - Remittance;Mini Mart Inc dba Loaf 'N Jug Pueblo

5139641568

Operator Contact: Nicole Younger-Taylor;Theodore Bezel;Mini Mart Inc dba Loaf 'N Jug Pueblo

3078717831;5139641568

Owner/Operator: Mini Mart Inc dba Loaf 'N Jug Pueblo

- Nicole Younger-Taylor, UST Class A Operator
- Theodore Bezel, UST Class A Operator
- Theodore Bezel, UST Class B Global Operator
- Theodore Bezel, UST Class B Operator
- Timothy Osterman, UST Class B Global Operator
- Timothy Osterman, UST Class B Operator

| Tank Code | Age | Installed | Tank Material Construction | Piping Material | Overfill Types |
|------------------|-----|-----------------------|---|--------------------------|-------------------|
| Tag # | AST | Sump Tightness | Secondary Option | Secondary Option | Spill Protected |
| Status | | Piping Installed Date | Catastrophic L.D. Type 3.0 | Piping Type | CP Met Types |
| Product | | Tank/Pipe CP | Tank Detection | Primary Pipe Detection | Vapor Recovery |
| Capacity | | Line Tightness | ATG Type | Secondary Pipe Detection | Energy Act |
| 01 | 37 | 03/24/1984 | Cathodically Protected Steel | Flexible Plastic | Flapper Valve |
| 1624 | No | | Lined Interior/Impressed Current | Double Walled | Yes |
| Currently in Use | | | Electronic Line Leak Detector | Pressurized | Impressed Current |
| Gasoline | | 05/18/2016 | Automatic Tank Gauging 0.2 | ELLD 0.2 | No |
| 12,000 | | | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | No |
| 02 | 37 | 03/24/1984 | Cathodically Protected Steel | Flexible Plastic | Flapper Valve |
| 1625 | No | | Lined Interior/Impressed Current | Double Walled | Yes |

| | | | | | |
|------------------|------------|------------|---|------------------|-------------------|
| Currently in Use | | | Electronic Line Leak Detector | Pressurized | Impressed Current |
| Gasoline | 05/18/2016 | | Automatic Tank Gauging 0.2 | ELLD 0.2 | No |
| 12,000 | | | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | No |
| 03 | 37 | 03/24/1984 | Cathodically Protected Steel | Flexible Plastic | Flapper Valve |
| 1626 | No | | Lined Interior/Impressed Current | Double Walled | Yes |
| Currently in Use | | | Electronic Line Leak Detector | Pressurized | Impressed Current |
| Gasoline | 05/18/2016 | | Automatic Tank Gauging 0.2 | ELLD 0.2 | No |
| 12,000 | | | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | No |

Facility Summary in Cascade County in the City of Great Falls

Location: LOAF 'N JUG #766
900 1st Ave N
Great Falls, MT 59401 Cascade

Legacy ID:07-05775

Facility ID: 18584
Last Inspected On: 06/25/2019
Operating Permit Renewal Date: 08/13/2022

Owner Operator Contact: Elena Lau;Mini Mart Inc dba Loaf N Jug - Remittance;Elena Lau;Mini Mart Inc dba Loaf N Jug Hutchinson;Mini Mart Inc dba Loaf 'N Jug Pueblo

5139641568

Operator Contact: John Sumowski;Nicole Younger-Taylor;Randal Liebnow;Theodore Bezel;Mini Mart Inc dba Loaf 'N Jug Pueblo

3078717831;5139641568

Owner/Operator: Mini Mart Inc dba Loaf 'N Jug Pueblo

- John Sumowski, UST Class A Operator
- Nicole Younger-Taylor, UST Class A Operator
- Randal Liebnow, UST Class A Operator
- Scott Huether, UST Class B Global Operator
- Stevie Ulstad, UST Class B Global Operator
- Stevie Ulstad, UST Class B Operator
- Theodore Bezel, UST Class A Operator
- Theodore Bezel, UST Class B Global Operator
- Theodore Bezel, UST Class B Operator
- Timothy Osterman, UST Class B Global Operator

| Tank Code | Age | Installed | Tank Material Construction | Piping Material | Overfill Types |
|-----------|-----|-----------------------|----------------------------|------------------------|-----------------|
| Tag # | AST | Sump Tightness | Secondary Option | Secondary Option | Spill Protected |
| Status | | Piping Installed Date | Catastrophic L.D. Type 3.0 | Piping Type | CP Met Types |
| Product | | Tank/Pipe CP | Tank Detection | Primary Pipe Detection | Vapor Recovery |

| Capacity | Line Tightness | ATG Type | Secondary Pipe Detection | Energy Act | |
|------------------|----------------|------------|---|------------------|---------------|
| 01 | 38 | 04/27/1983 | Cathodically Protected Steel | Flexible Plastic | Flapper Valve |
| 1627 | No | | | Double Walled | Yes |
| Currently in Use | | | Electronic Line Leak Detector | Pressurized | Galvanic |
| Diesel | | 05/18/2016 | Automatic Tank Gauging 0.2 | ELLD 0.2 | No |
| 8,000 | | | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | No |
| 02 | 38 | 04/27/1983 | Cathodically Protected Steel | Flexible Plastic | Flapper Valve |
| 1628 | No | | | Double Walled | Yes |
| Currently in Use | | | Electronic Line Leak Detector | Pressurized | Galvanic |
| Gasoline | | 05/18/2016 | Automatic Tank Gauging 0.2 | ELLD 0.2 | No |
| 8,000 | | | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | No |
| 03 | 38 | 04/27/1983 | Cathodically Protected Steel | Flexible Plastic | Flapper Valve |
| 1629 | No | | | Double Walled | Yes |
| Currently in Use | | | Electronic Line Leak Detector | Pressurized | Galvanic |
| Gasoline | | 05/18/2016 | Automatic Tank Gauging 0.2 | ELLD 0.2 | No |
| 8,000 | | | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | No |

Facility Summary in Cascade County in the City of Great Falls

Location: LOAF 'N JUG #767
601 Smelter Ave NW
Great Falls, MT 59404 Cascade

Legacy ID:07-05776

Facility ID: 18585
Last Inspected On: 06/25/2019
Operating Permit Renewal Date: 08/06/2022

Owner Operator Contact: Mini Mart Inc dba Loaf 'N Jug Pueblo

5139641568

Operator Contact: Nicole Younger-Taylor;Randal Liebnow;Theodore Bezel;Mini Mart Inc dba Loaf 'N Jug Pueblo

3078717831;5139641568

Owner/Operator: Mini Mart Inc dba Loaf 'N Jug Pueblo

Hiede Richardson, UST Class B Global Operator
Jennifer Coleman, UST Class B Global Operator
Nicole Younger-Taylor, UST Class A Operator
Randal Liebnow, UST Class A Operator

Randal Liebnow, UST Class B Global Operator
 Scott Huether, UST Class B Global Operator
 Stevie Ulstad, UST Class B Operator
 Theodore Bezel, UST Class A Operator
 Theodore Bezel, UST Class B Global Operator
 Theodore Bezel, UST Class B Operator
 Timothy Osterman, UST Class B Global Operator
 Timothy Osterman, UST Class B Operator
 Toni Mullen, UST Class B Global Operator

| Tank Code | Age | Installed | Tank Material Construction | Piping Material | Overfill Types |
|------------------|-----|-----------------------|---|--|-----------------|
| Tag # | AST | Sump Tightness | Secondary Option | Secondary Option | Spill Protected |
| Status | | Piping Installed Date | Catastrophic L.D. Type 3.0 | Piping Type | CP Met Types |
| Product | | Tank/Pipe CP | Tank Detection | Primary Pipe Detection | Vapor Recovery |
| Capacity | | Line Tightness | ATG Type | Secondary Pipe Detection | Energy Act |
| 01 | 38 | 04/27/1983 | Cathodically Protected Steel | Fiberglass Reinforced Plastic | Flapper Valve |
| 3638 | No | | | None | Yes |
| Currently in Use | | | Electronic Line Leak Detector | Pressurized | Galvanic |
| Diesel | | 05/18/2016 | Automatic Tank Gauging 0.2 | Continuous Interstitial Monitoring; ELLD 0.2 | No |
| 10,000 | | | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | Yes |
| 02 | 38 | 04/27/1983 | Cathodically Protected Steel | Fiberglass Reinforced Plastic | Flapper Valve |
| 3639 | No | | | None | Yes |
| Currently in Use | | | Electronic Line Leak Detector | Pressurized | Galvanic |
| Gasoline | | 05/18/2016 | Automatic Tank Gauging 0.2 | Continuous Interstitial Monitoring; ELLD 0.2 | No |
| 10,000 | | | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | Yes |
| 03 | 38 | 04/27/1983 | Cathodically Protected Steel | Fiberglass Reinforced Plastic | Flapper Valve |
| 3640 | No | | | None | Yes |
| Currently in Use | | | Electronic Line Leak Detector | Pressurized | Galvanic |

| | | | | |
|----------|------------|---|---|-----|
| Gasoline | 05/18/2016 | Automatic Tank Gauging 0.2 | Continuous Interstitial Monitoring;ELLD 0.2 | No |
| 10,000 | | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | Yes |

Facility Summary in Cascade County in the City of Great Falls

Location: LOAF 'N JUG #768
1225 Central Ave W
Great Falls, MT 59404-3968 Cascade

Legacy ID:07-05777

Facility ID: 18586
Last Inspected On: 07/11/2019
Operating Permit Renewal Date: 08/06/2022

Owner Operator Contact: Elena Lau;Mini Mart Inc dba Loaf N Jug - Remittance;Elena Lau;Mini Mart Inc dba Loaf N Jug Hutchinson;Mini Mart Inc dba Loaf 'N Jug Pueblo

5139641568

Operator Contact: Chelsey Partridge;Holly Seymour;John Sumowski;Randal Liebnow;Theodore Bezel;Mini Mart Inc dba Loaf 'N Jug Pueblo

2677998664;4067508563;5139641568

Owner/Operator: Mini Mart Inc dba Loaf 'N Jug Pueblo

- Chelsey Partridge, UST Class A Operator
- Chelsey Partridge, UST Class B Operator
- Hiede Richardson, UST Class B Global Operator
- Holly Seymour, UST Class A Operator
- Holly Seymour, UST Class B Global Operator
- John Sumowski, UST Class A Operator
- Randal Liebnow, UST Class A Operator
- Randal Liebnow, UST Class B Global Operator
- Scott Huether, UST Class B Global Operator
- Stevie Ulstad, UST Class B Operator
- Theodore Bezel, UST Class A Operator
- Theodore Bezel, UST Class B Global Operator
- Theodore Bezel, UST Class B Operator
- Timothy Osterman, UST Class B Global Operator
- Timothy Osterman, UST Class B Operator
- Toni Mullen, UST Class B Global Operator

| Tank Code | Age | Installed | Tank Material Construction | Piping Material | Overfill Types |
|-----------|-----|-----------------------|----------------------------|--------------------------|-----------------|
| Tag # | AST | Sump Tightness | Secondary Option | Secondary Option | Spill Protected |
| Status | | Piping Installed Date | Catastrophic L.D. Type 3.0 | Piping Type | CP Met Types |
| Product | | Tank/Pipe CP | Tank Detection | Primary Pipe Detection | Vapor Recovery |
| Capacity | | Line Tightness | ATG Type | Secondary Pipe Detection | Energy Act |

| | | | | | |
|----|----|------------|------------------------------|------------------|---------------|
| 01 | 49 | 04/26/1972 | Cathodically Protected Steel | Flexible Plastic | Flapper Valve |
|----|----|------------|------------------------------|------------------|---------------|

| | | | | | |
|------------------|----|------------|---|--|-------------------|
| 1630 | No | 08/29/2016 | Lined Interior/Impressed Current | Double Walled | Yes |
| Currently in Use | | 10/19/2016 | Electronic Line Leak Detector | Pressurized | Impressed Current |
| Diesel | | 05/18/2016 | Automatic Tank Gauging 0.2 | Continuous Interstitial Monitoring; ELLD 0.2 | No |
| 8,000 | | 01/07/2011 | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | No |
| 02 | 49 | 04/26/1972 | Cathodically Protected Steel | Flexible Plastic | Flapper Valve |
| 1631 | No | 08/29/2016 | Lined Interior/Impressed Current | Double Walled | Yes |
| Currently in Use | | 10/19/2016 | Electronic Line Leak Detector | Pressurized | Impressed Current |
| Gasoline | | 05/18/2016 | Automatic Tank Gauging 0.2 | Continuous Interstitial Monitoring; ELLD 0.2 | No |
| 8,000 | | 01/07/2011 | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | No |
| 03 | 49 | 04/26/1972 | Cathodically Protected Steel | Flexible Plastic | Flapper Valve |
| 1632 | No | 08/29/2016 | Lined Interior/Impressed Current | Double Walled | Yes |
| Currently in Use | | 10/19/2016 | Electronic Line Leak Detector | Pressurized | Impressed Current |
| Gasoline | | 05/18/2016 | Automatic Tank Gauging 0.2 | Continuous Interstitial Monitoring; ELLD 0.2 | No |
| 8,000 | | 01/07/2011 | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | No |

Facility Summary in Cascade County in the City of Great Falls

Location: MCLAUGHLIN RESEARCH INSTITUTE
1520 23rd St S
Great Falls, MT 59405-4900 Cascade

Legacy ID:07-12790

Facility ID: 19013
Last Inspected On: 02/22/2019
Operating Permit Renewal Date: 07/16/2022

Owner Operator Contact: Joe Amato **4067994595**

Operator Contact: Joe Amato **4067994595**

Owner/Operator: Joe Amato

Joe Amato, UST Class A Operator
Joe Amato, UST Class B Global Operator

| Tank Code | Age | Installed | Tank Material Construction | Piping Material | Overfill Types |
|------------------|-----|-----------------------|-------------------------------|---|-----------------|
| Tag # | AST | Sump Tightness | Secondary Option | Secondary Option | Spill Protected |
| Status | | Piping Installed Date | Catastrophic L.D. Type 3.0 | Piping Type | CP Met Types |
| Product | | Tank/Pipe CP | Tank Detection | Primary Pipe Detection | Vapor Recovery |
| Capacity | | Line Tightness | ATG Type | Secondary Pipe Detection | Energy Act |
| 01 | 28 | 05/23/1993 | Fiberglass Reinforced Plastic | Fiberglass Reinforced Plastic | Flapper Valve |
| 2977 | No | | Double-Walled | Double Walled | Yes |
| Currently in Use | | | Auto Dialer | U.S. Suction | |
| Diesel | | | Automatic Tank Gauging 0.2 | 3-Year Line Tightness Test;Continuous Interstitial Monitoring | No |
| 1,000 | | 02/16/2016 | Gilbarco/EMC Basic | | No |

Facility Summary in Cascade County in the City of Great Falls

Location: MDOT GREAT FALLS
200 Smelter Ave NE
Great Falls, MT 59404-1900 Cascade

Legacy ID:07-04047

Facility ID: 18498
Last Inspected On: 12/09/2020
Operating Permit Renewal Date: 03/25/2024

Owner Operator Contact: Doug Compton;Montana Dept of Transportation **4064447647**

Operator Contact: Crystal Ford;Donald Ford;Jeff Gleason;Joe Radonich;Mike Murolo;Walt Kerttula **5095315827;5095316018**

Owner/Operator: MDOT Helena

Brian Boettcher, UST Class B Operator
Crystal Ford, UST Class A Operator
Crystal Ford, UST Class B Global Operator
Donald Ford, UST Class A Operator
Donald Ford, UST Class B Global Operator

Jeff Gleason, UST Class A Operator
 Joe Radonich, UST Class A Operator
 Joe Radonich, UST Class B Global Operator
 Kelly Holbrook, UST Class B Global Operator
 Lucas Cowan, UST Class B Global Operator
 Lucas Cowan, UST Class B Operator
 Mike Murolo, UST Class A Operator
 Steven Rupnow, UST Class B Operator
 Victor Scott, UST Class B Operator
 Walt Kerttula, UST Class A Operator

| Tank Code | Age | Installed | Tank Material Construction | Piping Material | Overfill Types |
|------------------|-----|-----------------------|------------------------------|-------------------------------|-----------------|
| Tag # | AST | Sump Tightness | Secondary Option | Secondary Option | Spill Protected |
| Status | | Piping Installed Date | Catastrophic L.D. Type 3.0 | Piping Type | CP Met Types |
| Product | | Tank/Pipe CP | Tank Detection | Primary Pipe Detection | Vapor Recovery |
| Capacity | | Line Tightness | ATG Type | Secondary Pipe Detection | Energy Act |
| 05 | 31 | 11/01/1990 | Cathodically Protected Steel | Fiberglass Reinforced Plastic | Flapper Valve |
| 3704 | No | | | None | Yes |
| Currently in Use | | | Not Required | Safe Suction | Galvanic |
| Diesel | | 10/23/2017 | Automatic Tank Gauging 0.2 | Deferred | No |
| 12,000 | | | Gilbarco/EMC Basic | | No |
| 06 | 29 | 04/01/1992 | Cathodically Protected Steel | Fiberglass Reinforced Plastic | Flapper Valve |
| 3705 | No | | | None | Yes |
| Currently in Use | | | Not Required | Safe Suction | Galvanic |
| Gasoline | | 10/23/2017 | Automatic Tank Gauging 0.2 | Deferred | No |
| 12,000 | | | Gilbarco/EMC Basic | | No |

Facility Summary in Cascade County in the City of Great Falls

Location: MEADOWLARK COUNTRY CLUB
 300 Country Club Blvd
 Great Falls, MT 59404-3355 Cascade

Legacy ID:07-11234

Facility ID: 18876
Last Inspected On: 10/31/2018
Operating Permit Renewal Date: 03/01/2022

Owner Operator Contact: Meadowlark Country Club

4064536531

Operator Contact: Tim Furan

4068996846

Owner/Operator: Meadowlark Country Club

Tim Furan, UST Class A Operator

Tim Furan, UST Class B Operator

| Tank Code | Age | Installed | Tank Material Construction | Piping Material | Overfill Types |
|------------------|-----|-----------------------|------------------------------|-------------------------------|-----------------|
| Tag # | AST | Sump Tightness | Secondary Option | Secondary Option | Spill Protected |
| Status | | Piping Installed Date | Catastrophic L.D. Type 3.0 | Piping Type | CP Met Types |
| Product | | Tank/Pipe CP | Tank Detection | Primary Pipe Detection | Vapor Recovery |
| Capacity | | Line Tightness | ATG Type | Secondary Pipe Detection | Energy Act |
| 02 | 30 | 05/23/1991 | Cathodically Protected Steel | Fiberglass Reinforced Plastic | Flapper Valve |
| 2317 | No | | | None | Yes |
| Currently in Use | | | Not Required | Safe Suction | Galvanic |
| Gasoline | | 10/31/2018 | Automatic Tank Gauging 0.2 | Deferred | No |
| 1,000 | | | OPW/EECO 1500 | | No |
| 03 | 30 | 05/23/1991 | Cathodically Protected Steel | Fiberglass Reinforced Plastic | Flapper Valve |
| 2318 | No | | | None | Yes |
| Currently in Use | | | Not Required | Safe Suction | Galvanic |
| Diesel | | 10/31/2018 | Automatic Tank Gauging 0.2 | Deferred | No |
| 1,000 | | | OPW/EECO 1500 | | No |

Facility Summary in Cascade County in the City of Great Falls

Location: MONTANA AIR NATIONAL GUARD UST
2800 Airport Ave B
Great Falls, MT 59404-5570 Cascade

Legacy ID:07-02294

Facility ID: 18433
Last Inspected On: 01/02/2020
Operating Permit Renewal Date: 03/11/2020

Owner Operator Contact: Montana Air National Guard

4067910316

Operator Contact: Briana Boggio;Cassie Clark;Clint Tyler;Dale Vig;Danny Collins;James Robertson;Joe Kerkes;Joseph Leggett;Mark Payton;Robin Atkison;Scott Kohles;Ted Clark

4062310600;4062573727;4063211887;4067710962;4067910305;4067949066;4068660384

Owner/Operator: Montana Air National Guard

Briana Boggio, UST Class A Operator

Briana Boggio, UST Class B Operator
 Cassie Clark, UST Class A Operator
 Cassie Clark, UST Class B Global Operator
 Clint Tyler, UST Class A Operator
 Dale Vig, UST Class A Operator
 Danny Collins, UST Class A Operator
 James Robertson, UST Class A Operator
 Joe Kerkes, UST Class A Operator
 Joseph Leggett, UST Class A Operator
 Mark Payton, UST Class A Operator
 Robin Atkison, UST Class A Operator
 Scott Kohles, UST Class A Operator
 Ted Clark, UST Class A Operator

| Tank Code | Age | Installed | Tank Material Construction | Piping Material | Overfill Types |
|-------------------------------|-----|-----------------------|---|--------------------------|-------------------|
| Tag # | AST | Sump Tightness | Secondary Option | Secondary Option | Spill Protected |
| Status | | Piping Installed Date | Catastrophic L.D. Type 3.0 | Piping Type | CP Met Types |
| Product | | Tank/Pipe CP | Tank Detection | Primary Pipe Detection | Vapor Recovery |
| Capacity | | Line Tightness | ATG Type | Secondary Pipe Detection | Energy Act |
| S25 | 27 | 10/01/1994 | Fiberglass Reinforced Plastic | No Piping | |
| | No | | Double-Walled | None | Yes |
| Currently in Use | | | | Not Listed | |
| Oil/Water Separator | | 09/19/2007 | Continuous Interstitial Monitoring;Deferred | | No |
| 500 | | | | | No |
| 3A | 66 | 01/01/1955 | Bare Steel | No Piping | High Level Alarm |
| 1662 | No | | Lined Interior/Impressed Current | None | Yes |
| Currently in Use | | | Not Required | Gravity Feed | Impressed Current |
| Jet Fuel (Jet-A, Jet-A1, JP5) | | 07/11/2016 | Automatic Tank Gauging 0.2 | Deferred | No |
| 25,000 | | | Gilbarco-Veeder Root/TLS-350 | | No |
| 3B | 66 | 01/01/1955 | Bare Steel | No Piping | High Level Alarm |

| | | | | | |
|-------------------------------|----|------------|----------------------------------|--------------|-------------------|
| 1663 | No | | Lined Interior/Impressed Current | None | Yes |
| Currently in Use | | | Not Required | Gravity Feed | Impressed Current |
| Jet Fuel (Jet-A, Jet-A1, JP5) | | 07/11/2016 | Automatic Tank Gauging 0.2 | Deferred | No |
| 25,000 | | | Gilbarco-Veeder Root/TLS-350 | | No |
| 3C | 66 | 01/01/1955 | Bare Steel | No Piping | High Level Alarm |
| 1664 | No | | Lined Interior/Impressed Current | None | Yes |
| Currently in Use | | | Not Required | Gravity Feed | Impressed Current |
| Jet Fuel (Jet-A, Jet-A1, JP5) | | 07/11/2016 | Automatic Tank Gauging 0.2 | Deferred | No |
| 25,000 | | | Gilbarco-Veeder Root/TLS-350 | | No |
| 3D | 66 | 01/01/1955 | Bare Steel | No Piping | High Level Alarm |
| 1665 | No | | Lined Interior/Impressed Current | None | Yes |
| Currently in Use | | | Not Required | Gravity Feed | Impressed Current |
| Jet Fuel (Jet-A, Jet-A1, JP5) | | 07/11/2016 | Automatic Tank Gauging 0.2 | Deferred | No |
| 25,000 | | | Gilbarco-Veeder Root/TLS-350 | | No |
| 3F | 66 | 01/01/1955 | Bare Steel | No Piping | High Level Alarm |
| 1667 | No | | Lined Interior/Impressed Current | None | Yes |
| Currently in Use | | | Not Required | Gravity Feed | Impressed Current |
| Jet Fuel (Jet-A, Jet-A1, JP5) | | 07/11/2016 | Automatic Tank Gauging 0.2 | Deferred | No |
| 25,000 | | | Gilbarco-Veeder Root/TLS-350 | | No |
| 3E | 66 | 01/01/1955 | Bare Steel | No Piping | High Level Alarm |
| 4783 | No | | Lined Interior/Impressed Current | None | Yes |
| Currently in Use | | | Not Required | Gravity Feed | Impressed Current |
| Jet Fuel (Jet-A, Jet-A1, JP5) | | 07/11/2016 | Automatic Tank Gauging 0.2 | Deferred | No |

25,000

Gilbarco-Veeder Root/TLS-350

No

Facility Summary in Cascade County in the City of Great Falls

Location: PHILLIPS 66 GREAT FALLS TERMINAL
1401 52nd St N
Great Falls, MT 59405-1073 Cascade

Legacy ID:07-01845

Facility ID: 18413
Last Inspected On: 03/07/2019
Operating Permit Renewal Date: 06/09/2022

Owner Operator Contact: Phillips 66 Co Billings

Operator Contact: Brian Buckley

Owner/Operator: Phillips 66 Great Falls Terminal

Brian Buckley, UST Class A Operator
Brian Buckley, UST Class B Operator
Scott Parker, UST Class B Operator

| Tank Code | Age | Installed | Tank Material Construction | Piping Material | Overfill Types |
|------------------|-----|-----------------------|----------------------------|----------------------------------|-----------------|
| Tag # | AST | Sump Tightness | Secondary Option | Secondary Option | Spill Protected |
| Status | | Piping Installed Date | Catastrophic L.D. Type 3.0 | Piping Type | CP Met Types |
| Product | | Tank/Pipe CP | Tank Detection | Primary Pipe Detection | Vapor Recovery |
| Capacity | | Line Tightness | ATG Type | Secondary Pipe Detection | Energy Act |
| S5 | 61 | 01/01/1960 | Unknown | Steel - Terminal Piping | |
| 704 | Yes | | | None | Yes |
| Currently in Use | | | Not Required | Pressurized | |
| Gasoline | | 05/13/2015 | Deferred | Terminal Piping Annual Line Test | No |
| 2,520,000 | | 12/04/2015 | | | No |
| S9 | 61 | 01/01/1960 | Unknown | Steel | |
| 707 | Yes | | | None | Yes |
| Currently in Use | | | Not Required | Pressurized | |
| Diesel | | 05/13/2015 | Deferred | Terminal Piping Annual Line Test | No |
| 1,512,000 | | 12/04/2015 | | | No |
| S11 | 61 | 01/01/1960 | Unknown | Steel - Terminal Piping | |

| | | | | | |
|------------------------|-----|------------|--------------|----------------------------------|-----|
| 709 | Yes | | | None | Yes |
| Currently in Use | | | Not Required | Pressurized | |
| Kerosene | | 05/13/2015 | Deferred | Terminal Piping Annual Line Test | No |
| 1,512,000 | | 12/04/2015 | | | No |
| S13 | 61 | 01/01/1960 | Unknown | Steel - Terminal Piping | |
| 711 | Yes | | | None | Yes |
| Currently in Use | | | Not Required | Pressurized | |
| Diesel | | 05/13/2015 | Deferred | Terminal Piping Annual Line Test | No |
| 1,050,000 | | 12/04/2015 | | | No |
| S15 | 61 | 01/01/1960 | Unknown | Steel | |
| 713 | Yes | | | None | Yes |
| Temporarily Out of Use | | | Not Required | Pressurized | |
| Kerosene | | 05/13/2015 | Deferred | Terminal Piping Annual Line Test | No |
| 21,000 | | 11/03/2009 | | | No |
| S16 | 61 | 01/01/1960 | Unknown | Steel | |
| 714 | Yes | | | None | Yes |
| Currently in Use | | | Not Required | Pressurized | |
| Gasoline | | 05/13/2015 | Deferred | Terminal Piping Annual Line Test | No |
| 1,512,000 | | 12/04/2015 | | | No |

Facility Summary in Cascade County in the City of Great Falls

Location: RAINBOW SHOP
6700 Rainbow Dam Rd
Great Falls, MT 59404-6000 Cascade

Legacy ID:07-01189

Facility ID: 18379
Last Inspected On: 07/25/2019
Operating Permit Renewal Date: 09/30/2022

Owner Operator Contact: Northwestern Energy Rocker

4066552521

Operator Contact: Michael Holzwarth;Scott Cleveland

Owner/Operator: Northwestern Energy Rocker

Jon Story, UST Class B Operator
 Kevin Holden, UST Class B Operator
 Michael Holzwarth, UST Class A Operator
 Scott Cleveland, UST Class A Operator
 Scott Cleveland, UST Class B Operator
 Zane Shaulis, UST Class B Operator

| Tank Code | Age | Installed | Tank Material Construction | Piping Material | Overfill Types |
|------------------|-----|-----------------------|-------------------------------|-------------------------------|------------------|
| Tag # | AST | Sump Tightness | Secondary Option | Secondary Option | Spill Protected |
| Status | | Piping Installed Date | Catastrophic L.D. Type 3.0 | Piping Type | CP Met Types |
| Product | | Tank/Pipe CP | Tank Detection | Primary Pipe Detection | Vapor Recovery |
| Capacity | | Line Tightness | ATG Type | Secondary Pipe Detection | Energy Act |
| 01 | 29 | 08/01/1992 | Fiberglass Reinforced Plastic | Fiberglass Reinforced Plastic | High Level Alarm |
| 1674 | No | | | None | Yes |
| Currently in Use | | | Not Required | Safe Suction | |
| Diesel | | 06/01/2016 | Automatic Tank Gauging 0.2 | Deferred | No |
| 550 | | | Gilbarco/EMC Basic | | No |
| 02 | 29 | 08/01/1992 | Fiberglass Reinforced Plastic | Fiberglass Reinforced Plastic | High Level Alarm |
| 1675 | No | | | None | Yes |
| Currently in Use | | | Not Required | Safe Suction | |
| Gasoline | | 06/01/2016 | Automatic Tank Gauging 0.2 | Deferred | No |
| 2,000 | | | Gilbarco/EMC Basic | | No |

Facility Summary in Cascade County in the City of Great Falls

Location: RENTAL CAR SERVICE BUILDING
 2700 Airport Dr
 Great Falls, MT 59404 Cascade

Legacy ID:07-12300

Facility ID: 18994
Last Inspected On: 06/13/2019
Operating Permit Renewal Date: 07/20/2022

Owner Operator Contact: Great Falls International Airport

Operator Contact: Chris Houghton;Christopher Upchurch;Kent Funyak;Michael Novak;Rod Hall;Tory Ewing

4067273404;4067993189

Owner/Operator: Great Falls International Airport

Chris Houghton, UST Class A Operator
 Chris Houghton, UST Class B Operator
 Christopher Upchurch, UST Class A Operator
 Christopher Upchurch, UST Class B Operator
 Kent Funiyak, UST Class A Operator
 Kent Funiyak, UST Class B Operator
 Michael Novak, UST Class A Operator
 Michael Novak, UST Class B Global Operator
 Rod Hall, UST Class A Operator
 Rod Hall, UST Class B Operator
 Tory Ewing, UST Class A Operator
 Tory Ewing, UST Class B Operator

| Tank Code | Age | Installed | Tank Material Construction | Piping Material | Overfill Types |
|------------------|-----|-----------------------|-------------------------------|-------------------------------|------------------|
| Tag # | AST | Sump Tightness | Secondary Option | Secondary Option | Spill Protected |
| Status | | Piping Installed Date | Catastrophic L.D. Type 3.0 | Piping Type | CP Met Types |
| Product | | Tank/Pipe CP | Tank Detection | Primary Pipe Detection | Vapor Recovery |
| Capacity | | Line Tightness | ATG Type | Secondary Pipe Detection | Energy Act |
| 01 | 31 | 11/27/1990 | Fiberglass Reinforced Plastic | Fiberglass Reinforced Plastic | High Level Alarm |
| 2704 | No | | | None | Yes |
| Currently in Use | | | Not Required | Safe Suction | Non-corrodible |
| Gasoline | | | Automatic Tank Gauging 0.2 | Deferred | No |
| 8,000 | | | Veeder Root/TLS-300 | | No |

Facility Summary in Cascade County in the City of Great Falls

Location: SAMS CLUB 6379
 401 Northwest Byp
 Great Falls, MT 59404-4124 Cascade

Legacy ID:56-14065

Facility ID: 30718
Last Inspected On: 04/16/2020
Operating Permit Renewal Date: 04/16/2023

Owner Operator Contact: Sams West Inc

8778295505

Operator Contact: Cheryl Shie;Shaiyna Chinery

4062172265;7606692468

Owner/Operator: Sams West Inc

Cheryl Shie, UST Class A Operator
 Cheryl Shie, UST Class B Operator

Johney Miller, UST Class B Global Operator
 Shaiyna Chinery, UST Class A Operator
 Shaiyna Chinery, UST Class B Global Operator

| Tank Code | Age | Installed | Tank Material Construction | Piping Material | Overfill Types |
|------------------|-----|-----------------------|---|--|-----------------|
| Tag # | AST | Sump Tightness | Secondary Option | Secondary Option | Spill Protected |
| Status | | Piping Installed Date | Catastrophic L.D. Type 3.0 | Piping Type | CP Met Types |
| Product | | Tank/Pipe CP | Tank Detection | Primary Pipe Detection | Vapor Recovery |
| Capacity | | Line Tightness | ATG Type | Secondary Pipe Detection | Energy Act |
| 01 | 19 | 08/05/2002 | Fiberglass Reinforced Plastic | Flexible Plastic | Flapper Valve |
| 4702 | No | | Double-Walled | Double Walled | Yes |
| Currently in Use | | | Mechanical Line Leak Detector | Pressurized | Non-corrodible |
| Gasoline | | | Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring | Continuous Interstitial Monitoring;MLLD Line Tightness Testing | No |
| 20,000 | | 02/22/2017 | Veeder Root/TLS-450 | | No |
| 02 | 19 | 08/05/2002 | Fiberglass Reinforced Plastic | Flexible Plastic | Flapper Valve |
| 4703 | No | | Double-Walled | Double Walled | Yes |
| Currently in Use | | | Mechanical Line Leak Detector | Pressurized | Non-corrodible |
| Gasoline | | | Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring | Continuous Interstitial Monitoring;MLLD Line Tightness Testing | No |
| 20,000 | | 02/22/2017 | Veeder Root/TLS-450 | | No |
| 03 | 19 | 08/05/2002 | Fiberglass Reinforced Plastic | Flexible Plastic | Flapper Valve |
| 4704 | No | | Double-Walled | Double Walled | Yes |
| Currently in Use | | | Mechanical Line Leak Detector | Pressurized | Non-corrodible |
| Gasoline | | | Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring | Continuous Interstitial Monitoring;MLLD Line Tightness Testing | No |
| 20,000 | | 02/22/2017 | Veeder Root/TLS-450 | | No |

Facility Summary in Cascade County in the City of Great Falls

Location: SCHULTES 38TH STREET STORE
 3800 3rd Ave S
 Great Falls, MT 59405 Cascade

Legacy ID:07-08480

Facility ID: 18691
Last Inspected On: 03/12/2021
Operating Permit Renewal Date: 03/24/2024

Owner Operator Contact: Great Falls Convenience Store

4064533450

Operator Contact: Judy Schulte;Rory Schulte

4064533450

Owner/Operator: Great Falls Convenience Store

Judy Schulte, UST Class A Operator
 Judy Schulte, UST Class B Operator
 Rory Schulte, UST Class A Operator
 Rory Schulte, UST Class B Global Operator

| Tank Code | Age | Installed | Tank Material Construction | Piping Material | Overfill Types |
|------------------|-----|-----------------------|-------------------------------|-------------------------------|-----------------|
| Tag # | AST | Sump Tightness | Secondary Option | Secondary Option | Spill Protected |
| Status | | Piping Installed Date | Catastrophic L.D. Type 3.0 | Piping Type | CP Met Types |
| Product | | Tank/Pipe CP | Tank Detection | Primary Pipe Detection | Vapor Recovery |
| Capacity | | Line Tightness | ATG Type | Secondary Pipe Detection | Energy Act |
| 01 | 36 | 12/07/1985 | Cathodically Protected Steel | Fiberglass Reinforced Plastic | Flapper Valve |
| 1906 | No | | | None | Yes |
| Currently in Use | | | Mechanical Line Leak Detector | Pressurized | Galvanic |
| Gasoline | | 02/22/2018 | Automatic Tank Gauging 0.2 | MLLD Line Tightness Testing | No |
| 8,000 | | 02/22/2018 | Veeder Root/TLS-350 | | No |
| 02 | 36 | 12/07/1985 | Cathodically Protected Steel | Fiberglass Reinforced Plastic | Flapper Valve |
| 1907 | No | | | None | Yes |
| Currently in Use | | | Mechanical Line Leak Detector | Pressurized | Galvanic |
| Gasoline | | 02/22/2018 | Automatic Tank Gauging 0.2 | MLLD Line Tightness Testing | No |
| 8,000 | | 02/22/2018 | Veeder Root/TLS-350 | | No |
| 03 | 32 | 12/07/1989 | Fiberglass Reinforced Plastic | Fiberglass Reinforced Plastic | Flapper Valve |
| 1908 | No | | | None | Yes |

| | | | | |
|------------------|------------|-------------------------------|-----------------------------|----------------|
| Currently in Use | | Mechanical Line Leak Detector | Pressurized | Non-corrodible |
| Diesel | 02/22/2018 | Automatic Tank Gauging 0.2 | MLLD Line Tightness Testing | No |
| 4,000 | 02/22/2018 | Veeder Root/TLS-350 | | No |

Facility Summary in Cascade County in the City of Great Falls

Location: SMITHS 166 FUEL CENTER
1601 Market Place Dr
Great Falls, MT 59401 Cascade

Legacy ID:60-15217

Facility ID: 30936
Last Inspected On: 02/01/2019
Operating Permit Renewal Date: 04/16/2022

Owner Operator Contact: Smiths Food and Drug

8019741400

Operator Contact: James Dye

8015600471

Owner/Operator: Smiths Food and Drug

James Dye, UST Class A Operator
James Dye, UST Class B Global Operator
Todd Dotseth, UST Class B Operator

| Tank Code | Age | Installed | Tank Material Construction | Piping Material | Overfill Types |
|------------------|-----|-----------------------|---|---|-----------------------------------|
| Tag # | AST | Sump Tightness | Secondary Option | Secondary Option | Spill Protected |
| Status | | Piping Installed Date | Catastrophic L.D. Type 3.0 | Piping Type | CP Met Types |
| Product | | Tank/Pipe CP | Tank Detection | Primary Pipe Detection | Vapor Recovery |
| Capacity | | Line Tightness | ATG Type | Secondary Pipe Detection | Energy Act |
| 01 | 9 | 12/01/2012 | Fiberglass Reinforced Plastic | Flexible Plastic | Ball Float Valve;High Level Alarm |
| 5395 | No | | Double-Walled | Double Walled | Yes |
| Currently in Use | | 10/17/2012 | Electronic Line Leak Detector | Pressurized | |
| Gasoline | | | Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring | Continuous Interstitial Monitoring;ELLD 0.2 | No |
| 20,000 | | | Veeder Root/TLS-450 | | Yes |
| 02 | 9 | 12/01/2012 | Fiberglass Reinforced Plastic | Flexible Plastic | Ball Float Valve;High Level Alarm |
| 5396 | No | | Double-Walled | Double Walled | Yes |
| Currently in Use | | 10/17/2012 | Electronic Line Leak Detector | Pressurized | |

| | | | | | |
|------------------|----|------------|---|--|-----------------------------------|
| Diesel | | | Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring | Continuous Interstitial Monitoring;ELLD 0.2 | No |
| 10,000 | | | Veeder Root/TLS-450 | | Yes |
| 03 | 9 | 12/01/2012 | Fiberglass Reinforced Plastic | Flexible Plastic | Ball Float Valve;High Level Alarm |
| 5397 | No | | Double-Walled | Double Walled | Yes |
| Currently in Use | | 10/17/2012 | Electronic Line Leak Detector | Pressurized | |
| Gasoline | | | Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring | Continuous Interstitial Monitoring;ELLD 0.2 | No |
| 8,000 | | | Veeder Root/TLS-450 | | Yes |

Facility Summary in Cascade County in the City of Great Falls

Location: SUCH GROUP INTERNATIONAL INC
2224 Vaughn Rd
Great Falls, MT 59404-2196 Cascade

Legacy ID:07-13632

Facility ID: 19051
Last Inspected On: 02/23/2021
Operating Permit Renewal Date:

Owner Operator Contact: Such Group International Inc

4067274144

Operator Contact: Todd Such

4067274114

Owner/Operator: Such Group International Inc

Todd Such, UST Class A Operator

Todd Such, UST Class B Operator

| Tank Code | Age | Installed | Tank Material Construction | Piping Material | Overfill Types |
|------------------------|-----|-----------------------|---|------------------------------------|------------------|
| Tag # | AST | Sump Tightness | Secondary Option | Secondary Option | Spill Protected |
| Status | | Piping Installed Date | Catastrophic L.D. Type 3.0 | Piping Type | CP Met Types |
| Product | | Tank/Pipe CP | Tank Detection | Primary Pipe Detection | Vapor Recovery |
| Capacity | | Line Tightness | ATG Type | Secondary Pipe Detection | Energy Act |
| 01 | 26 | 08/01/1995 | Fiberglass Reinforced Plastic | Flexible Plastic | High Level Alarm |
| 4389 | No | | | Double Walled | Yes |
| Temporarily Out of Use | | | Continuous Interstitial Monitoring | Pressurized | Non-corrodible |
| Gasoline | | | Automatic Tank Gauging 0.1;Automatic Tank Gauging 0.2 | Continuous Interstitial Monitoring | No |
| 10,000 | | | | | No |
| 02 | 26 | 08/01/1995 | Fiberglass Reinforced Plastic | Flexible Plastic | High Level Alarm |
| 4390 | No | | | Double Walled | Yes |
| Temporarily Out of Use | | | Continuous Interstitial Monitoring | Pressurized | Non-corrodible |
| Diesel | | | Automatic Tank Gauging 0.1;Automatic Tank Gauging 0.2 | Continuous Interstitial Monitoring | No |
| 12,000 | | | | | No |

Facility Summary in Cascade County in the City of Great Falls

Location: TOLAN DISTRIBUTING INC
2201 Vaughn Rd
Great Falls, MT 59404-2197 Cascade

Legacy ID:07-04511

Facility ID: 18527
Last Inspected On: 09/03/2020
Operating Permit Renewal Date: 09/15/2023

Owner Operator Contact: Tolan Distributing Inc

4064538810

Operator Contact: Derrick Tolan

Owner/Operator: Tolan Distributing Inc

Derrick Tolan, UST Class A Operator

Derrick Tolan, UST Class B Global Operator

| Tank Code | Age | Installed | Tank Material Construction | Piping Material | Overfill Types |
|------------------|-----|-----------------------|-------------------------------|--|------------------|
| Tag # | AST | Sump Tightness | Secondary Option | Secondary Option | Spill Protected |
| Status | | Piping Installed Date | Catastrophic L.D. Type 3.0 | Piping Type | CP Met Types |
| Product | | Tank/Pipe CP | Tank Detection | Primary Pipe Detection | Vapor Recovery |
| Capacity | | Line Tightness | ATG Type | Secondary Pipe Detection | Energy Act |
| 06 | 22 | 09/01/1999 | Fiberglass Reinforced Plastic | Flexible Plastic | High Level Alarm |
| 4098 | No | 10/15/2015 | | Double Walled | Yes |
| Currently in Use | | | Mechanical Line Leak Detector | Pressurized | Non-corrodible |
| Gasoline | | | Automatic Tank Gauging 0.2 | Continuous Interstitial Monitoring;MLLD Line Tightness Testing | No |
| 8,000 | | | EMCO Electronics/EECO 1500 | | No |
| 07 | 22 | 09/01/1999 | Fiberglass Reinforced Plastic | Flexible Plastic | High Level Alarm |
| 4099 | No | 10/15/2015 | | Double Walled | Yes |
| Currently in Use | | | Mechanical Line Leak Detector | Pressurized | Non-corrodible |
| Gasoline | | | Automatic Tank Gauging 0.2 | Continuous Interstitial Monitoring;MLLD Line Tightness Testing | No |
| 4,000 | | | EMCO Electronics/EECO 1500 | | No |
| 08 | 22 | 09/01/1999 | Fiberglass Reinforced Plastic | Flexible Plastic | High Level Alarm |
| 4100 | No | 10/15/2015 | | Double Walled | Yes |
| Currently in Use | | | Mechanical Line Leak Detector | Pressurized | Non-corrodible |
| Diesel | | | Automatic Tank Gauging 0.2 | Continuous Interstitial Monitoring;MLLD Line Tightness Testing | No |
| 8,000 | | | EMCO Electronics/EECO 1500 | | No |

| | | | | | |
|------------------|----|------------|-------------------------------|--|------------------|
| 09 | 22 | 09/01/1999 | Fiberglass Reinforced Plastic | Flexible Plastic | High Level Alarm |
| 4101 | No | 10/15/2015 | | Double Walled | Yes |
| Currently in Use | | | Mechanical Line Leak Detector | Pressurized | Non-corrodible |
| Diesel | | | Automatic Tank Gauging 0.2 | Continuous Interstitial Monitoring;MLLD Line Tightness Testing | No |
| 4,000 | | | EMCO Electronics/EECO 1500 | | No |

Facility Summary in Cascade County in the City of Great Falls

Location: TOWN PUMP GREAT FALLS #7
1411 10th Ave S
Great Falls, MT 59405 Cascade

Legacy ID:60-15283

Facility ID: 30990
Last Inspected On: 04/25/2020
Operating Permit Renewal Date: 08/06/2023

Owner Operator Contact:

Operator Contact: Don Edmiston

4064976700

Owner/Operator: Great Falls 7 Town Pump LLC

Don Edmiston, UST Class A Operator
Don Edmiston, UST Class B Operator

| Tank Code | Age | Installed | Tank Material Construction | Piping Material | Overfill Types |
|------------------|-----|-----------------------|--|--|-----------------------------------|
| Tag # | AST | Sump Tightness | Secondary Option | Secondary Option | Spill Protected |
| Status | | Piping Installed Date | Catastrophic L.D. Type 3.0 | Piping Type | CP Met Types |
| Product | | Tank/Pipe CP | Tank Detection | Primary Pipe Detection | Vapor Recovery |
| Capacity | | Line Tightness | ATG Type | Secondary Pipe Detection | Energy Act |
| 01 | 4 | 01/25/2017 | Fiberglass Reinforced Plastic | High Density Polyethylene | High Level Alarm;Positive Shutoff |
| 5665 | No | 09/01/2016 | Double-Walled | Double Walled | Yes |
| Currently in Use | | 07/01/2016 | Electronic Line Leak Detector | Pressurized | Non-corrodible |
| Diesel | | | Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation | Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation | No |
| 6,000 | | | Gilbarco-Veeder Root/TLS-450 | | Yes |
| 02 | 4 | 01/25/2017 | Fiberglass Reinforced Plastic | High Density Polyethylene | High Level Alarm;Positive Shutoff |

| | | | | | |
|------------------|----|------------|--|--|-----------------------------------|
| 5666 | No | 09/01/2016 | Double-Walled | Double Walled | Yes |
| Currently in Use | | 07/01/2016 | Electronic Line Leak Detector | Pressurized | Non-corrodible |
| Diesel | | | Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation | Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation | No |
| 15,000 | | | Gilbarco-Veeder Root/TLS-450 | | Yes |
| 03 | 4 | 01/25/2017 | Fiberglass Reinforced Plastic | High Density Polyethylene | High Level Alarm;Positive Shutoff |
| 5667 | No | 09/01/2016 | Double-Walled | Double Walled | Yes |
| Currently in Use | | 07/01/2016 | Electronic Line Leak Detector | Pressurized | Non-corrodible |
| Diesel | | | Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation | Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation | No |
| 6,000 | | | Gilbarco-Veeder Root/TLS-450 | | Yes |
| 04 | 4 | 01/25/2017 | Fiberglass Reinforced Plastic | High Density Polyethylene | High Level Alarm;Positive Shutoff |
| 5668 | No | 09/01/2016 | Double-Walled | Double Walled | Yes |
| Currently in Use | | 07/01/2016 | Electronic Line Leak Detector | Pressurized | Non-corrodible |
| Gasoline | | | Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation | Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation | No |
| 25,000 | | | Gilbarco-Veeder Root/TLS-450 | | Yes |
| 05 | 4 | 01/25/2017 | Fiberglass Reinforced Plastic | High Density Polyethylene | High Level Alarm;Positive Shutoff |
| 5669 | No | 09/01/2016 | Double-Walled | Double Walled | Yes |
| Currently in Use | | 07/01/2016 | Electronic Line Leak Detector | Pressurized | Non-corrodible |
| Gasoline | | | Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation | Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation | No |
| 15,000 | | | Gilbarco-Veeder Root/TLS-450 | | Yes |
| 06 | 4 | 01/25/2017 | Fiberglass Reinforced Plastic | High Density Polyethylene | High Level Alarm;Positive Shutoff |

| | | | | | |
|------------------|----|------------|--|--|----------------|
| 5670 | No | 09/01/2016 | Double-Walled | Double Walled | Yes |
| Currently in Use | | 07/01/2016 | Electronic Line Leak Detector | Pressurized | Non-corrodible |
| Gasoline | | | Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation | Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation | No |
| 6,000 | | | Gilbarco-Veeder Root/TLS-450 | | Yes |

Facility Summary in Cascade County in the City of Great Falls

Location: TOWN PUMP INC GREAT FALLS 1
401 10th Ave S
Great Falls, MT 59405-4044 Cascade

Legacy ID:07-08700

Facility ID: 18695
Last Inspected On: 06/01/2019
Operating Permit Renewal Date: 08/13/2022

Owner Operator Contact: Don Edmisten;Town Pump

4064976948

Operator Contact:

Owner/Operator: Great Falls 1 Town Pump LLC

Don Edmisten, UST Class B Global Operator

| Tank Code | Age | Installed | Tank Material Construction | Piping Material | Overfill Types |
|------------------|-----|-----------------------|---|--|-------------------|
| Tag # | AST | Sump Tightness | Secondary Option | Secondary Option | Spill Protected |
| Status | | Piping Installed Date | Catastrophic L.D. Type 3.0 | Piping Type | CP Met Types |
| Product | | Tank/Pipe CP | Tank Detection | Primary Pipe Detection | Vapor Recovery |
| Capacity | | Line Tightness | ATG Type | Secondary Pipe Detection | Energy Act |
| 01 | 35 | 01/01/1986 | Cathodically Protected Steel | Flexible Plastic | Ball Float Valve |
| 2391 | No | | | Double Walled | Yes |
| Currently in Use | | 07/12/2013 | Electronic Line Leak Detector | Pressurized | Impressed Current |
| Gasoline | | 02/19/2016 | Approved Remote Monitoring;Statistical Inventory Reconciliation | Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation | No |
| 10,000 | | | Gilbarco-Veeder Root/TLS-350 | | No |
| 02 | 35 | 01/01/1986 | Cathodically Protected Steel | Flexible Plastic | Ball Float Valve |
| 2392 | No | | | Double Walled | Yes |
| Currently in Use | | 07/12/2013 | Electronic Line Leak Detector | Pressurized | Impressed Current |

| | | | | | |
|------------------|----|------------|--|--|-------------------|
| Gasoline | | 02/19/2016 | Approved Remote Monitoring;Statistical Inventory Reconciliation | Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation | No |
| 10,000 | | | Gilbarco-Veeder Root/TLS-350 | | No |
| 03 | 33 | 08/18/1988 | Cathodically Protected Steel | Flexible Plastic | Ball Float Valve |
| 2393 | No | | | Double Walled | Yes |
| Currently in Use | | 07/12/2013 | Electronic Line Leak Detector | Pressurized | Impressed Current |
| Gasoline | | 02/19/2016 | Approved Remote Monitoring;Statistical Inventory Reconciliation | Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation | No |
| 10,000 | | | Gilbarco-Veeder Root/TLS-350 | | No |
| 04 | 23 | 05/01/1998 | Fiberglass Reinforced Plastic | Flexible Plastic | Ball Float Valve |
| 2394 | No | | Double-Walled | Double Walled | Yes |
| Currently in Use | | | Electronic Line Leak Detector | Pressurized | Non-corrodible |
| Gasoline | | 03/16/2010 | Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation | Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation | No |
| 10,000 | | | Gilbarco-Veeder Root/TLS-350 | | No |
| 05 | 23 | 05/01/1998 | Fiberglass Reinforced Plastic | Flexible Plastic | Ball Float Valve |
| 2395 | No | | Double-Walled | Double Walled | Yes |
| Currently in Use | | 07/12/2013 | Electronic Line Leak Detector | Pressurized | Non-corrodible |
| Gasoline | | 03/16/2010 | Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation | Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation | No |
| 8,000 | | | Gilbarco-Veeder Root/TLS-350 | | No |

Facility Summary in Cascade County in the City of Great Falls

Location: TOWN PUMP INC GREAT FALLS 2
1400 10th Ave S
Great Falls, MT 59405-2624 Cascade

Legacy ID:07-08701

Facility ID: 18696
Last Inspected On: 08/04/2021
Operating Permit Renewal Date: 07/20/2023

Owner Operator Contact:

Operator Contact:

Owner/Operator: Great Falls 2 Town Pump LLC

Don Edmisten, UST Class B Global Operator

| Tank Code | Age | Installed | Tank Material Construction | Piping Material | Overfill Types |
|------------------|-----|-----------------------|---|---|-----------------|
| Tag # | AST | Sump Tightness | Secondary Option | Secondary Option | Spill Protected |
| Status | | Piping Installed Date | Catastrophic L.D. Type 3.0 | Piping Type | CP Met Types |
| Product | | Tank/Pipe CP | Tank Detection | Primary Pipe Detection | Vapor Recovery |
| Capacity | | Line Tightness | ATG Type | Secondary Pipe Detection | Energy Act |
| 11 | 0 | | Fiberglass Reinforced Plastic | Flexible Plastic | Flapper Valve |
| 5944 | No | | Double-Walled | Double Walled | No |
| Currently in Use | | | Electronic Line Leak Detector | Pressurized | Non-corrodible |
| Gasoline | | | Continuous Interstitial Monitoring;Statistical Inventory Reconciliation | Continuous Interstitial Monitoring;Statistical Inventory Reconciliation | Yes |
| 15,000 | | | | | Yes |
| 12 | 0 | | Fiberglass Reinforced Plastic | Flexible Plastic | Flapper Valve |
| 5945 | No | | Double-Walled | Double Walled | No |
| Currently in Use | | | Electronic Line Leak Detector | Pressurized | Non-corrodible |
| Diesel | | | Continuous Interstitial Monitoring;Statistical Inventory Reconciliation | Continuous Interstitial Monitoring;Statistical Inventory Reconciliation | No |
| 15,000 | | | | | Yes |
| 13 | 0 | | Fiberglass Reinforced Plastic | Flexible Plastic | Flapper Valve |
| 5946 | No | | Double-Walled | Double Walled | No |
| Currently in Use | | | Electronic Line Leak Detector | Pressurized | Non-corrodible |
| Gasoline | | | Continuous Interstitial Monitoring;Statistical Inventory Reconciliation | Continuous Interstitial Monitoring;Statistical Inventory Reconciliation | Yes |
| 20,000 | | | | | Yes |

Facility Summary in Cascade County in the City of Great Falls

Location: TOWN PUMP INC GREAT FALLS 3
505 Northwest Byp
Great Falls, MT 59404-4102 Cascade

Legacy ID:56-14016

Facility ID: 30676
Last Inspected On: 06/01/2019
Operating Permit Renewal Date: 08/13/2022

Owner Operator Contact:

Operator Contact:

Owner/Operator: Great Falls 3 Town Pump LLC

Don Edmisten, UST Class B Global Operator

| Tank Code | Age | Installed | Tank Material Construction | Piping Material | Overfill Types |
|------------------|-----|-----------------------|--|--|------------------|
| Tag # | AST | Sump Tightness | Secondary Option | Secondary Option | Spill Protected |
| Status | | Piping Installed Date | Catastrophic L.D. Type 3.0 | Piping Type | CP Met Types |
| Product | | Tank/Pipe CP | Tank Detection | Primary Pipe Detection | Vapor Recovery |
| Capacity | | Line Tightness | ATG Type | Secondary Pipe Detection | Energy Act |
| 01 | 20 | 10/01/2001 | Fiberglass Reinforced Plastic | Flexible Plastic | Ball Float Valve |
| 4453 | No | | Double-Walled | Double Walled | Yes |
| Currently in Use | | | Electronic Line Leak Detector | Pressurized | Non-corrodible |
| Gasoline | | 11/30/2005 | Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation | Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation | Yes |
| 15,000 | | 10/12/2006 | Gilbarco-Veeder Root/TLS-350 | | No |
| 02 | 20 | 10/01/2001 | Fiberglass Reinforced Plastic | Flexible Plastic | Ball Float Valve |
| 4454 | No | | Double-Walled | Double Walled | Yes |
| Currently in Use | | | Electronic Line Leak Detector | Pressurized | Non-corrodible |
| Gasoline | | 11/30/2005 | Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation | Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation | No |
| 10,000 | | 10/12/2006 | Gilbarco-Veeder Root/TLS-350 | | No |
| 03 | 20 | 10/01/2001 | Fiberglass Reinforced Plastic | Flexible Plastic | Ball Float Valve |
| 4455 | No | | Double-Walled | Double Walled | Yes |

| | | | | | |
|------------------|----|------------|--|--|------------------|
| Currently in Use | | | Electronic Line Leak Detector | Pressurized | Non-corrodible |
| Diesel | | 11/30/2005 | Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation | Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation | No |
| 5,000 | | 10/12/2006 | Gilbarco-Veeder Root/TLS-350 | | No |
| 04 | 20 | 10/01/2001 | Fiberglass Reinforced Plastic | Flexible Plastic | Ball Float Valve |
| 4456 | No | | Double-Walled | Double Walled | Yes |
| Currently in Use | | | Electronic Line Leak Detector | Pressurized | Non-corrodible |
| Gasoline | | 11/30/2005 | Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation | Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation | No |
| 10,000 | | 10/12/2006 | Gilbarco-Veeder Root/TLS-350 | | No |
| 05 | 20 | 10/01/2001 | Fiberglass Reinforced Plastic | Flexible Plastic | Ball Float Valve |
| 4457 | No | | Double-Walled | Double Walled | Yes |
| Currently in Use | | | Electronic Line Leak Detector | Pressurized | Non-corrodible |
| Gasoline | | 11/30/2005 | Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation | Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation | No |
| 5,000 | | 10/12/2006 | Gilbarco-Veeder Root/TLS-350 | | No |

Facility Summary in Cascade County in the City of Great Falls

Location: TOWN PUMP INC GREAT FALLS 4
700 10th Ave S
Great Falls, MT 59405-4051 Cascade

Legacy ID:07-03217

Facility ID: 18470
Last Inspected On: 06/06/2019
Operating Permit Renewal Date: 08/13/2022

Owner Operator Contact: Don Edmisten;Billings Holdings LLC

4064976948

Operator Contact:

Owner/Operator: Great Falls 4 Town Pump LLC

Don Edmisten, UST Class B Global Operator

| Tank Code | Age | Installed | Tank Material Construction | Piping Material | Overfill Types |
|-----------|-----|-----------------------|----------------------------|------------------|-----------------|
| Tag # | AST | Sump Tightness | Secondary Option | Secondary Option | Spill Protected |
| Status | | Piping Installed Date | Catastrophic L.D. Type 3.0 | Piping Type | CP Met Types |

| Product | Tank/Pipe CP | Tank Detection | Primary Pipe Detection | Vapor Recovery | |
|------------------|----------------|----------------|--|--|------------------|
| Capacity | Line Tightness | ATG Type | Secondary Pipe Detection | Energy Act | |
| 08 | 19 | 08/18/2002 | Fiberglass Reinforced Plastic | Flexible Plastic | Ball Float Valve |
| 4708 | No | | Double-Walled | Double Walled | Yes |
| Currently in Use | | | Electronic Line Leak Detector | Pressurized | Non-corrodible |
| Diesel | | | Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation | Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation | No |
| 10,000 | | | Gilbarco-Veeder Root/TLS-350 | | No |
| 09 | 19 | 08/18/2002 | Fiberglass Reinforced Plastic | Flexible Plastic | Ball Float Valve |
| 4709 | No | | Double-Walled | Double Walled | Yes |
| Currently in Use | | | Electronic Line Leak Detector | Pressurized | Non-corrodible |
| Diesel | | | Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation | Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation | No |
| 5,000 | | | Gilbarco-Veeder Root/TLS-350 | | No |
| 05 | 26 | 08/01/1995 | Fiberglass Reinforced Plastic | Flexible Plastic | Ball Float Valve |
| 4804 | No | | | Double Walled | Yes |
| Currently in Use | | | Electronic Line Leak Detector | Pressurized | Non-corrodible |
| Diesel | | | Approved Remote Monitoring;Statistical Inventory Reconciliation | Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation | No |
| 2,000 | | | Gilbarco-Veeder Root/TLS-350 | | No |
| 06 | 26 | 08/01/1995 | Fiberglass Reinforced Plastic | Flexible Plastic | Ball Float Valve |
| 4805 | No | | | Double Walled | Yes |
| Currently in Use | | | Electronic Line Leak Detector | Pressurized | Non-corrodible |

| | | | | | |
|------------------|----|------------|---|--|------------------|
| Gasoline | | | Approved Remote Monitoring;Statistical Inventory Reconciliation | Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation | No |
| 12,000 | | | Gilbarco-Veeder Root/TLS-350 | | No |
| 07 | 26 | 08/01/1995 | Fiberglass Reinforced Plastic | Flexible Plastic | Ball Float Valve |
| 4806 | No | | | Double Walled | Yes |
| Currently in Use | | | Electronic Line Leak Detector | Pressurized | Non-corrodible |
| Gasoline | | | Approved Remote Monitoring;Statistical Inventory Reconciliation | Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation | No |
| 12,000 | | | Gilbarco-Veeder Root/TLS-350 | | No |

Facility Summary in Cascade County in the City of Great Falls

Location: TOWN PUMP INC GREAT FALLS 5
3700 31st St SW Ste 1
Great Falls, MT 59404-4734 Cascade

Legacy ID:07-03463

Facility ID: 18483
Last Inspected On: 06/01/2019
Operating Permit Renewal Date: 08/13/2022

Owner Operator Contact: Don Edmisten;Great Falls Holdings LLC

4064976948;4064976700

Operator Contact:

Owner/Operator: Great Falls 5 Town Pump Inc

Don Edmisten, UST Class B Global Operator

| Tank Code | Age | Installed | Tank Material Construction | Piping Material | Overfill Types |
|------------------|-----|-----------------------|---|--|------------------|
| Tag # | AST | Sump Tightness | Secondary Option | Secondary Option | Spill Protected |
| Status | | Piping Installed Date | Catastrophic L.D. Type 3.0 | Piping Type | CP Met Types |
| Product | | Tank/Pipe CP | Tank Detection | Primary Pipe Detection | Vapor Recovery |
| Capacity | | Line Tightness | ATG Type | Secondary Pipe Detection | Energy Act |
| 04 | 32 | 01/15/1989 | Steel Clad | Fiberglass Reinforced Plastic | Ball Float Valve |
| 2223 | No | | | Double Walled | Yes |
| Currently in Use | | | Electronic Line Leak Detector | Pressurized | Galvanic |
| Diesel | | 02/17/2016 | Approved Remote Monitoring;Statistical Inventory Reconciliation | Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation | No |

| | | | | | |
|------------------|----|------------|---|--|-------------------|
| 6,000 | | | Gilbarco-Veeder Root/TLS-350 | | No |
| 07 | 32 | 01/15/1989 | Cathodically Protected Steel | Fiberglass Reinforced Plastic | Ball Float Valve |
| 2224 | No | | | Double Walled | Yes |
| Currently in Use | | | Electronic Line Leak Detector | Pressurized | Impressed Current |
| Gasoline | | 02/17/2016 | Approved Remote Monitoring;Statistical Inventory Reconciliation | Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation | No |
| 14,000 | | | Gilbarco-Veeder Root/TLS-350 | | No |
| 08 | 28 | 04/01/1993 | Cathodically Protected Steel | Fiberglass Reinforced Plastic | Ball Float Valve |
| 2225 | No | | | Double Walled | Yes |
| Currently in Use | | | Electronic Line Leak Detector | Pressurized | Galvanic |
| Gasoline | | 02/17/2016 | Approved Remote Monitoring;Statistical Inventory Reconciliation | Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation | Yes |
| 10,000 | | | | | No |
| 09 | 28 | 04/01/1993 | Bare Steel | Fiberglass Reinforced Plastic | Ball Float Valve |
| 2226 | No | | | Double Walled | Yes |
| Currently in Use | | | Electronic Line Leak Detector | Pressurized | Impressed Current |
| Diesel | | 02/17/2016 | Approved Remote Monitoring;Statistical Inventory Reconciliation | Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation | No |
| 6,000 | | | Gilbarco-Veeder Root/TLS-350 | | No |
| 10 | 28 | 04/01/1993 | Bare Steel | Fiberglass Reinforced Plastic | Ball Float Valve |
| 2227 | No | | | Double Walled | Yes |
| Currently in Use | | | Electronic Line Leak Detector | Pressurized | Galvanic |
| Diesel | | 02/17/2016 | Approved Remote Monitoring;Statistical Inventory Reconciliation | Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation | No |

| | | | | | |
|------------------|----|------------|--|--|--------------------------------|
| 6,000 | | | Gilbarco-Veeder Root/TLS-350 | | No |
| 11 | 15 | 04/25/2006 | Fiberglass Reinforced Plastic | Fiberglass Reinforced Plastic | Ball Float Valve;Flapper Valve |
| 5080 | No | | Double-Walled | Double Walled | Yes |
| Currently in Use | | | Electronic Line Leak Detector | Pressurized | Non-corrodible |
| Diesel | | 03/12/2010 | Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation | Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation | No |
| 30,000 | | | Gilbarco-Veeder Root/TLS-350 | | No |
| 12 | 15 | 04/26/2006 | Fiberglass Reinforced Plastic | Fiberglass Reinforced Plastic | Ball Float Valve;Flapper Valve |
| 5081 | No | | Double-Walled | Double Walled | Yes |
| Currently in Use | | | Electronic Line Leak Detector | Pressurized | Non-corrodible |
| Diesel | | 03/12/2010 | Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation | Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation | No |
| 30,000 | | | Gilbarco-Veeder Root/TLS-350 | | No |
| 13 | 15 | 04/25/2006 | Fiberglass Reinforced Plastic | Fiberglass Reinforced Plastic | Ball Float Valve;Flapper Valve |
| 5082 | No | | Double-Walled | Double Walled | Yes |
| Currently in Use | | | Electronic Line Leak Detector | Pressurized | Non-corrodible |
| Diesel | | 03/12/2010 | Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation | Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation | No |
| 30,000 | | | Gilbarco-Veeder Root/TLS-350 | | No |

Facility Summary in Cascade County in the City of Great Falls

Location: WALMART SUPERCENTER #7199
5400 10th Ave S
Great Falls, MT 59405 Cascade

Legacy ID:60-15280

Facility ID: 30988
Last Inspected On: 05/13/2020
Operating Permit Renewal Date: 09/10/2023

Owner Operator Contact:

Operator Contact: Robert Hitchcock;Treavor Harpine

4067706083

Owner/Operator: Walmart Inc

Angela Powell, UST Class B Operator
 Johney Miller, UST Class B Global Operator
 Robert Hitchcock, UST Class A Operator
 Robert Hitchcock, UST Class B Global Operator
 Treavor Harpine, UST Class A Operator
 Treavor Harpine, UST Class B Global Operator

| Tank Code | Age | Installed | Tank Material Construction | Piping Material | Overfill Types |
|------------------|-----|-----------------------|------------------------------------|--|-----------------|
| Tag # | AST | Sump Tightness | Secondary Option | Secondary Option | Spill Protected |
| Status | | Piping Installed Date | Catastrophic L.D. Type 3.0 | Piping Type | CP Met Types |
| Product | | Tank/Pipe CP | Tank Detection | Primary Pipe Detection | Vapor Recovery |
| Capacity | | Line Tightness | ATG Type | Secondary Pipe Detection | Energy Act |
| 01 | 4 | 03/01/2017 | Fiberglass Reinforced Plastic | Flexible Plastic | Flapper Valve |
| 5646 | No | 06/22/2016 | Double-Walled | Double Walled | Yes |
| Currently in Use | | | Mechanical Line Leak Detector | Pressurized | Non-corrodible |
| Gasoline | | | Continuous Interstitial Monitoring | Continuous Interstitial Monitoring;MLLD Line Tightness Testing | Yes |
| 20,000 | | 03/07/2017 | Gilbarco-Veeder Root/TLS-450 | | Yes |
| 02 | 4 | 03/01/2017 | Fiberglass Reinforced Plastic | Flexible Plastic | Flapper Valve |
| 5647 | No | 06/22/2016 | Double-Walled | Double Walled | Yes |
| Currently in Use | | | Mechanical Line Leak Detector | Pressurized | Non-corrodible |
| Gasoline | | | Continuous Interstitial Monitoring | Continuous Interstitial Monitoring;MLLD Line Tightness Testing | Yes |
| 12,000 | | 03/07/2017 | Gilbarco-Veeder Root/TLS-450 | | Yes |
| 03 | 4 | 03/01/2017 | Fiberglass Reinforced Plastic | Flexible Plastic | Flapper Valve |
| 5648 | No | 06/22/2016 | Double-Walled | Double Walled | Yes |
| Currently in Use | | | Mechanical Line Leak Detector | Pressurized | Non-corrodible |
| Diesel | | | Continuous Interstitial Monitoring | Continuous Interstitial Monitoring;MLLD Line Tightness Testing | No |

8,000 03/07/2017 Gilbarco-Veeder Root/TLS-450 Yes

Facility Summary in Cascade County in the City of Great Falls

Location: ZIP TRIP 44
1608 Fox Farm Rd
Great Falls, MT 59404-3339 Cascade

Legacy ID:07-04945

Facility ID: 18550
Last Inspected On: 08/24/2020
Operating Permit Renewal Date: 09/03/2020

Owner Operator Contact: Jeff Averill;Jadyn Scott LLC;Jim Alford;CHS Inc - Spokane **5095367418**

Operator Contact: Jim Alford;Tom Savas **5095367418**

Owner/Operator: CHS Inc Spokane Valley

Jim Alford, UST Class A Operator
Jim Alford, UST Class B Global Operator
Luci Tuttle, UST Class B Operator
Tom Savas, UST Class A Operator

| Tank Code | Age | Installed | Tank Material Construction | Piping Material | Overfill Types |
|------------------|-----|------------|---|-------------------------------|------------------|
| 02 | 53 | 01/01/1968 | Fiberglass Reinforced Plastic | Fiberglass Reinforced Plastic | High Level Alarm |
| 1972 | No | | | None | Yes |
| Currently in Use | | | Electronic Line Leak Detector | Pressurized | |
| Gasoline | | | Automatic Tank Gauging 0.2 | ELLD 0.2 | No |
| 8,000 | | 03/19/2008 | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | No |
| 03 | 53 | 01/01/1968 | Fiberglass Reinforced Plastic | Fiberglass Reinforced Plastic | High Level Alarm |
| 1973 | No | | | Double Walled | Yes |
| Currently in Use | | | Electronic Line Leak Detector | Pressurized | |
| Gasoline | | | Automatic Tank Gauging 0.2 | ELLD 0.2 | No |
| 8,000 | | 03/19/2008 | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | No |

| | | | | | |
|------------------|----|------------|---|-------------------------------|------------------|
| 05 | 24 | 11/03/1997 | Fiberglass Reinforced Plastic | Fiberglass Reinforced Plastic | High Level Alarm |
| 1974 | No | | | None | Yes |
| Currently in Use | | | Electronic Line Leak Detector | Pressurized | |
| Diesel | | | Automatic Tank Gauging 0.2 | ELLD 0.2 | No |
| 4,000 | | 03/19/2008 | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | No |
| 06 | 24 | 11/01/1997 | Fiberglass Reinforced Plastic | Fiberglass Reinforced Plastic | High Level Alarm |
| 1975 | No | | | None | Yes |
| Currently in Use | | | Electronic Line Leak Detector | Pressurized | |
| Gasoline | | | Automatic Tank Gauging 0.2 | ELLD 0.2 | No |
| 8,000 | | 03/19/2008 | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | No |

Facility Summary in Cascade County in the City of Great Falls

Location: ZIP TRIP 45
625 1st Ave N
Great Falls, MT 59401-2510 Cascade

Legacy ID:07-01057

Facility ID: 18375
Last Inspected On: 10/01/2018
Operating Permit Renewal Date: 03/30/2022

Owner Operator Contact: Kim Haggerty;Miller and Holmes Inc

7153771730

Operator Contact: Jim Alford;Sean Hurley

5095357701;5095367418

Owner/Operator: CHS Inc Spokane Valley

Jim Alford, UST Class A Operator
Jim Alford, UST Class B Global Operator
Karina Serrano, UST Class B Global Operator
Luci Tuttle, UST Class B Operator
Sean Hurley, UST Class A Operator

| Tank Code | Age | Installed | Tank Material Construction | Piping Material | Overfill Types |
|-----------|-----|-----------------------|----------------------------|--------------------------|-----------------|
| Tag # | AST | Sump Tightness | Secondary Option | Secondary Option | Spill Protected |
| Status | | Piping Installed Date | Catastrophic L.D. Type 3.0 | Piping Type | CP Met Types |
| Product | | Tank/Pipe CP | Tank Detection | Primary Pipe Detection | Vapor Recovery |
| Capacity | | Line Tightness | ATG Type | Secondary Pipe Detection | Energy Act |

| | | | | | |
|----|----|------------|------------------------------|------------------|------------------|
| 01 | 39 | 04/27/1982 | Cathodically Protected Steel | Flexible Plastic | High Level Alarm |
|----|----|------------|------------------------------|------------------|------------------|

| | | | | | |
|------------------|----|------------|---|--|-------------------|
| 1610 | No | | | Double Walled | Yes |
| Currently in Use | | | Electronic Line Leak Detector | Pressurized | Impressed Current |
| Diesel | | 09/28/2018 | Automatic Tank Gauging 0.2 | Continuous Interstitial Monitoring; ELLD 0.2 | No |
| 15,000 | | | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | No |
| 02 | 39 | 04/27/1982 | Cathodically Protected Steel | Flexible Plastic | High Level Alarm |
| 1611 | No | | | Double Walled | Yes |
| Currently in Use | | | Electronic Line Leak Detector | Pressurized | Impressed Current |
| Gasoline | | 09/28/2018 | Automatic Tank Gauging 0.2 | Continuous Interstitial Monitoring; ELLD 0.2 | No |
| 15,000 | | | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | No |
| 03 | 39 | 04/27/1982 | Cathodically Protected Steel | Flexible Plastic | High Level Alarm |
| 1612 | No | | | Double Walled | Yes |
| Currently in Use | | | Electronic Line Leak Detector | Pressurized | Impressed Current |
| Gasoline | | 09/28/2018 | Automatic Tank Gauging 0.2 | Continuous Interstitial Monitoring; ELLD 0.2 | No |
| 15,000 | | | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | No |

Facility Summary in Cascade County in the City of Malmstrom A F B

Location: MALMSTROM AFB BLDG 1480 1482
6705 Flightline Dr
Malmstrom A F B, MT 59402-7524 Cascade

Legacy ID:07-10733

Facility ID: 18844
Last Inspected On: 04/06/2021
Operating Permit Renewal Date: 06/08/2024

Owner Operator Contact:

Operator Contact: Candace Ellsworth;Curtis Hester;William Smith **4067316239;4067317128**

Owner/Operator: 341 CES CEANQ

- Candace Ellsworth, UST Class A Operator
- Candace Ellsworth, UST Class B Global Operator
- Curtis Hester, UST Class A Operator
- Curtis Hester, UST Class B Global Operator
- Rodney Borger, UST Class B Global Operator
- William Smith, UST Class A Operator
- William Smith, UST Class B Global Operator

| Tank Code | Age | Installed | Tank Material Construction | Piping Material | Overfill Types |
|------------------|-----|-----------------------|------------------------------------|------------------------------------|--------------------------------|
| Tag # | AST | Sump Tightness | Secondary Option | Secondary Option | Spill Protected |
| Status | | Piping Installed Date | Catastrophic L.D. Type 3.0 | Piping Type | CP Met Types |
| Product | | Tank/Pipe CP | Tank Detection | Primary Pipe Detection | Vapor Recovery |
| Capacity | | Line Tightness | ATG Type | Secondary Pipe Detection | Energy Act |
| 04 | 25 | 08/01/1996 | Fiberglass Reinforced Plastic | Steel | Flapper Valve;High Level Alarm |
| 4325 | No | 05/22/2018 | Double-Walled | None | Yes |
| Currently in Use | | | Mechanical Line Leak Detector | Pressurized | |
| Jet Fuel, JP8 | | 05/22/2018 | Continuous Interstitial Monitoring | Continuous Interstitial Monitoring | No |
| 4,000 | | 11/26/2012 | Gilbarco-Veeder Root/TLS-350 | | No |

Facility Summary in Cascade County in the City of Malmstrom A F B

Location: MALMSTROM AFB BLDG 500
21 77th St N
Malmstrom A F B, MT 59402-7538 Cascade

Legacy ID:07-08954

Facility ID: 18720
Last Inspected On: 04/06/2021
Operating Permit Renewal Date: 06/08/2024

Owner Operator Contact:

Operator Contact: Candace Ellsworth;Curtis Hester;William Smith **4067316239;4067317128**

Owner/Operator: 341 CES CEANQ

Candace Ellsworth, UST Class A Operator
 Candace Ellsworth, UST Class B Global Operator
 Curtis Hester, UST Class A Operator
 Curtis Hester, UST Class B Global Operator
 David Degolier, UST Class B Operator
 William Smith, UST Class A Operator
 William Smith, UST Class B Global Operator

| Tank Code | Age | Installed | Tank Material Construction | Piping Material | Overfill Types |
|------------------|-----|------------|------------------------------------|------------------------------------|--------------------------------|
| 07 | 21 | 11/22/2000 | Fiberglass Reinforced Plastic | Flexible Plastic | Flapper Valve;High Level Alarm |
| 4227 | No | 05/22/2018 | Double-Walled | Double Walled | Yes |
| Currently in Use | | | Auto Dialer | U.S. Suction | Non-corrodible |
| Diesel | | | Continuous Interstitial Monitoring | Continuous Interstitial Monitoring | No |
| 12,000 | | | Gilbarco-Veeder Root/TLS-350 | | No |

Facility Summary in Cascade County in the City of Malmstrom A F B

Location: MILITARY VEHICLE REFUELING SITE BLDG 448
 7832 Flightline Dr
 Malmstrom A F B, MT 59402-7525 Cascade

Legacy ID:56-14116

Facility ID: 30757
Last Inspected On: 04/06/2021
Operating Permit Renewal Date: 06/08/2024

Owner Operator Contact: Malmstrom A F B **4067316167**

Operator Contact: Candace Ellsworth;Curtis Hester;William Smith **4067316239;4067317128**

Owner/Operator: Malmstrom A F B

Candace Ellsworth, UST Class A Operator
 Candace Ellsworth, UST Class B Global Operator
 Curtis Hester, UST Class A Operator
 Curtis Hester, UST Class B Global Operator
 William Smith, UST Class A Operator
 William Smith, UST Class B Global Operator

| Tank Code | Age | Installed | Tank Material Construction | Piping Material | Overfill Types |
|-----------|-----|-----------|----------------------------|-----------------|----------------|
|-----------|-----|-----------|----------------------------|-----------------|----------------|

| Tag # | AST | Sump Tightness | Secondary Option | Secondary Option | Spill Protected |
|------------------|-----|-----------------------|----------------------------|------------------------------------|------------------|
| Status | | Piping Installed Date | Catastrophic L.D. Type 3.0 | Piping Type | CP Met Types |
| Product | | Tank/Pipe CP | Tank Detection | Primary Pipe Detection | Vapor Recovery |
| Capacity | | Line Tightness | ATG Type | Secondary Pipe Detection | Energy Act |
| S1 | 16 | 06/15/2005 | Concrete | Flexible Plastic | High Level Alarm |
| 4971 | Yes | 05/22/2018 | | Double Walled | Yes |
| Currently in Use | | | Auto Dialer | Pressurized | |
| Biodiesel, <=B20 | | | Deferred | Continuous Interstitial Monitoring | No |
| 60,000 | | | | | No |
| S2 | 16 | 08/05/2005 | Concrete | Flexible Plastic | High Level Alarm |
| 4972 | Yes | 05/22/2018 | | Double Walled | Yes |
| Currently in Use | | | Auto Dialer | Pressurized | |
| Gasoline | | | Deferred | Continuous Interstitial Monitoring | No |
| 20,000 | | | | | No |
| S3 | 16 | 08/05/2005 | Concrete | Flexible Plastic | High Level Alarm |
| 5037 | Yes | 05/22/2018 | | Double Walled | Yes |
| Currently in Use | | | Auto Dialer | Pressurized | |
| Gasoline, E85 | | | Deferred | Continuous Interstitial Monitoring | No |
| 10,000 | | | | | No |

Facility Summary in Cascade County in the City of Malmstrom AFB

Location: AAFES SHOPPING CENTER BLDG 1340
7200 Perimeter Rd
Malmstrom AFB, MT 59402 Cascade

Legacy ID:60-15199

Facility ID: 30920
Last Inspected On: 04/06/2021
Operating Permit Renewal Date: 06/08/2024

Owner Operator Contact: Malmstrom A F B

4067316167

Operator Contact: Ashley Collins;Candace Ellsworth;Famh Kosoff;Fatima Quintanilla;Sonya Coker **4064541301;4067317128;4067618004**

Owner/Operator: Malmstrom A F B

Ashley Collins, UST Class A Operator
 Ashley Collins, UST Class B Global Operator
 Candace Ellsworth, UST Class A Operator
 Candace Ellsworth, UST Class B Global Operator
 Famh Kosoff, UST Class A Operator
 Fatima Quintanilla, UST Class A Operator
 Fatima Quintanilla, UST Class B Operator
 Ken Chorpensing, UST Class B Global Operator
 Sonya Coker, UST Class A Operator
 Sonya Coker, UST Class B Global Operator
 Sonya Coker, UST Class B Operator

| Tank Code | Age | Installed | Tank Material Construction | Piping Material | Overfill Types |
|------------------|-----|-----------------------|---|--|--------------------------------|
| Tag # | AST | Sump Tightness | Secondary Option | Secondary Option | Spill Protected |
| Status | | Piping Installed Date | Catastrophic L.D. Type 3.0 | Piping Type | CP Met Types |
| Product | | Tank/Pipe CP | Tank Detection | Primary Pipe Detection | Vapor Recovery |
| Capacity | | Line Tightness | ATG Type | Secondary Pipe Detection | Energy Act |
| 01 | 10 | 09/01/2011 | Fiberglass Reinforced Plastic | Flexible Plastic | Flapper Valve;High Level Alarm |
| 5329 | No | 05/14/2018 | Double-Walled | Double Walled | Yes |
| Currently in Use | | 08/31/2011 | Electronic Line Leak Detector | Pressurized | Non-corrodible |
| Gasoline | | 06/11/2012 | Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring | Continuous Interstitial Monitoring;ELLD 0.2 | No |
| 15,000 | | | Gilbarco-Veeder Root/TLS- 450;Veeder Root/TLS-450 | | Yes |
| 02 | 10 | 09/01/2011 | Fiberglass Reinforced Plastic | Flexible Plastic | Flapper Valve;High Level Alarm |
| 5330 | No | 05/14/2018 | Double-Walled | Double Walled | Yes |
| Currently in Use | | 08/31/2011 | Electronic Line Leak Detector | Pressurized | Non-corrodible |
| Gasoline | | 06/11/2012 | Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring | Continuous Interstitial Monitoring;ELLD 0.2 | No |
| 20,000 | | | Gilbarco-Veeder Root/TLS- 450;Veeder Root/TLS-450 | | Yes |

Facility Summary in Cascade County in the City of Monarch

Location: COUGAR CANYON LODGE and ESCAPE
5012 US Hwy 89 S
Monarch, MT 59463 Cascade

Legacy ID:07-01874

Facility ID: 18415
Last Inspected On: 07/11/2019
Operating Permit Renewal Date: 07/25/2022

Owner Operator Contact:

Operator Contact: Kurt Gallagher;Richard Hatanpaa

4062365922

Owner/Operator: Mark Properties LLC

Judy McCurdie, UST Class B Operator
Kurt Gallagher, UST Class A Operator
Kurt Gallagher, UST Class B Operator
Richard Hatanpaa, UST Class A Operator
Richard Hatanpaa, UST Class B Operator

| Tank Code | Age | Installed | Tank Material Construction | Piping Material | Overfill Types |
|------------------|-----|-----------------------|--------------------------------------|-------------------------------|-----------------|
| Tag # | AST | Sump Tightness | Secondary Option | Secondary Option | Spill Protected |
| Status | | Piping Installed Date | Catastrophic L.D. Type 3.0 | Piping Type | CP Met Types |
| Product | | Tank/Pipe CP | Tank Detection | Primary Pipe Detection | Vapor Recovery |
| Capacity | | Line Tightness | ATG Type | Secondary Pipe Detection | Energy Act |
| 01 | 29 | 09/01/1992 | Fiberglass Reinforced Plastic | Fiberglass Reinforced Plastic | Flapper Valve |
| 2979 | No | | | None | Yes |
| Currently in Use | | | Mechanical Line Leak Detector | Pressurized | |
| Gasoline | | | Statistical Inventory Reconciliation | MLLD Line Tightness Testing | No |
| 2,000 | | 07/17/2016 | | | No |

Facility Summary in Cascade County in the City of Monarch

Location: MALMSTROM AFB A 5
US Hwy 89
Monarch, MT 59463 Cascade

Legacy ID:07-08979

Facility ID: 18740
Last Inspected On: 05/24/2020
Operating Permit Renewal Date: 09/25/2023

Owner Operator Contact:

Operator Contact: Candace Ellsworth;Curtis Hester;William Smith

4067316239;4067317128

Owner/Operator: 341 CES CEANQ

Candace Ellsworth, UST Class A Operator
Candace Ellsworth, UST Class B Global Operator
Curtis Hester, UST Class A Operator
Curtis Hester, UST Class B Global Operator

William Smith, UST Class A Operator
 William Smith, UST Class B Global Operator

| Tank Code | Age | Installed | Tank Material Construction | Piping Material | Overfill Types |
|------------------|-----|-----------------------|------------------------------------|------------------------------------|--------------------------------|
| Tag # | AST | Sump Tightness | Secondary Option | Secondary Option | Spill Protected |
| Status | | Piping Installed Date | Catastrophic L.D. Type 3.0 | Piping Type | CP Met Types |
| Product | | Tank/Pipe CP | Tank Detection | Primary Pipe Detection | Vapor Recovery |
| Capacity | | Line Tightness | ATG Type | Secondary Pipe Detection | Energy Act |
| 02 | 29 | 06/01/1992 | Fiberglass Reinforced Plastic | Fiberglass Reinforced Plastic | Flapper Valve;High Level Alarm |
| 110 | No | 06/06/2017 | Double-Walled | Double Walled | Yes |
| Currently in Use | | | Auto Dialer | U.S. Suction | Non-corrodible |
| Diesel | | | Continuous Interstitial Monitoring | Continuous Interstitial Monitoring | No |
| 4,000 | | | Gilbarco-Veeder Root/TLS-350 | | No |

Facility Summary in Cascade County in the City of Monarch

Location: MALMSTROM AFB A 6
 US Hwy 89
 Monarch, MT 59463 Cascade

Legacy ID:07-08980

Facility ID: 18741
 Last Inspected On: 05/24/2020
 Operating Permit Renewal Date: 09/25/2023

Owner Operator Contact:

Operator Contact: Candace Ellsworth;Curtis Hester;William Smith **4067316239;4067317128**

Owner/Operator: 341 CES CEANQ

Candace Ellsworth, UST Class A Operator
 Candace Ellsworth, UST Class B Global Operator
 Curtis Hester, UST Class A Operator
 Curtis Hester, UST Class B Global Operator
 William Smith, UST Class A Operator
 William Smith, UST Class B Global Operator

| Tank Code | Age | Installed | Tank Material Construction | Piping Material | Overfill Types |
|-----------|-----|-----------------------|----------------------------|--------------------------|-----------------|
| Tag # | AST | Sump Tightness | Secondary Option | Secondary Option | Spill Protected |
| Status | | Piping Installed Date | Catastrophic L.D. Type 3.0 | Piping Type | CP Met Types |
| Product | | Tank/Pipe CP | Tank Detection | Primary Pipe Detection | Vapor Recovery |
| Capacity | | Line Tightness | ATG Type | Secondary Pipe Detection | Energy Act |

| | | | | | |
|------------------|----|------------|------------------------------------|------------------------------------|--------------------------------|
| 02 | 29 | 06/01/1992 | Fiberglass Reinforced Plastic | Fiberglass Reinforced Plastic | Flapper Valve;High Level Alarm |
| 111 | No | 06/06/2017 | Double-Walled | Double Walled | Yes |
| Currently in Use | | | Auto Dialer | U.S. Suction | Non-corrodible |
| Diesel | | | Continuous Interstitial Monitoring | Continuous Interstitial Monitoring | No |
| 4,000 | | | Gilbarco-Veeder Root/TLS-350 | | No |

Facility Summary in Cascade County in the City of Monarch

Location: MALMSTROM AFB A 7
US Hwy 89
Monarch, MT 59463 Cascade

Legacy ID:07-08981

Facility ID: 18742
Last Inspected On: 05/24/2020
Operating Permit Renewal Date: 10/07/2023

Owner Operator Contact:

Operator Contact: Candace Ellsworth;Curtis Hester;William Smith **4067316239;4067317128**

Owner/Operator: 341 CES CEANQ

- Candace Ellsworth, UST Class A Operator
- Candace Ellsworth, UST Class B Global Operator
- Curtis Hester, UST Class A Operator
- Curtis Hester, UST Class B Global Operator
- William Smith, UST Class A Operator
- William Smith, UST Class B Global Operator

| Tank Code | Age | Installed | Tank Material Construction | Piping Material | Overfill Types |
|------------------|-----|-----------------------|------------------------------------|------------------------------------|--------------------------------|
| Tag # | AST | Sump Tightness | Secondary Option | Secondary Option | Spill Protected |
| Status | | Piping Installed Date | Catastrophic L.D. Type 3.0 | Piping Type | CP Met Types |
| Product | | Tank/Pipe CP | Tank Detection | Primary Pipe Detection | Vapor Recovery |
| Capacity | | Line Tightness | ATG Type | Secondary Pipe Detection | Energy Act |
| 02 | 29 | 06/01/1992 | Fiberglass Reinforced Plastic | Fiberglass Reinforced Plastic | Flapper Valve;High Level Alarm |
| 112 | No | 06/27/2017 | Double-Walled | Double Walled | Yes |
| Currently in Use | | | Auto Dialer | U.S. Suction | Non-corrodible |
| Diesel | | | Continuous Interstitial Monitoring | Continuous Interstitial Monitoring | No |
| 4,000 | | | Gilbarco-Veeder Root/TLS-350 | | No |

Facility Summary in Cascade County in the City of Monarch

Location: MALMSTROM AFB A 8
US Hwy 89
Monarch, MT 59463 Cascade

Legacy ID:07-08982

Facility ID: 18743
Last Inspected On: 05/24/2020
Operating Permit Renewal Date: 09/25/2023

Owner Operator Contact:

Operator Contact: Candace Ellsworth;Curtis Hester;William Smith **4067316239;4067317128**

Owner/Operator: 341 CES CEANQ

Candace Ellsworth, UST Class A Operator
Candace Ellsworth, UST Class B Global Operator
Curtis Hester, UST Class A Operator
Curtis Hester, UST Class B Global Operator
William Smith, UST Class A Operator
William Smith, UST Class B Global Operator

| Tank Code | Age | Installed | Tank Material Construction | Piping Material | Overfill Types |
|------------------|-----|-----------------------|------------------------------------|------------------------------------|--------------------------------|
| Tag # | AST | Sump Tightness | Secondary Option | Secondary Option | Spill Protected |
| Status | | Piping Installed Date | Catastrophic L.D. Type 3.0 | Piping Type | CP Met Types |
| Product | | Tank/Pipe CP | Tank Detection | Primary Pipe Detection | Vapor Recovery |
| Capacity | | Line Tightness | ATG Type | Secondary Pipe Detection | Energy Act |
| 02 | 29 | 06/01/1992 | Fiberglass Reinforced Plastic | Fiberglass Reinforced Plastic | Flapper Valve;High Level Alarm |
| 113 | No | 06/07/2017 | Double-Walled | Double Walled | Yes |
| Currently in Use | | | Auto Dialer | U.S. Suction | Non-corrodible |
| Diesel | | | Continuous Interstitial Monitoring | Continuous Interstitial Monitoring | No |
| 4,000 | | | Gilbarco-Veeder Root/TLS-350 | | No |

Facility Summary in Cascade County in the City of Neihart

Location: BOBS BAR UST
107 Main St
Neihart, MT 59465-0037 Cascade

Legacy ID:07-09274

Facility ID: 18768
Last Inspected On: 04/15/2021
Operating Permit Renewal Date: 05/16/2024

Owner Operator Contact: Smith Bagheri LLC **4062365955**

Operator Contact: Janice Smith-Bagheri **4062365955**

Owner/Operator: Smith Bagheri LLC

Janice Smith-Bagheri, UST Class A Operator
Janice Smith-Bagheri, UST Class B Operator

| Tank Code | Age | Installed | Tank Material Construction | Piping Material | Overfill Types |
|------------------|-----|------------|------------------------------|-------------------------------|----------------|
| 01 | 34 | 02/16/1987 | Cathodically Protected Steel | Fiberglass Reinforced Plastic | Flapper Valve |
| 1455 | No | | | None | Yes |
| Currently in Use | | | Not Required | Safe Suction | Galvanic |
| Gasoline | | 12/22/2017 | Automatic Tank Gauging 0.2 | Deferred | No |
| 1,500 | | | Gilbarco-Veeder Root/ | | No |
| 02 | 34 | 02/16/1987 | Cathodically Protected Steel | Fiberglass Reinforced Plastic | Flapper Valve |
| 1456 | No | | | None | Yes |
| Currently in Use | | | Not Required | Safe Suction | Galvanic |
| Gasoline | | 12/22/2017 | Automatic Tank Gauging 0.2 | Deferred | No |
| 1,500 | | | Gilbarco-Veeder Root/ | | No |

Facility Summary in Cascade County in the City of Simms

Location: CURTISS SERVICE CENTER
12742 MT Hwy 200
Simms, MT 59477 Cascade

Legacy ID:07-01612

Facility ID: 18399
Last Inspected On: 06/03/2020
Operating Permit Renewal Date: 07/30/2023

Owner Operator Contact: Douglas Eisenzimer;Robert D Curtiss

4062645640;4062645746

Operator Contact: Robert D Curtiss

4062645640

Owner/Operator: Robert D Curtiss

Robert D Curtiss, UST Class A Operator
Robert D Curtiss, UST Class B Operator

| Tank Code | Age | Installed | Tank Material Construction | Piping Material | Overfill Types |
|----------------|------------|------------------------------|-----------------------------------|-------------------------------|------------------------|
| Tag # | AST | Sump Tightness | Secondary Option | Secondary Option | Spill Protected |
| Status | | Piping Installed Date | Catastrophic L.D. Type 3.0 | Piping Type | CP Met Types |
| Product | | Tank/Pipe CP | Tank Detection | Primary Pipe Detection | Vapor Recovery |

| Capacity | Line Tightness | ATG Type | Secondary Pipe Detection | Energy Act | |
|------------------|----------------|---|-------------------------------|-------------------------------|---------------|
| 06 | 22 | 11/01/1999 | Fiberglass Reinforced Plastic | Fiberglass Reinforced Plastic | Flapper Valve |
| 4124 | No | | None | Yes | |
| Currently in Use | | Mechanical Line Leak Detector | Pressurized | | |
| Gasoline | | Automatic Tank Gauging 0.2 | MLLD Line Tightness Testing | No | |
| 8,000 | 03/07/2017 | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | No | |
| 07 | 22 | 11/01/1999 | Fiberglass Reinforced Plastic | Fiberglass Reinforced Plastic | Flapper Valve |
| 4125 | No | | None | Yes | |
| Currently in Use | | Mechanical Line Leak Detector | Pressurized | | |
| Diesel | | Automatic Tank Gauging 0.2 | MLLD Line Tightness Testing | No | |
| 8,000 | 03/07/2017 | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | No | |
| 08 | 22 | 11/01/1999 | Fiberglass Reinforced Plastic | Fiberglass Reinforced Plastic | Flapper Valve |
| 4126 | No | | None | Yes | |
| Currently in Use | | Mechanical Line Leak Detector | Pressurized | | |
| Gasoline | | Automatic Tank Gauging 0.2 | MLLD Line Tightness Testing | No | |
| 4,000 | 03/07/2017 | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | No | |
| 09 | 22 | 11/01/1999 | Fiberglass Reinforced Plastic | Fiberglass Reinforced Plastic | Flapper Valve |
| 4127 | No | | None | Yes | |
| Currently in Use | | Mechanical Line Leak Detector | Pressurized | | |
| Diesel | | Automatic Tank Gauging 0.2 | MLLD Line Tightness Testing | No | |
| 4,000 | 03/07/2017 | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | No | |

Facility Summary in Cascade County in the City of Simms

Location: MALMSTROM AFB G 01
MT Hwy 200
Simms, MT 59477 Cascade

Legacy ID:25-09041

Facility ID: 23811
Last Inspected On: 06/14/2021
Operating Permit Renewal Date: 09/22/2024

Owner Operator Contact:

Operator Contact: Candace Ellsworth;Curtis Hester;William Smith

4067316239;4067317128

Owner/Operator: 341 CES CEANQ

Aaron Hill, UST Class B Operator
Allen Brooks, UST Class B Operator
Bethany Kent, UST Class B Operator
Brian Day, UST Class B Operator
Brian McVay, UST Class B Operator
Brian Rayner, UST Class B Operator
Cameron Smith, UST Class B Operator
Candace Ellsworth, UST Class A Operator
Candace Ellsworth, UST Class B Global Operator
Chris Ploof, UST Class B Operator
Curtis Hester, UST Class A Operator
Curtis Hester, UST Class B Global Operator
Damon McCarty, UST Class B Operator
David Cosner, UST Class B Operator
David Degolier, UST Class B Operator
Dustin Hemingway, UST Class B Operator
Glen Beck, UST Class B Operator
Hudson English, UST Class B Operator
Issac Price, UST Class B Operator
James Knudsen, UST Class B Operator
James Wooderchak, UST Class B Operator
Jason Vike, UST Class B Operator
Jeff Laird, UST Class B Operator
Jeff Nelson, UST Class B Operator
Jimmy Sonefeld, UST Class B Operator
John Corbett, UST Class B Operator
Jonathan Buesch, UST Class B Operator
Kieth McIlwain, UST Class B Operator
Kyle Topp, UST Class B Operator
Michael Murieen, UST Class B Operator
Michael Stokes, UST Class B Operator
Patrick Ellis, UST Class B Operator
Patrick Noppenberg, UST Class B Operator
Paul Floyd, UST Class B Global Operator
Paul Floyd, UST Class B Operator

Paul Ziemba, UST Class B Operator
 Ricardo Andrillon, UST Class B Operator
 Ronald Miller, UST Class B Operator
 Ryan Cox, UST Class B Operator
 Ryan Kofoed, UST Class B Operator
 Shane Hofstad, UST Class B Operator
 Shawn Ogrady, UST Class B Operator
 William Hoffmeister, UST Class B Operator
 William Smith, UST Class A Operator
 William Smith, UST Class B Global Operator

| Tank Code | Age | Installed | Tank Material Construction | Piping Material | Overfill Types |
|------------------|-----|-----------------------|---|------------------------------------|--------------------------------|
| Tag # | AST | Sump Tightness | Secondary Option | Secondary Option | Spill Protected |
| Status | | Piping Installed Date | Catastrophic L.D. Type 3.0 | Piping Type | CP Met Types |
| Product | | Tank/Pipe CP | Tank Detection | Primary Pipe Detection | Vapor Recovery |
| Capacity | | Line Tightness | ATG Type | Secondary Pipe Detection | Energy Act |
| 01 | 59 | 06/02/1962 | Cathodically Protected Steel | Flexible Plastic | Flapper Valve;High Level Alarm |
| 250 | No | 04/27/2018 | Lined Interior/Impressed Current | Double Walled | Yes |
| Currently in Use | | | Auto Dialer | U.S. Suction | Impressed Current |
| Diesel | | 04/30/2018 | Automatic Tank Gauging 0.2 | Continuous Interstitial Monitoring | No |
| 12,000 | | | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | No |

Facility Summary in Cascade County in the City of Simms

Location: MALMSTROM AFB G 11
 MT Hwy 200
 Simms, MT 59477 Cascade

Legacy ID:25-09051

Facility ID: 23817
Last Inspected On: 06/14/2021
Operating Permit Renewal Date: 09/22/2024

Owner Operator Contact:

Operator Contact: Candace Ellsworth;Curtis Hester;William Smith **4067316239;4067317128**

Owner/Operator: 341 CES CEANQ

Candace Ellsworth, UST Class A Operator
 Candace Ellsworth, UST Class B Global Operator
 Curtis Hester, UST Class A Operator
 Curtis Hester, UST Class B Global Operator
 William Smith, UST Class A Operator
 William Smith, UST Class B Global Operator

| Tank Code | Age | Installed | Tank Material Construction | Piping Material | Overfill Types |
|------------------|-----|-----------------------|------------------------------------|------------------------------------|--------------------------------|
| Tag # | AST | Sump Tightness | Secondary Option | Secondary Option | Spill Protected |
| Status | | Piping Installed Date | Catastrophic L.D. Type 3.0 | Piping Type | CP Met Types |
| Product | | Tank/Pipe CP | Tank Detection | Primary Pipe Detection | Vapor Recovery |
| Capacity | | Line Tightness | ATG Type | Secondary Pipe Detection | Energy Act |
| 02 | 32 | 05/21/1989 | Fiberglass Reinforced Plastic | Flexible Plastic | Flapper Valve;High Level Alarm |
| 256 | No | 04/27/2018 | Double-Walled | Double Walled | Yes |
| Currently in Use | | | Auto Dialer | U.S. Suction | Non-corrodible |
| Diesel | | | Continuous Interstitial Monitoring | Continuous Interstitial Monitoring | No |
| 4,000 | | | Gilbarco-Veeder Root/TLS-350 | | No |

Facility Summary in Cascade County in the City of Simms

Location: MALMSTROM AFB G 2
MT Hwy 200
Simms, MT 59477 Cascade

Legacy ID:07-09042

Facility ID: 18747
Last Inspected On: 06/14/2021
Operating Permit Renewal Date: 09/22/2024

Owner Operator Contact:

Operator Contact: Candace Ellsworth;Curtis Hester;William Smith **4067316239;4067317128**

Owner/Operator: 341 CES CEANQ

- Candace Ellsworth, UST Class A Operator
- Candace Ellsworth, UST Class B Global Operator
- Curtis Hester, UST Class A Operator
- Curtis Hester, UST Class B Global Operator
- William Smith, UST Class A Operator
- William Smith, UST Class B Global Operator

| Tank Code | Age | Installed | Tank Material Construction | Piping Material | Overfill Types |
|-----------|-----|-----------------------|-------------------------------|-------------------------------|--------------------------------|
| Tag # | AST | Sump Tightness | Secondary Option | Secondary Option | Spill Protected |
| Status | | Piping Installed Date | Catastrophic L.D. Type 3.0 | Piping Type | CP Met Types |
| Product | | Tank/Pipe CP | Tank Detection | Primary Pipe Detection | Vapor Recovery |
| Capacity | | Line Tightness | ATG Type | Secondary Pipe Detection | Energy Act |
| 02 | 29 | 06/01/1992 | Fiberglass Reinforced Plastic | Fiberglass Reinforced Plastic | Flapper Valve;High Level Alarm |

| | | | | | |
|------------------|----|------------|------------------------------------|------------------------------------|----------------|
| 117 | No | 04/27/2018 | Double-Walled | Double Walled | Yes |
| Currently in Use | | | Auto Dialer | U.S. Suction | Non-corrodible |
| Diesel | | | Continuous Interstitial Monitoring | Continuous Interstitial Monitoring | No |
| 4,000 | | | Gilbarco-Veeder Root/TLS-350 | | No |

Facility Summary in Cascade County in the City of Simms

Location: MALMSTROM AFB G 6
Road 287
Simms, MT 59477 Cascade

Legacy ID:25-09046

Facility ID: 23812
Last Inspected On: 06/14/2021
Operating Permit Renewal Date: 09/23/2024

Owner Operator Contact:

Operator Contact: Candace Ellsworth;Curtis Hester;William Smith **4067316239;4067317128**

Owner/Operator: 341 CES CEANQ

- Candace Ellsworth, UST Class A Operator
- Candace Ellsworth, UST Class B Global Operator
- Curtis Hester, UST Class A Operator
- Curtis Hester, UST Class B Global Operator
- William Smith, UST Class A Operator
- William Smith, UST Class B Global Operator

| Tank Code | Age | Installed | Tank Material Construction | Piping Material | Overfill Types |
|------------------|-----|-----------------------|------------------------------------|------------------------------------|--------------------------------|
| Tag # | AST | Sump Tightness | Secondary Option | Secondary Option | Spill Protected |
| Status | | Piping Installed Date | Catastrophic L.D. Type 3.0 | Piping Type | CP Met Types |
| Product | | Tank/Pipe CP | Tank Detection | Primary Pipe Detection | Vapor Recovery |
| Capacity | | Line Tightness | ATG Type | Secondary Pipe Detection | Energy Act |
| 02 | 29 | 05/01/1992 | Fiberglass Reinforced Plastic | Fiberglass Reinforced Plastic | Flapper Valve;High Level Alarm |
| 251 | No | 04/26/2018 | Double-Walled | Double Walled | Yes |
| Currently in Use | | | Auto Dialer | U.S. Suction | Non-corrodible |
| Diesel | | | Continuous Interstitial Monitoring | Continuous Interstitial Monitoring | No |
| 4,000 | | | Gilbarco-Veeder Root/TLS-350 | | No |

Facility Summary in Cascade County in the City of Simms

Location: MALMSTROM AFB G 7
MT Hwy 200
Simms, MT 59477 Cascade

Legacy ID:25-09047

Facility ID: 23813
Last Inspected On: 06/14/2021
Operating Permit Renewal Date: 09/22/2024

Owner Operator Contact:

Operator Contact: Candace Ellsworth;Curtis Hester;William Smith

4067316239;4067317128

Owner/Operator: 341 CES CEANQ

Candace Ellsworth, UST Class A Operator
Candace Ellsworth, UST Class B Global Operator
Curtis Hester, UST Class A Operator
Curtis Hester, UST Class B Global Operator
William Smith, UST Class A Operator
William Smith, UST Class B Global Operator

| Tank Code | Age | Installed | Tank Material Construction | Piping Material | Overfill Types |
|------------------|-----|-----------------------|------------------------------------|------------------------------------|--------------------------------|
| Tag # | AST | Sump Tightness | Secondary Option | Secondary Option | Spill Protected |
| Status | | Piping Installed Date | Catastrophic L.D. Type 3.0 | Piping Type | CP Met Types |
| Product | | Tank/Pipe CP | Tank Detection | Primary Pipe Detection | Vapor Recovery |
| Capacity | | Line Tightness | ATG Type | Secondary Pipe Detection | Energy Act |
| 02 | 29 | 05/01/1992 | Fiberglass Reinforced Plastic | Fiberglass Reinforced Plastic | Flapper Valve;High Level Alarm |
| 4271 | No | 04/26/2018 | Double-Walled | Double Walled | Yes |
| Currently in Use | | | Auto Dialer | U.S. Suction | Non-corrodible |
| Diesel | | | Continuous Interstitial Monitoring | Continuous Interstitial Monitoring | No |
| 4,000 | | | Gilbarco-Veeder Root/TLS-350 | | No |

Facility Summary in Cascade County in the City of Simms

Location: MALMSTROM AFB G 8
MT Hwy 200
Simms, MT 59477 Cascade

Legacy ID:25-09048

Facility ID: 23814
Last Inspected On: 06/14/2021
Operating Permit Renewal Date: 09/22/2024

Owner Operator Contact:

Operator Contact: Candace Ellsworth;Curtis Hester;William Smith

4067316239;4067317128

Owner/Operator: 341 CES CEANQ

Candace Ellsworth, UST Class A Operator
Candace Ellsworth, UST Class B Global Operator
Curtis Hester, UST Class A Operator

Curtis Hester, UST Class B Global Operator
 William Smith, UST Class A Operator
 William Smith, UST Class B Global Operator

| Tank Code | Age | Installed | Tank Material Construction | Piping Material | Overfill Types |
|------------------|-----|-----------------------|------------------------------------|------------------------------------|--------------------------------|
| Tag # | AST | Sump Tightness | Secondary Option | Secondary Option | Spill Protected |
| Status | | Piping Installed Date | Catastrophic L.D. Type 3.0 | Piping Type | CP Met Types |
| Product | | Tank/Pipe CP | Tank Detection | Primary Pipe Detection | Vapor Recovery |
| Capacity | | Line Tightness | ATG Type | Secondary Pipe Detection | Energy Act |
| 02 | 29 | 05/01/1992 | Fiberglass Reinforced Plastic | Fiberglass Reinforced Plastic | Flapper Valve;High Level Alarm |
| 253 | No | 04/26/2018 | Double-Walled | Double Walled | Yes |
| Currently in Use | | | Auto Dialer | U.S. Suction | Non-corrodible |
| Diesel | | | Continuous Interstitial Monitoring | Continuous Interstitial Monitoring | No |
| 4,000 | | | Gilbarco-Veeder Root/TLS-350 | | No |

Facility Summary in Cascade County in the City of Simms

Location: MALMSTROM AFB H 7
 MT Hwy 200
 Simms, MT 59477 Cascade

Legacy ID:07-09058

Facility ID: 18754
Last Inspected On: 06/07/2021
Operating Permit Renewal Date: 09/22/2024

Owner Operator Contact:

Operator Contact: Candace Ellsworth;Curtis Hester;William Smith **4067316239;4067317128**

Owner/Operator: 341 CES CEANQ

Candace Ellsworth, UST Class A Operator
 Candace Ellsworth, UST Class B Global Operator
 Curtis Hester, UST Class A Operator
 Curtis Hester, UST Class B Global Operator
 William Smith, UST Class A Operator
 William Smith, UST Class B Global Operator

| Tank Code | Age | Installed | Tank Material Construction | Piping Material | Overfill Types |
|-----------|-----|-----------------------|----------------------------|------------------------|-----------------|
| Tag # | AST | Sump Tightness | Secondary Option | Secondary Option | Spill Protected |
| Status | | Piping Installed Date | Catastrophic L.D. Type 3.0 | Piping Type | CP Met Types |
| Product | | Tank/Pipe CP | Tank Detection | Primary Pipe Detection | Vapor Recovery |

| Capacity | Line Tightness | ATG Type | Secondary Pipe Detection | Energy Act | |
|------------------|----------------|------------------------------------|------------------------------------|-------------------------------|--------------------------------|
| 02 | 30 | 09/01/1991 | Fiberglass Reinforced Plastic | Fiberglass Reinforced Plastic | Flapper Valve;High Level Alarm |
| 124 | No | 05/17/2018 | Double-Walled | Double Walled | Yes |
| Currently in Use | | Auto Dialer | U.S. Suction | Non-corrodible | |
| Diesel | | Continuous Interstitial Monitoring | Continuous Interstitial Monitoring | No | |
| 4,000 | | Gilbarco-Veeder Root/TLS-350 | | No | |

Facility Summary in Cascade County in the City of Simms

Location: MALMSTROM AFB H 8
 MT Hwy 21
 Simms, MT 59477 Cascade

Legacy ID:25-09059

Facility ID: 23818
 Last Inspected On: 06/07/2021
 Operating Permit Renewal Date: 09/22/2024

Owner Operator Contact:

Operator Contact: Candace Ellsworth;Curtis Hester;William Smith **4067316239;4067317128**

Owner/Operator: 341 CES CEANQ

- Candace Ellsworth, UST Class A Operator
- Candace Ellsworth, UST Class B Global Operator
- Curtis Hester, UST Class A Operator
- Curtis Hester, UST Class B Global Operator
- William Smith, UST Class A Operator
- William Smith, UST Class B Global Operator

| Tank Code | Age | Installed | Tank Material Construction | Piping Material | Overfill Types |
|------------------|----------------|------------------------------------|------------------------------------|-------------------------------|--------------------------------|
| Tag # | AST | Sump Tightness | Secondary Option | Secondary Option | Spill Protected |
| Status | | Piping Installed Date | Catastrophic L.D. Type 3.0 | Piping Type | CP Met Types |
| Product | | Tank/Pipe CP | Tank Detection | Primary Pipe Detection | Vapor Recovery |
| Capacity | Line Tightness | ATG Type | Secondary Pipe Detection | Energy Act | |
| 02 | 30 | 09/01/1991 | Fiberglass Reinforced Plastic | Fiberglass Reinforced Plastic | Flapper Valve;High Level Alarm |
| 257 | No | 05/17/2018 | Double-Walled | Double Walled | Yes |
| Currently in Use | | Auto Dialer | U.S. Suction | Non-corrodible | |
| Diesel | | Continuous Interstitial Monitoring | Continuous Interstitial Monitoring | No | |
| 4,000 | | Gilbarco-Veeder Root/TLS-350 | | No | |

Facility Summary in Cascade County in the City of Stockett

Location: MALMSTROM AFB A 9
Road 227
Stockett, MT 59480 Cascade

Legacy ID:07-08983

Facility ID: 18744
Last Inspected On: 05/24/2020
Operating Permit Renewal Date: 09/25/2023

Owner Operator Contact:

Operator Contact: Candace Ellsworth;Curtis Hester;William Smith **4067316239;4067317128**

Owner/Operator: 341 CES CEANQ

Candace Ellsworth, UST Class A Operator
Candace Ellsworth, UST Class B Global Operator
Curtis Hester, UST Class A Operator
Curtis Hester, UST Class B Global Operator
William Smith, UST Class A Operator
William Smith, UST Class B Global Operator

| Tank Code | Age | Installed | Tank Material Construction | Piping Material | Overfill Types |
|------------------|-----|-----------------------|------------------------------------|------------------------------------|--------------------------------|
| Tag # | AST | Sump Tightness | Secondary Option | Secondary Option | Spill Protected |
| Status | | Piping Installed Date | Catastrophic L.D. Type 3.0 | Piping Type | CP Met Types |
| Product | | Tank/Pipe CP | Tank Detection | Primary Pipe Detection | Vapor Recovery |
| Capacity | | Line Tightness | ATG Type | Secondary Pipe Detection | Energy Act |
| 02 | 29 | 05/01/1992 | Fiberglass Reinforced Plastic | Fiberglass Reinforced Plastic | Flapper Valve;High Level Alarm |
| 114 | No | 06/07/2017 | Double-Walled | Double Walled | Yes |
| Currently in Use | | | Auto Dialer | U.S. Suction | Non-corrodible |
| Diesel | | | Continuous Interstitial Monitoring | Continuous Interstitial Monitoring | No |
| 4,000 | | | Gilbarco-Veeder Root/TLS-350 | | No |

Facility Summary in Cascade County in the City of Stockett

Location: MALMSTROM AFB I 2
Road 226
Stockett, MT 59480 Cascade

Legacy ID:07-09064

Facility ID: 18756
Last Inspected On: 06/11/2021
Operating Permit Renewal Date: 09/22/2024

Owner Operator Contact:

Operator Contact: Candace Ellsworth;Curtis Hester;William Smith **4067316239;4067317128**

Owner/Operator: 341 CES CEANQ

Candace Ellsworth, UST Class A Operator

Candace Ellsworth, UST Class B Global Operator
 Curtis Hester, UST Class A Operator
 Curtis Hester, UST Class B Global Operator
 William Smith, UST Class A Operator
 William Smith, UST Class B Global Operator

| Tank Code | Age | Installed | Tank Material Construction | Piping Material | Overfill Types |
|------------------|-----|-----------------------|------------------------------------|------------------------------------|--------------------------------|
| Tag # | AST | Sump Tightness | Secondary Option | Secondary Option | Spill Protected |
| Status | | Piping Installed Date | Catastrophic L.D. Type 3.0 | Piping Type | CP Met Types |
| Product | | Tank/Pipe CP | Tank Detection | Primary Pipe Detection | Vapor Recovery |
| Capacity | | Line Tightness | ATG Type | Secondary Pipe Detection | Energy Act |
| 02 | 30 | 10/01/1991 | Fiberglass Reinforced Plastic | Fiberglass Reinforced Plastic | Flapper Valve;High Level Alarm |
| 126 | No | 04/23/2018 | Double-Walled | Double Walled | Yes |
| Currently in Use | | | Auto Dialer | U.S. Suction | Non-corrodible |
| Diesel | | | Continuous Interstitial Monitoring | Continuous Interstitial Monitoring | No |
| 4,000 | | | Gilbarco-Veeder Root/TLS-350 | | No |

Facility Summary in Cascade County in the City of Sun River

Location: MALMSTROM AFB H 4
 US Hwy 89
 Sun River, MT 59483 Cascade

Legacy ID:07-09055

Facility ID: 18751
Last Inspected On: 06/07/2021
Operating Permit Renewal Date: 09/22/2024

Owner Operator Contact:

Operator Contact: Candace Ellsworth;Curtis Hester;William Smith **4067316239;4067317128**

Owner/Operator: 341 CES CEANQ

Candace Ellsworth, UST Class A Operator
 Candace Ellsworth, UST Class B Global Operator
 Curtis Hester, UST Class A Operator
 Curtis Hester, UST Class B Global Operator
 William Smith, UST Class A Operator
 William Smith, UST Class B Global Operator

| Tank Code | Age | Installed | Tank Material Construction | Piping Material | Overfill Types |
|-----------|-----|-----------------------|----------------------------|------------------|-----------------|
| Tag # | AST | Sump Tightness | Secondary Option | Secondary Option | Spill Protected |
| Status | | Piping Installed Date | Catastrophic L.D. Type 3.0 | Piping Type | CP Met Types |

| Product | Tank/Pipe CP | Tank Detection | Primary Pipe Detection | Vapor Recovery | |
|------------------|----------------|------------------------------------|------------------------------------|------------------|--------------------------------|
| Capacity | Line Tightness | ATG Type | Secondary Pipe Detection | Energy Act | |
| 02 | 30 | 09/01/1991 | Fiberglass Reinforced Plastic | Flexible Plastic | Flapper Valve;High Level Alarm |
| 121 | No | 05/16/2018 | Double-Walled | Double Walled | Yes |
| Currently in Use | 04/20/2015 | Auto Dialer | U.S. Suction | Non-corrodible | |
| Diesel | | Continuous Interstitial Monitoring | Continuous Interstitial Monitoring | No | |
| 4,000 | 04/17/2015 | Gilbarco-Veeder Root/TLS-350 | | No | |

Facility Summary in Cascade County in the City of Sun River

Location: MALMSTROM AFB H 5
 US Hwy 89
 Sun River, MT 59483 Cascade

Legacy ID:07-09056

Facility ID: 18752
Last Inspected On: 06/07/2021
Operating Permit Renewal Date: 09/22/2024

Owner Operator Contact:

Operator Contact: Candace Ellsworth;Curtis Hester;William Smith **4067316239;4067317128**

Owner/Operator: 341 CES CEANQ

- Candace Ellsworth, UST Class A Operator
- Candace Ellsworth, UST Class B Global Operator
- Curtis Hester, UST Class A Operator
- Curtis Hester, UST Class B Global Operator
- William Smith, UST Class A Operator
- William Smith, UST Class B Global Operator

| Tank Code | Age | Installed | Tank Material Construction | Piping Material | Overfill Types |
|------------------|----------------|------------------------------------|------------------------------------|------------------|--------------------------------|
| Tag # | AST | Sump Tightness | Secondary Option | Secondary Option | Spill Protected |
| Status | | Piping Installed Date | Catastrophic L.D. Type 3.0 | Piping Type | CP Met Types |
| Product | Tank/Pipe CP | Tank Detection | Primary Pipe Detection | Vapor Recovery | |
| Capacity | Line Tightness | ATG Type | Secondary Pipe Detection | Energy Act | |
| 02 | 30 | 09/01/1991 | Fiberglass Reinforced Plastic | Flexible Plastic | Flapper Valve;High Level Alarm |
| 122 | No | 05/16/2018 | Double-Walled | Double Walled | Yes |
| Currently in Use | 05/18/2015 | Auto Dialer | U.S. Suction | Non-corrodible | |
| Diesel | | Continuous Interstitial Monitoring | Continuous Interstitial Monitoring | No | |

4,000

Gilbarco-Veeder Root/TLS-350

No

Facility Summary in Cascade County in the City of Ulm

Location: MALMSTROM AFB I 11
I-15
Ulm, MT 59485 Cascade

Legacy ID:07-09073

Facility ID: 18765
Last Inspected On: 06/11/2021
Operating Permit Renewal Date: 09/22/2024

Owner Operator Contact:

Operator Contact: Candace Ellsworth;Curtis Hester;William Smith **4067316239;4067317128**

Owner/Operator: 341 CES CEANQ

- Candace Ellsworth, UST Class A Operator
- Candace Ellsworth, UST Class B Global Operator
- Curtis Hester, UST Class A Operator
- Curtis Hester, UST Class B Global Operator
- William Smith, UST Class A Operator
- William Smith, UST Class B Global Operator

| Tank Code | Age | Installed | Tank Material Construction | Piping Material | Overfill Types |
|------------------|-----|-----------------------|------------------------------------|------------------------------------|--------------------------------|
| Tag # | AST | Sump Tightness | Secondary Option | Secondary Option | Spill Protected |
| Status | | Piping Installed Date | Catastrophic L.D. Type 3.0 | Piping Type | CP Met Types |
| Product | | Tank/Pipe CP | Tank Detection | Primary Pipe Detection | Vapor Recovery |
| Capacity | | Line Tightness | ATG Type | Secondary Pipe Detection | Energy Act |
| 02 | 30 | 10/01/1991 | Fiberglass Reinforced Plastic | Fiberglass Reinforced Plastic | Flapper Valve;High Level Alarm |
| 134 | No | 04/24/2018 | Double-Walled | Double Walled | Yes |
| Currently in Use | | | Auto Dialer | U.S. Suction | Non-corrodible |
| Diesel | | | Continuous Interstitial Monitoring | Continuous Interstitial Monitoring | No |
| 4,000 | | | Gilbarco-Veeder Root/TLS-350 | | No |

Facility Summary in Cascade County in the City of Ulm

Location: MALMSTROM AFB I 7
I-15
Ulm, MT 59485 Cascade

Legacy ID:07-09069

Facility ID: 18761
Last Inspected On: 06/11/2021
Operating Permit Renewal Date: 09/22/2024

Owner Operator Contact:

Operator Contact: Candace Ellsworth;Curtis Hester;William Smith **4067316239;4067317128**

Owner/Operator: 341 CES CEANQ

Candace Ellsworth, UST Class A Operator
 Candace Ellsworth, UST Class B Global Operator
 Curtis Hester, UST Class A Operator
 Curtis Hester, UST Class B Global Operator
 William Smith, UST Class A Operator
 William Smith, UST Class B Global Operator

| Tank Code | Age | Installed | Tank Material Construction | Piping Material | Overfill Types |
|------------------|-----|-----------------------|------------------------------------|------------------------------------|--------------------------------|
| Tag # | AST | Sump Tightness | Secondary Option | Secondary Option | Spill Protected |
| Status | | Piping Installed Date | Catastrophic L.D. Type 3.0 | Piping Type | CP Met Types |
| Product | | Tank/Pipe CP | Tank Detection | Primary Pipe Detection | Vapor Recovery |
| Capacity | | Line Tightness | ATG Type | Secondary Pipe Detection | Energy Act |
| 02 | 29 | 05/01/1992 | Fiberglass Reinforced Plastic | Fiberglass Reinforced Plastic | Flapper Valve;High Level Alarm |
| 131 | No | 04/24/2018 | Double-Walled | Double Walled | Yes |
| Currently in Use | | | Auto Dialer | U.S. Suction | Non-corrodible |
| Diesel | | | Continuous Interstitial Monitoring | Continuous Interstitial Monitoring | No |
| 4,000 | | | Gilbarco-Veeder Root/TLS-350 | | No |

Facility Summary in Cascade County in the City of Ulm

Location: MOUNTAIN VIEW CO OP
 2 Millegan Rd
 Ulm, MT 59485 Cascade

Legacy ID:56-13797

Facility ID: 30484
Last Inspected On: 09/22/2020
Operating Permit Renewal Date: 11/14/2023

Owner Operator Contact: Mountain View Coop Black Eagle

4064535900

Operator Contact: Charles Niswanger;David Douglas;Robin Niswanger

4068662030

Owner/Operator: Mountain View Coop Black Eagle

Charles Niswanger, UST Class A Operator
 Charles Niswanger, UST Class B Operator
 David Douglas, UST Class A Operator
 Jasmin Nguyen, UST Class B Global Operator
 Jasmin Nguyen, UST Class B Operator
 John Malley, UST Class B Operator
 Paul Obrien, UST Class B Operator
 Robin Niswanger, UST Class A Operator
 Scott Bartlett, UST Class B Operator

| Tank Code | Age | Installed | Tank Material Construction | Piping Material | Overfill Types |
|------------------|-----|-----------------------|---|-------------------------------|------------------|
| Tag # | AST | Sump Tightness | Secondary Option | Secondary Option | Spill Protected |
| Status | | Piping Installed Date | Catastrophic L.D. Type 3.0 | Piping Type | CP Met Types |
| Product | | Tank/Pipe CP | Tank Detection | Primary Pipe Detection | Vapor Recovery |
| Capacity | | Line Tightness | ATG Type | Secondary Pipe Detection | Energy Act |
| 01 | 24 | 10/01/1997 | Fiberglass Reinforced Plastic | Fiberglass Reinforced Plastic | High Level Alarm |
| 4428 | No | | | None | Yes |
| Currently in Use | | | Electronic Line Leak Detector | Pressurized | Non-corrodible |
| Gasoline | | | Automatic Tank Gauging 0.2 | ELLD 0.1;ELLD 0.2 | No |
| 6,000 | | 11/26/2016 | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | No |
| 02 | 24 | 10/01/1997 | Fiberglass Reinforced Plastic | Fiberglass Reinforced Plastic | High Level Alarm |
| 4429 | No | | | None | Yes |
| Currently in Use | | | Electronic Line Leak Detector | Pressurized | Non-corrodible |
| Diesel | | | Automatic Tank Gauging 0.2 | ELLD 0.1;ELLD 0.2 | No |
| 6,000 | | 05/14/2017 | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | No |
| 03 | 24 | 10/01/1997 | Fiberglass Reinforced Plastic | Fiberglass Reinforced Plastic | High Level Alarm |
| 4430 | No | | | None | Yes |
| Currently in Use | | | Electronic Line Leak Detector | Pressurized | Non-corrodible |
| Gasoline | | | Automatic Tank Gauging 0.2 | ELLD 0.1;ELLD 0.2 | No |
| 10,000 | | 05/14/2017 | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | No |

Facility Summary in Cascade County in the City of Vaughn

Location: GLACIER GATEWAY
99 US Hwy 89
Vaughn, MT 59487 Cascade

Legacy ID:56-13783

Facility ID: 30471
Last Inspected On: 04/02/2021
Operating Permit Renewal Date: 04/09/2024

Owner Operator Contact:

Operator Contact: Eric Bucher;Jake Neil;Kay Neil;Kevin Enochs;Kevin Francis **4068362087**

Owner/Operator: NCI Tech Company LLC Vaughn

Aaron McConnell, UST Class B Operator
 Allicia Wick, UST Class B Operator
 Amy Evans, UST Class B Operator
 Andrea Bowie, UST Class B Operator
 Barbara Matthews, UST Class B Operator
 Brenda Pischke, UST Class B Global Operator
 Bridget Bowen, UST Class B Operator
 Christine Igel, UST Class B Operator
 Debbie Pengilly, UST Class B Operator
 Eric Bucher, UST Class A Operator
 Helen Taylor, UST Class B Global Operator
 Jake Neil, UST Class A Operator
 Jake Neil, UST Class B Operator
 Janet Jensen, UST Class B Operator
 Jenifer Colden, UST Class B Operator
 Jenna Blair, UST Class B Operator
 Josh Wick, UST Class B Operator
 Justin Vallier, UST Class B Operator
 Kay Neil, UST Class A Operator
 Kay Neil, UST Class B Operator
 Kevin Enochs, UST Class A Operator
 Kevin Francis, UST Class A Operator
 Leigh Wilson, UST Class B Operator
 Marilyn Hutton, UST Class B Global Operator
 Matthew Schnittgen, UST Class B Operator
 Roy Powell, UST Class B Operator
 Shalina Abrams, UST Class B Operator
 Vicki Ferda, UST Class B Operator
 Vicki Kriedeman, UST Class B Operator

| Tank Code | Age | Installed | Tank Material Construction | Piping Material | Overfill Types |
|-----------|-----|-----------------------|----------------------------|--------------------------|-----------------|
| Tag # | AST | Sump Tightness | Secondary Option | Secondary Option | Spill Protected |
| Status | | Piping Installed Date | Catastrophic L.D. Type 3.0 | Piping Type | CP Met Types |
| Product | | Tank/Pipe CP | Tank Detection | Primary Pipe Detection | Vapor Recovery |
| Capacity | | Line Tightness | ATG Type | Secondary Pipe Detection | Energy Act |

| | | | | | |
|----|----|------------|-------------------------------|------------------|------------------|
| 01 | 24 | 06/01/1997 | Fiberglass Reinforced Plastic | Flexible Plastic | High Level Alarm |
|----|----|------------|-------------------------------|------------------|------------------|

| | | | | | |
|------------------|----|------------|-------------------------------|------------------|------------------|
| 3444 | No | | | Double Walled | Yes |
| Currently in Use | | | Electronic Line Leak Detector | Pressurized | Non-corrodible |
| Gasoline | | | Automatic Tank Gauging 0.2 | ELLD 0.2 | No |
| 12,000 | | | Veeder Root/TLS-300 | | No |
| 02 | 24 | 06/01/1997 | Fiberglass Reinforced Plastic | Flexible Plastic | High Level Alarm |
| 3445 | No | | | Double Walled | Yes |
| Currently in Use | | | Electronic Line Leak Detector | Pressurized | Non-corrodible |
| Diesel | | | Automatic Tank Gauging 0.2 | ELLD 0.2 | No |
| 12,000 | | | Veeder Root/TLS-300 | | No |
| 03 | 24 | 06/01/1997 | Fiberglass Reinforced Plastic | Flexible Plastic | High Level Alarm |
| 3446 | No | | | Double Walled | Yes |
| Currently in Use | | | Electronic Line Leak Detector | Pressurized | Non-corrodible |
| Gasoline | | | Automatic Tank Gauging 0.2 | ELLD 0.2 | No |
| 6,000 | | | Veeder Root/TLS-300 | | No |
| 04 | 24 | 06/01/1997 | Fiberglass Reinforced Plastic | Flexible Plastic | High Level Alarm |
| 3447 | No | | | Double Walled | Yes |
| Currently in Use | | | Electronic Line Leak Detector | Pressurized | Non-corrodible |
| Diesel, Dyed | | | Automatic Tank Gauging 0.2 | ELLD 0.2 | No |
| 6,000 | | | Veeder Root/TLS-300 | | No |

Facility Summary in Cascade County in the City of Vaughn

Location: MALMSTROM AFB H 3
I-15
Vaughn, MT 59487 Cascade

Legacy ID:50-09054

Facility ID: 28887
Last Inspected On: 06/07/2021
Operating Permit Renewal Date: 09/23/2024

Owner Operator Contact:

Operator Contact: Candace Ellsworth;Curtis Hester;William Smith **4067316239;4067317128**

Owner/Operator: 341 CES CEANQ

Candace Ellsworth, UST Class A Operator
Candace Ellsworth, UST Class B Global Operator
Curtis Hester, UST Class A Operator
Curtis Hester, UST Class B Global Operator
William Smith, UST Class A Operator
William Smith, UST Class B Global Operator

| Tank Code | Age | Installed | Tank Material Construction | Piping Material | Overfill Types |
|------------------|-----|-----------------------|------------------------------------|------------------------------------|--------------------------------|
| Tag # | AST | Sump Tightness | Secondary Option | Secondary Option | Spill Protected |
| Status | | Piping Installed Date | Catastrophic L.D. Type 3.0 | Piping Type | CP Met Types |
| Product | | Tank/Pipe CP | Tank Detection | Primary Pipe Detection | Vapor Recovery |
| Capacity | | Line Tightness | ATG Type | Secondary Pipe Detection | Energy Act |
| 02 | 30 | 09/01/1991 | Fiberglass Reinforced Plastic | Fiberglass Reinforced Plastic | Flapper Valve;High Level Alarm |
| 313 | No | 05/16/2018 | Double-Walled | Double Walled | Yes |
| Currently in Use | | | Auto Dialer | U.S. Suction | Non-corrodible |
| Diesel | | | Continuous Interstitial Monitoring | Continuous Interstitial Monitoring | No |
| 4,000 | | | Gilbarco-Veeder Root/TLS-350 | | No |

Facility Summary in Cascade County in the City of Vaughn

Location: MALMSTROM AFB I 10
I-15
Vaughn, MT 59487 Cascade

Legacy ID:07-09072

Facility ID: 18764
Last Inspected On: 06/11/2021
Operating Permit Renewal Date: 09/22/2024

Owner Operator Contact:

Operator Contact: Candace Ellsworth;Curtis Hester;William Smith **4067316239;4067317128**

Owner/Operator: 341 CES CEANQ

Candace Ellsworth, UST Class A Operator

Candace Ellsworth, UST Class B Global Operator
 Curtis Hester, UST Class A Operator
 Curtis Hester, UST Class B Global Operator
 William Smith, UST Class A Operator
 William Smith, UST Class B Global Operator

| Tank Code | Age | Installed | Tank Material Construction | Piping Material | Overfill Types |
|------------------|-----|-----------------------|------------------------------------|------------------------------------|--------------------------------|
| Tag # | AST | Sump Tightness | Secondary Option | Secondary Option | Spill Protected |
| Status | | Piping Installed Date | Catastrophic L.D. Type 3.0 | Piping Type | CP Met Types |
| Product | | Tank/Pipe CP | Tank Detection | Primary Pipe Detection | Vapor Recovery |
| Capacity | | Line Tightness | ATG Type | Secondary Pipe Detection | Energy Act |
| 02 | 30 | 08/01/1991 | Fiberglass Reinforced Plastic | Fiberglass Reinforced Plastic | Flapper Valve;High Level Alarm |
| 133 | No | 04/24/2018 | Double-Walled | Double Walled | Yes |
| Currently in Use | | | Auto Dialer | U.S. Suction | Non-corrodible |
| Diesel | | | Continuous Interstitial Monitoring | Continuous Interstitial Monitoring | No |
| 4,000 | | | Gilbarco-Veeder Root/TLS-350 | | No |

Facility Summary in Cascade County in the City of Vaughn

Location: MALMSTROM AFB J 10
 I-15
 Vaughn, MT 59487 Cascade

Legacy ID:50-09083

Facility ID: 28893
Last Inspected On: 06/07/2021
Operating Permit Renewal Date: 09/22/2024

Owner Operator Contact:

Operator Contact: Candace Ellsworth;Curtis Hester;William Smith **4067316239;4067317128**

Owner/Operator: 341 CES CEANQ

Candace Ellsworth, UST Class A Operator
 Candace Ellsworth, UST Class B Global Operator
 Curtis Hester, UST Class A Operator
 Curtis Hester, UST Class B Global Operator
 William Smith, UST Class A Operator
 William Smith, UST Class B Global Operator

| Tank Code | Age | Installed | Tank Material Construction | Piping Material | Overfill Types |
|-----------|-----|-----------------------|----------------------------|------------------|-----------------|
| Tag # | AST | Sump Tightness | Secondary Option | Secondary Option | Spill Protected |
| Status | | Piping Installed Date | Catastrophic L.D. Type 3.0 | Piping Type | CP Met Types |

| Product | Tank/Pipe CP | Tank Detection | Primary Pipe Detection | Vapor Recovery | |
|------------------|----------------|------------------------------------|------------------------------------|------------------|--------------------------------|
| Capacity | Line Tightness | ATG Type | Secondary Pipe Detection | Energy Act | |
| 02 | 30 | 08/01/1991 | Fiberglass Reinforced Plastic | Flexible Plastic | Flapper Valve;High Level Alarm |
| 319 | No | 05/15/2018 | Double-Walled | Double Walled | Yes |
| Currently in Use | 06/02/2015 | Auto Dialer | U.S. Suction | Non-corrodible | |
| Diesel | | Continuous Interstitial Monitoring | Continuous Interstitial Monitoring | No | |
| 4,000 | 05/29/2015 | Gilbarco-Veeder Root/TLS-350 | | No | |

Facility Summary in Cascade County in the City of Vaughn

Location: MALMSTROM AFB J 8
I-15
Vaughn, MT 59487 Cascade

Legacy ID:07-09081

Facility ID: 18766
Last Inspected On: 06/07/2021
Operating Permit Renewal Date: 09/22/2024

Owner Operator Contact:

Operator Contact: Candace Ellsworth;Curtis Hester;William Smith **4067316239;4067317128**

Owner/Operator: 341 CES CEANQ

- Candace Ellsworth, UST Class A Operator
- Candace Ellsworth, UST Class B Global Operator
- Curtis Hester, UST Class A Operator
- Curtis Hester, UST Class B Global Operator
- William Smith, UST Class A Operator
- William Smith, UST Class B Global Operator

| Tank Code | Age | Installed | Tank Material Construction | Piping Material | Overfill Types |
|------------------|----------------|------------------------------------|------------------------------------|------------------|--------------------------------|
| Tag # | AST | Sump Tightness | Secondary Option | Secondary Option | Spill Protected |
| Status | | Piping Installed Date | Catastrophic L.D. Type 3.0 | Piping Type | CP Met Types |
| Product | Tank/Pipe CP | Tank Detection | Primary Pipe Detection | Vapor Recovery | |
| Capacity | Line Tightness | ATG Type | Secondary Pipe Detection | Energy Act | |
| 02 | 30 | 08/01/1991 | Fiberglass Reinforced Plastic | Flexible Plastic | Flapper Valve;High Level Alarm |
| 135 | No | 08/11/2018 | Double-Walled | Double Walled | Yes |
| Currently in Use | 08/11/2018 | Auto Dialer | U.S. Suction | Non-corrodible | |
| Diesel | | Continuous Interstitial Monitoring | Continuous Interstitial Monitoring | No | |

4,000

Gilbarco-Veeder Root/TLS-350

No

Facility Summary in Cascade County in the City of Vaughn

Location: MALMSTROM AFB J 9
I-15
Vaughn, MT 59487 Cascade

Legacy ID:07-09082

Facility ID: 18767
Last Inspected On: 06/07/2021
Operating Permit Renewal Date: 06/17/2024

Owner Operator Contact:

Operator Contact: Candace Ellsworth;Curtis Hester;William Smith **4067316239;4067317128**

Owner/Operator: 341 CES CEANQ

- Candace Ellsworth, UST Class A Operator
- Candace Ellsworth, UST Class B Global Operator
- Curtis Hester, UST Class A Operator
- Curtis Hester, UST Class B Global Operator
- William Smith, UST Class A Operator
- William Smith, UST Class B Global Operator

| Tank Code | Age | Installed | Tank Material Construction | Piping Material | Overfill Types |
|------------------|-----|-----------------------|---|--|--------------------------------|
| Tag # | AST | Sump Tightness | Secondary Option | Secondary Option | Spill Protected |
| Status | | Piping Installed Date | Catastrophic L.D. Type 3.0 | Piping Type | CP Met Types |
| Product | | Tank/Pipe CP | Tank Detection | Primary Pipe Detection | Vapor Recovery |
| Capacity | | Line Tightness | ATG Type | Secondary Pipe Detection | Energy Act |
| 03 | 0 | | Fiberglass Reinforced Plastic | Flexible Plastic | Flapper Valve;High Level Alarm |
| 5925 | No | | Double-Walled | Double Walled | No |
| Currently in Use | | | Auto Dialer | U.S. Suction | Non-corrodible |
| Diesel | | | Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring | 3-Year Line Tightness Test;Continuous Interstitial Monitoring | No |
| 4,000 | | | | | Yes |