

## Facility Summary in Custer County in the City of Miles City

**Location:** CENEX ZIP TRIP 75  
1815 S Haynes Ave  
Miles City, MT 59301 Custer

System Facility ID: 60-15272

Facility Code: 30983  
Last Inspected On: 11/12/2025  
Operating Permit Renewal Date: 01/06/2029

**Note:** Inspection is due 90 days before the Operating Permit Renewal Date.

**Owner Operator Contact:** CHS Inc dba Cenex Zip Trip #75

(509) 535-7701

sean.hurley@chsinc.com

**Operator Contact:** Jim Alford; Sean Hurley

(509) 535-7701; (509) 536-7418

jim.alford@chsinc.com; sean.hurley@chsinc.com

**Owner/Operator:** CHS Inc dba Cenex Zip Trip #75

(509) 535-7701

sean.hurley@chsinc.com

Jim Alford, UST Class A Operator

jim.alford@chsinc.com

Jim Alford, UST Class B Operator

jim.alford@chsinc.com

Luci Tuttle, UST Class B Operator

Lucinda.Tuttle@chsinc.com

Nicholas Merritt, UST Class B Operator

nicholas.merritt@chsinc.com

Sean Hurley, UST Class A Operator

sean.hurley@chsinc.com

<b>Tank Code</b>	01	<b>Tank Age</b>	10	<b>Tank Installed Date</b>	08/15/2016	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Flapper Valve; High Level Alarm
<b>Tag Number</b>	5630	<b>Spill Test Date</b>	11/17/2025	<b>Piping Installed Date</b>	08/15/2016	<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	09/20/2024	<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Diesel	<b>PLLD Test Date</b>	07/30/2025	<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Continuous Interstitial Monitoring	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	No
<b>Capacity</b>	25000	<b>ATG Test Date</b>	07/30/2025	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Secondary Pipe Detection</b>	ELLD 0.2	<b>Energy Act</b>	Yes
		<b>Overfill Test Date</b>	07/30/2025			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-450; Veeder Root/TLS-450				
<b>Tank Code</b>	02	<b>Tank Age</b>	10	<b>Tank Installed Date</b>	08/15/2016	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	Flapper Valve; High Level Alarm
<b>Tag Number</b>	5631	<b>Spill Test Date</b>	11/12/2025	<b>Piping Installed Date</b>	08/15/2016	<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	09/20/2024	<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible

Product	Diesel	PLL D Test Date	07/30/2025	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	25000	ATG Test Date	07/30/2025	Line Tightness Test Date		Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	11/12/2025			ATG Type	Gilbarco-Veeder Root/TLS-450;Veeder Root/TLS-450				
Tank Code	03	Tank Age	10	Tank Installed Date	08/15/2016	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	5632	Spill Test Date	11/12/2025	Piping Installed Date	08/15/2016	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	09/20/2024	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLL D Test Date	07/30/2025	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	25000	ATG Test Date	07/30/2025	Line Tightness Test Date		Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	11/12/2025			ATG Type	Gilbarco-Veeder Root/TLS-450;Veeder Root/TLS-450				
Tank Code	04	Tank Age	10	Tank Installed Date	08/15/2016	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	5633	Spill Test Date	11/17/2025	Piping Installed Date	08/15/2016	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	09/20/2024	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLL D Test Date	07/30/2025	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	25000	ATG Test Date	07/30/2025	Line Tightness Test Date		Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	07/30/2025			ATG Type	Gilbarco-Veeder Root/TLS-450;Veeder Root/TLS-450				
Tank Code	05	Tank Age	10	Tank Installed Date	08/15/2016	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	5634	Spill Test Date	11/12/2025	Piping Installed Date	08/15/2016	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	09/20/2024	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible

Product	Diesel	PLL Test Date	07/30/2025	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	8000	ATG Test Date	07/30/2025	Line Tightness Test Date		Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	11/12/2025			ATG Type	Gilbarco-Veeder Root/TLS-450;Veeder Root/TLS-450				
Tank Code	06	Tank Age	10	Tank Installed Date	08/15/2016	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	5635	Spill Test Date	11/12/2025	Piping Installed Date	08/15/2016	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	09/20/2024	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLL Test Date	07/30/2025	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	10000	ATG Test Date	07/30/2025	Line Tightness Test Date		Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	07/30/2025			ATG Type	Gilbarco-Veeder Root/TLS-450;Veeder Root/TLS-450				
Tank Code	07	Tank Age	10	Tank Installed Date	08/15/2016	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	5636	Spill Test Date	11/12/2025	Piping Installed Date	08/15/2016	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	09/20/2024	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel, Dyed	PLL Test Date	07/30/2025	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	8000	ATG Test Date	07/30/2025	Line Tightness Test Date		Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	11/12/2025			ATG Type	Gilbarco-Veeder Root/TLS-450;Veeder Root/TLS-450				
Tank Code	08	Tank Age	11	Tank Installed Date	12/01/2015	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Not Listed	Overfill Types	
Tag Number	5722	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction		AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0		Piping Type	Pressurized	CP Met Types	

Product	DEF (Not Regulated)	PLL D Test Date	Tank/Piping CP Test Date	Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	6000	ATG Test Date	Line Tightness Test Date	Secondary Tank Leak Detection		Secondary Pipe Detection	Not Listed	Energy Act	No
		Overfill Test Date		ATG Type					

## Facility Summary in Custer County in the City of Miles City

**Location:** ENTERPRISE SYSTEMS SERVICE CENTER  
114 S Haynes Ave  
Miles City, MT 59301 Custer

System Facility ID: 60-15140

Facility Code: 30884  
Last Inspected On: 06/30/2025  
Operating Permit Renewal Date: 09/18/2028

**Note:** Inspection is due 90 days before the Operating Permit Renewal Date.

**Owner Operator Contact:** MT Dept of Administration ITSD

**Operator Contact:** Ed Sivils; John Salazar; Michael Krings

(406) 444-1815

esivils@mt.gov; jksalazar@midrivers.com; mkrings@mt.gov

**Owner/Operator:** MT Dept of Administration ITSD

Ed Sivils, UST Class A Operator

esivils@mt.gov

Ed Sivils, UST Class B Operator

esivils@mt.gov

John Salazar, UST Class A Operator

jksalazar@midrivers.com

John Salazar, UST Class B Operator

jksalazar@midrivers.com

Michael Krings, UST Class A Operator

mkrings@mt.gov

Mike Kennell, UST Class B Global Operator

m kennell2@mt.gov

Randy Anderson, UST Class B Global Operator

randerson3@mt.gov

Rennette Waldo, UST Class B Operator

shado@midrivers.com

Zane Rudolph, UST Class B Global Operator

zrudolph@mt.gov

Tank Code	S1	Tank Age	17	Tank Installed Date	07/21/2009	Tank Material	Unknown	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	5215	Spill Test Date		Piping Installed Date	07/21/2009	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	Yes
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Auto Dialer	Piping Type	Pressurized	CP Met Types	
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection		Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	4000	ATG Test Date	06/30/2025	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	Yes
		Overfill Test Date				ATG Type					

## Facility Summary in Custer County in the City of Miles City

**Location:** FRANKS QUICK STOP LLC  
1308 S Haynes Ave  
Miles City, MT 59301 Custer

System Facility ID:09-00624

Facility Code: 19399  
Last Inspected On: 11/06/2023  
Operating Permit Renewal Date: 11/06/2026

**Note:** Inspection is due 90 days before the Operating Permit Renewal Date.

**Owner Operator Contact:** Franks Quick Stop LLC (406) 234-6661 frankango@midrivers.com

**Operator Contact:** Frank Ngo (406) 234-6661 frankango@midrivers.com

**Owner/Operator:** Franks Quick Stop LLC (406) 234-6661 frankango@midrivers.com

Frank Ngo, UST Class A Operator  
Jason South, UST Class B Global Operator  
Jeremy Thomas, UST Class B Global Operator

Tank Code	08	Tank Age	36	Tank Installed Date	07/01/1990	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve;High Level Alarm
Tag Number	1788	Spill Test Date	10/11/2023	Piping Installed Date	09/27/2007	Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date	03/06/2023	Tank/Piping CP Test Date	10/11/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	8000	ATG Test Date	11/20/2023	Line Tightness Test Date	06/28/2020	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.1	Energy Act	No
		Overfill Test Date	11/20/2023			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	09	Tank Age	36	Tank Installed Date	07/01/1990	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve;High Level Alarm
Tag Number	1789	Spill Test Date	10/11/2023	Piping Installed Date	09/27/2007	Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date	03/06/2023	Tank/Piping CP Test Date	10/11/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	8000	ATG Test Date	11/20/2023	Line Tightness Test Date	06/21/2020	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.1	Energy Act	No

		<b>Overfill Test Date</b>	11/20/2023			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC			
<b>Tank Code</b>	10	<b>Tank Age</b>	36	<b>Tank Installed Date</b>	07/01/1990	<b>Tank Material</b>	Cathodically Protected Steel	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>
<b>Tag Number</b>	1790	<b>Spill Test Date</b>	10/11/2023	<b>Piping Installed Date</b>	09/27/2007	<b>Tank Construction</b>		<b>Piping Construction</b>	None	<b>AST</b>
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>
<b>Product</b>	Diesel	<b>PLLD Test Date</b>	03/06/2023	<b>Tank/Piping CP Test Date</b>	10/11/2023	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	ELLD 0.2	<b>Vapor Recovery</b>
<b>Capacity</b>	8000	<b>ATG Test Date</b>	11/20/2023	<b>Line Tightness Test Date</b>	06/20/2020	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>	ELLD 0.1	<b>Energy Act</b>
		<b>Overfill Test Date</b>	11/20/2023			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC			

## Facility Summary in Custer County in the City of Miles City

**Location:** FRANKS SHORT STOP II  
305 Main St  
Miles City, MT 59301 Custer

System Facility ID:09-07083

Facility Code: 19462  
Last Inspected On: 03/06/2023  
Operating Permit Renewal Date: 06/08/2026

**Note:** Inspection is due 90 days before the Operating Permit Renewal Date.

**Owner Operator Contact:** Frank's Short Stop (406) 853-1991 frankango@midrivers.com

**Operator Contact:** Frank Ngo (406) 234-6661 frankango@midrivers.com

**Owner/Operator:** Frank's Short Stop (406) 853-1991 frankango@midrivers.com

Frank Ngo, UST Class A Operator  
Frank Ngo, UST Class B Operator frankango@midrivers.com  
frankango@midrivers.com

<b>Tank Code</b>	10	<b>Tank Age</b>	29	<b>Tank Installed Date</b>	10/01/1997	<b>Tank Material</b>	Cathodically Protected Steel	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	595	<b>Spill Test Date</b>	05/25/2023	<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Galvanic
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>	05/25/2023	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	ELLD Line Tightness Testing	<b>Vapor Recovery</b>	No
<b>Capacity</b>	15000	<b>ATG Test Date</b>	03/06/2023	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	06/03/2023			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
<b>Tank Code</b>	11	<b>Tank Age</b>	29	<b>Tank Installed Date</b>	10/01/1997	<b>Tank Material</b>	Cathodically Protected Steel	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	596	<b>Spill Test Date</b>	03/06/2023	<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Galvanic
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>	01/30/2020	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	ELLD Line Tightness Testing	<b>Vapor Recovery</b>	No
<b>Capacity</b>	8000	<b>ATG Test Date</b>	03/06/2023	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	03/06/2023			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Tank Code	12	Tank Age	29	Tank Installed Date	10/01/1997	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	597	Spill Test Date	03/06/2023	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	01/30/2020	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD Line Tightness Testing	Vapor Recovery	No
Capacity	6000	ATG Test Date	03/06/2023	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	03/06/2023			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

## Facility Summary in Custer County in the City of Miles City

**Location:** GM PETROLEUM DISTRIBUTORS  
500 N 5th St  
Miles City, MT 59301-2306 Custer

System Facility ID:09-05859

Facility Code: 19449  
Last Inspected On: 06/30/2025  
Operating Permit Renewal Date: 11/15/2028

**Note:** Inspection is due 90 days before the Operating Permit Renewal Date.

<b>Owner Operator Contact:</b> City Service Valcon LLC	(406) 294-0865	tamara.noble@cityservicevalcon.com
--	----------------	------------------------------------

<b>Operator Contact:</b> Bill Grunstead;Roger Schmechel	(406) 208-3147	bgrunstead@gmpetroleum.com
---	----------------	----------------------------

<b>Owner/Operator:</b> City Service Valcon LLC	(406) 294-0865	tamara.noble@cityservicevalcon.com
--	----------------	------------------------------------

Bill Grunstead, UST Class A Operator

Roger Schmechel, UST Class A Operator

Roger Schmechel, UST Class B Operator

Tank Code	S5	Tank Age	28	Tank Installed Date	11/01/1998	Tank Material	Bare Steel	Piping Material	Steel	Overfill Types	
Tag Number	4009	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	Single Walled	AST	Yes
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Gasoline	PLLD Test Date	05/23/2025	Tank/Piping CP Test Date	06/16/2025	Primary Tank Leak Detection		Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	17335	ATG Test Date	05/23/2025	Line Tightness Test Date	07/12/2016	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					
Tank Code	S6	Tank Age	28	Tank Installed Date	11/01/1998	Tank Material	Bare Steel	Piping Material	Steel	Overfill Types	
Tag Number	4010	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	Yes
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Diesel	PLLD Test Date	05/23/2025	Tank/Piping CP Test Date	06/16/2025	Primary Tank Leak Detection		Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	17335	ATG Test Date	05/23/2025	Line Tightness Test Date	07/12/2016	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					
Tank Code	S7	Tank Age	28	Tank Installed Date	11/01/1998	Tank Material	Bare Steel	Piping Material	Steel	Overfill Types	
Tag Number	4011	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	Yes

Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Diesel	PLL D Test Date	05/23/2025	Tank/Piping CP Test Date	06/16/2025	Primary Tank Leak Detection		Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	17335	ATG Test Date	05/23/2025	Line Tightness Test Date	07/12/2016	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					
Tank Code	S8	Tank Age	28	Tank Installed Date	11/01/1998	Tank Material	Bare Steel	Piping Material	Steel	Overfill Types	
Tag Number	4012	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	Yes
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Gasoline	PLL D Test Date	06/30/2025	Tank/Piping CP Test Date	06/16/2025	Primary Tank Leak Detection		Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	10123	ATG Test Date	05/23/2025	Line Tightness Test Date	07/12/2016	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					

## Facility Summary in Custer County in the City of Miles City

**Location:** HOLY ROSARY HOSPITAL WILSON ST  
2600 Wilson St  
Miles City, MT 59301 Custer

System Facility ID:09-13574

Facility Code: 19513  
Last Inspected On: 08/14/2024  
Operating Permit Renewal Date: 02/10/2028

**Note:** Inspection is due 90 days before the Operating Permit Renewal Date.

**Owner Operator Contact:** Holy Rosary Hospital

**Operator Contact:** Al Miller;Holy Rosary Hospital;Dustin Leidholt;Scott Luedtke (406) 852-0342

allan.miller@sclhealth.org;dustin.leidholt@sclhealth.org;scott.luedtke@sclhealth.org

**Owner/Operator:** Holy Rosary Hospital

Al Miller, UST Class A Operator

allan.miller@sclhealth.org

Al Miller, UST Class B Operator

allan.miller@sclhealth.org

Dustin Leidholt, UST Class A Operator

dustin.leidholt@sclhealth.org

Dustin Leidholt, UST Class B Operator

dustin.leidholt@sclhealth.org

Scott Luedtke, UST Class A Operator

scott.luedtke@sclhealth.org

Scott Luedtke, UST Class B Global Operator

scott.luedtke@sclhealth.org

Tank Code	01	Tank Age	32	Tank Installed Date	08/01/1994	Tank Material	Steel Clad	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	4284	Spill Test Date	03/15/2022	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Auto Dialer	Piping Type	U.S. Suction	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	8000	ATG Test Date	08/14/2024	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	08/14/2024			ATG Type	Gilbarco-Veeder Root/ILS-350				

## Facility Summary in Custer County in the City of Miles City

**Location:** M AND H GAS MILES CITY  
1019 Main St  
Miles City, MT 59301 Custer

System Facility ID:09-01058

Facility Code: 19402  
Last Inspected On: 03/06/2024  
Operating Permit Renewal Date: 06/23/2027

**Note:** Inspection is due 90 days before the Operating Permit Renewal Date.

**Owner Operator Contact:** Miller and Holmes Inc

**Operator Contact:** Kevin Junker

[kjj@mhstores.com](mailto:kjj@mhstores.com)

**Owner/Operator:** Miller and Holmes Inc

Charles Kauffman, UST Class B Global Operator

[charlesjkauffman@gmail.com](mailto:charlesjkauffman@gmail.com)

Dave Lunder, UST Class B Operator

[darterdave1569@yahoo.com](mailto:darterdave1569@yahoo.com)

Debra Agnew, UST Class B Global Operator

[debra.agnew21@gmail.com](mailto:debra.agnew21@gmail.com)

Kevin Junker, UST Class A Operator

[kjj@mhstores.com](mailto:kjj@mhstores.com)

Kevin Junker, UST Class B Operator

[kjj@mhstores.com](mailto:kjj@mhstores.com)

Sandy Maine, UST Class B Operator

[maine10@midrivers.com](mailto:maine10@midrivers.com)

<b>Tank Code</b>	04	<b>Tank Age</b>	32	<b>Tank Installed Date</b>	10/01/1994	<b>Tank Material</b>	Cathodically Protected Steel	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Flapper Valve;High Level Alarm
<b>Tag Number</b>	1613	<b>Spill Test Date</b>	04/13/2023	<b>Piping Installed Date</b>	05/27/2008	<b>Tank Construction</b>		<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Galvanic
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>	03/06/2024	<b>Tank/Piping CP Test Date</b>	03/06/2024	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	ELLD 0.2	<b>Vapor Recovery</b>	No
<b>Capacity</b>	15000	<b>ATG Test Date</b>	03/06/2024	<b>Line Tightness Test Date</b>	02/03/2021	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	05/23/2024			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
<b>Tank Code</b>	05	<b>Tank Age</b>	32	<b>Tank Installed Date</b>	10/01/1994	<b>Tank Material</b>	Cathodically Protected Steel	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Flapper Valve;High Level Alarm
<b>Tag Number</b>	1614	<b>Spill Test Date</b>	04/13/2023	<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Galvanic
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>	03/06/2024	<b>Tank/Piping CP Test Date</b>	03/06/2024	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	ELLD 0.2	<b>Vapor Recovery</b>	No

Capacity	15000	ATG Test Date	03/06/2024	Line Tightness Test Date	02/03/2021	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	05/23/2024			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	06	Tank Age	32	Tank Installed Date	10/01/1994	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	1615	Spill Test Date	04/13/2023	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date	03/06/2024	Tank/Piping CP Test Date	03/06/2024	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	7500	ATG Test Date	03/06/2024	Line Tightness Test Date	01/30/2021	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	05/23/2024			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	07	Tank Age	32	Tank Installed Date	10/01/1994	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	1616	Spill Test Date	04/13/2023	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date	03/06/2024	Tank/Piping CP Test Date	03/06/2024	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	7500	ATG Test Date	03/06/2024	Line Tightness Test Date	02/01/2021	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	05/23/2024			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

## Facility Summary in Custer County in the City of Miles City

**Location:** MILES CITY BULK PLANT  
S 4th St & Pacific Ave  
Miles City, MT 59301-1440 Custer

System Facility ID:09-03211

Facility Code: 19419  
Last Inspected On: 03/07/2024  
Operating Permit Renewal Date: 08/03/2027

**Note:** Inspection is due 90 days before the Operating Permit Renewal Date.

**Owner Operator Contact:** Cenex Harvest States Sidney

(406) 234-1350

**Operator Contact:** Parker Murnion;Randy Bickle

(406) 234-1350;(406) 234-2350

parker.murnion@chsinc.com;randy.bickle@chsinc.com

**Owner/Operator:** Cenex Harvest States Sidney

(406) 234-1350

Parker Murnion, UST Class A Operator

parker.murnion@chsinc.com

Randy Bickle, UST Class A Operator

randy.bickle@chsinc.com

Randy Bickle, UST Class B Operator

randy.bickle@chsinc.com

<b>Tank Code</b>	01	<b>Tank Age</b>	49	<b>Tank Installed Date</b>	03/26/1977	<b>Tank Material</b>	Bare Steel	<b>Piping Material</b>	No Piping	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	3586	<b>Spill Test Date</b>	04/30/2024	<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	None	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Not Required	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Impressed Current
<b>Product</b>	Diesel	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>	03/07/2024	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>		<b>Vapor Recovery</b>	No
<b>Capacity</b>	11000	<b>ATG Test Date</b>	11/20/2023	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	03/07/2024			<b>ATG Type</b>	Veeder Root/TLS-300				
<b>Tank Code</b>	02	<b>Tank Age</b>	49	<b>Tank Installed Date</b>	03/26/1977	<b>Tank Material</b>	Bare Steel	<b>Piping Material</b>	No Piping	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	3587	<b>Spill Test Date</b>	03/07/2024	<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	None	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Not Required	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Impressed Current
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>	03/07/2024	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>		<b>Vapor Recovery</b>	No
<b>Capacity</b>	11000	<b>ATG Test Date</b>	11/20/2023	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	03/07/2024			<b>ATG Type</b>	Veeder Root/TLS-300				
<b>Tank Code</b>	04	<b>Tank Age</b>	49	<b>Tank Installed Date</b>	03/26/1977	<b>Tank Material</b>	Bare Steel	<b>Piping Material</b>	No Piping	<b>Overfill Types</b>	Flapper Valve

Tag Number	3588	Spill Test Date	03/07/2024	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	03/07/2024	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection		Vapor Recovery	No
Capacity	11000	ATG Test Date	11/20/2023	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	03/07/2024			ATG Type	Veeder Root/TLS-300				
Tank Code	05	Tank Age	49	Tank Installed Date	03/26/1977	Tank Material	Bare Steel	Piping Material	No Piping	Overfill Types	Flapper Valve
Tag Number	3589	Spill Test Date	04/30/2024	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	03/07/2024	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection		Vapor Recovery	No
Capacity	11000	ATG Test Date	11/20/2023	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	03/07/2024			ATG Type	Veeder Root/TLS-300				
Tank Code	06	Tank Age	49	Tank Installed Date	03/26/1977	Tank Material	Bare Steel	Piping Material	No Piping	Overfill Types	Flapper Valve
Tag Number	3590	Spill Test Date	04/30/2024	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	03/07/2024	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection		Vapor Recovery	No
Capacity	11000	ATG Test Date	11/20/2023	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	03/07/2024			ATG Type	Veeder Root/TLS-300				
Tank Code	03	Tank Age	49	Tank Installed Date	03/26/1977	Tank Material	Bare Steel	Piping Material	No Piping	Overfill Types	Flapper Valve
Tag Number	3764	Spill Test Date	03/07/2024	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	03/07/2024	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection		Vapor Recovery	No
Capacity	11000	ATG Test Date	11/20/2023	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	03/07/2024			ATG Type	Veeder Root/TLS-300				

## Facility Summary in Custer County in the City of Miles City

**Location:** QWEST MILES CITY CENTRAL OFFICE  
811 Pleasant St  
Miles City, MT 59301-3229 Custer

System Facility ID:09-08778

Facility Code: 19484  
Last Inspected On: 09/07/2023  
Operating Permit Renewal Date: 03/05/2027

**Note:** Inspection is due 90 days before the Operating Permit Renewal Date.

**Owner Operator Contact:** Qwest Corporation/Century Link (801) 238-0337 kevin.robison@centurylink.com

**Operator Contact:** Kevin Robison;Stephanie Miller (501) 680-8141;(801) 238-0337 kevin.robison@centurylink.com;Stephanie.miller@lumen.com

**Owner/Operator:** Qwest Corporation/Century Link (801) 238-0337 kevin.robison@centurylink.com

Kevin Robison, UST Class A Operator kevin.robison@centurylink.com  
Kevin Robison, UST Class B Global Operator kevin.robison@centurylink.com  
Kevin Robison, UST Class B Operator kevin.robison@centurylink.com  
Stephanie Miller, UST Class A Operator Stephanie.miller@lumen.com  
Stephanie Miller, UST Class B Global Operator Stephanie.miller@lumen.com

<b>Tank Code</b>	01	<b>Tank Age</b>	33	<b>Tank Installed Date</b>	05/01/1993	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	High Level Alarm
<b>Tag Number</b>	1725	<b>Spill Test Date</b>	09/07/2023	<b>Piping Installed Date</b>		<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Auto Dialer	<b>Piping Type</b>	U.S. Suction	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Diesel	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	<b>Primary Pipe Detection</b>	3-Year Line Tightness Test	<b>Vapor Recovery</b>	No
<b>Capacity</b>	553	<b>ATG Test Date</b>	09/07/2023	<b>Line Tightness Test Date</b>	07/25/2023	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	09/07/2023			<b>ATG Type</b>	Veeder Root/TLS-300				

## Facility Summary in Custer County in the City of Miles City

**Location:** THE SHORT STOP STORE  
16 N 7th St  
Miles City, MT 59301-3110 Custer

System Facility ID:09-04443

Facility Code: 19431  
Last Inspected On: 03/06/2023  
Operating Permit Renewal Date: 06/19/2026

**Note:** Inspection is due 90 days before the Operating Permit Renewal Date.

**Owner Operator Contact:** Frank Ngo;Teresa Newby (406) 234-6661 frankango@midrivers.com

**Operator Contact:** Frank Ngo (406) 234-6661 frankango@midrivers.com

**Owner/Operator:** Frank Ngo (406) 234-6661 frankango@midrivers.com

**Owner/Operator:** Teresa Newby (406) 234-6661 frankango@midrivers.com

Frank Ngo, UST Class A Operator

Frank Ngo, UST Class B Operator

Frankie Meade, UST Class B Operator

Tony Russo, UST Class B Operator

frankango@midrivers.com

frankango@midrivers.com

tamara@midrivers.com

sixguns45@hotmail.com

<b>Tank Code</b>	07	<b>Tank Age</b>	16	<b>Tank Installed Date</b>	12/17/2010	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	5284	<b>Spill Test Date</b>	03/06/2023	<b>Piping Installed Date</b>	11/29/2010	<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	03/06/2023	<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Continuous Interstitial Monitoring	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	No
<b>Capacity</b>	10000	<b>ATG Test Date</b>	03/06/2023	<b>Line Tightness Test Date</b>	10/09/2019	<b>Secondary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Secondary Pipe Detection</b>	ELLD 0.2	<b>Energy Act</b>	Yes
		<b>Overfill Test Date</b>	03/06/2023			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-350;Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
<b>Tank Code</b>	08	<b>Tank Age</b>	16	<b>Tank Installed Date</b>	12/17/2010	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	5285	<b>Spill Test Date</b>	03/06/2023	<b>Piping Installed Date</b>	11/29/2010	<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	03/06/2023	<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Continuous Interstitial Monitoring	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	No

<b>Capacity</b>	5000	<b>ATG Test Date</b>	03/06/2023	<b>Line Tightness Test Date</b>	10/08/2019	<b>Secondary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Secondary Pipe Detection</b>	ELLD 0.2	<b>Energy Act</b>	Yes
		<b>Overfill Test Date</b>	03/06/2023			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-350; Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

## Facility Summary in Custer County in the City of Miles City

**Location:** TOWN PUMP OF MILES CITY  
1210 S Haynes Ave  
Miles City, MT 59301 Custer

System Facility ID:09-07081

Facility Code: 19460  
Last Inspected On: 09/05/2025  
Operating Permit Renewal Date: 11/03/2024

**Note:** Inspection is due 90 days before the Operating Permit Renewal Date.

**Owner Operator Contact:** Miles City 1 Town Pump LLC

(406) 497-6700

environmental@townpump.com

**Operator Contact:** Trent Biggers

Trentb@townpump.com

**Owner/Operator:** Miles City 1 Town Pump LLC

(406) 497-6700

environmental@townpump.com

Trent Biggers, UST Class A Operator

Trent Biggers, UST Class B Global Operator

Trentb@townpump.com

Trentb@townpump.com

<b>Tank Code</b>	10	<b>Tank Age</b>	32	<b>Tank Installed Date</b>	05/01/1994	<b>Tank Material</b>	Cathodically Protected Steel	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	2401	<b>Spill Test Date</b>	09/27/2023	<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Temporarily Out of Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Galvanic
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>	03/12/2024	<b>Tank/Piping CP Test Date</b>	06/16/2021	<b>Primary Tank Leak Detection</b>	Statistical Inventory Reconciliation	<b>Primary Pipe Detection</b>	Statistical Inventory Reconciliation	<b>Vapor Recovery</b>	No
<b>Capacity</b>	12000	<b>ATG Test Date</b>	03/12/2024	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	09/27/2023			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-350				
<b>Tank Code</b>	11	<b>Tank Age</b>	32	<b>Tank Installed Date</b>	05/01/1994	<b>Tank Material</b>	Cathodically Protected Steel	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	2402	<b>Spill Test Date</b>	09/27/2023	<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Temporarily Out of Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Galvanic
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>	03/12/2024	<b>Tank/Piping CP Test Date</b>	06/16/2021	<b>Primary Tank Leak Detection</b>	Statistical Inventory Reconciliation	<b>Primary Pipe Detection</b>	Statistical Inventory Reconciliation	<b>Vapor Recovery</b>	No
<b>Capacity</b>	5000	<b>ATG Test Date</b>	03/12/2024	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	09/27/2023			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-350				

Tank Code	12	Tank Age	32	Tank Installed Date	05/01/1994	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	2403	Spill Test Date	03/06/2024	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Temporarily Out of Use	MLLD Test Date	03/03/2023	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date	03/12/2024	Tank/Piping CP Test Date	06/16/2021	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	5000	ATG Test Date	03/12/2024	Line Tightness Test Date	03/03/2023	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	03/06/2024			ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	13	Tank Age	31	Tank Installed Date	01/01/1995	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	2404	Spill Test Date	09/27/2023	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Temporarily Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	03/12/2024	Tank/Piping CP Test Date	12/17/2009	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	12000	ATG Test Date	03/12/2024	Line Tightness Test Date		Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	09/27/2023			ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	16	Tank Age	26	Tank Installed Date	11/01/2000	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	4232	Spill Test Date	03/06/2024	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	03/12/2024	Tank/Piping CP Test Date	12/17/2009	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	15000	ATG Test Date	03/12/2024	Line Tightness Test Date		Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	09/27/2023			ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	17	Tank Age	26	Tank Installed Date	11/01/2000	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	4233	Spill Test Date	03/06/2024	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No

Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	03/12/2024	Tank/Piping CP Test Date	12/17/2009	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	15000	ATG Test Date	03/12/2024	Line Tightness Test Date	10/13/2022	Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	09/27/2023			ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	18	Tank Age	26	Tank Installed Date	11/01/2000	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	4234	Spill Test Date	03/06/2024	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	06/16/2022	Tank/Piping CP Test Date	12/17/2009	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	15000	ATG Test Date	06/06/2022	Line Tightness Test Date		Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	06/16/2021			ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	19	Tank Age	26	Tank Installed Date	11/01/2000	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	4235	Spill Test Date	09/27/2023	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	03/12/2024	Tank/Piping CP Test Date	12/17/2009	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	10000	ATG Test Date	03/12/2024	Line Tightness Test Date		Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	09/27/2023			ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	20	Tank Age	26	Tank Installed Date	11/01/2000	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	4236	Spill Test Date	09/27/2023	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel, Dyed	PLLD Test Date	03/12/2024	Tank/Piping CP Test Date	12/17/2009	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No

Capacity	5000	ATG Test Date	03/12/2024	Line Tightness Test Date	12/11/2023	Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	09/27/2023			ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	21	Tank Age	0	Tank Installed Date		Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	5385	Spill Test Date		Piping Installed Date	08/14/2012	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Non Regulated	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	DEF (Not Regulated)	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.1;Continuous Interstitial Monitoring;Deferred	Primary Pipe Detection	Approved Remote Monitoring;Deferred;Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	10000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring;Not Listed	Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	22	Tank Age	2	Tank Installed Date	12/12/2024	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	
Tag Number	6277	Spill Test Date	04/29/2025	Piping Installed Date	12/12/2024	Tank Construction		Piping Construction		AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	Yes
Capacity	30000	ATG Test Date	04/29/2025	Line Tightness Test Date		Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	Yes
		Overfill Test Date	04/29/2025			ATG Type					
Tank Code	23	Tank Age	2	Tank Installed Date	12/12/2024	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	
Tag Number	6278	Spill Test Date	04/29/2025	Piping Installed Date	12/12/2024	Tank Construction		Piping Construction		AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No

Capacity	30000	ATG Test Date	04/29/2025	Line Tightness Test Date		Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	Yes
		Overfill Test Date	04/29/2025			ATG Type					
Tank Code	24	Tank Age	2	Tank Installed Date	12/12/2024	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	
Tag Number	6279	Spill Test Date	04/29/2025	Piping Installed Date	12/12/2024	Tank Construction		Piping Construction		AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Gasoline, E10	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	Yes
Capacity	20000	ATG Test Date	04/29/2025	Line Tightness Test Date		Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	Yes
		Overfill Test Date	04/29/2025			ATG Type					
Tank Code	25	Tank Age	2	Tank Installed Date	12/12/2024	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	
Tag Number	6280	Spill Test Date	04/29/2025	Piping Installed Date	12/12/2024	Tank Construction		Piping Construction		AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	Yes
Capacity	10000	ATG Test Date	04/29/2025	Line Tightness Test Date		Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	Yes
		Overfill Test Date	04/29/2025			ATG Type					
Tank Code	26	Tank Age	1	Tank Installed Date	12/12/2025	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	6281	Spill Test Date	09/08/2025	Piping Installed Date	07/30/2025	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel, Dyed	PLLD Test Date	09/08/2025	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	7000	ATG Test Date	09/08/2025	Line Tightness Test Date	09/08/2025	Secondary Tank Leak Detection	Statistical Inventory Reconciliation	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	Yes
		Overfill Test Date	09/08/2025			ATG Type					
Tank Code	27	Tank Age	1	Tank Installed Date	12/12/2025	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve;High Level Alarm

Tag Number	6282	Spill Test Date	09/08/2025	Piping Installed Date	07/30/2025	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	09/08/2025	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	Yes
Capacity	8000	ATG Test Date	09/08/2025	Line Tightness Test Date	09/08/2025	Secondary Tank Leak Detection	Statistical Inventory Reconciliation	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	Yes
		Overfill Test Date	09/08/2025			ATG Type					

## Facility Summary in Custer County in the City of Miles City

**Location:** VA MEDICAL CENTER MILES CITY  
210 S Winchester Ave  
Miles City, MT 59301-4757 Custer

System Facility ID:09-07784

Facility Code: 19471  
Last Inspected On: 04/29/2025  
Operating Permit Renewal Date: 08/02/2028

**Note:** Inspection is due 90 days before the Operating Permit Renewal Date.

**Owner Operator Contact:** VA Medical Center

(406) 874-5600

**Operator Contact:** James Arneson;Joseph Dejong

(406) 232-3060;(406) 874-5880

james.arneson@va.gov

**Owner/Operator:** VA Medical Center

(406) 874-5600

James Arneson, UST Class A Operator

james.arneson@va.gov

James Arneson, UST Class B Global Operator

james.arneson@va.gov

Joseph Dejong, UST Class A Operator

Tank Code	03	Tank Age	45	Tank Installed Date	04/22/1981	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Steel	Overfill Types	High Level Alarm
Tag Number	2191	Spill Test Date	04/29/2025	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Continuous Interstitial Monitoring	Piping Type	U.S. Suction	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	3-Year Line Tightness Test	Vapor Recovery	No
Capacity	12000	ATG Test Date	04/29/2025	Line Tightness Test Date	04/29/2025 <th>Secondary Tank Leak Detection</th> <td></td> <th>Secondary Pipe Detection</th> <td>Continuous Interstitial Monitoring</td> <th>Energy Act</th> <td>No</td>	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	04/29/2025			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	04	Tank Age	45	Tank Installed Date	04/22/1981	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Steel	Overfill Types	High Level Alarm
Tag Number	2192	Spill Test Date	04/29/2025	Piping Installed Date	<th>Tank Construction</th> <td></td> <th>Piping Construction</th> <td>Double Walled</td> <th>AST</th> <td>No</td>	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	<th>Catastrophic L.D Type 3.0</th> <td>Continuous Interstitial Monitoring</td> <th>Piping Type</th> <td>U.S. Suction</td> <th>CP Met Types</th> <td>Non-corrodible</td>	Catastrophic L.D Type 3.0	Continuous Interstitial Monitoring	Piping Type	U.S. Suction	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	<th>Primary Tank Leak Detection</th> <td>Automatic Tank Gauging 0.2</td> <th>Primary Pipe Detection</th> <td>3-Year Line Tightness Test</td> <th>Vapor Recovery</th> <td>No</td>	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	3-Year Line Tightness Test	Vapor Recovery	No
Capacity	12000	ATG Test Date	04/29/2025	Line Tightness Test Date	04/29/2025 <th>Secondary Tank Leak Detection</th> <td></td> <th>Secondary Pipe Detection</th> <td>Continuous Interstitial Monitoring</td> <th>Energy Act</th> <td>No</td>	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No

		<b>Overfill Test Date</b>	04/29/2025			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC			
<b>Tank Code</b>	06	<b>Tank Age</b>	34	<b>Tank Installed Date</b>	04/20/1992	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Steel	<b>Overfill Types</b>
<b>Tag Number</b>	2193	<b>Spill Test Date</b>	04/29/2025	<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	Double Walled	<b>AST</b>
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Continuous Interstitial Monitoring	<b>Piping Type</b>	U.S. Suction	<b>CP Met Types</b>
<b>Product</b>	Diesel	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	3-Year Line Tightness Test	<b>Vapor Recovery</b>
<b>Capacity</b>	4000	<b>ATG Test Date</b>	04/29/2025	<b>Line Tightness Test Date</b>	04/29/2025	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Energy Act</b>
		<b>Overfill Test Date</b>	04/29/2025			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC			
<b>Tank Code</b>	07	<b>Tank Age</b>	34	<b>Tank Installed Date</b>	11/17/1992	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Steel	<b>Overfill Types</b>
<b>Tag Number</b>	2194	<b>Spill Test Date</b>		<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	Double Walled	<b>AST</b>
<b>Tank Status</b>	Temporarily Out of Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Continuous Interstitial Monitoring	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>
<b>Product</b>	Diesel	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>
<b>Capacity</b>	2000	<b>ATG Test Date</b>		<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>
		<b>Overfill Test Date</b>				<b>ATG Type</b>				

## Facility Summary in Custer County in the City of Miles City

**Location:** ZIP TRIP 59  
1321 S Haynes Ave  
Miles City, MT 59301-5733 Custer

System Facility ID:09-08212

Facility Code: 19475  
Last Inspected On: 11/18/2024  
Operating Permit Renewal Date: 11/18/2027

**Note:** Inspection is due 90 days before the Operating Permit Renewal Date.

<b>Owner Operator Contact:</b> CHS Inc Spokane Valley	(509) 535-7701	jim.alford@chsinc.com
---	----------------	-----------------------

<b>Operator Contact:</b> Jim Alford;Sean Hurley	(509) 535-7701;(509) 536-7418	jim.alford@chsinc.com;sean.hurley@chsinc.com
---	-------------------------------	--

<b>Owner/Operator:</b> CHS Inc Spokane Valley	(509) 535-7701	jim.alford@chsinc.com
---	----------------	-----------------------

Jim Alford, UST Class A Operator

jim.alford@chsinc.com

Jim Alford, UST Class B Operator

jim.alford@chsinc.com

Luci Tuttle, UST Class B Operator

Lucinda.Tuttle@chsinc.com

Nicholas Merritt, UST Class B Operator

nicholas.merritt@chsinc.com

Sean Hurley, UST Class A Operator

sean.hurley@chsinc.com

<b>Tank Code</b>	14	<b>Tank Age</b>	3	<b>Tank Installed Date</b>	09/11/2023	<b>Tank Material</b>	Steel Clad	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Flapper Valve;High Level Alarm
<b>Tag Number</b>	6131	<b>Spill Test Date</b>	09/19/2023	<b>Piping Installed Date</b>	09/11/2023	<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Continuous Interstitial Monitoring	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	Yes
<b>Capacity</b>	10000	<b>ATG Test Date</b>	08/06/2024	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Secondary Pipe Detection</b>	ELLD 0.2	<b>Energy Act</b>	Yes
		<b>Overfill Test Date</b>	08/06/2024			<b>ATG Type</b>					
<b>Tank Code</b>	15	<b>Tank Age</b>	3	<b>Tank Installed Date</b>	09/11/2023	<b>Tank Material</b>	Steel Clad	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Flapper Valve;High Level Alarm
<b>Tag Number</b>	6132	<b>Spill Test Date</b>	09/19/2023	<b>Piping Installed Date</b>	09/11/2023	<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Continuous Interstitial Monitoring	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	Yes
<b>Capacity</b>	30000	<b>ATG Test Date</b>	08/06/2024	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Secondary Pipe Detection</b>	ELLD 0.2	<b>Energy Act</b>	Yes

		Overfill Test Date	08/06/2024			ATG Type				
Tank Code	16	Tank Age	3	Tank Installed Date	09/11/2023	Tank Material	Steel Clad	Piping Material	Flexible Plastic	Overfill Types
Tag Number	6133	Spill Test Date	09/19/2023	Piping Installed Date	09/11/2023	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery
Capacity	10000	ATG Test Date	08/06/2024	Line Tightness Test Date		Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act
		Overfill Test Date	08/06/2024			ATG Type				
Tank Code	17	Tank Age	3	Tank Installed Date	09/11/2023	Tank Material	Steel Clad	Piping Material	Flexible Plastic	Overfill Types
Tag Number	6134	Spill Test Date	09/19/2023	Piping Installed Date	09/11/2023	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery
Capacity	10000	ATG Test Date	08/06/2024	Line Tightness Test Date		Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act
		Overfill Test Date	08/06/2024			ATG Type				
Tank Code	18	Tank Age	3	Tank Installed Date	09/11/2023	Tank Material	Steel Clad	Piping Material	Flexible Plastic	Overfill Types
Tag Number	6135	Spill Test Date	09/19/2023	Piping Installed Date	09/11/2023	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types
Product	Diesel, Dyed	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery
Capacity	10000	ATG Test Date	08/06/2024	Line Tightness Test Date		Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act
		Overfill Test Date	08/06/2024			ATG Type				
Tank Code	19	Tank Age	3	Tank Installed Date	09/11/2023	Tank Material	Steel Clad	Piping Material	Flexible Plastic	Overfill Types
Tag Number	6137	Spill Test Date	09/19/2023	Piping Installed Date	09/11/2023	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST

Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types
Product	Diesel	PLL D Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery No
Capacity	30000	ATG Test Date	08/06/2024	Line Tightness Test Date		Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act Yes
		Overfill Test Date	08/06/2024			ATG Type				