

**Facility Summary in Custer County in the City of Miles City**

**Location:** CENEX ZIP TRIP 75  
1815 S Haynes Ave  
Miles City, MT 59301 Custer

System Facility ID:60-15272

**Facility Code:** 30983  
**Last Inspected On:** 11/12/2025  
**Operating Permit Renewal Date:** 01/06/2029

**Note: Inspection is due 90 days before the Operating Permit Renewal Date.**

**Owner Operator Contact:** CHS Inc dba Cenex Zip Trip #75 (509) 535-7701 sean.hurley@chsinc.com

**Operator Contact:** Jim Alford;Sean Hurley (509) 535-7701;(509) 536-7418 jim.alford@chsinc.com;sean.hurley@chsinc.com

**Owner/Operator:** CHS Inc dba Cenex Zip Trip #75 (509) 535-7701 sean.hurley@chsinc.com

Jim Alford, UST Class A Operator  
Jim Alford, UST Class B Operator  
Luci Tuttle, UST Class B Operator  
Nicholas Merritt, UST Class B Operator  
Sean Hurley, UST Class A Operator

jim.alford@chsinc.com  
jim.alford@chsinc.com  
Lucinda.Tuttle@chsinc.com  
nicholas.merritt@chsinc.com  
sean.hurley@chsinc.com

<b>Tank Code</b>	01	<b>Tank Age</b>	10	<b>Tank Installed Date</b>	08/15/2016	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Flapper Valve;High Level Alarm
<b>Tag Number</b>	5630	<b>Spill Test Date</b>	11/17/2025	<b>Piping Installed Date</b>	08/15/2016	<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	09/20/2024	<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Diesel	<b>PLLD Test Date</b>	07/30/2025	<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Continuous Interstitial Monitoring	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	No
<b>Capacity</b>	25000	<b>ATG Test Date</b>	07/30/2025	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Secondary Pipe Detection</b>	ELLD 0.2	<b>Energy Act</b>	Yes
		<b>Overfill Test Date</b>	07/30/2025			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-450;Veeder Root/TLS-450				
<b>Tank Code</b>	02	<b>Tank Age</b>	10	<b>Tank Installed Date</b>	08/15/2016	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	Flapper Valve;High Level Alarm
<b>Tag Number</b>	5631	<b>Spill Test Date</b>	11/12/2025	<b>Piping Installed Date</b>	08/15/2016	<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	09/20/2024	<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible

<b>Product</b>	Diesel	<b>PLLD Test Date</b>	07/30/2025	<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Continuous Interstitial Monitoring	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	No
<b>Capacity</b>	25000	<b>ATG Test Date</b>	07/30/2025	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Secondary Pipe Detection</b>	ELLD 0.2	<b>Energy Act</b>	Yes
		<b>Overfill Test Date</b>	11/12/2025			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-450;Veeder Root/TLS-450				
<b>Tank Code</b>	03	<b>Tank Age</b>	10	<b>Tank Installed Date</b>	08/15/2016	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	Flapper Valve;High Level Alarm
<b>Tag Number</b>	5632	<b>Spill Test Date</b>	11/12/2025	<b>Piping Installed Date</b>	08/15/2016	<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	09/20/2024	<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Diesel	<b>PLLD Test Date</b>	07/30/2025	<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Continuous Interstitial Monitoring	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	No
<b>Capacity</b>	25000	<b>ATG Test Date</b>	07/30/2025	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Secondary Pipe Detection</b>	ELLD 0.2	<b>Energy Act</b>	Yes
		<b>Overfill Test Date</b>	11/12/2025			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-450;Veeder Root/TLS-450				
<b>Tank Code</b>	04	<b>Tank Age</b>	10	<b>Tank Installed Date</b>	08/15/2016	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Flapper Valve;High Level Alarm
<b>Tag Number</b>	5633	<b>Spill Test Date</b>	11/17/2025	<b>Piping Installed Date</b>	08/15/2016	<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	09/20/2024	<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>	07/30/2025	<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Continuous Interstitial Monitoring	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	No
<b>Capacity</b>	25000	<b>ATG Test Date</b>	07/30/2025	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Secondary Pipe Detection</b>	ELLD 0.2	<b>Energy Act</b>	Yes
		<b>Overfill Test Date</b>	07/30/2025			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-450;Veeder Root/TLS-450				
<b>Tank Code</b>	05	<b>Tank Age</b>	10	<b>Tank Installed Date</b>	08/15/2016	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Flapper Valve;High Level Alarm
<b>Tag Number</b>	5634	<b>Spill Test Date</b>	11/12/2025	<b>Piping Installed Date</b>	08/15/2016	<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	09/20/2024	<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible

<b>Product</b>	Diesel	<b>PLLD Test Date</b>	07/30/2025	<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Continuous Interstitial Monitoring	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	No
<b>Capacity</b>	8000	<b>ATG Test Date</b>	07/30/2025	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Secondary Pipe Detection</b>	ELLD 0.2	<b>Energy Act</b>	Yes
		<b>Overfill Test Date</b>	11/12/2025			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-450;Veeder Root/TLS-450				
<b>Tank Code</b>	06	<b>Tank Age</b>	10	<b>Tank Installed Date</b>	08/15/2016	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Flapper Valve;High Level Alarm
<b>Tag Number</b>	5635	<b>Spill Test Date</b>	11/12/2025	<b>Piping Installed Date</b>	08/15/2016	<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	09/20/2024	<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>	07/30/2025	<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Continuous Interstitial Monitoring	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	No
<b>Capacity</b>	10000	<b>ATG Test Date</b>	07/30/2025	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Secondary Pipe Detection</b>	ELLD 0.2	<b>Energy Act</b>	Yes
		<b>Overfill Test Date</b>	07/30/2025			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-450;Veeder Root/TLS-450				
<b>Tank Code</b>	07	<b>Tank Age</b>	10	<b>Tank Installed Date</b>	08/15/2016	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Flapper Valve;High Level Alarm
<b>Tag Number</b>	5636	<b>Spill Test Date</b>	11/12/2025	<b>Piping Installed Date</b>	08/15/2016	<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	09/20/2024	<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Diesel, Dyed	<b>PLLD Test Date</b>	07/30/2025	<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Continuous Interstitial Monitoring	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	No
<b>Capacity</b>	8000	<b>ATG Test Date</b>	07/30/2025	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Secondary Pipe Detection</b>	ELLD 0.2	<b>Energy Act</b>	Yes
		<b>Overfill Test Date</b>	11/12/2025			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-450;Veeder Root/TLS-450				
<b>Tank Code</b>	08	<b>Tank Age</b>	11	<b>Tank Installed Date</b>	12/01/2015	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Not Listed	<b>Overfill Types</b>	
<b>Tag Number</b>	5722	<b>Spill Test Date</b>		<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>		<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>		<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	

<b>Product</b>	DEF (Not Regulated)	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Continuous Interstitial Monitoring	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	No
<b>Capacity</b>	6000	<b>ATG Test Date</b>		<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>	Not Listed	<b>Energy Act</b>	No
		<b>Overfill Test Date</b>				<b>ATG Type</b>					

**Facility Summary in Custer County in the City of Miles City**

**Location:** ENTERPRISE SYSTEMS SERVICE CENTER  
114 S Haynes Ave  
Miles City, MT 59301 Custer

System Facility ID:60-15140

**Facility Code:** 30884  
**Last Inspected On:** 06/30/2025  
**Operating Permit Renewal Date:** 09/18/2028

**Note: Inspection is due 90 days before the Operating Permit Renewal Date.**

**Owner Operator Contact:** MT Dept of Administration ITSD

**Operator Contact:** Ed Sivils;John Salazar;Michael Krings

**(406) 444-1815**

**esivils@mt.gov;jksalazar@midrivers.com;mkrings@mt.gov**

**Owner/Operator:** MT Dept of Administration ITSD

Ed Sivils, UST Class A Operator

esivils@mt.gov

Ed Sivils, UST Class B Operator

esivils@mt.gov

John Salazar, UST Class A Operator

jksalazar@midrivers.com

John Salazar, UST Class B Operator

jksalazar@midrivers.com

Michael Krings, UST Class A Operator

mkrings@mt.gov

Mike Kennell, UST Class B Global Operator

mkennell2@mt.gov

Randy Anderson, UST Class B Global Operator

randerson3@mt.gov

Rennette Waldo, UST Class B Operator

shado@midrivers.com

Zane Rudolph, UST Class B Global Operator

zrudolph@mt.gov

<b>Tank Code</b>	S1	<b>Tank Age</b>	17	<b>Tank Installed Date</b>	07/21/2009	<b>Tank Material</b>	Unknown	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	High Level Alarm
<b>Tag Number</b>	5215	<b>Spill Test Date</b>		<b>Piping Installed Date</b>	07/21/2009	<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	Double Walled	<b>AST</b>	Yes
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Auto Dialer	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	
<b>Product</b>	Diesel	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>		<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	No
<b>Capacity</b>	4000	<b>ATG Test Date</b>	06/30/2025	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	Yes
		<b>Overfill Test Date</b>				<b>ATG Type</b>					

**Facility Summary in Custer County in the City of Miles City**

**Location:** FRANKS QUICK STOP LLC  
1308 S Haynes Ave  
Miles City, MT 59301 Custer

System Facility ID:09-00624

**Facility Code:** 19399  
**Last Inspected On:** 11/06/2023  
**Operating Permit Renewal Date:** 11/06/2026

**Note: Inspection is due 90 days before the Operating Permit Renewal Date.**

**Owner Operator Contact:** Franks Quick Stop LLC (406) 234-6661 frankango@midrivers.com

**Operator Contact:** Frank Ngo (406) 234-6661 frankango@midrivers.com

**Owner/Operator:** Franks Quick Stop LLC (406) 234-6661 frankango@midrivers.com

Frank Ngo, UST Class A Operator frankango@midrivers.com  
Jason South, UST Class B Global Operator jj95south@yahoo.com  
Jeremy Thomas, UST Class B Global Operator

<b>Tank Code</b>	08	<b>Tank Age</b>	36	<b>Tank Installed Date</b>	07/01/1990	<b>Tank Material</b>	Cathodically Protected Steel	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	Ball Float Valve;High Level Alarm
<b>Tag Number</b>	1788	<b>Spill Test Date</b>	10/11/2023	<b>Piping Installed Date</b>	09/27/2007	<b>Tank Construction</b>		<b>Piping Construction</b>	None	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Impressed Current
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>	03/06/2023	<b>Tank/Piping CP Test Date</b>	10/11/2023	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	ELLD 0.2	<b>Vapor Recovery</b>	No
<b>Capacity</b>	8000	<b>ATG Test Date</b>	11/20/2023	<b>Line Tightness Test Date</b>	06/28/2020	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>	ELLD 0.1	<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	11/20/2023			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
<b>Tank Code</b>	09	<b>Tank Age</b>	36	<b>Tank Installed Date</b>	07/01/1990	<b>Tank Material</b>	Cathodically Protected Steel	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	Ball Float Valve;High Level Alarm
<b>Tag Number</b>	1789	<b>Spill Test Date</b>	10/11/2023	<b>Piping Installed Date</b>	09/27/2007	<b>Tank Construction</b>		<b>Piping Construction</b>	None	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Impressed Current
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>	03/06/2023	<b>Tank/Piping CP Test Date</b>	10/11/2023	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	ELLD 0.2	<b>Vapor Recovery</b>	No
<b>Capacity</b>	8000	<b>ATG Test Date</b>	11/20/2023	<b>Line Tightness Test Date</b>	06/21/2020	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>	ELLD 0.1	<b>Energy Act</b>	No

		<b>Overfill Test Date</b>	11/20/2023			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
<b>Tank Code</b>	10	<b>Tank Age</b>	36	<b>Tank Installed Date</b>	07/01/1990	<b>Tank Material</b>	Cathodically Protected Steel	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	Ball Float Valve;High Level Alarm
<b>Tag Number</b>	1790	<b>Spill Test Date</b>	10/11/2023	<b>Piping Installed Date</b>	09/27/2007	<b>Tank Construction</b>		<b>Piping Construction</b>	None	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Impressed Current
<b>Product</b>	Diesel	<b>PLLD Test Date</b>	03/06/2023	<b>Tank/Piping CP Test Date</b>	10/11/2023	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	ELLD 0.2	<b>Vapor Recovery</b>	No
<b>Capacity</b>	8000	<b>ATG Test Date</b>	11/20/2023	<b>Line Tightness Test Date</b>	06/20/2020	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>	ELLD 0.1	<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	11/20/2023			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

**Facility Summary in Custer County in the City of Miles City**

**Location:** FRANKS SHORT STOP II  
305 Main St  
Miles City, MT 59301 Custer

System Facility ID:09-07083

**Facility Code:** 19462  
**Last Inspected On:** 03/02/2026  
**Operating Permit Renewal Date:** 06/08/2026

**Note: Inspection is due 90 days before the Operating Permit Renewal Date.**

**Owner Operator Contact:** Frank's Short Stop (406) 853-1991 frankango@midrivers.com

**Operator Contact:** Frank Ngo (406) 234-6661 frankango@midrivers.com

**Owner/Operator:** Frank's Short Stop (406) 853-1991 frankango@midrivers.com

Frank Ngo, UST Class A Operator  
Frank Ngo, UST Class B Operator

frankango@midrivers.com  
frankango@midrivers.com

<b>Tank Code</b>	10	<b>Tank Age</b>	29	<b>Tank Installed Date</b>	10/01/1997	<b>Tank Material</b>	Cathodically Protected Steel	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	595	<b>Spill Test Date</b>	05/25/2023	<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Galvanic
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>	05/25/2023	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	ELLD Line Tightness Testing	<b>Vapor Recovery</b>	No
<b>Capacity</b>	15000	<b>ATG Test Date</b>	03/06/2023	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	06/03/2023			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
<b>Tank Code</b>	11	<b>Tank Age</b>	29	<b>Tank Installed Date</b>	10/01/1997	<b>Tank Material</b>	Cathodically Protected Steel	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	596	<b>Spill Test Date</b>	03/06/2023	<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Galvanic
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>	01/30/2020	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	ELLD Line Tightness Testing	<b>Vapor Recovery</b>	No
<b>Capacity</b>	8000	<b>ATG Test Date</b>	03/06/2023	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	03/06/2023			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

<b>Tank Code</b>	12	<b>Tank Age</b>	29	<b>Tank Installed Date</b>	10/01/1997	<b>Tank Material</b>	Cathodically Protected Steel	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	597	<b>Spill Test Date</b>	03/06/2023	<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Galvanic
<b>Product</b>	Diesel	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>	01/30/2020	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	ELLD Line Tightness Testing	<b>Vapor Recovery</b>	No
<b>Capacity</b>	6000	<b>ATG Test Date</b>	03/06/2023	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	03/06/2023			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

## Facility Summary in Custer County in the City of Miles City

**Location:** GM PETROLEUM DISTRIBUTORS  
500 N 5th St  
Miles City, MT 59301-2306 Custer

System Facility ID:09-05859

**Facility Code:** 19449  
**Last Inspected On:** 06/30/2025  
**Operating Permit Renewal Date:** 11/15/2028

**Note: Inspection is due 90 days before the Operating Permit Renewal Date.**

---

**Owner Operator Contact:** City Service Valcon LLC (406) 294-0865 tamara.noble@cityservicevalcon.com

---

**Operator Contact:** Bill Grunstead;Roger Schmechel (406) 208-3147 bgrunstead@gmpetroleum.com

---

**Owner/Operator:** City Service Valcon LLC (406) 294-0865 tamara.noble@cityservicevalcon.com

Bill Grunstead, UST Class A Operator  
Roger Schmechel, UST Class A Operator  
Roger Schmechel, UST Class B Operator

bgrunstead@gmpetroleum.com

<b>Tank Code</b>	S5	<b>Tank Age</b>	28	<b>Tank Installed Date</b>	11/01/1998	<b>Tank Material</b>	Bare Steel	<b>Piping Material</b>	Steel	<b>Overfill Types</b>	
<b>Tag Number</b>	4009	<b>Spill Test Date</b>		<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	Single Walled	<b>AST</b>	Yes
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>	05/23/2025	<b>Tank/Piping CP Test Date</b>	06/16/2025	<b>Primary Tank Leak Detection</b>		<b>Primary Pipe Detection</b>	ELLD 0.2	<b>Vapor Recovery</b>	No
<b>Capacity</b>	17335	<b>ATG Test Date</b>	05/23/2025	<b>Line Tightness Test Date</b>	07/12/2016	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>				<b>ATG Type</b>					
<b>Tank Code</b>	S6	<b>Tank Age</b>	28	<b>Tank Installed Date</b>	11/01/1998	<b>Tank Material</b>	Bare Steel	<b>Piping Material</b>	Steel	<b>Overfill Types</b>	
<b>Tag Number</b>	4010	<b>Spill Test Date</b>		<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	None	<b>AST</b>	Yes
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	
<b>Product</b>	Diesel	<b>PLLD Test Date</b>	05/23/2025	<b>Tank/Piping CP Test Date</b>	06/16/2025	<b>Primary Tank Leak Detection</b>		<b>Primary Pipe Detection</b>	ELLD 0.2	<b>Vapor Recovery</b>	No
<b>Capacity</b>	17335	<b>ATG Test Date</b>	05/23/2025	<b>Line Tightness Test Date</b>	07/12/2016	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>				<b>ATG Type</b>					
<b>Tank Code</b>	S7	<b>Tank Age</b>	28	<b>Tank Installed Date</b>	11/01/1998	<b>Tank Material</b>	Bare Steel	<b>Piping Material</b>	Steel	<b>Overfill Types</b>	
<b>Tag Number</b>	4011	<b>Spill Test Date</b>		<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	None	<b>AST</b>	Yes

<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	
<b>Product</b>	Diesel	<b>PLLD Test Date</b>	05/23/2025	<b>Tank/Piping CP Test Date</b>	06/16/2025	<b>Primary Tank Leak Detection</b>		<b>Primary Pipe Detection</b>	ELLD 0.2	<b>Vapor Recovery</b>	No
<b>Capacity</b>	17335	<b>ATG Test Date</b>	05/23/2025	<b>Line Tightness Test Date</b>	07/12/2016	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>				<b>ATG Type</b>					
<b>Tank Code</b>	S8	<b>Tank Age</b>	28	<b>Tank Installed Date</b>	11/01/1998	<b>Tank Material</b>	Bare Steel	<b>Piping Material</b>	Steel	<b>Overfill Types</b>	
<b>Tag Number</b>	4012	<b>Spill Test Date</b>		<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	None	<b>AST</b>	Yes
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>	06/30/2025	<b>Tank/Piping CP Test Date</b>	06/16/2025	<b>Primary Tank Leak Detection</b>		<b>Primary Pipe Detection</b>	ELLD 0.2	<b>Vapor Recovery</b>	No
<b>Capacity</b>	10123	<b>ATG Test Date</b>	05/23/2025	<b>Line Tightness Test Date</b>	07/12/2016	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>				<b>ATG Type</b>					

**Facility Summary in Custer County in the City of Miles City**

**Location:** HOLY ROSARY HOSPITAL WILSON ST  
2600 Wilson St  
Miles City, MT 59301 Custer

System Facility ID:09-13574

**Facility Code:** 19513  
**Last Inspected On:** 08/14/2024  
**Operating Permit Renewal Date:** 02/10/2028

**Note: Inspection is due 90 days before the Operating Permit Renewal Date.**

**Owner Operator Contact:** Holy Rosary Hospital

**Operator Contact:** Al Miller;Holy Rosary Hospital;Dustin Leidholt;Scott Luedtke (406) 852-0342

allan.miller@sclhealth.org;dustin.leidholt@sclhealth.org;scott.luedtke@sclhealth.org

**Owner/Operator:** Holy Rosary Hospital

Al Miller, UST Class A Operator  
Al Miller, UST Class B Operator  
Dustin Leidholt, UST Class A Operator  
Dustin Leidholt, UST Class B Operator  
Scott Luedtke, UST Class A Operator  
Scott Luedtke, UST Class B Global Operator

allan.miller@sclhealth.org  
allan.miller@sclhealth.org  
dustin.leidholt@sclhealth.org  
dustin.leidholt@sclhealth.org  
scott.luedtke@sclhealth.org  
scott.luedtke@sclhealth.org

<b>Tank Code</b>	01	<b>Tank Age</b>	32	<b>Tank Installed Date</b>	08/01/1994	<b>Tank Material</b>	Steel Clad	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	4284	<b>Spill Test Date</b>	03/15/2022	<b>Piping Installed Date</b>		<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Auto Dialer	<b>Piping Type</b>	U.S. Suction	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Diesel	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Continuous Interstitial Monitoring	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	No
<b>Capacity</b>	8000	<b>ATG Test Date</b>	08/14/2024	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	08/14/2024			<b>ATG Type</b>	Gilbarco-Veeder Root/ILS-350				

**Facility Summary in Custer County in the City of Miles City**

**Location:** M AND H GAS MILES CITY  
1019 Main St  
Miles City, MT 59301 Custer

System Facility ID:09-01058

**Facility Code:** 19402  
**Last Inspected On:** 03/06/2024  
**Operating Permit Renewal Date:** 06/23/2027

**Note: Inspection is due 90 days before the Operating Permit Renewal Date.**

**Owner Operator Contact:** Miller and Holmes Inc

**Operator Contact:** Kevin Junker

**kjj@mhstores.com**

**Owner/Operator:** Miller and Holmes Inc

Charles Kauffman, UST Class B Global Operator  
Dave Lunder, UST Class B Operator  
Debra Agnew, UST Class B Global Operator  
Kevin Junker, UST Class A Operator  
Kevin Junker, UST Class B Operator  
Sandy Maine, UST Class B Operator

charlesjkauffman@gmail.com  
darterdave1569@yahoo.com  
debra.agnew21@gmail.com  
kjj@mhstores.com  
kjj@mhstores.com  
maine10@midrivers.com

<b>Tank Code</b>	04	<b>Tank Age</b>	32	<b>Tank Installed Date</b>	10/01/1994	<b>Tank Material</b>	Cathodically Protected Steel	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Flapper Valve;High Level Alarm
<b>Tag Number</b>	1613	<b>Spill Test Date</b>	04/13/2023	<b>Piping Installed Date</b>	05/27/2008	<b>Tank Construction</b>		<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Galvanic
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>	03/06/2024	<b>Tank/Piping CP Test Date</b>	03/06/2024	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	ELLD 0.2	<b>Vapor Recovery</b>	No
<b>Capacity</b>	15000	<b>ATG Test Date</b>	03/06/2024	<b>Line Tightness Test Date</b>	02/03/2021	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	05/23/2024			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
<b>Tank Code</b>	05	<b>Tank Age</b>	32	<b>Tank Installed Date</b>	10/01/1994	<b>Tank Material</b>	Cathodically Protected Steel	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Flapper Valve;High Level Alarm
<b>Tag Number</b>	1614	<b>Spill Test Date</b>	04/13/2023	<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Galvanic
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>	03/06/2024	<b>Tank/Piping CP Test Date</b>	03/06/2024	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	ELLD 0.2	<b>Vapor Recovery</b>	No

<b>Capacity</b>	15000	<b>ATG Test Date</b>	03/06/2024	<b>Line Tightness Test Date</b>	02/03/2021	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	05/23/2024			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
<b>Tank Code</b>	06	<b>Tank Age</b>	32	<b>Tank Installed Date</b>	10/01/1994	<b>Tank Material</b>	Cathodically Protected Steel	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	High Level Alarm
<b>Tag Number</b>	1615	<b>Spill Test Date</b>	04/13/2023	<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Galvanic
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>	03/06/2024	<b>Tank/Piping CP Test Date</b>	03/06/2024	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	ELLD 0.2	<b>Vapor Recovery</b>	No
<b>Capacity</b>	7500	<b>ATG Test Date</b>	03/06/2024	<b>Line Tightness Test Date</b>	01/30/2021	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	05/23/2024			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
<b>Tank Code</b>	07	<b>Tank Age</b>	32	<b>Tank Installed Date</b>	10/01/1994	<b>Tank Material</b>	Cathodically Protected Steel	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	High Level Alarm
<b>Tag Number</b>	1616	<b>Spill Test Date</b>	04/13/2023	<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Galvanic
<b>Product</b>	Diesel	<b>PLLD Test Date</b>	03/06/2024	<b>Tank/Piping CP Test Date</b>	03/06/2024	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	ELLD 0.2	<b>Vapor Recovery</b>	No
<b>Capacity</b>	7500	<b>ATG Test Date</b>	03/06/2024	<b>Line Tightness Test Date</b>	02/01/2021	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	05/23/2024			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

**Facility Summary in Custer County in the City of Miles City**

**Location:** MILES CITY BULK PLANT  
S 4th St & Pacific Ave  
Miles City, MT 59301-1440 Custer

System Facility ID:09-03211

**Facility Code:** 19419  
**Last Inspected On:** 03/07/2024  
**Operating Permit Renewal Date:** 08/03/2027

**Note: Inspection is due 90 days before the Operating Permit Renewal Date.**

**Owner Operator Contact:** Cenex Harvest States Sidney (406) 234-1350

**Operator Contact:** Parker Murnion;Randy Bickle (406) 234-1350;(406) 234-2350 parker.murnion@chsinc.com;randy.bickle@chsinc.com

**Owner/Operator:** Cenex Harvest States Sidney (406) 234-1350

Parker Murnion, UST Class A Operator  
Randy Bickle, UST Class A Operator  
Randy Bickle, UST Class B Operator

parker.murnion@chsinc.com  
randy.bickle@chsinc.com  
randy.bickle@chsinc.com

<b>Tank Code</b>	01	<b>Tank Age</b>	49	<b>Tank Installed Date</b>	03/26/1977	<b>Tank Material</b>	Bare Steel	<b>Piping Material</b>	No Piping	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	3586	<b>Spill Test Date</b>	04/30/2024	<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	None	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Not Required	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Impressed Current
<b>Product</b>	Diesel	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>	03/07/2024	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>		<b>Vapor Recovery</b>	No
<b>Capacity</b>	11000	<b>ATG Test Date</b>	11/20/2023	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	03/07/2024			<b>ATG Type</b>	Veeder Root/TLS-300				
<b>Tank Code</b>	02	<b>Tank Age</b>	49	<b>Tank Installed Date</b>	03/26/1977	<b>Tank Material</b>	Bare Steel	<b>Piping Material</b>	No Piping	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	3587	<b>Spill Test Date</b>	03/07/2024	<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	None	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Not Required	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Impressed Current
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>	03/07/2024	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>		<b>Vapor Recovery</b>	No
<b>Capacity</b>	11000	<b>ATG Test Date</b>	11/20/2023	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	03/07/2024			<b>ATG Type</b>	Veeder Root/TLS-300				
<b>Tank Code</b>	04	<b>Tank Age</b>	49	<b>Tank Installed Date</b>	03/26/1977	<b>Tank Material</b>	Bare Steel	<b>Piping Material</b>	No Piping	<b>Overfill Types</b>	Flapper Valve

<b>Tag Number</b>	3588	<b>Spill Test Date</b>	03/07/2024	<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	None	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Not Required	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Impressed Current
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>	03/07/2024	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>		<b>Vapor Recovery</b>	No
<b>Capacity</b>	11000	<b>ATG Test Date</b>	11/20/2023	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	03/07/2024			<b>ATG Type</b>	Veeder Root/TLS-300				
<b>Tank Code</b>	05	<b>Tank Age</b>	49	<b>Tank Installed Date</b>	03/26/1977	<b>Tank Material</b>	Bare Steel	<b>Piping Material</b>	No Piping	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	3589	<b>Spill Test Date</b>	04/30/2024	<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	None	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Not Required	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Impressed Current
<b>Product</b>	Diesel	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>	03/07/2024	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>		<b>Vapor Recovery</b>	No
<b>Capacity</b>	11000	<b>ATG Test Date</b>	11/20/2023	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	03/07/2024			<b>ATG Type</b>	Veeder Root/TLS-300				
<b>Tank Code</b>	06	<b>Tank Age</b>	49	<b>Tank Installed Date</b>	03/26/1977	<b>Tank Material</b>	Bare Steel	<b>Piping Material</b>	No Piping	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	3590	<b>Spill Test Date</b>	04/30/2024	<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	None	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Not Required	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Impressed Current
<b>Product</b>	Diesel	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>	03/07/2024	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>		<b>Vapor Recovery</b>	No
<b>Capacity</b>	11000	<b>ATG Test Date</b>	11/20/2023	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	03/07/2024			<b>ATG Type</b>	Veeder Root/TLS-300				
<b>Tank Code</b>	03	<b>Tank Age</b>	49	<b>Tank Installed Date</b>	03/26/1977	<b>Tank Material</b>	Bare Steel	<b>Piping Material</b>	No Piping	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	3764	<b>Spill Test Date</b>	03/07/2024	<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	None	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Not Required	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Impressed Current
<b>Product</b>	Diesel	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>	03/07/2024	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>		<b>Vapor Recovery</b>	No
<b>Capacity</b>	11000	<b>ATG Test Date</b>	11/20/2023	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	03/07/2024			<b>ATG Type</b>	Veeder Root/TLS-300				

**Facility Summary in Custer County in the City of Miles City**

**Location:** QWEST MILES CITY CENTRAL OFFICE  
811 Pleasant St  
Miles City, MT 59301-3229 Custer

System Facility ID:09-08778

**Facility Code:** 19484  
**Last Inspected On:** 09/07/2023  
**Operating Permit Renewal Date:** 03/05/2027

**Note: Inspection is due 90 days before the Operating Permit Renewal Date.**

**Owner Operator Contact:** Qwest Corporation/Century Link (801) 238-0337 kevin.robison@centurylink.com

**Operator Contact:** Kevin Robison;Stephanie Miller (501) 680-8141;(801) 238-0337 kevin.robison@centurylink.com;Stephanie.miller@lumen.com

**Owner/Operator:** Qwest Corporation/Century Link (801) 238-0337 kevin.robison@centurylink.com

Kevin Robison, UST Class A Operator kevin.robison@centurylink.com  
 Kevin Robison, UST Class B Global Operator kevin.robison@centurylink.com  
 Kevin Robison, UST Class B Operator kevin.robison@centurylink.com  
 Stephanie Miller, UST Class A Operator Stephanie.miller@lumen.com  
 Stephanie Miller, UST Class B Global Operator Stephanie.miller@lumen.com

<b>Tank Code</b>	01	<b>Tank Age</b>	33	<b>Tank Installed Date</b>	05/01/1993	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	High Level Alarm
<b>Tag Number</b>	1725	<b>Spill Test Date</b>	09/07/2023	<b>Piping Installed Date</b>		<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Auto Dialer	<b>Piping Type</b>	U.S. Suction	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Diesel	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	<b>Primary Pipe Detection</b>	3-Year Line Tightness Test	<b>Vapor Recovery</b>	No
<b>Capacity</b>	553	<b>ATG Test Date</b>	09/07/2023	<b>Line Tightness Test Date</b>	07/25/2023	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	09/07/2023			<b>ATG Type</b>	Veeder Root/TLS-300				

**Facility Summary in Custer County in the City of Miles City**

**Location:** THE SHORT STOP STORE  
16 N 7th St  
Miles City, MT 59301-3110 Custer

System Facility ID:09-04443

**Facility Code:** 19431  
**Last Inspected On:** 03/02/2026  
**Operating Permit Renewal Date:** 06/19/2026

**Note: Inspection is due 90 days before the Operating Permit Renewal Date.**

**Owner Operator Contact:** Frank Ngo;Teresa Newby (406) 234-6661 frankango@midrivers.com

**Operator Contact:** Frank Ngo (406) 234-6661 frankango@midrivers.com

**Owner/Operator:** Frank Ngo (406) 234-6661 frankango@midrivers.com

**Owner/Operator:** Teresa Newby (406) 234-6661 frankango@midrivers.com

Frank Ngo, UST Class A Operator frankango@midrivers.com  
 Frank Ngo, UST Class B Operator frankango@midrivers.com  
 Frankie Meade, UST Class B Operator tamara@midrivers.com  
 Tony Russo, UST Class B Operator sixguns45@hotmail.com

<b>Tank Code</b>	07	<b>Tank Age</b>	16	<b>Tank Installed Date</b>	12/17/2010	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	5284	<b>Spill Test Date</b>	03/06/2023	<b>Piping Installed Date</b>	11/29/2010	<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	03/06/2023	<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Continuous Interstitial Monitoring	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	No
<b>Capacity</b>	10000	<b>ATG Test Date</b>	03/06/2023	<b>Line Tightness Test Date</b>	10/09/2019	<b>Secondary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Secondary Pipe Detection</b>	ELLD 0.2	<b>Energy Act</b>	Yes
		<b>Overfill Test Date</b>	03/06/2023			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-350;Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
<b>Tank Code</b>	08	<b>Tank Age</b>	16	<b>Tank Installed Date</b>	12/17/2010	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	5285	<b>Spill Test Date</b>	03/06/2023	<b>Piping Installed Date</b>	11/29/2010	<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	03/06/2023	<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Continuous Interstitial Monitoring	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	No

<b>Capacity</b>	5000	<b>ATG Test Date</b>	03/06/2023	<b>Line Tightness Test Date</b>	10/08/2019	<b>Secondary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Secondary Pipe Detection</b>	ELLD 0.2	<b>Energy Act</b>	Yes
		<b>Overfill Test Date</b>	03/06/2023			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-350; Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

**Facility Summary in Custer County in the City of Miles City**

**Location:** TOWN PUMP OF MILES CITY  
1210 S Haynes Ave  
Miles City, MT 59301 Custer

System Facility ID:09-07081

**Facility Code:** 19460  
**Last Inspected On:** 03/17/2026  
**Operating Permit Renewal Date:** 11/03/2024

**Note: Inspection is due 90 days before the Operating Permit Renewal Date.**

**Owner Operator Contact:** Miles City 1 Town Pump LLC

**(406) 497-6700**

**environmental@townpump.com**

**Operator Contact:** Trent Biggers

**Trentb@townpump.com**

**Owner/Operator:** Miles City 1 Town Pump LLC

**(406) 497-6700**

**environmental@townpump.com**

Trent Biggers, UST Class A Operator

Trentb@townpump.com

Trent Biggers, UST Class B Global Operator

Trentb@townpump.com

<b>Tank Code</b>	10	<b>Tank Age</b>	32	<b>Tank Installed Date</b>	05/01/1994	<b>Tank Material</b>	Cathodically Protected Steel	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	2401	<b>Spill Test Date</b>	09/27/2023	<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Temporarily Out of Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Galvanic
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>	03/12/2024	<b>Tank/Piping CP Test Date</b>	06/16/2021	<b>Primary Tank Leak Detection</b>	Statistical Inventory Reconciliation	<b>Primary Pipe Detection</b>	Statistical Inventory Reconciliation	<b>Vapor Recovery</b>	No
<b>Capacity</b>	12000	<b>ATG Test Date</b>	03/12/2024	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	09/27/2023			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-350				
<b>Tank Code</b>	11	<b>Tank Age</b>	32	<b>Tank Installed Date</b>	05/01/1994	<b>Tank Material</b>	Cathodically Protected Steel	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	2402	<b>Spill Test Date</b>	09/27/2023	<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Temporarily Out of Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Galvanic
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>	03/12/2024	<b>Tank/Piping CP Test Date</b>	06/16/2021	<b>Primary Tank Leak Detection</b>	Statistical Inventory Reconciliation	<b>Primary Pipe Detection</b>	Statistical Inventory Reconciliation	<b>Vapor Recovery</b>	No
<b>Capacity</b>	5000	<b>ATG Test Date</b>	03/12/2024	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	09/27/2023			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-350				

<b>Tank Code</b>	12	<b>Tank Age</b>	32	<b>Tank Installed Date</b>	05/01/1994	<b>Tank Material</b>	Cathodically Protected Steel	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	2403	<b>Spill Test Date</b>	03/06/2024	<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Temporarily Out of Use	<b>MLLD Test Date</b>	03/03/2023	<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Mechanical Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Galvanic
<b>Product</b>	Diesel	<b>PLLD Test Date</b>	03/12/2024	<b>Tank/Piping CP Test Date</b>	06/16/2021	<b>Primary Tank Leak Detection</b>	Statistical Inventory Reconciliation	<b>Primary Pipe Detection</b>	Statistical Inventory Reconciliation	<b>Vapor Recovery</b>	No
<b>Capacity</b>	5000	<b>ATG Test Date</b>	03/12/2024	<b>Line Tightness Test Date</b>	03/03/2023	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	03/06/2024			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-350				
<b>Tank Code</b>	13	<b>Tank Age</b>	31	<b>Tank Installed Date</b>	01/01/1995	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	2404	<b>Spill Test Date</b>	09/27/2023	<b>Piping Installed Date</b>		<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Temporarily Out of Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>	03/12/2024	<b>Tank/Piping CP Test Date</b>	12/17/2009	<b>Primary Tank Leak Detection</b>	Statistical Inventory Reconciliation	<b>Primary Pipe Detection</b>	Statistical Inventory Reconciliation	<b>Vapor Recovery</b>	No
<b>Capacity</b>	12000	<b>ATG Test Date</b>	03/12/2024	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>	Continuous Interstitial Monitoring	<b>Secondary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	09/27/2023			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-350				
<b>Tank Code</b>	16	<b>Tank Age</b>	26	<b>Tank Installed Date</b>	11/01/2000	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Ball Float Valve
<b>Tag Number</b>	4232	<b>Spill Test Date</b>	03/06/2024	<b>Piping Installed Date</b>		<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Diesel	<b>PLLD Test Date</b>	03/12/2024	<b>Tank/Piping CP Test Date</b>	12/17/2009	<b>Primary Tank Leak Detection</b>	Statistical Inventory Reconciliation	<b>Primary Pipe Detection</b>	Statistical Inventory Reconciliation	<b>Vapor Recovery</b>	No
<b>Capacity</b>	15000	<b>ATG Test Date</b>	03/12/2024	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>	Continuous Interstitial Monitoring	<b>Secondary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	09/27/2023			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-350				
<b>Tank Code</b>	17	<b>Tank Age</b>	26	<b>Tank Installed Date</b>	11/01/2000	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Ball Float Valve
<b>Tag Number</b>	4233	<b>Spill Test Date</b>	03/06/2024	<b>Piping Installed Date</b>		<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No

<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Diesel	<b>PLLD Test Date</b>	03/12/2024	<b>Tank/Piping CP Test Date</b>	12/17/2009	<b>Primary Tank Leak Detection</b>	Statistical Inventory Reconciliation	<b>Primary Pipe Detection</b>	Statistical Inventory Reconciliation	<b>Vapor Recovery</b>	No
<b>Capacity</b>	15000	<b>ATG Test Date</b>	03/12/2024	<b>Line Tightness Test Date</b>	10/13/2022	<b>Secondary Tank Leak Detection</b>	Continuous Interstitial Monitoring	<b>Secondary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	09/27/2023			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-350				
<b>Tank Code</b>	18	<b>Tank Age</b>	26	<b>Tank Installed Date</b>	11/01/2000	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Ball Float Valve
<b>Tag Number</b>	4234	<b>Spill Test Date</b>	03/06/2024	<b>Piping Installed Date</b>		<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Diesel	<b>PLLD Test Date</b>	06/16/2022	<b>Tank/Piping CP Test Date</b>	12/17/2009	<b>Primary Tank Leak Detection</b>	Statistical Inventory Reconciliation	<b>Primary Pipe Detection</b>	Statistical Inventory Reconciliation	<b>Vapor Recovery</b>	No
<b>Capacity</b>	15000	<b>ATG Test Date</b>	06/06/2022	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>	Continuous Interstitial Monitoring	<b>Secondary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	06/16/2021			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-350				
<b>Tank Code</b>	19	<b>Tank Age</b>	26	<b>Tank Installed Date</b>	11/01/2000	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Ball Float Valve
<b>Tag Number</b>	4235	<b>Spill Test Date</b>	09/27/2023	<b>Piping Installed Date</b>		<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Diesel	<b>PLLD Test Date</b>	03/12/2024	<b>Tank/Piping CP Test Date</b>	12/17/2009	<b>Primary Tank Leak Detection</b>	Statistical Inventory Reconciliation	<b>Primary Pipe Detection</b>	Statistical Inventory Reconciliation	<b>Vapor Recovery</b>	No
<b>Capacity</b>	10000	<b>ATG Test Date</b>	03/12/2024	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>	Continuous Interstitial Monitoring	<b>Secondary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	09/27/2023			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-350				
<b>Tank Code</b>	20	<b>Tank Age</b>	26	<b>Tank Installed Date</b>	11/01/2000	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Ball Float Valve
<b>Tag Number</b>	4236	<b>Spill Test Date</b>	09/27/2023	<b>Piping Installed Date</b>		<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Diesel, Dyed	<b>PLLD Test Date</b>	03/12/2024	<b>Tank/Piping CP Test Date</b>	12/17/2009	<b>Primary Tank Leak Detection</b>	Statistical Inventory Reconciliation	<b>Primary Pipe Detection</b>	Statistical Inventory Reconciliation	<b>Vapor Recovery</b>	No

<b>Capacity</b>	5000	<b>ATG Test Date</b>	03/12/2024	<b>Line Tightness Test Date</b>	12/11/2023	<b>Secondary Tank Leak Detection</b>	Continuous Interstitial Monitoring	<b>Secondary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	09/27/2023			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-350				
<b>Tank Code</b>	21	<b>Tank Age</b>	0	<b>Tank Installed Date</b>		<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	High Level Alarm
<b>Tag Number</b>	5385	<b>Spill Test Date</b>		<b>Piping Installed Date</b>	08/14/2012	<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Non Regulated	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	
<b>Product</b>	DEF (Not Regulated)	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.1;Continuous Interstitial Monitoring;Deferred	<b>Primary Pipe Detection</b>	Approved Remote Monitoring;Deferred;Statistical Inventory Reconciliation	<b>Vapor Recovery</b>	No
<b>Capacity</b>	10000	<b>ATG Test Date</b>		<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>	Continuous Interstitial Monitoring;Not Listed	<b>Energy Act</b>	No
		<b>Overfill Test Date</b>				<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
<b>Tank Code</b>	22	<b>Tank Age</b>	2	<b>Tank Installed Date</b>	12/12/2024	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	
<b>Tag Number</b>	6277	<b>Spill Test Date</b>	04/29/2025	<b>Piping Installed Date</b>	12/12/2024	<b>Tank Construction</b>		<b>Piping Construction</b>		<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Statistical Inventory Reconciliation	<b>Primary Pipe Detection</b>	Statistical Inventory Reconciliation	<b>Vapor Recovery</b>	Yes
<b>Capacity</b>	30000	<b>ATG Test Date</b>	04/29/2025	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>	Continuous Interstitial Monitoring	<b>Secondary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Energy Act</b>	Yes
		<b>Overfill Test Date</b>	04/29/2025			<b>ATG Type</b>					
<b>Tank Code</b>	23	<b>Tank Age</b>	2	<b>Tank Installed Date</b>	12/12/2024	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	
<b>Tag Number</b>	6278	<b>Spill Test Date</b>	04/29/2025	<b>Piping Installed Date</b>	12/12/2024	<b>Tank Construction</b>		<b>Piping Construction</b>		<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	
<b>Product</b>	Diesel	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Statistical Inventory Reconciliation	<b>Primary Pipe Detection</b>	Statistical Inventory Reconciliation	<b>Vapor Recovery</b>	No

<b>Capacity</b>	30000	<b>ATG Test Date</b>	04/29/2025	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>	Continuous Interstitial Monitoring	<b>Secondary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Energy Act</b>	Yes
		<b>Overfill Test Date</b>	04/29/2025			<b>ATG Type</b>					
<b>Tank Code</b>	24	<b>Tank Age</b>	2	<b>Tank Installed Date</b>	12/12/2024	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	
<b>Tag Number</b>	6279	<b>Spill Test Date</b>	04/29/2025	<b>Piping Installed Date</b>	12/12/2024	<b>Tank Construction</b>		<b>Piping Construction</b>		<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	
<b>Product</b>	Gasoline, E10	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Statistical Inventory Reconciliation	<b>Primary Pipe Detection</b>	Statistical Inventory Reconciliation	<b>Vapor Recovery</b>	Yes
<b>Capacity</b>	20000	<b>ATG Test Date</b>	04/29/2025	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>	Continuous Interstitial Monitoring	<b>Secondary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Energy Act</b>	Yes
		<b>Overfill Test Date</b>	04/29/2025			<b>ATG Type</b>					
<b>Tank Code</b>	25	<b>Tank Age</b>	2	<b>Tank Installed Date</b>	12/12/2024	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	
<b>Tag Number</b>	6280	<b>Spill Test Date</b>	04/29/2025	<b>Piping Installed Date</b>	12/12/2024	<b>Tank Construction</b>		<b>Piping Construction</b>		<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Statistical Inventory Reconciliation	<b>Primary Pipe Detection</b>	Statistical Inventory Reconciliation	<b>Vapor Recovery</b>	Yes
<b>Capacity</b>	10000	<b>ATG Test Date</b>	04/29/2025	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>	Continuous Interstitial Monitoring	<b>Secondary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Energy Act</b>	Yes
		<b>Overfill Test Date</b>	04/29/2025			<b>ATG Type</b>					
<b>Tank Code</b>	26	<b>Tank Age</b>	1	<b>Tank Installed Date</b>	12/12/2025	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	6281	<b>Spill Test Date</b>	09/08/2025	<b>Piping Installed Date</b>	07/30/2025	<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Diesel, Dyed	<b>PLLD Test Date</b>	09/08/2025	<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Continuous Interstitial Monitoring	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	No
<b>Capacity</b>	7000	<b>ATG Test Date</b>	09/08/2025	<b>Line Tightness Test Date</b>	09/08/2025	<b>Secondary Tank Leak Detection</b>	Statistical Inventory Reconciliation	<b>Secondary Pipe Detection</b>	Statistical Inventory Reconciliation	<b>Energy Act</b>	Yes
		<b>Overfill Test Date</b>	09/08/2025			<b>ATG Type</b>					
<b>Tank Code</b>	27	<b>Tank Age</b>	1	<b>Tank Installed Date</b>	12/12/2025	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Flapper Valve;High Level Alarm

<b>Tag Number</b>	6282	<b>Spill Test Date</b>	09/08/2025	<b>Piping Installed Date</b>	07/30/2025	<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Diesel	<b>PLLD Test Date</b>	09/08/2025	<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Continuous Interstitial Monitoring	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	Yes
<b>Capacity</b>	8000	<b>ATG Test Date</b>	09/08/2025	<b>Line Tightness Test Date</b>	09/08/2025	<b>Secondary Tank Leak Detection</b>	Statistical Inventory Reconciliation	<b>Secondary Pipe Detection</b>	Statistical Inventory Reconciliation	<b>Energy Act</b>	Yes
		<b>Overfill Test Date</b>	09/08/2025			<b>ATG Type</b>					

**Facility Summary in Custer County in the City of Miles City**

**Location:** VA MEDICAL CENTER MILES CITY  
210 S Winchester Ave  
Miles City, MT 59301-4757 Custer

System Facility ID:09-07784

**Facility Code:** 19471  
**Last Inspected On:** 04/29/2025  
**Operating Permit Renewal Date:** 08/02/2028

**Note: Inspection is due 90 days before the Operating Permit Renewal Date.**

**Owner Operator Contact:** VA Medical Center (406) 874-5600

**Operator Contact:** James Arneson;Joseph Dejong (406) 232-3060;(406) 874-5880 james.arneson@va.gov

**Owner/Operator:** VA Medical Center (406) 874-5600

James Arneson, UST Class A Operator

james.arneson@va.gov

James Arneson, UST Class B Global Operator

james.arneson@va.gov

Joseph Dejong, UST Class A Operator

<b>Tank Code</b>	03	<b>Tank Age</b>	45	<b>Tank Installed Date</b>	04/22/1981	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Steel	<b>Overfill Types</b>	High Level Alarm
<b>Tag Number</b>	2191	<b>Spill Test Date</b>	04/29/2025	<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Continuous Interstitial Monitoring	<b>Piping Type</b>	U.S. Suction	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Diesel	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	3-Year Line Tightness Test	<b>Vapor Recovery</b>	No
<b>Capacity</b>	12000	<b>ATG Test Date</b>	04/29/2025	<b>Line Tightness Test Date</b>	04/29/2025	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	04/29/2025			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
<b>Tank Code</b>	04	<b>Tank Age</b>	45	<b>Tank Installed Date</b>	04/22/1981	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Steel	<b>Overfill Types</b>	High Level Alarm
<b>Tag Number</b>	2192	<b>Spill Test Date</b>	04/29/2025	<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Continuous Interstitial Monitoring	<b>Piping Type</b>	U.S. Suction	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Diesel	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	3-Year Line Tightness Test	<b>Vapor Recovery</b>	No
<b>Capacity</b>	12000	<b>ATG Test Date</b>	04/29/2025	<b>Line Tightness Test Date</b>	04/29/2025	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Energy Act</b>	No

		<b>Overfill Test Date</b>	04/29/2025			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
<b>Tank Code</b>	06	<b>Tank Age</b>	34	<b>Tank Installed Date</b>	04/20/1992	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Steel	<b>Overfill Types</b>	High Level Alarm
<b>Tag Number</b>	2193	<b>Spill Test Date</b>	04/29/2025	<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Continuous Interstitial Monitoring	<b>Piping Type</b>	U.S. Suction	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Diesel	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	3-Year Line Tightness Test	<b>Vapor Recovery</b>	No
<b>Capacity</b>	4000	<b>ATG Test Date</b>	04/29/2025	<b>Line Tightness Test Date</b>	04/29/2025	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	04/29/2025			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
<b>Tank Code</b>	07	<b>Tank Age</b>	34	<b>Tank Installed Date</b>	11/17/1992	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Steel	<b>Overfill Types</b>	High Level Alarm
<b>Tag Number</b>	2194	<b>Spill Test Date</b>		<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Temporarily Out of Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Continuous Interstitial Monitoring	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Diesel	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	No
<b>Capacity</b>	2000	<b>ATG Test Date</b>		<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>				<b>ATG Type</b>					

## Facility Summary in Custer County in the City of Miles City

**Location:** ZIP TRIP 59  
1321 S Haynes Ave  
Miles City, MT 59301-5733 Custer

System Facility ID:09-08212

**Facility Code:** 19475  
**Last Inspected On:** 11/18/2024  
**Operating Permit Renewal Date:** 11/18/2027

**Note: Inspection is due 90 days before the Operating Permit Renewal Date.**

---

**Owner Operator Contact:** CHS Inc Spokane Valley (509) 535-7701 jim.alford@chsinc.com

---

**Operator Contact:** Jim Alford;Sean Hurley (509) 535-7701;(509) 536-7418 jim.alford@chsinc.com;sean.hurley@chsinc.com

---

**Owner/Operator:** CHS Inc Spokane Valley (509) 535-7701 jim.alford@chsinc.com

Jim Alford, UST Class A Operator Jim Alford, UST Class B Operator Luci Tuttle, UST Class B Operator Nicholas Merritt, UST Class B Operator Sean Hurley, UST Class A Operator	jim.alford@chsinc.com jim.alford@chsinc.com jim.alford@chsinc.com Lucinda.Tuttle@chsinc.com nicholas.merritt@chsinc.com sean.hurley@chsinc.com
--	---

<b>Tank Code</b>	14	<b>Tank Age</b>	3	<b>Tank Installed Date</b>	09/11/2023	<b>Tank Material</b>	Steel Clad	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Flapper Valve;High Level Alarm
<b>Tag Number</b>	6131	<b>Spill Test Date</b>	09/19/2023	<b>Piping Installed Date</b>	09/11/2023	<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Continuous Interstitial Monitoring	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	Yes
<b>Capacity</b>	10000	<b>ATG Test Date</b>	08/06/2024	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Secondary Pipe Detection</b>	ELLD 0.2	<b>Energy Act</b>	Yes
		<b>Overfill Test Date</b>	08/06/2024			<b>ATG Type</b>					
<b>Tank Code</b>	15	<b>Tank Age</b>	3	<b>Tank Installed Date</b>	09/11/2023	<b>Tank Material</b>	Steel Clad	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Flapper Valve;High Level Alarm
<b>Tag Number</b>	6132	<b>Spill Test Date</b>	09/19/2023	<b>Piping Installed Date</b>	09/11/2023	<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Continuous Interstitial Monitoring	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	Yes
<b>Capacity</b>	30000	<b>ATG Test Date</b>	08/06/2024	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Secondary Pipe Detection</b>	ELLD 0.2	<b>Energy Act</b>	Yes

		<b>Overfill Test Date</b>	08/06/2024			<b>ATG Type</b>					
<b>Tank Code</b>	16	<b>Tank Age</b>	3	<b>Tank Installed Date</b>	09/11/2023	<b>Tank Material</b>	Steel Clad	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Flapper Valve;High Level Alarm
<b>Tag Number</b>	6133	<b>Spill Test Date</b>	09/19/2023	<b>Piping Installed Date</b>	09/11/2023	<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	
<b>Product</b>	Diesel	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Continuous Interstitial Monitoring	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	No
<b>Capacity</b>	10000	<b>ATG Test Date</b>	08/06/2024	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Secondary Pipe Detection</b>	ELLD 0.2	<b>Energy Act</b>	Yes
		<b>Overfill Test Date</b>	08/06/2024			<b>ATG Type</b>					
<b>Tank Code</b>	17	<b>Tank Age</b>	3	<b>Tank Installed Date</b>	09/11/2023	<b>Tank Material</b>	Steel Clad	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Flapper Valve;High Level Alarm
<b>Tag Number</b>	6134	<b>Spill Test Date</b>	09/19/2023	<b>Piping Installed Date</b>	09/11/2023	<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Continuous Interstitial Monitoring	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	Yes
<b>Capacity</b>	10000	<b>ATG Test Date</b>	08/06/2024	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Secondary Pipe Detection</b>	ELLD 0.2	<b>Energy Act</b>	Yes
		<b>Overfill Test Date</b>	08/06/2024			<b>ATG Type</b>					
<b>Tank Code</b>	18	<b>Tank Age</b>	3	<b>Tank Installed Date</b>	09/11/2023	<b>Tank Material</b>	Steel Clad	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Flapper Valve;High Level Alarm
<b>Tag Number</b>	6135	<b>Spill Test Date</b>	09/19/2023	<b>Piping Installed Date</b>	09/11/2023	<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	
<b>Product</b>	Diesel, Dyed	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Continuous Interstitial Monitoring	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	No
<b>Capacity</b>	10000	<b>ATG Test Date</b>	08/06/2024	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Secondary Pipe Detection</b>	ELLD 0.2	<b>Energy Act</b>	Yes
		<b>Overfill Test Date</b>	08/06/2024			<b>ATG Type</b>					
<b>Tank Code</b>	19	<b>Tank Age</b>	3	<b>Tank Installed Date</b>	09/11/2023	<b>Tank Material</b>	Steel Clad	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Flapper Valve;High Level Alarm
<b>Tag Number</b>	6137	<b>Spill Test Date</b>	01/21/2026	<b>Piping Installed Date</b>	09/11/2023	<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No

<b>Tank Status</b>	<b>Currently in Use</b>	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	
<b>Product</b>	Diesel	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Continuous Interstitial Monitoring	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	No
<b>Capacity</b>	30000	<b>ATG Test Date</b>	08/06/2024	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Secondary Pipe Detection</b>	ELLD 0.2	<b>Energy Act</b>	Yes
		<b>Overfill Test Date</b>	08/06/2024			<b>ATG Type</b>					