

Facility Summary in Custer County in the City of Miles City

Location: CENEX ZIP TRIP #75
1815 S Haynes Ave
Miles City, MT 59301 Custer

Legacy ID:60-15272

Facility ID: 30983
Last Inspected On: 10/10/2019
Operating Permit Renewal Date: 01/06/2020

Owner Operator Contact: CHS Inc dba Cenex Zip Trip #75

Operator Contact: Jim Alford;Sean Hurley

5095357701;5095367418

Owner/Operator: CHS Inc dba Cenex Zip Trip #75

Darcy Ziegler, UST Class B Global Operator
Jim Alford, UST Class A Operator
Jim Alford, UST Class B Global Operator
Sean Hurley, UST Class A Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
01	5	08/15/2016	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm;Positive Shutoff
5630	No	07/20/2016	Double-Walled	Double Walled	Yes
Currently in Use		08/15/2016	Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel			Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	Continuous Interstitial Monitoring;ELLD 0.2	No
25,000			Gilbarco-Veeder Root/TLS- 450;Veeder Root/TLS-450		Yes
02	5	08/15/2016	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm;Positive Shutoff
5631	No	07/20/2016	Double-Walled	Double Walled	Yes
Currently in Use		08/15/2016	Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel			Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	Continuous Interstitial Monitoring;ELLD 0.2	No
25,000			Gilbarco-Veeder Root/TLS- 450;Veeder Root/TLS-450		Yes
03	5	08/15/2016	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm;Positive Shutoff

5632	No	07/20/2016	Double-Walled	Double Walled	Yes
Currently in Use		08/15/2016	Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel			Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	Continuous Interstitial Monitoring;ELLD 0.2	No
25,000			Gilbarco-Veeder Root/TLS- 450;Veeder Root/TLS-450		Yes
04	5	08/15/2016	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm;Positive Shutoff
5633	No	07/20/2016	Double-Walled	Double Walled	Yes
Currently in Use		08/15/2016	Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	Continuous Interstitial Monitoring;ELLD 0.2	No
25,000			Gilbarco-Veeder Root/TLS- 450;Veeder Root/TLS-450		Yes
05	5	08/15/2016	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm;Positive Shutoff
5634	No	07/20/2016	Double-Walled	Double Walled	Yes
Currently in Use		08/15/2016	Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel			Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	Continuous Interstitial Monitoring;ELLD 0.2	No
8,000			Gilbarco-Veeder Root/TLS- 450;Veeder Root/TLS-450		Yes
06	5	08/15/2016	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm;Positive Shutoff
5635	No	07/20/2016	Double-Walled	Double Walled	Yes
Currently in Use		08/15/2016	Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	Continuous Interstitial Monitoring;ELLD 0.2	No
10,000			Gilbarco-Veeder Root/TLS- 450;Veeder Root/TLS-450		Yes
07	5	08/15/2016	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm;Positive Shutoff
5636	No	07/20/2016	Double-Walled	Double Walled	Yes

Currently in Use	08/15/2016	Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel		Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	Continuous Interstitial Monitoring;ELLD 0.2	No
8,000		Gilbarco-Veeder Root/TLS- 450;Veeder Root/TLS-450		Yes

Facility Summary in Custer County in the City of Miles City

Location: ENTERPRISE SYSTEMS SERVICE CENTER
114 S Haynes Ave
Miles City, MT 59301 Custer

Legacy ID:60-15140

Facility ID: 30884
Last Inspected On: 06/05/2019
Operating Permit Renewal Date: 09/18/2022

Owner Operator Contact: MT Dept of Administration ITSD

4064442700

Operator Contact: Ed Sivils;John Salazar;Michael Krings

Owner/Operator: MT Dept of Administration ITSD

- Ed Sivils, UST Class A Operator
- Ed Sivils, UST Class B Operator
- John Salazar, UST Class A Operator
- John Salazar, UST Class B Operator
- Michael Krings, UST Class A Operator
- Mike Kennell, UST Class B Global Operator
- Randy Anderson, UST Class B Global Operator
- Rennette Waldo, UST Class B Operator
- Zane Rudolph, UST Class B Global Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
S1	12	07/21/2009	Unknown	Flexible Plastic	High Level Alarm
5215	Yes	07/29/2016	Double-Walled	Double Walled	Yes
Currently in Use		07/21/2009	Continuous Interstitial Monitoring	Pressurized	
Diesel			Deferred	Continuous Interstitial Monitoring	No
4,000					Yes

Facility Summary in Custer County in the City of Miles City

Location: FRANKS QUICK STOP LLC
1308 S Haynes Ave
Miles City, MT 59301 Custer

Legacy ID:09-00624

Facility ID: 19399
Last Inspected On: 11/16/2020
Operating Permit Renewal Date: 02/13/2024

Owner Operator Contact: Dennis Whitmore;Grunstead Whitmore LLP

4066515101

Operator Contact: Frank Ngo

4068531991

Owner/Operator: Franks Quick Stop LLC

Frank Ngo, UST Class A Operator
Jason South, UST Class B Global Operator
Jeremy Thomas, UST Class B Global Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
08	31	07/01/1990	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve;High Level Alarm
1788	No			None	Yes
Currently in Use		09/27/2007	Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		02/20/2017	Automatic Tank Gauging 0.2	ELLD 0.1;ELLD 0.2	No
8,000		06/22/2017	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
09	31	07/01/1990	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve;High Level Alarm
1789	No			None	Yes
Currently in Use		09/27/2007	Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		02/20/2017	Automatic Tank Gauging 0.2	ELLD 0.1;ELLD 0.2	No
8,000		06/14/2017	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
10	31	07/01/1990	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve;High Level Alarm
1790	No			None	Yes

Currently in Use	09/27/2007	Electronic Line Leak Detector	Pressurized	Impressed Current
Diesel	02/20/2017	Automatic Tank Gauging 0.2	ELLD 0.1;ELLD 0.2	No
8,000	06/12/2017	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No

Facility Summary in Custer County in the City of Miles City

Location: FRANK'S SHORT STOP II
305 Main St
Miles City, MT 59301 Custer

Legacy ID:09-07083

Facility ID: 19462
Last Inspected On: 01/30/2020
Operating Permit Renewal Date: 06/08/2023

Owner Operator Contact: Frank's Short Stop;Jerry Eide;Cenex Harvest States
Jerry Eide **4065438383;4068531991**

Operator Contact: Frank Ngo **4068531991**

Owner/Operator: Frank's Short Stop

- Amy Stinson, UST Class B Global Operator
- Dyna Bennett, UST Class B Operator
- Frank Ngo, UST Class A Operator
- Frank Ngo, UST Class B Operator
- Gordon Dorothy, UST Class B Operator
- Jodien Twardoski, UST Class B Operator
- Randall Morgan, UST Class B Operator
- Theresa Bradshaw, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
10	24	10/01/1997	Cathodically Protected Steel	Flexible Plastic	Flapper Valve
595	No			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		02/20/2017	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring;ELLD Line Tightness Testing	No
15,000			Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
11	24	10/01/1997	Cathodically Protected Steel	Flexible Plastic	Flapper Valve

596	No			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		02/20/2017	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring; ELLD Line Tightness Testing	No
8,000			Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
12	24	10/01/1997	Cathodically Protected Steel	Flexible Plastic	Flapper Valve
597	No			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		02/20/2017	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring; ELLD Line Tightness Testing	No
6,000			Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No

Facility Summary in Custer County in the City of Miles City

Location: GM PETROLEUM DISTRIBUTORS
500 N 5th St
Miles City, MT 59301-2306 Custer

Legacy ID:09-05859

Facility ID: 19449
Last Inspected On: 10/11/2019
Operating Permit Renewal Date: 11/15/2022

Owner Operator Contact: City Service Valcon LLC; Dennis Whitmore; Petro Services Co Inc

4066515101

Operator Contact: Bill Grunstead; Roger Schmechel

4062083147

Owner/Operator: City Service Valcon LLC

Owner/Operator: City Service Valcon LLC DBA GM Petroleum Distributors

- Bill Grunstead, UST Class A Operator
- Roger Schmechel, UST Class A Operator
- Roger Schmechel, UST Class B Operator
- Bill Grunstead, UST Class A Operator
- Laura Geffre, UST Class A Operator
- Laura Geffre, UST Class B Operator
- Roger Schmechel, UST Class A Operator
- Roger Schmechel, UST Class B Operator
- Jay Brookie, UST Class A Operator
- Jay Brookie, UST Class B Global Operator
- Laura Geffre, UST Class A Operator
- Laura Geffre, UST Class B Operator
- Margaret Flynn, UST Class A Operator

Margaret Flynn, UST Class B Operator
 Roger Schmechel, UST Class A Operator
 Roger Schmechel, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
S5	23	11/01/1998	Bare Steel	Steel	
4009	Yes			None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	
Gasoline		07/12/2016	Deferred	ELLD 0.1;ELLD 0.2	No
17,335		07/12/2016			No
S6	23	11/01/1998	Bare Steel	Steel	
4010	Yes			None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	
Diesel		07/12/2016	Deferred	ELLD 0.1;ELLD 0.2	No
17,335		07/12/2016			No
S7	23	11/01/1998	Bare Steel	Steel	
4011	Yes			None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	
Diesel		07/12/2016	Deferred	ELLD 0.1;ELLD 0.2	No
17,335		07/12/2016			No
S8	23	11/01/1998	Bare Steel	Steel	
4012	Yes			None	Yes

Currently in Use		Electronic Line Leak Detector	Pressurized	
Gasoline	07/12/2016	Deferred	ELLD 0.1;ELLD 0.2	No
10,123	07/12/2016			No

Facility Summary in Custer County in the City of Miles City

Location: HOLY ROSARY HOSPITAL WILSON ST
2600 Wilson St
Miles City, MT 59301 Custer

Legacy ID:09-13574

Facility ID: 19513
Last Inspected On: 12/04/2018
Operating Permit Renewal Date: 02/10/2022

Owner Operator Contact: Holy Rosary Hospital

4062332600

Operator Contact: Douglas Treu;Mike Ryan

4062332747

Owner/Operator: Holy Rosary Hospital

Douglas Treu, UST Class A Operator
Mike Ryan, UST Class A Operator
Shad Waldo, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
01	27	08/01/1994	Steel Clad	Flexible Plastic	Flapper Valve
4284	No	12/04/2018	Double-Walled	Double Walled	Yes
Currently in Use			Auto Dialer	U.S. Suction	
Diesel			Continuous Interstitial Monitoring	Continuous Interstitial Monitoring	No
8,000					No

Facility Summary in Custer County in the City of Miles City

Location: M and H GAS MILES CITY
1019 Main St
Miles City, MT 59301 Custer

Legacy ID:09-01058

Facility ID: 19402
Last Inspected On: 04/15/2021
Operating Permit Renewal Date: 06/23/2024

Owner Operator Contact: Kim Haggerty;Miller and Holmes Inc;Miller and Holmes Inc **7153771730**

Operator Contact: Kevin Junker

Owner/Operator: Miller and Holmes Inc

Charles Kauffman, UST Class B Global Operator
 Dave Lunder, UST Class B Operator
 Debra Agnew, UST Class B Global Operator
 Kevin Junker, UST Class A Operator
 Kevin Junker, UST Class B Operator
 Sandy Maine, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
04	27	10/01/1994	Cathodically Protected Steel	Flexible Plastic	Flapper Valve
1613	No			Double Walled	Yes
Currently in Use		05/27/2008	Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		01/22/2018	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring; ELLD 0.1; ELLD 0.2	No
15,000		01/15/2018	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
05	27	10/01/1994	Cathodically Protected Steel	Flexible Plastic	Flapper Valve
1614	No			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		01/22/2018	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring; ELLD 0.1; ELLD 0.2	No
15,000		01/15/2018	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
06	27	10/01/1994	Cathodically Protected Steel	Flexible Plastic	Flapper Valve
1615	No			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		01/22/2018	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring; ELLD 0.1; ELLD 0.2	No

7,500		01/14/2018	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
07	27	10/01/1994	Cathodically Protected Steel	Flexible Plastic	Flapper Valve
1616	No			Double Walled	No
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		01/22/2018	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring;ELLD 0.1;ELLD 0.2	No
7,500		01/14/2018	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No

Facility Summary in Custer County in the City of Miles City

Location: MILES CITY BULK PLANT
S 4th St & Pacific Ave
Miles City, MT 59301-1440 Custer

Legacy ID:09-03211

Facility ID: 19419
Last Inspected On: 06/11/2021
Operating Permit Renewal Date: 08/03/2024

Owner Operator Contact: Cenex Harvest States Sidney

4062341350

Operator Contact: Parker Murnion

4062342350

Owner/Operator: Cenex Harvest States Sidney

Parker Murnion, UST Class A Operator
Randy Bickle, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
01	44	03/26/1977	Bare Steel	No Piping	Flapper Valve
3586	No			None	Yes
Currently in Use			Not Required	Pressurized	Impressed Current
Diesel		08/04/2017	Automatic Tank Gauging 0.2	Deferred	No
11,000			Veeder Root/TLS-300		No
02	44	03/26/1977	Bare Steel	No Piping	Flapper Valve
3587	No			None	Yes

Currently in Use			Not Required	Pressurized	Impressed Current
Gasoline		08/04/2017	Automatic Tank Gauging 0.2	Deferred	No
11,000			Veeder Root/TLS-300		No
04	44	03/26/1977	Bare Steel	No Piping	Flapper Valve
3588	No			None	Yes
Currently in Use			Not Required	Pressurized	Impressed Current
Gasoline		08/04/2017	Automatic Tank Gauging 0.2	Deferred	No
11,000			Veeder Root/TLS-300		No
05	44	03/26/1977	Bare Steel	No Piping	Flapper Valve
3589	No			None	Yes
Currently in Use			Not Required	Pressurized	Impressed Current
Diesel		08/04/2017	Automatic Tank Gauging 0.2	Deferred	No
11,000			Veeder Root/TLS-300		No
06	44	03/26/1977	Bare Steel	No Piping	Flapper Valve
3590	No			None	Yes
Currently in Use			Not Required	Pressurized	Impressed Current
Diesel		08/04/2017	Automatic Tank Gauging 0.2	Deferred	No
11,000			Veeder Root/TLS-300		No
03	44	03/26/1977	Bare Steel	No Piping	Flapper Valve
3764	No			None	Yes
Currently in Use			Not Required	Pressurized	Impressed Current
Diesel		08/04/2017	Automatic Tank Gauging 0.2	Deferred	No
11,000			Veeder Root/TLS-300		No

Facility Summary in Custer County in the City of Miles City

Location: QWEST MILES CITY CENTRAL OFFICE
811 Pleasant St
Miles City, MT 59301-3229 Custer

Legacy ID:09-08778

Facility ID: 19484
Last Inspected On: 09/08/2020
Operating Permit Renewal Date: 03/05/2024

Owner Operator Contact: Qwest Corporation/Century Link

Operator Contact: Kevin Robison;Stephanie Miller;Thomas Pitts **2063467532;5016808141;8015983020**

Owner/Operator: Qwest Corporation/Century Link

- Kevin Robison, UST Class A Operator
- Kevin Robison, UST Class B Global Operator
- Kevin Robison, UST Class B Operator
- Stephanie Miller, UST Class A Operator
- Stephanie Miller, UST Class B Global Operator
- Thomas Pitts, UST Class A Operator
- Thomas Pitts, UST Class B Global Operator
- Thomas Pitts, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
01	28	05/01/1993	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
1725	No		Double-Walled	Double Walled	Yes
Currently in Use			Auto Dialer	U.S. Suction	Non-corrodible
Diesel			Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	3-Year Line Tightness Test	No
553		07/29/2016	Veeder Root/TLS-300		No

Facility Summary in Custer County in the City of Miles City

Location: THE SHORT STOP STORE
16 N 7th St
Miles City, MT 59301-3110 Custer

Legacy ID:09-04443

Facility ID: 19431
Last Inspected On: 01/30/2020
Operating Permit Renewal Date: 06/19/2023

Owner Operator Contact: Frank Ngo;Frank Ngo;The Short Stop Store

4068531991;4068531991;4062326661

Operator Contact: Frank Ngo **4068531991**

Owner/Operator: Frank Ngo

Owner/Operator: Teresa Newby

Frank Ngo, UST Class A Operator

Frank Ngo, UST Class B Operator

Frankie Meade, UST Class B Operator

Tony Russo, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
07	11	12/17/2010	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve
5284	No		Double-Walled	Double Walled	Yes
Currently in Use		11/29/2010	Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	Continuous Interstitial Monitoring;ELLD 0.1;ELLD 0.2	No
10,000		09/17/2016	Gilbarco-Veeder Root/TLS- 350;Gilbarco-Veeder Root/TLS- 350/Gilbarco EMC		Yes
08	11	12/17/2010	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve
5285	No		Double-Walled	Double Walled	Yes
Currently in Use		11/29/2010	Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	Continuous Interstitial Monitoring;ELLD 0.1;ELLD 0.2	No
5,000		09/17/2016	Gilbarco-Veeder Root/TLS- 350;Gilbarco-Veeder Root/TLS- 350/Gilbarco EMC		Yes

Facility Summary in Custer County in the City of Miles City

Location: TOWN PUMP OF MILES CITY
1210 S Haynes Ave
Miles City, MT 59301 Custer

Legacy ID:09-07081

Facility ID: 19460
Last Inspected On: 02/14/2019
Operating Permit Renewal Date: 04/27/2022

Owner Operator Contact: Don Edmisten;Western Catering Services Inc

4064976948;4064976700

Operator Contact: Daniel Sampson

Owner/Operator: Miles City 1 Town Pump LLC

Daniel Sampson, UST Class A Operator
 Daniel Sampson, UST Class B Global Operator
 Don Edmisten, UST Class B Global Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
10	27	05/01/1994	Cathodically Protected Steel	Flexible Plastic	Flapper Valve
2401	No			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		12/07/2018	Approved Remote Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
12,000			Gilbarco-Veeder Root/TLS-350		No
11	27	05/01/1994	Cathodically Protected Steel	Flexible Plastic	Flapper Valve
2402	No			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		12/07/2018	Approved Remote Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
5,000			Gilbarco-Veeder Root/TLS-350		No
12	27	05/01/1994	Cathodically Protected Steel	Flexible Plastic	Flapper Valve
2403	No			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic

Diesel		12/07/2018	Approved Remote Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
5,000			Gilbarco-Veeder Root/TLS-350		No
13	26	01/01/1995	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve
2404	No		Double-Walled	Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	
Gasoline		12/17/2009	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
12,000			Gilbarco-Veeder Root/TLS-350		No
16	21	11/01/2000	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4232	No		Double-Walled	Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	
Diesel		12/17/2009	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
15,000			Gilbarco-Veeder Root/TLS-350		No
17	21	11/01/2000	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4233	No		Double-Walled	Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	
Diesel		12/17/2009	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
15,000			Gilbarco-Veeder Root/TLS-350		No
18	21	11/01/2000	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4234	No		Double-Walled	Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	

Diesel		12/17/2009	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
15,000			Gilbarco-Veeder Root/TLS-350		No
19	21	11/01/2000	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4235	No		Double-Walled	Double Walled	Yes
Currently in Use		02/22/2013	Electronic Line Leak Detector	Pressurized	
Diesel		12/17/2009	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
10,000			Gilbarco-Veeder Root/TLS-350		No
20	21	11/01/2000	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4236	No		Double-Walled	Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	
Diesel		12/17/2009	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
5,000			Gilbarco-Veeder Root/TLS-350		No
14	26	01/01/1995	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve
4890	No		Double-Walled	Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	
Gasoline		12/17/2009	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
12,000			Gilbarco-Veeder Root/TLS-350		No
15	26	01/01/1995	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve
4891	No		Double-Walled	Double Walled	Yes
Currently in Use		02/22/2013	Electronic Line Leak Detector	Pressurized	

Diesel	12/17/2009	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
10,000		Gilbarco-Veeder Root/TLS-350		No

Facility Summary in Custer County in the City of Miles City

Location: VA MEDICAL CENTER MILES CITY
210 S Winchester Ave
Miles City, MT 59301-4757 Custer

Legacy ID:09-07784

Facility ID: 19471
Last Inspected On: 06/14/2019
Operating Permit Renewal Date: 08/02/2022

Owner Operator Contact: VA Medical Center

4062323060

Operator Contact: James Arneson;Joseph Dejong

4062323060

Owner/Operator: VA Medical Center

James Arneson, UST Class A Operator
James Arneson, UST Class B Global Operator
Joseph Dejong, UST Class A Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
03	40	04/22/1981	Fiberglass Reinforced Plastic	Steel	High Level Alarm
2191	No			Double Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	U.S. Suction	Non-corrodible
Diesel			Automatic Tank Gauging 0.2	3-Year Line Tightness Test;Continuous Interstitial Monitoring	No
12,000		05/13/2016	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
04	40	04/22/1981	Fiberglass Reinforced Plastic	Steel	High Level Alarm
2192	No			Double Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	U.S. Suction	Non-corrodible
Diesel			Automatic Tank Gauging 0.2	3-Year Line Tightness Test;Continuous Interstitial Monitoring	No

12,000		05/13/2016	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
06	29	04/20/1992	Fiberglass Reinforced Plastic	Steel	High Level Alarm
2193	No			Double Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	U.S. Suction	Non-corrodible
Diesel			Automatic Tank Gauging 0.2	3-Year Line Tightness Test;Continuous Interstitial Monitoring	No
4,000		05/13/2016	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
07	29	11/17/1992	Fiberglass Reinforced Plastic	Steel	High Level Alarm
2194	No			Double Walled	Yes
Temporarily Out of Use			Continuous Interstitial Monitoring	Pressurized	
Diesel			Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring	No
2,000					No