

Facility Summary in Daniels County in the City of Flaxville

Location: PRO CO-OP 3
 MT Hwy 5 & Main St
 Flaxville, MT 59222 Daniels

Legacy ID:10-01331

Facility ID: 19535
Last Inspected On: 06/17/2021
Operating Permit Renewal Date: 09/28/2024

Owner Operator Contact: Pro Coop Scobey

4064872741

Operator Contact: Tanner Trower

4064872741

Owner/Operator: Pro Coop Scobey

- Jason Nasby, UST Class B Operator
- Kent Cromwell, UST Class B Operator
- Richard Carrier, UST Class B Operator
- Tanner Trower, UST Class A Operator
- Tanner Trower, UST Class B Global Operator
- Tanner Trower, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
04	30	07/31/1991	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve
1225	No			Double Walled	Yes
Currently in Use		02/01/2013	Not Required	Safe Suction	Galvanic
Gasoline		08/19/2015	Automatic Tank Gauging 0.2	Deferred	No
2,000			Gilbarco-Veeder Root/Other		No
05	30	07/31/1991	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve
1226	No			Double Walled	Yes
Currently in Use		02/01/2013	Not Required	Safe Suction	Galvanic
Gasoline		08/19/2015	Automatic Tank Gauging 0.2	Deferred	No
2,000			Gilbarco-Veeder Root/Other		No

S6	8	02/01/2013	Bare Steel	Fiberglass Reinforced Plastic	High Level Alarm
5408	Yes	12/09/2015		Double Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Non-corrodible
Diesel			Deferred	Continuous Interstitial Monitoring	No
12,000					Yes
S7	8	02/01/2013	Bare Steel	Fiberglass Reinforced Plastic	High Level Alarm
5409	Yes	12/09/2015		Double Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Non-corrodible
Gasoline			Deferred	Continuous Interstitial Monitoring	No
12,000					Yes
S8	8	02/01/2013	Bare Steel	Fiberglass Reinforced Plastic	
5453	Yes	12/09/2015		Double Walled	No
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Non-corrodible
Diesel			Deferred	Continuous Interstitial Monitoring	No
12,000					Yes

Facility Summary in Daniels County in the City of Scobey

Location: CROMWELLS CONVENIENCE and PETROLEUM
101 Railroad Ave W
Scobey, MT 59263 Daniels

Legacy ID:10-01223

Facility ID: 19533
Last Inspected On: 09/21/2021
Operating Permit Renewal Date: 03/09/2025

Owner Operator Contact: Cromwells Convenience and Petroleum

Operator Contact: Shane Cromwell

4064872441

Owner/Operator: Cromwells Convenience and Petroleum

Shane Cromwell, UST Class A Operator
Shane Cromwell, UST Class B Global Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected

Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
S4	25	05/01/1996	Aboveground Tank	Flexible Plastic	
2176	Yes	06/07/2016		Double Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	
Gasoline			Deferred	Continuous Interstitial Monitoring	No
5,800					No
S5	25	05/01/1996	Aboveground Tank	Flexible Plastic	
2177	Yes	06/07/2016		Double Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	
Gasoline			Deferred	Continuous Interstitial Monitoring	No
12,000					No
S6	25	05/01/1996	Aboveground Tank	Flexible Plastic	
2178	Yes	06/07/2016		Double Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	
Diesel, Dyed			Deferred	Continuous Interstitial Monitoring	No
12,000					No
S7	25	05/01/1996	Aboveground Tank	Flexible Plastic	
2179	Yes	06/07/2016		Double Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	
Diesel			Deferred	Continuous Interstitial Monitoring	No
10,000					No

Facility Summary in Daniels County in the City of Scobey

Location: NEMONT COMMUNICATIONS INC
61 Hwy 13 S
Scobey, MT 59263 Daniels

Legacy ID:10-13610

Facility ID: 19682
Last Inspected On: 09/07/2018
Operating Permit Renewal Date: 02/23/2022

Owner Operator Contact: Nemont Communications Inc

4067835654

Operator Contact:

Owner/Operator: Nemont Communications Inc

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
01	26	04/01/1995	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	
3293	No			None	Yes
Currently in Use			Not Required	Gravity Feed	
Oil, Waste			Deferred	Deferred	No
100					No

Facility Summary in Daniels County in the City of Scobey

Location: PRO CO-OP 1
3 Daniels St
Scobey, MT 59263 Daniels

Legacy ID:10-04159

Facility ID: 19572
Last Inspected On: 06/17/2021
Operating Permit Renewal Date: 06/20/2024

Owner Operator Contact: Donavon Boos;Grain Growers Oil Co;Pro Coop Scobey **4064872741**

Operator Contact: Jason Nasby;Tanner Trower

4064872741

Owner/Operator: Pro Coop Scobey

Jason Nasby, UST Class A Operator
Jason Nasby, UST Class B Operator
Kent Cromwell, UST Class B Operator
Tanner Trower, UST Class A Operator
Tanner Trower, UST Class B Global Operator
Tanner Trower, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
-----------	-----	-----------	----------------------------	-----------------	----------------

Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
S11	13	10/10/2008	Unknown	Fiberglass Reinforced Plastic	
5134	Yes	08/18/2015	Double-Walled	Double Walled	Yes
Currently in Use		06/19/2007	Continuous Interstitial Monitoring	Pressurized	
Diesel			Deferred	Continuous Interstitial Monitoring	No
3,000					Yes
S10	13	10/10/2008	Unknown	Fiberglass Reinforced Plastic	
5699	Yes	08/18/2015	Double-Walled	Double Walled	Yes
Currently in Use		06/19/2007	Continuous Interstitial Monitoring	Pressurized	
Gasohol/Ethanol			Deferred	Continuous Interstitial Monitoring	No
3,000					Yes

Facility Summary in Daniels County in the City of Scobey

Location: PRO CO-OP 2
108 1st St
Scobey, MT 59263 Daniels

Legacy ID:10-03710

Facility ID: 19562
Last Inspected On: 06/17/2021
Operating Permit Renewal Date: 06/20/2024

Owner Operator Contact: Pro Coop Scobey **4064872741**

Operator Contact: Jason Nasby;Tanner Trower **4064872741**

Owner/Operator: Pro Coop Scobey

- Jason Nasby, UST Class A Operator
- Jason Nasby, UST Class B Operator
- Kent Cromwell, UST Class B Operator
- Tanner Trower, UST Class A Operator
- Tanner Trower, UST Class B Global Operator
- Tanner Trower, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected

Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
04	27	10/01/1994	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
1227	No	08/18/2015		Double Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		08/18/2015	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring;MLLD Line Tightness Testing	No
12,000			Gilbarco/EMC Basic		No
05	27	10/01/1994	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
1228	No	08/18/2015		Double Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		08/18/2015	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring;MLLD Line Tightness Testing	No
12,000			Gilbarco/EMC Basic		No
06	27	10/01/1994	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
1229	No	08/18/2015		Double Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Diesel		08/18/2015	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring;MLLD Line Tightness Testing	No
12,000			Gilbarco/EMC Basic		No
07	27	10/01/1994	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
1230	No	08/18/2015		Double Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Diesel		08/18/2015	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring;MLLD Line Tightness Testing	No

12,000			Gilbarco/EMC Basic		No
08	27	10/01/1994	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
1231	No	08/18/2015		Double Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Diesel		08/18/2015	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring;MLLD Line Tightness Testing	No
8,000			Gilbarco/EMC Basic		No
09	27	10/01/1994	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
1232	No	08/18/2015		Double Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Diesel		08/18/2015	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring;MLLD Line Tightness Testing	No
4,000			Gilbarco/EMC Basic		No