

Facility Summary in Dawson County in the City of Glendive

Location: BERGS TIRE INC
2111 W Towne St
Glendive, MT 59330-3214 Dawson

Legacy ID:11-03214

Facility ID: 19730
Last Inspected On: 02/11/2019
Operating Permit Renewal Date: 07/20/2022

Owner Operator Contact: Berg Tire

Operator Contact: James Berg

Owner/Operator: Berg Tire

James Berg, UST Class A Operator

James Berg, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
06	34	03/26/1987	Cathodically Protected Steel	Steel	Flapper Valve;High Level Alarm
598	No			None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Diesel		04/26/2016	Automatic Tank Gauging 0.2	ELLD 0.1;ELLD 0.2	No
12,000		04/26/2016	Veeder Root/TLS-450		No
07	34	03/26/1987	Cathodically Protected Steel	Steel	Flapper Valve;High Level Alarm
599	No			None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		04/26/2016	Automatic Tank Gauging 0.2	ELLD 0.1;ELLD 0.2	No
12,000		04/26/2016	Veeder Root/TLS-450		No
08	34	03/26/1987	Cathodically Protected Steel	Steel	Flapper Valve;High Level Alarm
600	No			None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current

Diesel		04/26/2016	Automatic Tank Gauging 0.2	ELLD 0.1;ELLD 0.2	No
6,000		04/26/2016	Veeder Root/TLS-450		No
09	34	03/26/1987	Cathodically Protected Steel	Steel	Flapper Valve;High Level Alarm
601	No			None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		04/26/2016	Automatic Tank Gauging 0.2	ELLD 0.1;ELLD 0.2	No
6,000		04/26/2016	Veeder Root/TLS-450		No

Facility Summary in Dawson County in the City of Glendive

Location: BN GLENDIVE RAIL YARD
310 N Merrill Ave
Glendive, MT 59330-1728 Dawson

Legacy ID:11-09528

Facility ID: 19829
Last Inspected On: 12/26/2019
Operating Permit Renewal Date: 12/04/2022

Owner Operator Contact: BNSF Railway Company Fort Worth

8173332000

Operator Contact: Tavita Masau

7736002860

Owner/Operator: BNSF Railway Company Fort Worth

Tavita Masau, UST Class A Operator
Tavita Masau, UST Class B Global Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
SKC1	30	09/01/1991	Bare Steel	Steel	
505	Yes			Double Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Gravity Feed	
Diesel		09/15/2016	Deferred	Continuous Interstitial Monitoring	No
680,000					No

Facility Summary in Dawson County in the City of Glendive

Location: CROSSROADS CONOCO GLENDIVE
 56 Hwy 16
 Glendive, MT 59330-3609 Dawson

Legacy ID:56-13872

Facility ID: 30551
Last Inspected On: 03/04/2021
Operating Permit Renewal Date: 03/14/2024

Owner Operator Contact: Gregory Cross

Operator Contact: Gregory Cross;R J Serpe;Timothy Fife

Owner/Operator: Greg Cross

Greg Cross, UST Class A Operator
 R J Serpe, UST Class A Operator
 R J Serpe, UST Class B Global Operator
 Ron Serpe, UST Class B Global Operator
 Timothy Fife, UST Class A Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
01	22	06/26/1999	Steel Clad	Flexible Plastic	Flapper Valve;High Level Alarm
4043	No		Double-Walled	Double Walled	Yes
Currently in Use		01/03/2013	Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel			Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring;ELLD 0.2	No
10,000		03/08/2012	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
02	22	06/26/1999	Steel Clad	Flexible Plastic	Flapper Valve;High Level Alarm
4044	No		Double-Walled	Double Walled	Yes
Currently in Use		01/03/2013	Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring;ELLD 0.2	No
15,000		03/08/2012	Gilbarco/EMC Basic		No
03	22	06/26/1999	Steel Clad	Flexible Plastic	Flapper Valve;High Level Alarm
4045	No		Double-Walled	Double Walled	Yes

Currently in Use	01/03/2013	Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline		Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring; ELLD 0.2	No
10,000	03/08/2012	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No

Facility Summary in Dawson County in the City of Glendive

Location: DAWSON COMMUNITY AIRPORT
402 Dry Creek Rd
Glendive, MT 59330-9204 Dawson

Legacy ID:11-02455

Facility ID: 19717
Last Inspected On: 11/18/2020
Operating Permit Renewal Date: 11/24/2023

Owner Operator Contact: Dawson County

Operator Contact: Craig Hostetler;Leon Baker

4063774505;4066873372

Owner/Operator: Dawson County

- Bill Stebbins, UST Class B Operator
- Craig Hostetler, UST Class A Operator
- Craig Hostetler, UST Class B Operator
- Leon Baker, UST Class A Operator
- Leon Baker, UST Class B Global Operator
- Leon Baker, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
04	27	11/21/1994	Cathodically Protected Steel	Steel	Flapper Valve
824	No	07/29/2012		Secondary Containment Chase	Yes
Currently in Use			Auto Dialer;Mechanical Line Leak Detector	Pressurized	Galvanic
Aviation Gas		08/25/2016	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	No
8,000			EMCO Electronics/EECO 1500		No
S5	47	01/01/1974	Unknown	Steel	
825	Yes			None	Yes
Currently in Use			Auto Dialer;Mechanical Line Leak Detector	Pressurized	
Jet Fuel (Jet-A, Jet-A1, JP5)		08/25/2016	Deferred	MLLD Line Tightness Testing	No
10,000		07/31/2018			No

Facility Summary in Dawson County in the City of Glendive

Location: EAST END CENEX
 1803 Merrill Ave
 Glendive, MT 59330 Dawson

Legacy ID:11-00033

Facility ID: 19684
Last Inspected On: 06/11/2021
Operating Permit Renewal Date: 07/21/2024

Owner Operator Contact: Cross Petroleum Services Glendive;Gregory Cross;Cross Petroleum Services Billings

4062525519

Operator Contact: Gregory Cross;R J Serpe;Timothy Fife

Owner/Operator: Cross Petroleum Services Glendive

Greg Cross, UST Class A Operator
 R J Serpe, UST Class A Operator
 R J Serpe, UST Class B Global Operator
 Ron Serpe, UST Class B Global Operator
 Timothy Fife, UST Class A Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
08	6	02/09/2015	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve;High Level Alarm
5535	No	02/05/2015	Double-Walled	Double Walled	Yes
Currently in Use		02/09/2015	Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Automatic Tank Gauging 0.1;Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	Continuous Interstitial Monitoring;ELLD 0.2	Yes
12,000		03/20/2015	Incon/TS-550 EVO		Yes
09	6	02/09/2015	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve;High Level Alarm
5536	No	02/05/2015	Double-Walled	Double Walled	Yes
Currently in Use		02/09/2015	Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel			Automatic Tank Gauging 0.1;Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	Continuous Interstitial Monitoring;ELLD 0.2	No
12,000		03/20/2015	Incon/TS-550 EVO		Yes

10	6	02/09/2015	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve;High Level Alarm
5537	No	02/05/2015	Double-Walled	Double Walled	Yes
Currently in Use		02/09/2015	Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Automatic Tank Gauging 0.1;Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	Continuous Interstitial Monitoring;ELLD 0.2	Yes
8,000		03/20/2015	Incon/TS-550 EVO		Yes
11	6	02/09/2015	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve;High Level Alarm
5538	No	02/05/2015	Double-Walled	Double Walled	Yes
Currently in Use		02/09/2015	Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel			Automatic Tank Gauging 0.1;Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	Continuous Interstitial Monitoring;ELLD 0.2	No
4,000		03/20/2015	Incon/TS-550 EVO		Yes

Facility Summary in Dawson County in the City of Glendive

Location: GLENDIVE COMBUSTION TURBINE
366 FAS 335
Glendive, MT 59330-9575 Dawson

Legacy ID:11-09400

Facility ID: 19827
Last Inspected On: 07/26/2021
Operating Permit Renewal Date: 11/17/2024

Owner Operator Contact: Montana Dakota Utilities Co Bismarck

7012227865

Operator Contact: Clay Olson;Evan Jones;Jim Shields;Kalle Kuether;Sean Cameron

3076963597;4069395341;9705090698

Owner/Operator: Montana Dakota Utilities Co Bismarck

- Chad Miller, UST Class B Operator
- Clay Olson, UST Class A Operator
- Clay Olson, UST Class B Global Operator
- Evan Jones, UST Class A Operator
- Evan Jones, UST Class B Operator
- Jim Shields, UST Class A Operator
- Jim Shields, UST Class B Global Operator
- Jody Gustafson, UST Class B Global Operator
- Kalle Kuether, UST Class A Operator
- Sean Cameron, UST Class A Operator
- Sean Cameron, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
S2	34	07/01/1987	Cathodically Protected Steel	Steel	
1692	Yes	07/02/2018		Double Walled	Yes
Currently in Use		07/13/2007	Auto Dialer	Pressurized	
Diesel			Deferred	Continuous Interstitial Monitoring	No
75,000					No

Facility Summary in Dawson County in the City of Glendive

Location: GLENDIVE MEDICAL CENTER
202 Prospect Dr
Glendive, MT 59330-1943 Dawson

Legacy ID:11-09735

Facility ID: 19832
Last Inspected On: 11/17/2020
Operating Permit Renewal Date: 12/19/2023

Owner Operator Contact: Glendive Medical Center

4063453306

Operator Contact: Mike Ryan;Sam Durham

Owner/Operator: Glendive Medical Center

Craig Torno, UST Class B Operator

Mike Ryan, UST Class A Operator

Sam Durham, UST Class A Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
03	26	11/16/1995	Steel Clad	Flexible Plastic	Flapper Valve
1223	No	09/23/2015	Double-Walled	Double Walled	Yes
Currently in Use			Auto Dialer	U.S. Suction	Non-corrodible
Diesel			Continuous Interstitial Monitoring	Continuous Interstitial Monitoring	No
4,000			Gilbarco-Veeder Root/TLS-300		No

Facility Summary in Dawson County in the City of Glendive

Location: HOLIDAY STATIONSTORE 271
701 N Merrill Ave
Glendive, MT 59330 Dawson

Legacy ID:11-08061

Facility ID: 19804
Last Inspected On: 11/16/2020
Operating Permit Renewal Date: 04/11/2024

Owner Operator Contact: Alan Cubberley;Circle K Stores Inc;Camie Pederson;Rocky Mountain Oil LLC - Env Director

3308144032;6027288000;9528308899

Operator Contact: Chuck Nyberg;Dean Townsend

9528308722

Owner/Operator: Rocky Mountain Oil Co Inc

Brad Lee, UST Class B Global Operator

Chuck Nyberg, UST Class A Operator

Dean Townsend, UST Class A Operator

Greg Brewer, UST Class B Global Operator

Kelly Jo Cooper, UST Class B Global Operator

Travis Struckman, UST Class B Global Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
-----------	-----	-----------	----------------------------	-----------------	----------------

Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
01	42	10/01/1979	Bare Steel	Fiberglass Reinforced Plastic	Ball Float Valve
3001	No			Double Walled	Yes
Currently in Use		06/03/2008	Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		07/07/2015	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring; ELLD 0.1; ELLD 0.2	Yes
12,000		02/15/2018	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
02	42	10/01/1979	Bare Steel	Fiberglass Reinforced Plastic	Ball Float Valve
3002	No			Double Walled	Yes
Currently in Use		06/03/2008	Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		07/07/2015	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring; ELLD 0.1; ELLD 0.2	Yes
12,000		02/11/2018	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
03	42	10/01/1979	Bare Steel	Fiberglass Reinforced Plastic	Ball Float Valve
3003	No			Double Walled	Yes
Currently in Use		06/03/2008	Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		07/07/2015	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring; ELLD 0.1; ELLD 0.2	Yes
8,000		02/09/2018	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
04	42	10/01/1979	Bare Steel	Fiberglass Reinforced Plastic	Ball Float Valve
3004	No			Double Walled	Yes
Currently in Use		06/03/2008	Electronic Line Leak Detector	Pressurized	Impressed Current
Diesel		07/07/2015	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring; ELLD 0.1; ELLD 0.2	No
8,000		02/05/2018	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No

Facility Summary in Dawson County in the City of Glendive

Location: JOYS GLENDIVE SERVICE INC
74 MT Hwy 16
Glendive, MT 59330-3609 Dawson

Legacy ID:11-07770

Facility ID: 19800
Last Inspected On: 02/19/2021
Operating Permit Renewal Date:

Owner Operator Contact: Glenn Lawres;Joys Glendive Service Inc;William Clemens

6085758642

Operator Contact: Glenn Lawres

Owner/Operator: William Clemens

Glenn Lawres, UST Class A Operator

Glenn Lawres, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
06	23	05/28/1998	Steel Clad	Flexible Plastic	Flapper Valve
1511	No		Double-Walled	Double Walled	Yes
Temporarily Out of Use			Mechanical Line Leak Detector	Pressurized	Non-corrodible
Gasoline		06/14/2013	Continuous Interstitial Monitoring	Continuous Interstitial Monitoring	No
8,000			Gilbarco-Veeder Root/ILS-350		No
07	23	05/28/1998	Steel Clad	Flexible Plastic	Flapper Valve
1512	No		Double-Walled	Double Walled	Yes
Temporarily Out of Use			Mechanical Line Leak Detector	Pressurized	Non-corrodible
Gasoline		06/14/2013	Continuous Interstitial Monitoring	Continuous Interstitial Monitoring	No
4,000			Gilbarco-Veeder Root/ILS-350		No
08	23	05/28/1998	Steel Clad	Flexible Plastic	Flapper Valve
1513	No		Double-Walled	Double Walled	Yes

Temporarily Out of Use			Mechanical Line Leak Detector	Pressurized	Non-corrodible
Diesel		06/14/2013	Continuous Interstitial Monitoring	Continuous Interstitial Monitoring	No
6,000			Gilbarco-Veeder Root/ILS-350		No
09	23	05/28/1998	Steel Clad	Flexible Plastic	Flapper Valve
1514	No		Double-Walled	Double Walled	Yes
Temporarily Out of Use			Mechanical Line Leak Detector	Pressurized	Non-corrodible
Diesel		06/14/2013	Continuous Interstitial Monitoring	Continuous Interstitial Monitoring	No
2,000			Gilbarco-Veeder Root/ILS-350		No

Facility Summary in Dawson County in the City of Glendive

Location: LOAF 'N JUG #710
322 E Barry St
Glendive, MT 59330-2306 Dawson

Legacy ID:11-05093

Facility ID: 19756
Last Inspected On: 10/10/2019
Operating Permit Renewal Date: 10/04/2022

Owner Operator Contact: Elena Lau;Mini Mart Inc dba Loaf N Jug - Remittance;Elena Lau;Mini Mart Inc dba Loaf N Jug Hutchinson;Mini Mart Inc dba Loaf 'N Jug Pueblo

5139641568

Operator Contact: Theodore Bezel;Mini Mart Inc dba Loaf 'N Jug Pueblo **5139641568**

Owner/Operator: Mini Mart Inc dba Loaf 'N Jug Pueblo

Theodore Bezel, UST Class A Operator
Theodore Bezel, UST Class B Global Operator
Theodore Bezel, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
04	25	09/01/1996	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve
1636	No			Double Walled	Yes
Currently in Use		05/07/2012	Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel		11/22/2011	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring;ELLD 0.2	No

10,000			Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
05	25	09/01/1996	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve
1637	No			Double Walled	Yes
Currently in Use		05/07/2012	Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline		11/22/2011	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring; ELLD 0.2	No
10,000			Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
06	25	09/01/1996	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve
1638	No			Double Walled	Yes
Currently in Use		05/07/2012	Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasohol/Ethanol		11/22/2011	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring; ELLD 0.2	No
10,000			Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No

Facility Summary in Dawson County in the City of Glendive

Location: QWEST GLENDIVE CENTRAL OFFICE
119 W Valentine St
Glendive, MT 59330-1638 Dawson

Legacy ID:11-06870

Facility ID: 19783
Last Inspected On: 04/15/2021
Operating Permit Renewal Date: 04/22/2024

Owner Operator Contact: Qwest Corporation/Century Link

Operator Contact: Kevin Robison;Stephanie Miller;Thomas Pitts **2063467532;5016808141;8015983020**

Owner/Operator: Qwest Corporation/Century Link

Kevin Robison, UST Class A Operator
Kevin Robison, UST Class B Global Operator
Stephanie Miller, UST Class A Operator
Stephanie Miller, UST Class B Global Operator
Thomas Pitts, UST Class A Operator
Thomas Pitts, UST Class B Global Operator
Thomas Pitts, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
01	28	04/01/1993	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
1726	No		Double-Walled	Double Walled	Yes
Currently in Use			Not Required	U.S. Suction	Non-corrodible
Diesel			Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	3-Year Line Tightness Test	No
553		09/19/2018	Veeder Root/TLS-300		No

Facility Summary in Dawson County in the City of Glendive

Location: SUPERPUMPER #80158
1320 N Merrill Ave
Glendive, MT 59330-1958 Dawson

Legacy ID:11-04213

Facility ID: 19747
Last Inspected On: 01/02/2019
Operating Permit Renewal Date: 06/09/2022

Owner Operator Contact: Superpumper Inc

Operator Contact: Lynn Becker;Timothy Mort;Whitney Ripley **4063652177;4063778521;4069393426**

Owner/Operator: Superpumper Inc

Evelyn Mort, UST Class B Operator
 Lynn Becker, UST Class A Operator
 Lynn Becker, UST Class B Operator
 Roger Pelzer, UST Class B Operator
 Timothy Mort, UST Class A Operator
 Timothy Mort, UST Class B Operator
 Victoria Shoopman, UST Class B Operator
 Whitney Ripley, UST Class A Operator
 Whitney Ripley, UST Class B Global Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
01	37	05/06/1984	Bare Steel	Steel	Flapper Valve
4308	No			None	Yes
Currently in Use		05/09/2007	Electronic Line Leak Detector	Pressurized	Impressed Current
Diesel		01/02/2019	Automatic Tank Gauging 0.2	ELLD 0.1;ELLD 0.2	No
10,000		12/24/2018	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
02	37	05/06/1984	Bare Steel	Steel	Flapper Valve
4309	No			None	Yes
Currently in Use		05/09/2007	Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		01/02/2019	Automatic Tank Gauging 0.2	ELLD 0.1;ELLD 0.2	No
10,000		12/26/2018	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
03	37	05/06/1984	Bare Steel	Steel	Flapper Valve
4310	No			None	Yes
Currently in Use		05/09/2007	Electronic Line Leak Detector	Pressurized	Impressed Current

Gasoline	01/02/2019	Automatic Tank Gauging 0.2	ELLD 0.1;ELLD 0.2	No
10,000	12/26/2018	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No

Facility Summary in Dawson County in the City of Glendive

Location: TOWN PUMP GLENDIVE TRAVEL PLAZA
73 Hwy 16
Glendive, MT 59330 Dawson

Legacy ID:60-15289

Facility ID: 30996
Last Inspected On: 07/17/2020
Operating Permit Renewal Date: 01/08/2024

Owner Operator Contact:

Operator Contact:

Owner/Operator: Glendive 1 Town Pump LLC

Don Edmisten, UST Class B Global Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
01	4	07/10/2017	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve
5686	No		Double-Walled	Double Walled	Yes
Currently in Use		07/10/2017	Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
30,000			Gilbarco-Veeder Root/TLS-450		Yes
02	4	07/10/2017	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve
5687	No		Double-Walled	Double Walled	Yes
Currently in Use		07/10/2017	Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
15,000			Gilbarco-Veeder Root/TLS-450		Yes

03	4	07/10/2017	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve
5688	No		Double-Walled	Double Walled	Yes
Currently in Use		07/10/2017	Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
7,000			Gilbarco-Veeder Root/TLS-450		Yes
04	4	07/10/2017	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve
5689	No		Double-Walled	Double Walled	Yes
Currently in Use		07/10/2017	Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel			Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
30,000			Gilbarco-Veeder Root/TLS-450		Yes
05	4	07/10/2017	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve
5690	No		Double-Walled	Double Walled	Yes
Currently in Use		07/10/2017	Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel			Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
8,000			Gilbarco-Veeder Root/TLS-450		Yes
06	4	07/10/2017	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve
5691	No		Double-Walled	Double Walled	Yes
Currently in Use		07/10/2017	Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel			Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
30,000			Gilbarco-Veeder Root/TLS-450		Yes

07	4	07/10/2017	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve
5692	No		Double-Walled	Double Walled	Yes
Currently in Use		07/10/2017	Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel			Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
7,000			Gilbarco-Veeder Root/TLS-450		Yes
08	4	07/10/2017	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve
5719	No		Double-Walled	Double Walled	Yes
Currently in Use		07/10/2017	Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel			Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
12,000			Gilbarco-Veeder Root/TLS-450		Yes

Facility Summary in Dawson County in the City of Glendive

Location: TRAIL STAR CAR AND TRUCK STOP
11 MT Hwy 16
Glendive, MT 59330 Dawson

Legacy ID:11-05754

Facility ID: 19761
Last Inspected On: 10/15/2020
Operating Permit Renewal Date: 03/09/2024

Owner Operator Contact: Clinton Lohman;Trail Star LLC;Trailstar Truck Stop Inc **4063650557**

Operator Contact: Cheryl Haggerty

Owner/Operator: Trailstar Truck Stop Inc

Cheryl Haggerty, UST Class A Operator
Cheryl Haggerty, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act

05	23	11/30/1998	Steel Clad	Flexible Plastic	Flapper Valve
----	----	------------	------------	------------------	---------------

4274	No		Double-Walled	Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Automatic Tank Gauging 0.1;Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	Continuous Interstitial Monitoring;ELLD 0.1;ELLD 0.2	No
4,000			Gilbarco-Veeder Root/TLS- 350/Gilbarco EMC		No
06	23	11/30/1998	Steel Clad	Flexible Plastic	Flapper Valve
4275	No		Double-Walled	Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Automatic Tank Gauging 0.1;Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	Continuous Interstitial Monitoring;ELLD 0.1;ELLD 0.2	No
8,000			Gilbarco-Veeder Root/TLS- 350/Gilbarco EMC		No
07	23	11/30/1998	Steel Clad	Flexible Plastic	Flapper Valve
4276	No		Double-Walled	Double Walled	Yes
Currently in Use		01/07/2011	Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel			Automatic Tank Gauging 0.1;Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	Continuous Interstitial Monitoring;ELLD 0.1;ELLD 0.2	No
12,000			Gilbarco-Veeder Root/TLS- 350/Gilbarco EMC		No
08	23	11/30/1998	Steel Clad	Flexible Plastic	Flapper Valve
4277	No		Double-Walled	Double Walled	Yes
Currently in Use		08/17/2009	Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel			Automatic Tank Gauging 0.1;Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	Continuous Interstitial Monitoring;ELLD 0.1;ELLD 0.2	No
8,000			Gilbarco-Veeder Root/TLS- 350/Gilbarco EMC		No
09	23	11/30/1998	Steel Clad	Flexible Plastic	Flapper Valve

4278	No		Double-Walled	Double Walled	Yes
Currently in Use	08/17/2009		Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel			Automatic Tank Gauging 0.1;Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	Continuous Interstitial Monitoring;ELLD 0.1;ELLD 0.2	No
15,000			Gilbarco-Veeder Root/TLS- 350/Gilbarco EMC		No

Facility Summary in Dawson County in the City of Glendive

Location: WEST PARK CENEX
2200 W Towne St
Glendive, MT 59330 Dawson

Legacy ID:11-08908

Facility ID: 19822
Last Inspected On: 07/06/2021
Operating Permit Renewal Date: 10/09/2024

Owner Operator Contact: Cross Petroleum Services Glendive;Todd King;CHS Inc (Todd King) **6126416363**

Operator Contact: Alvaro Garcia;Gregory Cross;R J Serpe **6023738892**

Owner/Operator: Cross Petroleum Services Glendive

- Alvaro Garcia, UST Class A Operator
- Alvaro Garcia, UST Class B Global Operator
- Greg Cross, UST Class A Operator
- R J Serpe, UST Class A Operator
- R J Serpe, UST Class B Global Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
S4	22	09/01/1999	Unknown	Fiberglass Reinforced Plastic	High Level Alarm
553	Yes			None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	
Gasoline			Deferred	ELLD 0.2	No
12,000		03/11/2015			No
S5	22	09/01/1999	Unknown	Fiberglass Reinforced Plastic	High Level Alarm

554	Yes			None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	
Gasoline			Deferred	ELLD 0.2	No
12,000		02/05/2015			No
S6	22	09/01/1999	Unknown	Fiberglass Reinforced Plastic	High Level Alarm
555	Yes			None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	
Diesel			Deferred	ELLD 0.2	No
10,000		02/07/2015			No

Facility Summary in Dawson County in the City of Glendive

Location: WESTGATE CENEX
56 MT Hwy 16
Glendive, MT 59330 Dawson

Legacy ID:11-08909

Facility ID: 19823
Last Inspected On: 07/06/2021
Operating Permit Renewal Date: 10/31/2024

Owner Operator Contact: Cross Petroleum Services Glendive;Jim Alford;CHS Inc **5095367418**
- Spokane

Operator Contact: Gregory Cross;R J Serpe;Timothy Fife

Owner/Operator: Cross Petroleum Services Glendive

Greg Cross, UST Class A Operator
R J Serpe, UST Class A Operator
R J Serpe, UST Class B Global Operator
Timothy Fife, UST Class A Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
01	60	05/22/1961	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve;Flapper Valve
556	No	07/13/2012	Lined Interior/Impressed Current	Double Walled	Yes

Currently in Use		08/23/2007	Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		08/05/2018	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring;ELLD 0.2	No
10,000		07/06/2012	Incon/TS-550 EVO		No
02	60	05/22/1961	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve
557	No	07/13/2012	Lined Interior/Impressed Current	Double Walled	Yes
Currently in Use		08/23/2007	Electronic Line Leak Detector	Pressurized	Impressed Current
Diesel		08/05/2018	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring;ELLD 0.2	No
8,000		08/09/2011	Incon/TS-550 EVO		No
05	29	02/07/1992	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve
558	No	07/13/2012		Double Walled	Yes
Currently in Use		08/23/2007	Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		08/05/2018	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring;ELLD 0.2	No
10,000		07/04/2012	Incon/TS-550 EVO		No

Facility Summary in Dawson County in the City of Richey

Location: FARMERS ELEVATOR RICHEY
111 Railroad Ave
Richey, MT 59259 Dawson

Legacy ID:11-05898

Facility ID: 19762
Last Inspected On: 11/23/2018
Operating Permit Renewal Date: 02/02/2023

Owner Operator Contact: CHS Inc Richey;Dave Hilger;Cenex Harvest States Coop Richey;Mark Dreesen;Farmers Elevator Co **4064853313;4067735758**

Operator Contact: David Corbin

Owner/Operator: CHS Inc Richey

David Corbin, UST Class A Operator
David Corbin, UST Class B Operator
Jana Olson, UST Class B Operator
Lance Schipman, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types

Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
05	20	07/11/2001	Steel Clad	Fiberglass Reinforced Plastic	Flapper Valve
4314	No		Double-Walled	None	Yes
Currently in Use			Not Required	Safe Suction	
Gasoline		10/29/2012	Manual Interstitial Monitoring	Deferred	No
4,000					No
06	20	07/11/2001	Steel Clad	Fiberglass Reinforced Plastic	Flapper Valve
4315	No		Double-Walled	None	Yes
Currently in Use			Not Required	Safe Suction	
Gasoline		10/29/2012	Manual Interstitial Monitoring	Deferred	No
4,000					No
07	20	07/11/2001	Steel Clad	Fiberglass Reinforced Plastic	Flapper Valve
4316	No		Double-Walled	None	Yes
Currently in Use			Not Required	Safe Suction	
Diesel		10/29/2012	Manual Interstitial Monitoring	Deferred	No
4,000					No
08	6	04/01/2015	Fiberglass Reinforced Plastic	Flexible Plastic	Positive Shutoff
5572	No	05/04/2015	Double-Walled	Double Walled	Yes
Currently in Use		05/07/2015	Not Required	Safe Suction	
Diesel			Continuous Interstitial Monitoring	Continuous Interstitial Monitoring;Deferred;Not Listed	No
8,000					Yes