

## Facility Summary in Dawson County in the City of Glendive

**Location:** BRAKE TIME 251715  
322 E Barry St  
Glendive, MT 59330-2306 Dawson

System Facility ID: 11-05093

Facility Code: 19756  
Last Inspected On: 08/06/2025  
Operating Permit Renewal Date: 10/04/2028

**Note:** Inspection is due 90 days before the Operating Permit Renewal Date.

**Owner Operator Contact:** GLENDIVE MT LLC (832) 539-8190 licensing@btcmstores.com

**Operator Contact:** Muhammad Akhtar (832) 539-8190 akhatarmuhammad65@gmail.com

**Owner/Operator:** GLENDIVE MT LLC (832) 539-8190 licensing@btcmstores.com

Muhammad Akhtar, UST Class A Operator akhatarmuhammad65@gmail.com

<b>Tank Code</b>	04	<b>Tank Age</b>	30	<b>Tank Installed Date</b>	09/01/1996	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	1636	<b>Spill Test Date</b>	08/06/2024	<b>Piping Installed Date</b>	05/07/2012	<b>Tank Construction</b>		<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Diesel	<b>PLLD Test Date</b>	08/06/2025	<b>Tank/Piping CP Test Date</b>	11/22/2011	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	No
<b>Capacity</b>	10000	<b>ATG Test Date</b>	08/06/2025	<b>Line Tightness Test Date</b>	05/24/2024	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>	ELLD 0.2	<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	08/06/2024			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
<b>Tank Code</b>	05	<b>Tank Age</b>	30	<b>Tank Installed Date</b>	09/01/1996	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	1637	<b>Spill Test Date</b>	08/06/2024	<b>Piping Installed Date</b>	05/07/2012	<b>Tank Construction</b>		<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>	08/06/2025	<b>Tank/Piping CP Test Date</b>	11/22/2011	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	No
<b>Capacity</b>	10000	<b>ATG Test Date</b>	08/06/2025	<b>Line Tightness Test Date</b>	07/19/2022	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>	ELLD 0.2	<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	08/06/2024			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Tank Code	06	Tank Age	30	Tank Installed Date	09/01/1996	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	1638	Spill Test Date	08/06/2024	Piping Installed Date	05/07/2012	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	08/06/2025	Tank/Piping CP Test Date	11/22/2011	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	10000	ATG Test Date	08/06/2025	Line Tightness Test Date	05/24/2024	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	08/06/2024			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

## Facility Summary in Dawson County in the City of Glendive

**Location:** CIRCLE K STORE 2746271  
701 N Merrill Ave  
Glendive, MT 59330 Dawson

System Facility ID:11-08061

Facility Code: 19804  
Last Inspected On: 01/02/2024  
Operating Permit Renewal Date: 04/11/2027

**Note:** Inspection is due 90 days before the Operating Permit Renewal Date.

**Owner Operator Contact:** Rocky Mountain Oil LLC (602) 728-8000 NT-ESS@Circlek.com

**Operator Contact:** Chuck Nyberg;Dean Townsend (952) 830-8722 dean.townsend@holidaycompanies.com

**Owner/Operator:** Rocky Mountain Oil LLC (602) 728-8000 NT-ESS@Circlek.com

Brad Lee, UST Class B Global Operator

brad.lee@holidaycompanies.com

Chuck Nyberg, UST Class A Operator

dean.townsend@holidaycompanies.com

Dean Townsend, UST Class A Operator

greg.brewer@holidaycompanies.com

Greg Brewer, UST Class B Global Operator

kellyjcooper205@gmail.com

Kelly Jo Cooper, UST Class B Global Operator

travis.struckman@holidaycompanies.com

Travis Struckman, UST Class B Global Operator

Tank Code	01	Tank Age	47	Tank Installed Date	10/01/1979	Tank Material	Bare Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve
Tag Number	3001	Spill Test Date	07/11/2024	Piping Installed Date	06/03/2008	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date	03/21/2023	Tank/Piping CP Test Date	03/21/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	Yes
Capacity	12000	ATG Test Date	03/21/2024	Line Tightness Test Date	08/27/2020 <th>Secondary Tank Leak Detection</th> <td></td> <th>Secondary Pipe Detection</th> <td>Continuous Interstitial Monitoring</td> <th>Energy Act</th> <td>No</td>	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	03/21/2023		<th>ATG Type</th> <td>Gilbarco-Veeder Root/TLS-350/Gilbarco EMC</td> <th></th> <td></td> <th></th> <td></td>	ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	02	Tank Age	47	Tank Installed Date	10/01/1979	Tank Material	Bare Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve
Tag Number	3002	Spill Test Date	07/11/2024	Piping Installed Date	06/03/2008	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	<th>Catastrophic L.D Type 3.0</th> <td>Electronic Line Leak Detector</td> <th>Piping Type</th> <td>Pressurized</td> <th>CP Met Types</th> <td>Impressed Current</td>	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date	03/21/2024	Tank/Piping CP Test Date	03/21/2023 <th>Primary Tank Leak Detection</th> <td>Automatic Tank Gauging 0.2</td> <th>Primary Pipe Detection</th> <td>ELLD 0.2</td> <th>Vapor Recovery</th> <td>Yes</td>	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	Yes

Capacity	12000	ATG Test Date	03/21/2024	Line Tightness Test Date	08/19/2020	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	03/21/2023			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	03	Tank Age	47	Tank Installed Date	10/01/1979	Tank Material	Bare Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve
Tag Number	3003	Spill Test Date	07/11/2024	Piping Installed Date	06/03/2008	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date	03/21/2024	Tank/Piping CP Test Date	03/21/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	Yes
Capacity	8000	ATG Test Date	03/21/2024	Line Tightness Test Date	08/13/2020	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	03/21/2023			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	04	Tank Age	47	Tank Installed Date	10/01/1979	Tank Material	Bare Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve
Tag Number	3004	Spill Test Date	07/11/2024	Piping Installed Date	06/03/2008	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Diesel	PLLD Test Date	03/21/2024	Tank/Piping CP Test Date	03/21/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	8000	ATG Test Date	03/21/2024	Line Tightness Test Date	08/23/2020	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	03/21/2023			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

## Facility Summary in Dawson County in the City of Glendive

**Location:** CROSSROADS CONOCO GLENDALE  
56 Hwy 16  
Glendive, MT 59330-3609 Dawson

System Facility ID: 56-13872

Facility Code: 30551  
Last Inspected On: 09/27/2023  
Operating Permit Renewal Date: 03/14/2027

**Note:** Inspection is due 90 days before the Operating Permit Renewal Date.

**Owner Operator Contact:** Gregory Cross (406) 698-2967 gcross@crosspetroleumservice.com

**Operator Contact:** Gregory Cross; R J Serpe; Timothy Fife (406) 698-2967 gcross@crosspetroleumservice.com; rlsrp@yahoo.com

**Owner/Operator:** Greg Cross (406) 698-2967 gcross@crosspetroleumservice.com  
Greg Cross, UST Class A Operator  
R J Serpe, UST Class A Operator  
R J Serpe, UST Class B Global Operator  
Ron Serpe, UST Class B Global Operator  
Timothy Fife, UST Class A Operator

<b>Tank Code</b>	01	<b>Tank Age</b>	27	<b>Tank Installed Date</b>	06/26/1999	<b>Tank Material</b>	Steel Clad	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Flapper Valve; High Level Alarm
<b>Tag Number</b>	4043	<b>Spill Test Date</b>	09/20/2020	<b>Piping Installed Date</b>	01/03/2013	<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	05/04/2024	<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Diesel	<b>PLLD Test Date</b>	08/11/2022	<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	No
<b>Capacity</b>	10000	<b>ATG Test Date</b>	09/24/2023	<b>Line Tightness Test Date</b>	03/08/2012	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>	ELLD 0.2	<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	09/20/2020			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
<b>Tank Code</b>	02	<b>Tank Age</b>	27	<b>Tank Installed Date</b>	06/26/1999	<b>Tank Material</b>	Steel Clad	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Flapper Valve; High Level Alarm
<b>Tag Number</b>	4044	<b>Spill Test Date</b>	09/03/2020	<b>Piping Installed Date</b>	01/03/2013	<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	05/04/2024	<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>	08/11/2022	<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	No

<b>Capacity</b>	15000	<b>ATG Test Date</b>	09/24/2023	<b>Line Tightness Test Date</b>	03/08/2012	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>	ELLD 0.2	<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	09/03/2020			<b>ATG Type</b>	Gilbarco/EMC Basic				
<b>Tank Code</b>	03	<b>Tank Age</b>	27	<b>Tank Installed Date</b>	06/26/1999	<b>Tank Material</b>	Steel Clad	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Flapper Valve;High Level Alarm
<b>Tag Number</b>	4045	<b>Spill Test Date</b>	09/03/2020	<b>Piping Installed Date</b>	01/03/2013	<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	05/04/2025	<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>	08/11/2022	<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	No
<b>Capacity</b>	10000	<b>ATG Test Date</b>	09/24/2023	<b>Line Tightness Test Date</b>	03/08/2012	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>	ELLD 0.2	<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	09/03/2020			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

## Facility Summary in Dawson County in the City of Glendive

**Location:** DAWSON COMMUNITY AIRPORT  
402 Dry Creek Rd  
Glendive, MT 59330-9204 Dawson

System Facility ID:11-02455

Facility Code: 19717  
Last Inspected On: 06/12/2023  
Operating Permit Renewal Date: 11/24/2026

**Note:** Inspection is due 90 days before the Operating Permit Renewal Date.

<b>Owner Operator Contact:</b> Dawson County	(406) 687-3372	airport@midrivers.com
--	----------------	-----------------------

<b>Operator Contact:</b> Craig Hostetler;Leon Baker	(406) 377-4505;(406) 989-2054	airport@midrivers.com;craig@midrivers.com
---	-------------------------------	---

<b>Owner/Operator:</b> Dawson County	(406) 687-3372	airport@midrivers.com
--------------------------------------	----------------	-----------------------

Bill Stebbins, UST Class B Operator

airport@midrivers.com

Craig Hostetler, UST Class A Operator

craig@midrivers.com

Craig Hostetler, UST Class B Operator

craig@midrivers.com

Leon Baker, UST Class A Operator

airport@midrivers.com

Leon Baker, UST Class B Global Operator

airport@midrivers.com

Leon Baker, UST Class B Operator

airport@midrivers.com

<b>Tank Code</b>	04	<b>Tank Age</b>	32	<b>Tank Installed Date</b>	11/21/1994	<b>Tank Material</b>	Cathodically Protected Steel	<b>Piping Material</b>	Steel	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	824	<b>Spill Test Date</b>	06/14/2022	<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	Secondary Containment Chase	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>	11/21/2022	<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Auto Dialer;Mechanical Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Galvanic
<b>Product</b>	Aviation Gas	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>	06/12/2023	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	MLLD Line Tightness Testing	<b>Vapor Recovery</b>	No
<b>Capacity</b>	8000	<b>ATG Test Date</b>	11/21/2022	<b>Line Tightness Test Date</b>	11/21/2022	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	06/14/2022			<b>ATG Type</b>	EMCO Electronics/EECO 1500				
<b>Tank Code</b>	S5	<b>Tank Age</b>	52	<b>Tank Installed Date</b>	01/01/1974	<b>Tank Material</b>	Unknown	<b>Piping Material</b>	Steel	<b>Overfill Types</b>	
<b>Tag Number</b>	825	<b>Spill Test Date</b>		<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	Single Walled	<b>AST</b>	Yes
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>	11/21/2022	<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Auto Dialer;Mechanical Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	

Product	Jet Fuel (Jet-A, Jet-A1, JP5)	PLL D Test Date	Tank/Piping CP Test Date	06/12/2023	Primary Tank Leak Detection	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	10000	ATG Test Date	Line Tightness Test Date	11/21/2022	Secondary Tank Leak Detection	Secondary Pipe Detection		Energy Act	No
		Overfill Test Date			ATG Type				

## Facility Summary in Dawson County in the City of Glendive

**Location:** EAST END CENEX  
1803 Merrill Ave  
Glendive, MT 59330 Dawson

System Facility ID:11-00033

Facility Code: 19684  
Last Inspected On: 03/11/2024  
Operating Permit Renewal Date: 07/21/2027

**Note:** Inspection is due 90 days before the Operating Permit Renewal Date.

**Owner Operator Contact:** Cross Petroleum Services Glendive

cross@midrivers.com

**Operator Contact:** Gregory Cross;R J Serpe;Timothy Fife

(406) 698-2967

gcross@crosspetroleumservice.com;rlsrp@yahoo.com

**Owner/Operator:** Cross Petroleum Services Glendive

cross@midrivers.com

Greg Cross, UST Class A Operator

gcross@crosspetroleumservice.com

R J Serpe, UST Class A Operator

rlsrp@yahoo.com

R J Serpe, UST Class B Global Operator

rlsrp@yahoo.com

Ron Serpe, UST Class B Global Operator

cross@midrivers.com

Timothy Fife, UST Class A Operator

<b>Tank Code</b>	08	<b>Tank Age</b>	11	<b>Tank Installed Date</b>	02/09/2015	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Flapper Valve;High Level Alarm
<b>Tag Number</b>	5535	<b>Spill Test Date</b>	03/11/2024	<b>Piping Installed Date</b>	02/09/2015	<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Continuous Interstitial Monitoring	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	Yes
<b>Capacity</b>	12000	<b>ATG Test Date</b>	07/20/2023	<b>Line Tightness Test Date</b>	03/20/2015	<b>Secondary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Secondary Pipe Detection</b>	ELLD 0.2	<b>Energy Act</b>	Yes
		<b>Overfill Test Date</b>	03/11/2024			<b>ATG Type</b>	Incon/TS-550 EVO				
<b>Tank Code</b>	09	<b>Tank Age</b>	11	<b>Tank Installed Date</b>	02/09/2015	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Flapper Valve;High Level Alarm
<b>Tag Number</b>	5536	<b>Spill Test Date</b>	03/11/2024	<b>Piping Installed Date</b>	02/09/2015	<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Diesel	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Continuous Interstitial Monitoring	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	No

Capacity	12000	ATG Test Date	07/20/2023	Line Tightness Test Date	03/20/2015	Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	03/11/2024			ATG Type	Incon/TS-550 EVO				
Tank Code	10	Tank Age	11	Tank Installed Date	02/09/2015	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	5537	Spill Test Date	03/11/2024	Piping Installed Date	02/09/2015	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	Yes
Capacity	8000	ATG Test Date	07/20/2023	Line Tightness Test Date	03/20/2015	Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	03/11/2024			ATG Type	Incon/TS-550 EVO				
Tank Code	11	Tank Age	11	Tank Installed Date	02/09/2015	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	5538	Spill Test Date	03/11/2024	Piping Installed Date	02/09/2015	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.1;Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	4000	ATG Test Date	07/20/2023	Line Tightness Test Date	03/20/2015	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	03/11/2024			ATG Type	Incon/TS-550 EVO				

## Facility Summary in Dawson County in the City of Glendive

**Location:** GILLS POINT S-GLENDIVE  
2111 W Towne St  
Glendive, MT 59330-3214 Dawson

System Facility ID: 11-03214

Facility Code: 19730  
Last Inspected On: 04/30/2025  
Operating Permit Renewal Date: 07/20/2028

**Note:** Inspection is due 90 days before the Operating Permit Renewal Date.

---

**Owner Operator Contact:** Nelson Tire LLC (541) 296-4363 kimgilges@gillstire.com

---

**Operator Contact:**

---

**Owner/Operator:** Nelson Tire LLC (541) 296-4363 kimgilges@gillstire.com

---

<b>Tank Code</b>	06	<b>Tank Age</b>	39	<b>Tank Installed Date</b>	03/26/1987	<b>Tank Material</b>	Cathodically Protected Steel	<b>Piping Material</b>	Steel	<b>Overfill Types</b>	Flapper Valve;High Level Alarm
<b>Tag Number</b>	598	<b>Spill Test Date</b>	04/30/2025	<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	None	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Impressed Current
<b>Product</b>	Diesel	<b>PLLD Test Date</b>	12/18/2024	<b>Tank/Piping CP Test Date</b>	12/18/2024	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	ELLD 0.2	<b>Vapor Recovery</b>	No
<b>Capacity</b>	12000	<b>ATG Test Date</b>	12/18/2024	<b>Line Tightness Test Date</b>	10/31/2018	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	12/18/2024			<b>ATG Type</b>	Veeder Root/TLS-450				
<b>Tank Code</b>	07	<b>Tank Age</b>	39	<b>Tank Installed Date</b>	03/26/1987	<b>Tank Material</b>	Cathodically Protected Steel	<b>Piping Material</b>	Steel	<b>Overfill Types</b>	High Level Alarm
<b>Tag Number</b>	599	<b>Spill Test Date</b>	04/30/2025	<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	None	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Impressed Current
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>	12/18/2024	<b>Tank/Piping CP Test Date</b>	12/18/2024	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	ELLD 0.2	<b>Vapor Recovery</b>	No
<b>Capacity</b>	12000	<b>ATG Test Date</b>	12/18/2024	<b>Line Tightness Test Date</b>	11/02/2018	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
<b>Tank Code</b>	08	<b>Tank Age</b>	39	<b>Tank Installed Date</b>	03/26/1987	<b>Tank Material</b>	Cathodically Protected Steel	<b>Piping Material</b>	Steel	<b>Overfill Types</b>	Flapper Valve;High Level Alarm

Tag Number	600	Spill Test Date	04/30/2025	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Diesel, Dyed	PLLD Test Date	12/18/2024	Tank/Piping CP Test Date	12/18/2024	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	6000	ATG Test Date	12/18/2024	Line Tightness Test Date	11/08/2018	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	12/18/2024			ATG Type	Veeder Root/TLS-450				
Tank Code	09	Tank Age	39	Tank Installed Date	03/26/1987	Tank Material	Cathodically Protected Steel	Piping Material	Steel	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	601	Spill Test Date	04/30/2025	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date	12/18/2024	Tank/Piping CP Test Date	12/18/2024	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	6000	ATG Test Date	12/18/2024	Line Tightness Test Date	10/29/2018	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	12/18/2024			ATG Type	Veeder Root/TLS-450				

## Facility Summary in Dawson County in the City of Glendive

**Location:** GLENDALE COMBUSTION TURBINE  
366 FAS 335  
Glendive, MT 59330-9575 Dawson

System Facility ID: 11-09400

Facility Code: 19827  
Last Inspected On: 07/02/2024  
Operating Permit Renewal Date: 11/17/2027

**Note:** Inspection is due 90 days before the Operating Permit Renewal Date.

**Owner Operator Contact:** Montana Dakota Utilities Co Bismarck

mark.dihle@mdu.com

**Operator Contact:** Clay Olson; Evan Jones; Jim Shields; Kalle Kuether; Sean Cameron

(307) 696-3597; (406) 939-5341; (970) 509-0698

clay.olson@mdu.com; evan.jones@mdu.com; jim.shields@MDU.co  
m; kalle.kuether@mdu.com; sean.cameron@mdu.com

**Owner/Operator:** Montana Dakota Utilities Co Bismarck

mark.dihle@mdu.com

Chad Miller, UST Class B Operator

clay.olson@mdu.com

Clay Olson, UST Class A Operator

clay.olson@mdu.com

Clay Olson, UST Class B Global Operator

evan.jones@mdu.com

Evan Jones, UST Class A Operator

evan.jones@mdu.com

Evan Jones, UST Class B Operator

jim.shields@MDU.com

Jim Shields, UST Class A Operator

jim.shields@MDU.com

Jim Shields, UST Class B Global Operator

jody.gustafson@mdu.com

Jody Gustafson, UST Class B Global Operator

kalle.kuether@mdu.com

Kalle Kuether, UST Class A Operator

sean.cameron@mdu.com

Sean Cameron, UST Class A Operator

sean.cameron@mdu.com

Sean Cameron, UST Class B Operator

Tank Code	S2	Tank Age	39	Tank Installed Date	07/01/1987	Tank Material	Cathodically Protected Steel	Piping Material	Steel	Overfill Types
Tag Number	1692	Spill Test Date		Piping Installed Date	07/13/2007	Tank Construction		Piping Construction	Double Walled	AST
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	07/26/2021	Catastrophic L.D Type 3.0	Auto Dialer	Piping Type	Pressurized	CP Met Types
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Deferred	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery
Capacity	75000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act
		Overfill Test Date				ATG Type				No

## Facility Summary in Dawson County in the City of Glendive

**Location:** GLENDIVE MEDICAL CENTER  
202 Prospect Dr  
Glendive, MT 59330-1943 Dawson

System Facility ID:11-09735

Facility Code: 19832  
Last Inspected On: 09/18/2023  
Operating Permit Renewal Date: 12/19/2026

**Note:** Inspection is due 90 days before the Operating Permit Renewal Date.

**Owner Operator Contact:** Glendive Medical Center

**Operator Contact:** Mike Ryan;Sam Durham

[durhams001@yahoo.com](mailto:durhams001@yahoo.com);[miryan@gmc.org](mailto:miryan@gmc.org)

**Owner/Operator:** Glendive Medical Center

Craig Torno, UST Class B Operator

[ctorno@gmc.org](mailto:ctorno@gmc.org)

Mike Ryan, UST Class A Operator

[miryan@gmc.org](mailto:miryan@gmc.org)

Sam Durham, UST Class A Operator

[durhams001@yahoo.com](mailto:durhams001@yahoo.com)

<b>Tank Code</b>	03	<b>Tank Age</b>	31	<b>Tank Installed Date</b>	11/16/1995	<b>Tank Material</b>	Steel Clad	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	1223	<b>Spill Test Date</b>	03/10/2022	<b>Piping Installed Date</b>		<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Auto Dialer	<b>Piping Type</b>	U.S. Suction	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Diesel	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Continuous Interstitial Monitoring	<b>Primary Pipe Detection</b>	3-Year Line Tightness Test	<b>Vapor Recovery</b>	No
<b>Capacity</b>	4000	<b>ATG Test Date</b>	03/09/2023	<b>Line Tightness Test Date</b>	03/10/2022	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	03/10/2022			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-300				

## Facility Summary in Dawson County in the City of Glendive

**Location:** JOYS GLENDIVE SERVICE INC  
74 MT Hwy 16  
Glendive, MT 59330-3609 Dawson

System Facility ID: 11-07770

Facility Code: 19800  
Last Inspected On: 02/06/2024  
Operating Permit Renewal Date: 02/06/2027

**Note:** Inspection is due 90 days before the Operating Permit Renewal Date.

**Owner Operator Contact:** William Clemens

(608) 575-8642

bcbeinc@yahoo.com

**Operator Contact:** Glenn Lawres

(406) 377-1821

**Owner/Operator:** William Clemens

(608) 575-8642

bcbeinc@yahoo.com

Glenn Lawres, UST Class A Operator

Glenn Lawres, UST Class B Operator

<b>Tank Code</b>	06	<b>Tank Age</b>	28	<b>Tank Installed Date</b>	05/28/1998	<b>Tank Material</b>	Steel Clad	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	1511	<b>Spill Test Date</b>		<b>Piping Installed Date</b>		<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Temporarily Out of Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Mechanical Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>	06/14/2013	<b>Primary Tank Leak Detection</b>	Continuous Interstitial Monitoring	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	No
<b>Capacity</b>	8000	<b>ATG Test Date</b>		<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>				<b>ATG Type</b>	Gilbarco-Veeder Root/ILS-350				
<b>Tank Code</b>	07	<b>Tank Age</b>	28	<b>Tank Installed Date</b>	05/28/1998	<b>Tank Material</b>	Steel Clad	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	1512	<b>Spill Test Date</b>		<b>Piping Installed Date</b>		<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Temporarily Out of Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Mechanical Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>	06/14/2013	<b>Primary Tank Leak Detection</b>	Continuous Interstitial Monitoring	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	No
<b>Capacity</b>	4000	<b>ATG Test Date</b>		<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>				<b>ATG Type</b>	Gilbarco-Veeder Root/ILS-350				
<b>Tank Code</b>	08	<b>Tank Age</b>	28	<b>Tank Installed Date</b>	05/28/1998	<b>Tank Material</b>	Steel Clad	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Flapper Valve

Tag Number	1513	Spill Test Date		Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Temporarily Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	06/14/2013	Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	6000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/ILS-350				
Tank Code	09	Tank Age	28	Tank Installed Date	05/28/1998	Tank Material	Steel Clad	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	1514	Spill Test Date		Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Temporarily Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	06/14/2013	Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	2000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/ILS-350				

## Facility Summary in Dawson County in the City of Glendive

**Location:** QWEST GLENDALE CENTRAL OFFICE  
119 W Valentine St  
Glendive, MT 59330-1638 Dawson

System Facility ID: 11-06870

Facility Code: 19783  
Last Inspected On: 09/07/2023  
Operating Permit Renewal Date: 04/22/2027

**Note:** Inspection is due 90 days before the Operating Permit Renewal Date.

**Owner Operator Contact:** Century Link Communication

(501) 680-8141

Stephanie.miller@lumen.com

**Operator Contact:** Stephanie Miller

(501) 680-8141

Stephanie.miller@lumen.com

**Owner/Operator:** Century Link Communication

(501) 680-8141

Stephanie.miller@lumen.com

Stephanie Miller, UST Class A Operator

Stephanie.miller@lumen.com

Stephanie Miller, UST Class B Global Operator

Stephanie.miller@lumen.com

<b>Tank Code</b>	01	<b>Tank Age</b>	33	<b>Tank Installed Date</b>	04/01/1993	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	High Level Alarm
<b>Tag Number</b>	1726	<b>Spill Test Date</b>	09/07/2023	<b>Piping Installed Date</b>		<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Not Required	<b>Piping Type</b>	U.S. Suction	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Diesel	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	3-Year Line Tightness Test	<b>Vapor Recovery</b>	No
<b>Capacity</b>	553	<b>ATG Test Date</b>	09/07/2023	<b>Line Tightness Test Date</b>	07/26/2023	<b>Secondary Tank Leak Detection</b>	Continuous Interstitial Monitoring	<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	09/07/2023			<b>ATG Type</b>	Veeder Root/TLS-300				

## Facility Summary in Dawson County in the City of Glendive

**Location:** SUPERPUMPER 58  
1320 N Merrill Ave  
Glendive, MT 59330-1958 Dawson

System Facility ID:11-04213

Facility Code: 19747  
Last Inspected On: 04/16/2025  
Operating Permit Renewal Date: 06/09/2028

**Note:** Inspection is due 90 days before the Operating Permit Renewal Date.

**Owner Operator Contact:** Superpumper Inc (701) 852-1194 ryan.berndt@parklandusa.com

**Operator Contact:** Ryan Berndt;Parkland USA Corporation (701) 367-5780;(701) 852-1194 ryan.berndt@parklandusa.com;ryan.berndt@parklandusa.com

**Owner/Operator:** Superpumper Inc (701) 852-1194 ryan.berndt@parklandusa.com

Curtis McBride, UST Class B Operator  
Ryan Berndt, UST Class A Operator  
Ryan Berndt, UST Class B Operator

ryan.berndt@parklandusa.com  
ryan.berndt@parklandusa.com  
ryan.berndt@parklandusa.com

<b>Tank Code</b>	01	<b>Tank Age</b>	42	<b>Tank Installed Date</b>	05/06/1984	<b>Tank Material</b>	Bare Steel	<b>Piping Material</b>	Steel	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	4308	<b>Spill Test Date</b>	04/16/2025	<b>Piping Installed Date</b>	05/09/2007	<b>Tank Construction</b>		<b>Piping Construction</b>	Single Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Impressed Current
<b>Product</b>	Diesel	<b>PLLD Test Date</b>	08/19/2024	<b>Tank/Piping CP Test Date</b>	04/16/2025	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	ELLD 0.2	<b>Vapor Recovery</b>	No
<b>Capacity</b>	10000	<b>ATG Test Date</b>	08/19/2024	<b>Line Tightness Test Date</b>	03/02/2025	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	04/16/2025			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
<b>Tank Code</b>	02	<b>Tank Age</b>	42	<b>Tank Installed Date</b>	05/06/1984	<b>Tank Material</b>	Bare Steel	<b>Piping Material</b>	Steel	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	4309	<b>Spill Test Date</b>	04/16/2025	<b>Piping Installed Date</b>	05/09/2007	<b>Tank Construction</b>		<b>Piping Construction</b>	Single Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Impressed Current
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>	08/19/2024	<b>Tank/Piping CP Test Date</b>	04/16/2025	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	ELLD 0.2	<b>Vapor Recovery</b>	No
<b>Capacity</b>	10000	<b>ATG Test Date</b>	08/19/2024	<b>Line Tightness Test Date</b>	02/28/2025	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	04/16/2025			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Tank Code	03	Tank Age	42	Tank Installed Date	05/06/1984	Tank Material	Bare Steel	Piping Material	Steel	Overfill Types	Flapper Valve
Tag Number	4310	Spill Test Date	04/16/2025	Piping Installed Date	05/09/2007	Tank Construction		Piping Construction	Single Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date	08/19/2024	Tank/Piping CP Test Date	04/16/2025	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	10000	ATG Test Date	08/19/2024	Line Tightness Test Date	02/02/2025	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	04/16/2025			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

## Facility Summary in Dawson County in the City of Glendive

**Location:** TOWN PUMP GLENDALE TRAVEL PLAZA  
73 Hwy 16  
Glendive, MT 59330 Dawson

System Facility ID: 60-15289

Facility Code: 30996  
Last Inspected On: 09/17/2024  
Operating Permit Renewal Date: 07/21/2027

**Note:** Inspection is due 90 days before the Operating Permit Renewal Date.

**Owner Operator Contact:** Glendive 1 Town Pump LLC

(406) 497-6700

environmental@townpump.com

**Operator Contact:** Trent Biggers; Town Pump

Trentb@townpump.com; environmental@townpump.com

**Owner/Operator:** Glendive 1 Town Pump LLC

(406) 497-6700

environmental@townpump.com

Trent Biggers, UST Class A Operator

environmental@townpump.com

Trent Biggers, UST Class B Operator

environmental@townpump.com

Tank Code	01	Tank Age	9	Tank Installed Date	07/10/2017	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	5686	Spill Test Date	01/24/2024	Piping Installed Date	07/10/2017	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	09/28/2023	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	02/06/2024	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	30000	ATG Test Date	02/06/2024	Line Tightness Test Date		Secondary Tank Leak Detection	Statistical Inventory Reconciliation	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	Yes
		Overfill Test Date	09/28/2023			ATG Type	Gilbarco-Veeder Root/TLS-450				
Tank Code	02	Tank Age	9	Tank Installed Date	07/10/2017	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	5687	Spill Test Date	09/28/2023	Piping Installed Date	07/10/2017	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	09/28/2023	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	02/06/2024	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection		Vapor Recovery	No
Capacity	15000	ATG Test Date	02/06/2024	Line Tightness Test Date		Secondary Tank Leak Detection	Statistical Inventory Reconciliation	Secondary Pipe Detection	Continuous Interstitial Monitoring; Statistical Inventory Reconciliation	Energy Act	Yes

		Overfill Test Date	09/28/2023			ATG Type	Gilbarco-Veeder Root/TLS-450			
Tank Code	03	Tank Age	9	Tank Installed Date	07/10/2017	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types
Tag Number	5688	Spill Test Date	09/28/2023	Piping Installed Date	07/10/2017	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	09/28/2023	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types
Product	Gasoline	PLLD Test Date	02/06/2024	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery
Capacity	7000	ATG Test Date	02/06/2024	Line Tightness Test Date		Secondary Tank Leak Detection	Statistical Inventory Reconciliation	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act
		Overfill Test Date	09/28/2023			ATG Type	Gilbarco-Veeder Root/TLS-450			
Tank Code	04	Tank Age	9	Tank Installed Date	07/10/2017	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types
Tag Number	5689	Spill Test Date	01/24/2024	Piping Installed Date	07/10/2017	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	02/06/2024	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types
Product	Diesel	PLLD Test Date	09/28/2023	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery
Capacity	30000	ATG Test Date	02/06/2024	Line Tightness Test Date		Secondary Tank Leak Detection	Statistical Inventory Reconciliation	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act
		Overfill Test Date	01/24/2024			ATG Type	Gilbarco-Veeder Root/TLS-450			
Tank Code	05	Tank Age	9	Tank Installed Date	07/10/2017	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types
Tag Number	5690	Spill Test Date	09/28/2023	Piping Installed Date	07/10/2017	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	09/28/2023	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types
Product	Diesel	PLLD Test Date	02/06/2024	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery
Capacity	8000	ATG Test Date	02/06/2024	Line Tightness Test Date		Secondary Tank Leak Detection	Statistical Inventory Reconciliation	Secondary Pipe Detection		Energy Act
		Overfill Test Date	09/28/2023			ATG Type	Gilbarco-Veeder Root/TLS-450			Yes
Tank Code	06	Tank Age	9	Tank Installed Date	07/10/2017	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types

Tag Number	5691	Spill Test Date	01/24/2024	Piping Installed Date	07/10/2017	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	06/14/2022	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	30000	ATG Test Date	06/14/2022	Line Tightness Test Date		Secondary Tank Leak Detection	Statistical Inventory Reconciliation	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	Yes
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-450				
Tank Code	07	Tank Age	9	Tank Installed Date	07/10/2017	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	5692	Spill Test Date	09/28/2023	Piping Installed Date	07/10/2017	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	09/28/2023	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	02/06/2024	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	7000	ATG Test Date	02/06/2024	Line Tightness Test Date		Secondary Tank Leak Detection	Statistical Inventory Reconciliation	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	Yes
		Overfill Test Date	09/28/2023			ATG Type	Gilbarco-Veeder Root/TLS-450				
Tank Code	08	Tank Age	9	Tank Installed Date	07/10/2017	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	5719	Spill Test Date	09/28/2023	Piping Installed Date	07/10/2017	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	09/28/2023	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	02/06/2024	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	12000	ATG Test Date	02/06/2024	Line Tightness Test Date		Secondary Tank Leak Detection	Statistical Inventory Reconciliation	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	Yes
		Overfill Test Date	09/28/2023			ATG Type	Gilbarco-Veeder Root/TLS-450				

## Facility Summary in Dawson County in the City of Glendive

**Location:** TRAIL STAR CAR AND TRUCK STOP  
11 MT Hwy 16  
Glendive, MT 59330 Dawson

System Facility ID: 11-05754

Facility Code: 19761  
Last Inspected On: 12/04/2023  
Operating Permit Renewal Date: 03/09/2027

**Note:** Inspection is due 90 days before the Operating Permit Renewal Date.

**Owner Operator Contact:** Trailstar Truck Stop Inc

**Operator Contact:** Cheryl Haggerty

trailstar@middrivers.com

**Owner/Operator:** Trailstar Truck Stop Inc

Cheryl Haggerty, UST Class A Operator

trailstar@middrivers.com

Cheryl Haggerty, UST Class B Operator

trailstar@middrivers.com

<b>Tank Code</b>	05	<b>Tank Age</b>	28	<b>Tank Installed Date</b>	11/30/1998	<b>Tank Material</b>	Steel Clad	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	4274	<b>Spill Test Date</b>	10/25/2023	<b>Piping Installed Date</b>		<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	10/16/2020	<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>	10/24/2023	<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	ELLD 0.2	<b>Vapor Recovery</b>	No
<b>Capacity</b>	4000	<b>ATG Test Date</b>	10/23/2023	<b>Line Tightness Test Date</b>	06/20/2020	<b>Secondary Tank Leak Detection</b>	Continuous Interstitial Monitoring	<b>Secondary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	10/24/2023			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
<b>Tank Code</b>	06	<b>Tank Age</b>	28	<b>Tank Installed Date</b>	11/30/1998	<b>Tank Material</b>	Steel Clad	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	4275	<b>Spill Test Date</b>	10/25/2023	<b>Piping Installed Date</b>		<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	10/16/2020	<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>	10/24/2023	<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	ELLD 0.2	<b>Vapor Recovery</b>	No
<b>Capacity</b>	8000	<b>ATG Test Date</b>	10/23/2023	<b>Line Tightness Test Date</b>	06/02/2020	<b>Secondary Tank Leak Detection</b>	Continuous Interstitial Monitoring	<b>Secondary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	10/24/2023			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Tank Code	07	Tank Age	28	Tank Installed Date	11/30/1998	Tank Material	Steel Clad	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	4276	Spill Test Date	10/25/2023	Piping Installed Date	01/07/2011	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	10/16/2020	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	10/24/2023	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	12000	ATG Test Date	10/23/2024	Line Tightness Test Date	08/20/2020	Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	10/24/2023			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	08	Tank Age	28	Tank Installed Date	11/30/1998	Tank Material	Steel Clad	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	4277	Spill Test Date	10/25/2023	Piping Installed Date	08/17/2009	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	10/16/2020	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	10/24/2023	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	8000	ATG Test Date	10/23/2023	Line Tightness Test Date	07/20/2020	Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	10/24/2023			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	09	Tank Age	28	Tank Installed Date	11/30/1998	Tank Material	Steel Clad	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	4278	Spill Test Date	10/25/2023	Piping Installed Date	08/17/2009	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	10/16/2020	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	10/24/2023	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	15000	ATG Test Date	10/23/2023	Line Tightness Test Date	07/20/2020	Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	10/24/2023			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

## Facility Summary in Dawson County in the City of Glendive

**Location:** WEST PARK CENEX  
2200 W Towne St  
Glendive, MT 59330 Dawson

System Facility ID: 11-08908

Facility Code: 19822  
Last Inspected On: 06/25/2024  
Operating Permit Renewal Date: 10/09/2027

**Note:** Inspection is due 90 days before the Operating Permit Renewal Date.

**Owner Operator Contact:** Cross Petroleum Services Glendive

cross@midrivers.com

**Operator Contact:** Alvaro Garcia; Gregory Cross; R J Serpe

(406) 698-2967; (602) 373-8892

garc8651@gmail.com; gcross@crosspetroleumservice.com; rlsrp@yahoo.com

**Owner/Operator:** Cross Petroleum Services Glendive

cross@midrivers.com

Alvaro Garcia, UST Class A Operator

garc8651@gmail.com

Alvaro Garcia, UST Class B Global Operator

garc8651@gmail.com

Greg Cross, UST Class A Operator

gcross@crosspetroleumservice.com

R J Serpe, UST Class A Operator

rlsrp@yahoo.com

R J Serpe, UST Class B Global Operator

rlsrp@yahoo.com

<b>Tank Code</b>	S4	<b>Tank Age</b>	27	<b>Tank Installed Date</b>	09/01/1999	<b>Tank Material</b>	Unknown	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	High Level Alarm
Tag Number	553	Spill Test Date		Piping Installed Date	09/21/2021	Tank Construction		Piping Construction	Double Walled	AST	Yes
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	06/25/2024	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Gasoline	PLLD Test Date	06/25/2024	Tank/Piping CP Test Date		Primary Tank Leak Detection		Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	12000	ATG Test Date	06/25/2024	Line Tightness Test Date	03/11/2015	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date				ATG Type					
<b>Tank Code</b>	S5	<b>Tank Age</b>	27	<b>Tank Installed Date</b>	09/01/1999	<b>Tank Material</b>	Unknown	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	High Level Alarm
Tag Number	554	Spill Test Date		Piping Installed Date	09/21/2021	Tank Construction		Piping Construction	Double Walled	AST	Yes
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	06/25/2024	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Gasoline	PLLD Test Date	06/25/2024	Tank/Piping CP Test Date		Primary Tank Leak Detection		Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	12000	ATG Test Date	06/25/2024	Line Tightness Test Date	02/05/2015	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date				ATG Type					

Tank Code	S6	Tank Age	27	Tank Installed Date	09/01/1999	Tank Material	Unknown	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	555	Spill Test Date		Piping Installed Date	09/21/2021	Tank Construction		Piping Construction	Double Walled	AST	Yes
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	06/25/2024	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Diesel	PLLD Test Date	06/25/2024	Tank/Piping CP Test Date		Primary Tank Leak Detection		Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	10000	ATG Test Date	06/25/2024	Line Tightness Test Date	02/07/2015	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date				ATG Type					

## Facility Summary in Dawson County in the City of Glendive

**Location:** WESTGATE CENEX  
56 MT Hwy 16  
Glendive, MT 59330 Dawson

System Facility ID: 11-08909

Facility Code: 19823  
Last Inspected On: 06/25/2024  
Operating Permit Renewal Date: 10/31/2027

**Note:** Inspection is due 90 days before the Operating Permit Renewal Date.

**Owner Operator Contact:** Cross Petroleum Services Glendive

cross@midrivers.com

**Operator Contact:** Gregory Cross; R J Serpe; Timothy Fife

(406) 698-2967

gcross@crosspetroleumservice.com; rlsrp@yahoo.com

**Owner/Operator:** Cross Petroleum Services Glendive

cross@midrivers.com

Greg Cross, UST Class A Operator

gcross@crosspetroleumservice.com

R J Serpe, UST Class A Operator

rlsrp@yahoo.com

R J Serpe, UST Class B Global Operator

rlsrp@yahoo.com

Timothy Fife, UST Class A Operator

<b>Tank Code</b>	01	<b>Tank Age</b>	65	<b>Tank Installed Date</b>	05/22/1961	<b>Tank Material</b>	Cathodically Protected Steel	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	Ball Float Valve; Flapper Valve
<b>Tag Number</b>	556	<b>Spill Test Date</b>	06/25/2024	<b>Piping Installed Date</b>	08/23/2007	<b>Tank Construction</b>	Lined Interior/Impressed Current	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Impressed Current
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>	06/25/2024	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	ELLD 0.2	<b>Vapor Recovery</b>	No
<b>Capacity</b>	10000	<b>ATG Test Date</b>	06/25/2024	<b>Line Tightness Test Date</b>	07/06/2012	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	06/25/2024			<b>ATG Type</b>	Incon/TS-550 EVO				
<b>Tank Code</b>	02	<b>Tank Age</b>	65	<b>Tank Installed Date</b>	05/22/1961	<b>Tank Material</b>	Cathodically Protected Steel	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	557	<b>Spill Test Date</b>	06/25/2024	<b>Piping Installed Date</b>	08/23/2007	<b>Tank Construction</b>	Lined Interior/Impressed Current	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Impressed Current
<b>Product</b>	Diesel	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>	06/25/2024	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	ELLD 0.2	<b>Vapor Recovery</b>	No

Capacity	8000	ATG Test Date	06/25/2024	Line Tightness Test Date	08/09/2011	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	06/25/2024			ATG Type	Incon/TS-550 EVO				
Tank Code	05	Tank Age	34	Tank Installed Date	02/07/1992	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	558	Spill Test Date	07/22/2024	Piping Installed Date	08/23/2007	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	06/25/2024	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	10000	ATG Test Date	06/25/2024	Line Tightness Test Date	07/04/2012	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	06/25/2024			ATG Type	Incon/TS-550 EVO				

## Facility Summary in Dawson County in the City of Richey

**Location:** FARMERS ELEVATOR RICHEY  
111 Railroad Ave  
Richey, MT 59259 Dawson

System Facility ID: 11-05898

Facility Code: 19762  
Last Inspected On: 01/29/2025  
Operating Permit Renewal Date: 02/02/2028

**Note:** Inspection is due 90 days before the Operating Permit Renewal Date.

**Owner Operator Contact:** CHS Inc Richey

(406) 773-5758

tim.buller@chsinc.com

**Operator Contact:**

**Owner/Operator:** CHS Inc Richey

(406) 773-5758

tim.buller@chsinc.com

Jana Olson, UST Class B Operator

jana.olson@chsinc.com

Lance Schipman, UST Class B Operator

lance.schipman@chsinc.com

<b>Tank Code</b>	05	<b>Tank Age</b>	25	<b>Tank Installed Date</b>	07/11/2001	<b>Tank Material</b>	Steel Clad	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	4314	<b>Spill Test Date</b>	01/29/2025	<b>Piping Installed Date</b>		<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	None	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Not Required	<b>Piping Type</b>	Safe Suction	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>	10/29/2012	<b>Primary Tank Leak Detection</b>	Manual Interstitial Monitoring	<b>Primary Pipe Detection</b>		<b>Vapor Recovery</b>	No
<b>Capacity</b>	4000	<b>ATG Test Date</b>	01/29/2025	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	01/29/2025			<b>ATG Type</b>					
<b>Tank Code</b>	06	<b>Tank Age</b>	25	<b>Tank Installed Date</b>	07/11/2001	<b>Tank Material</b>	Steel Clad	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	4315	<b>Spill Test Date</b>	01/29/2025	<b>Piping Installed Date</b>		<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	None	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Not Required	<b>Piping Type</b>	Safe Suction	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>	10/29/2012	<b>Primary Tank Leak Detection</b>	Manual Interstitial Monitoring	<b>Primary Pipe Detection</b>		<b>Vapor Recovery</b>	No
<b>Capacity</b>	4000	<b>ATG Test Date</b>	01/29/2025	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	01/29/2025			<b>ATG Type</b>					
<b>Tank Code</b>	07	<b>Tank Age</b>	25	<b>Tank Installed Date</b>	07/11/2001	<b>Tank Material</b>	Steel Clad	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	4316	<b>Spill Test Date</b>	01/29/2025	<b>Piping Installed Date</b>		<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	None	<b>AST</b>	No

Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Non-corrodible
Product	Diesel	PLL D Test Date		Tank/Piping CP Test Date	10/29/2012	Primary Tank Leak Detection	Manual Interstitial Monitoring	Primary Pipe Detection		Vapor Recovery	No
Capacity	4000	ATG Test Date	01/29/2025	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	01/29/2025			ATG Type					
Tank Code	08	Tank Age	11	Tank Installed Date	04/01/2015	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	5572	Spill Test Date	01/29/2025	Piping Installed Date	05/07/2015	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Non-corrodible
Product	Diesel	PLL D Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection		Vapor Recovery	No
Capacity	8000	ATG Test Date	01/29/2025	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	Yes
		Overfill Test Date	01/29/2025			ATG Type	Incon/TS-550 EVO				