Location: BERGS TIRE INC 2111 W Towne St

Glendive, MT 59330-3214 Dawson

System Facility ID:11-03214

Facility Code: 19730 Last Inspected On: 04/21/2022 Operating Permit Renewal Date: 07/20/2025

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Berg Tire 4063775286

Operator Contact: James Berg 4063775286

Owner/Operator: Berg Tire

James Berg, UST Class A Operator James Berg, UST Class B Operator

Tank Code	06	Tank Age	37	Tank Installed Date	03/26/1987	Tank Material	Cathodically Protected Steel	Piping Material	Steel	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	598	Spill Test Date	09/14/2021	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Diesel	PLLD Test Date	06/07/2021	Tank/Piping CP Test Date	04/21/2022	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	12000	ATG Test Date	09/14/2021	Line Tightness Test Date	10/31/2018	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	09/14/2021			ATG Type	Veeder Root/TLS- 450				
Tank Code	07	Tank Age	37	Tank Installed Date	03/26/1987	Tank Material	Cathodically Protected Steel	Piping Material	Steel	Overfill Types	High Level Alarm
Tag Number	599	Spill Test Date	06/13/2022	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date	06/07/2021	Tank/Piping CP Test Date	04/21/2022	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	12000	ATG Test Date	09/14/2021	Line Tightness Test Date	11/02/2018	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	09/14/2021			ATG Type	Veeder Root/TLS- 450				
Tank Code	08	Tank Age	37	Tank Installed Date	03/26/1987	Tank Material	Cathodically Protected Steel	Piping Material	Steel	Overfill Types	Flapper Valve;High Level Alarm

Report Created: 4/17/2024 Page [1] of [31]

Tag Number	600	Spill Test Date	09/14/2021	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Diesel, Dyed	PLLD Test Date	06/07/2021	Tank/Piping CP Test Date	04/21/2022	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	6000	ATG Test Date	09/14/2021	Line Tightness Test Date	11/08/2018	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	09/14/2021			ATG Type	Veeder Root/TLS- 450				
Tank Code	09	Tank Age	37	Tank Installed Date	03/26/1987	Tank Material	Cathodically Protected Steel	Piping Material	Steel	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	601	Spill Test Date	06/13/2022	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date	06/07/2021	Tank/Piping CP Test Date	04/21/2022	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	6000	ATG Test Date	09/14/2021	Line Tightness Test Date	10/29/2018	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	09/14/2021			ATG Type	Veeder Root/TLS- 450				

Report Created: 4/17/2024 Page [2] of [31]

Location: BN GLENDIVE RAIL YARD

310 N Merrill Ave

Glendive, MT 59330-1728 Dawson

Facility Code: 19829

Last Inspected On: 09/25/2019

/ ID:11-09528 Operating Permit Renewal Date: 12/04/2022

System Facility ID:11-09528

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: BNSF Railway Company Fort Worth 8173332000

Operator Contact: Tavita Masau 7736002860

Owner/Operator: BNSF Railway Company Fort Worth

Tavita Masau, UST Class A Operator Tavita Masau, UST Class B Global Operator

Tank Code	03	Tank Age	35	Tank Installed Date	12/28/1989	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	
Tag Number	504	Spill Test Date		Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Permanently Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Continuous Interstitial Monitoring	Piping Type	Gravity Feed	CP Met Types	Galvanic
Product	Mixture	PLLD Test Date		Tank/Piping CP Test Date	09/04/2019	Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	16000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					
Tank Code	SKC1	Tank Age	33	Tank Installed Date	09/01/1991	Tank Material	Bare Steel	Piping Material	Steel	Overfill Types	
Tag Number	505	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	Yes
Tank Status	Permanently Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Continuous Interstitial Monitoring	Piping Type	Gravity Feed	CP Met Types	
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	09/04/2019	Primary Tank Leak Detection		Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	680000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					

Report Created: 4/17/2024 Page [3] of [31]

Location: CIRCLE K STORE 2746271

701 N Merrill Ave

Glendive, MT 59330 Dawson

Facility Code: 19804
Last Inspected On: 01/02/2024
Operating Permit Renewal Date: 04/11/2027

System Facility ID:11-08061

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Rocky Mountain Oil LLC 6027288000

 Operator Contact:
 Chuck Nyberg; Dean Townsend
 9528308722

Owner/Operator: Rocky Mountain Oil LLC

Brad Lee, UST Class B Global Operator Chuck Nyberg, UST Class A Operator Dean Townsend, UST Class A Operator Greg Brewer, UST Class B Global Operator Kelly Jo Cooper, UST Class B Global Operator Travis Struckman, UST Class B Global Operator

Tank Code	01	Tank Age	45	Tank Installed Date	10/01/1979	Tank Material	Bare Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve
Tag Number	3001	Spill Test Date	03/15/2021	Piping Installed Date	06/03/2008	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date	03/21/2023	Tank/Piping CP Test Date	03/21/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	Yes
Capacity	12000	ATG Test Date	03/21/2023	Line Tightness Test Date	08/27/2020	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	03/21/2023			ATG Type	Gilbarco-Veeder Root/TLS- 350/Gilbarco EMC				
Tank Code	02	Tank Age	45	Tank Installed Date	10/01/1979	Tank Material	Bare Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve
Tag Number	3002	Spill Test Date	03/15/2021	Piping Installed Date	06/03/2008	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date	03/21/2023	Tank/Piping CP Test Date	03/21/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	Yes

Report Created: 4/17/2024 Page [4] of [31]

Capacity	12000	ATG Test Date	03/21/2023	Line Tightness Test Date	08/19/2020	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	03/21/2023			ATG Type	Gilbarco-Veeder Root/TLS- 350/Gilbarco EMC				
Tank Code	03	Tank Age	45	Tank Installed Date	10/01/1979	Tank Material	Bare Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve
Tag Number	3003	Spill Test Date	03/15/2021	Piping Installed Date	06/03/2008	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date	03/21/2023	Tank/Piping CP Test Date	03/21/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	Yes
Capacity	8000	ATG Test Date	03/21/2023	Line Tightness Test Date	08/13/2020	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	03/21/2023			ATG Type	Gilbarco-Veeder Root/TLS- 350/Gilbarco EMC				
Tank Code	04	Tank Age	45	Tank Installed Date	10/01/1979	Tank Material	Bare Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve
Tag Number	3004	Spill Test Date	03/15/2021	Piping Installed Date	06/03/2008	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Diesel	PLLD Test Date	03/21/2023	Tank/Piping CP Test Date	03/21/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	8000	ATG Test Date	03/21/2023	Line Tightness Test Date	08/23/2020	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	03/21/2023			ATG Type	Gilbarco-Veeder Root/TLS- 350/Gilbarco EMC				

Report Created: 4/17/2024 Page [5] of [31]

Location: CROSSROADS CONOCO GLENDIVE

56 Hwy 16

Glendive, MT 59330-3609 Dawson

Facility Code: 30551
Last Inspected On: 09/27/2023
System Facility ID:56-13872 Operating Permit Renewal Date: 03/14/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Gregory Cross 4066982967

Operator Contact: Gregory Cross;R J Serpe;Timothy Fife 4066982967

Owner/Operator: Greg Cross

Greg Cross, UST Class A Operator R J Serpe, UST Class A Operator R J Serpe, UST Class B Global Operator Ron Serpe, UST Class B Global Operator Timothy Fife, UST Class A Operator

Tank Code	01	Tank Age	25	Tank Installed Date	06/26/1999	Tank Material	Steel Clad	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	4043	Spill Test Date	09/20/2020	Piping Installed Date	01/03/2013	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	08/11/2022	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	10000	ATG Test Date	09/24/2023	Line Tightness Test Date	03/08/2012	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	09/20/2020			ATG Type	Gilbarco-Veeder Root/TLS- 350/Gilbarco EMC				
Tank Code	02	Tank Age	25	Tank Installed Date	06/26/1999	Tank Material	Steel Clad	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	4044	Spill Test Date	09/03/2020	Piping Installed Date	01/03/2013	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	08/11/2022	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No

Report Created: 4/17/2024 Page [6] of [31]

Capacity	15000	ATG Test Date	09/24/2023	Line Tightness Test Date	03/08/2012	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	09/03/2020			ATG Type	Gilbarco/EMC Basic				
Tank Code	03	Tank Age	25	Tank Installed Date	06/26/1999	Tank Material	Steel Clad	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	4045	Spill Test Date	09/03/2020	Piping Installed Date	01/03/2013	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	08/11/2022	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	10000	ATG Test Date	09/24/2023	Line Tightness Test Date	03/08/2012	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	09/03/2020			ATG Type	Gilbarco-Veeder Root/TLS- 350/Gilbarco EMC				

Report Created: 4/17/2024 Page [7] of [31]

Location: DAWSON COMMUNITY AIRPORT

402 Dry Creek Rd

Glendive, MT 59330-9204 Dawson

Facility Code: 19717
Last Inspected On: 06/12/2023
Operating Permit Renewal Date: 11/24/2026

System Facility ID:11-02455

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Dawson County 4066873372

Operator Contact: Craig Hostetler;Leon Baker 4063774505;4069892054

Owner/Operator: Dawson County

Bill Stebbins, UST Class B Operator Craig Hostetler, UST Class A Operator Craig Hostetler, UST Class B Operator Leon Baker, UST Class A Operator Leon Baker, UST Class B Global Operator Leon Baker, UST Class B Operator

Tank Code	04	Tank Age	30	Tank Installed Date	11/21/1994	Tank Material	Cathodically Protected Steel	Piping Material	Steel	Overfill Types	Flapper Valve
Tag Number	824	Spill Test Date	06/14/2022	Piping Installed Date		Tank Construction		Piping Construction	Secondary Containment Chase	AST	No
Tank Status	Currently in Use	MLLD Test Date	11/21/2022	Sump Tightness Test Date	07/29/2012	Catastrophic L.D Type 3.0	Auto Dialer;Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Aviation Gas	PLLD Test Date		Tank/Piping CP Test Date	06/12/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	8000	ATG Test Date	11/21/2022	Line Tightness Test Date	11/21/2022	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	06/14/2022			ATG Type	EMCO Electronics/EECO 1500				
Tank Code	S5	Tank Age	50	Tank Installed Date	01/01/1974	Tank Material	Unknown	Piping Material	Steel	Overfill Types	
Tag Number	825	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	Single Walled	AST	Yes
Tank Status	Currently in Use	MLLD Test Date	11/21/2022	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Auto Dialer;Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	

Report Created: 4/17/2024 Page [8] of [31]

Product	Jet Fuel (Jet- A, Jet-A1, JP5)	PLLD Test Date	Tank/Piping CP Test Date	06/12/2023	Primary Tank Leak Detection	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	10000	ATG Test Date	Line Tightness Test Date	11/21/2022	Secondary Tank Leak Detection	Secondary Pipe Detection		Energy Act	No
		Overfill Test Date			ATG Type				

Report Created: 4/17/2024 Page [9] of [31]

Location: EAST END CENEX

1803 Merrill Ave Glendive, MT 59330 Dawson

System Facility ID:11-00033

Facility Code: 19684
Last Inspected On: 03/11/2024
Operating Permit Renewal Date: 07/21/2024

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Cross Petroleum Services Glendive

Operator Contact: Gregory Cross;R J Serpe;Timothy Fife

4066982967

Owner/Operator: Cross Petroleum Services Glendive

Greg Cross, UST Class A Operator
R J Serpe, UST Class A Operator
R J Serpe, UST Class B Global Operator
Ron Serpe, UST Class B Global Operator
Timothy Fife, UST Class A Operator

Tank Code	08	Tank Age	9	Tank Installed Date	02/09/2015	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	5535	Spill Test Date		Piping Installed Date	02/09/2015	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	09/03/2020	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	Yes
Capacity	12000	ATG Test Date	09/06/2022	Line Tightness Test Date	03/20/2015	Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date				ATG Type	Incon/TS-550 EVO				
Tank Code	09	Tank Age	9	Tank Installed Date	02/09/2015	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	5536	Spill Test Date		Piping Installed Date	02/09/2015	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	09/03/2020	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No

Report Created: 4/17/2024 Page [10] of [31]

Capacity	12000	ATG Test Date	09/06/2022	Line Tightness Test Date	03/20/2015	Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date				ATG Type	Incon/TS-550 EVO				
Tank Code	10	Tank Age	9	Tank Installed Date	02/09/2015	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	5537	Spill Test Date		Piping Installed Date	02/09/2015	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	09/03/2020	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	Yes
Capacity	8000	ATG Test Date	09/06/2022	Line Tightness Test Date	03/20/2015	Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date				ATG Type	Incon/TS-550 EVO				
Tank Code	11	Tank Age	9	Tank Installed Date	02/09/2015	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	5538	Spill Test Date		Piping Installed Date	02/09/2015	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	09/03/2020	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.1;Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	4000	ATG Test Date	09/06/2022	Line Tightness Test Date	03/20/2015	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date				ATG Type	Incon/TS-550 EVO				

Report Created: 4/17/2024 Page [11] of [31]

Location: GLENDIVE COMBUSTION TURBINE

366 FAS 335

Glendive, MT 59330-9575 Dawson

Facility Code: 19827
Last Inspected On: 07/26/2021
Operating Permit Renewal Date: 11/17/2024

System Facility ID:11-09400

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Montana Dakota Utilities Co Bismarck

Operator Contact: Clay Olson; Evan Jones; Jim Shields; Kalle Kuether; Sean

Cameron

3076963597;4069395341;9705090698

Owner/Operator: Montana Dakota Utilities Co Bismarck

Chad Miller, UST Class B Operator

Clay Olson, UST Class A Operator

Clay Olson, UST Class B Global Operator

Evan Jones, UST Class A Operator

Evan Jones, UST Class B Operator

Jim Shields, UST Class A Operator

Jim Shields, UST Class B Global Operator

Jody Gustafson, UST Class B Global Operator

Kalle Kuether, UST Class A Operator

Sean Cameron, UST Class A Operator

Sean Cameron, UST Class B Operator

Tank Code	S2	Tank Age	37	Tank Installed Date	07/01/1987	Tank Material	Cathodically Protected Steel	Piping Material	Steel	Overfill Types	
Tag Number	1692	Spill Test Date		Piping Installed Date	07/13/2007	Tank Construction		Piping Construction	Double Walled	AST	Yes
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	07/02/2018	Catastrophic L.D Type 3.0	Auto Dialer	Piping Type	Pressurized	CP Met Types	
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Deferred	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	75000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					

Report Created: 4/17/2024 Page [12] of [31]

Location: GLENDIVE MEDICAL CENTER

202 Prospect Dr

Glendive, MT 59330-1943 Dawson

Facility Code: 19832 Last Inspected On: 09/18/2023 Operating Permit Renewal Date: 12/19/2026

System Facility ID:11-09735

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Glendive Medical Center

Operator Contact: Mike Ryan;Sam Durham

Owner/Operator: Glendive Medical Center

Craig Torno, UST Class B Operator Mike Ryan, UST Class A Operator Sam Durham, UST Class A Operator

Tank Code	03	Tank Age	29	Tank Installed Date	11/16/1995	Tank Material	Steel Clad	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	1223	Spill Test Date	03/10/2022	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	08/12/2018	Catastrophic L.D Type 3.0	Auto Dialer	Piping Type	U.S. Suction	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	3-Year Line Tightness Test	Vapor Recovery	No
Capacity	4000	ATG Test Date	03/09/2023	Line Tightness Test Date	03/10/2022	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	03/10/2022			ATG Type	Gilbarco-Veeder Root/TLS-300				

Page [13] of [31] Report Created: 4/17/2024

Location: JOYS GLENDIVE SERVICE INC 74 MT Hwy 16 Glendive, MT 59330-3609 Dawson

System Facility ID:11-07770

Facility Code: 19800 Last Inspected On: 02/06/2024 Operating Permit Renewal Date: 02/06/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: William Clemens 6085758642

Operator Contact: Glenn Lawres 4063771821

Owner/Operator: William Clemens

Glenn Lawres, UST Class A Operator Glenn Lawres, UST Class B Operator

Tank Code	06	Tank Age	26	Tank Installed Date	05/28/1998	Tank Material	Steel Clad	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	1511	Spill Test Date		Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Temporarily Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	06/14/2013	Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	8000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/ILS-350				
Tank Code	07	Tank Age	26	Tank Installed Date	05/28/1998	Tank Material	Steel Clad	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	1512	Spill Test Date		Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Temporarily Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	06/14/2013	Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	4000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/ILS-350				
Tank Code	08	Tank Age	26	Tank Installed Date	05/28/1998	Tank Material	Steel Clad	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve

Page [14] of [31] Report Created: 4/17/2024

Tag Number	1513	Spill Test Date		Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Temporarily Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	06/14/2013	Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	6000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/ILS-350				
Tank Code	09	Tank Age	26	Tank Installed Date	05/28/1998	Tank Material	Steel Clad	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	1514	Spill Test Date		Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Temporarily Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	06/14/2013	Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	2000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/ILS-350				

Report Created: 4/17/2024 Page [15] of [31]

Location: LOAF 'N JUG #710

322 E Barry St Glendive, MT 59330-2306 Dawson

System Facility ID:11-05093

Facility Code: 19756
Last Inspected On: 07/19/2022
Operating Permit Renewal Date: 10/04/2025

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Mini Mart Inc dba Loaf 'N Jug Pueblo 5139641568

Operator Contact: Theodore Bezel; Mini Mart Inc dba Loaf 'N Jug Pueblo 5139641568

Owner/Operator: Mini Mart Inc dba Loaf 'N Jug Pueblo

Theodore Bezel, UST Class A Operator
Theodore Bezel, UST Class B Global Operator
Theodore Bezel, UST Class B Operator

Tank Code	04	Tank Age	28	Tank Installed Date	09/01/1996	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	1636	Spill Test Date	10/21/2020	Piping Installed Date	05/07/2012	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	10/02/2020	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	07/19/2022	Tank/Piping CP Test Date	11/22/2011	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	10000	ATG Test Date	07/19/2022	Line Tightness Test Date	07/19/2022	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	10/21/2020			ATG Type	Gilbarco-Veeder Root/TLS- 350/Gilbarco EMC				
Tank Code	05	Tank Age	28	Tank Installed Date	09/01/1996	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	1637	Spill Test Date	10/21/2020	Piping Installed Date	05/07/2012	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	01/07/2021	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	07/19/2022	Tank/Piping CP Test Date	11/22/2011	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	10000	ATG Test Date	07/19/2022	Line Tightness Test Date	07/19/2022	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No

Report Created: 4/17/2024 Page [16] of [31]

		Overfill Test Date	10/21/2020			ATG Type	Gilbarco-Veeder Root/TLS- 350/Gilbarco EMC				
Tank Code	06	Tank Age	28	Tank Installed Date	09/01/1996	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	1638	Spill Test Date	10/21/2020	Piping Installed Date	05/07/2012	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	10/02/2020	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	07/19/2022	Tank/Piping CP Test Date	11/22/2011	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	10000	ATG Test Date	07/19/2022	Line Tightness Test Date	07/19/2022	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	10/21/2020			ATG Type	Gilbarco-Veeder Root/TLS- 350/Gilbarco EMC				

Report Created: 4/17/2024 Page [17] of [31]

Location: QWEST GLENDIVE CENTRAL OFFICE

119 W Valentine St

Glendive, MT 59330-1638 Dawson

Facility Code: 19783
Last Inspected On: 09/07/2023
Operating Permit Renewal Date: 04/22/2027

System Facility ID:11-06870

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Century Link Communication 5016808141

Operator Contact: Stephanie Miller 5016808141

Owner/Operator: Century Link Communication

Stephanie Miller, UST Class A Operator Stephanie Miller, UST Class B Global Operator

Tank Code	01	Tank Age	31	Tank Installed Date	04/01/1993	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	1726	Spill Test Date	09/07/2023	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	U.S. Suction	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	3-Year Line Tightness Test	Vapor Recovery	No
Capacity	553	ATG Test Date	09/07/2023	Line Tightness Test Date	07/26/2023	Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	09/07/2023			ATG Type	Veeder Root/TLS- 300				

Report Created: 4/17/2024 Page [18] of [31]

Location: SUPERPUMPER 58

1320 N Merrill Ave

Glendive, MT 59330-1958 Dawson

System Facility ID:11-04213

Facility Code: 19747
Last Inspected On: 03/23/2022
Operating Permit Renewal Date: 06/09/2025

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Superpumper Inc 7018521194

Operator Contact: Nancy Coen 7204212140

Owner/Operator: Superpumper Inc

Adrianna Zody, UST Class B Operator Nancy Coen, UST Class A Operator Nancy Coen, UST Class B Operator

Tank Code	01	Tank Age	40	Tank Installed Date	05/06/1984	Tank Material	Bare Steel	Piping Material	Steel	Overfill Types	Flapper Valve
Tag Number	4308	Spill Test Date	01/24/2023	Piping Installed Date	05/09/2007	Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Diesel	PLLD Test Date	09/14/2021	Tank/Piping CP Test Date	01/24/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	10000	ATG Test Date	09/14/2021	Line Tightness Test Date	12/28/2021	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	01/24/2023			ATG Type	Gilbarco-Veeder Root/TLS- 350/Gilbarco EMC				
Tank Code	02	Tank Age	40	Tank Installed Date	05/06/1984	Tank Material	Bare Steel	Piping Material	Steel	Overfill Types	Flapper Valve
Tag Number	4309	Spill Test Date	01/24/2023	Piping Installed Date	05/09/2007	Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date	09/14/2021	Tank/Piping CP Test Date	01/24/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	10000	ATG Test Date	09/14/2021	Line Tightness Test Date	12/30/2021	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	01/24/2023			ATG Type	Gilbarco-Veeder Root/TLS- 350/Gilbarco EMC				

Report Created: 4/17/2024 Page [19] of [31]

Tank Code	03	Tank Age	40	Tank Installed Date	05/06/1984	Tank Material	Bare Steel	Piping Material	Steel	Overfill Types	Flapper Valve
Tag Number	4310	Spill Test Date	01/24/2023	Piping Installed Date	05/09/2007	Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date	09/14/2021	Tank/Piping CP Test Date	01/24/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	10000	ATG Test Date	09/14/2021	Line Tightness Test Date	01/01/2022	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	01/24/2023			ATG Type	Gilbarco-Veeder Root/TLS- 350/Gilbarco EMC				

Report Created: 4/17/2024 Page [20] of [31]

Location: TOWN PUMP GLENDIVE TRAVEL PLAZA

73 Hwy 16

Glendive, MT 59330 Dawson

Facility Code: 30996 Last Inspected On: 02/06/2024 Operating Permit Renewal Date: 01/08/2027

System Facility ID:60-15289

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Glendive 1 Town Pump LLC 4064976700

Operator Contact: Trent Biggers;Town Pump

Owner/Operator: Glendive 1 Town Pump LLC

Trent Biggers, UST Class A Operator Trent Biggers, UST Class B Operator

Tank Code	01	Tank Age	7	Tank Installed Date	07/10/2017	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	5686	Spill Test Date	01/24/2024	Piping Installed Date	07/10/2017	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	08/12/2020	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	06/14/2022	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	30000	ATG Test Date	06/14/2022	Line Tightness Test Date		Secondary Tank Leak Detection	Statistical Inventory Reconciliation	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	Yes
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-450				
Tank Code	02	Tank Age	7	Tank Installed Date	07/10/2017	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	5687	Spill Test Date		Piping Installed Date	07/10/2017	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	08/12/2020	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	06/14/2022	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection		Vapor Recovery	No
Capacity	15000	ATG Test Date	06/14/2022	Line Tightness Test Date		Secondary Tank Leak Detection	Statistical Inventory Reconciliation	Secondary Pipe Detection	Continuous Interstitial Monitoring;Statisti cal Inventory Reconciliation	Energy Act	Yes

Page [21] of [31] Report Created: 4/17/2024

		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-450				
Tank Code	03	Tank Age	7	Tank Installed Date	07/10/2017	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	5688	Spill Test Date		Piping Installed Date	07/10/2017	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	08/12/2020	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	06/14/2022	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	7000	ATG Test Date	06/14/2022	Line Tightness Test Date		Secondary Tank Leak Detection	Statistical Inventory Reconciliation	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	Yes
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-450				
Tank Code	04	Tank Age	7	Tank Installed Date	07/10/2017	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	5689	Spill Test Date	01/24/2024	Piping Installed Date	07/10/2017	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	08/12/2020	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	06/14/2022	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	30000	ATG Test Date	06/14/2022	Line Tightness Test Date		Secondary Tank Leak Detection	Statistical Inventory Reconciliation	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	Yes
		Overfill Test Date	01/24/2024			ATG Type	Gilbarco-Veeder Root/TLS-450				
Tank Code	05	Tank Age	7	Tank Installed Date	07/10/2017	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	5690	Spill Test Date		Piping Installed Date	07/10/2017	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	08/12/2020	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	06/14/2022	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity 8	8000	ATG Test Date	06/14/2022	Line Tightness Test Date		Secondary Tank Leak Detection	Statistical Inventory Reconciliation	Secondary Pipe Detection		Energy Act	Yes
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-450				
Tank Code	06	Tank Age	7	Tank Installed Date	07/10/2017	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve

Report Created: 4/17/2024 Page [22] of [31]

Tag Number	5691	Spill Test Date	01/24/2024	Piping Installed Date	07/10/2017	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	08/12/2020	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	06/14/2022	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	30000	ATG Test Date	06/14/2022	Line Tightness Test Date		Secondary Tank Leak Detection	Statistical Inventory Reconciliation	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	Yes
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-450				
Tank Code	07	Tank Age	7	Tank Installed Date	07/10/2017	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	5692	Spill Test Date	10/09/2021	Piping Installed Date	07/10/2017	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	08/12/2020	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	06/14/2022	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	7000	ATG Test Date	06/14/2022	Line Tightness Test Date		Secondary Tank Leak Detection	Statistical Inventory Reconciliation	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	Yes
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-450				
Tank Code	08	Tank Age	7	Tank Installed Date	07/10/2017	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	5719	Spill Test Date		Piping Installed Date	07/10/2017	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	08/12/2020	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	06/14/2022	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	12000	ATG Test Date	06/14/2022	Line Tightness Test Date		Secondary Tank Leak Detection	Statistical Inventory Reconciliation	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	Yes
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-450				

Report Created: 4/17/2024 Page [23] of [31]

Location: TRAIL STAR CAR AND TRUCK STOP

11 MT Hwy 16 Glendive, MT 59330 Dawson

System Facility ID:11-05754

Facility Code: 19761 Last Inspected On: 12/04/2023 Operating Permit Renewal Date: 03/09/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Trailstar Truck Stop Inc

Operator Contact: Cheryl Haggerty

Owner/Operator: Trailstar Truck Stop Inc

Cheryl Haggerty, UST Class A Operator Cheryl Haggerty, UST Class B Operator

Tank Code	05	Tank Age	26	Tank Installed Date	11/30/1998	Tank Material	Steel Clad	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	4274	Spill Test Date	10/25/2023	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	10/24/2023	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	4000	ATG Test Date	10/23/2023	Line Tightness Test Date	06/20/2020	Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	10/24/2023			ATG Type	Gilbarco-Veeder Root/TLS- 350/Gilbarco EMC				
Tank Code	06	Tank Age	26	Tank Installed Date	11/30/1998	Tank Material	Steel Clad	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	4275	Spill Test Date	10/25/2023	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	10/24/2023	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	8000	ATG Test Date	10/23/2023	Line Tightness Test Date	06/02/2020	Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	10/24/2023			ATG Type	Gilbarco-Veeder Root/TLS- 350/Gilbarco EMC				

Page [24] of [31] Report Created: 4/17/2024

Tank Code	07	Tank Age	26	Tank Installed Date	11/30/1998	Tank Material	Steel Clad	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	4276	Spill Test Date	10/25/2023	Piping Installed Date	01/07/2011	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	10/24/2023	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	12000	ATG Test Date	10/23/2024	Line Tightness Test Date	08/20/2020	Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	10/24/2023			ATG Type	Gilbarco-Veeder Root/TLS- 350/Gilbarco EMC				
Tank Code	08	Tank Age	26	Tank Installed Date	11/30/1998	Tank Material	Steel Clad	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	4277	Spill Test Date	10/25/2023	Piping Installed Date	08/17/2009	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	10/24/2023	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	8000	ATG Test Date	10/23/2023	Line Tightness Test Date	07/20/2020	Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	10/24/2023			ATG Type	Gilbarco-Veeder Root/TLS- 350/Gilbarco EMC				
Tank Code	09	Tank Age	26	Tank Installed Date	11/30/1998	Tank Material	Steel Clad	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	4278	Spill Test Date	10/25/2023	Piping Installed Date	08/17/2009	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	10/24/2023	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	15000	ATG Test Date	10/23/2023	Line Tightness Test Date	07/20/2020	Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	10/24/2023			ATG Type	Gilbarco-Veeder Root/TLS- 350/Gilbarco EMC				

Report Created: 4/17/2024 Page [25] of [31]

Location: WEST PARK CENEX 2200 W Towne St

Glendive, MT 59330 Dawson

Facility Code: 19822
Last Inspected On: 07/06/2021

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Cross Petroleum Services Glendive

Operator Contact: Alvaro Garcia; Gregory Cross; R J Serpe

4066982967;6023738892

Owner/Operator: Cross Petroleum Services Glendive

Alvaro Garcia, UST Class A Operator Alvaro Garcia, UST Class B Global Operator Greg Cross, UST Class A Operator R J Serpe, UST Class A Operator R J Serpe, UST Class B Global Operator

Tank Code	S4	Tank Age	25	Tank Installed Date	09/01/1999	Tank Material	Unknown	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	553	Spill Test Date		Piping Installed Date	09/21/2021	Tank Construction		Piping Construction	Double Walled	AST	Yes
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Gasoline	PLLD Test Date	08/10/2022	Tank/Piping CP Test Date		Primary Tank Leak Detection		Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	12000	ATG Test Date	08/10/2022	Line Tightness Test Date	03/11/2015	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date				ATG Type					
Tank Code	S5	Tank Age	25	Tank Installed Date	09/01/1999	Tank Material	Unknown	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	554	Spill Test Date		Piping Installed Date	09/21/2021	Tank Construction		Piping Construction	Double Walled	AST	Yes
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Gasoline	PLLD Test Date	08/10/2022	Tank/Piping CP Test Date		Primary Tank Leak Detection		Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	12000	ATG Test Date	08/10/2022	Line Tightness	02/05/2015	Secondary Tank		Secondary Pipe	ELLD 0.2	Energy Act	No
	12000	ATO Test Date	00/10/2022	Test Date		Leak Detection		Detection		Lifergy Act	

Report Created: 4/17/2024 Page [26] of [31]

Tank Code	S6	Tank Age	25	Tank Installed Date	09/01/1999	Tank Material	Unknown	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	555	Spill Test Date		Piping Installed Date	09/21/2021	Tank Construction		Piping Construction	Double Walled	AST	Yes
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Diesel	PLLD Test Date	08/10/2022	Tank/Piping CP Test Date		Primary Tank Leak Detection		Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	10000	ATG Test Date	08/10/2022	Line Tightness Test Date	02/07/2015	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date				ATG Type					

Report Created: 4/17/2024 Page [27] of [31]

Location: WESTGATE CENEX

56 MT Hwy 16 Glendive, MT 59330 Dawson Facility Code: 19823
Last Inspected On: 07/06/2021
Operating Permit Renewal Date: 10/31/2024

System Facility ID:11-08909

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Cross Petroleum Services Glendive

Operator Contact: Gregory Cross;R J Serpe;Timothy Fife

4066982967

Owner/Operator: Cross Petroleum Services Glendive

Greg Cross, UST Class A Operator
R J Serpe, UST Class A Operator
R J Serpe, UST Class B Global Operator
Timothy Fife, UST Class A Operator

Tank Code	01	Tank Age	63	Tank Installed Date	05/22/1961	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve;Flapper Valve
Tag Number	556	Spill Test Date	08/18/2021	Piping Installed Date	08/23/2007	Tank Construction	Lined Interior/Impressed Current	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	07/13/2012	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	07/06/2021	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	10000	ATG Test Date	08/11/2022	Line Tightness Test Date	07/06/2012	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	08/18/2021			ATG Type	Incon/TS-550 EVO				
Tank Code	02	Tank Age	63	Tank Installed Date	05/22/1961	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	557	Spill Test Date	08/18/2021	Piping Installed Date	08/23/2007	Tank Construction	Lined Interior/Impressed Current	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	07/13/2012	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	07/06/2021	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No

Report Created: 4/17/2024 Page [28] of [31]

Capacity	8000	ATG Test Date	08/11/2022	Line Tightness Test Date	08/09/2011	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	08/18/2021			ATG Type	Incon/TS-550 EVO				
Tank Code	05	Tank Age	32	Tank Installed Date	02/07/1992	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	558	Spill Test Date	08/18/2021	Piping Installed Date	08/23/2007	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	07/13/2012	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	07/06/2021	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	10000	ATG Test Date	08/11/2022	Line Tightness Test Date	07/04/2012	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	08/18/2021			ATG Type	Incon/TS-550 EVO				

Report Created: 4/17/2024 Page [29] of [31]

Location: FARMERS ELEVATOR RICHEY

111 Railroad Ave

Richey, MT 59259 Dawson

Facility Code: 19762
Last Inspected On: 01/31/2022
Operating Permit Renewal Date: 02/02/2025

System Facility ID:11-05898

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: CHS Inc Richey 4067735758

Operator Contact:

Owner/Operator: CHS Inc Richey

Jana Olson, UST Class B Operator Lance Schipman, UST Class B Operator

Tank Code	05	Tank Age	23	Tank Installed Date	07/11/2001	Tank Material	Steel Clad	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	4314	Spill Test Date	08/02/2022	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	10/29/2012	Primary Tank Leak Detection	Manual Interstitial Monitoring	Primary Pipe Detection		Vapor Recovery	No
Capacity	4000	ATG Test Date	01/31/2022	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	01/31/2022		[ATG Type					
Tank Code	06	Tank Age	23	Tank Installed Date	07/11/2001	Tank Material	Steel Clad	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	4315	Spill Test Date	08/02/2022	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	10/29/2012	Primary Tank Leak Detection	Manual Interstitial Monitoring	Primary Pipe Detection		Vapor Recovery	No
Capacity	4000	ATG Test Date	01/31/2022	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	08/02/2022			ATG Type					
Tank Code	07	Tank Age	23	Tank Installed Date	07/11/2001	Tank Material	Steel Clad	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	4316	Spill Test Date	08/02/2022	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	None	AST	No

Report Created: 4/17/2024 Page [30] of [31]

Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	10/29/2012	Primary Tank Leak Detection	Manual Interstitial Monitoring	Primary Pipe Detection		Vapor Recovery	No
Capacity	4000	ATG Test Date	01/31/2022	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	08/02/2022			ATG Type					
Tank Code	08	Tank Age	9	Tank Installed Date	04/01/2015	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	5572	Spill Test Date	01/31/2022	Piping Installed Date	05/07/2015	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	05/04/2015	Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection		Vapor Recovery	No
Capacity	8000	ATG Test Date	01/31/2022	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	Yes
		Overfill Test Date	01/31/2022			ATG Type	Incon/TS-550 EVO				