

Facility Summary in Deer Lodge County in the City of Anaconda

Location: FAIRMONT RV PARK AND CAMPGROUND LLC
 1700 Fairmont Rd
 Anaconda, MT 59711-9419 Deer Lodge

Legacy ID:56-13976

Facility ID: 30638
Last Inspected On: 08/29/2019
Operating Permit Renewal Date: 11/01/2022

Owner Operator Contact: Fairmont RV Resort

Operator Contact: Joe Bashaw;Kevin Johnson;Nancy Johnson

4062091794;4065930929

Owner/Operator: Fairmont RV Resort

Caroline Thomer, UST Class B Operator
 Jeana Johnson, UST Class B Operator
 Joe Bashaw, UST Class A Operator
 Joe Bashaw, UST Class B Global Operator
 Kevin Johnson, UST Class A Operator
 Kevin Johnson, UST Class B Operator
 Nancy Johnson, UST Class A Operator
 Nancy Johnson, UST Class B Operator
 Shelia Johnson, UST Class B Operator

| Tank Code | Age | Installed | Tank Material Construction | Piping Material | Overfill Types |
|------------------|-----|-----------------------|--------------------------------|-------------------------------|-----------------|
| Tag # | AST | Sump Tightness | Secondary Option | Secondary Option | Spill Protected |
| Status | | Piping Installed Date | Catastrophic L.D. Type 3.0 | Piping Type | CP Met Types |
| Product | | Tank/Pipe CP | Tank Detection | Primary Pipe Detection | Vapor Recovery |
| Capacity | | Line Tightness | ATG Type | Secondary Pipe Detection | Energy Act |
| 02 | 21 | 04/01/2000 | Fiberglass Reinforced Plastic | Fiberglass Reinforced Plastic | Flapper Valve |
| 4187 | No | | Double-Walled | None | Yes |
| Currently in Use | | | Not Required | Safe Suction | Non-corrodible |
| Gasoline | | | Manual Interstitial Monitoring | Deferred | No |
| 3,000 | | | | | No |
| 03 | 21 | 04/01/2000 | Fiberglass Reinforced Plastic | Fiberglass Reinforced Plastic | Flapper Valve |
| 4188 | No | | Double-Walled | None | Yes |
| Currently in Use | | | Not Required | Safe Suction | Non-corrodible |
| Diesel | | | Manual Interstitial Monitoring | Deferred | No |

3,000

No

Facility Summary in Deer Lodge County in the City of Anaconda

Location: MAIN GRANULATED SLAG PILE - ANACONDA
SMELTER NPL SITE
6 mi west of I-90 on Hwy 1
Anaconda, MT 59711-9190 Deer Lodge

Legacy ID:12-10912

Facility ID: 19943
Last Inspected On: 07/19/2019
Operating Permit Renewal Date: 09/08/2022

Owner Operator Contact:

Operator Contact:

Owner/Operator: RDM Multi Enterprises Inc

William Prendergast, UST Class B Global Operator

| Tank Code | Age | Installed | Tank Material Construction | Piping Material | Overfill Types |
|------------------|-----|-----------------------|------------------------------------|--|-----------------|
| Tag # | AST | Sump Tightness | Secondary Option | Secondary Option | Spill Protected |
| Status | | Piping Installed Date | Catastrophic L.D. Type 3.0 | Piping Type | CP Met Types |
| Product | | Tank/Pipe CP | Tank Detection | Primary Pipe Detection | Vapor Recovery |
| Capacity | | Line Tightness | ATG Type | Secondary Pipe Detection | Energy Act |
| S1 | 36 | 04/16/1985 | Bare Steel | Steel | |
| 1836 | Yes | 05/06/2016 | | Double Walled | Yes |
| Currently in Use | | | Continuous Interstitial Monitoring | Pressurized | |
| Diesel | | | Deferred | Continuous Interstitial Monitoring;MLLD Line Tightness Testing | No |
| 12,800 | | 07/27/2016 | | | No |

Facility Summary in Deer Lodge County in the City of Anaconda

Location: THRIFTWAY SUPER STOP 3
1420 E Park Ave
Anaconda, MT 59711-2766 Deer Lodge

Legacy ID:12-07938

Facility ID: 19928
Last Inspected On: 02/22/2019
Operating Permit Renewal Date: 06/12/2022

Owner Operator Contact: Linda Sutey;Sutey Oil Co Inc;Sutey Oil Co Inc

4064942305;4064942305;4064942305

Operator Contact: Jack Hook;Linda Otonicar;Louis Sutey

4064915808;4064942305

Owner/Operator: Sutey Oil Co Inc

Jack Hook, UST Class A Operator
Jack Hook, UST Class B Global Operator
Jack Hook, UST Class B Operator

Ken Beck, UST Class B Operator
 Linda Otonicar, UST Class A Operator
 Louis Sutey, UST Class A Operator
 Louis Sutey, UST Class B Global Operator
 Ted Weinman, UST Class B Operator
 Theresa Weinman, UST Class B Operator

| Tank Code | Age | Installed | Tank Material Construction | Piping Material | Overfill Types |
|------------------|-----|-----------------------|---|--|-----------------|
| Tag # | AST | Sump Tightness | Secondary Option | Secondary Option | Spill Protected |
| Status | | Piping Installed Date | Catastrophic L.D. Type 3.0 | Piping Type | CP Met Types |
| Product | | Tank/Pipe CP | Tank Detection | Primary Pipe Detection | Vapor Recovery |
| Capacity | | Line Tightness | ATG Type | Secondary Pipe Detection | Energy Act |
| 06 | 31 | 09/01/1990 | Fiberglass Reinforced Plastic | Flexible Plastic | Flapper Valve |
| 2048 | No | 10/24/2012 | | Double Walled | Yes |
| Currently in Use | | 10/04/2012 | Electronic Line Leak Detector | Pressurized | |
| Gasoline | | | Automatic Tank Gauging 0.2 | Continuous Interstitial Monitoring; ELLD 0.1; ELLD 0.2 | No |
| 15,000 | | | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | No |
| 07 | 31 | 09/01/1990 | Fiberglass Reinforced Plastic | Flexible Plastic | Flapper Valve |
| 2049 | No | 10/17/2012 | | Double Walled | Yes |
| Currently in Use | | 10/04/2012 | Electronic Line Leak Detector | Pressurized | |
| Gasoline | | | Automatic Tank Gauging 0.2 | Continuous Interstitial Monitoring; ELLD 0.1; ELLD 0.2 | No |
| 12,000 | | | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | No |
| 08 | 31 | 09/01/1990 | Fiberglass Reinforced Plastic | Flexible Plastic | Flapper Valve |
| 2050 | No | 10/17/2012 | | Double Walled | Yes |
| Currently in Use | | 10/04/2012 | Electronic Line Leak Detector | Pressurized | |
| Diesel | | | Automatic Tank Gauging 0.2 | Continuous Interstitial Monitoring; ELLD 0.1; ELLD 0.2 | No |
| 12,000 | | | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | No |

| | | | | | |
|------------------|----|------------|---|--|---------------|
| 09 | 31 | 09/01/1990 | Fiberglass Reinforced Plastic | Flexible Plastic | Flapper Valve |
| 2051 | No | 10/17/2012 | | Double Walled | Yes |
| Currently in Use | | 10/04/2012 | Electronic Line Leak Detector | Pressurized | |
| Diesel | | | Automatic Tank Gauging 0.2 | Continuous Interstitial Monitoring; ELLD 0.1; ELLD 0.2 | No |
| 6,000 | | | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | No |
| 10 | 31 | 09/01/1990 | Fiberglass Reinforced Plastic | Flexible Plastic | Flapper Valve |
| 2052 | No | 10/17/2012 | | Double Walled | Yes |
| Currently in Use | | 10/04/2012 | Electronic Line Leak Detector | Pressurized | |
| Diesel | | | Automatic Tank Gauging 0.2 | Continuous Interstitial Monitoring; ELLD 0.1; ELLD 0.2 | No |
| 6,000 | | | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | No |

Facility Summary in Deer Lodge County in the City of Anaconda

Location: THRIFTWAY SUPER STOP 7
2035 W Park Ave
Anaconda, MT 59711-1774 Deer Lodge

Legacy ID:12-00101

Facility ID: 19861
Last Inspected On: 02/22/2019
Operating Permit Renewal Date: 02/27/2022

Owner Operator Contact: Sutey Oil Co Inc

4064942305

Operator Contact: Brian Clemons; Jack Hook; Linda Otonicar; Louis Sutey; Theodore Weinman

4064915808; 4064942305; 4065603928; 4065632410

Owner/Operator: Sutey Oil Co Inc

- Allyn Moses, UST Class B Operator
- Brian Clemons, UST Class A Operator
- Brian Clemons, UST Class B Operator
- Gwendolyn Wood, UST Class B Operator
- Jack Hook, UST Class A Operator
- Jack Hook, UST Class B Global Operator
- Jack Hook, UST Class B Operator
- Linda Otonicar, UST Class A Operator
- Louis Sutey, UST Class A Operator
- Louis Sutey, UST Class B Global Operator
- Theodore Weinman, UST Class A Operator
- Theodore Weinman, UST Class B Operator

| Tank Code | Age | Installed | Tank Material Construction | Piping Material | Overfill Types |
|-----------|-----|-----------|----------------------------|-----------------|----------------|
|-----------|-----|-----------|----------------------------|-----------------|----------------|

| Tag # | AST | Sump Tightness | Secondary Option | Secondary Option | Spill Protected |
|------------------|-----|-----------------------|----------------------------------|-------------------------------|-------------------|
| Status | | Piping Installed Date | Catastrophic L.D. Type 3.0 | Piping Type | CP Met Types |
| Product | | Tank/Pipe CP | Tank Detection | Primary Pipe Detection | Vapor Recovery |
| Capacity | | Line Tightness | ATG Type | Secondary Pipe Detection | Energy Act |
| 02 | 50 | 12/31/1971 | Cathodically Protected Steel | Fiberglass Reinforced Plastic | Flapper Valve |
| 2045 | No | | Lined Interior/Impressed Current | Double Walled | Yes |
| Currently in Use | | | Mechanical Line Leak Detector | Pressurized | Impressed Current |
| Gasoline | | 06/06/2016 | Automatic Tank Gauging 0.2 | MLLD Line Tightness Testing | No |
| 10,000 | | 04/11/2018 | Gilbarco/EMC Basic | | No |
| 04 | 28 | 07/01/1993 | Fiberglass Reinforced Plastic | Fiberglass Reinforced Plastic | Flapper Valve |
| 2046 | No | | | Double Walled | Yes |
| Currently in Use | | | Mechanical Line Leak Detector | Pressurized | |
| Gasoline | | 06/06/2016 | Automatic Tank Gauging 0.2 | MLLD Line Tightness Testing | No |
| 12,000 | | 04/11/2018 | Gilbarco/EMC Basic | | No |
| 05 | 28 | 07/01/1993 | Fiberglass Reinforced Plastic | Fiberglass Reinforced Plastic | Flapper Valve |
| 2047 | No | | | Double Walled | Yes |
| Currently in Use | | | Mechanical Line Leak Detector | Pressurized | |
| Diesel | | 06/06/2016 | Automatic Tank Gauging 0.2 | MLLD Line Tightness Testing | No |
| 12,000 | | 04/11/2018 | Gilbarco/EMC Basic | | No |

Facility Summary in Deer Lodge County in the City of Anaconda

Location: TOWN PUMP INC ANACONDA 1
6940 MT Hwy 1 Ste A
Anaconda, MT 59711 Deer Lodge

Legacy ID:12-09326

Facility ID: 19935
Last Inspected On: 12/30/2020
Operating Permit Renewal Date: 05/31/2024

Owner Operator Contact: Don Edmisten;Town Pump

4064976948

Operator Contact: Trent Biggers

Owner/Operator: Anaconda 1 Town Pump LLC

Trent Biggers, UST Class A Operator
Trent Biggers, UST Class B Global Operator

| Tank Code | Age | Installed | Tank Material Construction | Piping Material | Overfill Types |
|------------------|-----|-----------------------|---|--|-------------------|
| Tag # | AST | Sump Tightness | Secondary Option | Secondary Option | Spill Protected |
| Status | | Piping Installed Date | Catastrophic L.D. Type 3.0 | Piping Type | CP Met Types |
| Product | | Tank/Pipe CP | Tank Detection | Primary Pipe Detection | Vapor Recovery |
| Capacity | | Line Tightness | ATG Type | Secondary Pipe Detection | Energy Act |
| 05 | 30 | 05/01/1991 | Bare Steel | Flexible Plastic | Flapper Valve |
| 2411 | No | | | Double Walled | Yes |
| Currently in Use | | | Electronic Line Leak Detector | Pressurized | Impressed Current |
| Diesel | | 02/05/2018 | Approved Remote Monitoring;Statistical Inventory Reconciliation | Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation | No |
| 12,000 | | 09/01/2005 | Gilbarco-Veeder Root/TLS-350 | | No |
| 06 | 30 | 05/01/1991 | Bare Steel | Fiberglass Reinforced Plastic | Flapper Valve |
| 2412 | No | | | Double Walled | Yes |
| Currently in Use | | | Electronic Line Leak Detector | Pressurized | Impressed Current |
| Gasoline | | 02/05/2018 | Approved Remote Monitoring;Statistical Inventory Reconciliation | Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation | No |
| 12,000 | | 09/01/2005 | Gilbarco-Veeder Root/TLS-350 | | No |
| 07 | 27 | 12/01/1994 | Fiberglass Reinforced Plastic | Flexible Plastic | Flapper Valve |
| 2413 | No | | | Double Walled | Yes |
| Currently in Use | | | Electronic Line Leak Detector | Pressurized | Non-corrodible |
| Gasoline | | 06/24/2014 | Approved Remote Monitoring;Statistical Inventory Reconciliation | Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation | No |
| 10,000 | | 09/01/2005 | Gilbarco-Veeder Root/TLS-350 | | No |

| | | | | | |
|------------------|----|------------|--|--|------------------|
| 08 | 27 | 11/01/1994 | Fiberglass Reinforced Plastic | Flexible Plastic | Flapper Valve |
| 2414 | No | | | Double Walled | Yes |
| Currently in Use | | | Electronic Line Leak Detector | Pressurized | Non-corrodible |
| Gasoline | | 06/24/2014 | Approved Remote Monitoring;Statistical Inventory Reconciliation | Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation | No |
| 12,000 | | 09/01/2005 | Gilbarco-Veeder Root/TLS-350 | | No |
| 09 | 20 | 07/01/2001 | Fiberglass Reinforced Plastic | Flexible Plastic | Flapper Valve |
| 4574 | No | | Double-Walled | Double Walled | Yes |
| Currently in Use | | | Electronic Line Leak Detector | Pressurized | Non-corrodible |
| Diesel | | 05/05/2012 | Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation | Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation | No |
| 10,000 | | 09/01/2005 | Gilbarco-Veeder Root/TLS-350 | | No |
| 10 | 20 | 07/01/2001 | Fiberglass Reinforced Plastic | Flexible Plastic | Ball Float Valve |
| 4575 | No | | Double-Walled | Double Walled | Yes |
| Currently in Use | | | Electronic Line Leak Detector | Pressurized | Non-corrodible |
| Diesel | | 05/05/2012 | Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation | Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation | No |
| 5,000 | | 09/01/2005 | Gilbarco-Veeder Root/TLS-350 | | No |

Facility Summary in Deer Lodge County in the City of Anaconda

Location: TOWN PUMP INC ANACONDA 2
819 W Park Ave
Anaconda, MT 59711 Deer Lodge

Legacy ID:12-08668

Facility ID: 19933
Last Inspected On: 08/15/2020
Operating Permit Renewal Date: 02/06/2024

Owner Operator Contact: Don Edmisten;Town Pump Inc Anaconda PTRCB 1835 **4064976948**

Operator Contact: Trent Biggers

Owner/Operator: Anaconda 2 Town Pump LLC

Trent Biggers, UST Class A Operator
Trent Biggers, UST Class B Global Operator

| Tank Code | Age | Installed | Tank Material Construction | Piping Material | Overfill Types |
|------------------|-----|-----------------------|---|---|------------------|
| Tag # | AST | Sump Tightness | Secondary Option | Secondary Option | Spill Protected |
| Status | | Piping Installed Date | Catastrophic L.D. Type 3.0 | Piping Type | CP Met Types |
| Product | | Tank/Pipe CP | Tank Detection | Primary Pipe Detection | Vapor Recovery |
| Capacity | | Line Tightness | ATG Type | Secondary Pipe Detection | Energy Act |
| 03 | 30 | 04/01/1991 | Fiberglass Reinforced Plastic | Fiberglass Reinforced Plastic | Ball Float Valve |
| 2407 | No | | | None | Yes |
| Currently in Use | | | Electronic Line Leak Detector | Pressurized | Non-corrodible |
| Gasoline | | | Approved Remote Monitoring;Statistical Inventory Reconciliation | Approved Remote Monitoring;Statistical Inventory Reconciliation | No |
| 12,000 | | 10/31/2006 | Gilbarco-Veeder Root/TLS-350 | | No |
| 04 | 30 | 04/01/1991 | Fiberglass Reinforced Plastic | Fiberglass Reinforced Plastic | Ball Float Valve |
| 2408 | No | | | None | Yes |
| Currently in Use | | | Electronic Line Leak Detector | Pressurized | Non-corrodible |
| Gasoline | | | Approved Remote Monitoring;Statistical Inventory Reconciliation | Approved Remote Monitoring;Statistical Inventory Reconciliation | No |
| 12,000 | | 10/31/2006 | Gilbarco-Veeder Root/TLS-350 | | No |
| 05 | 30 | 04/01/1991 | Fiberglass Reinforced Plastic | Fiberglass Reinforced Plastic | Ball Float Valve |
| 2409 | No | | | None | Yes |
| Currently in Use | | | Electronic Line Leak Detector | Pressurized | Non-corrodible |
| Gasoline | | | Approved Remote Monitoring;Statistical Inventory Reconciliation | Approved Remote Monitoring;Statistical Inventory Reconciliation | No |
| 12,000 | | 10/31/2006 | Gilbarco-Veeder Root/TLS-350 | | No |
| 06 | 30 | 04/01/1991 | Fiberglass Reinforced Plastic | Fiberglass Reinforced Plastic | Ball Float Valve |
| 2410 | No | | | None | Yes |

| | | | | |
|------------------|------------|---|---|----------------|
| Currently in Use | | Electronic Line Leak Detector | Pressurized | Non-corrodible |
| Diesel | | Approved Remote Monitoring;Statistical Inventory Reconciliation | Approved Remote Monitoring;Statistical Inventory Reconciliation | No |
| 10,000 | 10/31/2006 | Gilbarco-Veeder Root/TLS-350 | | No |

Facility Summary in Deer Lodge County in the City of Warm Springs

Location: XANTHOPOULOS BLDG
2 C St
Warm Springs, MT 59756 Deer Lodge

Legacy ID:12-07585

Facility ID: 19926
Last Inspected On: 11/10/2020
Operating Permit Renewal Date: 11/26/2023

Owner Operator Contact: Montana Dept of Corrections

4064443930

Operator Contact: Pat Starcevich

Owner/Operator: Montana Dept of Corrections

Pat Starcevich, UST Class A Operator
Pat Starcevich, UST Class B Operator

| Tank Code | Age | Installed | Tank Material Construction | Piping Material | Overfill Types |
|------------------|-----|-----------------------|-------------------------------|------------------------------------|-----------------|
| Tag # | AST | Sump Tightness | Secondary Option | Secondary Option | Spill Protected |
| Status | | Piping Installed Date | Catastrophic L.D. Type 3.0 | Piping Type | CP Met Types |
| Product | | Tank/Pipe CP | Tank Detection | Primary Pipe Detection | Vapor Recovery |
| Capacity | | Line Tightness | ATG Type | Secondary Pipe Detection | Energy Act |
| 04 | 34 | 01/01/1987 | Fiberglass Reinforced Plastic | Flexible Plastic | Flapper Valve |
| 829 | No | 10/17/2017 | | Double Walled | Yes |
| Currently in Use | | | Not Required | U.S. Suction | Non-corrodible |
| Diesel | | | Automatic Tank Gauging 0.1 | Continuous Interstitial Monitoring | No |
| 2,000 | | | Veeder Root/TLS-300 | | No |