

Facility Summary in Fallon County in the City of Baker

Location: BAKER FARMERS UNION OIL
303 W Montana Ave
Baker, MT 59313 Fallon

System Facility ID:13-09960

Facility Code: 20017
Last Inspected On: 01/17/2024
Operating Permit Renewal Date: 05/16/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Farmers Union Oil Co Baker (406) 778-2519 cenexoffice@midrivers.com

Operator Contact: Tonya England (541) 643-4540 cenexoffice@midrivers.com

Owner/Operator: Farmers Union Oil Co Baker (406) 778-2519 cenexoffice@midrivers.com
 Kelly Brookes, UST Class B Operator
 Tonya England, UST Class A Operator cenexoffice@midrivers.com
 Tonya England, UST Class B Global Operator cenexoffice@midrivers.com
 Tonya England, UST Class B Operator cenexoffice@midrivers.com

Tank Code	12	Tank Age	9	Tank Installed Date	08/01/2017	Tank Material	Steel Clad	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	5693	Spill Test Date	09/08/2022	Piping Installed Date	08/01/2017	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	10/04/2022	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	10/24/2023	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	Yes
Capacity	20000	ATG Test Date	04/15/2024	Line Tightness Test Date		Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	09/08/2022			ATG Type	Gilbarco-Veeder Root/TLS-450;Veeder Root/TLS-450				
Tank Code	13	Tank Age	9	Tank Installed Date	08/01/2017	Tank Material	Steel Clad	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	5694	Spill Test Date	09/08/2022	Piping Installed Date	08/01/2017	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	10/04/2022	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	10/24/2023	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	14000	ATG Test Date	04/15/2024	Line Tightness Test Date		Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes

		Overfill Test Date	09/08/2022			ATG Type	Gilbarco-Veeder Root/TLS-450;Veeder Root/TLS-450				
Tank Code	14	Tank Age	9	Tank Installed Date	08/01/2017	Tank Material	Steel Clad	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	5695	Spill Test Date	09/08/2022	Piping Installed Date	08/01/2017	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	10/04/2022	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	10/24/2023	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	6000	ATG Test Date	10/24/2023	Line Tightness Test Date		Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	09/08/2022			ATG Type	Gilbarco-Veeder Root/TLS-450;Veeder Root/TLS-450				
Tank Code	15	Tank Age	9	Tank Installed Date	08/01/2017	Tank Material	Steel Clad	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	5696	Spill Test Date	09/08/2022	Piping Installed Date	08/01/2017	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	10/04/2022	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	10/24/2023	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	Yes
Capacity	8000	ATG Test Date	04/15/2024	Line Tightness Test Date		Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	09/08/2022			ATG Type	Gilbarco-Veeder Root/TLS-450;Veeder Root/TLS-450				
Tank Code	16	Tank Age	9	Tank Installed Date	08/01/2017	Tank Material	Steel Clad	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	5697	Spill Test Date	09/08/2022	Piping Installed Date	08/01/2017	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	10/04/2022	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	10/24/2023	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	6000	ATG Test Date	10/24/2023	Line Tightness Test Date		Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes

		Overfill Test Date	09/08/2022			ATG Type	Gilbarco-Veeder Root/TLS-450;Veeder Root/TLS-450				
Tank Code	17	Tank Age	9	Tank Installed Date	08/01/2017	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Positive Shutoff
Tag Number	5702	Spill Test Date	09/08/2022	Piping Installed Date	08/01/2017	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Other	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	DEF (Not Regulated)	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	Primary Pipe Detection	ELLD 0.2;ELLD Line Tightness Testing	Vapor Recovery	No
Capacity	2000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring;Not Listed	Energy Act	Yes
		Overfill Test Date	09/08/2022			ATG Type	Veeder Root/TLS-450				
Tank Code	06	Tank Age	31	Tank Installed Date	11/01/1995	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	973	Spill Test Date	10/24/2023	Piping Installed Date	05/30/2012	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	10/04/2022	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Diesel, Dyed	PLLD Test Date	10/24/2023	Tank/Piping CP Test Date	08/28/2024	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	15000	ATG Test Date	10/24/2023	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	04/15/2024			ATG Type	Veeder Root/TLS-450				
Tank Code	07	Tank Age	31	Tank Installed Date	11/01/1995	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	974	Spill Test Date	10/06/2022	Piping Installed Date	05/30/2012	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	10/04/2022	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date	10/24/2023	Tank/Piping CP Test Date	08/28/2024	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	5000	ATG Test Date	10/24/2023	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	04/15/2024			ATG Type	Veeder Root/TLS-450				

Tank Code	08	Tank Age	31	Tank Installed Date	11/01/1995	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	975	Spill Test Date	04/15/2024	Piping Installed Date	05/30/2012	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	10/04/2022	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date	10/24/2023	Tank/Piping CP Test Date	08/28/2024	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	10000	ATG Test Date	10/24/2023	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	04/15/2024			ATG Type	Veeder Root/TLS-450				
Tank Code	09	Tank Age	31	Tank Installed Date	11/01/1995	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	976	Spill Test Date	10/06/2022	Piping Installed Date	05/30/2012	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	10/04/2022	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date	10/24/2023	Tank/Piping CP Test Date	08/28/2024	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	15000	ATG Test Date	10/24/2023	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	04/15/2024			ATG Type	Veeder Root/TLS-450				
Tank Code	10	Tank Age	31	Tank Installed Date	11/01/1995	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	977	Spill Test Date	10/06/2022	Piping Installed Date	05/30/2012	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	10/04/2022	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date	10/24/2023	Tank/Piping CP Test Date	08/28/2024	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	5000	ATG Test Date	10/24/2023	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	04/15/2024			ATG Type	Veeder Root/TLS-450				
Tank Code	11	Tank Age	31	Tank Installed Date	11/01/1995	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	978	Spill Test Date	10/06/2022	Piping Installed Date	05/30/2012	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	10/04/2022	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic

Product	Diesel	PLLD Test Date	10/24/2023	Tank/Piping CP Test Date	08/28/2024	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	10000	ATG Test Date	04/15/2024	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	04/15/2024			ATG Type	Veeder Root/TLS-450				

Facility Summary in Fallon County in the City of Baker

Location: FALLON COUNTY MEDICAL COMPLEX
225 S 3rd St W
Baker, MT 59313 Fallon

System Facility ID:60-15072

Facility Code: 30843
Last Inspected On: 06/06/2023
Operating Permit Renewal Date: 07/13/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Fallon Medical Complex Inc

Operator Contact: Brad Kings;Tonna Hartman;Fallon Medical Complex Inc

(406) 778-5419;(406) 978-5220

bekings@fallonmedical.org;fmcmaintenance@fallonmedical.org

Owner/Operator: Fallon Medical Complex Inc

Brad Kings, UST Class A Operator
John Zook, UST Class B Global Operator
John Zook, UST Class B Operator
Tonna Hartman, UST Class A Operator
Tonna Hartman, UST Class B Global Operator

bekings@fallonmedical.org
jzook894@yahoo.com
jzook894@yahoo.com
fmcmaintenance@fallonmedical.org
fmcmaintenance@fallonmedical.org

Tank Code	01	Tank Age	20	Tank Installed Date	01/02/2006	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	5125	Spill Test Date	08/22/2023	Piping Installed Date	04/25/2007	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Auto Dialer	Piping Type	U.S. Suction	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	2500	ATG Test Date	06/06/2023	Line Tightness Test Date	06/24/2014	Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	08/22/2023			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Fallon County in the City of Baker

Location: FALLON COUNTY RD DEPT
122 E Center Ave
Baker, MT 59313 Fallon

System Facility ID:13-01687

Facility Code: 19967
Last Inspected On: 04/01/2024
Operating Permit Renewal Date: 08/03/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Fallon County Road Dept (406) 778-2019

Operator Contact: Alba Higgins;Bobby Wiedmer (406) 978-2015 falcord@midrivers.com

Owner/Operator: Fallon County Road Dept (406) 778-2019

Alba Higgins, UST Class A Operator	falcord@midrivers.com
Alba Higgins, UST Class B Operator	falcord@midrivers.com
Bobby Wiedmer, UST Class A Operator	falcord@midrivers.com
Bobby Wiedmer, UST Class B Operator	falcord@midrivers.com
Carl Overland, UST Class B Operator	blackycarlata1@gmail.com
Mitch Overn, UST Class B Operator	falcord@midrivers.com

Tank Code	05	Tank Age	33	Tank Installed Date	06/09/1993	Tank Material	Steel Clad	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	896	Spill Test Date	03/05/2024	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	09/13/2012	Primary Tank Leak Detection	Manual Interstitial Monitoring	Primary Pipe Detection		Vapor Recovery	No
Capacity	6000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	03/05/2024			ATG Type					
Tank Code	06	Tank Age	33	Tank Installed Date	06/01/1993	Tank Material	Steel Clad	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	897	Spill Test Date	03/05/2024	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	09/13/2012	Primary Tank Leak Detection	Manual Interstitial Monitoring	Primary Pipe Detection		Vapor Recovery	No
Capacity	6000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	03/05/2024			ATG Type					

Tank Code	07	Tank Age	33	Tank Installed Date	06/01/1993	Tank Material	Steel Clad	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	898	Spill Test Date	03/05/2024	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	09/13/2012	Primary Tank Leak Detection	Manual Interstitial Monitoring	Primary Pipe Detection		Vapor Recovery	No
Capacity	3000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	03/05/2024			ATG Type					

Facility Summary in Fallon County in the City of Baker

Location: GENERATIONAL PROPERTIES RENTAL
908 E Montana Ave
Baker, MT 59313-0000 Fallon

System Facility ID:13-08221

Facility Code: 20008
Last Inspected On: 07/01/2024
Operating Permit Renewal Date: 07/01/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: GENERATIONAL PROPERTIES LLC (406) 891-0979 generationalpropertiesmt@gmail.com

Operator Contact: Michael Miller; Promise Miller (406) 772-5828 flatlineincmg@gmail.com; promisemiller@hotmail.com

Owner/Operator: GENERATIONAL PROPERTIES LLC (406) 891-0979 generationalpropertiesmt@gmail.com

Michael Miller, UST Class A Operator flatlineincmg@gmail.com
 Michael Miller, UST Class B Operator flatlineincmg@gmail.com
 Promise Miller, UST Class A Operator promisemiller@hotmail.com
 Promise Miller, UST Class B Operator promisemiller@hotmail.com

Tank Code	04	Tank Age	27	Tank Installed Date	08/01/1999	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	4083	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Temporarily Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	10/15/2021	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection		Vapor Recovery	No
Capacity	8000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco/EMC Basic				
Tank Code	05	Tank Age	27	Tank Installed Date	08/01/1999	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	4084	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Temporarily Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	10/15/2021	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection		Vapor Recovery	No
Capacity	4000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco/EMC Basic				

Facility Summary in Fallon County in the City of Baker

Location: J and A MINI STORE
116 W Montana Ave
Baker, MT 59313 Fallon

System Facility ID:13-00685

Facility Code: 19958
Last Inspected On: 12/12/2023
Operating Permit Renewal Date: 12/16/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: ARMH Group LLC;Rose Heiser (406) 778-2411 jandaministore@gmail.com;rosemorast98@hotmail.com

Operator Contact: Rose Heiser (406) 778-2411 rosemorast98@hotmail.com

Owner/Operator: ARMH Group LLC (406) 778-2411 jandaministore@gmail.com

Owner/Operator: Rose Heiser (406) 778-2411 jandaministore@gmail.com

Rose Heiser, UST Class A Operator rosemorast98@hotmail.com

Rose Heiser, UST Class B Global Operator rosemorast98@hotmail.com

Tank Code	05	Tank Age	37	Tank Installed Date	05/24/1989	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	1447	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Temporarily Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	12/12/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection		Vapor Recovery	No
Capacity	4042	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	06	Tank Age	37	Tank Installed Date	05/24/1989	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	1448	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Temporarily Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	12/12/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection		Vapor Recovery	No
Capacity	9954	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Tank Code	07	Tank Age	37	Tank Installed Date	05/24/1989	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	1449	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Temporarily Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	12/12/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection		Vapor Recovery	No
Capacity	10003	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Fallon County in the City of Baker

Location: MUFFYS
19 E Montana Ave
Baker, MT 59313 Fallon

System Facility ID:13-00227

Facility Code: 19954
Last Inspected On: 11/01/2024
Operating Permit Renewal Date: 11/13/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Monica Stark (406) 978-2643 muffysirish@gmail.com

Operator Contact: Monica Stark (406) 978-2643 muffysirish@gmail.com

Owner/Operator: Monica Stark (406) 978-2643 muffysirish@gmail.com

Monica Stark, UST Class A Operator
Monica Stark, UST Class B Operator
Stacey Sterns, UST Class B Operator

muffysirish@gmail.com
muffysirish@gmail.com
muffysirish@gmail.com
sternsstacey03@gmail.com

Tank Code	05	Tank Age	37	Tank Installed Date	04/13/1989	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	3519	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Temporarily Out of Use	MLLD Test Date	12/03/2018	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	11/01/2024	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	4000	ATG Test Date		Line Tightness Test Date	12/03/2018	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco/EMC Basic				
Tank Code	06	Tank Age	28	Tank Installed Date	10/01/1998	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	3520	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Temporarily Out of Use	MLLD Test Date	12/03/2018	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	11/01/2024	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	6000	ATG Test Date		Line Tightness Test Date	12/03/2018	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco/EMC Basic				

Facility Summary in Fallon County in the City of Baker

Location: PRAIRIE FUELS
176 E Milwaukee Ave
Baker, MT 59313 Fallon

System Facility ID:13-07740

Facility Code: 20000
Last Inspected On: 07/01/2024
Operating Permit Renewal Date: 10/01/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Prairie Fuels (406) 778-3245

Operator Contact: Sharon Tronstad merwininc@midrivers.com

Owner/Operator: Prairie Fuels (406) 778-3245

Sharon Tronstad, UST Class A Operator
Sharon Tronstad, UST Class B Operator

merwininc@midrivers.com
merwininc@midrivers.com

Tank Code	S05	Tank Age	30	Tank Installed Date	09/01/1996	Tank Material	Bare Steel	Piping Material	Fiberglass	Overfill Types	
Tag Number	3197	Spill Test Date		Piping Installed Date	12/12/2014	Tank Construction		Piping Construction	Double Walled	AST	Yes
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Auto Dialer	Piping Type	Pressurized	CP Met Types	
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection		Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	17000	ATG Test Date	07/01/2024	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					
Tank Code	S06	Tank Age	30	Tank Installed Date	09/01/1996	Tank Material	Bare Steel	Piping Material	Fiberglass	Overfill Types	
Tag Number	3198	Spill Test Date		Piping Installed Date	07/20/2015	Tank Construction		Piping Construction	Double Walled	AST	Yes
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Auto Dialer	Piping Type	Pressurized	CP Met Types	
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection		Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	8500	ATG Test Date	07/01/2024	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					
Tank Code	S07	Tank Age	30	Tank Installed Date	09/01/1996	Tank Material	Bare Steel	Piping Material	Fiberglass	Overfill Types	

Tag Number	3199	Spill Test Date		Piping Installed Date	12/12/2014	Tank Construction		Piping Construction	Double Walled	AST	Yes
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Auto Dialer	Piping Type	Pressurized	CP Met Types	
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection		Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	12000	ATG Test Date	07/01/2024	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					
Tank Code	S08	Tank Age	30	Tank Installed Date	09/01/1996	Tank Material	Bare Steel	Piping Material	Fiberglass	Overfill Types	
Tag Number	3200	Spill Test Date		Piping Installed Date	12/12/2014	Tank Construction		Piping Construction	Double Walled	AST	Yes
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Auto Dialer	Piping Type	Pressurized	CP Met Types	
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection		Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	12000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					