

## Facility Summary in Fallon County in the City of Baker

**Location:** BAKER FARMERS UNION OIL  
303 W Montana Ave  
Baker, MT 59313 Fallon

System Facility ID:13-09960

Facility Code: 20017  
Last Inspected On: 01/17/2024  
Operating Permit Renewal Date: 05/16/2027

**Note: Inspection is due 90 days before the Operating Permit Renewal Date**

**Owner Operator Contact:** Farmers Union Oil Co Baker

**(406) 778-2519**

**cenexoffice@midrivers.com**

**Operator Contact:** Tonya England

**(541) 643-4540**

**cenexoffice@midrivers.com**

**Owner/Operator:** Farmers Union Oil Co Baker

(406) 778-2519

cenexoffice@middrivers.com

Kelly Brookes, UST Class B Operator

Tonya England, UST Class A Operator

Tonya England, UST Class B Global Operator

Tonya England, UST Class B Operator

Tank Code	12	Tank Age	9	Tank Installed Date	08/01/2017	Tank Material	Steel Clad	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	5693	Spill Test Date	09/08/2022	Piping Installed Date	08/01/2017	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	10/04/2022	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	10/24/2023	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	Yes
Capacity	20000	ATG Test Date	04/15/2024	Line Tightness Test Date		Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	09/08/2022			ATG Type	Gilbarco-Veeder Root/TLS-450;Veeder Root/TLS-450				

		<b>Overfill Test Date</b>	09/08/2022			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-450;Veeder Root/TLS-450			
<b>Tank Code</b>	14	<b>Tank Age</b>	9	<b>Tank Installed Date</b>	08/01/2017	<b>Tank Material</b>	Steel Clad	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>
<b>Tag Number</b>	5695	<b>Spill Test Date</b>	09/08/2022	<b>Piping Installed Date</b>	08/01/2017	<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	Double Walled	<b>AST</b>
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	10/04/2022	<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>
<b>Product</b>	Diesel	<b>PLLD Test Date</b>	10/24/2023	<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Continuous Interstitial Monitoring	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>
<b>Capacity</b>	6000	<b>ATG Test Date</b>	10/24/2023	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Secondary Pipe Detection</b>	ELLD 0.2	<b>Energy Act</b>
		<b>Overfill Test Date</b>	09/08/2022			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-450;Veeder Root/TLS-450			
<b>Tank Code</b>	15	<b>Tank Age</b>	9	<b>Tank Installed Date</b>	08/01/2017	<b>Tank Material</b>	Steel Clad	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>
<b>Tag Number</b>	5696	<b>Spill Test Date</b>	09/08/2022	<b>Piping Installed Date</b>	08/01/2017	<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	Double Walled	<b>AST</b>
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	10/04/2022	<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>	10/24/2023	<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Continuous Interstitial Monitoring	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>
<b>Capacity</b>	8000	<b>ATG Test Date</b>	04/15/2024	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Secondary Pipe Detection</b>	ELLD 0.2	<b>Energy Act</b>
		<b>Overfill Test Date</b>	09/08/2022			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-450;Veeder Root/TLS-450			
<b>Tank Code</b>	16	<b>Tank Age</b>	9	<b>Tank Installed Date</b>	08/01/2017	<b>Tank Material</b>	Steel Clad	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>
<b>Tag Number</b>	5697	<b>Spill Test Date</b>	09/08/2022	<b>Piping Installed Date</b>	08/01/2017	<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	Double Walled	<b>AST</b>
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	10/04/2022	<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>
<b>Product</b>	Diesel	<b>PLLD Test Date</b>	10/24/2023	<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Continuous Interstitial Monitoring	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>
<b>Capacity</b>	6000	<b>ATG Test Date</b>	10/24/2023	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Secondary Pipe Detection</b>	ELLD 0.2	<b>Energy Act</b>

		<b>Overfill Test Date</b>	09/08/2022			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-450;Veeder Root/TLS-450			
<b>Tank Code</b>	17	<b>Tank Age</b>	9	<b>Tank Installed Date</b>	08/01/2017	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>
<b>Tag Number</b>	5702	<b>Spill Test Date</b>	09/08/2022	<b>Piping Installed Date</b>	08/01/2017	<b>Tank Construction</b>		<b>Piping Construction</b>	Double Walled	<b>AST</b>
<b>Tank Status</b>	Other	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>
<b>Product</b>	DEF (Not Regulated)	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	<b>Primary Pipe Detection</b>	ELLD 0.2;ELLD Line Tightness Testing	<b>Vapor Recovery</b>
<b>Capacity</b>	2000	<b>ATG Test Date</b>		<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>	Continuous Interstitial Monitoring;Not Listed	<b>Energy Act</b>
		<b>Overfill Test Date</b>	09/08/2022			<b>ATG Type</b>	Veeder Root/TLS-450			
<b>Tank Code</b>	06	<b>Tank Age</b>	31	<b>Tank Installed Date</b>	11/01/1995	<b>Tank Material</b>	Cathodically Protected Steel	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>
<b>Tag Number</b>	973	<b>Spill Test Date</b>	10/24/2023	<b>Piping Installed Date</b>	05/30/2012	<b>Tank Construction</b>		<b>Piping Construction</b>	Double Walled	<b>AST</b>
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	10/04/2022	<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>
<b>Product</b>	Diesel, Dyed	<b>PLLD Test Date</b>	10/24/2023	<b>Tank/Piping CP Test Date</b>	08/28/2024	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>
<b>Capacity</b>	15000	<b>ATG Test Date</b>	10/24/2023	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>	ELLD 0.2	<b>Energy Act</b>
		<b>Overfill Test Date</b>	04/15/2024			<b>ATG Type</b>	Veeder Root/TLS-450			
<b>Tank Code</b>	07	<b>Tank Age</b>	31	<b>Tank Installed Date</b>	11/01/1995	<b>Tank Material</b>	Cathodically Protected Steel	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>
<b>Tag Number</b>	974	<b>Spill Test Date</b>	10/06/2022	<b>Piping Installed Date</b>	05/30/2012	<b>Tank Construction</b>		<b>Piping Construction</b>	Double Walled	<b>AST</b>
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	10/04/2022	<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>	10/24/2023	<b>Tank/Piping CP Test Date</b>	08/28/2024	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>
<b>Capacity</b>	5000	<b>ATG Test Date</b>	10/24/2023	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>	ELLD 0.2	<b>Energy Act</b>
		<b>Overfill Test Date</b>	04/15/2024			<b>ATG Type</b>	Veeder Root/TLS-450			

Tank Code	08	Tank Age	31	Tank Installed Date	11/01/1995	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	975	Spill Test Date	04/15/2024	Piping Installed Date	05/30/2012	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	10/04/2022	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date	10/24/2023	Tank/Piping CP Test Date	08/28/2024	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	10000	ATG Test Date	10/24/2023	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	04/15/2024			ATG Type	Veeder Root/TLS-450				
Tank Code	09	Tank Age	31	Tank Installed Date	11/01/1995	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	976	Spill Test Date	10/06/2022	Piping Installed Date	05/30/2012	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	10/04/2022	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date	10/24/2023	Tank/Piping CP Test Date	08/28/2024	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	15000	ATG Test Date	10/24/2023	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	04/15/2024			ATG Type	Veeder Root/TLS-450				
Tank Code	10	Tank Age	31	Tank Installed Date	11/01/1995	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	977	Spill Test Date	10/06/2022	Piping Installed Date	05/30/2012	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	10/04/2022	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date	10/24/2023	Tank/Piping CP Test Date	08/28/2024	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	5000	ATG Test Date	10/24/2023	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	04/15/2024			ATG Type	Veeder Root/TLS-450				
Tank Code	11	Tank Age	31	Tank Installed Date	11/01/1995	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	978	Spill Test Date	10/06/2022	Piping Installed Date	05/30/2012	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	10/04/2022	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic

<b>Product</b>	Diesel	<b>PLL D Test Date</b>	10/24/2023	<b>Tank/Piping CP Test Date</b>	08/28/2024	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	No
<b>Capacity</b>	10000	<b>ATG Test Date</b>	04/15/2024	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>	ELLD 0.2	<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	04/15/2024			<b>ATG Type</b>	Veeder Root/TLS-450				

## Facility Summary in Fallon County in the City of Baker

**Location:** FALON COUNTY MEDICAL COMPLEX  
225 S 3rd St W  
Baker, MT 59313 Fallon

System Facility ID:60-15072

Facility Code: 30843  
Last Inspected On: 06/06/2023  
Operating Permit Renewal Date: 07/13/2026

**Note:** Inspection is due 90 days before the Operating Permit Renewal Date.

**Owner Operator Contact:** Fallon Medical Complex Inc

**Operator Contact:** Brad Kings;Tonna Hartman;Fallon Medical Complex Inc

(406) 778-5419;(406) 978-5220

bekings@fallonmedical.org;fmcmaintenance@fallonmedical.org

**Owner/Operator:** Fallon Medical Complex Inc

Brad Kings, UST Class A Operator

bekings@fallonmedical.org

John Zook, UST Class B Global Operator

jzook894@yahoo.com

John Zook, UST Class B Operator

jzook894@yahoo.com

Tonna Hartman, UST Class A Operator

fmcmaintenance@fallonmedical.org

Tonna Hartman, UST Class B Global Operator

fmcmaintenance@fallonmedical.org

<b>Tank Code</b>	01	<b>Tank Age</b>	20	<b>Tank Installed Date</b>	01/02/2006	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	5125	<b>Spill Test Date</b>	08/22/2023	<b>Piping Installed Date</b>	04/25/2007	<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Auto Dialer	<b>Piping Type</b>	U.S. Suction	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Diesel	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Continuous Interstitial Monitoring	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	No
<b>Capacity</b>	2500	<b>ATG Test Date</b>	06/06/2023	<b>Line Tightness Test Date</b>	06/24/2014	<b>Secondary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	08/22/2023			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

## Facility Summary in Fallon County in the City of Baker

**Location:** FALLON COUNTY RD DEPT  
122 E Center Ave  
Baker, MT 59313 Fallon

System Facility ID:13-01687

Facility Code: 19967  
Last Inspected On: 04/01/2024  
Operating Permit Renewal Date: 08/03/2027

**Note:** Inspection is due 90 days before the Operating Permit Renewal Date.

**Owner Operator Contact:** Fallon County Road Dept

(406) 778-2019

**Operator Contact:** Alba Higgins;Bobby Wiedmer

(406) 978-2015

falcord@midrivers.com

**Owner/Operator:** Fallon County Road Dept

(406) 778-2019

Alba Higgins, UST Class A Operator

falcord@midrivers.com

Alba Higgins, UST Class B Operator

falcord@midrivers.com

Bobby Wiedmer, UST Class A Operator

falcord@midrivers.com

Bobby Wiedmer, UST Class B Operator

falcord@midrivers.com

Carl Overland, UST Class B Operator

blackycarlata1@gmail.com

Mitch Overn, UST Class B Operator

falcord@midrivers.com

Tank Code	05	Tank Age	33	Tank Installed Date	06/09/1993	Tank Material	Steel Clad	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	896	Spill Test Date	03/05/2024	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	09/13/2012	Primary Tank Leak Detection	Manual Interstitial Monitoring	Primary Pipe Detection		Vapor Recovery	No
Capacity	6000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	03/05/2024			ATG Type					
Tank Code	06	Tank Age	33	Tank Installed Date	06/01/1993	Tank Material	Steel Clad	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	897	Spill Test Date	03/05/2024	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	09/13/2012	Primary Tank Leak Detection	Manual Interstitial Monitoring	Primary Pipe Detection		Vapor Recovery	No
Capacity	6000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	03/05/2024			ATG Type					

Tank Code	07	Tank Age	33	Tank Installed Date	06/01/1993	Tank Material	Steel Clad	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	898	Spill Test Date	03/05/2024	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	09/13/2012	Primary Tank Leak Detection	Manual Interstitial Monitoring	Primary Pipe Detection		Vapor Recovery	No
Capacity	3000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	03/05/2024			ATG Type					

## Facility Summary in Fallon County in the City of Baker

**Location:** GENERATIONAL PROPERTIES RENTAL  
908 E Montana Ave  
Baker, MT 59313-0000 Fallon

System Facility ID:13-08221

Facility Code: 20008  
Last Inspected On: 07/01/2024  
Operating Permit Renewal Date: 07/01/2027

**Note:** Inspection is due 90 days before the Operating Permit Renewal Date.

**Owner Operator Contact:** GENERATIONAL PROPERTIES LLC

(406) 891-0979

generationalpropertiesmt@gmail.com

**Operator Contact:** Michael Miller;Promise Miller

(406) 772-5828

flatlineincmg@gmail.com;promisemiller@hotmail.com

**Owner/Operator:** GENERATIONAL PROPERTIES LLC

(406) 891-0979

generationalpropertiesmt@gmail.com

Michael Miller, UST Class A Operator

flatlineincmg@gmail.com

Michael Miller, UST Class B Operator

flatlineincmg@gmail.com

Promise Miller, UST Class A Operator

promisemiller@hotmail.com

Promise Miller, UST Class B Operator

promisemiller@hotmail.com

<b>Tank Code</b>	04	<b>Tank Age</b>	27	<b>Tank Installed Date</b>	08/01/1999	<b>Tank Material</b>	Cathodically Protected Steel	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	High Level Alarm
<b>Tag Number</b>	4083	<b>Spill Test Date</b>		<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	None	<b>AST</b>	No
<b>Tank Status</b>	Temporarily Out of Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Not Required	<b>Piping Type</b>	Safe Suction	<b>CP Met Types</b>	Galvanic
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>	10/15/2021	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>		<b>Vapor Recovery</b>	No
<b>Capacity</b>	8000	<b>ATG Test Date</b>		<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>				<b>ATG Type</b>	Gilbarco/EMC Basic				
<b>Tank Code</b>	05	<b>Tank Age</b>	27	<b>Tank Installed Date</b>	08/01/1999	<b>Tank Material</b>	Cathodically Protected Steel	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	High Level Alarm
<b>Tag Number</b>	4084	<b>Spill Test Date</b>		<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	None	<b>AST</b>	No
<b>Tank Status</b>	Temporarily Out of Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Not Required	<b>Piping Type</b>	Safe Suction	<b>CP Met Types</b>	Galvanic
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>	10/15/2021	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>		<b>Vapor Recovery</b>	No
<b>Capacity</b>	4000	<b>ATG Test Date</b>		<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>				<b>ATG Type</b>	Gilbarco/EMC Basic				

## Facility Summary in Fallon County in the City of Baker

**Location:** J and A MINI STORE  
116 W Montana Ave  
Baker, MT 59313 Fallon

System Facility ID:13-00685

Facility Code: 19958  
Last Inspected On: 12/12/2023  
Operating Permit Renewal Date: 12/16/2026

**Note:** Inspection is due 90 days before the Operating Permit Renewal Date.

**Owner Operator Contact:** ARMH Group LLC;Rose Heiser (406) 778-2411 jandaministore@gmail.com;rosemorast98@hotmail.com

**Operator Contact:** Rose Heiser (406) 778-2411 rosemorast98@hotmail.com

**Owner/Operator:** ARMH Group LLC (406) 778-2411 jandaministore@gmail.com

**Owner/Operator:** Rose Heiser (406) 778-2411 jandaministore@gmail.com

Rose Heiser, UST Class A Operator  
Rose Heiser, UST Class B Global Operator

Tank Code	05	Tank Age	37	Tank Installed Date	05/24/1989	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	1447	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Temporarily Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	12/12/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection		Vapor Recovery	No
Capacity	4042	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Tank Code	06	Tank Age	37	Tank Installed Date	05/24/1989	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	1448	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Temporarily Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	12/12/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection		Vapor Recovery	No
Capacity	9954	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Tank Code	07	Tank Age	37	Tank Installed Date	05/24/1989	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	1449	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Temporarily Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	12/12/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection		Vapor Recovery	No
Capacity	10003	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

## Facility Summary in Fallon County in the City of Baker

**Location:** MUFFYS  
19 E Montana Ave  
Baker, MT 59313 Fallon

System Facility ID:13-00227

Facility Code: 19954  
Last Inspected On: 11/01/2024  
Operating Permit Renewal Date: 11/13/2027

**Note:** Inspection is due 90 days before the Operating Permit Renewal Date.

**Owner Operator Contact:** Monica Stark (406) 978-2643 muffysirish@gmail.com

**Operator Contact:** Monica Stark (406) 978-2643 muffysirish@gmail.com

**Owner/Operator:** Monica Stark (406) 978-2643 muffysirish@gmail.com

Monica Stark, UST Class A Operator

muffysirish@gmail.com

Monica Stark, UST Class B Operator

muffysirish@gmail.com

Stacey Sterns, UST Class B Operator

sternsstacey03@gmail.com

<b>Tank Code</b>	05	<b>Tank Age</b>	37	<b>Tank Installed Date</b>	04/13/1989	<b>Tank Material</b>	Cathodically Protected Steel	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	Flapper Valve;High Level Alarm
<b>Tag Number</b>	3519	<b>Spill Test Date</b>		<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	None	<b>AST</b>	No
<b>Tank Status</b>	Temporarily Out of Use	<b>MLLD Test Date</b>	12/03/2018	<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Mechanical Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Galvanic
<b>Product</b>	Diesel	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>	11/01/2024	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	MLLD Line Tightness Testing	<b>Vapor Recovery</b>	No
<b>Capacity</b>	4000	<b>ATG Test Date</b>		<b>Line Tightness Test Date</b>	12/03/2018	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>				<b>ATG Type</b>	Gilbarco/EMC Basic				
<b>Tank Code</b>	06	<b>Tank Age</b>	28	<b>Tank Installed Date</b>	10/01/1998	<b>Tank Material</b>	Cathodically Protected Steel	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	High Level Alarm
<b>Tag Number</b>	3520	<b>Spill Test Date</b>		<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	None	<b>AST</b>	No
<b>Tank Status</b>	Temporarily Out of Use	<b>MLLD Test Date</b>	12/03/2018	<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Mechanical Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Galvanic
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>	11/01/2024	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	MLLD Line Tightness Testing	<b>Vapor Recovery</b>	No
<b>Capacity</b>	6000	<b>ATG Test Date</b>		<b>Line Tightness Test Date</b>	12/03/2018	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>				<b>ATG Type</b>	Gilbarco/EMC Basic				

## Facility Summary in Fallon County in the City of Baker

**Location:** PRAIRIE FUELS  
176 E Milwaukee Ave  
Baker, MT 59313 Fallon

System Facility ID:13-07740

Facility Code: 20000  
Last Inspected On: 07/01/2024  
Operating Permit Renewal Date: 10/01/2027

**Note:** Inspection is due 90 days before the Operating Permit Renewal Date.

**Owner Operator Contact:** Prairie Fuels

(406) 778-3245

**Operator Contact:** Sharon Tronstad

merwininc@midrivers.com

**Owner/Operator:** Prairie Fuels

(406) 778-3245

Sharon Tronstad, UST Class A Operator

merwininc@midrivers.com

Sharon Tronstad, UST Class B Operator

merwininc@midrivers.com

<b>Tank Code</b>	S05	<b>Tank Age</b>	30	<b>Tank Installed Date</b>	09/01/1996	<b>Tank Material</b>	Bare Steel	<b>Piping Material</b>	Fiberglass	<b>Overfill Types</b>	
<b>Tag Number</b>	3197	<b>Spill Test Date</b>		<b>Piping Installed Date</b>	12/12/2014	<b>Tank Construction</b>		<b>Piping Construction</b>	Double Walled	<b>AST</b>	Yes
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Auto Dialer	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>		<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	No
<b>Capacity</b>	17000	<b>ATG Test Date</b>	07/01/2024	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>				<b>ATG Type</b>					
<b>Tank Code</b>	S06	<b>Tank Age</b>	30	<b>Tank Installed Date</b>	09/01/1996	<b>Tank Material</b>	Bare Steel	<b>Piping Material</b>	Fiberglass	<b>Overfill Types</b>	
<b>Tag Number</b>	3198	<b>Spill Test Date</b>		<b>Piping Installed Date</b>	07/20/2015	<b>Tank Construction</b>		<b>Piping Construction</b>	Double Walled	<b>AST</b>	Yes
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Auto Dialer	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>		<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	No
<b>Capacity</b>	8500	<b>ATG Test Date</b>	07/01/2024	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>				<b>ATG Type</b>					
<b>Tank Code</b>	S07	<b>Tank Age</b>	30	<b>Tank Installed Date</b>	09/01/1996	<b>Tank Material</b>	Bare Steel	<b>Piping Material</b>	Fiberglass	<b>Overfill Types</b>	

Tag Number	3199	Spill Test Date		Piping Installed Date	12/12/2014	Tank Construction	Piping Construction	Double Walled	AST	Yes
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Auto Dialer	Piping Type	Pressurized	CP Met Types
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection		Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery
Capacity	12000	ATG Test Date	07/01/2024	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act
		Overfill Test Date				ATG Type				No
Tank Code	S08	Tank Age	30	Tank Installed Date	09/01/1996	Tank Material	Bare Steel	Piping Material	Fiberglass	Overfill Types
Tag Number	3200	Spill Test Date		Piping Installed Date	12/12/2014	Tank Construction	Piping Construction	Double Walled	AST	Yes
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Auto Dialer	Piping Type	Pressurized	CP Met Types
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection		Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery
Capacity	12000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act
		Overfill Test Date				ATG Type				No