

Facility Summary in Fallon County in the City of Baker

Location: BAKERS FARMER UNION OIL
303 W Montana Ave
Baker, MT 59313 Fallon

Legacy ID:13-09960

Facility ID: 20017
Last Inspected On: 05/07/2021
Operating Permit Renewal Date: 05/16/2024

Owner Operator Contact: Farmers Union Oil Co Baker;Travis Mashak;Farmers Union Oil Co Baker **4067782519;4069782522;4067782519**

Operator Contact: Tonya England

5416434540

Owner/Operator: Farmers Union Oil Co Baker

Kelly Brookes, UST Class B Operator

Tonya England, UST Class A Operator

Tonya England, UST Class B Global Operator

Tonya England, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
12	4	08/01/2017	Steel Clad	Flexible Plastic	Flapper Valve
5693	No	08/21/2017	Double-Walled	Double Walled	Yes
Currently in Use		08/01/2017	Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	Continuous Interstitial Monitoring;ELLD 0.2	Yes
20,000			Gilbarco-Veeder Root/TLS-450;Veeder Root/TLS-450		Yes
13	4	08/01/2017	Steel Clad	Flexible Plastic	Flapper Valve
5694	No	08/21/2017	Double-Walled	Double Walled	Yes
Currently in Use		08/01/2017	Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel			Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	Continuous Interstitial Monitoring;ELLD 0.2	No
14,000			Gilbarco-Veeder Root/TLS-450;Veeder Root/TLS-450		Yes

14	4	08/01/2017	Steel Clad	Flexible Plastic	Flapper Valve
5695	No	08/21/2017	Double-Walled	Double Walled	Yes
Currently in Use		08/01/2017	Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel			Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	Continuous Interstitial Monitoring;ELLD 0.2	No
6,000			Gilbarco-Veeder Root/TLS- 450;Veeder Root/TLS-450		Yes
15	4	08/01/2017	Steel Clad	Flexible Plastic	Flapper Valve
5696	No	08/21/2017	Double-Walled	Double Walled	Yes
Currently in Use		08/01/2017	Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	Continuous Interstitial Monitoring;ELLD 0.2	Yes
8,000			Gilbarco-Veeder Root/TLS- 450;Veeder Root/TLS-450		Yes
16	4	08/01/2017	Steel Clad	Flexible Plastic	Flapper Valve
5697	No	08/21/2017	Double-Walled	Double Walled	Yes
Currently in Use		08/01/2017	Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel			Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	Continuous Interstitial Monitoring;ELLD 0.2	No
6,000			Gilbarco-Veeder Root/TLS- 450;Veeder Root/TLS-450		Yes
06	26	11/01/1995	Cathodically Protected Steel	Flexible Plastic	Ball Float Valve
973	No			Double Walled	Yes
Currently in Use		05/30/2012	Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		11/14/2017	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring;ELLD 0.2	No
15,000			Veeder Root/TLS-450		No
07	26	11/01/1995	Cathodically Protected Steel	Flexible Plastic	Ball Float Valve
974	No			Double Walled	Yes

Currently in Use		05/30/2012	Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		11/14/2017	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring; ELLD 0.2	No
5,000			Veeder Root/TLS-450		No
08	26	11/01/1995	Cathodically Protected Steel	Flexible Plastic	Ball Float Valve
975	No			Double Walled	Yes
Currently in Use		05/30/2012	Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		11/14/2017	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring; ELLD 0.2	No
10,000			Veeder Root/TLS-450		No
09	26	11/01/1995	Cathodically Protected Steel	Flexible Plastic	Ball Float Valve
976	No			Double Walled	Yes
Currently in Use		05/30/2012	Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		11/14/2017	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring; ELLD 0.2	No
15,000			Veeder Root/TLS-450		No
10	26	11/01/1995	Cathodically Protected Steel	Flexible Plastic	Ball Float Valve
977	No			Double Walled	Yes
Currently in Use		05/30/2012	Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		11/14/2017	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring; ELLD 0.2	No
5,000			Veeder Root/TLS-450		No
11	26	11/01/1995	Cathodically Protected Steel	Flexible Plastic	Ball Float Valve
978	No			Double Walled	Yes
Currently in Use		05/30/2012	Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		11/14/2017	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring; ELLD 0.2	No
10,000			Veeder Root/TLS-450		No

Facility Summary in Fallon County in the City of Baker

Location: FALLON COUNTY AIRPORT
Fallon County Airport
Baker, MT 59313 Fallon

Legacy ID:13-10696

Facility ID: 20018
Last Inspected On: 05/27/2021
Operating Permit Renewal Date: 06/21/2024

Owner Operator Contact: Fallon County

4067783508

Operator Contact: Roger Meggers

4067783508

Owner/Operator: Fallon County

Roger Meggers, UST Class A Operator

Roger Meggers, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
01	33	01/01/1988	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
894	No			None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Jet Fuel (Jet-A, Jet-A1, JP5)		09/13/2012	Automatic Tank Gauging 0.2	ELLD 0.1	No
10,000		06/13/2018	OPW/EECO 1500		No
02	33	01/01/1988	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
895	No			None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Aviation Gas		09/13/2012	Automatic Tank Gauging 0.2	ELLD 0.1	No
10,000		06/13/2018	OPW/EECO 1500		No

Facility Summary in Fallon County in the City of Baker

Location: FALLON COUNTY MEDICAL COMPLEX
225 S 3rd St W
Baker, MT 59313 Fallon

Legacy ID:60-15072

Facility ID: 30843
Last Inspected On: 07/13/2020
Operating Permit Renewal Date: 07/13/2023

Owner Operator Contact: Fallon Medical Complex Inc

4067783331

Operator Contact: Brad Kings

4069785220

Owner/Operator: Fallon Medical Complex Inc

Brad Kings, UST Class A Operator
John Zook, UST Class B Global Operator
John Zook, UST Class B Operator
Tonna Hartman, UST Class B Global Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
01	15	01/02/2006	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve
5125	No	03/15/2018	Double-Walled	Double Walled	Yes
Currently in Use		04/25/2007	Auto Dialer	U.S. Suction	Non-corrodible
Diesel			Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	Continuous Interstitial Monitoring	No
2,500		06/24/2014	Gilbarco-Veeder Root/TLS- 350/Gilbarco EMC		No

Facility Summary in Fallon County in the City of Baker

Location: FALLON COUNTY RD DEPT
122 E Center Ave
Baker, MT 59313 Fallon

Legacy ID:13-01687

Facility ID: 19967
Last Inspected On: 05/11/2021
Operating Permit Renewal Date: 08/03/2024

Owner Operator Contact: Fallon County Road Dept;N/A ZZZ - TBL_OWN : **4067782019**
331;Fallon County Road Dept

Operator Contact: Alba Higgins;Bobby Wiedmer **4069782015**

Owner/Operator: Fallon County Road Dept

Alba Higgins, UST Class A Operator
Alba Higgins, UST Class B Operator
Bobby Wiedmer, UST Class A Operator
Bobby Wiedmer, UST Class B Operator
Carl Overland, UST Class B Operator
Mitch Overn, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
-----------	-----	-----------	----------------------------	-----------------	----------------

Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
05	28	06/09/1993	Steel Clad	Fiberglass Reinforced Plastic	Flapper Valve
896	No		Double-Walled	Double Walled	Yes
Currently in Use			Not Required	Safe Suction	Non-corrodible
Diesel		09/13/2012	Manual Interstitial Monitoring	Deferred	No
6,000					No
06	28	06/01/1993	Steel Clad	Fiberglass Reinforced Plastic	Flapper Valve
897	No		Double-Walled	Double Walled	Yes
Currently in Use			Not Required	Safe Suction	Non-corrodible
Diesel		09/13/2012	Manual Interstitial Monitoring	Deferred	No
6,000					No
07	28	06/01/1993	Steel Clad	Fiberglass Reinforced Plastic	Flapper Valve
898	No		Double-Walled	Double Walled	Yes
Currently in Use			Not Required	Safe Suction	Non-corrodible
Gasoline		09/13/2012	Manual Interstitial Monitoring	Deferred	No
3,000					No

Facility Summary in Fallon County in the City of Baker

Location: J and A MINI STORE
116 W Montana Ave
Baker, MT 59313 Fallon

Legacy ID:13-00685

Facility ID: 19958
Last Inspected On: 03/22/2021
Operating Permit Renewal Date: 03/25/2021

Owner Operator Contact:

Operator Contact: Rose Heiser

4068910229

Owner/Operator: ARMH Group LLC

Owner/Operator: Rose Heiser

Rose Heiser, UST Class A Operator

Rose Heiser, UST Class B Global Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
05	32	05/24/1989	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve
1447	No			None	Yes
Temporarily Out of Use			Not Required	Safe Suction	Galvanic
Diesel		09/29/2016	Automatic Tank Gauging 0.2	Deferred	No
4,042			Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
06	32	05/24/1989	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve
1448	No			None	Yes
Temporarily Out of Use			Not Required	Safe Suction	Galvanic
Gasoline		09/29/2016	Automatic Tank Gauging 0.2	Deferred	No
9,954			Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
07	32	05/24/1989	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve
1449	No			None	Yes
Temporarily Out of Use			Not Required	Safe Suction	Galvanic
Gasoline		09/29/2016	Automatic Tank Gauging 0.2	Deferred	No
10,003			Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No

Facility Summary in Fallon County in the City of Baker

Location: MUFFYS
 19 E Montana Ave
 Baker, MT 59313 Fallon

Legacy ID:13-00227

Facility ID: 19954
Last Inspected On: 12/03/2018
Operating Permit Renewal Date: 05/11/2022

Owner Operator Contact: Monica Stark;N/A ZZZ - TBL_OWN : 585;Lakeview Conoco **4067783144;4067783663**

Operator Contact: Monica Stark **4067783144**

Owner/Operator: Laurie Heiser

Owner/Operator: Monica Stark

Monica Stark, UST Class A Operator
 Monica Stark, UST Class B Operator
 Stacey Sterns, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
05	32	04/13/1989	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm;Positive Shutoff
3519	No			None	Yes
Temporarily Out of Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Diesel		12/03/2018	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	No
4,000		12/03/2018	Gilbarco/EMC Basic		No
06	23	10/01/1998	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
3520	No			None	Yes
Temporarily Out of Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		12/03/2018	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	No
6,000		12/03/2018	Gilbarco/EMC Basic		No

Facility Summary in Fallon County in the City of Baker

Location: PRAIRIE FUELS
 176 E Milwaukee Ave
 Baker, MT 59313 Fallon

Legacy ID:13-07740

Facility ID: 20000
Last Inspected On: 06/22/2021
Operating Permit Renewal Date: 10/01/2024

Owner Operator Contact: Prairie Fuels

4067783245

Operator Contact: Sharon Tronstad

Owner/Operator: Prairie Fuels

Sharon Tronstad, UST Class A Operator

Sharon Tronstad, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
S05	25	09/01/1996	Bare Steel	Fiberglass	
3197	Yes	12/12/2017		Double Walled	Yes
Currently in Use		12/12/2014	Continuous Interstitial Monitoring	Pressurized	
Gasoline			Deferred	Continuous Interstitial Monitoring	No
17,000					Yes
S06	25	09/01/1996	Bare Steel	Fiberglass	
3198	Yes	12/12/2017		Double Walled	Yes
Currently in Use		07/20/2015	Continuous Interstitial Monitoring	Pressurized	
Gasoline			Deferred	Continuous Interstitial Monitoring	No
8,500					Yes
S07	25	09/01/1996	Bare Steel	Fiberglass	
3199	Yes	12/12/2017		Double Walled	Yes
Currently in Use		12/12/2014	Continuous Interstitial Monitoring	Pressurized	
Diesel			Deferred	Continuous Interstitial Monitoring	No
12,000					Yes

S08	25	09/01/1996	Bare Steel	Fiberglass	
3200	Yes	12/12/2017		Double Walled	Yes
Currently in Use		12/12/2014	Continuous Interstitial Monitoring	Pressurized	
Diesel			Deferred	Continuous Interstitial Monitoring	No
12,000					No
S09	25	09/01/1996	Bare Steel	Fiberglass	
3201	Yes	12/12/2017		Double Walled	Yes
Currently in Use		12/12/2014	Continuous Interstitial Monitoring	Pressurized	
Diesel			Deferred	Continuous Interstitial Monitoring	No
2,000					Yes
S10	25	09/01/1996	Bare Steel	Fiberglass	
3202	Yes	12/12/2017		Double Walled	Yes
Currently in Use		12/12/2014	Continuous Interstitial Monitoring	Pressurized	
Diesel			Deferred	Continuous Interstitial Monitoring	No
2,000					Yes

Facility Summary in Fallon County in the City of Baker

Location: UNIVERSAL TIRE and ALIGNMENT
908 E Montana Ave
Baker, MT 59313-0000 Fallon

Legacy ID:13-08221

Facility ID: 20008
Last Inspected On: 10/15/2021
Operating Permit Renewal Date: 08/03/2021

Owner Operator Contact: John Geving;Marion Hartse

4067783675;4069782990

Operator Contact: John Geving

4069782990

Owner/Operator: John Geving

John Geving, UST Class A Operator
John Geving, UST Class B Global Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected

Status	Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types	
Product	Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery	
Capacity	Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act	
04	22	08/01/1999	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
4083	No			None	Yes
Temporarily Out of Use			Not Required	Safe Suction	Galvanic
Gasoline		06/12/2018	Automatic Tank Gauging 0.1;Automatic Tank Gauging 0.2	Deferred	No
8,000			Gilbarco/EMC Basic		No
05	22	08/01/1999	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
4084	No			None	Yes
Temporarily Out of Use			Not Required	Safe Suction	Galvanic
Gasoline		06/12/2018	Automatic Tank Gauging 0.1;Automatic Tank Gauging 0.2	Deferred	No
4,000			Gilbarco/EMC Basic		No
S6	22	08/01/1999	Bare Steel	Flexible Plastic	
4085	Yes	06/13/2018		Double Walled	Yes
Temporarily Out of Use			Continuous Interstitial Monitoring	Pressurized	
Diesel		06/12/2018	Deferred	Continuous Interstitial Monitoring	No
5,500					No