

**Facility Summary in Flathead County in the City of Bigfork**

**Location:** BIGFORK OUTDOOR RENTALS INC  
110 Swan River Rd  
Bigfork, MT 59911-6329 Flathead

Legacy ID:15-07361

**Facility ID:** 20728  
**Last Inspected On:** 04/16/2021  
**Operating Permit Renewal Date:**

**Owner Operator Contact:** Bigfork Outdoor Rentals Inc;Dale Whalen

**4063968185**

**Operator Contact:** Dale Whalen

**4063968185**

**Owner/Operator:** Bigfork Outdoor Rentals Inc

**Owner/Operator:** Dalen Whalen

Dale Whalen, UST Class A Operator

Dale Whalen, UST Class B Global Operator

Dale Whalen, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
06	26	11/01/1995	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
<b>3498</b>	No			None	Yes
Temporarily Out of Use			Not Required	Safe Suction	Galvanic
Gasoline		08/08/2018	Automatic Tank Gauging 0.1;Automatic Tank Gauging 0.2	Deferred	No
6,000			EMCO Electronics/EECO 1500		No
07	26	11/01/1995	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
<b>3499</b>	No			None	Yes
Temporarily Out of Use			Not Required	Safe Suction	Galvanic
Gasoline		08/08/2018	Automatic Tank Gauging 0.1;Automatic Tank Gauging 0.2	Deferred	No
3,000			EMCO Electronics/EECO 1500		No
08	26	11/01/1995	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm

3500	No		None	Yes
Temporarily Out of Use		Not Required	Safe Suction	Galvanic
Diesel	08/08/2018	Automatic Tank Gauging 0.1;Automatic Tank Gauging 0.2	Deferred	No
3,000		EMCO Electronics/EECO 1500		No

**Facility Summary in Flathead County in the City of Bigfork**

**Location:** BIGFORK STAGE STOP INC  
8263 MT Hwy 35  
Bigfork, MT 59911-3518 Flathead

Legacy ID:56-13885

**Facility ID:** 30560  
**Last Inspected On:** 07/12/2019  
**Operating Permit Renewal Date:** 12/02/2022

**Owner Operator Contact:** Bigfork Stage Stop Inc **4068375858**

**Operator Contact:** Vicky Miller;Bigfork Stage Stop Inc **4068371551;4068375858**

**Owner/Operator:** Bigfork Stage Stop Inc

Vicky Miller, UST Class A Operator  
Vicky Miller, UST Class B Global Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
01	23	10/01/1998	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
3531	No			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel			Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring;ELLD 0.2	No
12,000			Gilbarco/EMC Basic		No
02	23	10/01/1998	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
3532	No			Double Walled	Yes
Currently in Use		11/24/2008	Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring;ELLD 0.2	No

12,000			Gilbarco/EMC Basic		No
03	23	10/01/1998	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
<b>3533</b>	No			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring;ELLD 0.2	No
5,000			Gilbarco/EMC Basic		No

**Facility Summary in Flathead County in the City of Bigfork**

**Location:** CALUMET CARDLOCK  
8111 MT Hwy 35  
Bigfork, MT 59911-3588 Flathead

Legacy ID:15-09801

**Facility ID:** 20806  
**Last Inspected On:** 03/13/2019  
**Operating Permit Renewal Date:** 03/18/2022

**Owner Operator Contact:**

**Operator Contact:** Marcus Belgos;Bigfork Properties LLC

**4068375010;4068374550**

**Owner/Operator:** Bigfork Properties LLC

Marcus Belgos, UST Class A Operator

Marcus Belgos, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
01	40	05/01/1981	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve
<b>481</b>	No		Lined Interior/Impressed Current	None	Yes
Currently in Use			Not Required	Safe Suction	Impressed Current
Gasoline		03/06/2017	Automatic Tank Gauging 0.2	Deferred	No
8,000			Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
02	40	05/01/1981	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve
<b>482</b>	No		Lined Interior/Impressed Current	None	Yes

Currently in Use			Not Required	Safe Suction	Impressed Current
Diesel		03/06/2017	Automatic Tank Gauging 0.2	Deferred	No
12,000			Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
03	28	07/01/1993	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve
<b>483</b>	No			None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Gasoline		03/06/2017	Automatic Tank Gauging 0.2	Deferred	No
8,000			Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
04	26	04/01/1995	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve
<b>484</b>	No			None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Gasoline		03/06/2017	Automatic Tank Gauging 0.2	Deferred	No
6,000			Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
05	26	04/01/1995	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve
<b>485</b>	No			None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Diesel		03/06/2017	Automatic Tank Gauging 0.2	Deferred	No
4,000			Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No

**Facility Summary in Flathead County in the City of Bigfork**

**Location:** EAGLE BEND YACHT HARBOR  
371 Eagle Bend Dr  
Bigfork, MT 59911-6210 Flathead

Legacy ID:15-13152

**Facility ID:** 21034  
**Last Inspected On:** 05/10/2019  
**Operating Permit Renewal Date:** 06/01/2022

**Owner Operator Contact:**

**Operator Contact:** Sean Lujan

**4068715073**

**Owner/Operator:** Eagle Bend Yacht Harbor Boat Slip Owners Association

Sean Lujan, UST Class A Operator  
 Sean Lujan, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
01	28	07/01/1993	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
<b>4013</b>	No		Double-Walled	Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Continuous Interstitial Monitoring	Continuous Interstitial Monitoring; ELLD 0.2	No
5,000		08/02/2010	Gilbarco-Veeder Root/TLS-250		No
02	28	07/01/1993	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
<b>4014</b>	No		Double-Walled	Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Continuous Interstitial Monitoring	Continuous Interstitial Monitoring; ELLD 0.2	No
1,000		08/02/2010	Gilbarco-Veeder Root/TLS-250		No

**Facility Summary in Flathead County in the City of Bigfork**

**Location:** FERNDALE MARKET  
 1845 MT Hwy 209  
 Bigfork, MT 59911-6540 Flathead

Legacy ID:15-07199

**Facility ID:** 20719  
**Last Inspected On:** 06/09/2020  
**Operating Permit Renewal Date:** 08/08/2023

**Owner Operator Contact:**

**Operator Contact:** Brian Truckey; James Griggs; Jason Griggs; Ray Kleiv **4063148234; 4068375597**

**Owner/Operator:** Griggs Ferndale LLC

Brian Truckey, UST Class A Operator  
 Brian Truckey, UST Class B Operator  
 James Griggs, UST Class A Operator  
 Jason Griggs, UST Class A Operator  
 Jason Griggs, UST Class B Operator

Ray Kleiv, UST Class A Operator

Ray Kleiv, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
01	45	04/28/1976	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve
<b>3254</b>	No		Lined Interior/Impressed Current	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Diesel		03/06/2017	Automatic Tank Gauging 0.2	ELLD 0.2	No
4,000			Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
02	44	04/28/1977	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve
<b>3255</b>	No		Lined Interior/Impressed Current	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		03/06/2017	Automatic Tank Gauging 0.2	ELLD 0.2	No
8,000			Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
03	28	06/01/1993	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve
<b>3256</b>	No			None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		03/06/2017	Automatic Tank Gauging 0.2	ELLD 0.2	No
6,000			Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
04	28	06/01/1993	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve
<b>3257</b>	No			None	Yes

Currently in Use		Electronic Line Leak Detector	Pressurized	Impressed Current
Diesel	03/06/2017	Automatic Tank Gauging 0.2	ELLD 0.2	No
4,000		Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No

**Facility Summary in Flathead County in the City of Bigfork**

**Location:** FLATHEAD LAKE LODGE  
150 Flathead Lodge Rd  
Bigfork, MT 59911-7419 Flathead

Legacy ID:15-04551

**Facility ID:** 20643  
**Last Inspected On:** 02/05/2021  
**Operating Permit Renewal Date:**

**Owner Operator Contact:** Flathead Lake Lodge

**Operator Contact:** Douglas Averill

**4068374391**

**Owner/Operator:** Flathead Lake Lodge

Douglas Averill, UST Class A Operator  
Douglas Averill, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
04	29	05/14/1992	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve
<b>1826</b>	No			None	Yes
Temporarily Out of Use			Not Required	Safe Suction	Non-corrodible
Gasoline		01/10/2013	Manual Tank Gauging; Tank Tightness Testing	Not Listed	No
1,000					No
05	27	06/01/1994	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve
<b>1827</b>	No			None	Yes
Temporarily Out of Use			Not Required	Safe Suction	Non-corrodible
Gasoline		01/10/2013	Manual Tank Gauging; Tank Tightness Testing	Not Listed	No
600					No

**Facility Summary in Flathead County in the City of Bigfork**

**Location:** MARINA CAY RESORT  
180 Vista Lane  
Bigfork, MT 59911-6162 Flathead

Legacy ID:15-03002

**Facility ID:** 20591  
**Last Inspected On:** 08/05/2021  
**Operating Permit Renewal Date:** 10/14/2024

**Owner Operator Contact:**

<b>Operator Contact:</b> Jarvis Weibert	<b>4066791474</b>
---	-------------------

**Owner/Operator:** Elk LLC

Jarvis Weibert, UST Class A Operator  
Jarvis Weibert, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
<b>Tag #</b>	<b>AST</b>	<b>Sump Tightness</b>	<b>Secondary Option</b>	<b>Secondary Option</b>	<b>Spill Protected</b>
<b>Status</b>		<b>Piping Installed Date</b>	<b>Catastrophic L.D. Type 3.0</b>	<b>Piping Type</b>	<b>CP Met Types</b>
<b>Product</b>		<b>Tank/Pipe CP</b>	<b>Tank Detection</b>	<b>Primary Pipe Detection</b>	<b>Vapor Recovery</b>
<b>Capacity</b>		<b>Line Tightness</b>	<b>ATG Type</b>	<b>Secondary Pipe Detection</b>	<b>Energy Act</b>
02	22	05/05/1999	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
<b>4067</b>	No			Double Walled	Yes
Temporarily Out of Use			Continuous Interstitial Monitoring	Pressurized	
Gasoline			Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring	No
4,000					No
03	14	07/25/2007	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
<b>5110</b>	No	09/08/2015		Double Walled	Yes
Temporarily Out of Use		02/05/2006	Continuous Interstitial Monitoring	Pressurized	Non-corrodible
Gasoline			Automatic Tank Gauging 0.1	Continuous Interstitial Monitoring	No
4,000			Gilbarco/EMC Basic		No

**Facility Summary in Flathead County in the City of Bigfork**

**Location:** MONTANA RANCH LLC  
1463 Hwy 83  
Bigfork, MT 59911 Flathead

Legacy ID:60-15198

**Facility ID:** 30919  
**Last Inspected On:** 03/12/2021  
**Operating Permit Renewal Date:** 03/23/2024

**Owner Operator Contact:**



Operator Contact: Matt Cottle

4062538403

**Owner/Operator:** Montana Ranch LLC Bigfork

Matt Cottle, UST Class A Operator

Matt Cottle, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
01	10	08/29/2011	Fiberglass Reinforced Plastic	Steel	Flapper Valve
<b>5327</b>	No		Double-Walled	Double Walled	Yes
Currently in Use		08/29/2011	Not Required	Safe Suction	Non-corrodible
Gasoline			Continuous Interstitial Monitoring	Deferred	No
2,500		10/06/2011	Gilbarco-Veeder Root/EMC Basic		Yes
02	10	08/29/2011	Fiberglass Reinforced Plastic	Steel	Flapper Valve
<b>5328</b>	No		Double-Walled	Double Walled	Yes
Currently in Use		08/29/2011	Not Required	Safe Suction	Non-corrodible
Diesel			Continuous Interstitial Monitoring	Deferred	No
2,500		10/06/2011	Gilbarco-Veeder Root/EMC Basic		Yes

**Facility Summary in Flathead County in the City of Bigfork**

**Location:** O'CONNELL'S QWICK STOP  
21385 MT Hwy 83  
Bigfork, MT 59911-7811 Flathead

Legacy ID:24-05644

**Facility ID:** 22977  
**Last Inspected On:** 10/08/2020  
**Operating Permit Renewal Date:** 11/26/2023

**Owner Operator Contact:** PH and J Enterprises LLC;Preston O'Connell

**4068862300**

**Operator Contact:** Keith Broere

**Owner/Operator:** PH and J Enterprises LLC

**Owner/Operator:** Preston O'Connell

Keith Broere, UST Class A Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
04	35	05/07/1986	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve
<b>3325</b>	No			None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		03/06/2017	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	No
8,000		05/08/2018	Incon/TS-1000		No
05	35	05/07/1986	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve
<b>3326</b>	No			None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		03/06/2017	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	No
8,000		05/08/2018	Incon/TS-1000		No
06	25	07/01/1996	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve
<b>3327</b>	No			None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Diesel		03/06/2017	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	No
6,000		05/08/2018	Incon/TS-1000		No
07	25	07/01/1996	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve
<b>3328</b>	No			None	Yes
Temporarily Out of Use			Mechanical Line Leak Detector	Pressurized	Galvanic

Diesel	03/06/2017	Automatic Tank Gauging 0.1;Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	No
6,000	03/08/2011	Incon/TS-1000		No

**Facility Summary in Flathead County in the City of Bigfork**

**Location:** PAPA'S WOODSBAY MARKET  
14535 MT Hwy 35  
Bigfork, MT 59911 Flathead

Legacy ID:24-06085

**Facility ID:** 22990  
**Last Inspected On:** 03/10/2021  
**Operating Permit Renewal Date:** 03/28/2024

**Owner Operator Contact:**

**Operator Contact:** Diane Williams

**4068374884**

**Owner/Operator:** Randy Williams dba Papa's Woodsbay Market

**Owner/Operator:** Susan P Western

- Diane Williams, UST Class A Operator
- Rod Serres, UST Class B Global Operator
- Shawn Kneeland, UST Class B Global Operator
- Tami Pasha, UST Class B Global Operator
- Teri Bales, UST Class B Global Operator
- Tim Faber, UST Class B Global Operator
- Vicky Miller, UST Class B Global Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
<b>Tag #</b>	<b>AST</b>	<b>Sump Tightness</b>	<b>Secondary Option</b>	<b>Secondary Option</b>	<b>Spill Protected</b>
<b>Status</b>		<b>Piping Installed Date</b>	<b>Catastrophic L.D. Type 3.0</b>	<b>Piping Type</b>	<b>CP Met Types</b>
<b>Product</b>		<b>Tank/Pipe CP</b>	<b>Tank Detection</b>	<b>Primary Pipe Detection</b>	<b>Vapor Recovery</b>
<b>Capacity</b>		<b>Line Tightness</b>	<b>ATG Type</b>	<b>Secondary Pipe Detection</b>	<b>Energy Act</b>
01	37	01/30/1984	Bare Steel	Steel	Flapper Valve
<b>1279</b>	No			None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Impressed Current
Gasoline		03/12/2018	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	No
8,000		03/12/2018	EMCO Electronics/EECO 1000		No
02	37	01/30/1984	Bare Steel	Steel	Flapper Valve
<b>1280</b>	No			None	Yes

Currently in Use			Mechanical Line Leak Detector	Pressurized	Impressed Current
Gasoline	03/12/2018		Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	No
6,000	03/12/2018		EMCO Electronics/EECO 1000		No
03	27	05/01/1994	Cathodically Protected Steel	Steel	Flapper Valve
<b>1281</b>	No			None	Yes
Currently in Use			Not Required	Safe Suction	Impressed Current
Diesel	03/12/2018		Automatic Tank Gauging 0.2	Not Listed	No
4,000	05/13/2016		EMCO Electronics/EECO 1000		No

**Facility Summary in Flathead County in the City of Bigfork**

**Location:** ROE HATLEN  
20221 MT Hwy 35  
Bigfork, MT 59911-7254 Flathead

Legacy ID:56-14137

**Facility ID:** 30773  
**Last Inspected On:** 06/30/2020  
**Operating Permit Renewal Date:** 07/02/2023

**Owner Operator Contact:** Roe Hatlen **4068853160**

**Operator Contact:** Roe Hatlen **4068853160**

**Owner/Operator:** Roe Hatlen

Roe Hatlen, UST Class A Operator  
Roe Hatlen, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
01	16	03/21/2005	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
<b>5024</b>	No	11/12/2012	Double-Walled	Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline		03/11/2011	Continuous Interstitial Monitoring	Continuous Interstitial Monitoring; ELLD 0.2	No
1,000			Gilbarco-Veeder Root/TLS-350		No

## Facility Summary in Flathead County in the City of Bigfork

**Location:** YOUR TURN CONVENIENCE STOP  
7505 MT Hwy 35  
Bigfork, MT 59911-6215 Flathead

Legacy ID:15-02482

**Facility ID:** 20582  
**Last Inspected On:** 05/05/2020  
**Operating Permit Renewal Date:** 08/08/2023

**Owner Operator Contact:** Douglas White;White Enterprises;White Enterprises **4068376170;4068376170;4068376170**

**Operator Contact:** Alison Wallen;Angela Tull

### Owner/Operator: White Enterprises

Alison Wallen, UST Class A Operator  
Alison Wallen, UST Class B Operator  
Angela Tull, UST Class A Operator  
Angela Tull, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
06	24	01/10/1997	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
<b>3185</b>	No			Double Walled	Yes
Currently in Use		07/25/2013	Electronic Line Leak Detector	Pressurized	
Gasoline			Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring;ELLD 0.2	No
12,000		02/03/2011	Incon/TS-550 EVO		No
07	24	01/10/1997	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
<b>3186</b>	No			Double Walled	Yes
Currently in Use		07/25/2013	Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring;ELLD 0.2	No
12,000		02/03/2011	Incon/TS-550 EVO		No
08	24	01/10/1997	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve

<b>3187</b>	No			Double Walled	Yes
Currently in Use		07/25/2013	Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel			Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring; ELLD 0.2	No
12,000		02/03/2011	Incon/TS-550 EVO		No
09	24	11/01/1997	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
<b>3188</b>	No			Double Walled	Yes
Currently in Use		07/25/2013	Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel			Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring; ELLD 0.2	No
8,000		02/03/2011	Incon/TS-550 EVO		No

**Facility Summary in Flathead County in the City of Columbia Falls**

**Location:** CITY SERVICE VALCON  
195 Truck Route Rd  
Columbia Falls, MT 59912 Flathead

Legacy ID:15-12972

**Facility ID:** 21018  
**Last Inspected On:** 09/23/2020  
**Operating Permit Renewal Date:** 10/02/2023

**Owner Operator Contact:** Valcon Distributing LTD

**4067556611**

**Operator Contact:** Kary Tonjum

**4067554321**

**Owner/Operator:** Valcon Distributing LTD

Kary Tonjum, UST Class A Operator  
Kary Tonjum, UST Class B Global Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
01	29	12/15/1992	Cathodically Protected Steel	Flexible Plastic	Flapper Valve
<b>4404</b>	No	09/04/2014		Double Walled	Yes
Currently in Use		10/02/2014	Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		04/19/2017	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring; ELLD 0.2	No

15,000		09/29/2014	Veeder Root/TLS-450		No
04	29	11/15/1992	Cathodically Protected Steel	Flexible Plastic	Flapper Valve
<b>4405</b>	No	09/04/2014		Double Walled	Yes
Currently in Use		10/02/2014	Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		04/19/2017	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring;ELLD 0.2	No
5,000		09/29/2014	Veeder Root/TLS-450		No
05	29	11/15/1992	Cathodically Protected Steel	Flexible Plastic	Flapper Valve
<b>4406</b>	No	09/04/2014		Double Walled	Yes
Currently in Use		10/02/2014	Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		04/19/2017	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring;ELLD 0.2	No
5,000		09/29/2014	Veeder Root/TLS-450		No
03	29	11/15/1992	Cathodically Protected Steel	Flexible Plastic	Flapper Valve
<b>4407</b>	No	09/04/2014		Double Walled	Yes
Currently in Use		10/02/2014	Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		04/19/2017	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring;ELLD 0.2	No
8,000		09/29/2014	Veeder Root/TLS-450		No
02	29	11/15/1992	Cathodically Protected Steel	Flexible Plastic	Flapper Valve
<b>4408</b>	No	09/04/2014		Double Walled	Yes
Currently in Use		10/02/2014	Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		04/19/2017	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring;ELLD 0.2	No
10,000		09/29/2014	Veeder Root/TLS-450		No

**Facility Summary in Flathead County in the City of Columbia Falls**

**Location:** Hi-Star Properties LLC  
7356 US Hwy 2 E  
Columbia Falls, MT 59912-9107 Flathead

Legacy ID:15-11333

**Facility ID:** 20934  
**Last Inspected On:** 05/10/2019  
**Operating Permit Renewal Date:** 08/02/2022

**Owner Operator Contact:**

**Operator Contact:** Reed Miner;Wade Lindsay

**4067558982;4068900968**

**Owner/Operator:** Hi-Star Properties LLC

Reed Miner, UST Class A Operator

Reed Miner, UST Class B Global Operator

Wade Lindsay, UST Class A Operator

Wade Lindsay, UST Class B Global Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
01	31	01/01/1990	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
<b>686</b>	No			None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		03/14/2018	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	No
10,000		03/13/2018	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
02	31	01/01/1990	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
<b>687</b>	No			None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		03/14/2018	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	No
8,000		03/13/2018	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
03	31	01/01/1990	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
<b>688</b>	No			None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		03/14/2018	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	No



6,000		03/13/2018	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
04	31	01/01/1990	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
<b>689</b>	No			None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Diesel		03/14/2018	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	No
10,000		03/13/2018	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No

**Facility Summary in Flathead County in the City of Columbia Falls**

**Location:** JUNCTION GAS  
7322 US Hwy 2 E  
Columbia Falls, MT 59912-9107 Flathead

Legacy ID:15-02820

**Facility ID:** 20587  
**Last Inspected On:** 12/11/2019  
**Operating Permit Renewal Date:** 12/24/2022

**Owner Operator Contact:**

**Operator Contact:** David Brotnov;Ramdeep Kaur

**4068922004;8035225352**

**Owner/Operator: RKR LLC**

David M Brotnov, UST Class A Operator  
Marlene Sevesind, UST Class B Global Operator  
Ramdeep Kaur, UST Class A Operator  
Ramdeep Kaur, UST Class B Global Operator  
Ramdeep Kaur, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
<b>Tag #</b>	<b>AST</b>	<b>Sump Tightness</b>	<b>Secondary Option</b>	<b>Secondary Option</b>	<b>Spill Protected</b>
<b>Status</b>		<b>Piping Installed Date</b>	<b>Catastrophic L.D. Type 3.0</b>	<b>Piping Type</b>	<b>CP Met Types</b>
<b>Product</b>		<b>Tank/Pipe CP</b>	<b>Tank Detection</b>	<b>Primary Pipe Detection</b>	<b>Vapor Recovery</b>
<b>Capacity</b>		<b>Line Tightness</b>	<b>ATG Type</b>	<b>Secondary Pipe Detection</b>	<b>Energy Act</b>
01	44	07/01/1977	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve
<b>496</b>	No	12/06/2016	Lined Interior/Impressed Current	Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		12/06/2016	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring;ELLD 0.2	No
10,000		06/29/2010	Gilbarco/EMC Basic		No

02	44	07/01/1977	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve
<b>497</b>	No		Lined Interior/Impressed Current	Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		12/06/2016	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring; ELLD 0.2	No
10,000		12/06/2016	Gilbarco/EMC Basic		No
03	44	07/01/1977	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve
<b>498</b>	No	12/06/2016	Lined Interior/Impressed Current	Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Diesel		12/06/2016	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring; ELLD 0.2	No
6,000		06/29/2010	Gilbarco/EMC Basic		No
04	33	11/17/1988	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve
<b>499</b>	No			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic; Impressed Current
Diesel		12/06/2016	Automatic Tank Gauging 0.2	ELLD 0.2	No
6,000		12/06/2016	Gilbarco/EMC Basic		No

### **Facility Summary in Flathead County in the City of Columbia Falls**

**Location:** MIKES OF COLUMBIA FALLS  
1645 9th St W  
Columbia Falls, MT 59912 Flathead

Legacy ID: 15-06839

**Facility ID:** 20716  
**Last Inspected On:** 02/28/2020  
**Operating Permit Renewal Date:** 07/31/2023

**Owner Operator Contact:** Ron May; Mike's Conoco

**Operator Contact:** Ashley Whitford; Joe Stenzel; Michael Robinson; Reed Miner; Ronald May; Ronda Heil **4067558982**

**Owner/Operator:** KMR LLC

Ashley Whitford, UST Class A Operator  
Ashley Whitford, UST Class B Operator  
Jennifer Davis, UST Class B Operator  
Joe Stenzel, UST Class A Operator  
Kristy Stevenson, UST Class B Operator

Michael W Robinson, UST Class A Operator  
 Reed Miner, UST Class A Operator  
 Reed Miner, UST Class B Global Operator  
 Ronald May, UST Class A Operator  
 Ronda Heil, UST Class A Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
06	25	07/01/1996	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
<b>3366</b>	No			Secondary Containment Chase	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel			Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring; ELLD 0.1; ELLD 0.2	No
5,000			Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
07	25	07/01/1996	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
<b>3367</b>	No	06/02/2018		Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring; ELLD 0.1; ELLD 0.2	No
12,000			Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
08	25	07/01/1996	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
<b>3368</b>	No	06/02/2018		Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring; ELLD 0.1; ELLD 0.2	No
15,000			Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
09	25	07/01/1996	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve

<b>3369</b>	No	06/02/2018		Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Heating Oil			Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring; ELLD 0.1; ELLD 0.2	No
15,000			Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
05	25	07/01/1996	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
<b>4466</b>	No			Secondary Containment Chase	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel			Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring; ELLD 0.1; ELLD 0.2	No
8,000			Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No

### Facility Summary in Flathead County in the City of Columbia Falls

**Location:** SMITHS #168 FUEL CENTER  
150 Halfmoon Rd  
Columbia Falls, MT 59912 Flathead

Legacy ID:60-15336

**Facility ID:** 32381  
**Last Inspected On:** 05/21/2020  
**Operating Permit Renewal Date:** 07/29/2023

**Owner Operator Contact:** Smiths Food and Drug

**8019741400**

**Operator Contact:** Kerry Busey

**8019771048**

**Owner/Operator:** Smiths Food and Drug

Kerry Busey, UST Class A Operator  
Kerry Busey, UST Class B Global Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
01	0		Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve; High Level Alarm
<b>5926</b>	No		Double-Walled	Double Walled	No
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Continuous Interstitial Monitoring	Continuous Interstitial Monitoring; ELLD 0.2	Yes

20,000				Yes
02	0	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve;High Level Alarm
<b>5927</b>	No	Double-Walled	Double Walled	No
Currently in Use		Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel		Continuous Interstitial Monitoring	Continuous Interstitial Monitoring;ELLD 0.2	No
10,000				Yes
03	0	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve;High Level Alarm
<b>5928</b>	No	Double-Walled	Double Walled	No
Currently in Use		Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline		Continuous Interstitial Monitoring	Continuous Interstitial Monitoring;ELLD 0.2	Yes
8,000				Yes

**Facility Summary in Flathead County in the City of Columbia Falls**

**Location:** TOWN PUMP INC COLUMBIA FALLS 1  
502 9th St W  
Columbia Falls, MT 59912-3808 Flathead

Legacy ID:15-08690

**Facility ID:** 20763  
**Last Inspected On:** 02/14/2019  
**Operating Permit Renewal Date:** 04/21/2022

**Owner Operator Contact:** Don Edmisten;Town Pump Inc Columbia Falls PTRCB 4064976948  
1362

**Operator Contact:** Daniel Sampson;Reed Miner 4067558982

**Owner/Operator:** Columbia Falls 1 Town Pump LLC

- Daniel Sampson, UST Class A Operator
- Daniel Sampson, UST Class B Global Operator
- Don Edmisten, UST Class B Global Operator
- Reed Miner, UST Class A Operator
- Reed Miner, UST Class B Global Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act

02	40	07/14/1981	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve
<b>2420</b>	No			None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		10/11/2018	Approved Remote Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Statistical Inventory Reconciliation	Yes
12,000			Gilbarco-Veeder Root/TLS-350		No
07	32	07/14/1989	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	
<b>2423</b>	No			None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	
Gasoline			Approved Remote Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Statistical Inventory Reconciliation	Yes
12,000			Gilbarco-Veeder Root/TLS-350		No
05	36	10/01/1985	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve
<b>4380</b>	No			None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		10/11/2018	Approved Remote Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Statistical Inventory Reconciliation	Yes
10,000			Gilbarco-Veeder Root/TLS-350		No
06	32	07/14/1989	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve
<b>4381</b>	No			None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	
Gasoline			Approved Remote Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Statistical Inventory Reconciliation	Yes
12,000			Gilbarco-Veeder Root/TLS-350		No

**Facility Summary in Flathead County in the City of Columbia Falls**

**Location:** TOWN PUMP INC COLUMBIA FALLS 2  
 6102 US Hwy 2 W  
 Columbia Falls, MT 59912-8927 Flathead

Legacy ID:56-13825

**Facility ID:** 30511  
**Last Inspected On:** 06/04/2021  
**Operating Permit Renewal Date:** 11/19/2024

**Owner Operator Contact:** Don Edmisten;Columbia Falls Holdings LLC

**4064976948;4064976700**

**Operator Contact:** Trent Biggers

**Owner/Operator:** Columbia Falls 2 Town Pump LLC

Trent Biggers, UST Class A Operator  
 Trent Biggers, UST Class B Global Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
01	24	10/01/1997	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve;Flapper Valve
<b>2674</b>	No		Double-Walled	Double Walled	Yes
Currently in Use		10/08/2013	Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Approved Remote Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Yes
12,000			Gilbarco-Veeder Root/TLS-450		No
03	24	10/01/1997	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
<b>2676</b>	No		Double-Walled	Double Walled	Yes
Currently in Use		10/08/2013	Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Approved Remote Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Yes
10,000			Gilbarco-Veeder Root/TLS-450		No
04	24	10/01/1997	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
<b>2677</b>	No		Double-Walled	Double Walled	Yes

Currently in Use			Mechanical Line Leak Detector	Pressurized	
Diesel			Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;MLLD Line Tightness Testing;Statistical Inventory Reconciliation	No
10,000		11/12/2015			No
05	24	10/01/1997	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
<b>2678</b>	No		Double-Walled	Double Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	
Diesel			Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;MLLD Line Tightness Testing;Statistical Inventory Reconciliation	No
6,000		11/12/2015			No
06	24	10/01/1997	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
<b>2679</b>	No	10/07/2014	Double-Walled	Double Walled	Yes
Currently in Use		09/18/2014	Mechanical Line Leak Detector	Pressurized	
Diesel			Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;MLLD Line Tightness Testing;Statistical Inventory Reconciliation	No
6,000		11/12/2015			No
07	21	10/01/2000	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
<b>4249</b>	No		Double-Walled	Double Walled	Yes
Currently in Use		06/20/2012	Not Required	Pressurized	
Diesel			Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
15,000					No



08	21	10/01/2000	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
<b>4250</b>	No		Double-Walled	Double Walled	Yes
Currently in Use		06/20/2012	Not Required	Pressurized	
Diesel			Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
15,000					No
02	24	10/01/1997	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
<b>4670</b>	No		Double-Walled	Double Walled	Yes
Currently in Use		10/08/2013	Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel			Approved Remote Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
10,000			Gilbarco-Veeder Root/TLS-450		No
09	6	10/02/2015	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve
<b>5600</b>	No	09/17/2015	Double-Walled	Double Walled	Yes
Currently in Use		10/07/2015	Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Yes
15,000			Gilbarco-Veeder Root/TLS-450		Yes
10	6	10/02/2015	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve
<b>5601</b>	No	09/17/2015	Double-Walled	Double Walled	Yes
Currently in Use		10/07/2015	Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Yes
6,000			Gilbarco-Veeder Root/TLS-450		Yes

11	0	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
<b>5995</b>	No	Double-Walled	Double Walled	No
Currently in Use		Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline		Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Yes
6,000				Yes
12	0	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
<b>5996</b>	No	Double-Walled	Double Walled	No
Currently in Use		Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline		Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Yes
8,000				Yes
13	0	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
<b>5997</b>	No	Double-Walled	Double Walled	No
Currently in Use		Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline		Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Yes
6,000				Yes
14	0	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	
<b>5998</b>	No			No
Currently in Use			Pressurized	
DEF (Not Regulated)				No
8,000				No

15	0	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
<b>6009</b>	No	Double-Walled	Double Walled	No
Currently in Use		Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel		Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
30,000				Yes
16	0	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
<b>6010</b>	No	Double-Walled	Double Walled	No
Currently in Use		Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel		Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
10,000				Yes
17	0	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
<b>6011</b>	No	Double-Walled	Double Walled	No
Currently in Use		Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel, Dyed		Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
12,000				Yes

**Facility Summary in Flathead County in the City of Coram**

**Location:** GLACIER CENTER  
10049 US Hwy 2 E  
Coram, MT 59913 Flathead

Legacy ID:15-10895

**Facility ID:** 20898  
**Last Inspected On:** 02/14/2020  
**Operating Permit Renewal Date:** 06/03/2023

**Owner Operator Contact:** High Altitude Enterprises Inc Coram;Matt Kinsella;High Altitude Enterprises Inc Columbia Falls

**Operator Contact:** Matt Kinsella

**Owner/Operator:** High Altitude Enterprises Inc Coram

Matt Kinsella, UST Class A Operator

Matt Kinsella, UST Class B Operator  
 ShariLyn Gronitz, UST Class B Global Operator  
 ShariLyn Gronitz, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
04	33	04/17/1988	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
<b>1883</b>	No			None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Diesel		02/21/2017	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	No
6,000		10/18/2018	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
05	26	05/01/1995	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
<b>1884</b>	No			None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Non-corrodible
Gasoline		05/28/2014	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	No
12,000		10/18/2018	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
06	26	05/01/1995	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
<b>1885</b>	No			None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Non-corrodible
Gasoline		05/28/2014	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	No
12,000		10/18/2018	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
07	26	05/01/1995	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
<b>1886</b>	No			None	Yes

Currently in Use		Mechanical Line Leak Detector	Pressurized	Non-corrodible
Diesel	05/28/2014	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	No
5,000	10/18/2018	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No

**Facility Summary in Flathead County in the City of Hungry Horse**

**Location:** BOBS GENERAL STORE  
8930 US Hwy 2 E  
Hungry Horse, MT 59919 Flathead

Legacy ID:15-07506

**Facility ID:** 20733  
**Last Inspected On:** 03/18/2021  
**Operating Permit Renewal Date:** 03/24/2024

**Owner Operator Contact:** Robert Johnson;Bob's General Store;Swiss Chalet Rentals **4063874551;4063875504**

**Operator Contact:** Robert Johnson **4063874153**

**Owner/Operator:** Robert Johnson

**Owner/Operator:** Swiss Chalet Rentals

Robert Johnson, UST Class A Operator

Robert Johnson, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
01	41	09/01/1980	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
<b>4180</b>	No		Lined Interior/Impressed Current	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Impressed Current
Diesel		01/25/2018	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	No
2,000		01/25/2018	Incon/TS-1001		No
02	41	09/01/1980	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
<b>4181</b>	No		Lined Interior/Impressed Current	None	Yes
Currently in Use			Not Required	Safe Suction	Impressed Current
Gasoline		01/25/2018	Automatic Tank Gauging 0.2	Deferred	No

6,000		01/25/2018	Incon/TS-1001		No
03	41	09/01/1980	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
<b>4182</b>	No		Lined Interior/Impressed Current	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Impressed Current
Gasoline		01/25/2018	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	No
4,000		01/25/2018	Incon/TS-1001		No
04	41	09/01/1980	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
<b>4183</b>	No		Lined Interior/Impressed Current	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Impressed Current
Gasoline		01/25/2018	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	No
6,000		01/25/2018	Incon/TS-1001		No

**Facility Summary in Flathead County in the City of Hungry Horse**

**Location:** CENEX ZIP TRIP #71  
8840 US Hwy 2 E  
Hungry Horse, MT 59919 Flathead

Legacy ID:15-09708

**Facility ID:** 20804  
**Last Inspected On:** 01/31/2019  
**Operating Permit Renewal Date:** 04/29/2022

**Owner Operator Contact:** CHS Inc Spokane Valley;Jim Alford;CHS Inc - Spokane **5095367418**

**Operator Contact:** Jim Alford;Joe Stenzel;Michael Robinson;Reed Miner;Ronald May;Sean Hurley **4067558982;5095357701;5095367418**

**Owner/Operator:** CHS Inc Spokane Valley

- Andrew Duffie, UST Class B Operator
- Jim Alford, UST Class A Operator
- Jim Alford, UST Class B Global Operator
- Joe Stenzel, UST Class A Operator
- Justin Mace, UST Class B Operator
- Michael W Robinson, UST Class A Operator
- Reed Miner, UST Class A Operator
- Reed Miner, UST Class B Global Operator
- Ronald May, UST Class A Operator
- Sean Hurley, UST Class A Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
-----------	-----	-----------	----------------------------	-----------------	----------------

Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
05	3	10/23/2018	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve;High Level Alarm
<b>5855</b>	No	10/17/2018	Double-Walled	Double Walled	No
Currently in Use		10/23/2018	Electronic Line Leak Detector	Pressurized	
Gasoline			Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	Continuous Interstitial Monitoring;ELLD 0.2	No
20,000			Veeder Root/TLS-450		No
06	3	10/23/2018	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve;High Level Alarm
<b>5856</b>	No	10/17/2018	Double-Walled	Double Walled	No
Currently in Use		10/23/2018	Electronic Line Leak Detector	Pressurized	
Gasoline			Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	Continuous Interstitial Monitoring;ELLD 0.2	No
10,000			Veeder Root/TLS-450		No
07	3	10/23/2018	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve;High Level Alarm
<b>5857</b>	No	10/17/2018	Double-Walled	Double Walled	No
Currently in Use		10/23/2018	Electronic Line Leak Detector	Pressurized	
Diesel			Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	Continuous Interstitial Monitoring;ELLD 0.2	No
10,000			Veeder Root/TLS-450		No
08	3	10/23/2018	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve;High Level Alarm
<b>5858</b>	No	10/17/2018	Double-Walled	Double Walled	No
Currently in Use		10/23/2018	Electronic Line Leak Detector	Pressurized	

Diesel			Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	Continuous Interstitial Monitoring;ELLD 0.2	No
10,000			Veeder Root/TLS-450		No
09	3	10/23/2018	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve;High Level Alarm
<b>5859</b>	No	10/17/2018	Double-Walled	Double Walled	Yes
Currently in Use		10/23/2018	Electronic Line Leak Detector	Pressurized	
Diesel			Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	Continuous Interstitial Monitoring;ELLD 0.2	No
10,000			Gilbarco-Veeder Root/TLS- 350/Gilbarco EMC		No

**Facility Summary in Flathead County in the City of Kalispell**

**Location:** APPLEWAY CONOCO  
100 N Meridian Rd  
Kalispell, MT 59901-3848 Flathead

Legacy ID:15-00113

**Facility ID:** 20517  
**Last Inspected On:** 10/21/2020  
**Operating Permit Renewal Date:** 01/12/2024

**Owner Operator Contact:** Appleway Conoco

**Operator Contact:** Linda Bertoli

**Owner/Operator:** Appleway Conoco

Linda Bertoli, UST Class A Operator  
Linda Bertoli, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
01	42	12/31/1979	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve
<b>3141</b>	No		Lined Interior/Impressed Current	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Impressed Current
Gasoline		12/07/2016	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	No
10,000		12/07/2016	Gilbarco/EMC Basic		No



02	42	12/31/1979	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve
<b>3142</b>	No		Lined Interior/Impressed Current	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Impressed Current
Gasoline		12/07/2016	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	No
10,000		12/07/2016	Gilbarco/EMC Basic		No
03	42	12/31/1979	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve
<b>3143</b>	No		Lined Interior/Impressed Current	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Impressed Current
Gasoline		12/07/2016	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	No
10,000		12/07/2016	Gilbarco/EMC Basic		No

**Facility Summary in Flathead County in the City of Kalispell**

**Location:** BRIANS C STORE  
2075 US Hwy 2 E  
Kalispell, MT 59901-2944 Flathead

Legacy ID:15-13730

**Facility ID:** 21091  
**Last Inspected On:** 01/08/2021  
**Operating Permit Renewal Date:** 01/14/2024

**Owner Operator Contact:** DJL LLC

**4067514623**

**Operator Contact:** Brian Kahler

**4063606484**

**Owner/Operator:** DJL LLC

Brian Kahler, UST Class A Operator  
Brian Kahler, UST Class B Global Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
01	25	06/01/1996	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
<b>3352</b>	No			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible

Diesel			Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring; ELLD 0.1; ELLD 0.2	No
20,000		03/24/2017	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
02	25	06/01/1996	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
<b>3353</b>	No			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring; ELLD 0.1; ELLD 0.2	No
20,000		07/22/2017	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
03	25	06/01/1996	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
<b>3354</b>	No			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring; ELLD 0.1; ELLD 0.2	No
12,000		03/22/2017	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
04	25	06/01/1996	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
<b>3355</b>	No			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel			Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring; ELLD 0.1; ELLD 0.2	No
12,000		03/20/2017	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
05	25	06/01/1996	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
<b>3356</b>	No			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel			Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring; ELLD 0.1; ELLD 0.2	No
8,000		07/07/2017	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
06	25	06/01/1996	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve

3357	No		Double Walled	Yes
Currently in Use		Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel		Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring; ELLD 0.1; ELLD 0.2	No
8,000	04/27/2017	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No

**Facility Summary in Flathead County in the City of Kalispell**

**Location:** BRIANS INC  
1319 US Hwy 93 S  
Kalispell, MT 59901-5765 Flathead

Legacy ID:15-09820

**Facility ID:** 20807  
**Last Inspected On:** 03/11/2020  
**Operating Permit Renewal Date:** 06/28/2023

**Owner Operator Contact:** DJL LLC;Rory Abraham

**4067514623;4067527339**

**Operator Contact:** Brian Kahler

**4063606484**

**Owner/Operator:** Darryl Bjork

**Owner/Operator:** DJL LLC

Brian Kahler, UST Class A Operator  
Brian Kahler, UST Class B Global Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
05	26	09/01/1995	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
1847	No			None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Diesel		04/26/2017	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	No
15,000		04/26/2017	Incon/TS-1000		No
06	26	09/01/1995	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
1848	No			None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic

Gasoline		04/26/2017	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	No
15,000		04/26/2017	Incon/TS-1000		No
07	26	09/01/1995	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
<b>1849</b>	No			None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		04/26/2017	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	No
7,500		04/26/2017	Incon/TS-1000		No
08	26	09/01/1995	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
<b>1850</b>	No			None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Diesel		04/26/2017	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	No
7,500		04/26/2017	Incon/TS-1000		No

**Facility Summary in Flathead County in the City of Kalispell**

**Location:** CHS - WEST  
120 W Idaho St  
Kalispell, MT 59901 Flathead

Legacy ID:15-05069

**Facility ID:** 20654  
**Last Inspected On:** 06/27/2017  
**Operating Permit Renewal Date:** 06/30/2020

**Owner Operator Contact:** DOCO LLC;Jerry Eide;Cenex Harvest States Jerry Eide;Mark Lalum;Mountain West Cooperative **4065438383**

**Operator Contact:** Bob Westin **4067557427**

**Owner/Operator: DOCO LLC**

Bob Westin, UST Class A Operator  
Bob Westin, UST Class B Global Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act

11	25	03/01/1996	Cathodically Protected Steel	Flexible Plastic	Flapper Valve
----	----	------------	------------------------------	------------------	---------------

<b>866</b>	No			Double Walled	Yes
Temporarily Out of Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		06/28/2017	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring; ELLD 0.2; ELLD Line Tightness Testing	No
12,000		03/16/2017	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
12	25	03/01/1996	Cathodically Protected Steel	Flexible Plastic	Flapper Valve
<b>867</b>	No			Double Walled	Yes
Temporarily Out of Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		06/28/2017	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring; ELLD 0.2; ELLD Line Tightness Testing	No
12,000		03/16/2017	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
13	25	03/01/1996	Cathodically Protected Steel	Flexible Plastic	Flapper Valve
<b>868</b>	No			Double Walled	Yes
Temporarily Out of Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		06/28/2017	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring; ELLD 0.2; ELLD Line Tightness Testing	No
15,000		03/16/2017	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No

**Facility Summary in Flathead County in the City of Kalispell**

**Location:** CITY SERVICE BULK PLANT  
1841 3rd Ave E  
Kalispell, MT 59901-5758 Flathead

Legacy ID:56-13824

**Facility ID:** 30510  
**Last Inspected On:** 11/20/2019  
**Operating Permit Renewal Date:** 12/24/2022

**Owner Operator Contact:** City Service Inc

**4067554321**

**Operator Contact:** Drew Pike;Kary Tonjum;Margaret Flynn

**4062940863;4067554321**

**Owner/Operator:** City Service Inc

Drew Pike, UST Class A Operator  
Drew Pike, UST Class B Global Operator  
Kary Tonjum, UST Class A Operator  
Kary Tonjum, UST Class B Global Operator  
Margaret Flynn, UST Class A Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
01	24	08/01/1997	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
<b>681</b>	No	09/28/2017		Double Walled	Yes
Currently in Use		09/28/2017	Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel			Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring; ELLD 0.2	No
15,000			Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
02	24	08/01/1997	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
<b>682</b>	No	09/28/2017		Double Walled	Yes
Currently in Use		09/28/2017	Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring; ELLD 0.2	No
15,000		09/22/2016	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
03	24	08/01/1997	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
<b>683</b>	No	09/28/2017		Double Walled	Yes
Currently in Use		09/28/2017	Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring; ELLD 0.2	No
20,000			Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
04	24	08/01/1997	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
<b>684</b>	No	09/28/2017		Double Walled	Yes
Currently in Use		09/28/2017	Electronic Line Leak Detector	Pressurized	Non-corrodible

Diesel			Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring; ELLD 0.2	No
20,000			Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
05	24	08/01/1997	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
<b>685</b>	No	09/28/2017		Double Walled	Yes
Currently in Use		09/28/2017	Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel			Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring; ELLD 0.2	No
20,000			Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No

**Facility Summary in Flathead County in the City of Kalispell**

**Location:** CITY SERVICE VALCON - EAGLE FUEL  
3150 US Hwy 2  
Kalispell, MT 59901 Flathead

Legacy ID:56-14014

**Facility ID:** 30674  
**Last Inspected On:** 11/20/2019  
**Operating Permit Renewal Date:** 12/31/2022

**Owner Operator Contact:** City Service Valcon LLC

**Operator Contact:** Kary Tonjum

**4067554321**

**Owner/Operator:** City Service Valcon LLC

Kary Tonjum, UST Class A Operator  
Kary Tonjum, UST Class B Global Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
01	20	07/01/2001	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
<b>4605</b>	No			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring; ELLD 0.1; ELLD 0.2	No
4,000			Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
02	20	07/01/2001	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm

<b>4606</b>	No			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel			Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring; ELLD 0.1; ELLD 0.2	No
4,000			Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
03	20	07/01/2001	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
<b>4607</b>	No			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel			Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring; ELLD 0.1; ELLD 0.2	No
20,000			Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
04	20	07/01/2001	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
<b>4608</b>	No			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring; ELLD 0.1; ELLD 0.2	No
8,000			Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No

**Facility Summary in Flathead County in the City of Kalispell**

**Location:** CITY SERVICE VALCON LLC  
52 5th Ave W N  
Kalispell, MT 59901-3802 Flathead

Legacy ID:15-01680

**Facility ID:** 20552  
**Last Inspected On:** 04/26/2019  
**Operating Permit Renewal Date:** 05/01/2022

**Owner Operator Contact:** City Service Valcon LLC; Dallas Herron; Valcon Distributing LTD

**4067514623;4067556611**

**Operator Contact:** Drew Pike; Jay Brookie

**4062524661;4067554321**

**Owner/Operator:** City Service Valcon LLC

David Wines, UST Class B Global Operator  
Drew Pike, UST Class A Operator  
Drew Pike, UST Class B Global Operator  
Jay Brookie, UST Class A Operator  
Jay Brookie, UST Class B Global Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
-----------	-----	-----------	----------------------------	-----------------	----------------



Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
09	23	11/01/1998	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
<b>3689</b>	No			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel			Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring; ELLD 0.2	No
25,000			Gilbarco/EMC Basic		No
10	23	11/01/1998	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
<b>3690</b>	No			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring; ELLD 0.2	No
25,000			Gilbarco/EMC Basic		No
11	23	11/01/1998	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
<b>3691</b>	No			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel			Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring; ELLD 0.2	No
20,000			Gilbarco/EMC Basic		No
12	23	11/01/1998	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
<b>3692</b>	No			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring; ELLD 0.2	No
15,000			Gilbarco/EMC Basic		No

13	23	12/01/1998	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
<b>3693</b>	No			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Heating Oil			Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring; ELLD 0.2	No
8,000			Gilbarco/EMC Basic		No

**Facility Summary in Flathead County in the City of Kalispell**

**Location:** CONOCO CAR CARE CENTER  
292 3rd Ave E N  
Kalispell, MT 59901 Flathead

Legacy ID:15-01677

**Facility ID:** 20550  
**Last Inspected On:** 10/13/2020  
**Operating Permit Renewal Date:** 12/12/2023

**Owner Operator Contact:** Valcon Distributing LTD **4067556611**

**Operator Contact:** Kary Tonjum;Shawn Norby **4067554321**

**Owner/Operator:** Valcon Distributing LTD

Kary Tonjum, UST Class A Operator  
Kary Tonjum, UST Class B Global Operator  
Shawn Norby, UST Class A Operator  
Shawn Norby, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
01	50	04/24/1971	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve
<b>2199</b>	No		Lined Interior/Impressed Current	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Impressed Current
Gasoline		08/08/2017	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	No
10,000		08/02/2017	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
02	50	04/24/1971	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve

<b>2200</b>	No		Lined Interior/Impressed Current	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Impressed Current
Gasoline		08/08/2017	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	No
10,000		08/02/2017	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
03	45	04/23/1976	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve
<b>2201</b>	No		Lined Interior/Impressed Current	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Impressed Current
Diesel		08/08/2017	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	No
6,000		08/02/2017	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
09	35	04/23/1986	Cathodically Protected Steel	No Piping	High Level Alarm
<b>2202</b>	No			None	Yes
Currently in Use			Not Required	Gravity Feed	Galvanic
Oil, Waste		08/08/2017	Automatic Tank Gauging 0.2	3-Year Line Tightness Test	No
1,000		08/16/2017	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No

**Facility Summary in Flathead County in the City of Kalispell**

**Location:** COSTCO WHOLESALE  
2330 US Hwy 93 N  
Kalispell, MT 59901-2547 Flathead

Legacy ID:60-15012

**Facility ID:** 30802  
**Last Inspected On:** 01/31/2020  
**Operating Permit Renewal Date:** 02/07/2023

**Owner Operator Contact:**

**Operator Contact:** Dan Martinez;David Ely;George Cox

**4064711892;4067582501**

**Owner/Operator:** Costco Wholesale

Dan Martinez, UST Class A Operator  
David Ely, UST Class A Operator  
David Ely, UST Class B Operator  
George Cox, UST Class A Operator  
George Cox, UST Class B Global Operator  
George Cox, UST Class B Operator  
Michael Williams, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
01	16	10/07/2005	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
<b>5033</b>	No		Double-Walled	Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Continuous Interstitial Monitoring	Continuous Interstitial Monitoring; ELLD 0.2	No
20,000		05/06/2011	Gilbarco-Veeder Root/TLS-350		No
02	16	10/07/2005	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
<b>5034</b>	No		Double-Walled	Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Continuous Interstitial Monitoring	Continuous Interstitial Monitoring; ELLD 0.2	No
20,000		05/06/2011	Gilbarco-Veeder Root/TLS-350		No
03	16	10/07/2005	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
<b>5035</b>	No		Double-Walled	Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Continuous Interstitial Monitoring	Continuous Interstitial Monitoring; ELLD 0.2	No
20,000		05/06/2011	Gilbarco-Veeder Root/TLS-350		No
04	10	04/19/2011	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
<b>5280</b>	No		Double-Walled	Double Walled	Yes
Currently in Use		10/25/2010	Mechanical Line Leak Detector	Pressurized	Non-corrodible

Hazardous Substance		Continuous Interstitial Monitoring	Continuous Interstitial Monitoring;MLLD Line Tightness Testing	No
1,500	12/16/2016	Gilbarco-Veeder Root/TLS-350		Yes

**Facility Summary in Flathead County in the City of Kalispell**

**Location:** DIAMOND AIRE LLC LEASEE  
1893 Airport Rd  
Kalispell, MT 59901-7501 Flathead

Legacy ID:15-03172

**Facility ID:** 20598  
**Last Inspected On:** 11/06/2019  
**Operating Permit Renewal Date:** 12/20/2022

**Owner Operator Contact:** John Talmage;Montana Diamond Aire Inc;Montana Diamond Aire Inc **4067525092**

**Operator Contact:** John Talmage **4067525092**

**Owner/Operator:** Montana Diamond Aire Inc

John Talmage, UST Class A Operator  
John Talmage, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
<b>Tag #</b>	<b>AST</b>	<b>Sump Tightness</b>	<b>Secondary Option</b>	<b>Secondary Option</b>	<b>Spill Protected</b>
<b>Status</b>		<b>Piping Installed Date</b>	<b>Catastrophic L.D. Type 3.0</b>	<b>Piping Type</b>	<b>CP Met Types</b>
<b>Product</b>		<b>Tank/Pipe CP</b>	<b>Tank Detection</b>	<b>Primary Pipe Detection</b>	<b>Vapor Recovery</b>
<b>Capacity</b>		<b>Line Tightness</b>	<b>ATG Type</b>	<b>Secondary Pipe Detection</b>	<b>Energy Act</b>
07	26	05/24/1995	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
<b>3285</b>	No	11/29/2016		Double Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Non-corrodible
Jet Fuel (Jet-A, Jet-A1, JP5)			Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring	No
12,000			Gilbarco/EMC Basic		No
08	26	05/24/1995	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
<b>3286</b>	No	11/29/2016		Double Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Non-corrodible
Aviation Gas			Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring	No
5,000			Gilbarco/EMC Basic		No

**Facility Summary in Flathead County in the City of Kalispell**

**Location:** EVERGREEN GAS and DELI  
2100 US Hwy 2 E  
Kalispell, MT 59901-2814 Flathead

Legacy ID:15-00108

**Facility ID:** 20512  
**Last Inspected On:** 11/21/2020  
**Operating Permit Renewal Date:** 12/02/2023

**Owner Operator Contact:** Aries Enterprises LLC

**4068905047**

**Operator Contact:** Ramdeep Kaur

**8035225352**

**Owner/Operator:** Aries Enterprises LLC

**Owner/Operator:** Kristi Lyn Ruggles

Ramdeep Kaur, UST Class A Operator  
Ramdeep Kaur, UST Class B Global Operator  
Ramdeep Kaur, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
04	23	06/01/1998	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
<b>3180</b>	No			None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	No
10,000		03/13/2018	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
05	23	06/01/1998	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
<b>3181</b>	No			None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	No
12,000		03/13/2018	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No

**Facility Summary in Flathead County in the City of Kalispell**

**Location:** FLATHEAD COUNTY JUSTICE CENTER  
920 S Main St  
Kalispell, MT 59901 Flathead

Legacy ID:15-09279

**Facility ID:** 20774  
**Last Inspected On:** 11/06/2019  
**Operating Permit Renewal Date:** 03/16/2023

**Owner Operator Contact:** Flathead County Commissioners

**4067585790**

**Operator Contact:** David Covill;Don Mills;Michael Hovila

**4064716592;4067585834**

**Owner/Operator:** Flathead County Commissioners

David Covill, UST Class A Operator  
David Covill, UST Class B Operator  
Don Mills, UST Class A Operator  
Don Mills, UST Class B Operator  
Michael Hovila, UST Class A Operator  
Michael Hovila, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
01	34	03/11/1987	Cathodically Protected Steel	No Piping	Flapper Valve
3810	No	10/04/2016		None	Yes
Currently in Use			Auto Dialer	U.S. Suction	Galvanic
Diesel		10/06/2016	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring	No
6,000			Gilbarco/EMC Basic		No

**Facility Summary in Flathead County in the City of Kalispell**

**Location:** FLATHEAD COUNTY ROAD DEPT  
1249 Willow Glen Dr  
Kalispell, MT 59901-7541 Flathead

Legacy ID:15-06286

**Facility ID:** 20703  
**Last Inspected On:** 05/13/2019  
**Operating Permit Renewal Date:** 05/23/2022

**Owner Operator Contact:** Flathead County Commissioners;Ted Gilbertson;Flathead County Road Dept

**4067585790**

**Operator Contact:** Corey Pilsch

**4067524962**

**Owner/Operator:** Flathead County Commissioners

Corey Pilsch, UST Class A Operator  
Corey Pilsch, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
08	23	05/01/1998	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
1088	No	12/19/2013		Double Walled	Yes
Currently in Use		11/19/2013	Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel			Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring;ELLD 0.2	No
10,000			Gilbarco/EMC Basic		No
09	23	05/01/1998	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
1089	No	12/19/2013		Double Walled	Yes
Currently in Use		11/19/2013	Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring;ELLD 0.2	No
3,000			Gilbarco/EMC Basic		No

**Facility Summary in Flathead County in the City of Kalispell**

**Location:** FLATHEAD COUNTY SOLID WASTE DIST  
4098 US Hwy 93 N  
Kalispell, MT 59901-6820 Flathead

Legacy ID:56-14041

**Facility ID:** 30696  
**Last Inspected On:** 08/21/2019  
**Operating Permit Renewal Date:** 12/26/2022

**Owner Operator Contact:** Flathead County Commissioners

**4067585790**

**Operator Contact:** James Chilton

**Owner/Operator:** Flathead County Commissioners

James Chilton, UST Class A Operator  
James Chilton, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types



Product	Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity	Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
01	20	11/26/2001	Fiberglass Reinforced Plastic	Ball Float Valve
<b>4559</b>	No	08/24/2016	Double-Walled	Yes
Currently in Use		Not Required	Not Listed	Non-corrodible
Oil, Waste		Continuous Interstitial Monitoring	Manual Interstitial Monitoring	No
1,000				No
S2	18	02/25/2003	Concrete	High Level Alarm
<b>4802</b>	Yes	08/24/2016		Yes
Currently in Use		Mechanical Line Leak Detector	Pressurized	
Diesel		Deferred	Continuous Interstitial Monitoring;MLLD Line Tightness Testing	No
15,000				No
S3	18	02/25/2003	Concrete	High Level Alarm
<b>4803</b>	Yes	08/24/2016		Yes
Currently in Use		Mechanical Line Leak Detector	Pressurized	
Gasoline		Deferred	Continuous Interstitial Monitoring;MLLD Line Tightness Testing	No
3,000				No

**Facility Summary in Flathead County in the City of Kalispell**

**Location:** FLATHEAD ELECTRIC COOP KALISPELL  
2510 US Hwy 2 E  
Kalispell, MT 59901-2312 Flathead

Legacy ID:15-00044

**Facility ID:** 20508  
**Last Inspected On:** 02/25/2020  
**Operating Permit Renewal Date:** 08/08/2023

**Owner Operator Contact:** Flathead Electric Cooperative Inc

**4067514483**

**Operator Contact:** Brenda Butler;Terry Tintzman

**4067514405**

**Owner/Operator:** Flathead Electric Cooperative Inc

Brenda Butler, UST Class A Operator

Brenda Butler, UST Class B Operator

Brent Senner, UST Class B Operator  
 Terry Tintzman, UST Class A Operator  
 Terry Tintzman, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
04	23	04/01/1998	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
<b>1090</b>	No			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring; ELLD 0.2	No
10,000			Veeder Root/TLS-450		No
05	23	04/01/1998	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
<b>1091</b>	No			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel			Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring; ELLD 0.2	No
6,000			Veeder Root/TLS-450		No
06	23	04/01/1998	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
<b>1092</b>	No			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring; ELLD 0.2	No
5,000			Veeder Root/TLS-450		No

**Facility Summary in Flathead County in the City of Kalispell**

**Location:** Glacier Gas N Go  
 1454 MT Hwy 35  
 Kalispell, MT 59901-2916 Flathead

Legacy ID:15-08357

**Facility ID:** 20756  
**Last Inspected On:** 09/03/2020  
**Operating Permit Renewal Date:** 08/20/2023

**Owner Operator Contact:**

**Operator Contact:** Stephen Symington

**4067560399**

**Owner/Operator:** HARJ93, LLC

Stephen Symington, UST Class A Operator

Stephen Symington, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
01	39	05/08/1982	Bare Steel	Steel	Flapper Valve
1420	No			None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Impressed Current
Gasoline		11/17/2017	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	No
8,000		05/09/2018	Veeder Root/TLS-300		No
02	39	05/08/1982	Bare Steel	Steel	Flapper Valve
1421	No			None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Impressed Current
Gasoline		11/17/2017	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	No
8,000		05/09/2018	Veeder Root/TLS-300		No

**Facility Summary in Flathead County in the City of Kalispell**

**Location:** HEALTH CENTER NORTHWEST  
320 Sunnyview Ln  
Kalispell, MT 59901-3177 Flathead

Legacy ID:56-14072

**Facility ID:** 30724  
**Last Inspected On:** 08/21/2019  
**Operating Permit Renewal Date:** 09/29/2022

**Owner Operator Contact:** Flathead Hospital Development Co

**4067525111**

**Operator Contact:** Kyle Hovey;Mark Chitwood;Steve Herman

**4062128644;4062611847;4067511814**

**Owner/Operator:** Flathead Hospital Development Co

Kyle Hovey, UST Class A Operator

Kyle Hovey, UST Class B Operator  
 Mark Chitwood, UST Class A Operator  
 Mark Chitwood, UST Class B Global Operator  
 Steve Herman, UST Class A Operator  
 Steve Herman, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
S1	18	12/16/2003	Concrete	Flexible Plastic	
<b>4880</b>	Yes	08/19/2016	Double-Walled	Double Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	U.S. Suction	
Diesel			Deferred	Continuous Interstitial Monitoring	No
6,000					No

**Facility Summary in Flathead County in the City of Kalispell**

**Location:** HOLIDAY STATIONSTORE 722  
 840 W Idaho St  
 Kalispell, MT 59901-3844 Flathead

Legacy ID:56-13985

**Facility ID:** 30646  
**Last Inspected On:** 10/28/2021  
**Operating Permit Renewal Date:** 03/30/2022

**Owner Operator Contact:**

**Operator Contact:** Chuck Nyberg;Patrick Patnaude;Robert Deninno;Stephen Reckinger;Valeria Jeffries;Veronica Rivera

**9528308028;9528308721;9528308722**

**Owner/Operator:** Rocky Mountain Oil Co Inc

Brad Lee, UST Class B Global Operator  
 Chuck Nyberg, UST Class A Operator  
 Patrick Patnaude, UST Class A Operator  
 Robert Deninno, UST Class A Operator  
 Stephen Reckinger, UST Class A Operator  
 Todd White, UST Class B Global Operator  
 Valeria Jeffries, UST Class A Operator  
 Veronica Rivera, UST Class A Operator  
 Veronica Rivera, UST Class B Global Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
01	21	10/01/2000	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve;High Level Alarm
<b>4239</b>	No		Double-Walled	Double Walled	Yes
Currently in Use		10/20/2000	Electronic Line Leak Detector	Pressurized	
Gasoline			Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	Continuous Interstitial Monitoring;ELLD 0.2;ELLD Line Tightness Testing	No
15,000		07/24/2018	Gilbarco-Veeder Root/TLS- 350/Gilbarco EMC		No
02	21	10/01/2000	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve;High Level Alarm
<b>4240</b>	No		Double-Walled	Double Walled	Yes
Currently in Use		10/20/2000	Electronic Line Leak Detector	Pressurized	
Gasoline			Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	Continuous Interstitial Monitoring;ELLD 0.2;ELLD Line Tightness Testing	No
10,000		07/25/2018	Gilbarco-Veeder Root/TLS- 350/Gilbarco EMC		No

**Facility Summary in Flathead County in the City of Kalispell**

**Location:** KALISPELL REGIONAL MEDICAL CENTER  
325 Claremont St  
Kalispell, MT 59901-3576 Flathead

Legacy ID:15-00800

**Facility ID:** 20529  
**Last Inspected On:** 03/08/2019  
**Operating Permit Renewal Date:** 03/13/2022

**Owner Operator Contact:** Northwest Healthcare

**4067563695**

**Operator Contact:** Kyle Hovey;Mark Chitwood;Steve Herman

**4062128644;4062611847;4067511814**

**Owner/Operator:** Northwest Healthcare

- Kyle Hovey, UST Class A Operator
- Kyle Hovey, UST Class B Operator
- Mark Chitwood, UST Class A Operator
- Mark Chitwood, UST Class B Global Operator
- Steve Herman, UST Class A Operator
- Steve Herman, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
02	31	11/06/1990	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
1465	No			None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	
Jet Fuel (Jet-A, Jet-A1, JP5)			Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	No
6,000		09/27/2018	Gilbarco/EMC Basic		No

**Facility Summary in Flathead County in the City of Kalispell**

**Location:** KALS FOOD STORES #101  
1645 US Hwy 93 S  
Kalispell, MT 59901-5775 Flathead

Legacy ID:15-02014

**Facility ID:** 20564  
**Last Inspected On:** 02/05/2019  
**Operating Permit Renewal Date:** 02/13/2022

**Owner Operator Contact:** Kary Tonjum;City Service Inc

**4067554321;4067554321**

**Operator Contact:** Kari Barnhouse

**4067554075**

**Owner/Operator:** Brar Brothers LLC

Baljeet Singh, UST Class B Operator  
Kari Barnhouse, UST Class A Operator  
Kari Barnhouse, UST Class B Global Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
11	24	05/01/1997	Steel Clad	Flexible Plastic	Ball Float Valve
650	No			Double Walled	Yes
Currently in Use		11/04/2013	Electronic Line Leak Detector	Pressurized	

Diesel			Automatic Tank Gauging 0.1;Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring;ELLD 0.1;ELLD 0.2	No
10,000			Gilbarco/EMC Basic		No
12	24	05/01/1997	Steel Clad	Flexible Plastic	Ball Float Valve
<b>651</b>	No			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	
Diesel			Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring;ELLD 0.1;ELLD 0.2	No
15,000			Gilbarco/EMC Basic		No
13	24	05/01/1997	Steel Clad	Flexible Plastic	Ball Float Valve
<b>652</b>	No			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	
Gasoline			Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring;ELLD 0.1;ELLD 0.2	No
12,000			Gilbarco/EMC Basic		No
14	24	05/01/1997	Steel Clad	Flexible Plastic	Ball Float Valve
<b>653</b>	No			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	
Gasoline			Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring;ELLD 0.1;ELLD 0.2	No
15,000			Gilbarco/EMC Basic		No

**Facility Summary in Flathead County in the City of Kalispell**

**Location:** KAL'S FOOD STORES #102  
1090 N Meridian Rd  
Kalispell, MT 59901-3564 Flathead

Legacy ID:15-00110

**Facility ID:** 20514  
**Last Inspected On:** 01/28/2019  
**Operating Permit Renewal Date:** 03/23/2022

**Owner Operator Contact:**

**Operator Contact:** Kari Barnhouse

**4067554075**

**Owner/Operator:** Brar Brothers LLC

Kari Barnhouse, UST Class A Operator  
Kari Barnhouse, UST Class B Global Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
04	24	11/01/1997	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve
<b>3171</b>	No			None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		01/17/2019	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	No
10,000		01/17/2019	Gilbarco/EMC Basic		No
05	24	11/01/1997	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve
<b>3172</b>	No			None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Diesel		01/17/2019	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	No
5,000		01/17/2019	Gilbarco/EMC Basic		No
06	24	11/01/1997	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve
<b>3173</b>	No			None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		01/17/2019	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	No
5,000		01/17/2019	Gilbarco/EMC Basic		No

**Facility Summary in Flathead County in the City of Kalispell**

**Location:** KELLY RAES INC  
25 Batavia Ln  
Kalispell, MT 59901-7280 Flathead

Legacy ID:15-06101

**Facility ID:** 20691  
**Last Inspected On:** 07/29/2019  
**Operating Permit Renewal Date:** 02/03/2023

**Owner Operator Contact:** Kelly Raes Inc;Tab Young Marcie Riley;Kelly Raes Inc **4067525880**

**Operator Contact:** Dawn Brown;Lisa Myers;Marcie Riley;Tab Young **4067525880**



**Owner/Operator:** Kelly Raes Inc

Connie Parker, UST Class B Operator  
 Dawn Brown, UST Class A Operator  
 Dawn Brown, UST Class B Global Operator  
 Dawn Brown, UST Class B Operator  
 Kayla Weisz, UST Class B Operator  
 Lisa Meyers, UST Class B Operator  
 Lisa Myers, UST Class A Operator  
 Lisa Myers, UST Class B Operator  
 Marcie Riley, UST Class A Operator  
 Mona Woodruff, UST Class B Operator  
 Stephanie Brussels, UST Class B Operator  
 Tab Young, UST Class A Operator  
 Tish Keck, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
03	27	02/01/1994	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve
<b>4505</b>	No			Double Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Diesel		08/16/2016	Statistical Inventory Reconciliation	MLLD Line Tightness Testing	No
6,000		08/16/2016	Gilbarco-Veeder Root/TLS-450		No
S6	2	01/10/2019	Aboveground Tank	Flexible Plastic	
<b>5891</b>	Yes			Double Walled	No
Currently in Use			Electronic Line Leak Detector	Pressurized	
Diesel			Not Listed	Continuous Interstitial Monitoring;ELLD 0.2	No
5,000					No

S7	2	01/10/2019	Aboveground Tank	Flexible Plastic	
<b>5892</b>	Yes			Double Walled	No
Currently in Use			Electronic Line Leak Detector	Pressurized	
Diesel			Not Listed	Continuous Interstitial Monitoring; ELLD 0.2	No
10,000					No
S8	2	01/10/2019	Aboveground Tank	Flexible Plastic	
<b>5893</b>	Yes			Double Walled	No
Currently in Use			Electronic Line Leak Detector	Pressurized	
Gasoline			Not Listed	Continuous Interstitial Monitoring; ELLD 0.2	No
15,000					No
S9	2	01/10/2019	Aboveground Tank	Flexible Plastic	
<b>5894</b>	Yes			Double Walled	No
Currently in Use			Electronic Line Leak Detector	Pressurized	
Gasoline			Not Listed	Continuous Interstitial Monitoring; ELLD 0.2	No
5,000					No

**Facility Summary in Flathead County in the City of Kalispell**

**Location:** MDOT KALISPELL  
85 5th Ave E N  
Kalispell, MT 59901-4115 Flathead

Legacy ID:15-08733

**Facility ID:** 20766  
**Last Inspected On:** 10/28/2021  
**Operating Permit Renewal Date:** 05/01/2022

**Owner Operator Contact:** Doug Compton; Montana Dept of Transportation **4064447647**

**Operator Contact:** Joe Radonich; Mike Murolo; Walt Kerttula

**Owner/Operator:** MDOT Helena

Joe Radonich, UST Class A Operator  
Joe Radonich, UST Class B Global Operator  
Mike Murolo, UST Class A Operator  
Nick Rosenbaum, UST Class B Global Operator  
Walt Kerttula, UST Class A Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
04	30	12/01/1991	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve
<b>2892</b>	No			None	Yes
Currently in Use			Not Required	Safe Suction	Non-corrodible
Gasoline			Automatic Tank Gauging 0.2	Deferred	No
10,000			Gilbarco/EMC Basic		No
05	30	12/01/1991	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve
<b>2893</b>	No			None	Yes
Currently in Use			Not Required	Safe Suction	Non-corrodible
Diesel			Automatic Tank Gauging 0.2	Deferred	No
12,000			Gilbarco/EMC Basic		No

**Facility Summary in Flathead County in the City of Kalispell**

**Location:** MICHAELS EAST  
1278 US Hwy 2 E  
Kalispell, MT 59901-3219 Flathead

Legacy ID:15-09707

**Facility ID:** 20803  
**Last Inspected On:** 10/17/2020  
**Operating Permit Renewal Date:** 09/04/2023

**Owner Operator Contact:** Camie Pederson;Rocky Mountain Oil LLC - Env Director  
**9528308899**

**Operator Contact:** Tiffany Howard

**Owner/Operator:** Indian Brothers LLC

- Sharon Trickey, UST Class B Global Operator
- Sharon Trickey, UST Class B Operator
- Sherry Doyle, UST Class B Global Operator
- Tiffany Howard, UST Class A Operator
- Tiffany Howard, UST Class B Global Operator
- Tiffany Howard, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
01	36	06/01/1985	Cathodically Protected Steel	Steel	Ball Float Valve
<b>3005</b>	No			None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		11/17/2017	Automatic Tank Gauging 0.2	ELLD 0.1;ELLD 0.2	Yes
12,000			Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
02	36	06/01/1985	Cathodically Protected Steel	Steel	Ball Float Valve
<b>3006</b>	No			None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		11/17/2017	Automatic Tank Gauging 0.2	ELLD 0.1;ELLD 0.2	Yes
12,000			Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
03	36	06/01/1985	Cathodically Protected Steel	Steel	Ball Float Valve
<b>3007</b>	No			None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		11/17/2017	Automatic Tank Gauging 0.2	ELLD 0.1;ELLD 0.2	Yes
10,000			Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
04	36	06/01/1985	Cathodically Protected Steel	Steel	Ball Float Valve
<b>3008</b>	No			None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Diesel		11/17/2017	Automatic Tank Gauging 0.2	ELLD 0.1;ELLD 0.2	No

10,000

Gilbarco-Veeder Root/TLS-350/Gilbarco EMC

No

**Facility Summary in Flathead County in the City of Kalispell**

**Location:** MICHAELS EXXON  
1011 US Hwy 2 W  
Kalispell, MT 59901-3800 Flathead

Legacy ID:15-02330

**Facility ID:** 20571  
**Last Inspected On:** 06/19/2020  
**Operating Permit Renewal Date:** 09/25/2023

**Owner Operator Contact:** Beargrass Holdings LLP;Kary Tonjum;City Service Inc;Michael Blend;Beargrass Holdings LLP;Mike Hayes;Michaels Convenience Stores Inc

**4067525250;4067525250;4067525250;4067554075;4067554321;4067554321**

**Operator Contact:** Christina Turner;Michael Hayes;Tiffany Howard

**4067554075**

**Owner/Operator:** Beargrass Holdings LLP

- Alice Reeves, UST Class B Operator
- Christina Turner, UST Class A Operator
- Michael Hayes, UST Class A Operator
- Tiffany Howard, UST Class A Operator
- Tiffany Howard, UST Class B Global Operator
- Tiffany Howard, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
30	29	12/01/1992	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
<b>654</b>	No			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Automatic Tank Gauging 0.2	ELLD 0.2	No
12,000			Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
31	29	12/01/1992	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
<b>655</b>	No			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Automatic Tank Gauging 0.2	ELLD 0.2	No

12,000			Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
32	29	12/01/1992	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
656	No			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Automatic Tank Gauging 0.2	ELLD 0.2	No
12,000		03/12/2015	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
33	28	04/01/1993	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
657	No			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel			Automatic Tank Gauging 0.2	ELLD 0.2	No
12,000			Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
34	28	04/01/1993	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
658	No			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel			Automatic Tank Gauging 0.2	ELLD 0.2	No
8,000			Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
35	28	04/01/1993	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
659	No			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel			Automatic Tank Gauging 0.2	ELLD 0.2	No
4,000			Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
36	28	06/01/1993	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
660	No			Double Walled	Yes

Currently in Use	Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline	Automatic Tank Gauging 0.2	ELLD 0.2	No
4,000	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No

**Facility Summary in Flathead County in the City of Kalispell**

**Location:** MOUNTAIN WEST COOP KALISPELL  
700 Rail Park Dr  
Kalispell, MT 59901 Flathead

Legacy ID:60-15343

**Facility ID:** 32409  
**Last Inspected On:** 06/16/2020  
**Operating Permit Renewal Date:** 09/08/2023

**Owner Operator Contact:** Mountain West Cooperative

**4065438383**

**Operator Contact:** Bob Westin

**4067557427**

**Owner/Operator:** Mountain West Cooperative

Bob Westin, UST Class A Operator

Bob Westin, UST Class B Global Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
01	0		Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve
<b>5963</b>	No		Double-Walled	Double Walled	No
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Automatic Tank Gauging 0.1;Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	Continuous Interstitial Monitoring;ELLD 0.2	No
4,000					Yes
02	0		Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve
<b>5964</b>	No		Double-Walled	Double Walled	No
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible

Diesel		Automatic Tank Gauging 0.1;Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	Continuous Interstitial Monitoring;ELLD 0.2	No
8,000				Yes
03	0	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve
<b>5965</b>	No	Double-Walled	Double Walled	No
Currently in Use		Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel		Automatic Tank Gauging 0.1;Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	Continuous Interstitial Monitoring;ELLD 0.2	Yes
4,000				Yes
04	0	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve
<b>5966</b>	No	Double-Walled	Double Walled	No
Currently in Use		Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline		Automatic Tank Gauging 0.1;Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	Continuous Interstitial Monitoring;ELLD 0.2	No
8,000				Yes
05	0	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve
<b>5967</b>	No	Double-Walled	Double Walled	No
Currently in Use		Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel, Dyed		Automatic Tank Gauging 0.1;Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	Continuous Interstitial Monitoring;ELLD 0.2	Yes
7,000				Yes

**Facility Summary in Flathead County in the City of Kalispell**

**Location:** RED EAGLE AVIATION INC  
1880 US Hwy 93 S  
Kalispell, MT 59901-5729 Flathead

Legacy ID:15-11166

**Facility ID:** 20921  
**Last Inspected On:** 09/03/2020  
**Operating Permit Renewal Date:** 09/14/2023

**Owner Operator Contact:** Red Eagle Aviation Inc



Operator Contact: Paige Pitz

**Owner/Operator:** Red Eagle Aviation Inc

Paige Pitz, UST Class A Operator

Paige Pitz, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
03	40	01/01/1981	Bare Steel	Fiberglass Reinforced Plastic	High Level Alarm
4144	No		Lined Interior/Impressed Current	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Impressed Current
Aviation Gas		12/19/2017	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	No
12,000		12/19/2017	Incon/TS-1000		No
04	40	01/01/1981	Bare Steel	Fiberglass Reinforced Plastic	High Level Alarm
4173	No			None	Yes
Currently in Use			Not Required	Pressurized	Impressed Current
Jet Fuel (Jet-A, Jet-A1, JP5)		12/19/2017	Automatic Tank Gauging 0.2	Deferred	No
12,000		11/28/2011	Incon/TS-1000		No

**Facility Summary in Flathead County in the City of Kalispell**

**Location:** RMC KALISPELL SHOP  
2214 US Hwy 2 E  
Kalispell, MT 59901-2816 Flathead

Legacy ID:15-04359

**Facility ID:** 20634  
**Last Inspected On:** 09/02/2020  
**Operating Permit Renewal Date:** 09/03/2023

**Owner Operator Contact:** Rocky Mountain Contractors Inc Kalispell

**4067524280**

**Operator Contact:** Leona Prezeau

**4067566012**

**Owner/Operator:** Rocky Mountain Contractors Inc Kalispell

Leona Prezeau, UST Class A Operator

Leona Prezeau, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
03	27	01/01/1994	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve
1284	No			Single Walled	Yes
Currently in Use			Not Required	Safe Suction	Non-corrodible
Gasoline			Automatic Tank Gauging 0.2	Deferred	No
12,000			Gilbarco-Veeder Root/TLS-300		No
04	27	01/01/1994	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve
1285	No			None	Yes
Currently in Use			Not Required	Safe Suction	Non-corrodible
Diesel			Automatic Tank Gauging 0.2	Deferred	No
12,000			Gilbarco-Veeder Root/TLS-300		No

**Facility Summary in Flathead County in the City of Kalispell**

**Location:** SMITHS FUEL CENTER 172  
195 3rd Ave E N  
Kalispell, MT 59901-4051 Flathead

Legacy ID:56-14062

**Facility ID:** 30715  
**Last Inspected On:** 10/20/2020  
**Operating Permit Renewal Date:** 11/04/2023

**Owner Operator Contact:** Smiths Food and Drug

**8019741400**

**Operator Contact:** David Harris;Gary Dotseth;James Dye;Kerry Busey;Michael Crumley;Ronnie Houtekamer;Steven Perkins;Todd Dotseth

**4064527649;4065446677;4067882338;8015600471;8019741206;8019741317;8019771048;8019772012**

**Owner/Operator:** Smiths Food and Drug

- David Harris, UST Class A Operator
- David Harris, UST Class B Global Operator
- Gary Dotseth, UST Class A Operator
- Gary Dotseth, UST Class B Global Operator
- James Dye, UST Class A Operator
- James Dye, UST Class B Global Operator

Kerry Busey, UST Class A Operator  
 Kerry Busey, UST Class B Global Operator  
 Michael Crumley, UST Class A Operator  
 Michael Crumley, UST Class B Global Operator  
 Ronnie Houtekamer, UST Class A Operator  
 Ronnie Houtekamer, UST Class B Global Operator  
 Steven Perkins, UST Class A Operator  
 Steven Perkins, UST Class B Global Operator  
 Todd Dotseth, UST Class A Operator  
 Todd Dotseth, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
01	19	08/23/2002	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve
<b>4742</b>	No		Double-Walled	Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Continuous Interstitial Monitoring	Continuous Interstitial Monitoring; ELLD 0.2	Yes
20,000			Gilbarco-Veeder Root/TLS-350		Yes
02	19	08/23/2002	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve
<b>4743</b>	No		Double-Walled	Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Continuous Interstitial Monitoring	Continuous Interstitial Monitoring; ELLD 0.2	Yes
8,000			Gilbarco-Veeder Root/TLS-350		Yes
03	19	08/23/2002	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve
<b>4744</b>	No		Double-Walled	Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible

Diesel	Continuous Interstitial Monitoring	Continuous Interstitial Monitoring; ELLD 0.2	No
8,000	Gilbarco-Veeder Root/TLS-350		Yes

**Facility Summary in Flathead County in the City of Kalispell**

**Location:** SWEET PEAKS ICE CREAM  
343 S Main St  
Kalispell, MT 59901-4847 Flathead

Legacy ID:15-04894

**Facility ID:** 20649  
**Last Inspected On:** 07/25/2019  
**Operating Permit Renewal Date:** 08/06/2022

**Owner Operator Contact:** Robert Berry

**4067524883**

**Operator Contact:** Keith Broere; Lisa Shriver

**Owner/Operator:** Gene Towle

- Keith Broere, UST Class A Operator
- Keith Broere, UST Class B Global Operator
- Lisa Shriver, UST Class A Operator
- Lisa Shriver, UST Class B Global Operator
- Lisa Shriver, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
03	26	09/14/1995	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
<b>438</b>	No			None	Yes
Temporarily Out of Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		10/17/2016	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	No
12,000			Incon/TS-1000		No
04	26	09/14/1995	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
<b>439</b>	No			None	Yes
Temporarily Out of Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		10/17/2016	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	No

6,000

Incon/TS-1000

No

**Facility Summary in Flathead County in the City of Kalispell**

**Location:** TOWN PUMP INC KALISPELL 1  
445 W Idaho St  
Kalispell, MT 59901 Flathead

Legacy ID:15-08709

**Facility ID:** 20764  
**Last Inspected On:** 04/20/2021  
**Operating Permit Renewal Date:** 04/23/2024

**Owner Operator Contact:** Don Edmisten;Town Pump

**4064976948**

**Operator Contact:** Trent Biggers

**Owner/Operator:** Kalispell 1 Town Pump LLC

Trent Biggers, UST Class A Operator  
Trent Biggers, UST Class B Global Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
02	39	04/14/1982	Bare Steel	Fiberglass Reinforced Plastic	Flapper Valve
2425	No			None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		10/05/2018	Approved Remote Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Statistical Inventory Reconciliation	No
12,000			Gilbarco-Veeder Root/TLS-350		No
06	24	05/28/1997	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
2426	No		Double-Walled	Single Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Approved Remote Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Statistical Inventory Reconciliation	No
6,000			Gilbarco-Veeder Root/TLS-350		No
01	39	04/14/1982	Bare Steel	Fiberglass Reinforced Plastic	Flapper Valve

<b>4679</b>	No			Single Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		10/05/2018	Approved Remote Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Statistical Inventory Reconciliation	No
8,000			Gilbarco-Veeder Root/TLS-350		No
07	24	05/28/1997	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
<b>4680</b>	No		Double-Walled	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel			Approved Remote Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Statistical Inventory Reconciliation	No
8,000			Gilbarco-Veeder Root/TLS-350		No
08	17	08/18/2004	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
<b>4939</b>	No		Double-Walled	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Statistical Inventory Reconciliation	No
20,000			Gilbarco-Veeder Root/TLS-350		No

**Facility Summary in Flathead County in the City of Kalispell**

**Location:** TOWN PUMP INC KALISPELL 2  
1100 E Idaho St  
Kalispell, MT 59901 Flathead

Legacy ID:15-13764

**Facility ID:** 21094  
**Last Inspected On:** 04/21/2021  
**Operating Permit Renewal Date:** 04/23/2024

**Owner Operator Contact:**

**Operator Contact:** Trent Biggers

Trent Biggers, UST Class A Operator  
Trent Biggers, UST Class B Global Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected

Status	Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types	
Product	Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery	
Capacity	Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act	
01	24	04/01/1997	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
<b>4814</b>	No		Double-Walled	Double Walled	Yes
Currently in Use		07/12/2013	Not Required	Pressurized	Non-corrodible
Gasoline			Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
12,000			Gilbarco-Veeder Root/TLS-350		No
02	24	04/01/1997	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
<b>4815</b>	No		Double-Walled	Double Walled	Yes
Currently in Use		07/12/2013	Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
12,000			Gilbarco-Veeder Root/TLS-350		No
03	24	04/01/1997	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
<b>4816</b>	No		Double-Walled	Double Walled	Yes
Currently in Use		07/12/2013	Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel			Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
12,000			Gilbarco-Veeder Root/TLS-350		No
04	24	04/01/1997	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
<b>4817</b>	No		Double-Walled	Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible

Gasoline			Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
12,000			Gilbarco-Veeder Root/TLS-350		No
05	24	04/01/1997	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve
<b>4818</b>	No		Double-Walled	Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
12,000			Gilbarco-Veeder Root/TLS-350		No

**Facility Summary in Flathead County in the City of Kalispell**

**Location:** TOWN PUMP INC KALISPELL 3  
2605 US Hwy 2 E  
Kalispell, MT 59901-2363 Flathead

Legacy ID:15-13732

**Facility ID:** 21092  
**Last Inspected On:** 04/22/2021  
**Operating Permit Renewal Date:** 04/23/2024

**Owner Operator Contact:**

**Operator Contact:** Trent Biggers

**Owner/Operator:** Kalispell 3 Town Pump

Trent Biggers, UST Class A Operator  
Trent Biggers, UST Class B Global Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
01	25	07/01/1996	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve
<b>4766</b>	No	07/20/2014		Double Walled	Yes
Currently in Use		12/02/2013	Electronic Line Leak Detector	Pressurized	Non-corrodible



Gasoline			Approved Remote Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Yes
20,000			Gilbarco-Veeder Root/TLS-350		No
02	25	07/01/1996	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve
<b>4767</b>	No	07/20/2014		Double Walled	Yes
Currently in Use		12/02/2013	Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Approved Remote Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Yes
15,000			Gilbarco-Veeder Root/TLS-350		No
03	25	07/01/1996	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve
<b>4768</b>	No	07/20/2014		Double Walled	Yes
Currently in Use		12/02/2013	Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel			Approved Remote Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
15,000			Gilbarco-Veeder Root/TLS-350		No
04	25	07/01/1996	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve
<b>4769</b>	No	07/20/2014		Double Walled	Yes
Currently in Use		12/02/2013	Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel			Approved Remote Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
8,000			Gilbarco-Veeder Root/TLS-350		No
05	25	07/01/1996	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve
<b>4770</b>	No	07/20/2014		Double Walled	Yes
Currently in Use		12/02/2013	Electronic Line Leak Detector	Pressurized	Non-corrodible

Diesel	Approved Remote Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
8,000	Gilbarco-Veeder Root/TLS-350		No

**Facility Summary in Flathead County in the City of Kalispell**

**Location:** TOWN PUMP INC KALISPELL 5  
2910 US Hwy 93 S  
Kalispell, MT 59901-7901 Flathead

Legacy ID:15-13765

**Facility ID:** 21095  
**Last Inspected On:** 09/10/2021  
**Operating Permit Renewal Date:** 01/07/2025

**Owner Operator Contact:**

**Operator Contact:** Trent Biggers

**Owner/Operator:** Kalispell 5 Town Pump LLC

Trent Biggers, UST Class A Operator  
Trent Biggers, UST Class B Global Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
01	25	09/01/1996	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
<b>3430</b>	No			Double Walled	Yes
Currently in Use		04/20/2011	Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel			Approved Remote Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
15,000			Gilbarco-Veeder Root/TLS-450		No
02	25	09/01/1996	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
<b>3431</b>	No			Double Walled	Yes
Currently in Use		04/20/2011	Electronic Line Leak Detector	Pressurized	Non-corrodible

Gasoline			Approved Remote Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
15,000			Gilbarco-Veeder Root/TLS-450		No
03	25	09/01/1996	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve;Positive Shutoff
<b>3432</b>	No			Double Walled	Yes
Currently in Use		04/20/2011	Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Approved Remote Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Yes
20,000			Gilbarco-Veeder Root/TLS-450		No
04	3	12/05/2018	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve
<b>5793</b>	No		Double-Walled	Double Walled	No
Currently in Use		12/05/2018	Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel			Approved Remote Monitoring;Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
6,000			Gilbarco-Veeder Root/TLS-450		Yes
05	3	12/05/2018	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve
<b>5794</b>	No		Double-Walled	Double Walled	No
Currently in Use		12/05/2018	Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Approved Remote Monitoring;Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
15,000			Gilbarco-Veeder Root/TLS-450		Yes
06	3	12/05/2018	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve
<b>5795</b>	No		Double-Walled	Double Walled	No

Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel			Approved Remote Monitoring;Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
6,000			Gilbarco-Veeder Root/TLS-450		Yes
07	3	12/05/2018	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve
<b>5796</b>	No		Double-Walled	Double Walled	No
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Approved Remote Monitoring;Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Yes
6,000			Gilbarco-Veeder Root/TLS-450		Yes
08	3	12/05/2018	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve
<b>5797</b>	No		Double-Walled	Double Walled	No
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Approved Remote Monitoring;Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Yes
15,000			Gilbarco-Veeder Root/TLS-450		Yes
09	3	12/05/2018	Fiberglass Reinforced Plastic	Flexible Plastic	
<b>5798</b>	No		Double-Walled	Double Walled	No
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Non-corrodible
DEF (Not Regulated)			Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
6,000					No

10	3	12/05/2018	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve
<b>5799</b>	No		Double-Walled	Double Walled	No
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel			Approved Remote Monitoring;Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Yes
20,000			Gilbarco-Veeder Root/TLS-450		Yes

**Facility Summary in Flathead County in the City of Kalispell**

**Location:** TOWN PUMP KALISPELL #7  
859 W Reserve St  
Kalispell, MT 59901 Flathead

Legacy ID:60-15262

**Facility ID:** 30977  
**Last Inspected On:** 04/27/2021  
**Operating Permit Renewal Date:** 04/28/2024

**Owner Operator Contact:**

**Operator Contact:** Trent Biggers

**Owner/Operator:** Kalispell 7 Town Pump LLC

Trent Biggers, UST Class A Operator

Trent Biggers, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
01	6	11/04/2015	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm;Positive Shutoff
<b>5604</b>	No	12/03/2015	Double-Walled	Double Walled	Yes
Currently in Use		05/28/2016	Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Yes
30,000			Gilbarco-Veeder Root/TLS-450		Yes
02	6	11/04/2015	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm;Positive Shutoff

<b>5605</b>	No	12/03/2015	Double-Walled	Double Walled	Yes
Currently in Use		05/28/2016	Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Yes
6,000			Gilbarco-Veeder Root/TLS-450		Yes
03	6	11/04/2015	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm;Positive Shutoff
<b>5606</b>	No	12/03/2015	Double-Walled	Double Walled	Yes
Currently in Use		05/28/2016	Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Yes
15,000			Gilbarco-Veeder Root/TLS-450		Yes
05	6	11/04/2015	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm;Positive Shutoff
<b>5608</b>	No	12/03/2015	Double-Walled	Double Walled	Yes
Currently in Use		05/28/2016	Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel			Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
6,000			Gilbarco-Veeder Root/TLS-450		Yes
06	6	11/04/2015	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm;Positive Shutoff
<b>5609</b>	No	12/03/2015	Double-Walled	Double Walled	Yes
Currently in Use		05/28/2016	Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel			Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
15,000			Gilbarco-Veeder Root/TLS-450		Yes
07	6	11/04/2015	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm;Positive Shutoff

5610	No	12/03/2015	Double-Walled	Double Walled	Yes
Currently in Use		05/28/2016	Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel			Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
6,000			Gilbarco-Veeder Root/TLS-450		Yes

**Facility Summary in Flathead County in the City of Kalispell**

**Location:** WARDEN HUTTERIAN BRETHERN  
295 Middle Rd  
Kalispell, MT 59901-7700 Flathead

Legacy ID:15-05344

**Facility ID:** 20661  
**Last Inspected On:** 08/26/2018  
**Operating Permit Renewal Date:** 02/12/2022

**Owner Operator Contact:** Warden Hutterian Brethren

**4062532276**

**Operator Contact:** Steve Streich

**4062532276**

**Owner/Operator:** Warden Hutterian Brethren

Steve Streich, UST Class A Operator  
Steve Streich, UST Class B Global Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
S3	26	11/01/1995	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve
869	No			None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Gasoline		10/11/2018	Manual Tank Gauging	Deferred	No
1,000					No
S4	26	11/01/1995	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve
870	No			None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic

Diesel	10/11/2018	Manual Tank Gauging	Deferred	No
1,000				No

**Facility Summary in Flathead County in the City of Kalispell**

**Location:** WEST VALLEY SCHOOL DIST 1  
2290 Farm To Market Rd  
Kalispell, MT 59901-7108 Flathead

Legacy ID:15-10295

**Facility ID:** 20846  
**Last Inspected On:** 08/24/2020  
**Operating Permit Renewal Date:**

**Owner Operator Contact:** School Dist 1 West Valley

**4067557239**

**Operator Contact:** Phillip Jackson

**4067557239**

**Owner/Operator:** School Dist 1 West Valley

Phillip Jackson, UST Class A Operator  
Phillip Jackson, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
S2	26	08/09/1995	Fiberglass Reinforced Plastic	Copper	Flapper Valve
2249	No	07/23/2015		Secondary Containment Chase	Yes
Temporarily Out of Use			Not Required	U.S. Suction	Non-corrodible
Heating Oil			Manual Tank Gauging	3-Year Line Tightness Test	No
1,000					No

**Facility Summary in Flathead County in the City of Kalispell**

**Location:** WHITE OAK SUPER STOP  
4810 US Hwy 93 S  
Kalispell, MT 59901-7985 Flathead

Legacy ID:15-13287

**Facility ID:** 21043  
**Last Inspected On:** 09/01/2020  
**Operating Permit Renewal Date:** 10/17/2023

**Owner Operator Contact:** Tabish Brothers Distributors Inc

**4065437621**

**Operator Contact:** Amber Terrell;Karly Shafer;Kristy Stevenson

**4063962206;4068572344;4068718400**

**Owner/Operator:** Greg Tabish

**Owner/Operator:** Tabish Brothers Distributors Inc

Amber Terrell, UST Class A Operator



Amber Terrell, UST Class B Operator  
 Karly Shafer, UST Class A Operator  
 Karly Shafer, UST Class B Global Operator  
 Kristy Stevenson, UST Class A Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
01	38	10/01/1983	Bare Steel	Flexible Plastic	Flapper Valve
<b>4481</b>	No			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		11/18/2017	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring;ELLD 0.2	No
10,000			Gilbarco-Veeder Root/TLS-450		No
02	38	11/01/1983	Bare Steel	Flexible Plastic	Flapper Valve
<b>4482</b>	No			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Diesel		11/18/2017	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring;ELLD 0.2	No
10,000			Gilbarco-Veeder Root/TLS-450		No
03	38	11/01/1983	Bare Steel	Flexible Plastic	Flapper Valve
<b>4483</b>	No			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Diesel		11/18/2017	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring;ELLD 0.2	No
6,000			Veeder Root/TLS-450		No
04	4	09/01/2017	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve

5781	No	10/04/2017	Double-Walled	Double Walled	Yes
Currently in Use		09/01/2017	Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	Continuous Interstitial Monitoring;ELLD 0.2	No
20,000		10/18/2017	Veeder Root/TLS-450		Yes

**Facility Summary in Flathead County in the City of Kalispell**

**Location:** WOODLAND QUIKSTOP  
81 Woodland Park Dr  
Kalispell, MT 59901-4665 Flathead

Legacy ID:15-00115

**Facility ID:** 20518  
**Last Inspected On:** 06/05/2019  
**Operating Permit Renewal Date:** 06/11/2022

**Owner Operator Contact:** Scott Curry;Scott Curry;Woodland Qwikstop **4067555075**

**Operator Contact:** Scott Curry **4067555075**

**Owner/Operator:** Scott Curry

Scott Curry, UST Class A Operator  
Scott Curry, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
03	23	07/23/1998	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
<b>3524</b>	No			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring;ELLD 0.2	No
10,000			Gilbarco/EMC Basic		No
04	23	07/23/1998	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
<b>3525</b>	No			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring;ELLD 0.2	No
12,000			Gilbarco/EMC Basic		No

**Facility Summary in Flathead County in the City of Kalispell**

**Location:** WOODYS COUNTRY STORE INC  
3333 MT Hwy 35  
Kalispell, MT 59901-7724 Flathead

Legacy ID:15-05801

**Facility ID:** 20677  
**Last Inspected On:** 03/10/2021  
**Operating Permit Renewal Date:** 03/17/2024

**Owner Operator Contact:** Woodys Country Store Inc **4067555544**

**Owner/Operator:** Woodys Country Store Inc

Charles Weiss, UST Class A Operator

Charles Weiss, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
01	37	12/05/1984	Bare Steel	Fiberglass Reinforced Plastic	Flapper Valve
<b>2243</b>	No			None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		10/05/2017	Automatic Tank Gauging 0.2	ELLD 0.2	No
10,000			EMCO Electronics/EECO 1500		No
02	37	12/05/1984	Bare Steel	Fiberglass Reinforced Plastic	Flapper Valve
<b>2244</b>	No			None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		10/05/2017	Automatic Tank Gauging 0.2	ELLD 0.2	No
10,000			EMCO Electronics/EECO 1500		No
03	37	12/05/1984	Bare Steel	Fiberglass Reinforced Plastic	Flapper Valve
<b>2245</b>	No			None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Diesel		10/05/2017	Automatic Tank Gauging 0.2	ELLD 0.2	No
10,000			EMCO Electronics/EECO 1500		No

**Facility Summary in Flathead County in the City of Kalispell**

**Location:** ZIP TRIP 39  
 305 E Idaho St  
 Kalispell, MT 59901-4134 Flathead

Legacy ID:15-03915

**Facility ID:** 20624  
**Last Inspected On:** 05/25/2021  
**Operating Permit Renewal Date:** 10/01/2024

**Owner Operator Contact:** Dirk Cooper;Hi Noon Petroleum Missoula

**4065420384**

**Operator Contact:** Jim Alford;Pete Nussbaum;Tom Savas

**5095367418**

**Owner/Operator:** CHS Inc Spokane Valley

Andrew Duffie, UST Class B Operator  
 Ian Johnstone, UST Class B Global Operator  
 Jim Alford, UST Class A Operator  
 Jim Alford, UST Class B Global Operator  
 Justin Mace, UST Class B Operator  
 Karina Serrano, UST Class B Global Operator  
 Luci Tuttle, UST Class B Operator  
 Pete Nussbaum, UST Class A Operator  
 Pete Nussbaum, UST Class B Global Operator  
 Tom Savas, UST Class A Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
04	23	10/01/1998	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve;High Level Alarm
<b>1306</b>	No			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring;ELLD 0.2	No
12,000			Gilbarco/EMC Basic		No
05	23	10/01/1998	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve;High Level Alarm
<b>1307</b>	No			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring;ELLD 0.2	No

12,000			Gilbarco/EMC Basic		No
06	23	10/01/1998	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve;High Level Alarm
<b>1308</b>	No		Double-Walled	Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	Continuous Interstitial Monitoring;ELLD 0.2	No
6,000			Gilbarco/EMC Basic		No
07	23	10/01/1998	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve;High Level Alarm
<b>1309</b>	No		Double-Walled	Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel			Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	Continuous Interstitial Monitoring;ELLD 0.2	No
5,000			Gilbarco/EMC Basic		No

**Facility Summary in Flathead County in the City of Kalispell**

**Location:** ZIP TRIP 40  
1420 1st Ave E  
Kalispell, MT 59901 Flathead

Legacy ID:15-02331

**Facility ID:** 20572  
**Last Inspected On:** 09/23/2019  
**Operating Permit Renewal Date:** 03/14/2023

**Owner Operator Contact:** Dirk Cooper;Hi Noon Petroleum Missoula

**4065420384**

**Operator Contact:** Jim Alford;Tom Savas

**5095367418**

**Owner/Operator:** CHS Inc Spokane Valley

Alex Henson, UST Class B Global Operator  
Andrew Duffie, UST Class B Operator  
Jim Alford, UST Class A Operator  
Jim Alford, UST Class B Global Operator  
Justin Mace, UST Class B Operator  
Luci Tuttle, UST Class B Operator  
Tom Savas, UST Class A Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types

Product	Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery	
Capacity	Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act	
01	39	04/30/1982	Bare Steel	Fiberglass Reinforced Plastic	Ball Float Valve
<b>1303</b>	No			Double Walled	Yes
Currently in Use		Electronic Line Leak Detector	Pressurized		Impressed Current
Gasoline	03/30/2017	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring; ELLD 0.1; ELLD 0.2		No
8,000		Gilbarco/EMC Basic			No
02	39	04/30/1982	Bare Steel	Fiberglass Reinforced Plastic	Ball Float Valve
<b>1304</b>	No			Double Walled	Yes
Currently in Use		Electronic Line Leak Detector	Pressurized		Impressed Current
Diesel	03/30/2017	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring; ELLD 0.1; ELLD 0.2		No
8,000		Gilbarco/EMC Basic			No
03	39	04/30/1982	Bare Steel	Fiberglass Reinforced Plastic	Ball Float Valve
<b>1305</b>	No			Double Walled	Yes
Currently in Use		Electronic Line Leak Detector	Pressurized		Impressed Current
Gasoline	03/30/2017	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring; ELLD 0.1; ELLD 0.2		No
8,000		Gilbarco/EMC Basic			No

**Facility Summary in Flathead County in the City of Kalispell**

**Location:** ZIP TRIP 41  
2490 US Hwy 93 N  
Kalispell, MT 59901-2148 Flathead

Legacy ID:15-07432

**Facility ID:** 20730  
**Last Inspected On:** 06/13/2019  
**Operating Permit Renewal Date:** 11/09/2022

**Owner Operator Contact:**

**Operator Contact:** Jim Alford; Sean Hurley

**5095357701; 5095367418**

**Owner/Operator:** CHS Inc Spokane Valley

Andrew Duffie, UST Class B Operator  
Jim Alford, UST Class A Operator  
Jim Alford, UST Class B Global Operator

Justin Mace, UST Class B Operator  
 Luci Tuttle, UST Class B Operator  
 Sean Hurley, UST Class A Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
01	36	04/23/1985	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
<b>382</b>	No			None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		06/29/2015	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	No
10,000		07/11/2016	Veeder Root/TLS-300		No
02	36	04/23/1985	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
<b>383</b>	No			None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		06/29/2015	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	No
10,000		07/11/2016	Veeder Root/TLS-300		No
03	19	06/21/2002	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
<b>4685</b>	No			None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	
Gasoline		06/29/2015	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	No
10,000		07/11/2016	Veeder Root/TLS-300		No

**Facility Summary in Flathead County in the City of Lakeside**

**Location:** ARIES GAS AND GROCERY  
 7254 US Hwy 93  
 Lakeside, MT 59922 Flathead

Legacy ID:15-13487

**Facility ID:** 21062  
**Last Inspected On:** 06/26/2019  
**Operating Permit Renewal Date:** 12/06/2022



Owner Operator Contact: Kary Tonjum;City Service Inc

4067554321;4067554321

Operator Contact: Asham Singh;Janet Heinze;Ramdeep Kaur;Rod Phillips;Steven Heinze

4068440336;4068717278;4068905047;8035225352

Owner/Operator: RKR LLC

Owner/Operator: Steven & Janet Heinze

Asham Singh, UST Class A Operator  
Asham Singh, UST Class B Operator  
Janet Heinze, UST Class A Operator  
Janet Heinze, UST Class B Operator  
Ramdeep Kaur, UST Class A Operator  
Rod Phillips, UST Class A Operator  
Rod Phillips, UST Class B Operator  
Steven Heinze, UST Class A Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
01	27	08/01/1994	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
<b>666</b>	No			None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	No
12,000		03/14/2018	Incon/TS-2000		No
02	27	08/01/1994	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
<b>667</b>	No			None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	No
12,000		03/14/2018	Incon/TS-2000		No

03	27	08/01/1994	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
<b>668</b>	No			None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Non-corrodible
Diesel			Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	No
7,000		03/14/2018	Incon/TS-2000		No
04	27	08/01/1994	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
<b>669</b>	No			None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Non-corrodible
Diesel			Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	No
5,000		03/14/2018	Incon/TS-2000		No

**Facility Summary in Flathead County in the City of Lakeside**

**Location:** ARSR GATR BLDG  
Blacktail Mountain Rd  
Lakeside, MT 59922 Flathead

Legacy ID:15-03618

**Facility ID:** 20613  
**Last Inspected On:** 02/11/2021  
**Operating Permit Renewal Date:** 02/19/2024

**Owner Operator Contact:**

**Operator Contact:** Rob Jodsaas

**Owner/Operator:** Federal Aviation Admin Renton

Rob Jodsaas, UST Class A Operator  
Rob Jodsaas, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
S5	25	09/25/1996	Unknown	Flexible Plastic	
4565	Yes	08/23/2017		Double Walled	Yes
Currently in Use			Auto Dialer	Pressurized	
Diesel			Deferred	Continuous Interstitial Monitoring	No
2,000					No

**Facility Summary in Flathead County in the City of Lakeside**

**Location:** DR VAN KIRKE NELSON  
616 Lutheran Camp Rd  
Lakeside, MT 59922 Flathead

Legacy ID:56-14069

**Facility ID:** 30721  
**Last Inspected On:** 01/23/2021  
**Operating Permit Renewal Date:** 02/19/2024

**Owner Operator Contact:** Helen Nelson

4067555656

**Operator Contact:** Greg Nelson

**Owner/Operator:** Helen Nelson

Greg Nelson, UST Class A Operator  
Greg Nelson, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected

Status	Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types	
Product	Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery	
Capacity	Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act	
S1	19	12/30/2002	Steel Clad	Flexible Plastic	Flapper Valve
<b>4781</b>	No	08/23/2017		Double Walled	Yes
Currently in Use		Auto Dialer	U.S. Suction	Non-corrodible	
Heating Oil		Manual Tank Gauging	Continuous Interstitial Monitoring	No	
800				No	

**Facility Summary in Flathead County in the City of Lakeside**

Location: JOE BLOGZ  
7170 US Hwy 93 S  
Lakeside, MT 59922-9728 Flathead

Legacy ID:15-10513

Facility ID: 20867  
Last Inspected On: 09/26/2018  
Operating Permit Renewal Date: 02/20/2022

Owner Operator Contact: Cruiser LLC

4068443372

Operator Contact:

Owner/Operator: Cruiser LLC

Owner/Operator: FH Properties LLC

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status	Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types	
Product	Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery	
Capacity	Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act	
01	36	03/07/1985	Cathodically Protected Steel	Flexible Plastic	Flapper Valve
<b>3798</b>	No		Lined Interior/Impressed Current	Double Walled	Yes
Currently in Use		Electronic Line Leak Detector	Pressurized	Impressed Current	
Gasoline	05/03/2016	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring;ELLD 0.2	No	
8,000		Gilbarco/EMC Basic		No	

02	36	03/07/1985	Cathodically Protected Steel	Flexible Plastic	Flapper Valve
<b>3799</b>	No		Lined Interior/Impressed Current	Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		05/03/2016	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring;ELLD 0.2	No
8,000			Gilbarco/EMC Basic		No

**Facility Summary in Flathead County in the City of Marion**

**Location:** CABIN CREEK LANDING LLC  
166 Wright Way  
Marion, MT 59925-9874 Flathead

Legacy ID:56-14102

**Facility ID:** 30745  
**Last Inspected On:** 10/22/2019  
**Operating Permit Renewal Date:** 04/04/2023

**Owner Operator Contact:** Cabin Creek Landing LLC Dillon

**Operator Contact:** J. Peter Gross;Russell Olsen

**4062700910;4067520051**

**Owner/Operator:** Cabin Creek Landing LLC Dillon

**Owner/Operator:** Russell Olsen

- J. Peter Gross, UST Class A Operator
- J. Peter Gross, UST Class B Operator
- Russell Olsen, UST Class A Operator
- Russell Olsen, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
01	17	02/09/2004	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
<b>4883</b>	No	03/07/2017		Double Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Non-corrodible
Aviation Gas			Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring;MLLD Line Tightness Testing	No
6,000		12/17/2017	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No

**Facility Summary in Flathead County in the City of Marion**

**Location:** CANI INC  
8205 US Hwy 2 W  
Marion, MT 59925-9740 Flathead

Legacy ID:56-13803

**Facility ID:** 30490  
**Last Inspected On:** 09/13/2019  
**Operating Permit Renewal Date:** 11/06/2022

**Owner Operator Contact:** CANI Inc

**4068542992**

**Operator Contact:** Tonia Gardner

**Owner/Operator:** CANI Inc

**Owner/Operator:** Terrance G Sidener

Tonia Gardner, UST Class A Operator

Tonia Gardner, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
01	24	08/01/1997	Cathodically Protected Steel	Flexible Plastic	Flapper Valve
<b>834</b>	No			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		10/06/2016	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring;ELLD 0.2	No
5,000			EMCO Electronics/EECO 1500		No
02	24	08/01/1997	Cathodically Protected Steel	Flexible Plastic	Flapper Valve
<b>835</b>	No			Double Walled	Yes
Currently in Use		02/20/2015	Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		10/06/2016	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring;ELLD 0.2	No
5,000			EMCO Electronics/EECO 1500		No
03	24	08/01/1997	Cathodically Protected Steel	Flexible Plastic	Flapper Valve
<b>836</b>	No			Double Walled	Yes

Currently in Use	02/20/2015	Electronic Line Leak Detector	Pressurized	Galvanic
Diesel	10/06/2016	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring; ELLD 0.2	No
5,000	02/12/2015	EMCO Electronics/EECO 1500		No

**Facility Summary in Flathead County in the City of Marion**

**Location:** MOOSE CROSSING INC  
8405 US Hwy 2 W  
Marion, MT 59925-9701 Flathead

Legacy ID:15-10015

**Facility ID:** 20822  
**Last Inspected On:** 09/28/2021  
**Operating Permit Renewal Date:** 10/12/2024

**Owner Operator Contact:** Vern Taber Moose Crossing Inc;Vernon Taber **4068542070**

**Operator Contact:** Rebecca Taber;Vernon Taber **4068542070**

**Owner/Operator:** Vern Taber Moose Crossing Inc

**Owner/Operator:** Virginia Guderjahn

Rebecca Taber, UST Class A Operator  
Rebecca Taber, UST Class B Operator  
Vernon Taber, UST Class A Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
<b>Tag #</b>	<b>AST</b>	<b>Sump Tightness</b>	<b>Secondary Option</b>	<b>Secondary Option</b>	<b>Spill Protected</b>
<b>Status</b>		<b>Piping Installed Date</b>	<b>Catastrophic L.D. Type 3.0</b>	<b>Piping Type</b>	<b>CP Met Types</b>
<b>Product</b>		<b>Tank/Pipe CP</b>	<b>Tank Detection</b>	<b>Primary Pipe Detection</b>	<b>Vapor Recovery</b>
<b>Capacity</b>		<b>Line Tightness</b>	<b>ATG Type</b>	<b>Secondary Pipe Detection</b>	<b>Energy Act</b>
S3	24	09/25/1997	Unknown	Flexible Plastic	
<b>1245</b>	Yes	04/19/2016		Double Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Gravity Feed	
Gasoline			Deferred	Continuous Interstitial Monitoring	No
4,000					No
S4	24	09/25/1997	Unknown	Flexible Plastic	
<b>1246</b>	Yes	04/19/2016		Double Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	

Gasoline			Deferred	Continuous Interstitial Monitoring	No
3,000					No
S5	24	09/25/1997	Unknown	Flexible Plastic	
<b>1247</b>	Yes	04/19/2016		Double Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	
Diesel			Deferred	Continuous Interstitial Monitoring	No
1,000					No

**Facility Summary in Flathead County in the City of Olney**

**Location:** GLACIER GOLD LLC  
255 Good Creek Rd  
Olney, MT 59927 Flathead

Legacy ID:15-02973

**Facility ID:** 20589  
**Last Inspected On:** 02/26/2021  
**Operating Permit Renewal Date:**

**Owner Operator Contact:** Glacier Gold LLC

**4068813030**

**Operator Contact:** Joe Warner

**4068813030**

**Owner/Operator:** Glacier Gold LLC

Joe Warner, UST Class A Operator

Joe Warner, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
03	33	03/29/1988	Cathodically Protected Steel	No Piping	Flapper Valve
<b>3583</b>	No			None	Yes
Temporarily Out of Use			Not Required		Galvanic
Gasoline		03/14/2018	Automatic Tank Gauging 0.1;Automatic Tank Gauging 0.2;Vapor Monitoring	Deferred	No
9,000					No

**Facility Summary in Flathead County in the City of Olney**



**Location:** OLNEY STORE  
 105 Olney Loop Rd  
 Olney, MT 59927 Flathead

Legacy ID:56-13849

**Facility ID:** 30531  
**Last Inspected On:** 09/13/2019  
**Operating Permit Renewal Date:** 09/17/2022

**Owner Operator Contact:** Fred Peters

**4068814010**

**Operator Contact:** Fred Peters

**4068814010**

**Owner/Operator:** Fred Peters

Fred Peters, UST Class A Operator

Fred Peters, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
03	23	06/01/1998	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
<b>3504</b>	No			None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Gasoline		06/17/2016	Automatic Tank Gauging 0.2	Deferred	No
1,000			EMCO Electronics/EECO 1500		No
04	23	06/01/1998	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
<b>3505</b>	No			None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Gasoline		06/17/2016	Automatic Tank Gauging 0.2	Deferred	No
500			EMCO Electronics/EECO 1500		No
05	23	06/01/1998	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
<b>3506</b>	No			None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Diesel		06/17/2016	Automatic Tank Gauging 0.2	Deferred	No

### Facility Summary in Flathead County in the City of West Glacier

**Location:** GLACIER HIGHLAND RESORT  
12555 US Hwy 2 E  
West Glacier, MT 59936 Flathead

Legacy ID:15-10685

**Facility ID:** 20877  
**Last Inspected On:** 08/24/2020  
**Operating Permit Renewal Date:** 09/17/2020

**Owner Operator Contact:** Glacier Highland Resort

**4068885427**

**Operator Contact:** Joseph Hoff

**4068885427**

**Owner/Operator:** Glacier Highland Resort

**Owner/Operator:** Joseph B Hoff

Joseph Hoff, UST Class A Operator

Joseph Hoff, UST Class B Global Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
03	23	10/01/1998	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve
<b>3214</b>	No			None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		06/21/2017	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	No
10,000		06/21/2017	EMCO Electronics/EECO 1500		No
04	23	10/01/1998	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve
<b>3215</b>	No			None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		06/21/2017	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	No
6,000		06/21/2017	EMCO Electronics/EECO 1500		No

### Facility Summary in Flathead County in the City of West Glacier

**Location:** GLACIER PARK HDQTRS GAS PUMPS  
 64 Grinnell Dr  
 West Glacier, MT 59936-0128 Flathead

Legacy ID:15-09491

**Facility ID:** 20794  
**Last Inspected On:** 07/20/2020  
**Operating Permit Renewal Date:** 08/02/2023

**Owner Operator Contact:** Glacier National Park

**4067327718**

**Operator Contact:** Franklin Thompson;Lori King;Patrick Glynn

**4068887967**

**Owner/Operator:** Glacier National Park

Franklin Thompson, UST Class A Operator  
 Franklin Thompson, UST Class B Operator  
 Lori King, UST Class A Operator  
 Lori King, UST Class B Operator  
 Patrick Glynn, UST Class A Operator  
 Patrick Glynn, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
06	31	11/01/1990	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
<b>1219</b>	No	06/30/2017		Double Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Diesel		06/22/2017	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring;MLLD Line Tightness Testing	No
5,000			Veeder Root/TLS-300		No
07	31	11/01/1990	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
<b>1220</b>	No	06/30/2017		Double Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		06/22/2017	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring;MLLD Line Tightness Testing	No
12,000			Veeder Root/TLS-300		No

**Facility Summary in Flathead County in the City of West Glacier**

**Location:** MRC GAS STATION  
 200 Going To The Sun Rd  
 West Glacier, MT 59936 Flathead

Legacy ID:15-03288

**Facility ID:** 20602  
**Last Inspected On:** 09/09/2020  
**Operating Permit Renewal Date:** 12/02/2023

**Owner Operator Contact:** Glacier Park Inc

**4068926708**

**Operator Contact:** Cassandra Pyles;Charles Krasselt

**4062708013;4063875082**

**Owner/Operator:** Glacier Park Inc

Cassandra Pyles, UST Class A Operator  
 Cassandra Pyles, UST Class B Operator  
 Charles Krasselt, UST Class A Operator  
 Charles Krasselt, UST Class B Global Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
04	32	10/23/1989	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
<b>2246</b>	No		Double-Walled	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		05/11/2017	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	No
10,000		05/23/2018	Veeder Root/TLS-300		No
05	32	10/23/1989	Cathodically Protected Steel	No Piping	Ball Float Valve
<b>2247</b>	No		Double-Walled	None	Yes
Currently in Use			Not Required	Pressurized	Galvanic
Gasoline		05/11/2017	Automatic Tank Gauging 0.2	Not Listed	No
8,000		05/23/2018	Veeder Root/TLS-300		No
06	32	10/23/1989	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
<b>2248</b>	No		Double-Walled	None	Yes

Currently in Use		Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline	05/11/2017	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	No
6,000	05/23/2018	Veeder Root/TLS-300		No

**Facility Summary in Flathead County in the City of Whitefish**

**Location:** ALPINE VILLAGE MARKET  
721 Wisconsin Ave  
Whitefish, MT 59937-2131 Flathead

Legacy ID:15-10944

**Facility ID:** 20900  
**Last Inspected On:** 12/16/2020  
**Operating Permit Renewal Date:** 12/31/2023

**Owner Operator Contact:** Super Grocer Corp **4068625025**

**Operator Contact:** Alan Reisch;Brent Silcox **4068625025**

**Owner/Operator:** Super Grocer Corp

- Alan Reisch, UST Class A Operator
- Alan Reisch, UST Class B Operator
- Brent Silcox, UST Class A Operator
- Brent Silcox, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act

01	40	04/21/1981	Bare Steel	Fiberglass Reinforced Plastic	Flapper Valve
<b>4692</b>	No			Double Walled	Yes

Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		09/13/2017	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring;ELLD 0.2	No
10,000		09/10/2014	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No

02	40	04/21/1981	Bare Steel	Fiberglass Reinforced Plastic	Flapper Valve
<b>4693</b>	No			Double Walled	Yes

Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		09/13/2017	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring;ELLD 0.2	No

10,000		08/15/2014	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
03	30	10/01/1991	Bare Steel	Fiberglass Reinforced Plastic	Flapper Valve
<b>4694</b>	No			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Diesel		09/13/2017	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring;ELLD 0.2	No
5,000		09/09/2017	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No

**Facility Summary in Flathead County in the City of Whitefish**

**Location:** BIG MOUNTAIN SKI RESORT SHOP  
3910 Big Mountain Rd  
Whitefish, MT 59937 Flathead

Legacy ID:15-05579

**Facility ID:** 20672  
**Last Inspected On:** 10/04/2019  
**Operating Permit Renewal Date:** 10/22/2022

**Owner Operator Contact:** Pat Gould;Winter Sports Inc;Winter Sports Inc

**4068622987;4068622987;4068622987**

**Operator Contact:** Rory Kizer

**Owner/Operator:** Winter Sports Inc

Rory Kizer, UST Class A Operator  
Rory Kizer, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
08	29	09/01/1992	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Positive Shutoff
<b>2295</b>	No			None	Yes
Currently in Use		07/20/2007	Mechanical Line Leak Detector	Pressurized	Non-corrodible
Diesel			Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	No
10,000		10/26/2018	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
09	23	07/14/1998	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve
<b>2296</b>	No			None	Yes

Currently in Use			Not Required	Safe Suction	Non-corrodible
Diesel			Automatic Tank Gauging 0.2	Deferred	No
12,000		11/01/2006	Gilbarco-Veeder Root/Other		No
10	23	07/14/1998	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve
<b>2297</b>	No			None	Yes
Currently in Use			Not Required	Safe Suction	Non-corrodible
Gasoline			Automatic Tank Gauging 0.2	Deferred	No
2,000		11/01/2006	Gilbarco-Veeder Root/Other		No

**Facility Summary in Flathead County in the City of Whitefish**

**Location:** CENEX ZIP TRIP #69  
6585 US Hwy 93 S  
Whitefish, MT 59937 Flathead

Legacy ID:15-04903

**Facility ID:** 20650  
**Last Inspected On:** 07/01/2019  
**Operating Permit Renewal Date:** 12/27/2022

**Owner Operator Contact:** CHS Inc Spokane Valley;James Parker

**4068422078**

**Operator Contact:** Jim Alford;Joe Stenzel;Michael Robinson;Ronald May

**5095367418**

**Owner/Operator:** CHS Inc Spokane Valley

- Andrew Duffie, UST Class B Operator
- Jim Alford, UST Class A Operator
- Jim Alford, UST Class B Global Operator
- Joe Stenzel, UST Class A Operator
- Justin Mace, UST Class B Global Operator
- Justin Mace, UST Class B Operator
- Michael W Robinson, UST Class A Operator
- Ronald May, UST Class A Operator
- Suzan Hughes, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act

07	30	11/04/1991	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
----	----	------------	------------------------------	-------------------------------	------------------

<b>2956</b>	No	11/02/2018		None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		08/24/2015	Automatic Tank Gauging 0.2	ELLD 0.2	No
10,000			Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
08	30	11/04/1991	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
<b>2957</b>	No	11/02/2018		None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		08/24/2015	Automatic Tank Gauging 0.2	ELLD 0.2	No
10,000			Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
09	30	11/04/1991	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
<b>2958</b>	No	11/02/2018		None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		08/24/2015	Automatic Tank Gauging 0.2	ELLD 0.2	No
10,000			Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
10	30	11/04/1991	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
<b>2959</b>	No	11/02/2018		None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		08/24/2015	Automatic Tank Gauging 0.2	ELLD 0.2	No
12,000			Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No

**Facility Summary in Flathead County in the City of Whitefish**

**Location:** MIDWAY MINI MART  
4899 US Hwy 93 S  
Whitefish, MT 59937-8520 Flathead

Legacy ID:15-07766

**Facility ID:** 20742  
**Last Inspected On:** 07/24/2020  
**Operating Permit Renewal Date:** 08/07/2023

**Owner Operator Contact:** Daniel Scheffer

**4068621451**

**Operator Contact:** Daniel Scheffer

**4068621451**



**Owner/Operator:** Daniel Scheffer

Daniel Scheffer, UST Class A Operator

Daniel Scheffer, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
04	25	04/01/1996	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve
<b>3384</b>	No			None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		03/21/2017	Automatic Tank Gauging 0.2	ELLD 0.1;ELLD 0.2	No
12,000			Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
05	25	04/01/1996	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve
<b>3385</b>	No			None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		03/21/2017	Automatic Tank Gauging 0.2	ELLD 0.1;ELLD 0.2	No
7,000			Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
06	25	04/01/1996	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve
<b>3386</b>	No			None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		03/21/2017	Automatic Tank Gauging 0.2	ELLD 0.1;ELLD 0.2	No
5,000			Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No

**Facility Summary in Flathead County in the City of Whitefish**

**Location:** NORTH VALLEY HOSPITAL  
1600 Hospital Way  
Whitefish, MT 59937-2990 Flathead

Legacy ID:60-15034

**Facility ID:** 30816  
**Last Inspected On:** 03/08/2019  
**Operating Permit Renewal Date:** 03/13/2022

**Owner Operator Contact:** North Valley Hospital

**4608633561**

**Operator Contact:** Jim Rickerson;Mark Sarracino

**Owner/Operator:** North Valley Hospital

Jim Rickerson, UST Class A Operator  
Jim Rickerson, UST Class B Operator  
Mark Sarracino, UST Class A Operator  
Mark Sarracino, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
S1	14	01/17/2007	Aboveground Tank	Flexible Plastic	
5123	Yes	09/14/2018		Double Walled	Yes
Currently in Use			Auto Dialer	Pressurized	
Heating Oil			Deferred	Continuous Interstitial Monitoring	No
4,000					No

**Facility Summary in Flathead County in the City of Whitefish**

**Location:** SAFEWAY FUEL STATION #2106  
110 W 13th St  
Whitefish, MT 59937 Flathead

Legacy ID:60-15151

**Facility ID:** 30892  
**Last Inspected On:** 12/16/2019  
**Operating Permit Renewal Date:** 12/28/2022

**Owner Operator Contact:**

**Operator Contact:** Aaron Nelson;Lynn Pehrson;Rachel Jones

**2083953269;4252016301**

**Owner/Operator:** Safeway #2106

A Beagle, UST Class B Global Operator  
Aaron Nelson, UST Class A Operator  
Allen Long, UST Class B Global Operator  
Debbie Dull, UST Class B Global Operator  
Lynn Pehrson, UST Class A Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
01	11	04/28/2010	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm;Positive Shutoff
<b>5233</b>	No		Double-Walled	Double Walled	Yes
Currently in Use		04/08/2010	Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	Continuous Interstitial Monitoring;ELLD 0.2	No
20,000			Gilbarco-Veeder Root/TLS- 350;Gilbarco-Veeder Root/TLS- 350/Gilbarco EMC		Yes
02	11	04/28/2010	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm;Positive Shutoff
<b>5234</b>	No		Double-Walled	Double Walled	Yes
Currently in Use		04/08/2010	Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	Continuous Interstitial Monitoring;ELLD 0.2	No
10,000			Gilbarco-Veeder Root/TLS- 350;Gilbarco-Veeder Root/TLS- 350/Gilbarco EMC		Yes
03	11	04/28/2010	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm;Positive Shutoff
<b>5235</b>	No		Double-Walled	Double Walled	Yes
Currently in Use		04/08/2010	Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel			Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	Continuous Interstitial Monitoring;ELLD 0.2	No
10,000			Gilbarco-Veeder Root/TLS- 350;Gilbarco-Veeder Root/TLS- 350/Gilbarco EMC		Yes

**Facility Summary in Flathead County in the City of Whitefish**

**Location:** TOWN PUMP INC WHITEFISH 2  
6600 US Hwy 93 S  
Whitefish, MT 59937 Flathead

Legacy ID:15-10105

**Facility ID:** 20827  
**Last Inspected On:** 09/13/2021  
**Operating Permit Renewal Date:** 09/22/2024

**Owner Operator Contact:** Don Edmisten;Town Pump Inc Troy PTRCB 1667 **4064976948**

**Operator Contact:** Trent Biggers

**Owner/Operator:** Whitefish 1 Town Pump LLC

Trent Biggers, UST Class A Operator  
Trent Biggers, UST Class B Global Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
01	31	01/17/1990	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve
<b>2428</b>	No			None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	
Diesel			Approved Remote Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Statistical Inventory Reconciliation	No
12,000			Gilbarco-Veeder Root/TLS-350		No
03	31	01/17/1990	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve
<b>2430</b>	No			None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	
Gasoline			Approved Remote Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Statistical Inventory Reconciliation	No
12,000			Gilbarco-Veeder Root/TLS-350		No
04	31	01/17/1990	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve
<b>2431</b>	No			None	Yes

Currently in Use			Electronic Line Leak Detector	Pressurized	
Gasoline			Approved Remote Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Statistical Inventory Reconciliation	No
12,000			Gilbarco-Veeder Root/TLS-350		No
02	31	01/17/1990	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve
<b>4306</b>	No			None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	
Gasoline			Approved Remote Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Statistical Inventory Reconciliation	No
12,000			Gilbarco-Veeder Root/TLS-350		No
05	17	10/01/2004	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
<b>4941</b>	No		Double-Walled	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	
Gasoline			Approved Remote Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Statistical Inventory Reconciliation	No
20,000			Gilbarco-Veeder Root/TLS-350		No

**Facility Summary in Flathead County in the City of Whitefish**

**Location:** WESTSIDE EXXON  
145 2nd St W  
Whitefish, MT 59937 Flathead

Legacy ID:15-00112

**Facility ID:** 20516  
**Last Inspected On:** 03/17/2021  
**Operating Permit Renewal Date:** 09/06/2024

**Owner Operator Contact:** Barnes Enterprises Inc;Don Gray

**4068624535**

**Operator Contact:** Franklin Barnes

**4068624535**

**Owner/Operator:** Barnes Enterprises Inc

**Owner/Operator:** Frank D Barnes

Franklin Barnes, UST Class A Operator  
Franklin Barnes, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected

Status	Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types	
Product	Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery	
Capacity	Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act	
03	25	11/01/1996	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve
<b>3421</b>	No	05/07/2018	Double-Walled	Double Walled	Yes
Currently in Use		05/08/2018	Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Continuous Interstitial Monitoring	Continuous Interstitial Monitoring; ELLD 0.2	No
12,000			Gilbarco-Veeder Root/TLS-300		No
04	25	11/01/1996	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve
<b>3422</b>	No	05/07/2018	Double-Walled	Double Walled	Yes
Currently in Use		05/08/2018	Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Continuous Interstitial Monitoring	Continuous Interstitial Monitoring; ELLD 0.2	No
12,000			Gilbarco-Veeder Root/TLS-300		No

**Facility Summary in Flathead County in the City of Whitefish**

**Location:** WHITEFISH LAKE LODGE  
1380 Wisconsin Ave  
Whitefish, MT 59937-3338 Flathead

Legacy ID:15-12719

**Facility ID:** 21003  
**Last Inspected On:** 05/06/2020  
**Operating Permit Renewal Date:** 09/29/2023

**Owner Operator Contact:** Whitefish Lake Lodge

**Operator Contact:** Chris Gulick; Dave Wood; Heath Howell

**4068634000;4068634049;6154263939**

**Owner/Operator:** Whitefish Lake Lodge

- Chris Gulick, UST Class A Operator
- Chris Gulick, UST Class B Operator
- Dave Wood, UST Class A Operator
- Dave Wood, UST Class B Operator
- Heath Howell, UST Class A Operator
- Heath Howell, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status	Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types	

<b>Product</b>		<b>Tank/Pipe CP</b>	<b>Tank Detection</b>	<b>Primary Pipe Detection</b>	<b>Vapor Recovery</b>
<b>Capacity</b>		<b>Line Tightness</b>	<b>ATG Type</b>	<b>Secondary Pipe Detection</b>	<b>Energy Act</b>
02	29	04/01/1992	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
<b>4898</b>	No	08/22/2017	Double-Walled	Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Continuous Interstitial Monitoring	Continuous Interstitial Monitoring; ELLD 0.2	No
4,000		07/22/2014	Gilbarco-Veeder Root/TLS-350		No