

Facility Summary in Flathead County in the City of Bigfork

Location: BIGFORK OUTDOOR RENTALS INC
110 Swan River Rd
Bigfork, MT 59911-6329 Flathead

System Facility ID:15-07361

Facility Code: 20728
Last Inspected On: 01/04/2024
Operating Permit Renewal Date: 01/03/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Bigfork Outdoor Rentals Inc;Dalen Whalen (406) 396-8185 dwhalen9@gmail.com

Operator Contact: Dale Whalen (406) 396-8185 dalewhalen@gmail.com

Owner/Operator: Bigfork Outdoor Rentals Inc (406) 396-8185 dwhalen9@gmail.com

Owner/Operator: Dalen Whalen (406) 396-8185 dwhalen9@gmail.com

Dale Whalen, UST Class A Operator dalewhalen@gmail.com
Dale Whalen, UST Class B Global Operator dalewhalen@gmail.com
Dale Whalen, UST Class B Operator dalewhalen@gmail.com

Tank Code	06	Tank Age	31	Tank Installed Date	11/01/1995	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	3498	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	Single Walled	AST	No
Tank Status	Temporarily Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	01/03/2024	Primary Tank Leak Detection	Automatic Tank Gauging 0.1;Automatic Tank Gauging 0.2	Primary Pipe Detection		Vapor Recovery	No
Capacity	6000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type	EMCO Electronics/EECO 1500				
Tank Code	07	Tank Age	31	Tank Installed Date	11/01/1995	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	3499	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Temporarily Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	01/03/2024	Primary Tank Leak Detection	Automatic Tank Gauging 0.1;Automatic Tank Gauging 0.2	Primary Pipe Detection		Vapor Recovery	No

Capacity	3000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type	EMCO Electronics/EECO 1500				
Tank Code	08	Tank Age	31	Tank Installed Date	11/01/1995	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	3500	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Temporarily Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	01/03/2024	Primary Tank Leak Detection	Automatic Tank Gauging 0.1; Automatic Tank Gauging 0.2	Primary Pipe Detection		Vapor Recovery	No
Capacity	3000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type	EMCO Electronics/EECO 1500				

Facility Summary in Flathead County in the City of Bigfork

Location: BIGFORK STAGE STOP INC
8263 MT Hwy 35
Bigfork, MT 59911-3518 Flathead

System Facility ID:56-13885

Facility Code: 30560
Last Inspected On: 09/17/2025
Operating Permit Renewal Date: 12/02/2028

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Bigfork Stage Stop Inc (406) 837-5858

Operator Contact: Vicky Miller;Bigfork Stage Stop Inc (406) 837-1551;(406) 837-5858 vicky@bigfork-stagestop.com

Owner/Operator: Bigfork Stage Stop Inc (406) 837-5858

Vicky Miller, UST Class A Operator

vicky@bigfork-stagestop.com

Vicky Miller, UST Class B Global Operator

vicky@bigfork-stagestop.com

Tank Code	01	Tank Age	28	Tank Installed Date	10/01/1998	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	3531	Spill Test Date	09/17/2025	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	12000	ATG Test Date	09/17/2025	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	09/17/2025			ATG Type	Gilbarco/EMC Basic				
Tank Code	02	Tank Age	28	Tank Installed Date	10/01/1998	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	3532	Spill Test Date	09/17/2025	Piping Installed Date	11/24/2008	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	12000	ATG Test Date	09/17/2025	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	09/17/2025			ATG Type	Gilbarco/EMC Basic				
Tank Code	03	Tank Age	28	Tank Installed Date	10/01/1998	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve

Tag Number	3533	Spill Test Date	09/17/2025	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	5000	ATG Test Date	09/17/2025	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	09/17/2025			ATG Type	Gilbarco/EMC Basic				

Facility Summary in Flathead County in the City of Bigfork

Location: CALUMET CARDLOCK
8111 MT Hwy 35
Bigfork, MT 59911-3588 Flathead

System Facility ID:15-09801

Facility Code: 20806
Last Inspected On: 01/27/2025
Operating Permit Renewal Date: 03/18/2028

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Lakehills Family Center of Bigfork, Inc (406) 827-5010 bhf_marcus@centurytel.net

Operator Contact: Marcus Balgos;Bigfork Properties LLC (406) 837-5010 bhf_marcus@centurytel.net

Owner/Operator: Lakehills Family Center of Bigfork, Inc (406) 827-5010 bhf_marcus@centurytel.net

Marcus Balgos, UST Class A Operator
Marcus Balgos, UST Class B Operator

bhf_marcus@centurytel.net
bhf_marcus@centurytel.net
bhf_marcus@centurytel.net

Tank Code	01	Tank Age	45	Tank Installed Date	05/01/1981	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	481	Spill Test Date	10/08/2024	Piping Installed Date	02/02/2022	Tank Construction	Lined Interior/Impressed Current	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	10/08/2024	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection		Vapor Recovery	No
Capacity	8000	ATG Test Date	12/22/2025	Line Tightness Test Date	02/02/2022	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	10/08/2024			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	02	Tank Age	45	Tank Installed Date	05/01/1981	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	482	Spill Test Date	11/14/2024	Piping Installed Date	02/02/2022	Tank Construction	Lined Interior/Impressed Current	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Impressed Current
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	10/08/2024	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection		Vapor Recovery	No
Capacity	12000	ATG Test Date	12/22/2025	Line Tightness Test Date	02/02/2022	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	10/08/2024			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Tank Code	03	Tank Age	33	Tank Installed Date	07/01/1993	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	483	Spill Test Date	10/08/2024	Piping Installed Date	02/02/2022	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	10/08/2024	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection		Vapor Recovery	No
Capacity	8000	ATG Test Date	12/22/2025	Line Tightness Test Date	02/02/2022	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	10/08/2024			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	04	Tank Age	31	Tank Installed Date	04/01/1995	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	484	Spill Test Date	11/14/2024	Piping Installed Date	02/02/2022	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	10/08/2024	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection		Vapor Recovery	No
Capacity	6000	ATG Test Date	12/22/2025	Line Tightness Test Date	02/02/2022	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	11/14/2024			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	05	Tank Age	31	Tank Installed Date	04/01/1995	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	485	Spill Test Date	10/08/2024	Piping Installed Date	02/02/2022	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	10/08/2024	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection		Vapor Recovery	No
Capacity	4000	ATG Test Date	12/22/2025	Line Tightness Test Date	02/02/2022	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	10/08/2024			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Flathead County in the City of Bigfork

Location: EAGLE BEND YACHT HARBOR
371 Eagle Bend Dr
Bigfork, MT 59911-6210 Flathead

System Facility ID:15-13152

Facility Code: 21034
Last Inspected On: 05/28/2025
Operating Permit Renewal Date: 06/01/2028

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Eagle Bend Yacht Harbor Boat Slip Owners Association (406) 837-4536

Operator Contact: Dave Roberts (406) 253-2840 droberts@westernmountains.com

Owner/Operator: Eagle Bend Yacht Harbor Boat Slip Owners Association (406) 837-4536

Dave Roberts, UST Class A Operator
Dave Roberts, UST Class B Operator

droberts@westernmountains.com
droberts@westernmountains.com

Tank Code	01	Tank Age	33	Tank Installed Date	07/01/1993	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Steel with plastic coating	Overfill Types	High Level Alarm
Tag Number	4013	Spill Test Date	05/28/2025	Piping Installed Date	05/28/2025	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	05/28/2025	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	5000	ATG Test Date	05/28/2025	Line Tightness Test Date	08/02/2010	Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	Yes
		Overfill Test Date	05/28/2025			ATG Type	Veeder Root/TLS-450PLUS				
Tank Code	02	Tank Age	33	Tank Installed Date	07/01/1993	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Steel with plastic coating	Overfill Types	High Level Alarm
Tag Number	4014	Spill Test Date	05/28/2025	Piping Installed Date	05/28/2025	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	05/28/2025	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	1000	ATG Test Date	05/28/2025	Line Tightness Test Date	08/02/2010	Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	Yes
		Overfill Test Date	05/28/2025			ATG Type	Veeder Root/TLS-450PLUS				

Facility Summary in Flathead County in the City of Bigfork

Location: FERNDALE MARKET
1845 MT Hwy 209
Bigfork, MT 59911-6540 Flathead

System Facility ID:15-07199

Facility Code: 20719
Last Inspected On: 04/27/2023
Operating Permit Renewal Date: 08/08/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Griggs Ferndale LLC (406) 837-5597 invoices@ferndalemarket.net

Operator Contact: Brian Truckey;Griggs Ferndale LLC;Robert Dileo;Ferndale Market (406) 407-0743;(406) 837-5597 btruckey@gmail.com;invoices@ferndalemarket.net;dileorobert@gmail.com

Owner/Operator: Griggs Ferndale LLC (406) 837-5597 invoices@ferndalemarket.net
 Brian Truckey, UST Class A Operator invoices@ferndalemarket.net
 Brian Truckey, UST Class B Operator invoices@ferndalemarket.net
 Robert Dileo, UST Class A Operator dileorobert@gmail.com
 Robert Dileo, UST Class B Operator dileorobert@gmail.com

Tank Code	01	Tank Age	50	Tank Installed Date	04/28/1976	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	3254	Spill Test Date	04/27/2023	Piping Installed Date		Tank Construction	Lined Interior/Impressed Current	Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	04/27/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	4000	ATG Test Date	04/27/2023	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	04/27/2023			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	02	Tank Age	49	Tank Installed Date	04/28/1977	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	3255	Spill Test Date	04/27/2023	Piping Installed Date		Tank Construction	Lined Interior/Impressed Current	Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	04/27/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	8000	ATG Test Date	04/27/2023	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No

		Overfill Test Date	04/27/2023			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	03	Tank Age	33	Tank Installed Date	06/01/1993	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	3256	Spill Test Date	09/12/2023	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	04/27/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	6000	ATG Test Date	04/27/2023	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	04/27/2023			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	04	Tank Age	33	Tank Installed Date	06/01/1993	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	3257	Spill Test Date	09/12/2023	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	04/27/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	4000	ATG Test Date	04/27/2023	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	04/27/2023			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Flathead County in the City of Bigfork

Location: MARINA CAY RESORT
180 Vista Lane
Bigfork, MT 59911-6162 Flathead

System Facility ID:15-03002

Facility Code: 20591
Last Inspected On: 11/21/2025
Operating Permit Renewal Date: 10/14/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Ken Wheeler;Marina Cay Resort (406) 837-5861 k.wheeler@frontlineag.com>

Operator Contact: David Roberts (406) 358-2422 droberts@westernmountains.com

Owner/Operator: Ken Wheeler,Marina Cay Resort (406) 837-5861 k.wheeler@frontlineag.com>

David Roberts, UST Class A Operator
David Roberts, UST Class B Operator

droberts@westernmountains.com
droberts@westernmountains.com

Tank Code	02	Tank Age	27	Tank Installed Date	05/05/1999	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	4067	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Temporarily Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Continuous Interstitial Monitoring	Piping Type	Pressurized	CP Met Types	
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	4000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					
Tank Code	03	Tank Age	19	Tank Installed Date	07/25/2007	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	5110	Spill Test Date	05/06/2025	Piping Installed Date	02/05/2006	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	05/30/2025	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.1	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	4000	ATG Test Date	05/30/2025	Line Tightness Test Date	10/21/2022	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	05/06/2025			ATG Type	Gilbarco-Veeder Root/TLS-450PLUS				

Facility Summary in Flathead County in the City of Bigfork

Location: MEADOWLARK ENTERPRISES LLC
20221 MT Hwy 35
Bigfork, MT 59911-7254 Flathead

System Facility ID:56-14137

Facility Code: 30773
Last Inspected On: 03/23/2026
Operating Permit Renewal Date: 07/02/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Meadowlark Enterprises LLC (415) 225-2249 michael@baumer.us

Operator Contact: Michael Baumer;Stephen Baumer;Meadowlark Enterprises LLC (415) 225-2249 michael@baumer.us;stephen@baumer.us;michael@baumer.us

Owner/Operator: Meadowlark Enterprises LLC (415) 225-2249 michael@baumer.us

Michael Baumer, UST Class A Operator michael@baumer.us
 Michael Baumer, UST Class B Operator michael@baumer.us
 Stephen Baumer, UST Class A Operator michael@baumer.us
 Stephen Baumer, UST Class B Operator michael@baumer.us

Tank Code	01	Tank Age	21	Tank Installed Date	03/21/2005	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	5024	Spill Test Date	09/15/2021	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	03/11/2011	Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	1000	ATG Test Date	04/19/2023	Line Tightness Test Date	06/30/2020	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	04/19/2023			ATG Type	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Flathead County in the City of Bigfork

Location: MONTANA RANCH LLC
1463 Hwy 83
Bigfork, MT 59911 Flathead

System Facility ID:60-15198

Facility Code: 30919
Last Inspected On: 02/05/2024
Operating Permit Renewal Date: 03/23/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Montana Ranch LLC Bigfork (406) 837-5109 mattc@sabey.com

Operator Contact: Matt Cottle (406) 253-8403 mattc@sabey.com

Owner/Operator: Montana Ranch LLC Bigfork (406) 837-5109 mattc@sabey.com
 Matt Cottle, UST Class A Operator mattc@sabey.com
 Matt Cottle, UST Class B Operator mattc@sabey.com

Tank Code	01	Tank Age	15	Tank Installed Date	08/29/2011	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Steel	Overfill Types	Flapper Valve
Tag Number	5327	Spill Test Date	02/05/2024	Piping Installed Date	08/29/2011	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection		Vapor Recovery	No
Capacity	2500	ATG Test Date	02/05/2024	Line Tightness Test Date	10/06/2011	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	Yes
		Overfill Test Date	02/05/2024			ATG Type	Gilbarco-Veeder Root/EMC Basic				
Tank Code	02	Tank Age	15	Tank Installed Date	08/29/2011	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Steel	Overfill Types	Flapper Valve
Tag Number	5328	Spill Test Date	02/05/2024	Piping Installed Date	08/29/2011	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection		Vapor Recovery	No
Capacity	2500	ATG Test Date	02/05/2024	Line Tightness Test Date	10/06/2011	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	Yes
		Overfill Test Date	02/05/2024			ATG Type	Gilbarco-Veeder Root/EMC Basic				

Facility Summary in Flathead County in the City of Bigfork

Location: O'CONNELLS QWICK STOP
21385 MT Hwy 83
Bigfork, MT 59911-7811 Flathead

System Facility ID:24-05644

Facility Code: 22977
Last Inspected On: 10/08/2023
Operating Permit Renewal Date: 11/26/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: PH and J Enterprises LLC;Preston O'Connell (406) 886-2300 froggitha@gmail.com

Operator Contact: Keith Broere (406) 541-3246 kbroere@aetmt.com

Owner/Operator: PH and J Enterprises LLC (406) 886-2300 froggitha@gmail.com

Owner/Operator: Preston O'Connell (406) 886-2300 froggitha@gmail.com

Keith Broere, UST Class A Operator kbroere@aetmt.com

Keith Broere, UST Class B Operator kbroere@aetmt.com

Tank Code	04	Tank Age	40	Tank Installed Date	05/07/1986	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	3325	Spill Test Date	10/06/2023	Piping Installed Date		Tank Construction		Piping Construction	Single Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	10/16/2025	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	10/06/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	8000	ATG Test Date	10/16/2025	Line Tightness Test Date	10/06/2023	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	10/16/2025			ATG Type	Incon/TS-1000				
Tank Code	05	Tank Age	40	Tank Installed Date	05/07/1986	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	3326	Spill Test Date	10/06/2023	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date	10/16/2025	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	10/06/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	8000	ATG Test Date	10/16/2025	Line Tightness Test Date	10/06/2023	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	10/16/2025			ATG Type	Incon/TS-1000				
Tank Code	06	Tank Age	30	Tank Installed Date	07/01/1996	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve

Tag Number	3327	Spill Test Date	10/06/2023	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date	10/16/2025	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	10/06/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	6000	ATG Test Date	10/16/2025	Line Tightness Test Date	10/06/2023	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	10/16/2025			ATG Type	Incon/TS-1000				
Tank Code	07	Tank Age	30	Tank Installed Date	07/01/1996	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	3328	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Temporarily Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	10/06/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.1;Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	6000	ATG Test Date		Line Tightness Test Date	03/08/2011	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type	Incon/TS-1000				

Facility Summary in Flathead County in the City of Bigfork

Location: PAPAS MARKET
14535 MT Hwy 35
Bigfork, MT 59911 Flathead

System Facility ID:24-06085

Facility Code: 22990
Last Inspected On: 02/19/2026
Operating Permit Renewal Date: 03/28/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Patrick Gembala;GEMBALA LLC (406) 885-6944;(406) 837-4884 papasmarket.gembala@gmail.com;papasmarket.gembala@gmail.com

Operator Contact: Patrick Gembala;GEMBALA LLC;Shawn Gembala (406) 837-4884;(406) 885-6944;(406) 837-4884 papasmarket.gembala@gmail.com;papasmarket.gembala@gmail.com;papasmarket.gembala@gmail.com

Owner/Operator: Patrick Gembala,GEMBALA LLC (406) 885-6944 papasmarket.gembala@gmail.com
Patrick Gembala, UST Class A Operator papasmarket.gembala@gmail.com
Patrick Gembala, UST Class B Operator papasmarket.gembala@gmail.com
Shawn Gembala, UST Class A Operator papasmarket.gembala@gmail.com
Shawn Gembala, UST Class B Operator papasmarket.gembala@gmail.com

Tank Code	01	Tank Age	42	Tank Installed Date	01/30/1984	Tank Material	Bare Steel	Piping Material	Steel	Overfill Types	Flapper Valve
Tag Number	1279	Spill Test Date	09/06/2023	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date	09/06/2023	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	09/06/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	8000	ATG Test Date	11/30/2023	Line Tightness Test Date	09/06/2023	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	09/06/2023			ATG Type	Gilbarco-Veeder Root/TLS-300				
Tank Code	02	Tank Age	42	Tank Installed Date	01/30/1984	Tank Material	Bare Steel	Piping Material	Steel	Overfill Types	Flapper Valve
Tag Number	1280	Spill Test Date	09/06/2023	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date	09/06/2023	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	09/06/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	6000	ATG Test Date	11/30/2023	Line Tightness Test Date	09/06/2023	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	09/06/2023			ATG Type	Gilbarco-Veeder Root/TLS-300				

Tank Code	03	Tank Age	32	Tank Installed Date	05/01/1994	Tank Material	Cathodically Protected Steel	Piping Material	Steel	Overfill Types	Flapper Valve
Tag Number	1281	Spill Test Date	09/06/2023	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date	09/06/2023	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Impressed Current
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	09/06/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection		Vapor Recovery	No
Capacity	4000	ATG Test Date	11/30/2023	Line Tightness Test Date	05/13/2016	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	09/06/2023			ATG Type	Gilbarco-Veeder Root/TLS-300				

Facility Summary in Flathead County in the City of Bigfork

Location: YOUR TURN CONVENIENCE STOP
7505 MT Hwy 35
Bigfork, MT 59911-6215 Flathead

System Facility ID:15-02482

Facility Code: 20582
Last Inspected On: 04/01/2026
Operating Permit Renewal Date: 08/08/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: White Enterprises (406) 837-6170 yourturnmercantile@hotmail.com

Operator Contact: Charity Neal;Your Turn Convenience Stop (406) 837-6170 ytm1993@yahoo.com

Owner/Operator: White Enterprises (406) 837-6170 yourturnmercantile@hotmail.com

Charity Neal, UST Class A Operator ytm1993@yahoo.com
Charity Neal, UST Class B Operator ytm1993@yahoo.com

Tank Code	06	Tank Age	29	Tank Installed Date	01/10/1997	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	3185	Spill Test Date	12/21/2021	Piping Installed Date	07/25/2013	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	12000	ATG Test Date	05/02/2023	Line Tightness Test Date	02/03/2011	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	01/05/2022			ATG Type	Incon/TS-550 EVO				
Tank Code	07	Tank Age	29	Tank Installed Date	01/10/1997	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	3186	Spill Test Date	05/03/2023	Piping Installed Date	07/25/2013	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	05/02/2023	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	12000	ATG Test Date		Line Tightness Test Date	02/03/2011	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	05/03/2023			ATG Type	Incon/TS-550 EVO				
Tank Code	08	Tank Age	29	Tank Installed Date	01/10/1997	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve

Tag Number	3187	Spill Test Date	05/03/2023	Piping Installed Date	07/25/2013	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	12000	ATG Test Date	05/03/2023	Line Tightness Test Date	02/03/2011	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	05/03/2023			ATG Type	Incon/TS-550 EVO				
Tank Code	09	Tank Age	29	Tank Installed Date	11/01/1997	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	3188	Spill Test Date	12/22/2021	Piping Installed Date	07/25/2013	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	8000	ATG Test Date	05/02/2023	Line Tightness Test Date	02/03/2011	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	01/05/2022			ATG Type	Incon/TS-550 EVO				

Facility Summary in Flathead County in the City of Columbia Falls

Location: CSV CARDLOCK NORTH
195 Truck Route Rd
Columbia Falls, MT 59912 Flathead

System Facility ID:15-12972

Facility Code: 21018
Last Inspected On: 08/22/2023
Operating Permit Renewal Date: 10/02/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: City Service Valcon LLC

(406) 294-0865

tamara.noble@cityservicevalcon.com

Operator Contact: Kary Tonjum

Owner/Operator: City Service Valcon LLC

(406) 294-0865

tamara.noble@cityservicevalcon.com

Kary Tonjum, UST Class A Operator

Kary Tonjum, UST Class B Global Operator

Tank Code	01	Tank Age	34	Tank Installed Date	12/15/1992	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	4404	Spill Test Date	05/03/2023	Piping Installed Date	10/02/2014	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	05/03/2023	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date	05/03/2023	Tank/Piping CP Test Date	05/03/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	15000	ATG Test Date	05/03/2023	Line Tightness Test Date	09/29/2014	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	05/03/2023			ATG Type	Veeder Root/TLS-450				
Tank Code	04	Tank Age	34	Tank Installed Date	11/15/1992	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	4405	Spill Test Date	11/11/2021	Piping Installed Date	10/02/2014	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	04/19/2017	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	5000	ATG Test Date		Line Tightness Test Date	09/29/2014	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	11/29/2021			ATG Type	Veeder Root/TLS-450				
Tank Code	05	Tank Age	34	Tank Installed Date	11/15/1992	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve

Tag Number	4406	Spill Test Date	04/07/2021	Piping Installed Date	10/02/2014	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	05/28/2020	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	5000	ATG Test Date		Line Tightness Test Date	09/29/2014	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date				ATG Type	Veeder Root/TLS-450				
Tank Code	03	Tank Age	34	Tank Installed Date	11/15/1992	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	4407	Spill Test Date	04/07/2021	Piping Installed Date	10/02/2014	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	05/28/2020	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	8000	ATG Test Date		Line Tightness Test Date	09/29/2014	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date				ATG Type	Veeder Root/TLS-450				
Tank Code	02	Tank Age	34	Tank Installed Date	11/15/1992	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	4408	Spill Test Date	05/03/2023	Piping Installed Date	10/02/2014	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	05/03/2023	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date	05/03/2023	Tank/Piping CP Test Date	05/03/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	10000	ATG Test Date	05/03/2023	Line Tightness Test Date	09/29/2014	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	05/03/2023			ATG Type	Veeder Root/TLS-450				

Facility Summary in Flathead County in the City of Columbia Falls

Location: HI-STAR PROPERTIES LLC
7356 US Hwy 2 E
Columbia Falls, MT 59912-9107 Flathead

System Facility ID:15-11333

Facility Code: 20934
Last Inspected On: 08/01/2025
Operating Permit Renewal Date: 08/02/2028

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Hi-Star Properties LLC (509) 994-6599 histarms3@yahoo.com

Operator Contact: Wade Lindsay (406) 890-0968 wade.w.lindsay@gmail.com

Owner/Operator: Hi-Star Properties LLC (509) 994-6599 histarms3@yahoo.com

Wade Lindsay, UST Class A Operator

wade.w.lindsay@gmail.com

Wade Lindsay, UST Class B Global Operator

wade.w.lindsay@gmail.com

Tank Code	01	Tank Age	36	Tank Installed Date	01/01/1990	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve;High Level Alarm
Tag Number	686	Spill Test Date	03/21/2023	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date	07/08/2025	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	08/06/2025	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	10000	ATG Test Date	07/08/2025	Line Tightness Test Date	07/08/2025	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	07/08/2025			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	02	Tank Age	36	Tank Installed Date	01/01/1990	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve;High Level Alarm
Tag Number	687	Spill Test Date	03/21/2023	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date	07/08/2025	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	08/06/2025	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	8000	ATG Test Date	07/08/2025	Line Tightness Test Date	07/08/2025	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	07/08/2025			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Tank Code	03	Tank Age	36	Tank Installed Date	01/01/1990	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve;High Level Alarm
Tag Number	688	Spill Test Date	03/21/2023	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date	07/08/2025	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	08/06/2025	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	6000	ATG Test Date	07/08/2025	Line Tightness Test Date	07/08/2025	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	07/08/2025			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	04	Tank Age	36	Tank Installed Date	01/01/1990	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve;High Level Alarm
Tag Number	689	Spill Test Date	03/21/2023	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date	07/08/2025	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	08/06/2025	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	10000	ATG Test Date	07/08/2025	Line Tightness Test Date	07/08/2025	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	07/08/2025			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Flathead County in the City of Columbia Falls

Location: JUNCTION GAS
7322 US Hwy 2 E
Columbia Falls, MT 59912-9107 Flathead

System Facility ID:15-02820

Facility Code: 20587
Last Inspected On: 07/15/2025
Operating Permit Renewal Date: 12/24/2028

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Kalispell Properties LLC (509) 994-6599 histarms01@yahoo.com

Operator Contact: Shishay Hadgu;KABIEL LLC DBA JUNCTION GAS (404) 242-9376;(404) 242-9376 shishayhadgu55@gmail.com;shishayhadgu55@gmail.com

Owner/Operator: Kalispell Properties LLC (509) 994-6599 histarms01@yahoo.com

Shishay Hadgu, UST Class A Operator
Shishay Hadgu, UST Class B Operator

shishayhadgu55@gmail.com
shishayhadgu55@gmail.com

Tank Code	01	Tank Age	49	Tank Installed Date	07/01/1977	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	496	Spill Test Date	07/15/2025	Piping Installed Date		Tank Construction	Lined Interior/Impressed Current	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	07/15/2025	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	10000	ATG Test Date	07/14/2025	Line Tightness Test Date	06/29/2010	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	07/15/2025			ATG Type	Gilbarco/EMC Basic				
Tank Code	02	Tank Age	49	Tank Installed Date	07/01/1977	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	497	Spill Test Date	07/15/2025	Piping Installed Date		Tank Construction	Lined Interior/Impressed Current	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	07/15/2025	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	10000	ATG Test Date	07/14/2025	Line Tightness Test Date	12/06/2016	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	07/15/2025			ATG Type	Gilbarco/EMC Basic				

Tank Code	03	Tank Age	49	Tank Installed Date	07/01/1977	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	498	Spill Test Date	07/15/2025	Piping Installed Date		Tank Construction	Lined Interior/Impressed Current	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Diesel, Dyed	PLLD Test Date		Tank/Piping CP Test Date	07/15/2025	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	6000	ATG Test Date	07/14/2025	Line Tightness Test Date	06/29/2010	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	07/15/2025			ATG Type	Gilbarco/EMC Basic				
Tank Code	04	Tank Age	38	Tank Installed Date	11/17/1988	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	499	Spill Test Date	07/15/2025	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	07/15/2025	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	6000	ATG Test Date	07/14/2025	Line Tightness Test Date	12/06/2016	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	07/15/2025			ATG Type	Gilbarco/EMC Basic				

Facility Summary in Flathead County in the City of Columbia Falls

Location: MIKES OF COLUMBIA FALLS
1645 9th St W
Columbia Falls, MT 59912 Flathead

System Facility ID:15-06839

Facility Code: 20716
Last Inspected On: 04/07/2026
Operating Permit Renewal Date: 07/31/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Dan Elder;KMR LLC;KMR LLC (253) 985-5039;(406) 892-2078;(406) 892-2078 dane@mikesconoco.com;dane@mikesconoco.com;dane@mikesconoco.com

Operator Contact: Ronda Heil;Shawn Damphier (406) 892-2078 schopper12345@gmail.com

Owner/Operator: Dan Elder,KMR LLC (253) 985-5039 dane@mikesconoco.com

Owner/Operator: KMR LLC (253) 985-5039 dane@mikesconoco.com

Ronda Heil, UST Class A Operator

Shawn Damphier, UST Class A Operator

Shawn Damphier, UST Class B Operator

schopper12345@gmail.com

schopper12345@gmail.com

Tank Code	06	Tank Age	30	Tank Installed Date	07/01/1996	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	3366	Spill Test Date	11/30/2024	Piping Installed Date	03/30/2017	Tank Construction		Piping Construction	Secondary Containment Chase	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	01/22/2025	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	5000	ATG Test Date	01/22/2025	Line Tightness Test Date	02/25/2020	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	06/29/2023			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	07	Tank Age	30	Tank Installed Date	07/01/1996	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	3367	Spill Test Date	11/30/2024	Piping Installed Date	03/30/2017	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	01/22/2025	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	12000	ATG Test Date	01/22/2025	Line Tightness Test Date	02/26/2020	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No

		Overfill Test Date	06/29/2023			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	08	Tank Age	30	Tank Installed Date	07/01/1996	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	3368	Spill Test Date	06/29/2023	Piping Installed Date	03/30/2017	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	01/22/2025	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	15000	ATG Test Date	01/22/2025	Line Tightness Test Date	02/26/2020	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	06/29/2023			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	09	Tank Age	30	Tank Installed Date	07/01/1996	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	3369	Spill Test Date	06/29/2023	Piping Installed Date	03/30/2017	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	01/22/2025	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	15000	ATG Test Date	01/22/2025	Line Tightness Test Date	02/25/2020	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	06/29/2023			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	05	Tank Age	30	Tank Installed Date	07/01/1996	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	4466	Spill Test Date	06/28/2023	Piping Installed Date	03/30/2017	Tank Construction		Piping Construction	Secondary Containment Chase	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	01/22/2025	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	8000	ATG Test Date	01/22/2025	Line Tightness Test Date	02/25/2020	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	06/29/2023			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Flathead County in the City of Columbia Falls

Location: SMITHS #168 FUEL CENTER
150 Halfmoon Rd
Columbia Falls, MT 59912 Flathead

System Facility ID:60-15336

Facility Code: 32381
Last Inspected On: 03/04/2026
Operating Permit Renewal Date: 07/29/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Smiths Food and Drug (801) 974-1400 roger.gough@sfdc.com

Operator Contact: Braxton Hill;Kerry Busey braxton.hill@sfdc.com;kerry.busey@sfdc.com

Owner/Operator: Smiths Food and Drug (801) 974-1400 roger.gough@sfdc.com

Braxton Hill, UST Class A Operator	braxton.hill@sfdc.com
Braxton Hill, UST Class B Operator	braxton.hill@sfdc.com
Kerry Busey, UST Class A Operator	kerry.busey@sfdc.com
Kerry Busey, UST Class B Global Operator	kerry.busey@sfdc.com

Tank Code	01	Tank Age	6	Tank Installed Date	01/27/2020	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	5926	Spill Test Date	09/22/2022	Piping Installed Date	01/27/2020	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	Yes
Capacity	20000	ATG Test Date	09/24/2024	Line Tightness Test Date	02/20/2020	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	11/20/2024			ATG Type					
Tank Code	02	Tank Age	6	Tank Installed Date	01/27/2020	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	5927	Spill Test Date	09/22/2022	Piping Installed Date	01/27/2020	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	10000	ATG Test Date	09/24/2024	Line Tightness Test Date	02/20/2020	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	11/20/2024			ATG Type					

Tank Code	03	Tank Age	6	Tank Installed Date	01/27/2020	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve; High Level Alarm
Tag Number	5928	Spill Test Date	12/28/2022	Piping Installed Date	01/27/2020	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	Yes
Capacity	8000	ATG Test Date	09/24/2024	Line Tightness Test Date	02/20/2020	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	11/20/2024			ATG Type					

Facility Summary in Flathead County in the City of Columbia Falls

Location: TOWN PUMP INC COLUMBIA FALLS 1
502 9th St W
Columbia Falls, MT 59912-3808 Flathead

System Facility ID:15-08690

Facility Code: 20763
Last Inspected On: 03/15/2026
Operating Permit Renewal Date: 08/28/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Columbia Falls 1 Town Pump LLC (406) 497-6700 environmental@townpump.com

Operator Contact: Trent Biggers Trentb@townpump.com

Owner/Operator: Columbia Falls 1 Town Pump LLC (406) 497-6700 environmental@townpump.com

Trent Biggers, UST Class A Operator Trentb@townpump.com
Trent Biggers, UST Class B Global Operator Trentb@townpump.com

Tank Code	02	Tank Age	45	Tank Installed Date	07/14/1981	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	2420	Spill Test Date	03/12/2025	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date	02/07/2022	Tank/Piping CP Test Date	09/19/2022	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	Yes
Capacity	12000	ATG Test Date	03/12/2025	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	09/19/2022			ATG Type	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Code	07	Tank Age	37	Tank Installed Date	07/14/1989	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	2423	Spill Test Date	03/12/2025	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Gasoline	PLLD Test Date	02/07/2022	Tank/Piping CP Test Date	02/07/2022	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	Yes
Capacity	12000	ATG Test Date	03/12/2025	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	09/19/2022			ATG Type	Gilbarco-Veeder Root/TLS-450PLUS				

Tank Code	05	Tank Age	41	Tank Installed Date	10/01/1985	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	4380	Spill Test Date	03/12/2025	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date	02/07/2022	Tank/Piping CP Test Date	09/19/2022	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	10000	ATG Test Date	03/12/2025	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	09/19/2022			ATG Type	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Code	06	Tank Age	37	Tank Installed Date	07/14/1989	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	4381	Spill Test Date	03/12/2025	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Gasoline	PLLD Test Date	02/07/2022	Tank/Piping CP Test Date	02/07/2022	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	Yes
Capacity	12000	ATG Test Date	03/12/2025	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	09/19/2022			ATG Type	Gilbarco-Veeder Root/TLS-450PLUS				

Facility Summary in Flathead County in the City of Columbia Falls

Location: TOWN PUMP INC COLUMBIA FALLS 2
6102 US Hwy 2 W
Columbia Falls, MT 59912-8927 Flathead

System Facility ID:56-13825

Facility Code: 30511
Last Inspected On: 03/10/2023
Operating Permit Renewal Date: 08/29/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Columbia Falls 2 Town Pump LLC (406) 497-6700 environmental@townpump.com

Operator Contact: Trent Biggers Trentb@townpump.com

Owner/Operator: Columbia Falls 2 Town Pump LLC (406) 497-6700 environmental@townpump.com

Trent Biggers, UST Class A Operator Trentb@townpump.com
Trent Biggers, UST Class B Global Operator Trentb@townpump.com

Tank Code	01	Tank Age	29	Tank Installed Date	10/01/1997	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	2674	Spill Test Date	09/21/2022	Piping Installed Date	10/08/2013	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	09/21/2022	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	05/11/2021	Tank/Piping CP Test Date		Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	Yes
Capacity	12000	ATG Test Date	03/09/2023	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	No
		Overfill Test Date	09/21/2022			ATG Type	Gilbarco-Veeder Root/TLS-450				
Tank Code	03	Tank Age	29	Tank Installed Date	10/01/1997	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	2676	Spill Test Date	09/21/2022	Piping Installed Date	10/08/2013	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	09/21/2022	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	05/11/2021	Tank/Piping CP Test Date		Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	Yes
Capacity	10000	ATG Test Date	03/09/2023	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	No

		Overfill Test Date	11/17/2022			ATG Type	Gilbarco-Veeder Root/TLS-450				
Tank Code	02	Tank Age	29	Tank Installed Date	10/01/1997	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	4670	Spill Test Date	09/21/2022	Piping Installed Date	10/08/2013	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	09/21/2022	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	05/11/2021	Tank/Piping CP Test Date		Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	10000	ATG Test Date	03/09/2023	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	No
		Overfill Test Date	11/17/2022			ATG Type	Gilbarco-Veeder Root/TLS-450				
Tank Code	09	Tank Age	11	Tank Installed Date	10/02/2015	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	5600	Spill Test Date	09/21/2022	Piping Installed Date	10/07/2015	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	09/21/2022	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	05/11/2021	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	Yes
Capacity	15000	ATG Test Date	03/09/2023	Line Tightness Test Date		Secondary Tank Leak Detection	Statistical Inventory Reconciliation	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	Yes
		Overfill Test Date	09/21/2022			ATG Type	Gilbarco-Veeder Root/TLS-450				
Tank Code	10	Tank Age	11	Tank Installed Date	10/02/2015	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	5601	Spill Test Date	09/21/2022	Piping Installed Date	10/07/2015	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	09/21/2022	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	05/11/2021	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	Yes
Capacity	6000	ATG Test Date	03/09/2023	Line Tightness Test Date		Secondary Tank Leak Detection	Statistical Inventory Reconciliation	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	Yes
		Overfill Test Date	09/21/2022			ATG Type	Gilbarco-Veeder Root/TLS-450				
Tank Code	11	Tank Age	5	Tank Installed Date	01/18/2021	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve;High Level Alarm

Tag Number	5995	Spill Test Date	09/21/2022	Piping Installed Date	01/18/2021	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	09/21/2022	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	05/11/2021	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	Yes
Capacity	6000	ATG Test Date	03/09/2023	Line Tightness Test Date		Secondary Tank Leak Detection	Statistical Inventory Reconciliation	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	Yes
		Overfill Test Date	09/21/2022			ATG Type					
Tank Code	12	Tank Age	5	Tank Installed Date	01/18/2021	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	5996	Spill Test Date	09/21/2022	Piping Installed Date	01/18/2021	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	09/21/2022	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	05/11/2021	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	Yes
Capacity	8000	ATG Test Date	03/09/2023	Line Tightness Test Date		Secondary Tank Leak Detection	Statistical Inventory Reconciliation	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	Yes
		Overfill Test Date	09/21/2022			ATG Type					
Tank Code	13	Tank Age	5	Tank Installed Date	01/18/2021	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	5997	Spill Test Date	09/21/2022	Piping Installed Date	01/18/2021	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	09/21/2022	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	05/11/2021	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	Yes
Capacity	6000	ATG Test Date	03/09/2023	Line Tightness Test Date		Secondary Tank Leak Detection	Statistical Inventory Reconciliation	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	Yes
		Overfill Test Date	09/21/2022			ATG Type					
Tank Code	14	Tank Age	5	Tank Installed Date	01/18/2021	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	
Tag Number	5998	Spill Test Date	09/29/2020	Piping Installed Date		Tank Construction		Piping Construction		AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0		Piping Type	Pressurized	CP Met Types	
Product	DEF (Not Regulated)	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection		Primary Pipe Detection		Vapor Recovery	No

Capacity	8000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	09/29/2020			ATG Type					
Tank Code	15	Tank Age	5	Tank Installed Date	01/18/2021	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	6009	Spill Test Date	09/21/2022	Piping Installed Date	01/18/2021	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	09/21/2022	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	05/11/2021	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	30000	ATG Test Date	03/09/2023	Line Tightness Test Date		Secondary Tank Leak Detection	Statistical Inventory Reconciliation	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	Yes
		Overfill Test Date	09/21/2022			ATG Type					
Tank Code	16	Tank Age	5	Tank Installed Date	01/18/2021	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	6010	Spill Test Date	09/21/2022	Piping Installed Date	01/18/2021	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	09/21/2022	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	05/11/2021	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	10000	ATG Test Date	03/09/2023	Line Tightness Test Date		Secondary Tank Leak Detection	Statistical Inventory Reconciliation	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	Yes
		Overfill Test Date	09/21/2022			ATG Type					
Tank Code	17	Tank Age	5	Tank Installed Date	01/18/2021	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	6011	Spill Test Date	09/21/2022	Piping Installed Date	01/18/2021	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	09/21/2022	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel, Dyed	PLLD Test Date	05/11/2021	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	12000	ATG Test Date	03/09/2023	Line Tightness Test Date		Secondary Tank Leak Detection	Statistical Inventory Reconciliation	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	Yes
		Overfill Test Date	09/21/2022			ATG Type					

Facility Summary in Flathead County in the City of Coram

Location: GLACIER CENTER
10049 US Hwy 2 E
Coram, MT 59913 Flathead

System Facility ID:15-10895

Facility Code: 20898
Last Inspected On: 03/03/2026
Operating Permit Renewal Date: 06/03/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Kalispell Properties LLC (509) 994-6599 histarms01@yahoo.com

Operator Contact: Rhonda Andverson;Wade Lindsay;Kalispell Properties LLC (406) 38-75090;(406) 890-0968;(509) 994-6599 glaciercentergas@gmail.com;wade.w.lindsay@gmail.com;histarm s01@yahoo.com

Owner/Operator: Kalispell Properties LLC (509) 994-6599 histarms01@yahoo.com
Rhonda Andverson, UST Class A Operator glaciercentergas@gmail.com
Wade Lindsay, UST Class A Operator histarms01@yahoo.com
Wade Lindsay, UST Class B Operator histarms01@yahoo.com

Tank Code	04	Tank Age	38	Tank Installed Date	04/17/1988	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve
Tag Number	1883	Spill Test Date	05/03/2023	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date	05/03/2023	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	05/03/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	6000	ATG Test Date	05/03/2023	Line Tightness Test Date	05/03/2023	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	05/03/2023			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	05	Tank Age	31	Tank Installed Date	05/01/1995	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve
Tag Number	1884	Spill Test Date	05/03/2023	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date	05/03/2023	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	05/28/2014	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	12000	ATG Test Date	05/03/2023	Line Tightness Test Date	05/03/2023	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	05/03/2023			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Tank Code	06	Tank Age	31	Tank Installed Date	05/01/1995	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve
Tag Number	1885	Spill Test Date	05/03/2023	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date	05/03/2023	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	05/28/2014	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	12000	ATG Test Date	05/03/2023	Line Tightness Test Date	05/03/2023	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	05/03/2023			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	07	Tank Age	31	Tank Installed Date	05/01/1995	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve
Tag Number	1886	Spill Test Date	05/03/2023	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date	05/03/2023	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	05/28/2014	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	5000	ATG Test Date	05/03/2023	Line Tightness Test Date	05/03/2023	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	05/03/2023			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Flathead County in the City of Hungry Horse

Location: BOBS SINCLAIR HUNGRY HORSE
8930 US Hwy 2 E
Hungry Horse, MT 59919 Flathead

System Facility ID:15-07506

Facility Code: 20733
Last Inspected On: 01/24/2024
Operating Permit Renewal Date: 03/24/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: SCR Investment LLC (406) 206-3676 snowman190202@gmail.com

Operator Contact: Jeff Johnson (406) 260-3676 snowman190202@gmail.com

Owner/Operator: SCR Investment LLC (406) 206-3676 snowman190202@gmail.com
 Jeff Johnson, UST Class A Operator snowman190202@gmail.com
 Jeff Johnson, UST Class B Operator snowman190202@gmail.com

Tank Code	01	Tank Age	46	Tank Installed Date	09/01/1980	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve;Flapper Valve
Tag Number	4180	Spill Test Date	04/15/2021	Piping Installed Date	04/15/2021	Tank Construction	Lined Interior/Impressed Current	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	03/17/2021	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	04/28/2021	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	2000	ATG Test Date		Line Tightness Test Date	04/28/2021	Secondary Tank Leak Detection		Secondary Pipe Detection	MLLD Line Tightness Testing	Energy Act	No
		Overfill Test Date	04/15/2021			ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	02	Tank Age	46	Tank Installed Date	09/01/1980	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve;Flapper Valve
Tag Number	4181	Spill Test Date	04/15/2021	Piping Installed Date	04/15/2021	Tank Construction	Lined Interior/Impressed Current	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Safe Suction	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	04/28/2021	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	6000	ATG Test Date		Line Tightness Test Date	04/28/2021	Secondary Tank Leak Detection		Secondary Pipe Detection	MLLD Line Tightness Testing	Energy Act	No

		Overfill Test Date	04/15/2021			ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	03	Tank Age	46	Tank Installed Date	09/01/1980	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve;Flapper Valve
Tag Number	4182	Spill Test Date	04/15/2021	Piping Installed Date	04/15/2021	Tank Construction	Lined Interior/Impressed Current	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	03/17/2021	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	04/28/2021	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	4000	ATG Test Date		Line Tightness Test Date	04/28/2021	Secondary Tank Leak Detection		Secondary Pipe Detection	MLLD Line Tightness Testing	Energy Act	No
		Overfill Test Date	04/15/2021			ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	04	Tank Age	46	Tank Installed Date	09/01/1980	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve;Flapper Valve
Tag Number	4183	Spill Test Date	04/15/2021	Piping Installed Date	04/15/2021	Tank Construction	Lined Interior/Impressed Current	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	03/17/2021	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	04/28/2021	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	6000	ATG Test Date		Line Tightness Test Date	04/28/2021	Secondary Tank Leak Detection		Secondary Pipe Detection	MLLD Line Tightness Testing	Energy Act	No
		Overfill Test Date	04/15/2021			ATG Type	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Flathead County in the City of Hungry Horse

Location: CENEX ZIP TRIP 71
8840 US Hwy 2 E
Hungry Horse, MT 59919 Flathead

System Facility ID:15-09708

Facility Code: 20804
Last Inspected On: 11/07/2024
Operating Permit Renewal Date: 04/29/2028

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: CHS Inc Spokane Valley (509) 535-7701 jim.alford@chsinc.com

Operator Contact: Jim Alford;Sean Hurley (509) 535-7701;(509) 536-7418 jim.alford@chsinc.com;sean.hurley@chsinc.com

Owner/Operator: CHS Inc Spokane Valley (509) 535-7701 jim.alford@chsinc.com

Jason Brenner, UST Class B Operator jason.brenner@chsinc.com
 Jim Alford, UST Class A Operator jim.alford@chsinc.com
 Jim Alford, UST Class B Operator jim.alford@chsinc.com
 Luci Tuttle, UST Class B Operator Lucinda.Tuttle@chsinc.com
 Sean Hurley, UST Class A Operator sean.hurley@chsinc.com

Tank Code	05	Tank Age	8	Tank Installed Date	10/23/2018	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	5855	Spill Test Date	11/07/2024	Piping Installed Date	10/23/2018	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	09/15/2021	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	08/07/2024	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	20000	ATG Test Date	08/07/2024	Line Tightness Test Date	10/18/2018	Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	03/10/2025			ATG Type	Gilbarco-Veeder Root/TLS-450;Veeder Root/TLS-450				
Tank Code	06	Tank Age	8	Tank Installed Date	10/23/2018	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	5856	Spill Test Date	11/07/2024	Piping Installed Date	10/23/2018	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	11/07/2024	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible

Product	Gasoline	PLLD Test Date	12/12/2025	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	10000	ATG Test Date	08/07/2024	Line Tightness Test Date	10/18/2018	Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	03/10/2025			ATG Type	Gilbarco-Veeder Root/TLS-450;Veeder Root/TLS-450				
Tank Code	07	Tank Age	8	Tank Installed Date	10/23/2018	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	5857	Spill Test Date	11/07/2024	Piping Installed Date	10/23/2018	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	11/07/2024	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	08/07/2024	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	10000	ATG Test Date	08/07/2024	Line Tightness Test Date	10/18/2018	Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	03/10/2025			ATG Type	Gilbarco-Veeder Root/TLS-450;Veeder Root/TLS-450				
Tank Code	08	Tank Age	8	Tank Installed Date	10/23/2018	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	5858	Spill Test Date	11/07/2024	Piping Installed Date	10/23/2018	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	11/07/2024	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	08/07/2024	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	10000	ATG Test Date	08/07/2024	Line Tightness Test Date	10/18/2018	Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	03/10/2025			ATG Type	Gilbarco-Veeder Root/TLS-450;Veeder Root/TLS-450				
Tank Code	09	Tank Age	8	Tank Installed Date	10/23/2018	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	5859	Spill Test Date	11/07/2024	Piping Installed Date	10/23/2018	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	11/07/2024	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible

Product	Diesel	PLLD Test Date	08/07/2024	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	10000	ATG Test Date	08/07/2024	Line Tightness Test Date	10/18/2018	Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	03/10/2025			ATG Type	Gilbarco-Veeder Root/TLS-450PLUS				

Facility Summary in Flathead County in the City of Kalispell

Location: APPLEWAY CONOCO
100 N Meridian Rd
Kalispell, MT 59901-3848 Flathead

System Facility ID:15-00113

Facility Code: 20517
Last Inspected On: 10/12/2023
Operating Permit Renewal Date: 01/12/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Appleway Conoco

applewayconoco1@gmail.com

Operator Contact: Linda Bertoli

(509) 315-9959

lindabertoli@gmail.com

Owner/Operator: Appleway Conoco

applewayconoco1@gmail.com

Linda Bertoli, UST Class A Operator

lindabertoli@gmail.com

Linda Bertoli, UST Class B Operator

lindabertoli@gmail.com

Tank Code	01	Tank Age	47	Tank Installed Date	12/31/1979	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	3141	Spill Test Date	03/10/2022	Piping Installed Date		Tank Construction	Lined Interior/Impressed Current	Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date	08/31/2023	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	08/31/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	10000	ATG Test Date	08/31/2023	Line Tightness Test Date	08/31/2023	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	03/10/2022			ATG Type	Gilbarco/EMC Basic				
Tank Code	02	Tank Age	47	Tank Installed Date	12/31/1979	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	3142	Spill Test Date	03/10/2022	Piping Installed Date		Tank Construction	Lined Interior/Impressed Current	Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date	08/31/2023	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	08/31/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	10000	ATG Test Date	08/31/2023	Line Tightness Test Date	08/31/2023	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	03/10/2022			ATG Type	Gilbarco/EMC Basic				
Tank Code	03	Tank Age	47	Tank Installed Date	12/31/1979	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve

Tag Number	3143	Spill Test Date	03/10/2022	Piping Installed Date		Tank Construction	Lined Interior/Impressed Current	Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date	08/31/2023	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	08/31/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	10000	ATG Test Date	08/31/2023	Line Tightness Test Date	08/31/2023	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	03/10/2022			ATG Type	Gilbarco/EMC Basic				

Facility Summary in Flathead County in the City of Kalispell

Location: BRAR FOOD STORE
1090 N Meridian Rd
Kalispell, MT 59901-3564 Flathead

System Facility ID:15-00110

Facility Code: 20514
Last Inspected On: 12/24/2024
Operating Permit Renewal Date: 03/23/2028

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: BRAR FOOD STORE INC (341) 345-8514 BFS.USA@YAHOO.COM

Operator Contact: Navneet Brar;BRAR FOOD STORE INC;Paramjit Singh;BRAR FOOD STORE INC (341) 345-8514 bfs.usa@xyz.com;BFS.USA@YAHOO.COM;branaman0@gmail.com;BFS.USA@YAHOO.COM

Owner/Operator: BRAR FOOD STORE INC (341) 345-8514 BFS.USA@YAHOO.COM

Muskan Sohi, UST Class B Operator 4.sohi062@gmail.com
Navneet Brar, UST Class A Operator BFS.USA@YAHOO.COM
Navneet Brar, UST Class B Operator BFS.USA@YAHOO.COM
Paramjit Singh, UST Class A Operator BFS.USA@YAHOO.COM
Paramjit Singh, UST Class B Operator BFS.USA@YAHOO.COM

Tank Code	04	Tank Age	29	Tank Installed Date	11/01/1997	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	3171	Spill Test Date	01/15/2022	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date	12/09/2021	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	03/20/2025	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	10000	ATG Test Date	12/09/2021	Line Tightness Test Date	12/09/2021	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	01/15/2022			ATG Type	Gilbarco/EMC Basic				
Tank Code	05	Tank Age	29	Tank Installed Date	11/01/1997	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	3172	Spill Test Date	11/23/2021	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date	12/09/2021	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	03/20/2025	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	5000	ATG Test Date	12/09/2021	Line Tightness Test Date	12/09/2021	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	01/15/2022			ATG Type	Gilbarco/EMC Basic				

Tank Code	06	Tank Age	29	Tank Installed Date	11/01/1997	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	3173	Spill Test Date	01/15/2022	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date	12/09/2021	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	03/20/2025	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	5000	ATG Test Date	12/09/2021	Line Tightness Test Date	12/09/2021	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	01/15/2022			ATG Type	Gilbarco/EMC Basic				

Facility Summary in Flathead County in the City of Kalispell

Location: BRIANS C STORE
2075 US Hwy 2 E
Kalispell, MT 59901-2944 Flathead

System Facility ID:15-13730

Facility Code: 21091
Last Inspected On: 01/03/2024
Operating Permit Renewal Date: 01/14/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: DJL LLC (406) 755-7447

Operator Contact: Brian Kahler (406) 360-6484 muddsin1@yahoo.com

Owner/Operator: DJL LLC (406) 755-7447

Brian Kahler, UST Class A Operator

muddsin1@yahoo.com

Brian Kahler, UST Class B Global Operator

muddsin1@yahoo.com

Tank Code	01	Tank Age	30	Tank Installed Date	06/01/1996	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	3352	Spill Test Date	03/21/2024	Piping Installed Date	11/28/2023	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	11/16/2023	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	20000	ATG Test Date	11/16/2023	Line Tightness Test Date	05/25/2021	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	03/21/2024			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	02	Tank Age	30	Tank Installed Date	06/01/1996	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	3353	Spill Test Date	03/21/2024	Piping Installed Date	11/28/2023	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	11/16/2023	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	20000	ATG Test Date	11/16/2023	Line Tightness Test Date	08/07/2020	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	03/21/2024			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Tank Code	03	Tank Age	30	Tank Installed Date	06/01/1996	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	3354	Spill Test Date	11/16/2023	Piping Installed Date	11/28/2023	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	11/16/2023	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	12000	ATG Test Date	11/16/2023	Line Tightness Test Date	10/04/2020	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	03/21/2024			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	04	Tank Age	30	Tank Installed Date	06/01/1996	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	3355	Spill Test Date	11/16/2023	Piping Installed Date	11/28/2023	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	11/16/2023	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	12000	ATG Test Date	11/16/2023	Line Tightness Test Date	10/04/2020	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	11/16/2023			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	05	Tank Age	30	Tank Installed Date	06/01/1996	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	3356	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	8000	ATG Test Date		Line Tightness Test Date	05/28/2021	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	06	Tank Age	30	Tank Installed Date	06/01/1996	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	3357	Spill Test Date	03/21/2024	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No

Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	8000	ATG Test Date		Line Tightness Test Date	04/28/2020	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	03/21/2024			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Flathead County in the City of Kalispell

Location: BRIANS INC
1319 US Hwy 93 S
Kalispell, MT 59901-5765 Flathead

System Facility ID:15-09820

Facility Code: 20807
Last Inspected On: 03/09/2026
Operating Permit Renewal Date: 06/28/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Darryl Bjork;DJL LLC (406) 755-7447

Operator Contact: Brian Kahler (406) 360-6484 muddsin1@yahoo.com

Owner/Operator: Darryl Bjork

Owner/Operator: DJL LLC

Brian Kahler, UST Class A Operator

muddsin1@yahoo.com

Brian Kahler, UST Class B Global Operator

muddsin1@yahoo.com

Tank Code	05	Tank Age	31	Tank Installed Date	09/01/1995	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve;Flapper Valve
Tag Number	1847	Spill Test Date	05/17/2023	Piping Installed Date		Tank Construction		Piping Construction	Single Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	05/17/2023	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	05/18/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	15000	ATG Test Date	05/17/2023	Line Tightness Test Date	05/17/2023	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	06/28/2023			ATG Type	Incon/TS-1000				
Tank Code	06	Tank Age	31	Tank Installed Date	09/01/1995	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve
Tag Number	1848	Spill Test Date	05/17/2023	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date	05/17/2023	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	05/18/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	15000	ATG Test Date	05/17/2023	Line Tightness Test Date	05/17/2023	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	05/17/2023			ATG Type	Incon/TS-1000				
Tank Code	07	Tank Age	31	Tank Installed Date	09/01/1995	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve;Flapper Valve

Tag Number	1849	Spill Test Date	06/27/2023	Piping Installed Date		Tank Construction		Piping Construction	Single Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	05/17/2023	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	05/18/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	7500	ATG Test Date	05/17/2023	Line Tightness Test Date	05/17/2023	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	06/28/2023			ATG Type	Incon/TS-1000				
Tank Code	08	Tank Age	31	Tank Installed Date	09/01/1995	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve
Tag Number	1850	Spill Test Date	05/17/2023	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date	05/17/2023	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	05/18/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	7500	ATG Test Date	05/17/2023	Line Tightness Test Date	05/17/2023	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	05/17/2023			ATG Type	Incon/TS-1000				

Facility Summary in Flathead County in the City of Kalispell

Location: CITY SERVICE BULK PLANT
1841 3rd Ave E
Kalispell, MT 59901-5758 Flathead

System Facility ID:56-13824

Facility Code: 30510
Last Inspected On: 09/30/2025
Operating Permit Renewal Date: 12/24/2028

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: City Service Inc

Operator Contact: Drew Pike;Kary Tonjum;Margaret Flynn

(406) 294-0863;(406) 755-4321

drewp@cityservicevalcon.com;margaretf@cityservicevalcon.com

Owner/Operator: City Service Inc

Drew Pike, UST Class A Operator
Drew Pike, UST Class B Global Operator
Kary Tonjum, UST Class A Operator
Kary Tonjum, UST Class B Global Operator
Margaret Flynn, UST Class A Operator
Margaret Flynn, UST Class B Operator

drewp@cityservicevalcon.com

drewp@cityservicevalcon.com

margaretf@cityservicevalcon.com

margaretf@cityservicevalcon.com

Tank Code	01	Tank Age	29	Tank Installed Date	08/01/1997	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	681	Spill Test Date	05/02/2025	Piping Installed Date	09/28/2017	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	05/02/2025	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	04/22/2025	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	15000	ATG Test Date	04/22/2025	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	05/02/2025			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	02	Tank Age	29	Tank Installed Date	08/01/1997	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	682	Spill Test Date	05/02/2025	Piping Installed Date	09/28/2017	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	05/02/2025	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	04/22/2025	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No

Capacity	15000	ATG Test Date	04/22/2025	Line Tightness Test Date	09/22/2016	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	05/02/2025			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	03	Tank Age	29	Tank Installed Date	08/01/1997	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	683	Spill Test Date	05/02/2025	Piping Installed Date	09/28/2017	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	05/02/2025	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	04/22/2025	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	20000	ATG Test Date	04/22/2025	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	05/02/2025			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	04	Tank Age	29	Tank Installed Date	08/01/1997	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	684	Spill Test Date	05/02/2025	Piping Installed Date	09/28/2017	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	05/02/2025	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel, Dyed	PLLD Test Date	04/22/2025	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	20000	ATG Test Date	04/22/2025	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	05/02/2025			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	05	Tank Age	29	Tank Installed Date	08/01/1997	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	685	Spill Test Date	05/02/2025	Piping Installed Date	09/28/2017	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	05/02/2025	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	04/22/2025	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	20000	ATG Test Date	04/22/2025	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	05/02/2025			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Flathead County in the City of Kalispell

Location: CITY SERVICE VALCON - EAGLE FUEL
3150 US Hwy 2
Kalispell, MT 59901 Flathead

System Facility ID:56-14014

Facility Code: 30674
Last Inspected On: 09/30/2025
Operating Permit Renewal Date: 12/31/2028

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: City Service Valcon LLC

(406) 294-0865

tamara.noble@cityservicevalcon.com

Operator Contact: Kary Tonjum

Owner/Operator: City Service Valcon LLC

(406) 294-0865

tamara.noble@cityservicevalcon.com

Kary Tonjum, UST Class A Operator

Kary Tonjum, UST Class B Global Operator

Tank Code	01	Tank Age	25	Tank Installed Date	07/01/2001	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	4605	Spill Test Date	09/30/2025	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	09/30/2025	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	04/22/2025	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	4000	ATG Test Date	04/22/2025	Line Tightness Test Date	12/13/2018	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	09/30/2025			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	02	Tank Age	25	Tank Installed Date	07/01/2001	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	4606	Spill Test Date	09/30/2025	Piping Installed Date	12/20/2018	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	09/30/2025	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel, Dyed	PLLD Test Date	04/22/2025	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	4000	ATG Test Date	04/22/2025	Line Tightness Test Date	12/13/2018	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	09/30/2025			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Tank Code	03	Tank Age	25	Tank Installed Date	07/01/2001	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	4607	Spill Test Date	09/30/2025	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	09/30/2025	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	04/22/2025	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	20000	ATG Test Date	04/22/2025	Line Tightness Test Date	12/13/2018	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	09/30/2025			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	04	Tank Age	25	Tank Installed Date	07/01/2001	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	4608	Spill Test Date	09/30/2025	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	09/30/2025	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	04/22/2025	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	8000	ATG Test Date	04/22/2025	Line Tightness Test Date	12/13/2018	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	09/30/2025			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Flathead County in the City of Kalispell

Location: CITY SERVICE VALCON LLC
52 5th Ave W N
Kalispell, MT 59901-3802 Flathead

System Facility ID:15-01680

Facility Code: 20552
Last Inspected On: 01/27/2025
Operating Permit Renewal Date: 05/01/2028

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: City Service Valcon LLC (406) 294-0865 tamara.noble@cityservicevalcon.com

Operator Contact: Drew Pike;Jay Brookie;Kary Tonjum (406) 252-4661;(406) 755-4321 drewp@cityservicevalcon.com;jayb@cityservicevalcon.com

Owner/Operator: City Service Valcon LLC (406) 294-0865 tamara.noble@cityservicevalcon.com

- David Wines, UST Class B Global Operator
- Drew Pike, UST Class A Operator
- Drew Pike, UST Class B Global Operator
- Jay Brookie, UST Class A Operator
- Jay Brookie, UST Class B Global Operator
- Kary Tonjum, UST Class A Operator
- Kary Tonjum, UST Class B Operator

- davidw@cityservicevalcon.com
- drewp@cityservicevalcon.com
- drewp@cityservicevalcon.com
- jayb@cityservicevalcon.com
- jayb@cityservicevalcon.com

Tank Code	09	Tank Age	28	Tank Installed Date	11/01/1998	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	3689	Spill Test Date	05/01/2024	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	05/01/2024	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	25000	ATG Test Date	05/01/2024	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	05/01/2024			ATG Type	Gilbarco/EMC				
Tank Code	10	Tank Age	28	Tank Installed Date	11/01/1998	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	3690	Spill Test Date	05/01/2024	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	05/01/2024	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No

Capacity	25000	ATG Test Date	05/01/2024	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	05/01/2024			ATG Type	Gilbarco/EMC				
Tank Code	11	Tank Age	28	Tank Installed Date	11/01/1998	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	3691	Spill Test Date	05/01/2024	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	05/01/2024	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	20000	ATG Test Date	05/01/2024	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	05/01/2024			ATG Type	Gilbarco/EMC				
Tank Code	12	Tank Age	28	Tank Installed Date	11/01/1998	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	3692	Spill Test Date	05/01/2024	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	05/01/2024	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	15000	ATG Test Date	05/01/2024	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	05/01/2024			ATG Type	Gilbarco/EMC				
Tank Code	13	Tank Age	28	Tank Installed Date	12/01/1998	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	3693	Spill Test Date	05/01/2024	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel, Dyed	PLLD Test Date	05/01/2024	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	8000	ATG Test Date	05/01/2024	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	05/01/2024			ATG Type	Gilbarco/EMC				

Facility Summary in Flathead County in the City of Kalispell

Location: CONOCO CAR CARE CENTER
292 3rd Ave E N
Kalispell, MT 59901 Flathead

System Facility ID:15-01677

Facility Code: 20550
Last Inspected On: 11/22/2024
Operating Permit Renewal Date: 12/12/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Maurissa Spain (406) 609-8977 maurissaspain@gmail.com

Operator Contact: Dallas Herron;Maurissa Spain (406) 609-8977;(406) 751-4623 dallash@cityservicevalcon.com;maurissaspain@gmail.com

Owner/Operator: Maurissa Spain (406) 609-8977 maurissaspain@gmail.com
 Dallas Herron, UST Class A Operator dallash@cityservicevalcon.com
 Maurissa Spain, UST Class A Operator maurissaspain@gmail.com
 Maurissa Spain, UST Class B Operator maurissaspain@gmail.com

Tank Code	01	Tank Age	55	Tank Installed Date	04/24/1971	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	2199	Spill Test Date	11/30/2023	Piping Installed Date		Tank Construction	Lined Interior/Impressed Current	Piping Construction	Single Walled	AST	No
Tank Status	Temporarily Out of Use	MLLD Test Date	11/30/2023	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	11/30/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	20000	ATG Test Date	11/30/2023	Line Tightness Test Date	11/30/2023	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	11/30/2023			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	02	Tank Age	55	Tank Installed Date	04/24/1971	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	2200	Spill Test Date	08/05/2024	Piping Installed Date		Tank Construction	Lined Interior/Impressed Current	Piping Construction	None	AST	No
Tank Status	Temporarily Out of Use	MLLD Test Date	11/30/2023	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	11/30/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	20000	ATG Test Date	11/30/2023	Line Tightness Test Date	11/30/2023	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No

		Overfill Test Date	11/30/2023			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	03	Tank Age	50	Tank Installed Date	04/23/1976	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	2201	Spill Test Date	08/05/2024	Piping Installed Date		Tank Construction	Lined Interior/Impressed Current	Piping Construction	None	AST	No
Tank Status	Temporarily Out of Use	MLLD Test Date	11/30/2023	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	11/30/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	12000	ATG Test Date	11/30/2023	Line Tightness Test Date	11/30/2023	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	11/30/2023			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	09	Tank Age	40	Tank Installed Date	04/23/1986	Tank Material	Cathodically Protected Steel	Piping Material	No Piping	Overfill Types	High Level Alarm
Tag Number	2202	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Temporarily Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Gravity Feed	CP Met Types	Galvanic
Product	Oil, Waste	PLLD Test Date		Tank/Piping CP Test Date	02/20/2020	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	3-Year Line Tightness Test	Vapor Recovery	No
Capacity	2000	ATG Test Date		Line Tightness Test Date	10/07/2020	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Flathead County in the City of Kalispell

Location: COSTCO FUEL FACILITY KALISPELL LOC 1746
305 Cascade Loop
Kalispell, MT 59901 Flathead

System Facility ID:00-32589

Facility Code: 32589
Last Inspected On: 03/10/2026
Operating Permit Renewal Date: 03/10/2029

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Shawn Kipp;Costco Wholesale

(406) 671-7789;(425) 251-6222

w069gas@costco.com;gaslicenses@costco.com

Operator Contact:

Owner/Operator: Shawn Kipp,Costco Wholesale

(406) 671-7789

w069gas@costco.com

Tank Code	01	Tank Age	1	Tank Installed Date	08/18/2025	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	6300	Spill Test Date	11/17/2025	Piping Installed Date	09/03/2025	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	11/17/2025	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	Yes
Capacity	40000	ATG Test Date	11/17/2025	Line Tightness Test Date	11/19/2025	Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	11/17/2025			ATG Type					
Tank Code	02	Tank Age	1	Tank Installed Date	08/18/2025	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	6301	Spill Test Date	11/17/2025	Piping Installed Date	09/03/2025	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	11/17/2025	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	Yes
Capacity	40000	ATG Test Date	11/17/2025	Line Tightness Test Date	11/19/2025	Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	11/19/2025			ATG Type					
Tank Code	03	Tank Age	1	Tank Installed Date	08/18/2025	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve;High Level Alarm

Tag Number	6302	Spill Test Date	11/17/2025	Piping Installed Date	09/03/2025	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	11/17/2025	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	Yes
Capacity	40000	ATG Test Date	11/17/2025	Line Tightness Test Date	11/19/2025	Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	11/17/2025			ATG Type					
Tank Code	04	Tank Age	1	Tank Installed Date	08/18/2025	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	6303	Spill Test Date	11/17/2025	Piping Installed Date	09/03/2025	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	11/17/2025	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	30000	ATG Test Date	11/17/2025	Line Tightness Test Date	11/19/2025	Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	11/17/2025			ATG Type					
Tank Code	05	Tank Age	1	Tank Installed Date	08/18/2025	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	6304	Spill Test Date	11/17/2025	Piping Installed Date	09/03/2025	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Hazardous Substance	PLLD Test Date	11/17/2025	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	2000	ATG Test Date	11/17/2025	Line Tightness Test Date	11/19/2025	Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	11/17/2025			ATG Type					
Tank Code	06	Tank Age	1	Tank Installed Date	08/18/2025	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	6305	Spill Test Date	11/17/2025	Piping Installed Date	09/03/2025	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Hazardous Substance	PLLD Test Date	11/17/2025	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No

Capacity	1500	ATG Test Date	11/17/2025	Line Tightness Test Date	11/19/2025	Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	11/17/2025			ATG Type					

Facility Summary in Flathead County in the City of Kalispell

Location: DIAMOND AIRE LLC LEASEE
1893 Airport Rd
Kalispell, MT 59901-7501 Flathead

System Facility ID:15-03172

Facility Code: 20598
Last Inspected On: 09/30/2025
Operating Permit Renewal Date: 12/20/2028

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: John Talmage;Montana Diamond Aire Inc (406) 752-5092 john@diamondaire.com;tia@flymissionmountain.com

Operator Contact:

Owner/Operator: John Talmage (406) 752-5092 john@diamondaire.com

Owner/Operator: Montana Diamond Aire Inc (406) 752-5092 john@diamondaire.com

Tank Code	07	Tank Age	31	Tank Installed Date	05/24/1995	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	3285	Spill Test Date	09/30/2025	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	09/30/2025	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Aviation Gas	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	12000	ATG Test Date	09/30/2025	Line Tightness Test Date	09/30/2025	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	09/30/2025			ATG Type	Gilbarco/TLS-350				
Tank Code	08	Tank Age	31	Tank Installed Date	05/24/1995	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	3286	Spill Test Date	09/30/2025	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	09/30/2025	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Jet Fuel (Jet-A, Jet-A1, JP5)	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	5000	ATG Test Date	09/30/2025	Line Tightness Test Date	09/30/2025	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	09/30/2025			ATG Type	Gilbarco/TLS-350				

Facility Summary in Flathead County in the City of Kalispell

Location: EVERGREEN GAS and DELI
2100 US Hwy 2 E
Kalispell, MT 59901-2814 Flathead

System Facility ID:15-00108

Facility Code: 20512
Last Inspected On: 10/11/2023
Operating Permit Renewal Date: 12/02/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Aries Enterprises LLC;Kristi Ruggles (406) 890-5047 ramdeeprokha@yahoo.com

Operator Contact: Ramdeep Kaur (803) 522-5352 ramdeeprokha@yahoo.com

Owner/Operator: Aries Enterprises LLC (406) 890-5047 ramdeeprokha@yahoo.com
Owner/Operator: Kristi Lyn Ruggles (406) 890-5047 ramdeeprokha@yahoo.com
 Ramdeep Kaur, UST Class A Operator ramdeeprokha@yahoo.com
 Ramdeep Kaur, UST Class B Global Operator ramdeeprokha@yahoo.com
 Ramdeep Kaur, UST Class B Operator ramdeeprokha@yahoo.com

Tank Code	04	Tank Age	28	Tank Installed Date	06/01/1998	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve
Tag Number	3180	Spill Test Date	10/20/2022	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date	08/29/2025	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	10000	ATG Test Date	08/29/2025	Line Tightness Test Date	08/29/2025	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	08/29/2025			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	05	Tank Age	28	Tank Installed Date	06/01/1998	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve
Tag Number	3181	Spill Test Date	10/20/2022	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date	08/29/2025	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	12000	ATG Test Date	08/29/2025	Line Tightness Test Date	08/29/2025	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No

		Overfill Test Date	08/29/2025			ATG Type	Gilbarco-Veeder Root/TLS- 350/Gilbarco EMC				
--	--	---------------------------	------------	--	--	-----------------	--	--	--	--	--

Facility Summary in Flathead County in the City of Kalispell

Location: FLATHEAD COUNTY JUSTICE CENTER
920 S Main St
Kalispell, MT 59901 Flathead

System Facility ID:15-09279

Facility Code: 20774
Last Inspected On: 03/25/2026
Operating Permit Renewal Date: 03/16/2029

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Flathead County Commissioners

(406) 758-5834

dcloninger@flatheadcounty.gov

Operator Contact:

Owner/Operator: Flathead County Commissioners

(406) 758-5834

dcloninger@flatheadcounty.gov

Tank Code	01	Tank Age	39	Tank Installed Date	03/11/1987	Tank Material	Cathodically Protected Steel	Piping Material	Copper	Overfill Types	Flapper Valve
Tag Number	3810	Spill Test Date	03/25/2026	Piping Installed Date		Tank Construction		Piping Construction	Secondary Containment Chase	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Auto Dialer	Piping Type	U.S. Suction	CP Met Types	Galvanic
Product	Diesel, Dyed	PLLD Test Date		Tank/Piping CP Test Date	03/25/2026	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	12000	ATG Test Date	03/25/2026	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	03/25/2026			ATG Type	Gilbarco/EMC Basic				

Facility Summary in Flathead County in the City of Kalispell

Location: FLATHEAD COUNTY ROAD DEPT
1249 Willow Glen Dr
Kalispell, MT 59901-7541 Flathead

System Facility ID:15-06286

Facility Code: 20703
Last Inspected On: 01/22/2025
Operating Permit Renewal Date: 05/23/2028

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Flathead County Commissioners

(406) 758-5834

dcloninger@flatheadcounty.gov

Operator Contact: Corey Pilsch

(406) 752-4962

Owner/Operator: Flathead County Commissioners

(406) 758-5834

dcloninger@flatheadcounty.gov

Corey Pilsch, UST Class A Operator

Corey Pilsch, UST Class B Operator

Tank Code	08	Tank Age	28	Tank Installed Date	05/01/1998	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	1088	Spill Test Date	06/13/2024	Piping Installed Date	11/19/2013	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	10000	ATG Test Date	06/13/2024	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	06/13/2024			ATG Type	Gilbarco/EMC Basic				
Tank Code	09	Tank Age	28	Tank Installed Date	05/01/1998	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	1089	Spill Test Date	06/13/2024	Piping Installed Date	11/19/2013	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	3000	ATG Test Date	06/13/2024	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	06/13/2024			ATG Type	Gilbarco/EMC Basic				

Facility Summary in Flathead County in the City of Kalispell

Location: FLATHEAD COUNTY SOLID WASTE DIST
4098 US Hwy 93 N
Kalispell, MT 59901-6820 Flathead

System Facility ID:56-14041

Facility Code: 30696
Last Inspected On: 11/19/2025
Operating Permit Renewal Date: 12/26/2028

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Flathead County Commissioners

(406) 758-5834

dcloninger@flatheadcounty.gov

Operator Contact: James Chilton

jchilton@flathead.mt.gov

Owner/Operator: Flathead County Commissioners

(406) 758-5834

dcloninger@flatheadcounty.gov

James Chilton, UST Class A Operator

jchilton@flathead.mt.gov

James Chilton, UST Class B Operator

jchilton@flathead.mt.gov

Tank Code	S2	Tank Age	23	Tank Installed Date	02/25/2003	Tank Material	Concrete	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	4802	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	Yes
Tank Status	Currently in Use	MLLD Test Date	11/19/2025	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection		Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	15000	ATG Test Date	11/19/2025	Line Tightness Test Date	11/19/2025	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date				ATG Type					
Tank Code	S3	Tank Age	23	Tank Installed Date	02/25/2003	Tank Material	Concrete	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	4803	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	Yes
Tank Status	Currently in Use	MLLD Test Date	11/19/2025	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection		Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	3000	ATG Test Date	11/19/2025	Line Tightness Test Date	11/19/2025	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date				ATG Type					

Facility Summary in Flathead County in the City of Kalispell

Location: FLATHEAD ELECTRIC COOP KALISPELL
2510 US Hwy 2 E
Kalispell, MT 59901-2312 Flathead

System Facility ID:15-00044

Facility Code: 20508
Last Inspected On: 08/08/2023
Operating Permit Renewal Date: 08/08/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Flathead Electric Cooperative Inc (406) 751-4483

Operator Contact: Christopher Anderson;Flathead Electric Cooperative Inc;Francisco Carbajal;Flathead Electric Cooperative Inc (406) 471-0554;(406) 751-4483;(406) 751-4483 c.anderson@flathead.coop;f.carbajal@flathead.coop

Owner/Operator: Flathead Electric Cooperative Inc (406) 751-4483

Christopher Anderson, UST Class A Operator
Christopher Anderson, UST Class B Operator
Francisco Carbajal, UST Class A Operator
Francisco Carbajal, UST Class B Operator

c.anderson@flathead.coop
c.anderson@flathead.coop
f.carbajal@flathead.coop
f.carbajal@flathead.coop

Tank Code	04	Tank Age	28	Tank Installed Date	04/01/1998	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	1090	Spill Test Date	08/08/2023	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	08/08/2023	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	10000	ATG Test Date	08/08/2023	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	08/08/2023			ATG Type	Veeder Root/TLS-450				
Tank Code	05	Tank Age	28	Tank Installed Date	04/01/1998	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	1091	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	6000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date				ATG Type	Veeder Root/TLS-450				

Tank Code	06	Tank Age	28	Tank Installed Date	04/01/1998	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	1092	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	5000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date				ATG Type	Veeder Root/TLS-450				

Facility Summary in Flathead County in the City of Kalispell

Location: GLACIER GAS N GO
1454 MT Hwy 35
Kalispell, MT 59901-2916 Flathead

System Facility ID:15-08357

Facility Code: 20756
Last Inspected On: 07/18/2023
Operating Permit Renewal Date: 08/20/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: HARJ93, LLC (206) 834-5349 sheragroupllc@gmail.com

Operator Contact: Rahul Kumar;Ranch Hand Inc (406) 296-2342 tharejallc@gmail.com

Owner/Operator: HARJ93, LLC (206) 834-5349 sheragroupllc@gmail.com

Rahul Kumar, UST Class A Operator
Rahul Kumar, UST Class B Operator

tharejallc@gmail.com
tharejallc@gmail.com

Tank Code	01	Tank Age	44	Tank Installed Date	05/08/1982	Tank Material	Bare Steel	Piping Material	Steel	Overfill Types	Flapper Valve
Tag Number	1420	Spill Test Date	05/08/2023	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date	05/08/2023	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	05/08/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	8000	ATG Test Date	05/08/2023	Line Tightness Test Date	05/08/2023	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	05/08/2023			ATG Type	Veeder Root/TLS-300				
Tank Code	02	Tank Age	44	Tank Installed Date	05/08/1982	Tank Material	Bare Steel	Piping Material	Steel	Overfill Types	Flapper Valve
Tag Number	1421	Spill Test Date	06/26/2023	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date	05/08/2023	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	05/09/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	8000	ATG Test Date	05/08/2023	Line Tightness Test Date	05/08/2023	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	05/08/2023			ATG Type	Veeder Root/TLS-300				

Facility Summary in Flathead County in the City of Kalispell

Location: KELLY RAES INC
25 Batavia Ln
Kalispell, MT 59901-7280 Flathead

System Facility ID:15-06101

Facility Code: 20691
Last Inspected On: 12/16/2025
Operating Permit Renewal Date: 02/03/2029

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Kalispell Properties LLC (509) 994-6599 histarms01@yahoo.com

Operator Contact: Lisa Myers (406) 752-5880 lisaloumyers@gmail.com

Owner/Operator: Kalispell Properties LLC (509) 994-6599 histarms01@yahoo.com

Lisa Myers, UST Class A Operator

lisaloumyers@gmail.com

Lisa Myers, UST Class B Operator

lisaloumyers@gmail.com

Tank Code	03	Tank Age	32	Tank Installed Date	02/01/1994	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	4505	Spill Test Date	01/18/2023	Piping Installed Date		Tank Construction		Piping Construction	Single Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	12/07/2022	Sump Tightness Test Date	04/19/2023	Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date	12/16/2025	Tank/Piping CP Test Date	01/18/2023	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	6000	ATG Test Date	12/16/2025	Line Tightness Test Date	12/07/2022	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	12/07/2022			ATG Type	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Code	S6	Tank Age	7	Tank Installed Date	01/10/2019	Tank Material	Aboveground Tank	Piping Material	Flexible Plastic	Overfill Types	
Tag Number	5891	Spill Test Date		Piping Installed Date	01/10/2019	Tank Construction		Piping Construction	Double Walled	AST	Yes
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	04/19/2023	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Diesel, Dyed	PLLD Test Date	12/16/2025	Tank/Piping CP Test Date		Primary Tank Leak Detection		Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	5000	ATG Test Date	12/16/2025	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date				ATG Type					
Tank Code	S7	Tank Age	7	Tank Installed Date	01/10/2019	Tank Material	Aboveground Tank	Piping Material	Flexible Plastic	Overfill Types	

Tag Number	5892	Spill Test Date		Piping Installed Date	01/10/2019	Tank Construction		Piping Construction	Double Walled	AST	Yes
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	04/19/2023	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Diesel	PLLD Test Date	12/16/2025	Tank/Piping CP Test Date		Primary Tank Leak Detection		Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	10000	ATG Test Date	12/16/2025	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date				ATG Type					
Tank Code	S8	Tank Age	7	Tank Installed Date	01/10/2019	Tank Material	Aboveground Tank	Piping Material	Flexible Plastic	Overfill Types	
Tag Number	5893	Spill Test Date		Piping Installed Date	01/10/2019	Tank Construction		Piping Construction	Double Walled	AST	Yes
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	04/19/2023	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Gasoline	PLLD Test Date	12/16/2025	Tank/Piping CP Test Date		Primary Tank Leak Detection		Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	15000	ATG Test Date	12/16/2025	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date				ATG Type					
Tank Code	S9	Tank Age	7	Tank Installed Date	01/10/2019	Tank Material	Aboveground Tank	Piping Material	Flexible Plastic	Overfill Types	
Tag Number	5894	Spill Test Date		Piping Installed Date	01/10/2019	Tank Construction		Piping Construction	Double Walled	AST	Yes
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	04/19/2023	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Gasoline	PLLD Test Date	12/16/2025	Tank/Piping CP Test Date		Primary Tank Leak Detection		Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	5000	ATG Test Date	12/16/2025	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date				ATG Type					

Facility Summary in Flathead County in the City of Kalispell

Location: LOGAN HEALTH MEDICAL CENTER - ALERT
325 Claremont St
Kalispell, MT 59901-3576 Flathead

System Facility ID:15-00800

Facility Code: 20529
Last Inspected On: 12/02/2024
Operating Permit Renewal Date: 03/15/2028

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Northwest Healthcare (406) 752-5111

Operator Contact: Kevin McCallum;Logan Health Whitefish;Kyle Hovey;Monti Arneson;Logan Health Whitefish (406) 212-8644

got2fish62@gmail.com;jnewson@logan.org;khovey@krmc.org;kmccallum@logan.org;jnewson@logan.org

Owner/Operator: Northwest Healthcare (406) 752-5111

Kevin McCallum, UST Class A Operator
Kevin McCallum, UST Class B Operator
Kyle Hovey, UST Class A Operator
Kyle Hovey, UST Class B Operator
Monti Arneson, UST Class A Operator
Monti Arneson, UST Class B Operator

jnewson@logan.org
jnewson@logan.org
khovey@krmc.org
khovey@krmc.org
jnewson@logan.org
jnewson@logan.org

Tank Code	02	Tank Age	36	Tank Installed Date	11/06/1990	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve
Tag Number	1465	Spill Test Date	06/18/2024	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date	06/18/2024	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Jet Fuel (Jet-A, Jet-A1, JP5)	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	6000	ATG Test Date	06/18/2024	Line Tightness Test Date	06/18/2024	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	12/02/2024			ATG Type	Gilbarco/EMC Basic				

Facility Summary in Flathead County in the City of Kalispell

Location: MATES 101
1645 US Hwy 93 S
Kalispell, MT 59901-5775 Flathead

System Facility ID:15-02014

Facility Code: 20564
Last Inspected On: 02/13/2025
Operating Permit Renewal Date: 02/13/2028

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: MATES 101 INC (929) 372-6087 101matesinc@gmail.com

Operator Contact: Tejas Sehgal;MATES 101 INC (929) 372-6087 tejassehgal12@gmail.com;101matesinc@gmail.com

Owner/Operator: MATES 101 INC (929) 372-6087 101matesinc@gmail.com

Michael Apoka, UST Class B Operator
Tejas Sehgal, UST Class A Operator

101matesinc@gmail.com
101matesinc@gmail.com

Tank Code	11	Tank Age	29	Tank Installed Date	05/01/1997	Tank Material	Steel Clad	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	650	Spill Test Date	11/22/2021	Piping Installed Date	11/04/2013	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	11/22/2021	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	12/08/2021	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	10000	ATG Test Date	12/08/2021	Line Tightness Test Date	09/07/2021	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	11/22/2021			ATG Type	Gilbarco/EMC Basic				
Tank Code	12	Tank Age	29	Tank Installed Date	05/01/1997	Tank Material	Steel Clad	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	651	Spill Test Date	11/22/2021	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	12/08/2021	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	15000	ATG Test Date	12/08/2021	Line Tightness Test Date	12/14/2021	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	11/22/2021			ATG Type	Gilbarco/EMC Basic				
Tank Code	13	Tank Age	29	Tank Installed Date	05/01/1997	Tank Material	Steel Clad	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve

Tag Number	652	Spill Test Date	11/22/2021	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	12/08/2021	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	12000	ATG Test Date	12/08/2021	Line Tightness Test Date	08/26/2021	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	11/22/2021			ATG Type	Gilbarco/EMC Basic				
Tank Code	14	Tank Age	29	Tank Installed Date	05/01/1997	Tank Material	Steel Clad	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	653	Spill Test Date	11/22/2021	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	12/08/2021	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	15000	ATG Test Date	12/08/2021	Line Tightness Test Date	09/30/2021	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	11/22/2021			ATG Type	Gilbarco/EMC Basic				

Facility Summary in Flathead County in the City of Kalispell

Location: MDOT KALISPELL
85 5th Ave E N
Kalispell, MT 59901-4115 Flathead

System Facility ID:15-08733

Facility Code: 20766
Last Inspected On: 07/30/2024
Operating Permit Renewal Date: 11/01/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: MDOT Helena (406) 444-6163 mmurolo@mt.gov

Operator Contact: Joe Radonich;Montana Dept of Transportation;Tracy Deeds;MDOT Helena;Walt Kerttula;Montana Department of Transportation Helena (406) 444-6151;(406) 444-9204;(406) 444-7632;(406) 461-0769;(406) 444-6163 jradonich@mt.gov;jradonich@mt.gov;tdeeds@mt.gov;mmurolo@mt.gov;wkerttula@mt.gov

Owner/Operator: MDOT Helena (406) 444-6163 mmurolo@mt.gov

Joe Radonich, UST Class A Operator	jradonich@mt.gov
Joe Radonich, UST Class B Operator	jradonich@mt.gov
Nick Rosenbaum, UST Class B Operator	nrosenbaum@mt.gov
Tracy Deeds, UST Class A Operator	mmurolo@mt.gov
Walt Kerttula, UST Class A Operator	wkerttula@mt.gov

Tank Code	04	Tank Age	35	Tank Installed Date	12/01/1991	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	2892	Spill Test Date	07/30/2024	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection		Vapor Recovery	No
Capacity	10000	ATG Test Date	07/30/2024	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	07/30/2024			ATG Type	Gilbarco/EMC Basic				
Tank Code	05	Tank Age	35	Tank Installed Date	12/01/1991	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	2893	Spill Test Date	07/30/2024	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection		Vapor Recovery	No
Capacity	12000	ATG Test Date	07/30/2024	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	07/30/2024			ATG Type	Gilbarco/EMC Basic				

Facility Summary in Flathead County in the City of Kalispell

Location: MICHAELS WEST FACILITY
1011 US Hwy 2 W
Kalispell, MT 59901-3800 Flathead

System Facility ID:15-02330

Facility Code: 20571
Last Inspected On: 12/17/2024
Operating Permit Renewal Date: 09/25/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: S AND M LLC (406) 253-2458 MAHAYES801@GMAIL.COM

Operator Contact: Christina Turner;Michael Hayes;Tiffany Howard (406) 253-2458 christinackt948@gmail.com;hayes6@centurytel.net;vwgirl_1117@yahoo.com

Owner/Operator: S AND M LLC (406) 253-2458 MAHAYES801@GMAIL.COM

Alice Reeves, UST Class B Operator	
Christina Turner, UST Class A Operator	christinackt948@gmail.com
Michael Hayes, UST Class A Operator	hayes6@centurytel.net
Tiffany Howard, UST Class A Operator	vwgirl_1117@yahoo.com
Tiffany Howard, UST Class B Global Operator	vwgirl_1117@yahoo.com
Tiffany Howard, UST Class B Operator	vwgirl_1117@yahoo.com

Tank Code	30	Tank Age	34	Tank Installed Date	12/01/1992	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	654	Spill Test Date	08/13/2024	Piping Installed Date	07/01/2024	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	Yes
Capacity	12000	ATG Test Date	12/11/2024	Line Tightness Test Date	08/09/2024	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	08/13/2024			ATG Type	Franklin Fueling Systems/EVO 600				
Tank Code	31	Tank Age	34	Tank Installed Date	12/01/1992	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	655	Spill Test Date	08/13/2024	Piping Installed Date	07/01/2024	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	Yes

Capacity	12000	ATG Test Date	12/11/2024	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	08/13/2024			ATG Type	Franklin Fueling Systems/EVO 600				
Tank Code	32	Tank Age	34	Tank Installed Date	12/01/1992	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	656	Spill Test Date	08/13/2024	Piping Installed Date	07/01/2024	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	Yes
Capacity	12000	ATG Test Date	12/11/2024	Line Tightness Test Date	03/12/2015	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	08/13/2024			ATG Type	Franklin Fueling Systems/EVO 600				
Tank Code	33	Tank Age	33	Tank Installed Date	04/01/1993	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	657	Spill Test Date	08/13/2024	Piping Installed Date	07/01/2024	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	12000	ATG Test Date	12/11/2024	Line Tightness Test Date	08/09/2024	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	08/13/2024			ATG Type	Franklin Fueling Systems/EVO 600				
Tank Code	34	Tank Age	33	Tank Installed Date	04/01/1993	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	658	Spill Test Date	08/13/2024	Piping Installed Date	07/01/2024	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel, Dyed	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	8000	ATG Test Date	12/11/2024	Line Tightness Test Date	08/09/2024	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	08/13/2024			ATG Type	Franklin Fueling Systems/EVO 600				

Tank Code	35	Tank Age	33	Tank Installed Date	04/01/1993	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	659	Spill Test Date	08/13/2024	Piping Installed Date	07/01/2024	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	4000	ATG Test Date	12/11/2024	Line Tightness Test Date	08/09/2024	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	08/13/2024			ATG Type	Franklin Fueling Systems/EVO 600				
Tank Code	36	Tank Age	33	Tank Installed Date	06/01/1993	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	660	Spill Test Date	08/13/2024	Piping Installed Date	07/01/2024	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	Yes
Capacity	4000	ATG Test Date	12/11/2024	Line Tightness Test Date	08/09/2024	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	08/13/2024			ATG Type	Franklin Fueling Systems/EVO 600				

Facility Summary in Flathead County in the City of Kalispell

Location: MOUNTAIN WEST COOP KALISPELL
700 Rail Park Dr
Kalispell, MT 59901 Flathead

System Facility ID:60-15343

Facility Code: 32409
Last Inspected On: 08/30/2023
Operating Permit Renewal Date: 09/08/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Mountain West Cooperative (406) 543-8383

Operator Contact: Banee Simonsen;Mountain West Coop;Dusty Smith;Mountain West Coop;Michael Gourley;CHS Inc Inver Grove Heights;Vanee Simonsen;Mountain West Cooperative (406) 370-3920;(800) 232-3638;(406) 543-8383;(406) 777-5441 banee.simonsen@chsinc.com;dusty.smith@chsinc.com;michael.gourley@chsinc.com;mary.blel@chsinc.com;Vanee.Simonsen@chsinc.com

Owner/Operator: Mountain West Cooperative (406) 543-8383

Banee Simonsen, UST Class A Operator
Dusty Smith, UST Class A Operator
Dusty Smith, UST Class B Operator
Michael Gourley, UST Class A Operator
Vanee Simonsen, UST Class A Operator
Vanee Simonsen, UST Class B Operator

banee.simonsen@chsinc.com
dusty.smith@chsinc.com
dusty.smith@chsinc.com
mary.blel@chsinc.com
Vanee.Simonsen@chsinc.com
Vanee.Simonsen@chsinc.com

Tank Code	01	Tank Age	6	Tank Installed Date	03/09/2020	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	5963	Spill Test Date	08/30/2023	Piping Installed Date	03/09/2020	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	08/30/2023	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	08/30/2023	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	Yes
Capacity	4000	ATG Test Date	08/30/2023	Line Tightness Test Date		Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	08/30/2023			ATG Type					
Tank Code	02	Tank Age	6	Tank Installed Date	03/09/2020	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	5964	Spill Test Date	08/30/2023	Piping Installed Date	03/09/2020	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	08/30/2023	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	08/30/2023	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No

Capacity	8000	ATG Test Date	08/30/2023	Line Tightness Test Date		Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	08/30/2023			ATG Type					
Tank Code	03	Tank Age	6	Tank Installed Date	03/09/2020	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	5965	Spill Test Date	08/30/2023	Piping Installed Date	03/09/2020	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	08/30/2023	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	08/30/2023	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	4000	ATG Test Date	08/30/2023	Line Tightness Test Date		Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	08/30/2023			ATG Type					
Tank Code	04	Tank Age	6	Tank Installed Date	03/09/2020	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	5966	Spill Test Date	08/30/2023	Piping Installed Date	03/09/2020	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	08/30/2023	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	08/30/2023	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	Yes
Capacity	8000	ATG Test Date	08/30/2023	Line Tightness Test Date		Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	08/30/2023			ATG Type					
Tank Code	05	Tank Age	6	Tank Installed Date	03/09/2020	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	5967	Spill Test Date	08/30/2023	Piping Installed Date	03/09/2020	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	08/30/2023	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel, Dyed	PLLD Test Date	08/30/2023	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	7000	ATG Test Date	08/30/2023	Line Tightness Test Date		Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	08/30/2023			ATG Type					

Facility Summary in Flathead County in the City of Kalispell

Location: ON YOUR WAY 103
1278 US Hwy 2 E
Kalispell, MT 59901-3219 Flathead

System Facility ID:15-09707

Facility Code: 20803
Last Inspected On: 08/09/2023
Operating Permit Renewal Date: 09/04/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Indian Brothers LLC (406) 759-5538 chestersupermarket@gmail.com

Operator Contact: Tiffany Howard vwgirl_1117@yahoo.com

Owner/Operator: Indian Brothers LLC (406) 759-5538 chestersupermarket@gmail.com

Sharon Trickey, UST Class B Global Operator
Sharon Trickey, UST Class B Operator
Sherry Doyle, UST Class B Global Operator
Tiffany Howard, UST Class A Operator
Tiffany Howard, UST Class B Global Operator
Tiffany Howard, UST Class B Operator

trickeykid@gmail.com
trickeykid@gmail.com
sherryhabtech2@yahoo.com
vwgirl_1117@yahoo.com
vwgirl_1117@yahoo.com
vwgirl_1117@yahoo.com

Tank Code	01	Tank Age	41	Tank Installed Date	06/01/1985	Tank Material	Cathodically Protected Steel	Piping Material	Steel	Overfill Types	Ball Float Valve
Tag Number	3005	Spill Test Date	09/19/2023	Piping Installed Date		Tank Construction		Piping Construction	Single Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date	08/07/2023	Tank/Piping CP Test Date	08/09/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	Yes
Capacity	12000	ATG Test Date	08/09/2023	Line Tightness Test Date	10/08/2020	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	08/09/2023			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	02	Tank Age	41	Tank Installed Date	06/01/1985	Tank Material	Cathodically Protected Steel	Piping Material	Steel	Overfill Types	Ball Float Valve
Tag Number	3006	Spill Test Date	09/19/2023	Piping Installed Date		Tank Construction		Piping Construction	Single Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date	08/07/2023	Tank/Piping CP Test Date	08/09/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	Yes
Capacity	12000	ATG Test Date	08/09/2023	Line Tightness Test Date	10/08/2020	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No

		Overfill Test Date	08/09/2023			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	03	Tank Age	41	Tank Installed Date	06/01/1985	Tank Material	Cathodically Protected Steel	Piping Material	Steel	Overfill Types	Ball Float Valve
Tag Number	3007	Spill Test Date	09/19/2023	Piping Installed Date		Tank Construction		Piping Construction	Single Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date	08/07/2023	Tank/Piping CP Test Date	08/09/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	Yes
Capacity	10000	ATG Test Date	08/09/2023	Line Tightness Test Date	10/08/2020	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	08/09/2023			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	04	Tank Age	41	Tank Installed Date	06/01/1985	Tank Material	Cathodically Protected Steel	Piping Material	Steel	Overfill Types	Ball Float Valve
Tag Number	3008	Spill Test Date	08/07/2023	Piping Installed Date		Tank Construction		Piping Construction	Single Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Diesel	PLLD Test Date	08/07/2023	Tank/Piping CP Test Date	08/09/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	10000	ATG Test Date	08/09/2023	Line Tightness Test Date	10/08/2020	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	08/09/2023			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Flathead County in the City of Kalispell

Location: RED EAGLE AVIATION INC
1880 US Hwy 93 S
Kalispell, MT 59901-5729 Flathead

System Facility ID:15-11166

Facility Code: 20921
Last Inspected On: 04/14/2026
Operating Permit Renewal Date: 09/14/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Red Eagle Aviation Inc (406) 755-2376

Operator Contact: Chris Nance;Red Eagle Aviation Inc (406) 755-2376 chris@redeagleaviation.com

Owner/Operator: Red Eagle Aviation Inc (406) 755-2376

Chris Nance, UST Class A Operator
Chris Nance, UST Class B Operator

chris@redeagleaviation.com
chris@redeagleaviation.com

Tank Code	03	Tank Age	45	Tank Installed Date	01/01/1981	Tank Material	Bare Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	4144	Spill Test Date	09/30/2022	Piping Installed Date		Tank Construction	Lined Interior/Impressed Current	Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date	08/24/2023	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Aviation Gas	PLLD Test Date		Tank/Piping CP Test Date	08/24/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	12000	ATG Test Date	08/24/2023	Line Tightness Test Date	08/24/2023	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	08/24/2023			ATG Type	Incon/TS-1000				
Tank Code	04	Tank Age	45	Tank Installed Date	01/01/1981	Tank Material	Bare Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	4173	Spill Test Date	09/30/2022	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Jet Fuel (Jet-A, Jet-A1, JP5)	PLLD Test Date		Tank/Piping CP Test Date	08/24/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection		Vapor Recovery	No
Capacity	12000	ATG Test Date	08/24/2023	Line Tightness Test Date	11/28/2011	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	08/24/2023			ATG Type	Incon/TS-1000				

Facility Summary in Flathead County in the City of Kalispell

Location: RMC KALISPELL SHOP
2214 US Hwy 2 E
Kalispell, MT 59901-2816 Flathead

System Facility ID:15-04359

Facility Code: 20634
Last Inspected On: 05/05/2023
Operating Permit Renewal Date: 09/03/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Rocky Mountain Contractors Inc Kalispell

Operator Contact: Leona Prezeau

(406) 756-6012

leona.prezeau@rmcontractors.com

Owner/Operator: Rocky Mountain Contractors Inc Kalispell

Leona Prezeau, UST Class A Operator
Leona Prezeau, UST Class B Operator

leona.prezeau@rmcontractors.com
leona.prezeau@rmcontractors.com

Tank Code	03	Tank Age	32	Tank Installed Date	01/01/1994	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	1284	Spill Test Date	03/15/2022	Piping Installed Date		Tank Construction		Piping Construction	Single Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection		Vapor Recovery	No
Capacity	12000	ATG Test Date	05/05/2023	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	03/15/2022			ATG Type	Gilbarco-Veeder Root/TLS-300				
Tank Code	04	Tank Age	32	Tank Installed Date	01/01/1994	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	1285	Spill Test Date	03/15/2022	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection		Vapor Recovery	No
Capacity	12000	ATG Test Date	05/05/2023	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	03/15/2022			ATG Type	Gilbarco-Veeder Root/TLS-300				

Facility Summary in Flathead County in the City of Kalispell

Location: SMITHS FUEL CENTER 172
195 3rd Ave E N
Kalispell, MT 59901-4051 Flathead

System Facility ID:56-14062

Facility Code: 30715
Last Inspected On: 08/30/2023
Operating Permit Renewal Date: 11/04/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Smiths Food and Drug	(801) 974-1400	roger.gough@sfdc.com
Operator Contact: Braxton Hill;David Harris;Gary Dotseth;James Dye;Kerry Busey;Michael Crumley;Ronnie Houtekamer;Steven Perkins;Todd Dotseth	(406) 454-1359;(406) 788-2338;(801) 560-0471;(801) 974-1317;(801) 977-2012	braxton.hill@sfdc.com;david.harris@sfdc.com;jim.dye@sfdc.com;kerry.busey@sfdc.com;mike.crumley@kenecopetro.com;petrocompliance@gmail.com;ronnie.houtekamer@sfdc.com;steven.perkins@sfdc.com

Owner/Operator: Smiths Food and Drug	(801) 974-1400	roger.gough@sfdc.com
Braxton Hill, UST Class A Operator		braxton.hill@sfdc.com
Braxton Hill, UST Class B Operator		braxton.hill@sfdc.com
David Harris, UST Class A Operator		david.harris@sfdc.com
David Harris, UST Class B Global Operator		david.harris@sfdc.com
Gary Dotseth, UST Class A Operator		petrocompliance@gmail.com
Gary Dotseth, UST Class B Global Operator		petrocompliance@gmail.com
James Dye, UST Class A Operator		jim.dye@sfdc.com
James Dye, UST Class B Global Operator		jim.dye@sfdc.com
Kerry Busey, UST Class A Operator		kerry.busey@sfdc.com
Kerry Busey, UST Class B Global Operator		kerry.busey@sfdc.com
Michael Crumley, UST Class A Operator		mike.crumley@kenecopetro.com
Michael Crumley, UST Class B Global Operator		mike.crumley@kenecopetro.com
Ronnie Houtekamer, UST Class A Operator		ronnie.houtekamer@sfdc.com
Ronnie Houtekamer, UST Class B Global Operator		ronnie.houtekamer@sfdc.com
Steven Perkins, UST Class A Operator		steven.perkins@sfdc.com
Steven Perkins, UST Class B Global Operator		steven.perkins@sfdc.com
Todd Dotseth, UST Class A Operator		petrocompliance@gmail.com
Todd Dotseth, UST Class B Operator		petrocompliance@gmail.com

Tank Code	01	Tank Age	24	Tank Installed Date	08/23/2002	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve;Flapper Valve;High Level Alarm
Tag Number	4742	Spill Test Date	08/16/2023	Piping Installed Date	08/23/2002	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	08/24/2023	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible

Product	Gasoline	PLLD Test Date	08/24/2023	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	Yes
Capacity	20000	ATG Test Date	08/24/2023	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	Yes
		Overfill Test Date	08/16/2023			ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	02	Tank Age	24	Tank Installed Date	08/23/2002	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve;Flapper Valve;High Level Alarm
Tag Number	4743	Spill Test Date	08/16/2023	Piping Installed Date	08/23/2002	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	08/24/2023	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	08/24/2023	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	Yes
Capacity	8000	ATG Test Date	08/24/2023	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	Yes
		Overfill Test Date	08/16/2023			ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	03	Tank Age	24	Tank Installed Date	08/23/2002	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	4744	Spill Test Date	08/16/2023	Piping Installed Date	08/23/2002	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	08/24/2023	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	08/24/2023	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	8000	ATG Test Date	08/24/2023	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	Yes
		Overfill Test Date	08/16/2023			ATG Type	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Flathead County in the City of Kalispell

Location: TOWN PUMP INC KALISPELL 1
445 W Idaho St
Kalispell, MT 59901 Flathead

System Facility ID:15-08709

Facility Code: 20764
Last Inspected On: 03/26/2026
Operating Permit Renewal Date: 09/11/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Kalispell 1 Town Pump LLC (406) 497-6700 environmental@townpump.com

Operator Contact: Trent Biggers Trentb@townpump.com

Owner/Operator: Kalispell 1 Town Pump LLC (406) 497-6700 environmental@townpump.com

Trent Biggers, UST Class A Operator

Trentb@townpump.com

Trent Biggers, UST Class B Global Operator

Trentb@townpump.com

Tank Code	02	Tank Age	44	Tank Installed Date	04/14/1982	Tank Material	Bare Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	2425	Spill Test Date	09/15/2022	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date	04/20/2021	Tank/Piping CP Test Date	09/15/2022	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	12000	ATG Test Date	10/12/2023	Line Tightness Test Date	10/12/2023	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	09/15/2022			ATG Type	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Code	06	Tank Age	29	Tank Installed Date	05/28/1997	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve; Flapper Valve
Tag Number	2426	Spill Test Date	05/08/2025	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Single Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	04/20/2021	Tank/Piping CP Test Date		Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	6000	ATG Test Date	10/12/2023	Line Tightness Test Date	10/12/2023	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	05/08/2025			ATG Type	Gilbarco-Veeder Root/TLS-450PLUS				

Tank Code	01	Tank Age	44	Tank Installed Date	04/14/1982	Tank Material	Bare Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	4679	Spill Test Date	09/15/2022	Piping Installed Date		Tank Construction		Piping Construction	Single Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date	04/20/2021	Tank/Piping CP Test Date	09/15/2022	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	8000	ATG Test Date	10/10/2023	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	09/15/2022			ATG Type	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Code	07	Tank Age	29	Tank Installed Date	05/28/1997	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve
Tag Number	4680	Spill Test Date	09/15/2022	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	04/20/2021	Tank/Piping CP Test Date		Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	8000	ATG Test Date	10/12/2023	Line Tightness Test Date	10/12/2023	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	09/15/2022			ATG Type	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Code	08	Tank Age	22	Tank Installed Date	08/18/2004	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve
Tag Number	4939	Spill Test Date	09/15/2022	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	04/20/2021	Tank/Piping CP Test Date		Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	20000	ATG Test Date	10/12/2023	Line Tightness Test Date	10/12/2023	Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	09/15/2022			ATG Type	Gilbarco-Veeder Root/TLS-450PLUS				

Facility Summary in Flathead County in the City of Kalispell

Location: TOWN PUMP INC KALISPELL 2
1100 E Idaho St
Kalispell, MT 59901 Flathead

System Facility ID:15-13764

Facility Code: 21094
Last Inspected On: 03/27/2026
Operating Permit Renewal Date: 09/12/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Kalispell 2 Town Pump LLC

(406) 497-6700

environmental@townpump.com

Operator Contact: Trent Biggers

Trentb@townpump.com

Owner/Operator: Kalispell 2 Town Pump LLC

(406) 497-6700

environmental@townpump.com

Trent Biggers, UST Class A Operator

Trentb@townpump.com

Trent Biggers, UST Class B Global Operator

Trentb@townpump.com

Tank Code	01	Tank Age	29	Tank Installed Date	04/01/1997	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	4814	Spill Test Date	12/01/2022	Piping Installed Date	07/12/2013	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	04/21/2021	Tank/Piping CP Test Date		Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	12000	ATG Test Date	05/18/2023	Line Tightness Test Date		Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	No
		Overfill Test Date	12/01/2022			ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	02	Tank Age	29	Tank Installed Date	04/01/1997	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	4815	Spill Test Date	12/01/2022	Piping Installed Date	07/12/2013	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	04/21/2021	Tank/Piping CP Test Date		Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	12000	ATG Test Date	05/18/2023	Line Tightness Test Date		Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	No
		Overfill Test Date	12/01/2022			ATG Type	Gilbarco-Veeder Root/TLS-350				

Tank Code	03	Tank Age	29	Tank Installed Date	04/01/1997	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	4816	Spill Test Date	12/01/2022	Piping Installed Date	07/12/2013	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	04/21/2021	Tank/Piping CP Test Date		Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	12000	ATG Test Date	05/18/2023	Line Tightness Test Date		Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	No
		Overfill Test Date	12/01/2022			ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	04	Tank Age	29	Tank Installed Date	04/01/1997	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	4817	Spill Test Date	12/01/2022	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	04/21/2021	Tank/Piping CP Test Date		Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	12000	ATG Test Date	05/18/2023	Line Tightness Test Date		Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	12/01/2022			ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	05	Tank Age	29	Tank Installed Date	04/01/1997	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	4818	Spill Test Date		Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	04/21/2021	Tank/Piping CP Test Date		Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	12000	ATG Test Date	05/18/2023	Line Tightness Test Date		Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Flathead County in the City of Kalispell

Location: TOWN PUMP INC KALISPELL 3
2605 US Hwy 2 E
Kalispell, MT 59901-2363 Flathead

System Facility ID:15-13732

Facility Code: 21092
Last Inspected On: 03/27/2026
Operating Permit Renewal Date: 09/13/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Kalispell 3 Town Pump (406) 497-6700 environmental@townpump.com

Operator Contact: Trent Biggers Trentb@townpump.com

Owner/Operator: Kalispell 3 Town Pump (406) 497-6700 environmental@townpump.com
Trent Biggers, UST Class A Operator Trentb@townpump.com
Trent Biggers, UST Class B Global Operator Trentb@townpump.com

Tank Code	01	Tank Age	30	Tank Installed Date	07/01/1996	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	4766	Spill Test Date	09/13/2022	Piping Installed Date	12/02/2013	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	09/13/2022	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	Yes
Capacity	20000	ATG Test Date	05/16/2023	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	No
		Overfill Test Date	09/13/2022			ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	02	Tank Age	30	Tank Installed Date	07/01/1996	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	4767	Spill Test Date	09/13/2022	Piping Installed Date	12/02/2013	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	09/13/2022	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	Yes
Capacity	15000	ATG Test Date	05/16/2023	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	No
		Overfill Test Date	09/13/2022			ATG Type	Gilbarco-Veeder Root/TLS-350				

Tank Code	03	Tank Age	30	Tank Installed Date	07/01/1996	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	4768	Spill Test Date	09/13/2022	Piping Installed Date	12/02/2013	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	09/13/2022	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	15000	ATG Test Date	05/16/2023	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	No
		Overfill Test Date	09/13/2022			ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	04	Tank Age	30	Tank Installed Date	07/01/1996	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	4769	Spill Test Date	09/13/2022	Piping Installed Date	12/02/2013	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	09/13/2022	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	8000	ATG Test Date	05/16/2023	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	No
		Overfill Test Date	09/13/2022			ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	05	Tank Age	30	Tank Installed Date	07/01/1996	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	4770	Spill Test Date	09/13/2022	Piping Installed Date	12/02/2013	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	09/13/2022	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	8000	ATG Test Date	05/16/2023	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	No
		Overfill Test Date	09/13/2022			ATG Type	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Flathead County in the City of Kalispell

Location: TOWN PUMP INC KALISPELL 5
2910 US Hwy 93 S
Kalispell, MT 59901-7901 Flathead

System Facility ID:15-13765

Facility Code: 21095
Last Inspected On: 03/25/2026
Operating Permit Renewal Date: 09/14/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Kalispell 5 Town Pump LLC (406) 497-6700 environmental@townpump.com

Operator Contact: Trent Biggers Trentb@townpump.com

Owner/Operator: Kalispell 5 Town Pump LLC (406) 497-6700 environmental@townpump.com

Trent Biggers, UST Class A Operator

Trentb@townpump.com

Trent Biggers, UST Class B Global Operator

Trentb@townpump.com

Tank Code	01	Tank Age	30	Tank Installed Date	09/01/1996	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	3430	Spill Test Date	08/25/2022	Piping Installed Date	04/20/2011	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	08/25/2023	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	05/17/2023	Tank/Piping CP Test Date		Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	15000	ATG Test Date	05/17/2023	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	No
		Overfill Test Date	08/25/2022			ATG Type	Gilbarco-Veeder Root/TLS-450				
Tank Code	02	Tank Age	30	Tank Installed Date	09/01/1996	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	3431	Spill Test Date	06/01/2022	Piping Installed Date	04/20/2011	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	15000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-450				

Tank Code	03	Tank Age	30	Tank Installed Date	09/01/1996	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve;Positive Shutoff
Tag Number	3432	Spill Test Date	05/04/2021	Piping Installed Date	04/20/2011	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	Yes
Capacity	20000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-450				
Tank Code	04	Tank Age	8	Tank Installed Date	12/05/2018	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	5793	Spill Test Date	05/04/2021	Piping Installed Date	12/05/2018	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	6000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection	Statistical Inventory Reconciliation	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	Yes
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-450				
Tank Code	05	Tank Age	8	Tank Installed Date	12/05/2018	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	5794	Spill Test Date	05/04/2021	Piping Installed Date	12/05/2018	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	15000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection	Statistical Inventory Reconciliation	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	Yes
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-450				
Tank Code	06	Tank Age	8	Tank Installed Date	12/05/2018	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	5795	Spill Test Date	05/04/2021	Piping Installed Date	12/05/2018	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No

Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	6000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection	Statistical Inventory Reconciliation	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	Yes
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-450				
Tank Code	07	Tank Age	8	Tank Installed Date	12/05/2018	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	5796	Spill Test Date	12/30/2024	Piping Installed Date	12/05/2018	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	Yes
Capacity	6000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection	Statistical Inventory Reconciliation	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	Yes
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-450				
Tank Code	08	Tank Age	8	Tank Installed Date	12/05/2018	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	5797	Spill Test Date	05/04/2021	Piping Installed Date	12/05/2018	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	Yes
Capacity	15000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection	Statistical Inventory Reconciliation	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	Yes
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-450				
Tank Code	09	Tank Age	8	Tank Installed Date	12/05/2018	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	
Tag Number	5798	Spill Test Date		Piping Installed Date	12/05/2018	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Continuous Interstitial Monitoring	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	DEF (Not Regulated)	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection		Primary Pipe Detection		Vapor Recovery	No

Capacity	6000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					
Tank Code	10	Tank Age	8	Tank Installed Date	12/05/2018	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	5799	Spill Test Date	05/04/2021	Piping Installed Date	12/05/2018	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	Yes
Capacity	20000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection	Statistical Inventory Reconciliation	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	Yes
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-450				

Facility Summary in Flathead County in the City of Kalispell

Location: TOWN PUMP KALISPELL 7
859 W Reserve St
Kalispell, MT 59901 Flathead

System Facility ID:60-15262

Facility Code: 30977
Last Inspected On: 03/25/2026
Operating Permit Renewal Date: 09/15/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Kalispell 7 Town Pump LLC (406) 497-6700 environmental@townpump.com

Operator Contact: Trent Biggers Trentb@townpump.com

Owner/Operator: Kalispell 7 Town Pump LLC (406) 497-6700 environmental@townpump.com

Trent Biggers, UST Class A Operator
Trent Biggers, UST Class B Operator

Trentb@townpump.com
Trentb@townpump.com

Tank Code	01	Tank Age	11	Tank Installed Date	11/04/2015	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	5604	Spill Test Date	09/12/2022	Piping Installed Date	05/28/2016	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	09/12/2022	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	05/16/2023	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	Yes
Capacity	30000	ATG Test Date	05/16/2023	Line Tightness Test Date		Secondary Tank Leak Detection	Statistical Inventory Reconciliation	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	Yes
		Overfill Test Date	09/12/2023			ATG Type	Gilbarco-Veeder Root/TLS-450				
Tank Code	02	Tank Age	11	Tank Installed Date	11/04/2015	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	5605	Spill Test Date	09/12/2022	Piping Installed Date	05/28/2016	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	09/12/2023	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	05/16/2023	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	Yes
Capacity	6000	ATG Test Date	05/16/2023	Line Tightness Test Date		Secondary Tank Leak Detection	Statistical Inventory Reconciliation	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	Yes

		Overfill Test Date	09/12/2022			ATG Type	Gilbarco-Veeder Root/TLS-450				
Tank Code	03	Tank Age	11	Tank Installed Date	11/04/2015	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	5606	Spill Test Date	09/12/2022	Piping Installed Date	05/28/2016	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	09/12/2023	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	05/16/2023	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	Yes
Capacity	15000	ATG Test Date	05/16/2023	Line Tightness Test Date		Secondary Tank Leak Detection	Statistical Inventory Reconciliation	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	Yes
		Overfill Test Date	09/12/2022			ATG Type	Gilbarco-Veeder Root/TLS-450				
Tank Code	04	Tank Age	11	Tank Installed Date	11/04/2015	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	5607	Spill Test Date	04/15/2020	Piping Installed Date	05/28/2016	Tank Construction	Double-Walled	Piping Construction	None	AST	No
Tank Status	Other	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	DEF (Not Regulated)	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Approved Remote Monitoring;Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	Yes
Capacity	6000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	Approved Remote Monitoring;Continuous Interstitial Monitoring;Not Listed	Energy Act	Yes
		Overfill Test Date				ATG Type	Veeder Root/TLS-450				
Tank Code	05	Tank Age	11	Tank Installed Date	11/04/2015	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	5608	Spill Test Date	09/12/2022	Piping Installed Date	05/28/2016	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	09/12/2023	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	05/16/2023	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No

Capacity	6000	ATG Test Date	05/16/2023	Line Tightness Test Date		Secondary Tank Leak Detection	Statistical Inventory Reconciliation	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	Yes
		Overfill Test Date	09/12/2022			ATG Type	Gilbarco-Veeder Root/TLS-450				
Tank Code	06	Tank Age	11	Tank Installed Date	11/04/2015	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	5609	Spill Test Date	09/12/2022	Piping Installed Date	05/28/2016	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	09/12/2023	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	05/16/2023	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	15000	ATG Test Date	05/16/2023	Line Tightness Test Date		Secondary Tank Leak Detection	Statistical Inventory Reconciliation	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	Yes
		Overfill Test Date	09/12/2022			ATG Type	Gilbarco-Veeder Root/TLS-450				
Tank Code	07	Tank Age	11	Tank Installed Date	11/04/2015	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	5610	Spill Test Date	09/12/2023	Piping Installed Date	05/28/2016	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	09/12/2022	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	05/16/2023	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	6000	ATG Test Date	05/16/2023	Line Tightness Test Date		Secondary Tank Leak Detection	Statistical Inventory Reconciliation	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	Yes
		Overfill Test Date	09/12/2022			ATG Type	Gilbarco-Veeder Root/TLS-450				

Facility Summary in Flathead County in the City of Kalispell

Location: WARDEN HUTTERIAN BRETHREN
295 Middle Rd
Kalispell, MT 59901-7700 Flathead

System Facility ID:15-05344

Facility Code: 20661
Last Inspected On: 11/04/2024
Operating Permit Renewal Date: 02/12/2028

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Warden Hutterian Brethren

pkwollman@gmail.com

Operator Contact: Steve Streich

(406) 253-2276

spudtruck@montanasky.net

Owner/Operator: Warden Hutterian Brethren

pkwollman@gmail.com

Steve Streich, UST Class A Operator

spudtruck@montanasky.net

Steve Streich, UST Class B Global Operator

spudtruck@montanasky.net

Tank Code	S3	Tank Age	31	Tank Installed Date	11/01/1995	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	869	Spill Test Date	11/04/2024	Piping Installed Date		Tank Construction		Piping Construction	Single Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	11/04/2024	Primary Tank Leak Detection	Manual Tank Gauging	Primary Pipe Detection		Vapor Recovery	No
Capacity	1000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	01/23/2025			ATG Type					
Tank Code	S4	Tank Age	31	Tank Installed Date	11/01/1995	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	870	Spill Test Date	11/04/2024	Piping Installed Date		Tank Construction		Piping Construction	Single Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	11/04/2024	Primary Tank Leak Detection	Manual Tank Gauging	Primary Pipe Detection		Vapor Recovery	No
Capacity	1000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	01/23/2025			ATG Type					

Facility Summary in Flathead County in the City of Kalispell

Location: WEST VALLEY SCHOOL DIST 1
2290 Farm To Market Rd
Kalispell, MT 59901-7108 Flathead

System Facility ID:15-10295

Facility Code: 20846
Last Inspected On: 04/02/2026
Operating Permit Renewal Date: 08/24/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: School Dist 1 West Valley

crisher@westvalleyschool.com

Operator Contact: Phillip Jackson

(406) 755-7239

pjackson@westvalleyschool.com

Owner/Operator: School Dist 1 West Valley

crisher@westvalleyschool.com

Phillip Jackson, UST Class A Operator

pjackson@westvalleyschool.com

Phillip Jackson, UST Class B Operator

pjackson@westvalleyschool.com

Tank Code	S2	Tank Age	31	Tank Installed Date	08/09/1995	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Copper	Overfill Types	Flapper Valve
Tag Number	2249	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	Secondary Containment Chase	AST	No
Tank Status	Temporarily Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	U.S. Suction	CP Met Types	Non-corrodible
Product	Heating Oil	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Manual Tank Gauging	Primary Pipe Detection	3-Year Line Tightness Test	Vapor Recovery	No
Capacity	1000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					

Facility Summary in Flathead County in the City of Kalispell

Location: WHITE OAK SUPER STOP
4810 US Hwy 93 S
Kalispell, MT 59901-7985 Flathead

System Facility ID:15-13287

Facility Code: 21043
Last Inspected On: 09/13/2023
Operating Permit Renewal Date: 10/17/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Greg Tabish;Tabish Brothers Distributors Inc

lss@gwpetrol.com;zootown@gwpetrol.com

Operator Contact: Amber Terrell;Karly Shafer;Kristy Stevenson

(406) 396-2206;(406) 857-2344;(406) 871-8400

ambert2007@gmail.com;karly@gwpetrol.com;kristyinmontana@gmail.com

Owner/Operator: Greg Tabish

zootown@gwpetrol.com

Owner/Operator: Tabish Brothers Distributors Inc

zootown@gwpetrol.com

Amber Terrell, UST Class A Operator

ambert2007@gmail.com

Amber Terrell, UST Class B Operator

ambert2007@gmail.com

Karly Shafer, UST Class A Operator

karly@gwpetrol.com

Karly Shafer, UST Class B Global Operator

karly@gwpetrol.com

Kristy Stevenson, UST Class A Operator

kristyinmontana@gmail.com

Tank Code	01	Tank Age	43	Tank Installed Date	10/01/1983	Tank Material	Bare Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	4481	Spill Test Date		Piping Installed Date	09/01/2017	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	11/18/2017	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	10000	ATG Test Date		Line Tightness Test Date	10/09/2019	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	09/12/2023			ATG Type	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Code	02	Tank Age	43	Tank Installed Date	11/01/1983	Tank Material	Bare Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	4482	Spill Test Date		Piping Installed Date	09/01/2017	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	11/18/2017	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No

Capacity	10000	ATG Test Date		Line Tightness Test Date	10/09/2019	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-450				
Tank Code	03	Tank Age	43	Tank Installed Date	11/01/1983	Tank Material	Bare Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	4483	Spill Test Date		Piping Installed Date	09/01/2017	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	11/18/2017	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	6000	ATG Test Date		Line Tightness Test Date	10/09/2019	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date				ATG Type	Veeder Root/TLS-450				
Tank Code	04	Tank Age	9	Tank Installed Date	09/01/2017	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	5781	Spill Test Date	09/12/2023	Piping Installed Date	09/01/2017	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	20000	ATG Test Date		Line Tightness Test Date	10/09/2019	Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-450PLUS;Veeder Root/TLS-450PLUS				

Facility Summary in Flathead County in the City of Kalispell

Location: WOODLAND QUIKSTOP
81 Woodland Park Dr
Kalispell, MT 59901-4665 Flathead

System Facility ID:15-00115

Facility Code: 20518
Last Inspected On: 03/11/2025
Operating Permit Renewal Date: 06/11/2028

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Kalispell Properties LLC (509) 994-6599 histarms01@yahoo.com

Operator Contact: Semere Kentiba sammyimagination@gmail.com

Owner/Operator: Kalispell Properties LLC (509) 994-6599 histarms01@yahoo.com

Semere Kentiba, UST Class A Operator sammyimagination@gmail.com
Semere Kentiba, UST Class B Global Operator sammyimagination@gmail.com

Tank Code	03	Tank Age	28	Tank Installed Date	07/23/1998	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Positive Shutoff
Tag Number	3524	Spill Test Date	07/09/2025	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	10000	ATG Test Date	03/11/2025	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	07/09/2025			ATG Type	Gilbarco/EMC Basic				
Tank Code	04	Tank Age	28	Tank Installed Date	07/23/1998	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Positive Shutoff
Tag Number	3525	Spill Test Date	02/11/2025	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	12000	ATG Test Date	03/11/2025	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	07/09/2025			ATG Type	Gilbarco/EMC Basic				

Facility Summary in Flathead County in the City of Kalispell

Location: WOODYS COUNTRY STORE INC
3333 MT Hwy 35
Kalispell, MT 59901-7724 Flathead

System Facility ID:15-05801

Facility Code: 20677
Last Inspected On: 11/06/2023
Operating Permit Renewal Date: 03/17/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Woodys Country Store Inc (406) 755-5544

Operator Contact: Charles Weiss (406) 755-5544 charlesalanweis@gmail.com

Owner/Operator: Woodys Country Store Inc (406) 755-5544

Charles Weiss, UST Class A Operator
Charles Weiss, UST Class B Operator

charlesalanweis@gmail.com
charlesalanweis@gmail.com

Tank Code	01	Tank Age	42	Tank Installed Date	12/05/1984	Tank Material	Bare Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	2243	Spill Test Date	10/18/2023	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	10/18/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	10000	ATG Test Date	02/10/2025	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	10/18/2023			ATG Type	Franklin Fueling Systems/EVO 600				
Tank Code	02	Tank Age	42	Tank Installed Date	12/05/1984	Tank Material	Bare Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	2244	Spill Test Date	10/18/2023	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	10/18/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	10000	ATG Test Date	02/10/2025	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	10/18/2023			ATG Type	Franklin Fueling Systems/EVO 600				
Tank Code	03	Tank Age	42	Tank Installed Date	12/05/1984	Tank Material	Bare Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	2245	Spill Test Date	10/18/2023	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No

Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	10/18/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	10000	ATG Test Date	02/10/2025	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	10/18/2023			ATG Type	Franklin Fueling Systems/EVO 600				

Facility Summary in Flathead County in the City of Kalispell

Location: ZIP TRIP 39
305 E Idaho St
Kalispell, MT 59901-4134 Flathead

System Facility ID:15-03915

Facility Code: 20624
Last Inspected On: 08/14/2024
Operating Permit Renewal Date: 08/14/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: CHS Inc Spokane Valley (509) 535-7701 jim.alford@chsinc.com

Operator Contact: Jim Alford (509) 536-7418 jim.alford@chsinc.com

Owner/Operator: CHS Inc Spokane Valley (509) 535-7701 jim.alford@chsinc.com

Andrew Duffie, UST Class B Operator	duffstars@yahoo.com
Ian Johnstone, UST Class B Global Operator	ianj@ziptrip.net
Jim Alford, UST Class A Operator	jim.alford@chsinc.com
Jim Alford, UST Class B Global Operator	jim.alford@chsinc.com
Justin Mace, UST Class B Operator	minuzle@gmail.com
Wesley Bentley, UST Class B Operator	wesley.bentley@chsinc.com

Tank Code	08	Tank Age	3	Tank Installed Date	09/06/2023	Tank Material	Steel Clad	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	6196	Spill Test Date	01/09/2024	Piping Installed Date	09/06/2023	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	Yes
Capacity	14000	ATG Test Date	01/17/2024	Line Tightness Test Date		Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	01/09/2024			ATG Type					
Tank Code	09	Tank Age	3	Tank Installed Date	09/06/2023	Tank Material	Steel Clad	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	6197	Spill Test Date	01/09/2024	Piping Installed Date	09/06/2023	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	Yes

Capacity	6000	ATG Test Date	01/17/2024	Line Tightness Test Date		Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	01/09/2024			ATG Type					
Tank Code	10	Tank Age	3	Tank Installed Date	09/06/2023	Tank Material	Steel Clad	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	6198	Spill Test Date	01/09/2024	Piping Installed Date	09/06/2023	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	14000	ATG Test Date	01/17/2024	Line Tightness Test Date		Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	01/09/2024			ATG Type					
Tank Code	11	Tank Age	3	Tank Installed Date	09/06/2023	Tank Material	Steel Clad	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	6199	Spill Test Date	01/09/2024	Piping Installed Date	09/06/2023	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	Yes
Capacity	6000	ATG Test Date	01/17/2024	Line Tightness Test Date		Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	01/09/2024			ATG Type					

Facility Summary in Flathead County in the City of Kalispell

Location: ZIP TRIP 40
1420 1st Ave E
Kalispell, MT 59901 Flathead

System Facility ID:15-02331

Facility Code: 20572
Last Inspected On: 12/02/2025
Operating Permit Renewal Date: 03/14/2029

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: CHS Inc Spokane Valley (509) 535-7701 jim.alford@chsinc.com

Operator Contact: Jim Alford;Sean Hurley (509) 535-7701;(509) 536-7418 jim.alford@chsinc.com;sean.hurley@chsinc.com

Owner/Operator: CHS Inc Spokane Valley (509) 535-7701 jim.alford@chsinc.com

Jason Brenner, UST Class B Operator jason.brenner@chsinc.com
 Jim Alford, UST Class A Operator jim.alford@chsinc.com
 Jim Alford, UST Class B Operator jim.alford@chsinc.com
 Luci Tuttle, UST Class B Operator Lucinda.Tuttle@chsinc.com
 Sean Hurley, UST Class A Operator sean.hurley@chsinc.com

Tank Code	01	Tank Age	44	Tank Installed Date	04/30/1982	Tank Material	Bare Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve;Flapper Valve
Tag Number	1303	Spill Test Date	12/03/2025	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date	08/05/2025	Tank/Piping CP Test Date	08/08/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	8000	ATG Test Date	08/05/2025	Line Tightness Test Date	07/26/2022	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	12/03/2025			ATG Type	Gilbarco/EMC Basic				
Tank Code	02	Tank Age	44	Tank Installed Date	04/30/1982	Tank Material	Bare Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve;Flapper Valve
Tag Number	1304	Spill Test Date	12/03/2025	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Diesel	PLLD Test Date	08/05/2025	Tank/Piping CP Test Date	08/08/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No

Capacity	8000	ATG Test Date	08/05/2025	Line Tightness Test Date	07/26/2022	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	12/03/2025			ATG Type	Gilbarco/EMC Basic				
Tank Code	03	Tank Age	44	Tank Installed Date	04/30/1982	Tank Material	Bare Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve; Flapper Valve
Tag Number	1305	Spill Test Date	12/03/2025	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date	08/05/2025	Tank/Piping CP Test Date	08/08/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	8000	ATG Test Date	08/05/2025	Line Tightness Test Date	07/26/2022	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	12/03/2025			ATG Type	Gilbarco/EMC Basic				

Facility Summary in Flathead County in the City of Kalispell

Location: ZIP TRIP 41
2490 US Hwy 93 N
Kalispell, MT 59901-2148 Flathead

System Facility ID:15-07432

Facility Code: 20730
Last Inspected On: 08/05/2025
Operating Permit Renewal Date: 11/09/2028

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: CHS Inc Spokane Valley (509) 535-7701 jim.alford@chsinc.com

Operator Contact: Jim Alford;Sean Hurley (509) 535-7701;(509) 536-7418 jim.alford@chsinc.com;sean.hurley@chsinc.com

Owner/Operator: CHS Inc Spokane Valley (509) 535-7701 jim.alford@chsinc.com

Jason Brenner, UST Class B Operator jason.brenner@chsinc.com
 Jim Alford, UST Class A Operator jim.alford@chsinc.com
 Jim Alford, UST Class B Operator jim.alford@chsinc.com
 Luci Tuttle, UST Class B Operator Lucinda.Tuttle@chsinc.com
 Sean Hurley, UST Class A Operator sean.hurley@chsinc.com

Tank Code	01	Tank Age	41	Tank Installed Date	04/23/1985	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve;Flapper Valve
Tag Number	382	Spill Test Date	02/04/2026	Piping Installed Date		Tank Construction		Piping Construction	Single Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	08/05/2025	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	08/05/2025	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	10000	ATG Test Date	08/05/2025	Line Tightness Test Date	08/05/2025	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	02/04/2026			ATG Type	Veeder Root/TLS-300				
Tank Code	02	Tank Age	41	Tank Installed Date	04/23/1985	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve;Flapper Valve
Tag Number	383	Spill Test Date	02/04/2026	Piping Installed Date		Tank Construction		Piping Construction	Single Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	08/05/2025	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	08/05/2025	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection		Vapor Recovery	No
Capacity	10000	ATG Test Date	08/05/2025	Line Tightness Test Date	08/05/2025	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No

		Overfill Test Date	02/04/2026			ATG Type	Veeder Root/TLS-300				
Tank Code	03	Tank Age	24	Tank Installed Date	06/21/2002	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve; Flapper Valve
Tag Number	4685	Spill Test Date	02/04/2026	Piping Installed Date		Tank Construction		Piping Construction	Single Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	08/05/2025	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	08/05/2025	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	10000	ATG Test Date	08/05/2025	Line Tightness Test Date	08/05/2025	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	02/04/2026			ATG Type	Veeder Root/TLS-300				

Facility Summary in Flathead County in the City of Lakeside

Location: ARIES GAS AND GROCERY
7254 US Hwy 93
Lakeside, MT 59922 Flathead

System Facility ID:15-13487

Facility Code: 21062
Last Inspected On: 08/29/2025
Operating Permit Renewal Date: 12/06/2028

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: RKR LLC (406) 890-5047 ramdeeprokha@hotmail.com

Operator Contact: Asham Singh;Janet Heinze;Ramdeep Kaur;Rod Phillips;Steven Heinze (406) 844-0336;(406) 871-7278;(406) 890-5047;(803) 522-5352 ashamjeet_singh@yahoo.com;backinblack_07@hotmail.com;ramdeeprokha@yahoo.com;sjdheinze@hotmail.com

Owner/Operator: RKR LLC (406) 890-5047 ramdeeprokha@hotmail.com

Asham Singh, UST Class A Operator ashamjeet_singh@yahoo.com
 Asham Singh, UST Class B Operator ashamjeet_singh@yahoo.com
 Janet Heinze, UST Class A Operator sjdheinze@hotmail.com
 Janet Heinze, UST Class B Operator sjdheinze@hotmail.com
 Ramdeep Kaur, UST Class A Operator ramdeeprokha@yahoo.com
 Rod Phillips, UST Class A Operator backinblack_07@hotmail.com
 Rod Phillips, UST Class B Operator backinblack_07@hotmail.com
 Steven Heinze, UST Class A Operator sjdheinze@hotmail.com

Tank Code	01	Tank Age	32	Tank Installed Date	08/01/1994	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve;Flapper Valve
Tag Number	666	Spill Test Date	08/29/2025	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date	08/29/2025	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	12000	ATG Test Date	08/29/2025	Line Tightness Test Date	08/29/2025	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	08/29/2025			ATG Type	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Code	02	Tank Age	32	Tank Installed Date	08/01/1994	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve;Flapper Valve
Tag Number	667	Spill Test Date	08/29/2025	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date	08/29/2025	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible

Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	12000	ATG Test Date	08/29/2025	Line Tightness Test Date	08/29/2025	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	08/29/2025			ATG Type	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Code	03	Tank Age	32	Tank Installed Date	08/01/1994	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve;Flapper Valve
Tag Number	668	Spill Test Date	08/29/2025	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date	08/29/2025	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	7000	ATG Test Date	08/29/2025	Line Tightness Test Date	08/29/2025	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	08/29/2025			ATG Type	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Code	04	Tank Age	32	Tank Installed Date	08/01/1994	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	669	Spill Test Date	08/29/2025	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date	08/29/2025	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel, Dyed	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	5000	ATG Test Date	08/29/2025	Line Tightness Test Date	08/29/2025	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	08/29/2025			ATG Type	Gilbarco-Veeder Root/TLS-450PLUS				

Facility Summary in Flathead County in the City of Lakeside

Location: ARSR GATR BLDG
 Blacktail Mountain Rd
 Lakeside, MT 59922 Flathead

System Facility ID:15-03618

Facility Code: 20613
Last Inspected On: 02/14/2024
Operating Permit Renewal Date: 02/19/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Federal Aviation Admin Renton (206) 227-2367

Operator Contact: Rob Jodsaas rob.jodsaas@faa.gov

Owner/Operator: Federal Aviation Admin Renton (206) 227-2367

Rob Jodsaas, UST Class A Operator
 Rob Jodsaas, UST Class B Operator

rob.jodsaas@faa.gov
 rob.jodsaas@faa.gov

Tank Code	S5	Tank Age	30	Tank Installed Date	09/25/1996	Tank Material	Unknown	Piping Material	Flexible Plastic	Overfill Types	
Tag Number	4565	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	Yes
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Auto Dialer	Piping Type	Pressurized	CP Met Types	
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection		Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	2000	ATG Test Date	02/14/2024	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					

Facility Summary in Flathead County in the City of Lakeside

Location: JOE BLOGZ
7170 US Hwy 93 S
Lakeside, MT 59922-9728 Flathead

System Facility ID:15-10513

Facility Code: 20867
Last Inspected On: 11/20/2024
Operating Permit Renewal Date: 02/20/2028

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: FH Properties LLC (509) 833-6629 JoeBlogz@gmail.com

Operator Contact: Atinderpal Chana;FH Properties LLC (509) 833-6629 Joeblogzcasino@gmail.com;JoeBlogz@gmail.com

Owner/Operator: FH Properties LLC (509) 833-6629 JoeBlogz@gmail.com

Atinderpal Chana, UST Class A Operator

JoeBlogz@gmail.com

Atinderpal Chana, UST Class B Operator

JoeBlogz@gmail.com

Tank Code	01	Tank Age	41	Tank Installed Date	03/07/1985	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	3798	Spill Test Date	11/20/2024	Piping Installed Date	04/01/1999	Tank Construction	Lined Interior/Impressed Current	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	11/20/2024	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	8000	ATG Test Date	11/20/2024	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	11/20/2024			ATG Type	Gilbarco/EMC Basic				
Tank Code	02	Tank Age	41	Tank Installed Date	03/07/1985	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	3799	Spill Test Date	11/20/2024	Piping Installed Date	04/01/1999	Tank Construction	Lined Interior/Impressed Current	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	11/20/2024	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	8000	ATG Test Date	11/20/2024	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	11/20/2024			ATG Type	Gilbarco/EMC Basic				

Facility Summary in Flathead County in the City of Lakeside

Location: MOCCASIN LODGE LLC
 616 Lutheran Camp Rd
 Lakeside, MT 59922 Flathead

System Facility ID:56-14069

Facility Code: 30721
Last Inspected On: 11/15/2023
Operating Permit Renewal Date: 02/19/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Moccasin Lodge LLC (406) 844-3569 kgnelson@centurytel.net

Operator Contact: Kathleen Nelson (406) 253-1021 kgnelson@centurytel.net

Owner/Operator: Moccasin Lodge LLC (406) 844-3569 kgnelson@centurytel.net

Kathleen Nelson, UST Class A Operator kgnelson@centurytel.net
 Kathleen Nelson, UST Class B Operator kgnelson@centurytel.net

Tank Code	S1	Tank Age	24	Tank Installed Date	12/30/2002	Tank Material	Steel Clad	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	4781	Spill Test Date	11/15/2023	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Temporarily Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Auto Dialer	Piping Type	U.S. Suction	CP Met Types	Non-corrodible
Product	Heating Oil	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Manual Tank Gauging	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	1600	ATG Test Date	11/15/2023	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	11/15/2023			ATG Type					

Facility Summary in Flathead County in the City of Marion

Location: CABIN CREEK LANDING LLC
166 Wright Way
Marion, MT 59925-9874 Flathead

System Facility ID:56-14102

Facility Code: 30745
Last Inspected On: 04/13/2026
Operating Permit Renewal Date: 04/04/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Tom Jacobs (253) 686-8587 tjacobs@jacobsandjacobs.net

Operator Contact:

Owner/Operator: Tom Jacobs (253) 686-8587 tjacobs@jacobsandjacobs.net

Tank Code	01	Tank Age	22	Tank Installed Date	02/09/2004	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	4883	Spill Test Date	09/08/2022	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Temporarily Out of Use	MLLD Test Date	09/08/2022	Sump Tightness Test Date	09/08/2022	Catastrophic L.D Type 3.0	Continuous Interstitial Monitoring; Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Aviation Gas	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	6000	ATG Test Date	09/08/2022	Line Tightness Test Date	09/08/2022	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	09/08/2022			ATG Type	Gilbarco-Veeder Root/EMC Basic				

Facility Summary in Flathead County in the City of Marion

Location: CANI INC
8205 US Hwy 2 W
Marion, MT 59925-9740 Flathead

System Facility ID:56-13803

Facility Code: 30490
Last Inspected On: 07/08/2025
Operating Permit Renewal Date: 11/06/2028

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: CANI Inc (406) 261-5912 caniincstore@gmail.com

Operator Contact: Tonia Gardner tonia159@hotmail.com

Owner/Operator: CANI Inc (406) 261-5912 caniincstore@gmail.com

Tonia Gardner, UST Class A Operator tonia159@hotmail.com
Tonia Gardner, UST Class B Operator tonia159@hotmail.com

Tank Code	01	Tank Age	29	Tank Installed Date	08/01/1997	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	834	Spill Test Date	07/08/2025	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	07/08/2025	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	07/08/2025	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	5000	ATG Test Date	07/08/2025	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	07/08/2025			ATG Type	EMCO Electronics/EECO 1500				
Tank Code	02	Tank Age	29	Tank Installed Date	08/01/1997	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	835	Spill Test Date	07/08/2025	Piping Installed Date	02/20/2015	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	07/08/2025	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	07/08/2025	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	5000	ATG Test Date	07/08/2025	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	07/08/2025			ATG Type	EMCO Electronics/EECO 1500				

Tank Code	03	Tank Age	29	Tank Installed Date	08/01/1997	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	836	Spill Test Date	07/08/2025	Piping Installed Date	02/20/2015	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	07/08/2025	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	07/08/2025	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	5000	ATG Test Date	07/08/2025	Line Tightness Test Date	02/12/2015	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	07/08/2025			ATG Type	EMCO Electronics/EECO 1500				

Facility Summary in Flathead County in the City of Olney

Location: GLACIER GOLD LLC
255 Good Creek Rd
Olney, MT 59927 Flathead

System Facility ID:15-02973

Facility Code: 20589
Last Inspected On: 01/23/2024
Operating Permit Renewal Date: 01/23/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Glacier Gold LLC

Operator Contact: Joe Warner

(406) 881-3030

glacieregold@centurytel.net

Owner/Operator: Glacier Gold LLC

Joe Warner, UST Class A Operator
Joe Warner, UST Class B Operator

glacieregold@centurytel.net
glacieregold@centurytel.net

Tank Code	03	Tank Age	38	Tank Installed Date	03/29/1988	Tank Material	Cathodically Protected Steel	Piping Material	No Piping	Overfill Types	Flapper Valve
Tag Number	3583	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Temporarily Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type		CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	01/23/2024	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection		Vapor Recovery	No
Capacity	9000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection	Automatic Tank Gauging 0.1	Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					

Facility Summary in Flathead County in the City of Olney

Location: OLNEY STORE
105 Olney Loop Rd
Olney, MT 59927 Flathead

System Facility ID:56-13849

Facility Code: 30531
Last Inspected On: 09/16/2025
Operating Permit Renewal Date: 09/16/2028

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Jon Lemburg (406) 471-5557 1lastbestplace@gmail.com

Operator Contact: Fred Peters;Jon Lemburg;Briggs Mercantile (406) 471-5557;(406) 881-2100;(406) 881-4010 1lastbestplace@gmail.com;birddog@blackfoot.net

Owner/Operator: Jon Lemburg (406) 471-5557 1lastbestplace@gmail.com

Fred Peters, UST Class A Operator
Fred Peters, UST Class B Operator
Jon Lemburg, UST Class A Operator

birddog@blackfoot.net
birddog@blackfoot.net
1lastbestplace@gmail.com

Tank Code	03	Tank Age	28	Tank Installed Date	06/01/1998	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	3504	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Temporarily Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	09/16/2025	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection		Vapor Recovery	No
Capacity	1000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type	EMCO Electronics/EECO 1500				
Tank Code	04	Tank Age	28	Tank Installed Date	06/01/1998	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	3505	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Temporarily Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	09/16/2025	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection		Vapor Recovery	No
Capacity	500	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type	EMCO Electronics/EECO 1500				

Tank Code	05	Tank Age	28	Tank Installed Date	06/01/1998	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	3506	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Temporarily Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	09/16/2025	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection		Vapor Recovery	No
Capacity	500	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type	EMCO Electronics/EECO 1500				

Facility Summary in Flathead County in the City of West Glacier

Location: GLACIER HIGHLAND RESORT
12555 US Hwy 2 E
West Glacier, MT 59936 Flathead

System Facility ID:15-10685

Facility Code: 20877
Last Inspected On: 09/14/2023
Operating Permit Renewal Date: 09/17/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Glacier Highland Resort;Joseph Hoff (406) 888-5427 glacierhighland@gmail.com

Operator Contact: Joseph Hoff bubba284@icloud.com

Owner/Operator: Glacier Highland Resort (406) 888-5427 glacierhighland@gmail.com

Owner/Operator: Joseph B Hoff (406) 888-5427 glacierhighland@gmail.com

Joseph Hoff, UST Class A Operator bubba284@icloud.com

Joseph Hoff, UST Class B Global Operator bubba284@icloud.com

Tank Code	03	Tank Age	28	Tank Installed Date	10/01/1998	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	3214	Spill Test Date	09/13/2023	Piping Installed Date		Tank Construction		Piping Construction	Single Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	09/13/2023	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	09/14/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	10000	ATG Test Date	09/13/2023	Line Tightness Test Date	09/13/2023	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	09/13/2023			ATG Type	EMCO Electronics/EECO 1500				
Tank Code	04	Tank Age	28	Tank Installed Date	10/01/1998	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	3215	Spill Test Date	09/13/2023	Piping Installed Date		Tank Construction		Piping Construction	Single Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	09/13/2023	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	09/14/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	6000	ATG Test Date	09/13/2023	Line Tightness Test Date	09/13/2023	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	09/13/2023			ATG Type	EMCO Electronics/EECO 1500				

Facility Summary in Flathead County in the City of West Glacier

Location: GLACIER PARK HDQTRS GAS PUMPS
64 Grinnell Dr
West Glacier, MT 59936-0128 Flathead

System Facility ID:15-09491

Facility Code: 20794
Last Inspected On: 04/06/2026
Operating Permit Renewal Date: 08/02/2029

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Glacier National Park

john_lucke@nps.gov

Operator Contact: Franklin Thompson;Lori King;Patrick Glynn

(406) 888-7967

frank_thompson@nps.gov;patrick_glynn@nps.gov

Owner/Operator: Glacier National Park

john_lucke@nps.gov

Franklin Thompson, UST Class A Operator
Franklin Thompson, UST Class B Operator
Lori King, UST Class A Operator
Lori King, UST Class B Operator
Patrick Glynn, UST Class A Operator
Patrick Glynn, UST Class B Operator

frank_thompson@nps.gov
frank_thompson@nps.gov

patrick_glynn@nps.gov
patrick_glynn@nps.gov

Tank Code	06	Tank Age	36	Tank Installed Date	11/01/1990	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve
Tag Number	1219	Spill Test Date	06/21/2023	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	04/06/2026	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	06/21/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	5000	ATG Test Date	04/06/2026	Line Tightness Test Date	06/21/2023	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	04/06/2026			ATG Type	Veeder Root/TLS-300				
Tank Code	07	Tank Age	36	Tank Installed Date	11/01/1990	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve
Tag Number	1220	Spill Test Date	06/21/2023	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	04/06/2026	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	04/06/2026	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No

Capacity	12000	ATG Test Date	04/06/2026	Line Tightness Test Date	07/07/2020	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	04/06/2026			ATG Type	Veeder Root/TLS-300				

Facility Summary in Flathead County in the City of West Glacier

Location: MRC GAS STATION
200 Going To The Sun Rd
West Glacier, MT 59936 Flathead

System Facility ID:15-03288

Facility Code: 20602
Last Inspected On: 07/16/2025
Operating Permit Renewal Date: 12/02/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Glacier Park Inc (406) 892-6708 lwyrick@pursuitcollection.com

Operator Contact: Charles Krasselt (406) 270-8013 ckrasselt@glacierparkinc.com

Owner/Operator: Glacier Park Inc (406) 892-6708 lwyrick@pursuitcollection.com

Charles Krasselt, UST Class A Operator

ckrasselt@glacierparkinc.com

Charles Krasselt, UST Class B Global Operator

ckrasselt@glacierparkinc.com

Tank Code	04	Tank Age	37	Tank Installed Date	10/23/1989	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve
Tag Number	2246	Spill Test Date	03/26/2025	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Single Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	03/26/2025	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	05/09/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	10000	ATG Test Date	03/26/2025	Line Tightness Test Date	03/26/2025	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	04/28/2022			ATG Type	Veeder Root/TLS-300				
Tank Code	05	Tank Age	37	Tank Installed Date	10/23/1989	Tank Material	Cathodically Protected Steel	Piping Material	No Piping	Overfill Types	Ball Float Valve
Tag Number	2247	Spill Test Date	03/26/2025	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date	03/16/2022	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	05/09/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection		Vapor Recovery	No
Capacity	8000	ATG Test Date	03/26/2025	Line Tightness Test Date	03/16/2022	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	04/28/2022			ATG Type	Veeder Root/TLS-300				
Tank Code	06	Tank Age	37	Tank Installed Date	10/23/1989	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve
Tag Number	2248	Spill Test Date	03/26/2025	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Single Walled	AST	No

Tank Status	Currently in Use	MLLD Test Date	03/26/2025	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	05/09/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	6000	ATG Test Date	03/26/2025	Line Tightness Test Date	03/26/2025	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	04/28/2022			ATG Type	Veeder Root/TLS-300				

Facility Summary in Flathead County in the City of Whitefish

Location: ALPINE VILLAGE MARKET
721 Wisconsin Ave
Whitefish, MT 59937-2131 Flathead

System Facility ID:15-10944

Facility Code: 20900
Last Inspected On: 09/20/2023
Operating Permit Renewal Date: 12/31/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Super Grocer Corp (406) 862-5025

Operator Contact: Alan Reisch;Brent Silcox (406) 862-5025 alpine1@aboutmontana.net

Owner/Operator: Super Grocer Corp (406) 862-5025

Alan Reisch, UST Class A Operator
Alan Reisch, UST Class B Operator
Brent Silcox, UST Class A Operator
Brent Silcox, UST Class B Operator

alpine1@aboutmontana.net
alpine1@aboutmontana.net
alpine1@aboutmontana.net
alpine1@aboutmontana.net

Tank Code	01	Tank Age	45	Tank Installed Date	04/21/1981	Tank Material	Bare Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	4692	Spill Test Date	12/21/2023	Piping Installed Date	09/13/2002	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date	11/12/2025	Tank/Piping CP Test Date	09/19/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	10000	ATG Test Date	11/12/2025	Line Tightness Test Date	09/10/2014	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	09/19/2023			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	02	Tank Age	45	Tank Installed Date	04/21/1981	Tank Material	Bare Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	4693	Spill Test Date	12/21/2023	Piping Installed Date	09/13/2002	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date	11/12/2025	Tank/Piping CP Test Date	09/19/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	10000	ATG Test Date	11/12/2025	Line Tightness Test Date	08/15/2014	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No

		Overfill Test Date	09/19/2023			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	03	Tank Age	35	Tank Installed Date	10/01/1991	Tank Material	Bare Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	4694	Spill Test Date	12/21/2023	Piping Installed Date	09/13/2002	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Diesel	PLLD Test Date	11/12/2025	Tank/Piping CP Test Date	09/19/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	5000	ATG Test Date	11/12/2025	Line Tightness Test Date	09/09/2017	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	12/21/2023			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Flathead County in the City of Whitefish

Location: BIG MOUNTAIN SKI RESORT SHOP
3910 Big Mountain Rd
Whitefish, MT 59937 Flathead

System Facility ID:15-05579

Facility Code: 20672
Last Inspected On: 09/04/2025
Operating Permit Renewal Date: 10/22/2028

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Winter Sports Inc

Operator Contact: Gardner Beougher

(406) 862-2987

gardnerb@skiwhhitefish.com

Owner/Operator: Winter Sports Inc

Gardner Beougher, UST Class A Operator

gardnerb@skiwhhitefish.com

Gardner Beougher, UST Class B Operator

gardnerb@skiwhhitefish.com

Tank Code	08	Tank Age	34	Tank Installed Date	09/01/1992	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve
Tag Number	2295	Spill Test Date	09/04/2025	Piping Installed Date	07/20/2007	Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date	09/04/2025	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	10000	ATG Test Date	09/04/2025	Line Tightness Test Date	09/04/2025	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	09/04/2025			ATG Type	Gilbarco-Veeder Root/TLS-450				
Tank Code	09	Tank Age	28	Tank Installed Date	07/14/1998	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	2296	Spill Test Date	09/04/2025	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection		Vapor Recovery	No
Capacity	12000	ATG Test Date	09/04/2025	Line Tightness Test Date	11/01/2006	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	09/04/2025			ATG Type	Gilbarco-Veeder Root/Other				
Tank Code	10	Tank Age	28	Tank Installed Date	07/14/1998	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	2297	Spill Test Date	09/04/2025	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No

Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection		Vapor Recovery	No
Capacity	2000	ATG Test Date	09/04/2025	Line Tightness Test Date	11/01/2006	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	09/04/2025			ATG Type	Gilbarco-Veeder Root/Other				

Facility Summary in Flathead County in the City of Whitefish

Location: CENEX ZIP TRIP #69
6585 US Hwy 93 S
Whitefish, MT 59937 Flathead

System Facility ID:15-04903

Facility Code: 20650
Last Inspected On: 08/05/2025
Operating Permit Renewal Date: 12/27/2028

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: CHS Inc Spokane Valley (509) 535-7701 jim.alford@chsinc.com

Operator Contact: Jim Alford;Sean Hurley (509) 535-7701;(509) 536-7418 jim.alford@chsinc.com;sean.hurley@chsinc.com

Owner/Operator: CHS Inc Spokane Valley (509) 535-7701 jim.alford@chsinc.com

Jason Brenner, UST Class B Operator	jim.alford@chsinc.com
Jim Alford, UST Class A Operator	jim.alford@chsinc.com
Jim Alford, UST Class B Operator	jim.alford@chsinc.com
Luci Tuttle, UST Class B Operator	Lucinda.Tuttle@chsinc.com
Sean Hurley, UST Class A Operator	sean.hurley@chsinc.com

Tank Code	07	Tank Age	35	Tank Installed Date	11/04/1991	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	2956	Spill Test Date	08/05/2025	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	08/05/2025	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	10000	ATG Test Date	08/05/2025	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	08/05/2025			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	08	Tank Age	35	Tank Installed Date	11/04/1991	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	2957	Spill Test Date	08/05/2025	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	08/05/2025	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	10000	ATG Test Date	08/05/2025	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No

		Overfill Test Date	08/05/2025			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	09	Tank Age	35	Tank Installed Date	11/04/1991	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	2958	Spill Test Date	08/05/2025	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Diesel, Dyed	PLLD Test Date		Tank/Piping CP Test Date	08/05/2025	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	10000	ATG Test Date	08/12/2025	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	08/05/2025			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	10	Tank Age	35	Tank Installed Date	11/04/1991	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	2959	Spill Test Date	08/05/2025	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	08/05/2025	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	12000	ATG Test Date	08/05/2025	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	08/05/2025			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Flathead County in the City of Whitefish

Location: LOGAN HEALTH WHITEFISH
1600 Hospital Way
Whitefish, MT 59937-2990 Flathead

System Facility ID:60-15034

Facility Code: 30816
Last Inspected On: 03/12/2025
Operating Permit Renewal Date: 03/13/2028

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Logan Health Whitefish

jnewson@logan.org

Operator Contact: Jeff Greene;Logan Health Whitefish;Matthew Moody;Logan Health Whitefish;Steven Reasner;Logan Health Whitefish

(406) 471-2116

jeffgreene@logan.org;jnewson@logan.org;moodster10@hotmail.com;jnewson@logan.org;sreasner@logan.org;jnewson@logan.org

Owner/Operator: Logan Health Whitefish

jnewson@logan.org

- Jeff Greene, UST Class A Operator
- Jeff Greene, UST Class B Operator
- Matthew Moody, UST Class A Operator
- Matthew Moody, UST Class B Operator
- Steven Reasner, UST Class A Operator
- Steven Reasner, UST Class B Operator

- jnewson@logan.org
- jnewson@logan.org
- jnewson@logan.org
- jnewson@logan.org
- jnewson@logan.org
- jnewson@logan.org

Tank Code	S1	Tank Age	19	Tank Installed Date	01/17/2007	Tank Material	Aboveground Tank	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	5123	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	Yes
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Auto Dialer	Piping Type	Pressurized	CP Met Types	
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection		Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	4000	ATG Test Date	03/12/2025	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	Yes
		Overfill Test Date				ATG Type					

Facility Summary in Flathead County in the City of Whitefish

Location: MIDWAY MINI MART
4899 US Hwy 93 S
Whitefish, MT 59937-8520 Flathead

System Facility ID:15-07766

Facility Code: 20742
Last Inspected On: 05/10/2023
Operating Permit Renewal Date: 08/07/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Midway MM Inc **(406) 862-6365** **victorsmarket@outlook.com**

Operator Contact: Riley Workman **riley.a.workman@gmail.com**

Owner/Operator: Midway MM Inc (406) 862-6365 victorsmarket@outlook.com

Riley Workman, UST Class A Operator riley.a.workman@gmail.com
Riley Workman, UST Class B Operator riley.a.workman@gmail.com

Tank Code	04	Tank Age	30	Tank Installed Date	04/01/1996	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	3384	Spill Test Date	05/10/2023	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	05/10/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	12000	ATG Test Date	05/10/2023	Line Tightness Test Date	06/04/2020	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	05/10/2023			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	05	Tank Age	30	Tank Installed Date	04/01/1996	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	3385	Spill Test Date	05/10/2023	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	05/10/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	7000	ATG Test Date	05/10/2023	Line Tightness Test Date	06/04/2020	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	05/10/2023			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	06	Tank Age	30	Tank Installed Date	04/01/1996	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve

Tag Number	3386	Spill Test Date	05/10/2023	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	05/10/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	5000	ATG Test Date	05/10/2023	Line Tightness Test Date	06/04/2020	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	05/10/2023			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Flathead County in the City of Whitefish

Location: SAFEWAY FUEL STATION #2106
110 W 13th St
Whitefish, MT 59937 Flathead

System Facility ID:60-15151

Facility Code: 30892
Last Inspected On: 07/14/2025
Operating Permit Renewal Date: 12/28/2028

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Safeway #2106	(623) 869-3573	liz.alwine@safeway.com
Operator Contact: Jesse Wees;Martha Scott;Albertsons - Safeway;Page Rost	(208) 412-2233	jesse.wees@albertsons.com;mscot17@safeway.com;page.rost@albertsons.com;page.rost@albertsons.com

Owner/Operator: Safeway #2106	(623) 869-3573	liz.alwine@safeway.com
A Beagle, UST Class B Global Operator		
Allen Long, UST Class B Global Operator		s2106c60@safeway.com
Jesse Wees, UST Class A Operator		jesse.wees@albertsons.com
Martha Scott, UST Class A Operator		page.rost@albertsons.com
Martha Scott, UST Class B Operator		page.rost@albertsons.com
Page Rost, UST Class A Operator		page.rost@albertsons.com
Page Rost, UST Class B Global Operator		page.rost@albertsons.com

Tank Code	01	Tank Age	16	Tank Installed Date	04/28/2010	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	5233	Spill Test Date	05/20/2025	Piping Installed Date	04/08/2010	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	05/20/2025	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	20000	ATG Test Date	05/20/2025	Line Tightness Test Date		Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	05/20/2025			ATG Type	Gilbarco-Veeder Root/TLS-350;Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	02	Tank Age	16	Tank Installed Date	04/28/2010	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	5234	Spill Test Date	05/20/2025	Piping Installed Date	04/08/2010	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No

Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	05/20/2025	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	10000	ATG Test Date	05/20/2025	Line Tightness Test Date		Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	05/20/2025			ATG Type	Gilbarco-Veeder Root/TLS-350;Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	03	Tank Age	16	Tank Installed Date	04/28/2010	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	5235	Spill Test Date	05/20/2025	Piping Installed Date	04/08/2010	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	05/20/2025	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	10000	ATG Test Date	05/20/2025	Line Tightness Test Date		Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	05/20/2025			ATG Type	Gilbarco-Veeder Root/TLS-350;Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Flathead County in the City of Whitefish

Location: TOWN PUMP INC WHITEFISH 1
6600 US Hwy 93 S
Whitefish, MT 59937 Flathead

System Facility ID:15-10105

Facility Code: 20827
Last Inspected On: 03/15/2026
Operating Permit Renewal Date: 08/31/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Whitefish 1 Town Pump LLC (406) 497-6700 environmental@townpump.com

Operator Contact: Trent Biggers Trentb@townpump.com

Owner/Operator: Whitefish 1 Town Pump LLC (406) 497-6700 environmental@townpump.com

Trent Biggers, UST Class A Operator

Trentb@townpump.com

Trent Biggers, UST Class B Global Operator

Trentb@townpump.com

Tank Code	01	Tank Age	36	Tank Installed Date	01/17/1990	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	2428	Spill Test Date	10/22/2024	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Diesel	PLLD Test Date	04/28/2021	Tank/Piping CP Test Date	11/18/2021	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	12000	ATG Test Date	05/24/2023	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	09/22/2022			ATG Type	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Code	03	Tank Age	36	Tank Installed Date	01/17/1990	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	2430	Spill Test Date	11/16/2022	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Gasoline	PLLD Test Date	04/28/2021	Tank/Piping CP Test Date	11/18/2021	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	12000	ATG Test Date	05/24/2023	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	09/22/2022			ATG Type	Gilbarco-Veeder Root/TLS-450PLUS				

Tank Code	04	Tank Age	36	Tank Installed Date	01/17/1990	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	2431	Spill Test Date	10/22/2024	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Gasoline	PLLD Test Date	04/28/2021	Tank/Piping CP Test Date	11/18/2021	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	12000	ATG Test Date	05/24/2023	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	09/22/2022			ATG Type	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Code	02	Tank Age	36	Tank Installed Date	01/17/1990	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	4306	Spill Test Date	11/16/2022	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Gasoline	PLLD Test Date	04/28/2021	Tank/Piping CP Test Date	11/18/2021	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	12000	ATG Test Date	05/24/2023	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	09/22/2022			ATG Type	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Code	05	Tank Age	22	Tank Installed Date	10/01/2004	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve
Tag Number	4941	Spill Test Date	10/22/2024	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Gasoline	PLLD Test Date	04/28/2021	Tank/Piping CP Test Date	11/18/2021	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	20000	ATG Test Date	05/24/2023	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	09/22/2022			ATG Type	Gilbarco-Veeder Root/TLS-450PLUS				

Facility Summary in Flathead County in the City of Whitefish

Location: TOWN PUMP WHITEFISH 2
4825 US Hwy 40
Whitefish, MT 59937 Flathead

System Facility ID:60-15355

Facility Code: 32453
Last Inspected On: 11/05/2025
Operating Permit Renewal Date: 05/29/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Whitefish #2 Town Pump LLC

(406) 497-6900

environmental@townpump.com

Operator Contact: Trent Biggers;Town Pump

Trentb@townpump.com;environmental@townpump.com

Owner/Operator: Whitefish #2 Town Pump LLC

(406) 497-6900

environmental@townpump.com

Trent Biggers, UST Class A Operator

environmental@townpump.com

Trent Biggers, UST Class B Global Operator

environmental@townpump.com

Tank Code	01	Tank Age	5	Tank Installed Date	11/26/2021	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	6044	Spill Test Date	07/21/2025	Piping Installed Date	11/26/2021	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	07/21/2025	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	Yes
Capacity	30000	ATG Test Date	07/21/2025	Line Tightness Test Date		Secondary Tank Leak Detection	Statistical Inventory Reconciliation	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	Yes
		Overfill Test Date	07/21/2025			ATG Type					
Tank Code	02	Tank Age	5	Tank Installed Date	11/26/2021	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	6045	Spill Test Date	07/21/2025	Piping Installed Date	11/26/2021	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	07/21/2025	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	Yes
Capacity	6000	ATG Test Date	07/21/2025	Line Tightness Test Date		Secondary Tank Leak Detection	Statistical Inventory Reconciliation	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	Yes
		Overfill Test Date	07/21/2025			ATG Type					
Tank Code	03	Tank Age	5	Tank Installed Date	11/26/2021	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve

Tag Number	6046	Spill Test Date	07/21/2025	Piping Installed Date	11/26/2021	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	07/21/2025	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	Yes
Capacity	15000	ATG Test Date	07/21/2025	Line Tightness Test Date		Secondary Tank Leak Detection	Statistical Inventory Reconciliation	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	Yes
		Overfill Test Date	07/21/2025			ATG Type					
Tank Code	04	Tank Age	5	Tank Installed Date	11/26/2021	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	6047	Spill Test Date	07/21/2025	Piping Installed Date	11/26/2021	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	07/21/2025	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	6000	ATG Test Date	07/21/2025	Line Tightness Test Date		Secondary Tank Leak Detection	Statistical Inventory Reconciliation	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	Yes
		Overfill Test Date	07/21/2025			ATG Type					
Tank Code	05	Tank Age	5	Tank Installed Date	11/26/2021	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	6048	Spill Test Date	09/27/2022	Piping Installed Date	11/26/2021	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	07/21/2025	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel, Dyed	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	7000	ATG Test Date	07/21/2025	Line Tightness Test Date		Secondary Tank Leak Detection	Statistical Inventory Reconciliation	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	Yes
		Overfill Test Date	07/21/2025			ATG Type					
Tank Code	06	Tank Age	5	Tank Installed Date	11/26/2021	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	6049	Spill Test Date	07/21/2025	Piping Installed Date	11/26/2021	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	07/21/2025	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No

Capacity	20000	ATG Test Date	07/21/2025	Line Tightness Test Date		Secondary Tank Leak Detection	Statistical Inventory Reconciliation	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	Yes
		Overfill Test Date	07/21/2025			ATG Type					

Facility Summary in Flathead County in the City of Whitefish

Location: WHITEFISH LAKE LODGE
1380 Wisconsin Ave
Whitefish, MT 59937-3338 Flathead

System Facility ID:15-12719

Facility Code: 21003
Last Inspected On: 08/29/2023
Operating Permit Renewal Date: 04/30/2019

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Whitefish Lake Lodge (406) 837-7050

Operator Contact: Chris Gulick;Dave Wood;Heath Howell

(406) 863-4000;(406) 863-4049;(615) 426-3939

chrisgulick@lodgeatwhitefishlake.com;marina@lodgeatwhitefishlake.com

Owner/Operator: Whitefish Lake Lodge

(406) 837-7050

Chris Gulick, UST Class A Operator
Chris Gulick, UST Class B Operator
Dave Wood, UST Class A Operator
Dave Wood, UST Class B Operator
Heath Howell, UST Class A Operator
Heath Howell, UST Class B Operator

chrisgulick@lodgeatwhitefishlake.com
chrisgulick@lodgeatwhitefishlake.com
marina@lodgeatwhitefishlake.com
marina@lodgeatwhitefishlake.com

Tank Code	01	Tank Age	34	Tank Installed Date	04/01/1992	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	
Tag Number		Spill Test Date		Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Other	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0		Piping Type	Pressurized	CP Met Types	
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring;MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	4000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					
Tank Code	02	Tank Age	34	Tank Installed Date	04/01/1992	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	4898	Spill Test Date		Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No

Capacity	4000	ATG Test Date		Line Tightness Test Date	07/22/2014	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Flathead County in the City of Whitefish

Location: WHITEFISH WESTSIDE MARKET
145 2nd St W
Whitefish, MT 59937 Flathead

System Facility ID:15-00112

Facility Code: 20516
Last Inspected On: 08/22/2024
Operating Permit Renewal Date: 09/06/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: West 2nd Property Group LLC (406) 862-4535 westsidemarket406@gmail.com

Operator Contact: Bill Kahle;Whitefish Westside Market LLC (406) 862-4535 westsidemarket406@gmail.com;westsidemarket406@gmail.com

Owner/Operator: West 2nd Property Group LLC (406) 862-4535 westsidemarket406@gmail.com
Bill Kahle, UST Class A Operator westsidemarket406@gmail.com
Bill Kahle, UST Class B Operator westsidemarket406@gmail.com

Tank Code	03	Tank Age	30	Tank Installed Date	11/01/1996	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	3421	Spill Test Date	10/17/2024	Piping Installed Date	05/08/2018	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	08/22/2024	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	08/22/2024	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	12000	ATG Test Date	05/15/2025	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	08/22/2024			ATG Type	Gilbarco-Veeder Root/TLS-300				
Tank Code	04	Tank Age	30	Tank Installed Date	11/01/1996	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	3422	Spill Test Date		Piping Installed Date	05/08/2018	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	12000	ATG Test Date	05/15/2025	Line Tightness Test Date		Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-300				