

Facility Summary in Garfield County in the City of Jordan

Location: FARMERS UNION OIL CO JORDAN
201 Jordan Ave
Jordan, MT 59337 Garfield

System Facility ID:17-05702

Facility Code: 21878
Last Inspected On: 03/01/2026
Operating Permit Renewal Date: 08/19/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Farmers Union Oil Co Jordan

cenexjor@midrivers.com

Operator Contact: Robert Wilson

(406) 557-2218

cenexjor@midrivers.com

Owner/Operator: Farmers Union Oil Co Jordan

cenexjor@midrivers.com

Loren Edwards, UST Class B Global Operator

edwards_loren@yahoo.com

Robert Wilson, UST Class A Operator

cenexjor@midrivers.com

Tank Code	06	Tank Age	28	Tank Installed Date	12/01/1998	Tank Material	Steel Clad	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	941	Spill Test Date	02/17/2023	Piping Installed Date	09/18/2024	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	01/30/2008	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	12000	ATG Test Date		Line Tightness Test Date	09/18/2024	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	02/17/2023			ATG Type	Franklin Fueling Systems/				
Tank Code	07	Tank Age	28	Tank Installed Date	12/01/1998	Tank Material	Steel Clad	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	942	Spill Test Date	02/17/2023	Piping Installed Date	10/02/2014	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	01/30/2008	Primary Tank Leak Detection	Manual Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	4100	ATG Test Date		Line Tightness Test Date	06/26/2017	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	02/17/2023			ATG Type					
Tank Code	08	Tank Age	28	Tank Installed Date	12/01/1998	Tank Material	Steel Clad	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve

Tag Number	943	Spill Test Date	02/17/2023	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Not Listed	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	01/30/2008	Primary Tank Leak Detection	Manual Interstitial Monitoring	Primary Pipe Detection		Vapor Recovery	No
Capacity	4100	ATG Test Date		Line Tightness Test Date	06/26/2017	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	02/17/2023			ATG Type					
Tank Code	09	Tank Age	28	Tank Installed Date	12/01/1998	Tank Material	Steel Clad	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	944	Spill Test Date	02/17/2023	Piping Installed Date	10/02/2014	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	01/30/2008	Primary Tank Leak Detection	Manual Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	3760	ATG Test Date		Line Tightness Test Date	06/26/2017	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	02/17/2023			ATG Type					
Tank Code	10	Tank Age	28	Tank Installed Date	12/01/1998	Tank Material	Steel Clad	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	945	Spill Test Date	02/17/2023	Piping Installed Date	06/03/2011	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	01/30/2008	Primary Tank Leak Detection	Manual Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	7900	ATG Test Date		Line Tightness Test Date	06/26/2017	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	02/17/2023			ATG Type					
Tank Code	11	Tank Age	28	Tank Installed Date	12/01/1998	Tank Material	Steel Clad	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	946	Spill Test Date	02/17/2023	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Not Listed	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	01/30/2008	Primary Tank Leak Detection	Manual Interstitial Monitoring	Primary Pipe Detection		Vapor Recovery	No
Capacity	4100	ATG Test Date		Line Tightness Test Date	06/26/2017	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	02/17/2023			ATG Type					

Facility Summary in Garfield County in the City of Jordan

Location: FARMERS UNION OIL CO JORDAN 2
40 Brusett Rd
Jordan, MT 59337 Garfield

System Facility ID:60-15243

Facility Code: 30960
Last Inspected On: 03/01/2026
Operating Permit Renewal Date: 07/05/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Farmers Union Oil Co Jordan

cenexjor@midrivers.com

Operator Contact: Robert Wilson

(406) 557-2218

cenexjor@midrivers.com

Owner/Operator: Farmers Union Oil Co Jordan

cenexjor@midrivers.com

Loren Edwards, UST Class B Global Operator

edwards_loren@yahoo.com

Robert Wilson, UST Class A Operator

cenexjor@midrivers.com

Tank Code	S1	Tank Age	12	Tank Installed Date	10/28/2014	Tank Material	Aboveground Tank	Piping Material	Flexible Plastic	Overfill Types	
Tag Number	5498	Spill Test Date		Piping Installed Date	10/28/2014	Tank Construction		Piping Construction	Double Walled	AST	Yes
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection		Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	15000	ATG Test Date		Line Tightness Test Date	06/26/2017	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date				ATG Type					
Tank Code	S2	Tank Age	12	Tank Installed Date	10/28/2014	Tank Material	Aboveground Tank	Piping Material	Flexible Plastic	Overfill Types	
Tag Number	5499	Spill Test Date		Piping Installed Date	10/28/2014	Tank Construction		Piping Construction	Double Walled	AST	Yes
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection		Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	15000	ATG Test Date		Line Tightness Test Date	06/26/2017	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date				ATG Type					
Tank Code	S3	Tank Age	12	Tank Installed Date	10/28/2014	Tank Material	Aboveground Tank	Piping Material	Flexible Plastic	Overfill Types	

Tag Number	5500	Spill Test Date		Piping Installed Date	10/28/2014	Tank Construction		Piping Construction	Double Walled	AST	Yes
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection		Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	15000	ATG Test Date		Line Tightness Test Date	06/26/2017	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date				ATG Type					

Facility Summary in Garfield County in the City of Jordan

Location: JAKES PLACE
618 Jordan Ave
Jordan, MT 59337 Garfield

System Facility ID:17-10707

Facility Code: 21895
Last Inspected On: 08/07/2023
Operating Permit Renewal Date: 11/16/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Jakes Property Investments LLC	(406) 853-1732	skylarharbaugh@hotmail.com
Operator Contact: Kenneth Ellington;Rex Phipps;Skylar Harbaugh	(406) 853-1732	kellington@middrivers.com;rex@garfieldcountybank.com;skylarharbaugh@hotmail.com

Owner/Operator: Jakes Property Investments LLC (406) 853-1732 skylarharbaugh@hotmail.com

Kenneth Ellington, UST Class A Operator
Kenneth Ellington, UST Class B Operator
Rex Phipps, UST Class A Operator
Rex Phipps, UST Class B Operator
Skylar Harbaugh, UST Class A Operator
Skylar Harbaugh, UST Class B Global Operator

kellington@middrivers.com
kellington@middrivers.com
rex@garfieldcountybank.com
rex@garfieldcountybank.com
skylarharbaugh@hotmail.com
skylarharbaugh@hotmail.com

Tank Code	05	Tank Age	25	Tank Installed Date	06/01/2001	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	4311	Spill Test Date	08/07/2023	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	8000	ATG Test Date	08/07/2023	Line Tightness Test Date	08/24/2020	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	08/07/2023			ATG Type	Incon/TS-550 EVO				
Tank Code	06	Tank Age	25	Tank Installed Date	06/01/2001	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	4312	Spill Test Date	08/07/2023	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No

Capacity	4000	ATG Test Date	08/07/2023	Line Tightness Test Date	08/27/2020	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	08/07/2023			ATG Type	Incon/TS-550 EVO				
Tank Code	07	Tank Age	25	Tank Installed Date	06/01/2001	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	4313	Spill Test Date	08/07/2023	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	4000	ATG Test Date	08/07/2023	Line Tightness Test Date	08/23/2020	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	08/07/2023			ATG Type	Incon/TS-550 EVO				