

Facility Summary in Garfield County in the City of Jordan

Location: FARMERS UNION OIL CO JORDAN
201 Jordan Ave
Jordan, MT 59337 Garfield

Legacy ID:17-05702

Facility ID: 21878
Last Inspected On: 04/07/2020
Operating Permit Renewal Date: 08/19/2023

Owner Operator Contact: Farmers Union Oil Co Jordan;Robert Wilson;Farmers Union Oil Co Jordan **4065572215;4065572218;4065572215**

Operator Contact: Robert Wilson **4065572218**

Owner/Operator: Farmers Union Oil Co Jordan

Loren Edwards, UST Class B Global Operator
Robert Wilson, UST Class A Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
06	23	12/01/1998	Steel Clad	Flexible Plastic	Flapper Valve
941	No		Double-Walled	Double Walled	Yes
Currently in Use		10/02/2014	Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline		01/30/2008	Manual Interstitial Monitoring	Continuous Interstitial Monitoring;ELLD 0.2	No
12,000		06/26/2017			No
07	23	12/01/1998	Steel Clad	Flexible Plastic	Flapper Valve
942	No		Double-Walled	Double Walled	Yes
Currently in Use		10/02/2014	Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline		01/30/2008	Manual Interstitial Monitoring	Continuous Interstitial Monitoring;ELLD 0.2	No
4,100		06/26/2017			No
08	23	12/01/1998	Steel Clad	Flexible Plastic	Flapper Valve
943	No		Double-Walled	Double Walled	Yes

Currently in Use			Not Required	Not Listed	Non-corrodible
Diesel		01/30/2008	Manual Interstitial Monitoring	Not Listed	No
4,100		06/26/2017			No
09	23	12/01/1998	Steel Clad	Flexible Plastic	Flapper Valve
944	No		Double-Walled	Double Walled	Yes
Currently in Use		10/02/2014	Electronic Line Leak Detector	Pressurized	
Diesel		01/30/2008	Manual Interstitial Monitoring	Continuous Interstitial Monitoring; ELLD 0.2	No
3,760		06/26/2017			No
10	23	12/01/1998	Steel Clad	Flexible Plastic	Flapper Valve
945	No		Double-Walled	Double Walled	Yes
Currently in Use		06/03/2011	Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel		01/30/2008	Manual Interstitial Monitoring	Continuous Interstitial Monitoring; ELLD 0.2	No
7,900		06/26/2017			No
11	23	12/01/1998	Steel Clad	Flexible Plastic	Flapper Valve
946	No		Double-Walled	Double Walled	Yes
Currently in Use			Not Required	Not Listed	Non-corrodible
Diesel		01/30/2008	Manual Interstitial Monitoring	Not Listed	No
4,100		06/26/2017			No

Facility Summary in Garfield County in the City of Jordan

Location: FARMERS UNION OIL CO JORDAN 2
40 Brusett Rd
Jordan, MT 59337 Garfield

Legacy ID:60-15243

Facility ID: 30960
Last Inspected On: 05/18/2020
Operating Permit Renewal Date: 07/05/2023

Owner Operator Contact: Farmers Union Oil Co Jordan

4065572215

Operator Contact: Robert Wilson

4065572218

Owner/Operator: Farmers Union Oil Co Jordan

Loren Edwards, UST Class B Global Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
S1	7	10/28/2014	Aboveground Tank	Flexible Plastic	
5498	Yes	10/28/2014		Double Walled	No
Currently in Use		10/28/2014	Electronic Line Leak Detector	Pressurized	
Gasoline			Deferred	Continuous Interstitial Monitoring; ELLD 0.2	No
15,000		06/26/2017			Yes
S2	7	10/28/2014	Aboveground Tank	Flexible Plastic	
5499	Yes	10/28/2014		Double Walled	No
Currently in Use		10/28/2014	Electronic Line Leak Detector	Pressurized	
Diesel			Deferred	Continuous Interstitial Monitoring; ELLD 0.2	No
15,000		06/26/2017			Yes
S3	7	10/28/2014	Aboveground Tank	Flexible Plastic	
5500	Yes	10/28/2014		Double Walled	No
Currently in Use		10/28/2014	Electronic Line Leak Detector	Pressurized	
Diesel			Deferred	Continuous Interstitial Monitoring; ELLD 0.2	No
15,000		06/26/2017			Yes

Facility Summary in Garfield County in the City of Jordan

Location: JAKES PLACE
618 Jordan Ave
Jordan, MT 59337 Garfield

Legacy ID:17-10707

Facility ID: 21895
Last Inspected On: 08/27/2020
Operating Permit Renewal Date: 11/16/2023

Owner Operator Contact: Dale Fellman; Fellmans Hardware Inc

Owner/Operator: Jakes Property Investments LLC

Kenneth Ellington, UST Class A Operator
 Kenneth Ellington, UST Class B Operator
 Rex Phipps, UST Class A Operator
 Rex Phipps, UST Class B Operator
 Skylar Harbaugh, UST Class A Operator
 Skylar Harbaugh, UST Class B Global Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
05	20	06/01/2001	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
4311	No	10/17/2013		Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring;ELLD 0.1;ELLD 0.2	No
8,000			Incon/TS-550 EVO		No
06	20	06/01/2001	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
4312	No	10/17/2013		Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring;ELLD 0.1;ELLD 0.2	No
4,000			Incon/TS-550 EVO		No
07	20	06/01/2001	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
4313	No	10/17/2013		Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible

Diesel	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring; ELLD 0.1; ELLD 0.2	No
4,000	Incon/TS-550 EVO		No
