

Facility Summary in Glacier County in the City of Babb

Location: LARIAT MOTEL
US Hwy 89
Babb, MT 59411 Glacier

Legacy ID:18-02264

Facility ID: 21930
Last Inspected On:
Operating Permit Renewal Date:

Owner Operator Contact: Robert Burns

4067324532

Operator Contact:

Owner/Operator: Robert Burns

Owner/Operator: W H Burns

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
03	36	04/25/1985	Bare Steel	Steel	
	No				No
Temporarily Out of Use				Not Listed	
Gasoline			Not Listed	Not Listed	No
10,000					No

Facility Summary in Glacier County in the City of Babb

Location: THRONSONS STORE
US Hwy 89
Babb, MT 59411 Glacier

Legacy ID:18-03871

Facility ID: 21949
Last Inspected On: 04/06/2020
Operating Permit Renewal Date: 09/03/2023

Owner Operator Contact: Thronsons Store

4067325530

Operator Contact: Michael Thronson

4067325530

Owner/Operator: Thronsons Store

Michael Thronson, UST Class A Operator
Michael Thronson, UST Class B Global Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected

Status	Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types	
Product	Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery	
Capacity	Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act	
07	32	12/31/1989	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
4401	No		Double-Walled	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline	06/20/2017		Manual Interstitial Monitoring	MLLD Line Tightness Testing	No
7,000	12/04/2018				No
08	32	12/31/1989	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
4402	No		Double-Walled	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline	06/20/2017		Manual Interstitial Monitoring	MLLD Line Tightness Testing	No
3,000	12/04/2018				No
06	32	12/31/1989	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
4403	No		Double-Walled	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline	06/20/2017		Manual Interstitial Monitoring	MLLD Line Tightness Testing	No
8,000	12/04/2018				No

Facility Summary in Glacier County in the City of Browning

Location: COOP'S CORNER CONOCO
330 W Central Ave
Browning, MT 59417 Glacier

Legacy ID:18-05813

Facility ID: 21980
Last Inspected On: 03/09/2021
Operating Permit Renewal Date: 03/13/2024

Owner Operator Contact: Dirk Cooper;Hi Noon Petroleum Missoula **4065420384**

Operator Contact: Michael Sherwood;Randy Livingston;Troy Wilson **4063382575**

Owner/Operator: Glacier Park 66 Inc

Michael Sherwood, UST Class A Operator
Michael Sherwood, UST Class B Operator

Randy Livingston, UST Class A Operator
 Randy Livingston, UST Class B Operator
 Troy Wilson, UST Class A Operator
 Troy Wilson, UST Class B Global Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
04	24	01/03/1997	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve
4441	No		Double-Walled	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline		12/10/2008	Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	ELLD 0.2	No
20,000		12/10/2008	Gilbarco/EMC Basic		No
05	24	01/03/1997	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve
4442	No		Double-Walled	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel		12/10/2008	Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	ELLD 0.2	No
12,000		05/25/2017	Gilbarco/EMC Basic		No
06	24	01/03/1997	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve
4443	No		Double-Walled	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline		12/10/2008	Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	ELLD 0.2	No
12,000		05/25/2017	Gilbarco/EMC Basic		No

Facility Summary in Glacier County in the City of Browning

Location: GLACIER FAMILY FOODS
601 SE Boundary St
Browning, MT 59417 Glacier

Legacy ID:60-15286

Facility ID: 30993
Last Inspected On: 06/21/2019
Operating Permit Renewal Date: 10/14/2022

Owner Operator Contact: Siyeh Development Corporation

4063385669

Operator Contact: Dori Goss;Mark Magee;Tahnee Armstrong

4063387283

Owner/Operator: Siyeh Development Corporation

Dori Goss, UST Class A Operator
Dori Goss, UST Class B Operator
Mark Magee, UST Class A Operator
Mark Magee, UST Class B Operator
Tahnee Armstrong, UST Class A Operator
Tahnee Armstrong, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
01	6	10/01/2015	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm;Positive Shutoff
5673	No	06/27/2016	Double-Walled	Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel			Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	Continuous Interstitial Monitoring;ELLD 0.1;ELLD 0.2	No
12,000			Incon/TS-550 EVO		Yes
02	6	10/01/2015	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm;Positive Shutoff
5674	No	06/27/2016	Double-Walled	Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel			Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	Continuous Interstitial Monitoring;ELLD 0.1;ELLD 0.2	No
8,000			Incon/TS-550 EVO		Yes

03	6	10/01/2015	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm;Positive Shutoff
5675	No	06/27/2016	Double-Walled	Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	Continuous Interstitial Monitoring;ELLD 0.1;ELLD 0.2	Yes
20,000			Incon/TS-550 EVO		Yes
04	6	10/01/2015	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm;Positive Shutoff
5676	No	06/27/2016	Double-Walled	Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	Continuous Interstitial Monitoring;ELLD 0.1;ELLD 0.2	Yes
8,000			Incon/TS-550 EVO		Yes

Facility Summary in Glacier County in the City of Browning

Location: GLACIER WAY CONVENIENCE STORE
200 MT Hwy 464
Browning, MT 59417 Glacier

Legacy ID:18-13768

Facility ID: 22049
Last Inspected On: 11/23/2020
Operating Permit Renewal Date: 12/20/2023

Owner Operator Contact: Pat Schildt

4063387163

Operator Contact: Charles Lafley;Harold Schildt;Pardeep Kumar;Stacey Keller

4063384464;4063387568;4084499333;7755602318

Owner/Operator: Pat Schildt

- Charles Lafley, UST Class A Operator
- Charles Lafley, UST Class B Global Operator
- Harold Schildt, UST Class A Operator
- Harold Schildt, UST Class B Global Operator
- Pardeep Kumar, UST Class A Operator
- Pardeep Kumar, UST Class B Operator
- Stacey Keller, UST Class A Operator
- Stacey Keller, UST Class B Global Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types

Product	Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery	
Capacity	Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act	
01	25	09/25/1996	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
3425	No	04/20/2018	Double-Walled	Double Walled	Yes
Currently in Use		Mechanical Line Leak Detector	Pressurized	Non-corrodible	
Gasoline	07/09/2008	Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	Continuous Interstitial Monitoring;MLLD Line Tightness Testing	No	
20,000		Gilbarco-Veeder Root/TLS- 350/Gilbarco EMC		No	
02	25	09/25/1996	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
3426	No	04/20/2018	Double-Walled	Double Walled	Yes
Currently in Use		Mechanical Line Leak Detector	Pressurized	Non-corrodible	
Diesel	07/09/2008	Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	Continuous Interstitial Monitoring;MLLD Line Tightness Testing	No	
15,000		Gilbarco-Veeder Root/TLS- 350/Gilbarco EMC		No	
03	25	09/25/1996	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
3427	No	04/20/2018	Double-Walled	Double Walled	Yes
Currently in Use		Mechanical Line Leak Detector	Pressurized	Non-corrodible	
Gasoline	07/09/2008	Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	Continuous Interstitial Monitoring;MLLD Line Tightness Testing	No	
10,000		Gilbarco-Veeder Root/TLS- 350/Gilbarco EMC		No	

Facility Summary in Glacier County in the City of Browning

Location: PARK CAFE AND GROCERY
3147 US Hwy 89 W
Browning, MT 59417-9701 Glacier

Legacy ID:18-06436

Facility ID: 21989
Last Inspected On: 04/06/2020
Operating Permit Renewal Date: 05/30/2023

Owner Operator Contact:

Operator Contact: Keith Hilton

4062501193

Owner/Operator: Hilton Family Corporation

Owner/Operator: Neil Miller

Keith Hilton, UST Class A Operator

Keith Hilton, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
05	30	11/01/1991	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
1380	No			None	Yes
Temporarily Out of Use			Mechanical Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	No
12,000		05/11/2017	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
06	30	11/01/1991	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
1381	No			None	Yes
Temporarily Out of Use			Mechanical Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	No
6,000		05/11/2017	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
07	30	11/01/1991	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
1382	No			None	Yes
Temporarily Out of Use			Mechanical Line Leak Detector	Pressurized	Non-corrodible
Diesel			Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	No
2,000		05/11/2017	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No

Facility Summary in Glacier County in the City of Browning

Location: SCHOOL DIST 9 MAINTENANCE COMPLEX
105 E Boundary St
Browning, MT 59417 Glacier

Legacy ID:18-03868

Facility ID: 21947
Last Inspected On: 09/26/2018
Operating Permit Renewal Date: 03/22/2022

Owner Operator Contact:

Operator Contact: Teri DeRoche

4063382952

Owner/Operator: School Dist 9 Browning

Ryan Wood, UST Class B Global Operator
Teri DeRoche, UST Class A Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
02	35	11/29/1986	Cathodically Protected Steel	Steel	Flapper Valve
4130	No			None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Gasoline		09/26/2018	Automatic Tank Gauging 0.2	Deferred	No
8,000			Gilbarco/EMC Basic		No
03	32	11/28/1989	Steel Clad	Steel	Flapper Valve
4131	No			None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Diesel		09/26/2018	Automatic Tank Gauging 0.2	Deferred	No
8,000			Gilbarco/EMC Basic		No

Facility Summary in Glacier County in the City of Browning

Location: SCHOOL DIST 9 TRANSPORTATION DEPT
829 SW Boundary St
Browning, MT 59417 Glacier

Legacy ID:18-12747

Facility ID: 22038
Last Inspected On: 09/26/2018
Operating Permit Renewal Date: 03/22/2022

Owner Operator Contact: John Walter;Browning Public Schools

Operator Contact: Teri DeRoche

4063382952

Owner/Operator: School Dist 9 Browning

Ryan Wood, UST Class B Global Operator

Teri DeRoche, UST Class A Operator

Teri DeRoche, UST Class B Global Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
01	29	07/01/1992	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
1898	No			None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		09/26/2018	Automatic Tank Gauging 0.2	ELLD 0.2	No
8,000		09/08/2009	Gilbarco/EMC Basic		No
02	29	07/01/1992	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
1899	No			None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Diesel		09/26/2018	Automatic Tank Gauging 0.2	ELLD 0.2	No
8,000		09/08/2009	Gilbarco/EMC Basic		No
03	29	07/01/1992	Cathodically Protected Steel	Flexible Plastic	High Level Alarm
1900	No	09/18/2018		Double Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Impressed Current
Oil, Waste		09/26/2018	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring	No
1,000		09/08/2009	Gilbarco/EMC Basic		No

Facility Summary in Glacier County in the City of Browning

Location: TOWN PUMP INC BROWNING 2
304 SE Boundary St
Browning, MT 59417 Glacier

Legacy ID:18-08677

Facility ID: 22011
Last Inspected On: 01/20/2019
Operating Permit Renewal Date: 04/01/2022

Owner Operator Contact: Kevin Kenneally;Major Brands Dist Imports Inc;Major Brands Dist Imports Inc **4067829121**

Operator Contact: Daniel Sampson

Owner/Operator: Major Brands Dist Imports Inc

Daniel Sampson, UST Class A Operator
Daniel Sampson, UST Class B Global Operator
Don Edmisten, UST Class B Global Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
09	26	06/01/1995	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve;Flapper Valve
2463	No		Double-Walled	Double Walled	Yes
Currently in Use		07/11/2013	Electronic Line Leak Detector	Pressurized	
Gasoline		11/26/2012	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
12,000		12/01/2006			No
11	26	06/01/1995	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
2465	No		Double-Walled	Double Walled	Yes
Currently in Use		07/11/2013	Electronic Line Leak Detector	Pressurized	
Gasoline		11/26/2012	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
12,000		11/30/2006			No
12	26	06/01/1995	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve;Flapper Valve

2466	No		Double-Walled	Double Walled	Yes
Currently in Use		07/11/2013	Electronic Line Leak Detector	Pressurized	
Gasoline		12/04/2009	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
12,000		11/30/2006			No
13	26	06/01/1995	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
2467	No		Double-Walled	Double Walled	Yes
Currently in Use		07/11/2013	Electronic Line Leak Detector	Pressurized	
Diesel		11/26/2012	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
12,000		11/30/2006			No
14	18	08/14/2003	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve;Flapper Valve
4859	No		Double-Walled	Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	
Diesel		12/04/2009	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
10,000		12/01/2006			No
15	18	08/14/2003	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4860	No		Double-Walled	Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	
Diesel		11/26/2012	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
5,000		12/01/2006			No
10	26	06/01/1995	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve

4888	No		Double-Walled	Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	
Diesel	11/26/2012		Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
12,000	11/30/2006				No

Facility Summary in Glacier County in the City of Cut Bank

Location: BEN TAYLOR INC - CUT BANK BULK PLANT
201 BN Industrial Site
Cut Bank, MT 59427-2936 Glacier

Legacy ID:18-04137

Facility ID: 21958
Last Inspected On: 08/28/2019
Operating Permit Renewal Date: 11/17/2022

Owner Operator Contact: Ben Taylor Inc;Ben Taylor;Ben Taylor Inc

4064345076

Operator Contact: Scott Curry;Shannon Gabbard

4068732812

Owner/Operator: Ben Taylor Inc

Scott Curry, UST Class A Operator
Shannon Gabbard, UST Class A Operator
Shannon Gabbard, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
S16	21	10/29/2000	Unknown	Flexible Plastic	
4241	Yes	04/18/2014		Double Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	
Gasoline			Deferred	Continuous Interstitial Monitoring;MLLD Line Tightness Testing	No
34,000					No
S17	21	10/29/2000	Unknown	Flexible Plastic	
4242	Yes	04/18/2014		Double Walled	Yes

Currently in Use			Mechanical Line Leak Detector	Pressurized	
Gasoline			Deferred	Continuous Interstitial Monitoring;MLLD Line Tightness Testing	No
11,700					No
S18	21	10/29/2000	Unknown	Flexible Plastic	
4243	Yes	04/18/2014		Double Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	
Diesel			Deferred	Continuous Interstitial Monitoring;MLLD Line Tightness Testing	No
12,500					No
S19	21	10/29/2000	Unknown	Flexible Plastic	
4244	Yes	04/18/2014		Double Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	
Diesel			Deferred	Continuous Interstitial Monitoring;MLLD Line Tightness Testing	No
34,000					No
S20	21	10/29/2000	Unknown	Flexible Plastic	
4245	Yes	04/18/2014		Double Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	
Diesel			Deferred	Continuous Interstitial Monitoring;MLLD Line Tightness Testing	No
12,500					No
S21	21	10/29/2000	Unknown	Flexible Plastic	
4246	Yes	04/18/2014		Double Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	

Diesel	Deferred	Continuous Interstitial Monitoring;MLLD Line Tightness Testing	No
11,700			No

Facility Summary in Glacier County in the City of Cut Bank

Location: CUT BANK MUNICIPAL AIRPORT
2705 Valier Hwy
Cut Bank, MT 59427 Glacier

Legacy ID:18-00137

Facility ID: 21903
Last Inspected On: 08/02/2019
Operating Permit Renewal Date: 01/31/2023

Owner Operator Contact: Cut Bank Airport Authority;David Anderson;Cut Bank Airport Authority **4068738683**

Operator Contact: David Ries;Ronald Hermanet;Roy Nollkamper **4068738683**

Owner/Operator: Cut Bank Airport Authority

- David Ries, UST Class A Operator
- David Ries, UST Class B Global Operator
- Ronald Hermanet, UST Class A Operator
- Roy Nollkamper, UST Class A Operator
- Roy Nollkamper, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
08	24	11/01/1997	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve;Flapper Valve
793	No	05/09/2016		Double Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Non-corrodible
Jet Fuel (Jet-A, Jet-A1, JP5)			Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring;MLLD Line Tightness Testing	No
12,000			Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
09	24	11/01/1997	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve;Flapper Valve
794	No	05/09/2016		Double Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Non-corrodible

Aviation Gas	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring;MLLD Line Tightness Testing	No
12,000	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No

Facility Summary in Glacier County in the City of Cut Bank

Location: HARVEST STATES COOP CUT BANK
29 N Central Ave
Cut Bank, MT 59427-2995 Glacier

Legacy ID:18-13623

Facility ID: 22046
Last Inspected On:
Operating Permit Renewal Date:

Owner Operator Contact: Harvest States Coop Cut Bank

4068732081

Operator Contact:

Owner/Operator: Harvest States Coop Cut Bank

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
S1	26	05/20/1995	Unknown	Steel	
	Yes			None	Yes
Currently in Use				Safe Suction	
Hazardous Substance			Deferred	Not Listed	No
1,000					No

Facility Summary in Glacier County in the City of Cut Bank

Location: KENNYS SUPER SERVICE
401 E Main St
Cut Bank, MT 59427-3014 Glacier

Legacy ID:18-00321

Facility ID: 21907
Last Inspected On: 09/28/2021
Operating Permit Renewal Date: 11/04/2023

Owner Operator Contact: Kennys Super Service

4068732432

Operator Contact: Randall Fetters

4068732432

Owner/Operator: Kennys Super Service

Owner/Operator: Randy Fetters

Randy Fetters, UST Class A Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
01	36	06/13/1985	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
1471	No			None	Yes
Temporarily Out of Use		07/20/2007	Not Required	Safe Suction	Galvanic
Gasoline		08/15/2017	Automatic Tank Gauging 0.2	Deferred	No
6,000			EMCO Electronics/EECO 1500		No
02	36	06/13/1985	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
1472	No			None	Yes
Temporarily Out of Use		07/20/2007	Not Required	Safe Suction	Galvanic
Gasoline		08/15/2017	Automatic Tank Gauging 0.2	Deferred	No
6,000			EMCO Electronics/EECO 1500		No

Facility Summary in Glacier County in the City of Cut Bank

Location: SIMONS PETROLEUM
813 E Railroad St
Cut Bank, MT 59427 Glacier

Legacy ID:56-13775

Facility ID: 30464
Last Inspected On: 02/27/2020
Operating Permit Renewal Date: 07/30/2023

Owner Operator Contact: Ben Taylor Inc;Ben Taylor;Ben Taylor Inc

4064345076

Operator Contact: Scott Curry;Steve Nelson

4068734612

Owner/Operator: Ben Taylor Inc

Owner/Operator: Unclaimed

- Joseph Pehan, UST Class B Operator
- Justin Aikins, UST Class B Operator
- Scott Curry, UST Class A Operator
- Steve Nelson, UST Class A Operator
- Steve Nelson, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
S1	24	10/31/1997	Bare Steel	Flexible Plastic	
1928	Yes	03/02/2012		Double Walled	Yes
Currently in Use		01/03/2012	Electronic Line Leak Detector	Pressurized	
Diesel			Deferred	Continuous Interstitial Monitoring; ELLD 0.2	No
12,000					No
S2	24	10/31/1997	Bare Steel	Flexible Plastic	
1929	Yes	03/02/2012		Double Walled	Yes
Currently in Use		01/03/2012	Electronic Line Leak Detector	Pressurized	
Gasoline			Deferred	Continuous Interstitial Monitoring; ELLD 0.2	No
8,000					No
03	9	03/01/2012	Unknown	Flexible Plastic	
5494	Yes	03/02/2012		Double Walled	No
Currently in Use			Electronic Line Leak Detector	Pressurized	
Diesel			Deferred	Continuous Interstitial Monitoring; ELLD 0.2	No
11,800					No

Facility Summary in Glacier County in the City of Cut Bank

Location: TOWN PUMP INC CUT BANK 2
510 W Main St
Cut Bank, MT 59427-2808 Glacier

Legacy ID:18-03417

Facility ID: 21942
Last Inspected On: 07/15/2021
Operating Permit Renewal Date: 10/04/2024

Owner Operator Contact:

Operator Contact: Trent Biggers

Owner/Operator: Cut Bank 2 Town Pump LLC

Trent Biggers, UST Class A Operator

Trent Biggers, UST Class B Global Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
01	28	03/01/1993	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
2459	No			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel			Approved Remote Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
10,000		12/02/2009	Gilbarco-Veeder Root/TLS-350		No
02	28	03/01/1993	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve;Flapper Valve
2460	No			None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Approved Remote Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Statistical Inventory Reconciliation	No
12,000		12/02/2009	Gilbarco-Veeder Root/TLS-350		No
03	28	03/01/1993	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve
2461	No			None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Approved Remote Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Statistical Inventory Reconciliation	No
12,000		12/02/2009	Gilbarco-Veeder Root/TLS-350		No

04	28	03/01/1993	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
2462	No			None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel			Approved Remote Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Statistical Inventory Reconciliation	No
12,000		12/02/2009	Gilbarco-Veeder Root/TLS-350		No
07	21	05/01/2000	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4185	No		Double-Walled	Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel			Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
10,000		12/02/2009	Gilbarco-Veeder Root/TLS-350		No
08	21	05/01/2000	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4186	No		Double-Walled	Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel			Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
5,000		12/02/2009	Gilbarco-Veeder Root/TLS-350		No

Facility Summary in Glacier County in the City of Cut Bank

Location: TOWN PUMP OF CUT BANK #3
1119 E Main St
Cut Bank, MT 59427 Glacier

Legacy ID:60-15144

Facility ID: 30888
Last Inspected On: 06/14/2021
Operating Permit Renewal Date: 12/11/2024

Owner Operator Contact:

Operator Contact: Trent Biggers

Owner/Operator: Cut Bank 1 Town Pump LLC

Trent Biggers, UST Class A Operator
Trent Biggers, UST Class B Global Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
01	11	07/03/2010	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
5227	No		Double-Walled	Double Walled	Yes
Currently in Use		07/03/2010	Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
20,000			Gilbarco-Veeder Root/TLS-350		Yes
02	11	07/03/2010	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
5228	No		Double-Walled	Double Walled	Yes
Currently in Use		07/03/2010	Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel			Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
12,000			Gilbarco-Veeder Root/TLS-350		Yes
03	11	07/03/2010	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
5229	No		Double-Walled	Double Walled	Yes
Currently in Use		07/03/2010	Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
8,000			Gilbarco-Veeder Root/TLS-350		Yes

Facility Summary in Glacier County in the City of East Glacier Park

Location: BEAR TRACK TRAVEL CENTER
20958 US Hwy 2
East Glacier Park, MT 59434 Glacier

Legacy ID:56-13933

Facility ID: 30603
Last Inspected On: 01/28/2019
Operating Permit Renewal Date: 06/30/2022

Owner Operator Contact:

Operator Contact: Julie Fortune

4062265504

Owner/Operator: Fortune Development Corp

Jim Fortune, UST Class B Operator
Julie Fortune, UST Class A Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
S1	22	06/01/1999	Unknown	Flexible Plastic	High Level Alarm
4068	Yes		Double-Walled	Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	
Diesel			Deferred	ELLD 0.2	No
8,000					No
S2	22	06/01/1999	Unknown	Flexible Plastic	High Level Alarm
4069	Yes		Double-Walled	Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	
Gasoline			Deferred	ELLD 0.2	No
5,000					No
S3	14	09/14/2007	Concrete	Flexible Plastic	High Level Alarm
5126	Yes		Double-Walled	Double Walled	Yes
Currently in Use		04/23/2007	Electronic Line Leak Detector	Pressurized	
Gasoline			Deferred	ELLD 0.2	No

12,000

Yes

Facility Summary in Glacier County in the City of East Glacier Park

Location: SEARS MOTEL and GIFT SHOP
1023 Hwy 49 N
East Glacier Park, MT 59434 Glacier

Legacy ID:18-03870

Facility ID: 21948
Last Inspected On: 02/05/2021
Operating Permit Renewal Date: 12/31/2020

Owner Operator Contact: Judy Jones

2396940279

Operator Contact: Judy Jones

2396940279

Owner/Operator: Judy Jones

Judy Jones, UST Class A Operator
Judy Jones, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
03	31	09/28/1990	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve
1453	No			None	Yes
Temporarily Out of Use			Not Required	Safe Suction	Non-corrodible
Gasoline			Automatic Tank Gauging 0.2	Deferred	No
2,000			Gilbarco/EMC Basic		No
04	31	09/01/1990	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve
1454	No			None	Yes
Temporarily Out of Use			Not Required	Safe Suction	Non-corrodible
Gasoline			Automatic Tank Gauging 0.2	Deferred	No
2,000			Gilbarco/EMC Basic		No

Facility Summary in Glacier County in the City of Saint Mary

Location: SAINT MARY RANGER STATION
73 Hudson Bay Rd
Saint Mary, MT 59411 Glacier

Legacy ID:18-02745

Facility ID: 21939
Last Inspected On: 10/30/2018
Operating Permit Renewal Date: 04/04/2022

Owner Operator Contact: National Park Service Browning

4067327724

Operator Contact: Jeff Wysong;Mark Hickcox

4067327721;4067327724

Owner/Operator: National Park Service Browning

Jeff Wysong, UST Class A Operator
Mark Hickcox, UST Class A Operator
Mark Hickcox, UST Class B Global Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
04	34	07/01/1987	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve
1221	No	12/20/2012		Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		10/30/2018	Automatic Tank Gauging 0.2	ELLD 0.2	No
12,000		11/03/2015	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
06	6	10/01/2015	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve
5620	No	10/28/2015	Double-Walled	Double Walled	Yes
Currently in Use		10/28/2015	Not Required	Safe Suction	
Diesel			Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	Deferred	No
10,000			Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		Yes

Facility Summary in Glacier County in the City of Saint Mary

Location: ST MARY LODGE
3 Going To The Sun Rd
Saint Mary, MT 59411 Glacier

Legacy ID:18-01907

Facility ID: 21924
Last Inspected On: 10/09/2020
Operating Permit Renewal Date: 10/20/2023

Owner Operator Contact: Glacier Park Inc;Jon Noe

4067324431;4068926708

Operator Contact: Jon Noe;Lisa Wyrick

4062265675;4067324431

Owner/Operator: Glacier Park Inc

Owner/Operator: Sally Black Welder

Bob Hines, UST Class B Operator

Jon Noe, UST Class A Operator

Lisa Wyrick, UST Class A Operator

Lisa Wyrick, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
01	31	06/01/1990	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
451	No			None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		05/29/2017	Automatic Tank Gauging 0.2	ELLD 0.2	No
15,000		10/17/2007	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
02	31	06/01/1990	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
452	No			Secondary Containment Chase	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		05/29/2017	Automatic Tank Gauging 0.2	ELLD 0.2	No
15,000		10/17/2007	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
03	31	06/01/1990	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
453	No			Secondary Containment Chase	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic

Gasoline		05/29/2017	Automatic Tank Gauging 0.2	ELLD 0.2	No
7,000		10/17/2007	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
04	31	06/01/1990	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
454	No			Secondary Containment Chase	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		05/29/2017	Automatic Tank Gauging 0.2	ELLD 0.2	No
3,000		10/17/2011	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No