

Facility Summary in Glacier County in the City of Babb

Location: THRONSONS STORE
US Hwy 89
Babb, MT 59411 Glacier

System Facility ID:18-03871

Facility Code: 21949
Last Inspected On: 06/02/2023
Operating Permit Renewal Date: 09/03/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Thronsons Store (406) 732-5530

Operator Contact: Michael Thronson (406) 732-5530 mikethronson@hotmail.com

Owner/Operator: Thronsons Store (406) 732-5530

Michael Thronson, UST Class A Operator mikethronson@hotmail.com

Michael Thronson, UST Class B Global Operator mikethronson@hotmail.com

Tank Code	07	Tank Age	37	Tank Installed Date	12/31/1989	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve
Tag Number	4401	Spill Test Date	06/30/2021	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	None	AST	No
Tank Status	Temporarily Out of Use	MLLD Test Date	05/26/2020	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	06/01/2023	Primary Tank Leak Detection	Manual Interstitial Monitoring	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	7000	ATG Test Date		Line Tightness Test Date	05/26/2020	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	09/09/2023			ATG Type					
Tank Code	08	Tank Age	37	Tank Installed Date	12/31/1989	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve
Tag Number	4402	Spill Test Date	05/22/2025	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Single Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	05/22/2025	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	06/01/2023	Primary Tank Leak Detection	Manual Interstitial Monitoring	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	3000	ATG Test Date		Line Tightness Test Date	05/22/2025	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	09/09/2021			ATG Type					
Tank Code	06	Tank Age	37	Tank Installed Date	12/31/1989	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve
Tag Number	4403	Spill Test Date	05/22/2025	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	None	AST	No

Tank Status	Currently in Use	MLLD Test Date	05/22/2025	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLL D Test Date		Tank/Piping CP Test Date	06/01/2023	Primary Tank Leak Detection	Manual Interstitial Monitoring	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	8000	ATG Test Date		Line Tightness Test Date	05/22/2025	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	09/09/2021			ATG Type					

Facility Summary in Glacier County in the City of Browning

Location: CORNER STORE
330 W Central Ave
Browning, MT 59417 Glacier

System Facility ID:18-05813

Facility Code: 21980
Last Inspected On: 11/09/2023
Operating Permit Renewal Date: 03/13/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: CORNER STORE

(406) 338-2575

JAMIE.ALICE@HOTMAIL.COM

Operator Contact:

Owner/Operator: CORNER STORE

(406) 338-2575

JAMIE.ALICE@HOTMAIL.COM

Tank Code	04	Tank Age	29	Tank Installed Date	01/03/1997	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	4441	Spill Test Date	09/19/2023	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	09/19/2023	Tank/Piping CP Test Date	09/19/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	20000	ATG Test Date	09/19/2023	Line Tightness Test Date	12/10/2008	Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	09/19/2023			ATG Type	Gilbarco/EMC Basic				
Tank Code	05	Tank Age	29	Tank Installed Date	01/03/1997	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	4442	Spill Test Date	05/21/2024	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	09/19/2023	Tank/Piping CP Test Date	09/19/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	12000	ATG Test Date	09/19/2023	Line Tightness Test Date	05/25/2017	Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	05/21/2024			ATG Type	Gilbarco/EMC Basic				
Tank Code	06	Tank Age	29	Tank Installed Date	01/03/1997	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve

Tag Number	4443	Spill Test Date	09/19/2023	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	09/19/2023	Tank/Piping CP Test Date	09/19/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	12000	ATG Test Date	09/19/2023	Line Tightness Test Date	05/25/2017	Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	09/19/2023			ATG Type	Gilbarco/EMC Basic				

Facility Summary in Glacier County in the City of Browning

Location: GLACIER FAMILY FOODS
601 SE Boundary St
Browning, MT 59417 Glacier

System Facility ID: 60-15286

Facility Code: 30993
Last Inspected On: 05/28/2025
Operating Permit Renewal Date: 10/14/2028

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Siyeh Development Corporation

TArmstrong@glaciercash.com

Operator Contact: Dori Johnson; Siyeh Development Corporation; Mark Magee

dori.johnson@siyehdevelopment.com; TArmstrong@glaciercash.com; mark.magee@siyehinc.com

Owner/Operator: Siyeh Development Corporation

TArmstrong@glaciercash.com

Dori Johnson, UST Class A Operator

TArmstrong@glaciercash.com

Dori Johnson, UST Class B Operator

dori.johnson@siyehdevelopment.com

Mark Magee, UST Class A Operator

mark.magee@siyehinc.com

Mark Magee, UST Class B Operator

mark.magee@siyehinc.com

Tank Code	01	Tank Age	11	Tank Installed Date	10/01/2015	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve; High Level Alarm
Tag Number	5673	Spill Test Date	05/28/2025	Piping Installed Date	10/01/2015	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	05/28/2025	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	04/17/2019	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	12000	ATG Test Date	05/28/2025	Line Tightness Test Date		Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	05/28/2025			ATG Type	Incon/TS-550 EVO				
Tank Code	02	Tank Age	11	Tank Installed Date	10/01/2015	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve; High Level Alarm
Tag Number	5674	Spill Test Date	05/28/2025	Piping Installed Date	10/01/2015	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	05/28/2025	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel, Dyed	PLLD Test Date	04/17/2019	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	8000	ATG Test Date	05/28/2025	Line Tightness Test Date		Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes

		Overfill Test Date	05/28/2025			ATG Type	Incon/TS-550 EVO			
Tank Code	03	Tank Age	11	Tank Installed Date	10/01/2015	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types
Tag Number	5675	Spill Test Date	05/28/2025	Piping Installed Date	10/01/2015	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	05/28/2025	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types
Product	Gasoline	PLLD Test Date	04/17/2019	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery
Capacity	20000	ATG Test Date	05/28/2025	Line Tightness Test Date		Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act
		Overfill Test Date	05/28/2025			ATG Type	Incon/TS-550 EVO			
Tank Code	04	Tank Age	11	Tank Installed Date	10/01/2015	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types
Tag Number	5676	Spill Test Date	05/28/2025	Piping Installed Date	10/01/2015	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	05/28/2025	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types
Product	Gasoline	PLLD Test Date	04/17/2019	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery
Capacity	8000	ATG Test Date	05/28/2025	Line Tightness Test Date		Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act
		Overfill Test Date	05/28/2025			ATG Type	Incon/TS-550 EVO			

Facility Summary in Glacier County in the City of Browning

Location: GLACIER WAY CONVENIENCE STORE
200 MT Hwy 464
Browning, MT 59417 Glacier

System Facility ID: 18-13768

Facility Code: 22049
Last Inspected On: 12/21/2023
Operating Permit Renewal Date: 12/20/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Pat Schildt (406) 338-4464 pschildt2@yahoo.com

Operator Contact: Charles Lafley; Harold Schildt; Stacey Keller (406) 338-4464; (406) 338-7568; (775) 560-2318 s_keller21@yahoo.com

Owner/Operator: Pat Schildt (406) 338-4464 pschildt2@yahoo.com

Charles Lafley, UST Class A Operator

Charles Lafley, UST Class B Global Operator

Harold Schildt, UST Class A Operator

Harold Schildt, UST Class B Global Operator

Stacey Keller, UST Class A Operator

Stacey Keller, UST Class B Global Operator

s_keller21@yahoo.com

s_keller21@yahoo.com

Tank Code	01	Tank Age	30	Tank Installed Date	09/25/1996	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	3425	Spill Test Date	12/12/2023	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	07/17/2023	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	07/09/2008	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	20000	ATG Test Date	07/17/2023	Line Tightness Test Date	07/17/2023	Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	07/17/2023			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	02	Tank Age	30	Tank Installed Date	09/25/1996	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	3426	Spill Test Date	12/12/2023	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	07/17/2023	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	07/09/2008	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No

Capacity	15000	ATG Test Date	07/17/2023	Line Tightness Test Date	07/17/2023	Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	12/12/2023			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	03	Tank Age	30	Tank Installed Date	09/25/1996	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	3427	Spill Test Date	07/17/2023	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	07/17/2023	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	07/09/2008	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	10000	ATG Test Date	07/17/2023	Line Tightness Test Date	07/17/2023	Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	07/17/2023			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Glacier County in the City of Browning

Location: PARK CAFE AND GROCERY
3147 US Hwy 89 W
Browning, MT 59417-9701 Glacier

System Facility ID: 18-06436

Facility Code: 21989
Last Inspected On: 07/29/2025
Operating Permit Renewal Date: 09/30/2028

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Hilton Family Corporation (406) 250-1193 hh.electric@yahoo.com

Operator Contact: Keith Hilton (406) 250-1193 hh.electric@yahoo.com

Owner/Operator: Hilton Family Corporation (406) 250-1193 hh.electric@yahoo.com

Keith Hilton, UST Class A Operator hh.electric@yahoo.com

Keith Hilton, UST Class B Operator hh.electric@yahoo.com

Tank Code	05	Tank Age	35	Tank Installed Date	11/01/1991	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve
Tag Number	1380	Spill Test Date	05/05/2025	Piping Installed Date		Tank Construction		Piping Construction	Single Walled	AST	No
Tank Status	Temporarily Out of Use	MLLD Test Date	05/05/2025	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	24000	ATG Test Date	05/05/2025	Line Tightness Test Date	05/05/2025	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	05/05/2025			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	06	Tank Age	35	Tank Installed Date	11/01/1991	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve
Tag Number	1381	Spill Test Date	05/05/2025	Piping Installed Date		Tank Construction		Piping Construction	Single Walled	AST	No
Tank Status	Temporarily Out of Use	MLLD Test Date	05/05/2025	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	12000	ATG Test Date	05/05/2025	Line Tightness Test Date	05/05/2025	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	05/05/2025			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	07	Tank Age	35	Tank Installed Date	11/01/1991	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve

Tag Number	1382	Spill Test Date	05/05/2025	Piping Installed Date		Tank Construction		Piping Construction	Single Walled	AST	No
Tank Status	Temporarily Out of Use	MLLD Test Date	05/05/2025	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	4000	ATG Test Date	05/05/2025	Line Tightness Test Date	05/05/2025	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	05/05/2025			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Glacier County in the City of Browning

Location: SCHOOL DIST 9 MAINTENANCE COMPLEX
105 E Boundary St
Browning, MT 59417 Glacier

System Facility ID:18-03868

Facility Code: 21947
Last Inspected On: 02/25/2025
Operating Permit Renewal Date: 03/22/2028

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: School Dist 9 Browning (406) 338-2952

Operator Contact: Reid Reagan (406) 338-2490 reidr@bps.k12.mt.gov

Owner/Operator: School Dist 9 Browning (406) 338-2952

Reid Reagan, UST Class A Operator
Reid Reagan, UST Class B Operator
reidr@bps.k12.mt.gov
reidr@bps.k12.mt.gov

Tank Code	02	Tank Age	40	Tank Installed Date	11/29/1986	Tank Material	Cathodically Protected Steel	Piping Material	Steel	Overfill Types	Flapper Valve
Tag Number	4130	Spill Test Date	04/05/2022	Piping Installed Date		Tank Construction		Piping Construction	Single Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	03/02/2022	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection		Vapor Recovery	No
Capacity	8000	ATG Test Date	03/12/2024	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	03/12/2024			ATG Type	Gilbarco/TLS-350				
Tank Code	03	Tank Age	37	Tank Installed Date	11/28/1989	Tank Material	Steel Clad	Piping Material	Steel	Overfill Types	Flapper Valve
Tag Number	4131	Spill Test Date	04/05/2022	Piping Installed Date		Tank Construction		Piping Construction	Single Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	03/02/2022	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection		Vapor Recovery	No
Capacity	8000	ATG Test Date	03/12/2024	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	03/12/2024			ATG Type	Gilbarco/TLS-350				

Facility Summary in Glacier County in the City of Browning

Location: SCHOOL DIST 9 TRANSPORTATION DEPT
829 SW Boundary St
Browning, MT 59417 Glacier

System Facility ID:18-12747

Facility Code: 22038
Last Inspected On: 02/25/2025
Operating Permit Renewal Date: 03/22/2028

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: School Dist 9 Browning (406) 338-2952

Operator Contact: Wayne Bulcalf;School Dist 9 Browning (406) 338-2952 francisb@bps.k12.mt.us

Owner/Operator: School Dist 9 Browning (406) 338-2952

Wayne Bulcalf, UST Class A Operator
Wayne Bulcalf, UST Class B Global Operator francisb@bps.k12.mt.us
francisb@bps.k12.mt.us

Tank Code	01	Tank Age	34	Tank Installed Date	07/01/1992	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	1898	Spill Test Date	03/02/2022	Piping Installed Date		Tank Construction		Piping Construction	Single Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date	03/12/2024	Tank/Piping CP Test Date	03/02/2022	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	8000	ATG Test Date	03/12/2024	Line Tightness Test Date	03/12/2024	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	03/12/2024			ATG Type	Gilbarco/TLS-350				
Tank Code	02	Tank Age	34	Tank Installed Date	07/01/1992	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	1899	Spill Test Date	03/23/2022	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Diesel	PLLD Test Date	03/12/2024	Tank/Piping CP Test Date	03/02/2022	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	8000	ATG Test Date	03/12/2024	Line Tightness Test Date	03/12/2024	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	03/12/2024			ATG Type	Gilbarco/TLS-350				
Tank Code	03	Tank Age	34	Tank Installed Date	07/01/1992	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	1900	Spill Test Date	03/02/2022	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No

Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Continuous Interstitial Monitoring	Piping Type	U.S. Suction	CP Met Types	Impressed Current
Product	Oil, Waste	PLL D Test Date		Tank/Piping CP Test Date	03/02/2022	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	1000	ATG Test Date	03/02/2022	Line Tightness Test Date	09/08/2009	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	03/22/2022			ATG Type	Gilbarco/TLS-350				

Facility Summary in Glacier County in the City of Browning

Location: TOWN PUMP INC BROWNING 2
304 SE Boundary St
Browning, MT 59417 Glacier

System Facility ID:18-08677

Facility Code: 22011
Last Inspected On: 03/15/2024
Operating Permit Renewal Date: 08/06/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Town Pump Inc Browning 2

Operator Contact: Trent Biggers

Trentb@townpump.com

Owner/Operator: Town Pump Inc Browning 2

Trent Biggers, UST Class A Operator

Trent Biggers, UST Class B Global Operator

Trentb@townpump.com

Trentb@townpump.com

Tank Code	09	Tank Age	31	Tank Installed Date	06/01/1995	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve;Flapper Valve
Tag Number	2463	Spill Test Date	07/07/2023	Piping Installed Date	07/11/2013	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	07/24/2025	Tank/Piping CP Test Date	11/26/2012	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	Yes
Capacity	12000	ATG Test Date	07/24/2025	Line Tightness Test Date	12/01/2006	Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	No
		Overfill Test Date	07/07/2023			ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	11	Tank Age	31	Tank Installed Date	06/01/1995	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve;Flapper Valve
Tag Number	2465	Spill Test Date	07/07/2023	Piping Installed Date	07/11/2013	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	07/24/2025	Tank/Piping CP Test Date	11/26/2012	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	Yes
Capacity	12000	ATG Test Date	07/24/2025	Line Tightness Test Date	11/30/2006	Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	No

		Overfill Test Date	07/07/2023			ATG Type	Gilbarco-Veeder Root/TLS-350			
Tank Code	12	Tank Age	31	Tank Installed Date	06/01/1995	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types
Tag Number	2466	Spill Test Date	08/29/2023	Piping Installed Date	07/11/2013	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types
Product	Diesel	PLLD Test Date	07/24/2025	Tank/Piping CP Test Date	12/04/2009	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery
Capacity	12000	ATG Test Date	07/24/2025	Line Tightness Test Date	11/30/2006	Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act
		Overfill Test Date	08/29/2023			ATG Type	Gilbarco-Veeder Root/TLS-350			
Tank Code	13	Tank Age	31	Tank Installed Date	06/01/1995	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types
Tag Number	2467	Spill Test Date	07/07/2023	Piping Installed Date	07/11/2013	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types
Product	Diesel	PLLD Test Date	07/24/2025	Tank/Piping CP Test Date	11/26/2012	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery
Capacity	12000	ATG Test Date	07/24/2025	Line Tightness Test Date	11/30/2006	Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act
		Overfill Test Date	07/07/2023			ATG Type	Gilbarco-Veeder Root/TLS-350			
Tank Code	14	Tank Age	23	Tank Installed Date	08/14/2003	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types
Tag Number	4859	Spill Test Date	07/07/2023	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types
Product	Diesel	PLLD Test Date	07/24/2025	Tank/Piping CP Test Date	12/04/2009	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery
Capacity	10000	ATG Test Date	07/24/2025	Line Tightness Test Date	12/01/2006	Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act
		Overfill Test Date	07/07/2023			ATG Type	Gilbarco-Veeder Root/TLS-350			
Tank Code	15	Tank Age	23	Tank Installed Date	08/14/2003	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types

Tag Number	4860	Spill Test Date	08/29/2023	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	07/24/2025	Tank/Piping CP Test Date	11/26/2012	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	5000	ATG Test Date	07/24/2025	Line Tightness Test Date	12/01/2006	Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	08/29/2023			ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	10	Tank Age	31	Tank Installed Date	06/01/1995	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve;Flapper Valve
Tag Number	4888	Spill Test Date	07/07/2023	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	07/24/2025	Tank/Piping CP Test Date	11/26/2012	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	Yes
Capacity	12000	ATG Test Date	07/24/2025	Line Tightness Test Date	11/30/2006	Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	07/07/2023			ATG Type	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Glacier County in the City of Cut Bank

Location: BEN TAYLOR INC - CUT BANK BULK PLANT
201 BN Industrial Site
Cut Bank, MT 59427-2936 Glacier

System Facility ID:18-04137

Facility Code: 21958
Last Inspected On: 05/29/2025
Operating Permit Renewal Date: 11/17/2028

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Ben Taylor Inc

bt1@3rivers.net

Operator Contact: Scott Curry;Shannon Gabbard

(406) 289-0525

scott.curry@btimontana.com;shannong@bentaylorinc.com

Owner/Operator: Ben Taylor Inc

bt1@3rivers.net

Scott Curry, UST Class A Operator

scott.curry@btimontana.com

Shannon Gabbard, UST Class A Operator

shannong@bentaylorinc.com

Shannon Gabbard, UST Class B Operator

shannong@bentaylorinc.com

Tank Code	S16	Tank Age	26	Tank Installed Date	10/29/2000	Tank Material	Unknown	Piping Material	Flexible Plastic	Overfill Types	
Tag Number	4241	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	Yes
Tank Status	Currently in Use	MLLD Test Date	05/29/2025	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection		Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	34000	ATG Test Date		Line Tightness Test Date	05/29/2025	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date				ATG Type					
Tank Code	S17	Tank Age	26	Tank Installed Date	10/29/2000	Tank Material	Unknown	Piping Material	Flexible Plastic	Overfill Types	
Tag Number	4242	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	Yes
Tank Status	Currently in Use	MLLD Test Date	05/29/2025	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection		Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	11700	ATG Test Date		Line Tightness Test Date	05/29/2025	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date				ATG Type					
Tank Code	S18	Tank Age	26	Tank Installed Date	10/29/2000	Tank Material	Unknown	Piping Material	Flexible Plastic	Overfill Types	

Tag Number	4243	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	Yes
Tank Status	Currently in Use	MLLD Test Date	05/29/2025	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection		Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	12500	ATG Test Date		Line Tightness Test Date	05/29/2025	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date				ATG Type					
Tank Code	S19	Tank Age	26	Tank Installed Date	10/29/2000	Tank Material	Unknown	Piping Material	Flexible Plastic	Overfill Types	
Tag Number	4244	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	Yes
Tank Status	Currently in Use	MLLD Test Date	05/29/2025	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Diesel, Dyed	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection		Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	34000	ATG Test Date		Line Tightness Test Date	05/29/2025	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date				ATG Type					
Tank Code	S20	Tank Age	26	Tank Installed Date	10/29/2000	Tank Material	Unknown	Piping Material	Flexible Plastic	Overfill Types	
Tag Number	4245	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	Yes
Tank Status	Currently in Use	MLLD Test Date	05/29/2025	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Diesel, Dyed	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection		Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	12500	ATG Test Date		Line Tightness Test Date	05/29/2025	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date				ATG Type					
Tank Code	S21	Tank Age	26	Tank Installed Date	10/29/2000	Tank Material	Unknown	Piping Material	Flexible Plastic	Overfill Types	
Tag Number	4246	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	Yes
Tank Status	Currently in Use	MLLD Test Date	05/29/2025	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection		Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	11700	ATG Test Date		Line Tightness Test Date	05/29/2025	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date				ATG Type					

Facility Summary in Glacier County in the City of Cut Bank

Location: BTI 813 E RAILROAD CARDLOCK
813 E Railroad St
Cut Bank, MT 59427 Glacier

System Facility ID: 56-13775

Facility Code: 30464
Last Inspected On: 03/08/2023
Operating Permit Renewal Date: 07/30/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Ben Taylor Inc

bt@3rivers.net

Operator Contact: Scott Curry; Steve Nelson

(406) 873-4612

ditchrider61@yahoo.com; scott.curry@btimontana.com

Owner/Operator: Ben Taylor Inc

bt@3rivers.net

Joseph Pehan, UST Class B Operator
Justin Aikins, UST Class B Operator
Scott Curry, UST Class A Operator
Steve Nelson, UST Class A Operator
Steve Nelson, UST Class B Operator

simonspt@3rivers.net
justinleeaikins@gmail.com
scott.curry@btimontana.com
ditchrider61@yahoo.com
ditchrider61@yahoo.com

Tank Code	S1	Tank Age	29	Tank Installed Date	10/31/1997	Tank Material	Bare Steel	Piping Material	Flexible Plastic	Overfill Types	
Tag Number	1928	Spill Test Date		Piping Installed Date	01/03/2012	Tank Construction		Piping Construction	Double Walled	AST	Yes
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	03/08/2023	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection		Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	12000	ATG Test Date		Line Tightness Test Date	02/26/2020	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date				ATG Type					
Tank Code	S2	Tank Age	29	Tank Installed Date	10/31/1997	Tank Material	Bare Steel	Piping Material	Flexible Plastic	Overfill Types	
Tag Number	1929	Spill Test Date		Piping Installed Date	01/03/2012	Tank Construction		Piping Construction	Double Walled	AST	Yes
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	03/08/2023	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection		Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	8000	ATG Test Date		Line Tightness Test Date	02/26/2020	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date				ATG Type					

Tank Code	03	Tank Age	14	Tank Installed Date	03/01/2012	Tank Material	Unknown	Piping Material	Flexible Plastic	Overfill Types	
Tag Number	5494	Spill Test Date		Piping Installed Date	03/01/2012	Tank Construction		Piping Construction	Double Walled	AST	Yes
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	03/08/2023	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection		Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	11800	ATG Test Date		Line Tightness Test Date	02/26/2020	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date				ATG Type					

Facility Summary in Glacier County in the City of Cut Bank

Location: CUT BANK MUNICIPAL AIRPORT
2705 Valier Hwy
Cut Bank, MT 59427 Glacier

System Facility ID:18-00137

Facility Code: 21903
Last Inspected On: 09/28/2022
Operating Permit Renewal Date: 01/31/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Cut Bank Airport Authority

Operator Contact: Ronald Hermanet;Roy Nollkamper;Tom Redfield

(406) 873-8683

cbaa_mt@yahoo.com

Owner/Operator: Cut Bank Airport Authority

Ronald Hermanet, UST Class A Operator

cbaa_mt@yahoo.com

Roy Nollkamper, UST Class A Operator

Roy Nollkamper, UST Class B Operator

Tom Redfield, UST Class A Operator

cbaa_mt@yahoo.com

Tom Redfield, UST Class B Global Operator

cbaa_mt@yahoo.com

Tank Code	08	Tank Age	29	Tank Installed Date	11/01/1997	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	793	Spill Test Date	07/12/2021	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	04/06/2022	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Jet Fuel (Jet-A, Jet-A1, JP5)	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	12000	ATG Test Date	04/06/2022	Line Tightness Test Date	04/06/2022	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	07/25/2022			ATG Type	Gilbarco-Veeder Root/EMC Basic				
Tank Code	09	Tank Age	29	Tank Installed Date	11/01/1997	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	794	Spill Test Date	07/12/2021	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	04/06/2022	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Aviation Gas	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	12000	ATG Test Date	04/06/2022	Line Tightness Test Date	04/06/2022	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No

	Overfill Test Date	07/25/2022		ATG Type	Gilbarco-Veeder Root/EMC Basic		
--	---------------------------	------------	--	-----------------	-----------------------------------	--	--

Facility Summary in Glacier County in the City of Cut Bank

Location: EZZIES CUT BANK
31 Old Kevin Hwy
Cut Bank, MT 59427 Glacier

System Facility ID:00-32578

Facility Code: 32578
Last Inspected On: 12/01/2025
Operating Permit Renewal Date: 02/01/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Ezzies Wholesale Inc

(406) 654-2331

bill@ezzies.com

Operator Contact: Ian Loch

ian.loch@yahoo.com

Owner/Operator: Ezzies Wholesale Inc

(406) 654-2331

bill@ezzies.com

Ian Loch, UST Class A Operator

ian.loch@yahoo.com

Tank Code	01	Tank Age	1	Tank Installed Date	06/19/2025	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	6253	Spill Test Date	06/19/2025	Piping Installed Date	06/19/2025	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	06/19/2025	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	12000	ATG Test Date	06/19/2025	Line Tightness Test Date		Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	06/19/2025			ATG Type					
Tank Code	02	Tank Age	1	Tank Installed Date	06/19/2025	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Steel with plastic coating	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	6254	Spill Test Date	06/19/2025	Piping Installed Date	06/19/2025	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	06/19/2025	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Methanol	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	12000	ATG Test Date	06/19/2025	Line Tightness Test Date		Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
Tank Code	03	Tank Age	1	Tank Installed Date	06/19/2025	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve;High Level Alarm

Tag Number	6255	Spill Test Date	06/19/2025	Piping Installed Date	06/19/2025	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	Yes
Capacity	12000	ATG Test Date	06/19/2025	Line Tightness Test Date		Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	06/19/2025			ATG Type					
Tank Code	04	Tank Age	2	Tank Installed Date	09/01/2024	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	6256	Spill Test Date		Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0		Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection		Primary Pipe Detection		Vapor Recovery	No
Capacity	12000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	Yes
		Overfill Test Date				ATG Type					
Tank Code	05	Tank Age	2	Tank Installed Date	09/01/2024	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	
Tag Number	6257	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction		AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0		Piping Type	Pressurized	CP Met Types	
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection		Primary Pipe Detection		Vapor Recovery	Yes
Capacity	8000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	Yes
		Overfill Test Date				ATG Type					
Tank Code	06	Tank Age	2	Tank Installed Date	09/01/2024	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	
Tag Number	6258	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction		AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0		Piping Type	Pressurized	CP Met Types	
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection		Primary Pipe Detection		Vapor Recovery	No
Capacity	9000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	Yes
		Overfill Test Date				ATG Type					

Tank Code	07	Tank Age	2	Tank Installed Date	09/01/2024	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	
Tag Number	6259	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction		AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0		Piping Type	Pressurized	CP Met Types	
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection		Primary Pipe Detection		Vapor Recovery	No
Capacity	8000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	Yes
		Overfill Test Date				ATG Type					

Facility Summary in Glacier County in the City of Cut Bank

Location: TOWN PUMP INC CUT BANK 2
510 W Main St
Cut Bank, MT 59427-2808 Glacier

System Facility ID:18-03417

Facility Code: 21942
Last Inspected On: 03/13/2024
Operating Permit Renewal Date: 08/06/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Cut Bank 2 Town Pump LLC

(406) 497-6700

environmental@townpump.com

Operator Contact: Trent Biggers

Trentb@townpump.com

Owner/Operator: Cut Bank 2 Town Pump LLC

(406) 497-6700

environmental@townpump.com

Trent Biggers, UST Class A Operator

Trent Biggers, UST Class B Global Operator

Trentb@townpump.com

Trentb@townpump.com

Tank Code	01	Tank Age	33	Tank Installed Date	03/01/1993	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve
Tag Number	2459	Spill Test Date	07/19/2023	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	03/13/2024	Tank/Piping CP Test Date		Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	10000	ATG Test Date	03/13/2024	Line Tightness Test Date	12/02/2009	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	07/19/2023			ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	02	Tank Age	33	Tank Installed Date	03/01/1993	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve;Flapper Valve
Tag Number	2460	Spill Test Date	07/19/2023	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	03/13/2024	Tank/Piping CP Test Date		Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	12000	ATG Test Date	03/13/2024	Line Tightness Test Date	12/02/2009	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	07/19/2023			ATG Type	Gilbarco-Veeder Root/TLS-350				

Tank Code	03	Tank Age	33	Tank Installed Date	03/01/1993	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	2461	Spill Test Date	07/19/2023	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	03/13/2024	Tank/Piping CP Test Date		Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	12000	ATG Test Date	03/13/2024	Line Tightness Test Date	12/02/2009	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	07/19/2023			ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	04	Tank Age	33	Tank Installed Date	03/01/1993	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve
Tag Number	2462	Spill Test Date	07/19/2023	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	03/13/2024	Tank/Piping CP Test Date		Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	12000	ATG Test Date	03/13/2024	Line Tightness Test Date	12/02/2009	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	07/19/2023			ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	07	Tank Age	26	Tank Installed Date	05/01/2000	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	4185	Spill Test Date	07/19/2023	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	03/13/2024	Tank/Piping CP Test Date		Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	10000	ATG Test Date	03/13/2024	Line Tightness Test Date	12/02/2009	Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	07/19/2023			ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	08	Tank Age	26	Tank Installed Date	05/01/2000	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	4186	Spill Test Date	07/19/2023	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible

Product	Diesel	PLL D Test Date	03/13/2024	Tank/Piping CP Test Date		Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	5000	ATG Test Date	03/13/2024	Line Tightness Test Date	12/02/2009	Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	07/19/2023			ATG Type	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Glacier County in the City of Cut Bank

Location: TOWN PUMP OF CUT BANK 1
1119 E Main St
Cut Bank, MT 59427 Glacier

System Facility ID: 60-15144

Facility Code: 30888
Last Inspected On: 03/13/2024
Operating Permit Renewal Date: 08/06/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Cut Bank 1 Town Pump LLC

(406) 497-6700

environmental@townpump.com

Operator Contact: Trent Biggers

Trentb@townpump.com

Owner/Operator: Cut Bank 1 Town Pump LLC

(406) 497-6700

environmental@townpump.com

Trent Biggers, UST Class A Operator

Trent Biggers, UST Class B Global Operator

Trentb@townpump.com

Trentb@townpump.com

Tank Code	01	Tank Age	16	Tank Installed Date	07/03/2010	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve
Tag Number	5227	Spill Test Date	07/26/2023	Piping Installed Date	07/03/2010	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	03/13/2024	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	20000	ATG Test Date	03/13/2024	Line Tightness Test Date		Secondary Tank Leak Detection	Statistical Inventory Reconciliation	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	Yes
		Overfill Test Date	07/26/2023			ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	02	Tank Age	16	Tank Installed Date	07/03/2010	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve
Tag Number	5228	Spill Test Date	07/06/2023	Piping Installed Date	07/03/2010	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	03/13/2024	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	12000	ATG Test Date	03/13/2024	Line Tightness Test Date		Secondary Tank Leak Detection	Statistical Inventory Reconciliation	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	Yes
		Overfill Test Date	07/06/2023			ATG Type	Gilbarco-Veeder Root/TLS-350				

Tank Code	03	Tank Age	16	Tank Installed Date	07/03/2010	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve
Tag Number	5229	Spill Test Date	07/06/2023	Piping Installed Date	07/03/2010	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	03/13/2024	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	8000	ATG Test Date	03/13/2024	Line Tightness Test Date		Secondary Tank Leak Detection	Statistical Inventory Reconciliation	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	Yes
		Overfill Test Date	07/06/2023			ATG Type	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Glacier County in the City of East Glacier Park

Location: BEAR TRACK TRAVEL CENTER
20958 US Hwy 2
East Glacier Park, MT 59434 Glacier

System Facility ID: 56-13933

Facility Code: 30603
Last Inspected On: 07/18/2024
Operating Permit Renewal Date: 11/23/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Blackfeet Tribe

Operator Contact: Mark Magee; Tahnee Armstrong; Siyeh Development Corporation; Thomas Bearchild

(406) 338-5669

mark.magee@siyehinc.com; tarmstrong96@yahoo.com; TArmstrong@glaciercash.com; tbearchild@glaciercash.com

Owner/Operator: Blackfeet Tribe

Mark Magee, UST Class A Operator

Mark Magee, UST Class B Operator

Tahnee Armstrong, UST Class A Operator

Tahnee Armstrong, UST Class B Operator

Thomas Bearchild, UST Class A Operator

Thomas Bearchild, UST Class B Operator

mark.magee@siyehinc.com

mark.magee@siyehinc.com

TArmstrong@glaciercash.com

TArmstrong@glaciercash.com

tbearchild@glaciercash.com

tbearchild@glaciercash.com

Tank Code	S1	Tank Age	27	Tank Installed Date	06/01/1999	Tank Material	Unknown	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	4068	Spill Test Date		Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	Yes
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection		Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	8000	ATG Test Date	07/18/2024	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	Manual Interstitial Monitoring	Energy Act	No
		Overfill Test Date	07/18/2024			ATG Type					
Tank Code	S2	Tank Age	27	Tank Installed Date	06/01/1999	Tank Material	Unknown	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	4069	Spill Test Date		Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	Yes
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection		Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	5000	ATG Test Date	07/18/2024	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	Manual Interstitial Monitoring	Energy Act	No
		Overfill Test Date	07/18/2024			ATG Type					

Tank Code	S3	Tank Age	19	Tank Installed Date	09/14/2007	Tank Material	Concrete	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	5126	Spill Test Date		Piping Installed Date	04/23/2007	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	Yes
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection		Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	12000	ATG Test Date	07/18/2024	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	Manual Interstitial Monitoring	Energy Act	No
		Overfill Test Date	07/18/2024			ATG Type					

Facility Summary in Glacier County in the City of East Glacier Park

Location: SEARS MOTEL and GIFT SHOP
1023 Hwy 49 N
East Glacier Park, MT 59434 Glacier

System Facility ID:18-03870

Facility Code: 21948
Last Inspected On: 02/05/2021
Operating Permit Renewal Date: 02/05/2024

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Judy Jones;William Stewart

(406) 226-4432;(406) 250-7525

EGlacier@aol.com;Sundaysun.bs@gmail.com

Operator Contact: Judy Jones

(406) 226-4432

EGlacier@aol.com

Owner/Operator: Judy Jones

(406) 226-4432

EGlacier@aol.com

Owner/Operator: William Stewart

(406) 226-4432

EGlacier@aol.com

Judy Jones, UST Class A Operator

Judy Jones, UST Class B Operator

EGlacier@aol.com

EGlacier@aol.com

Tank Code	03	Tank Age	36	Tank Installed Date	09/28/1990	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	1453	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	Single Walled	AST	No
Tank Status	Temporarily Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection		Vapor Recovery	No
Capacity	2000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco/EMC Basic				
Tank Code	04	Tank Age	36	Tank Installed Date	09/01/1990	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	1454	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Temporarily Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection		Vapor Recovery	No
Capacity	2000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco/EMC Basic				

Facility Summary in Glacier County in the City of Saint Mary

Location: SAINT MARY RANGER STATION
73 Hudson Bay Rd
Saint Mary, MT 59411 Glacier

System Facility ID: 18-02745

Facility Code: 21939
Last Inspected On: 12/23/2024
Operating Permit Renewal Date: 04/04/2028

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: National Park Service Browning (406) 732-7724 mark_hickcox@nps.gov

Operator Contact: Patrick Glynn (406) 888-7967 patrick_glynn@nps.gov

Owner/Operator: National Park Service Browning (406) 732-7724 mark_hickcox@nps.gov

Patrick Glynn, UST Class A Operator patrick_glynn@nps.gov

Patrick Glynn, UST Class B Global Operator patrick_glynn@nps.gov

Tank Code	04	Tank Age	39	Tank Installed Date	07/01/1987	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	1221	Spill Test Date	09/02/2024	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date	09/02/2024	Tank/Piping CP Test Date	11/10/2024	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	12000	ATG Test Date	09/02/2024	Line Tightness Test Date	11/03/2015	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	09/02/2024			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	06	Tank Age	11	Tank Installed Date	10/01/2015	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	5620	Spill Test Date	09/02/2024	Piping Installed Date	10/28/2015	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection		Vapor Recovery	No
Capacity	10000	ATG Test Date	09/02/2024	Line Tightness Test Date		Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection		Energy Act	Yes

	Overfill Test Date	09/02/2024		ATG Type	Gilbarco-Veeder Root/TLS- 350;Gilbarco- Veeder Root/TLS- 350/Gilbarco EMC		
--	---------------------------	------------	--	-----------------	---	--	--

Facility Summary in Glacier County in the City of Saint Mary

Location: ST MARY LODGE
3 Going To The Sun Rd
Saint Mary, MT 59411 Glacier

System Facility ID:18-01907

Facility Code: 21924
Last Inspected On: 06/01/2023
Operating Permit Renewal Date: 10/20/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Glacier Park Inc;Sally Welder

(406) 892-6708

lwyrick@pursuitcollection.com

Operator Contact: Jon Noe;Lisa Wyrick

(406) 226-5675;(406) 732-4431

lwyrick@pursuitcollection.com

Owner/Operator: Glacier Park Inc

(406) 892-6708

lwyrick@pursuitcollection.com

Owner/Operator: Sally Black Welder

(406) 892-6708

lwyrick@pursuitcollection.com

Bob Hines, UST Class B Operator

Jon Noe, UST Class A Operator

Lisa Wyrick, UST Class A Operator

Lisa Wyrick, UST Class B Operator

lhines@glacierparkinc.com

lwyrick@pursuitcollection.com

lwyrick@pursuitcollection.com

Tank Code	01	Tank Age	36	Tank Installed Date	06/01/1990	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve
Tag Number	451	Spill Test Date	04/07/2022	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date	06/18/2024	Tank/Piping CP Test Date	05/27/2020	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	15000	ATG Test Date	06/18/2024	Line Tightness Test Date	10/17/2007	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	04/07/2022			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	02	Tank Age	36	Tank Installed Date	06/01/1990	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve
Tag Number	452	Spill Test Date	04/07/2022	Piping Installed Date		Tank Construction		Piping Construction	Secondary Containment Chase	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date	06/18/2024	Tank/Piping CP Test Date	05/27/2020	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	15000	ATG Test Date	06/18/2024	Line Tightness Test Date	10/17/2007	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No

		Overfill Test Date	04/07/2022			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC			
Tank Code	03	Tank Age	36	Tank Installed Date	06/01/1990	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types
Tag Number	453	Spill Test Date	04/07/2022	Piping Installed Date		Tank Construction		Piping Construction	Secondary Containment Chase	AST
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types
Product	Gasoline	PLLD Test Date	06/18/2024	Tank/Piping CP Test Date	05/27/2020	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery
Capacity	7000	ATG Test Date	06/18/2024	Line Tightness Test Date	10/17/2007	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act
		Overfill Test Date	04/07/2022			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC			
Tank Code	04	Tank Age	36	Tank Installed Date	06/01/1990	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types
Tag Number	454	Spill Test Date	04/07/2022	Piping Installed Date		Tank Construction		Piping Construction	Secondary Containment Chase	AST
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types
Product	Diesel	PLLD Test Date	06/18/2024	Tank/Piping CP Test Date	05/27/2020	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery
Capacity	3000	ATG Test Date	06/18/2024	Line Tightness Test Date	10/17/2011	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act
		Overfill Test Date	04/07/2022			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC			