

**Facility Summary in Golden Valley County in the City of Lavina**

**Location:** FARMERS UNION TRADING CO - LAVINA  
 4666 MT Hwy 3  
 Lavina, MT 59046-7156 Golden Valley

Legacy ID:19-13681

**Facility ID:** 22075  
**Last Inspected On:** 06/24/2019  
**Operating Permit Renewal Date:** 10/24/2022

**Owner Operator Contact:** Farmers Union Trading Co Columbus

**4067800660**

**Operator Contact:** Jennifer Calovis

**4067800660**

**Owner/Operator:** Farmers Union Trading Co Columbus

David Maki, UST Class B Global Operator  
 David Maki, UST Class B Operator  
 Jacob Granger, UST Class B Operator  
 Jennifer Calovis, UST Class A Operator  
 Jennifer Calovis, UST Class B Global Operator  
 Samantha Tuss, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
S1	25	03/01/1996	Unknown	Flexible Plastic	
<b>3381</b>	Yes	10/21/2016		Double Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	
Diesel			Deferred	Continuous Interstitial Monitoring	No
10,000					No
S2	25	03/01/1996	Unknown	Flexible Plastic	
<b>3382</b>	Yes	10/21/2016		Double Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	
Gasoline			Deferred	Continuous Interstitial Monitoring	No
10,000					No

**Facility Summary in Golden Valley County in the City of Ryegate**

**Location:** RYEGATE PUBLIC SCHOOLS DIST 1  
207 2nd Ave W  
Ryegate, MT 59074-0129 Golden Valley

Legacy ID:19-07975

**Facility ID:** 22067  
**Last Inspected On:** 10/14/2021  
**Operating Permit Renewal Date:** 06/04/2022

**Owner Operator Contact:** Robert Heppner;Ryegate Public Schools;School Dist 1 4065682211  
Ryegate

**Operator Contact:** Penny Stradtman;Thomas Bracha

**Owner/Operator:** School Dist 1 Ryegate

Penny Stradtman, UST Class A Operator  
Penny Stradtman, UST Class B Operator  
Thomas Bracha, UST Class A Operator  
Thomas Bracha, UST Class B Global Operator  
Thomas Bracha, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
S2	25	08/01/1996	Bare Steel	Flexible Plastic	Flapper Valve
1870	Yes	04/19/2016		Double Walled	Yes
Currently in Use		07/30/2014	Auto Dialer	U.S. Suction	
Diesel			Deferred	Continuous Interstitial Monitoring	No
5,000		07/31/2014			No

**Facility Summary in Golden Valley County in the City of Ryegate**

**Location:** SUPER D GROCERY  
203 E Railway Ave  
Ryegate, MT 59074 Golden Valley

Legacy ID:19-13735

**Facility ID:** 22076  
**Last Inspected On:** 09/10/2021  
**Operating Permit Renewal Date:** 12/10/2024

**Owner Operator Contact:** Super D Grocery Inc

**Operator Contact:** Peggy Sutton

4065682378

**Owner/Operator:** Clifford Sutton

**Owner/Operator:** Super D Grocery Inc

Peggy Sutton, UST Class A Operator  
Peggy Sutton, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
S1	25	04/08/1996	Unknown	Flexible Plastic	High Level Alarm
<b>3462</b>	Yes			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	
Gasoline			Deferred	Continuous Interstitial Monitoring; ELLD 0.2	No
5,000					No
S2	23	12/01/1998	Unknown	Flexible Plastic	High Level Alarm
<b>3727</b>	Yes			Double Walled	Yes
Currently in Use		08/20/2008	Electronic Line Leak Detector	Pressurized	
Gasoline			Deferred	Continuous Interstitial Monitoring; ELLD 0.2	No
8,000					No
S3	23	12/01/1998	Unknown	Flexible Plastic	High Level Alarm
<b>3728</b>	Yes			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	
Diesel			Deferred	Continuous Interstitial Monitoring; ELLD 0.2	No
4,000					No