

Facility Summary in Golden Valley County in the City of Lavina

Location: FARMERS OASIS LLC
4666 MT Hwy 3
Lavina, MT 59046-7156 Golden Valley

System Facility ID:19-13681

Facility Code: 22075
Last Inspected On: 07/03/2025
Operating Permit Renewal Date: 10/24/2028

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Mike Bury;FARMERS OASIS LLC

(406) 632-4329;(561) 693-8795

mike@raysoasis.com;MIKE@RAYOASIS.COM

Operator Contact: Jeff Parker;FARMERS OASIS LLC

(406) 636-4005;(561) 693-8795

jeff@oasistravelcenters.com;MIKE@RAYOASIS.COM

Owner/Operator: Mike Bury,FARMERS OASIS LLC

(406) 632-4329

mike@raysoasis.com

Jeff Parker, UST Class A Operator

MIKE@RAYOASIS.COM

Jeff Parker, UST Class B Operator

MIKE@RAYOASIS.COM

Tank Code	S1	Tank Age	30	Tank Installed Date	03/01/1996	Tank Material	Unknown	Piping Material	Flexible Plastic	Overfill Types	
Tag Number	3381	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	Yes
Tank Status	Currently in Use	MLLD Test Date	07/03/2025	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Deferred	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	10000	ATG Test Date	07/03/2025	Line Tightness Test Date	07/14/2022	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					
Tank Code	S2	Tank Age	30	Tank Installed Date	03/01/1996	Tank Material	Unknown	Piping Material	Flexible Plastic	Overfill Types	
Tag Number	3382	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	Yes
Tank Status	Currently in Use	MLLD Test Date	07/03/2025	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Deferred	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	10000	ATG Test Date	07/03/2025	Line Tightness Test Date	07/14/2022	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					

Facility Summary in Golden Valley County in the City of Ryegate

Location: RYEGATE PUBLIC SCHOOLS DIST 1
207 2nd Ave W
Ryegate, MT 59074-0129 Golden Valley

System Facility ID:19-07975

Facility Code: 22067
Last Inspected On: 08/01/2024
Operating Permit Renewal Date: 11/01/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: School Dist 1 Ryegate

(406) 568-2211

Operator Contact: Penny Stradtman

pstradtman@ryegate.k12.mt.us

Owner/Operator: School Dist 1 Ryegate

(406) 568-2211

Penny Stradtman, UST Class A Operator

pstradtman@ryegate.k12.mt.us

Penny Stradtman, UST Class B Operator

pstradtman@ryegate.k12.mt.us

Tank Code	S2	Tank Age	30	Tank Installed Date	08/01/1996	Tank Material	Bare Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	1870	Spill Test Date		Piping Installed Date	07/30/2014	Tank Construction		Piping Construction	Double Walled	AST	Yes
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Auto Dialer	Piping Type	U.S. Suction	CP Met Types	
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection		Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	5000	ATG Test Date	05/28/2025	Line Tightness Test Date	07/31/2014	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					

Facility Summary in Golden Valley County in the City of Ryegate

Location: SUPER D GROCERY
203 E Railway Ave
Ryegate, MT 59074 Golden Valley

System Facility ID: 19-13735

Facility Code: 22076
Last Inspected On: 09/26/2024
Operating Permit Renewal Date: 12/10/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Clifford Sutton; Super D Grocery Inc (406) 568-2378 superd@midrivers.com

Operator Contact: Peggy Sutton (406) 568-2378 superd@midrivers.com

Owner/Operator: Clifford Sutton (406) 568-2378

Owner/Operator: Super D Grocery Inc (406) 568-2378

Peggy Sutton, UST Class A Operator

Peggy Sutton, UST Class B Operator

superd@midrivers.com

superd@midrivers.com

Tank Code	S1	Tank Age	30	Tank Installed Date	04/08/1996	Tank Material	Unknown	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	3462	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	Yes
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Deferred	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	5000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date				ATG Type					
Tank Code	S2	Tank Age	28	Tank Installed Date	12/01/1998	Tank Material	Unknown	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	3727	Spill Test Date		Piping Installed Date	08/20/2008	Tank Construction		Piping Construction	Double Walled	AST	Yes
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	09/25/2024	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Deferred	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	8000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date				ATG Type					
Tank Code	S3	Tank Age	28	Tank Installed Date	12/01/1998	Tank Material	Unknown	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm

Tag Number	3728	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	Yes
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Deferred	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	4000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date				ATG Type					