

Facility Summary in Granite County in the City of Drummond

Location: FICS KWIK SIX
410 E Front St
Drummond, MT 59832-9648 Granite

Legacy ID:20-03192

Facility ID: 22104
Last Inspected On: 08/14/2019
Operating Permit Renewal Date: 10/14/2022

Owner Operator Contact: Fickler Oil Co Inc Deer Lodge

4068463970

Operator Contact: Bonnie Cyr;Deanna Huberg;Judy Rasmussen

4062883220

Owner/Operator: Fickler Oil Co Inc Deer Lodge

- Bonnie Cyr, UST Class A Operator
- Bonnie Cyr, UST Class B Operator
- Deanna Huberg, UST Class A Operator
- Deanna Huberg, UST Class B Operator
- Dolly Brewer, UST Class B Global Operator
- Judy Rasmussen, UST Class A Operator
- Judy Rasmussen, UST Class B Operator
- Todd Flicker, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
10	11	07/01/2010	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve
5264	No		Double-Walled	Double Walled	Yes
Currently in Use		03/31/2010	Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	Continuous Interstitial Monitoring;ELLD 0.2	No
12,000		11/18/2009	Gilbarco-Veeder Root/TLS- 350;Gilbarco-Veeder Root/TLS- 350/Gilbarco EMC		Yes
11	11	07/01/2010	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve
5265	No		Double-Walled	Double Walled	Yes
Currently in Use		03/31/2010	Electronic Line Leak Detector	Pressurized	Non-corrodible

Gasoline			Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	Continuous Interstitial Monitoring;ELLD 0.2	No
5,000		11/18/2009	Gilbarco-Veeder Root/TLS- 350;Gilbarco-Veeder Root/TLS- 350/Gilbarco EMC		Yes
12	11	07/01/2010	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve
5266	No		Double-Walled	Double Walled	Yes
Currently in Use		03/31/2010	Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel			Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	Continuous Interstitial Monitoring;ELLD 0.2	No
10,000		11/18/2009	Gilbarco-Veeder Root/TLS- 350;Gilbarco-Veeder Root/TLS- 350/Gilbarco EMC		Yes
13	11	07/01/2010	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve
5267	No		Double-Walled	Double Walled	Yes
Currently in Use		03/31/2010	Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel			Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	Continuous Interstitial Monitoring;ELLD 0.2	No
5,000		11/18/2009	Gilbarco-Veeder Root/TLS- 350;Gilbarco-Veeder Root/TLS- 350/Gilbarco EMC		Yes

Facility Summary in Granite County in the City of Drummond

Location: MOUNTAIN WEST CO OP
350 E Front St
Drummond, MT 59832 Granite

Legacy ID:20-03611

Facility ID: 22107
Last Inspected On: 06/03/2019
Operating Permit Renewal Date: 01/25/2022

Owner Operator Contact: William Parke;Parkes Stage Station

4062883423

Operator Contact: John Thompson

4066651728

Owner/Operator: CHS Inc Inver Grove Heights

Owner/Operator: Mountain West Coop Drummond

John Thompson, UST Class A Operator
John Thompson, UST Class B Global Operator
John Thompson, UST Class B Operator
Robin Cochrell, UST Class B Operator
Robin McCurdy, UST Class B Operator

Dave Otto, UST Class A Operator
 Dave Otto, UST Class B Global Operator
 John Thompson, UST Class A Operator
 John Thompson, UST Class B Global Operator
 John Thompson, UST Class B Operator
 Will Dukart, UST Class A Operator
 Will Dukart, UST Class B Global Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
06	61	06/15/1960	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve
1458	No		Lined Interior/Impressed Current	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Impressed Current
Gasoline		01/19/2019	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	No
4,000		01/29/2019	Gilbarco/EMC Basic		No
07	50	06/16/1971	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Positive Shutoff
1459	No		Lined Interior/Impressed Current	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Impressed Current
Gasoline		01/29/2019	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	No
8,000		01/29/2019	Gilbarco/EMC Basic		No
08	30	05/13/1991	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve
1460	No			None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Impressed Current
Diesel		01/29/2019	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	No
6,000		01/29/2019	Gilbarco/EMC Basic		No

09	30	05/13/1991	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve
1461	No			None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Impressed Current
Diesel		01/29/2019	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	No
6,000		01/29/2019	Gilbarco/EMC Basic		No
05	61	06/15/1960	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve
4461	No		Lined Interior/Impressed Current	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Impressed Current
Diesel		01/29/2019	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	No
2,000		01/29/2019	Gilbarco/EMC Basic		No

Facility Summary in Granite County in the City of Philipsburg

Location: PINTLER PETROLEUM INC
906 W Broadway Rd
Philipsburg, MT 59858 Granite

Legacy ID:56-13983

Facility ID: 30645
Last Inspected On: 09/30/2020
Operating Permit Renewal Date: 10/07/2023

Owner Operator Contact: William Antonioli

4068593164

Operator Contact: William Antonioli

4068593164

Owner/Operator: Bill Antonioli

Owner/Operator: William Antonioli

William Antonioli, UST Class A Operator

William Antonioli, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
S1	21	09/01/2000	Unknown	Flexible Plastic	
4215	Yes	09/17/2014		Double Walled	Yes

Currently in Use			Continuous Interstitial Monitoring;Mechanical Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Deferred	Continuous Interstitial Monitoring	No
12,000					No
S2	21	09/01/2000	Unknown	Flexible Plastic	
4216	Yes	09/17/2014		Double Walled	Yes
Currently in Use			Continuous Interstitial Monitoring;Mechanical Line Leak Detector	Pressurized	Non-corrodible
Diesel			Deferred	Continuous Interstitial Monitoring	No
12,000					No
S3	21	09/01/2000	Unknown	Flexible Plastic	
4217	Yes	09/17/2014		Double Walled	Yes
Currently in Use			Continuous Interstitial Monitoring;Mechanical Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Deferred	Continuous Interstitial Monitoring	No
20,000					No
S4	21	09/01/2000	Unknown	Flexible Plastic	
4218	Yes	09/17/2014		Double Walled	Yes
Currently in Use			Continuous Interstitial Monitoring;Mechanical Line Leak Detector	Pressurized	Non-corrodible
Diesel			Deferred	Continuous Interstitial Monitoring	No
24,000					No

Facility Summary in Granite County in the City of Philipsburg

Location: SUNSHINE STATION 417
3830 MT Hwy 1
Philipsburg, MT 59858-9748 Granite

Legacy ID:20-05771

Facility ID: 22120
Last Inspected On: 12/03/2020
Operating Permit Renewal Date: 02/11/2024

Owner Operator Contact: Hi Noon Petroleum Missoula

4065420384

Owner/Operator: Hi Noon Petroleum Missoula

Aaron Bay, UST Class A Operator
 Aaron Bay, UST Class B Global Operator
 Aaron Bay, UST Class B Operator
 Bill Dirkes, UST Class B Global Operator
 John Monahan, UST Class A Operator
 John Monahan, UST Class B Global Operator
 Randy Livingston, UST Class A Operator
 Randy Livingston, UST Class B Global Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
01	38	04/27/1983	Bare Steel	Flexible Plastic	High Level Alarm
1313	No			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		12/04/2017	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring;ELLD 0.2	No
10,000			Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
02	38	04/27/1983	Bare Steel	Flexible Plastic	High Level Alarm
4516	No			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		12/04/2017	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring;ELLD 0.2	No
10,000			Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
03	22	09/20/1999	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
4517	No			Double Walled	Yes

Currently in Use	Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring; ELLD 0.2	No
12,000	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No