

Facility Summary in Hill County in the City of Havre

Location: BN HAVRE RAIL YARD
235 Main St
Havre, MT 59501-3523 Hill

Legacy ID:21-09548

Facility ID: 22426
Last Inspected On: 07/06/2020
Operating Permit Renewal Date: 08/26/2023

Owner Operator Contact: BNSF Railway Company Fort Worth

8173332000

Operator Contact: Tavita Masau;Tim Christianson

4069394254;7736002860

Owner/Operator: BNSF Railway Company Fort Worth

Doran Loftus, UST Class B Global Operator
Dwayne Whitaker, UST Class B Operator
Ed Hill, UST Class B Operator
Tavita Masau, UST Class A Operator
Tavita Masau, UST Class B Global Operator
Tim Christianson, UST Class A Operator
Tom Swinney, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
S23	17	01/22/2004	Concrete	Steel - Terminal Piping	
4877	Yes			None	Yes
Currently in Use			Not Required	Pressurized	
Diesel		04/19/2017	Deferred	Continuous Interstitial Monitoring;Terminal Piping Annual Line Test	No
640,000		10/31/2016			No
S24	17	01/22/2004	Concrete	Steel - Terminal Piping	
4878	Yes			None	Yes
Currently in Use			Not Required	Pressurized	
Diesel		04/19/2017	Deferred	Continuous Interstitial Monitoring;Terminal Piping Annual Line Test	No

640,000		10/31/2016			No
22	28	06/21/1993	Cathodically Protected Steel	No Piping	High Level Alarm
506	No		Double-Walled	None	Yes
Currently in Use			Not Required	Not Listed	Impressed Current
Oil, Waste		04/19/2017	Manual Interstitial Monitoring	Not Listed	No
20,000					No

Facility Summary in Hill County in the City of Havre

Location: EMPORIUM FOOD and FUEL
1415 1st St
Havre, MT 59501 Hill

Legacy ID:21-12763

Facility ID: 22461
Last Inspected On: 01/29/2019
Operating Permit Renewal Date: 06/30/2022

Owner Operator Contact: Duck Inn Inc

4062654200

Operator Contact: Jonathan Wells;Tami Carlson

2178718699;4062658861

Owner/Operator: Duck Inn Inc

Cindy Lee, UST Class B Operator
Jonathan Wells, UST Class A Operator
Tami Carlson, UST Class A Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
01	29	08/01/1992	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
2971	No			None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	
Diesel			Automatic Tank Gauging 0.2	ELLD 0.1;ELLD 0.2	No
12,000		03/22/2016	Gilbarco/EMC Basic		No
02	29	08/01/1992	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm

2972	No			None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	
Gasoline			Automatic Tank Gauging 0.2	ELLD 0.1;ELLD 0.2	No
12,000		03/22/2016	Gilbarco/EMC Basic		No
03	29	08/01/1992	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
2973	No			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	
Diesel			Automatic Tank Gauging 0.2	ELLD 0.1;ELLD 0.2	No
6,000		03/22/2016	Gilbarco/EMC Basic		No
04	29	08/01/1992	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
2974	No			None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	
Diesel			Automatic Tank Gauging 0.2	ELLD 0.1;ELLD 0.2	No
6,000		03/22/2016	Gilbarco/EMC Basic		No

Facility Summary in Hill County in the City of Havre

Location: EZZIES CENEX CARDTROL
33 1st St
Havre, MT 59501 Hill

Legacy ID:21-07467

Facility ID: 22339
Last Inspected On: 09/10/2020
Operating Permit Renewal Date: 01/07/2024

Owner Operator Contact: Ezzies Wholesale Inc;Ryan Lammers;CHS - Milk River **4062652275**

Operator Contact: David Skiff **4066542331**

Owner/Operator: Ezzies Wholesale Inc

- David Skiff, UST Class A Operator
- David Skiff, UST Class B Global Operator
- David Skiff, UST Class B Operator
- Harold Anderson, UST Class B Global Operator
- Harold Anderson, UST Class B Operator
- Jimmy Kimberling, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
-----------	-----	-----------	----------------------------	-----------------	----------------

Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
08	24	06/01/1997	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
538	No			Double Walled	Yes
Currently in Use		08/27/2008	Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel			Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring; ELLD 0.1; ELLD 0.2	No
4,000			Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
09	24	06/01/1997	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
539	No			Double Walled	Yes
Currently in Use		08/27/2008	Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel			Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring; ELLD 0.1; ELLD 0.2	No
4,000			Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
10	24	06/01/1997	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
540	No			Double Walled	Yes
Currently in Use		08/27/2008	Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring; ELLD 0.1; ELLD 0.2	No
4,000			Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
11	24	06/28/1997	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
541	No			Double Walled	Yes
Currently in Use		08/27/2008	Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel			Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring; ELLD 0.1; ELLD 0.2	No
6,000			Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No

12	24	06/28/1997	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
542	No			Double Walled	Yes
Currently in Use		08/27/2008	Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring; ELLD 0.1; ELLD 0.2	No
6,000			Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
13	24	06/01/1997	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
543	No			Double Walled	Yes
Currently in Use		08/27/2008	Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel			Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring; ELLD 0.1; ELLD 0.2	No
8,000			Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No

Facility Summary in Hill County in the City of Havre

Location: EZZIES WHOLESALE HAVRE
726 1st St W
Havre, MT 59501-3418 Hill

Legacy ID:21-12751

Facility ID: 22460
Last Inspected On: 01/29/2019
Operating Permit Renewal Date: 07/09/2022

Owner Operator Contact: Ezzies Wholesale Inc

Operator Contact: David Skiff

4066542331

Owner/Operator: Ezzies Wholesale Inc

- David Skiff, UST Class A Operator
- David Skiff, UST Class B Global Operator
- David Skiff, UST Class B Operator
- Harold Anderson, UST Class B Global Operator
- Harold Anderson, UST Class B Operator
- Jimmy Kimberling, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act

01	29	07/01/1992	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
----	----	------------	------------------------------	-------------------------------	------------------

878	No			None	Yes
Temporarily Out of Use			Electronic Line Leak Detector	Pressurized	Galvanic
Solvent, Stoddard		03/22/2016	Automatic Tank Gauging 0.2	ELLD 0.2	No
4,000		03/21/2013	Gilbarco/EMC Basic		No
02	29	07/01/1992	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
879	No			None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		03/22/2016	Automatic Tank Gauging 0.2	ELLD 0.2	No
12,000		08/29/2007	Gilbarco/EMC Basic		No
03	29	07/01/1992	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
880	No			None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		03/22/2016	Automatic Tank Gauging 0.2	ELLD 0.2	No
12,000		08/29/2007	Gilbarco/EMC Basic		No
04	29	07/01/1992	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
881	No			None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		03/22/2016	Automatic Tank Gauging 0.2	ELLD 0.2	No
12,000		08/29/2007	Gilbarco/EMC Basic		No
05	29	07/01/1992	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
882	No			None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		03/22/2016	Automatic Tank Gauging 0.2	ELLD 0.2	No

12,000		08/29/2007	Gilbarco/EMC Basic		No
06	29	07/01/1992	Bare Steel	Fiberglass Reinforced Plastic	High Level Alarm
883	No			None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	
Diesel		03/22/2016	Automatic Tank Gauging 0.2	ELLD 0.2	No
12,000		08/29/2007	Gilbarco/EMC Basic		No
07	29	07/01/1992	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
884	No			None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		03/22/2016	Automatic Tank Gauging 0.2	ELLD 0.2	No
12,000		08/29/2007	Gilbarco/EMC Basic		No
08	29	07/01/1992	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
885	No			None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		03/22/2016	Automatic Tank Gauging 0.2	ELLD 0.2	No
12,000		08/29/2007	Gilbarco/EMC Basic		No

Facility Summary in Hill County in the City of Havre

Location: HAVRE 1 TOWN PUMP
136 1st St W
Havre, MT 59501 Hill

Legacy ID:21-08705

Facility ID: 22359
Last Inspected On: 07/13/2021
Operating Permit Renewal Date: 09/09/2024

Owner Operator Contact: Don Edmisten;Town Pump Inc Havre

4064976948;4064976700

Operator Contact: Daniel Sampson

Owner/Operator: Havre 1 Town Pump LLC

Daniel Sampson, UST Class A Operator
Daniel Sampson, UST Class B Global Operator
Don Edmisten, UST Class B Global Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
03	32	11/15/1989	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve
2472	No	02/04/2015		Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Approved Remote Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
12,000		01/29/2015	Gilbarco-Veeder Root/TLS-350		No
04	32	11/15/1989	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve
2473	No	02/04/2015		Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Approved Remote Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
12,000		01/29/2015	Gilbarco-Veeder Root/TLS-350		No
05	32	11/15/1989	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve
2474	No	02/04/2015		Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Approved Remote Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
12,000		01/29/2015	Gilbarco-Veeder Root/TLS-350		No
06	32	11/15/1989	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve

2475	No			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel			Approved Remote Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
12,000		01/29/2015	Gilbarco-Veeder Root/TLS-350		No
07	7	08/01/2014	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve
5510	No	02/04/2015	Double-Walled	Double Walled	Yes
Currently in Use		07/25/2014	Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel			Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
6,000		01/29/2015	Gilbarco-Veeder Root/TLS-350		Yes
08	7	08/01/2014	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve
5514	No	02/04/2015	Double-Walled	Double Walled	Yes
Currently in Use		07/25/2014	Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel			Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
15,000		01/29/2015	Gilbarco-Veeder Root/TLS-350		No

Facility Summary in Hill County in the City of Havre

Location: HILL COUNTY JUSTICE CENTER
1450 2nd St W
Havre, MT 59501-3497 Hill

Legacy ID:56-13886

Facility ID: 30561
Last Inspected On: 09/03/2021
Operating Permit Renewal Date: 11/05/2021

Owner Operator Contact: Hill County Commissioners

4062655481

Operator Contact: Daryl Anez;Joseph Smith;Richard Ricci

4062623467;4069451497

Owner/Operator: Hill County Commissioners

Daryl Anez, UST Class A Operator
Daryl Anez, UST Class B Global Operator
Daryl Anez, UST Class B Operator

Joseph Smith, UST Class A Operator
 Joseph Smith, UST Class B Operator
 Mike Winchell, UST Class B Global Operator
 Richard Ricci, UST Class A Operator
 Richard Ricci, UST Class B Global Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
S1	23	07/20/1998	Concrete	Steel	
1377	Yes			Secondary Containment Chase	Yes
Currently in Use			Continuous Interstitial Monitoring	U.S. Suction	
Diesel			Deferred	Continuous Interstitial Monitoring	No
2,000					No

Facility Summary in Hill County in the City of Havre

Location: HOLIDAY STATIONSTORE 272
 200 1st St W
 Havre, MT 59501 Hill

Legacy ID:21-08068

Facility ID: 22350
Last Inspected On: 09/09/2020
Operating Permit Renewal Date: 12/04/2023

Owner Operator Contact: Camie Pederson;Rocky Mountain Oil LLC - Env Director

9528308899

Operator Contact: Brent Johnson;Chuck Nyberg;Dean Townsend;Veronica Rivera

9528308722

Owner/Operator: Rocky Mountain Oil Co Inc

Brad Lee, UST Class B Global Operator
 Brent Johnson, UST Class A Operator
 Brent Johnson, UST Class B Global Operator
 Chuck Nyberg, UST Class A Operator
 Daniel Rayl, UST Class B Operator
 Dean Townsend, UST Class A Operator
 Greg Brewer, UST Class B Global Operator
 Todd Boucher, UST Class B Operator
 Travis Struckman, UST Class B Global Operator
 Veronica Rivera, UST Class A Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
01	36	10/01/1985	Cathodically Protected Steel	Flexible Plastic	Ball Float Valve
3013	No			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		09/07/2017	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring; ELLD 0.2	Yes
12,000		08/09/2017	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		Yes
02	36	10/01/1985	Cathodically Protected Steel	Flexible Plastic	Ball Float Valve
3014	No			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		09/07/2017	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring; ELLD 0.2	Yes
12,000		08/09/2017	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		Yes
03	36	10/01/1985	Cathodically Protected Steel	Flexible Plastic	Ball Float Valve
3015	No			None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		09/07/2017	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring; ELLD 0.2	Yes
10,000		08/07/2017	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		Yes
04	36	10/01/1985	Cathodically Protected Steel	Flexible Plastic	Ball Float Valve
3016	No			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current

Diesel	09/07/2017	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring;ELLD 0.2	No
10,000	08/09/2017	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		Yes

Facility Summary in Hill County in the City of Havre

Location: STROMBERGS SINCLAIR
1200 1st St
Havre, MT 59501-3802 Hill

Legacy ID:21-02166

Facility ID: 22209
Last Inspected On: 10/08/2019
Operating Permit Renewal Date: 12/12/2022

Owner Operator Contact: Stromberg Sinclair;Todd O'Leary;Stromberg Sinclair **4062623441;4062653441;4062653441**

Operator Contact: Todd O'Leary **4062623441**

Owner/Operator: Stromberg Sinclair

Todd O'Leary, UST Class A Operator
Todd O'Leary, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
08	22	03/01/1999	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
3965	No			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring;ELLD 0.2	No
12,000			Gilbarco/EMC Basic		No
09	22	03/01/1999	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
3966	No			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring;ELLD 0.2	No
8,000			Gilbarco/EMC Basic		No
10	22	03/01/1999	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve

3967	No		Double Walled	Yes
Currently in Use		Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel		Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring; ELLD 0.2	No
4,000		Gilbarco/EMC Basic		No

Facility Summary in Hill County in the City of Havre

Location: ZIP TRIP 48
911 11th St W
Havre, MT 59501 Hill

Legacy ID:21-00089

Facility ID: 22169
Last Inspected On: 05/17/2021
Operating Permit Renewal Date: 06/27/2024

Owner Operator Contact: Robert Moss; Thriftway Marketing Corp - Former Gasamat of MT

5053265571

Operator Contact: Jim Alford; Sean Hurley; Tom Savas

5095357701; 5095367418

Owner/Operator: CHS Inc Spokane Valley

Jim Alford, UST Class A Operator
Jim Alford, UST Class B Global Operator
Luci Tuttle, UST Class B Operator
Sean Hurley, UST Class A Operator
Tom Savas, UST Class A Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
03	10	10/01/2011	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
5341	No		Double-Walled	Double Walled	Yes
Currently in Use		10/11/2011	Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Automatic Tank Gauging 0.2; Continuous Interstitial Monitoring	Continuous Interstitial Monitoring; ELLD 0.2	No
15,000			Gilbarco/EMC Basic; Gilbarco- Veeder Root/EMC Basic		Yes
04	10	10/01/2011	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve

5342	No		Double-Walled	Double Walled	Yes
Currently in Use		10/11/2011	Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	Continuous Interstitial Monitoring;ELLD 0.2	No
10,000			Gilbarco/EMC Basic;Gilbarco- Veeder Root/EMC Basic		Yes
05	10	10/01/2011	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
5343	No		Double-Walled	Double Walled	Yes
Currently in Use		10/11/2011	Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel			Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	Continuous Interstitial Monitoring;ELLD 0.2	No
6,000			Gilbarco/EMC Basic;Gilbarco- Veeder Root/EMC Basic		Yes

Facility Summary in Hill County in the City of Havre

Location: ZIP TRIP 49
1004 1st St
Havre, MT 59501 Hill

Legacy ID:21-00103

Facility ID: 22170
Last Inspected On: 06/12/2019
Operating Permit Renewal Date: 12/04/2022

Owner Operator Contact: Jim Alford;CHS Inc - Spokane

5095367418

Operator Contact: Jim Alford;Sean Hurley;Tom Savas

5095357701;5095367418

Owner/Operator: CHS Inc Spokane Valley

Alex Henson, UST Class B Global Operator
Jim Alford, UST Class A Operator
Jim Alford, UST Class B Global Operator
Luci Tuttle, UST Class B Operator
Sean Hurley, UST Class A Operator
Tom Savas, UST Class A Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act

04	8	05/01/2013	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve
----	---	------------	-------------------------------	------------------	---------------

5405	No	05/01/2013	Double-Walled	Double Walled	Yes
Currently in Use		11/27/2012	Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	Continuous Interstitial Monitoring;ELLD 0.2	No
12,000			Gilbarco-Veeder Root/TLS- 350;Gilbarco-Veeder Root/TLS- 350/Gilbarco EMC		Yes
05	8	05/01/2013	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve
5406	No	05/01/2013	Double-Walled	Double Walled	Yes
Currently in Use		11/27/2012	Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	Continuous Interstitial Monitoring;ELLD 0.2	No
6,000			Gilbarco-Veeder Root/TLS- 350;Gilbarco-Veeder Root/TLS- 350/Gilbarco EMC		Yes
06	8	05/01/2013	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve
5407	No	05/01/2013	Double-Walled	Double Walled	Yes
Currently in Use		11/27/2012	Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel			Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	Continuous Interstitial Monitoring;ELLD 0.2	No
4,000			Gilbarco-Veeder Root/TLS- 350;Gilbarco-Veeder Root/TLS- 350/Gilbarco EMC		Yes

Facility Summary in Hill County in the City of Hingham

Location: HINGHAM MOTORS LLC
Central Ave & 1st St N
Hingham, MT 59528 Hill

Legacy ID:21-00783

Facility ID: 22185
Last Inspected On: 04/16/2020
Operating Permit Renewal Date: 05/14/2020

Owner Operator Contact:

Operator Contact: Robert Spicher

4063903171

Owner/Operator: D's Automotive & Company

Robert Spicher, UST Class A Operator

Robert Spicher, UST Class B Global Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
-----------	-----	-----------	----------------------------	-----------------	----------------

Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
S06	26	07/25/1995	Unknown	Flexible Plastic	
1383	Yes	05/13/2014		Double Walled	Yes
Temporarily Out of Use			Continuous Interstitial Monitoring	Pressurized	
Diesel			Deferred	Continuous Interstitial Monitoring	No
12,000					No
S07	23	10/01/1998	Unknown	Flexible Plastic	
1384	Yes	05/13/2014		Double Walled	Yes
Temporarily Out of Use			Continuous Interstitial Monitoring	Pressurized	
Gasoline			Deferred	Continuous Interstitial Monitoring	No
12,000					No
S08	23	10/01/1998	Unknown	Flexible Plastic	
1385	Yes	05/13/2014		Double Walled	Yes
Temporarily Out of Use			Continuous Interstitial Monitoring	Pressurized	
Gasoline			Deferred	Continuous Interstitial Monitoring	No
12,000					No
S09	23	10/01/1998	Unknown	Flexible Plastic	
1386	Yes	05/13/2014		Double Walled	Yes
Temporarily Out of Use			Continuous Interstitial Monitoring	Pressurized	
Diesel			Deferred	Continuous Interstitial Monitoring	No
12,000					No

Facility Summary in Hill County in the City of Inverness

Location: FRASER OIL INC INVERNESS
125 Main St
Inverness, MT 59530 Hill

Legacy ID:21-07327

Facility ID: 22337
Last Inspected On: 11/03/2020
Operating Permit Renewal Date: 03/27/2024

Owner Operator Contact: Fraser Oil Inc

Operator Contact: Cory Fraser

Owner/Operator: Fraser Oil Inc

Cory Fraser, UST Class A Operator

Cory Fraser, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
04	29	10/15/1992	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
1120	No			None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Gasoline		10/24/2017	Automatic Tank Gauging 0.2	Deferred	No
1,000		12/11/2008	Gilbarco/EMC Basic		No
05	29	10/15/1992	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
1121	No			None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Diesel		10/24/2017	Automatic Tank Gauging 0.2	Deferred	No
1,000		12/11/2008	Gilbarco/EMC Basic		No
06	29	10/15/1992	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
1122	No			None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic

Gasoline	10/24/2017	Automatic Tank Gauging 0.2	Deferred	No
1,000	12/11/2008	Gilbarco/EMC Basic		No

Facility Summary in Hill County in the City of Rudyard

Location: FARMERS UNION OIL CO RUDYARD
1 Main St
Rudyard, MT 59540 Hill

Legacy ID:21-03509

Facility ID: 22239
Last Inspected On: 08/01/2019
Operating Permit Renewal Date: 09/28/2022

Owner Operator Contact: Farmers Union Oil Co Rudyard;William Gorder;Farmers Union Oil Co Rudyard

4063554543

Operator Contact: Matthew Meyers

4063554543

Owner/Operator: Farmers Union Oil Co Rudyard

Matthew Meyers, UST Class A Operator
Matthew Meyers, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
S4	55	04/23/1966	Bare Steel	Fiberglass Reinforced Plastic	
947	Yes	03/21/2016		Double Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	
Diesel			Deferred	Continuous Interstitial Monitoring	No
2,000					No
S5	55	04/23/1966	Bare Steel	Fiberglass Reinforced Plastic	
948	Yes	03/21/2016		Double Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	
Gasoline			Deferred	Continuous Interstitial Monitoring	No
10,000					No

S6	55	04/23/1966	Bare Steel	Fiberglass Reinforced Plastic	
949	Yes	03/21/2016		Double Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	
Gasoline			Deferred	Continuous Interstitial Monitoring	No
5,000					No

Facility Summary in Hill County in the City of Rudyard

Location: TONERS TIRE RAMA
103 Main St
Rudyard, MT 59540 Hill

Legacy ID:21-02475

Facility ID: 22212
Last Inspected On: 04/25/2019
Operating Permit Renewal Date: 09/24/2022

Owner Operator Contact: Bob Toner;Toner's Tire Rama;Toner's Tire Rama **4063554131**

Operator Contact: David Toner;Rick Pester;Robert Toner **4063554131;4063763248**

Owner/Operator: Toner's Tire Rama

David Toner, UST Class A Operator
David Toner, UST Class B Operator
Rick Pester, UST Class A Operator
Rick Pester, UST Class B Operator
Robert Toner, UST Class A Operator
Robert Toner, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
05	24	11/01/1997	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
2108	No			None	Yes
Currently in Use			Not Required	Safe Suction	Non-corrodible
Diesel		04/14/2016	Automatic Tank Gauging 0.1	Deferred	No
2,000			Other/		No
06	24	11/01/1997	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
2109	No			None	Yes
Currently in Use			Not Required	Safe Suction	Non-corrodible
Gasoline		04/14/2016	Automatic Tank Gauging 0.1	Deferred	No
2,000			Other/		No