

Facility Summary in Hill County in the City of Havre

Location: BN HAVRE RAIL YARD
235 Main St
Havre, MT 59501-3523 Hill

System Facility ID:21-09548

Facility Code: 22426
Last Inspected On: 05/26/2023
Operating Permit Renewal Date: 08/26/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: BNSF Railway Company Fort Worth 8173332000

Operator Contact: Robert Mantle;BNSF Railway Havre;Tavita Masau;Tim Christianson 4062650483;4069394254;7736002860

Owner/Operator: BNSF Railway Company Fort Worth

- Doran Loftus, UST Class B Global Operator
- Dwayne Whitaker, UST Class B Operator
- Ed Hill, UST Class B Operator
- Robert Mantle, UST Class A Operator
- Tavita Masau, UST Class A Operator
- Tavita Masau, UST Class B Global Operator
- Tim Christianson, UST Class A Operator
- Tom Swinney, UST Class B Operator

Tank Code	S23	Tank Age	20	Tank Installed Date	01/22/2004	Tank Material	Concrete	Piping Material	Steel - Terminal Piping	Overfill Types	
Tag Number	4877	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	Yes
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Pressurized	CP Met Types	
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	11/02/2023	Primary Tank Leak Detection		Primary Pipe Detection	Terminal Piping Annual Line Test	Vapor Recovery	No
Capacity	640000	ATG Test Date	05/23/2023	Line Tightness Test Date	08/02/2019	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date				ATG Type					
Tank Code	S24	Tank Age	20	Tank Installed Date	01/22/2004	Tank Material	Concrete	Piping Material	Steel - Terminal Piping	Overfill Types	
Tag Number	4878	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	Yes
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Pressurized	CP Met Types	
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	11/02/2023	Primary Tank Leak Detection		Primary Pipe Detection	Terminal Piping Annual Line Test	Vapor Recovery	No

Capacity	640000	ATG Test Date	05/23/2023	Line Tightness Test Date	08/02/2019	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date				ATG Type					
Tank Code	22	Tank Age	31	Tank Installed Date	06/21/1993	Tank Material	Cathodically Protected Steel	Piping Material	No Piping	Overfill Types	High Level Alarm
Tag Number	506	Spill Test Date		Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Not Listed	CP Met Types	Impressed Current
Product	Oil, Waste	PLLD Test Date		Tank/Piping CP Test Date	11/02/2023	Primary Tank Leak Detection	Manual Interstitial Monitoring	Primary Pipe Detection		Vapor Recovery	No
Capacity	20000	ATG Test Date	05/05/2023	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					

Facility Summary in Hill County in the City of Havre

Location: CIRCLE K STORE 2746272
200 1st St W
Havre, MT 59501 Hill

System Facility ID:21-08068

Facility Code: 22350
Last Inspected On: 05/23/2023
Operating Permit Renewal Date: 12/04/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Rocky Mountain Oil LLC	6027288000
Operator Contact: Veronica Rivera	

Owner/Operator: Rocky Mountain Oil LLC

Brad Lee, UST Class B Global Operator
Jeff Reed, UST Class B Global Operator
Veronica Rivera, UST Class A Operator

Tank Code	01	Tank Age	0	Tank Installed Date		Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	3013	Spill Test Date		Piping Installed Date	11/24/2020	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	11/11/2020	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date	09/09/2020	Tank/Piping CP Test Date	09/06/2022	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	Yes
Capacity	12000	ATG Test Date	05/23/2023	Line Tightness Test Date	11/12/2020	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	09/07/2022			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	02	Tank Age	39	Tank Installed Date	10/01/1985	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	3014	Spill Test Date		Piping Installed Date	11/24/2020	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	11/11/2020	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date	09/09/2020	Tank/Piping CP Test Date	09/06/2022	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	Yes
Capacity	12000	ATG Test Date	05/23/2023	Line Tightness Test Date	11/17/2020	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No

		Overfill Test Date	09/08/2022			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	03	Tank Age	39	Tank Installed Date	10/01/1985	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	3015	Spill Test Date		Piping Installed Date	11/24/2020	Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	11/11/2020	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date	09/09/2020	Tank/Piping CP Test Date	09/06/2022	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	Yes
Capacity	10000	ATG Test Date	05/23/2023	Line Tightness Test Date	11/10/2020	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	09/07/2022			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	04	Tank Age	39	Tank Installed Date	10/01/1985	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	3016	Spill Test Date		Piping Installed Date	11/24/2020	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	11/11/2020	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Diesel	PLLD Test Date	09/09/2020	Tank/Piping CP Test Date	09/06/2022	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	10000	ATG Test Date	05/23/2023	Line Tightness Test Date	11/11/2020	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	09/07/2022			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Hill County in the City of Havre

Location: EMPORIUM FOOD AND FUEL
1415 1st St
Havre, MT 59501 Hill

System Facility ID:21-12763

Facility Code: 22461
Last Inspected On: 03/29/2022
Operating Permit Renewal Date: 06/30/2025

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Duck Inn Inc

Operator Contact: Joseph Hopf;Marie Hawkins;Duck Inn Inc 4063442966

Owner/Operator: Duck Inn Inc

Cindy Lee, UST Class B Operator
Dustin Rolfe, UST Class B Operator
Joseph Hopf, UST Class A Operator
Joseph Hopf, UST Class B Operator
Marie Hawkins, UST Class A Operator
Marie Hawkins, UST Class B Operator

Tank Code	01	Tank Age	32	Tank Installed Date	08/01/1992	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	2971	Spill Test Date	05/12/2020	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	05/12/2021	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	12000	ATG Test Date	09/06/2022	Line Tightness Test Date	03/21/2022	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	09/06/2022			ATG Type	Other/Other				
Tank Code	02	Tank Age	32	Tank Installed Date	08/01/1992	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	2972	Spill Test Date	10/22/2021	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	05/12/2021	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	12000	ATG Test Date	09/06/2022	Line Tightness Test Date	03/21/2022	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	09/06/2022			ATG Type	Other/Other				

Tank Code	03	Tank Age	32	Tank Installed Date	08/01/1992	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	2973	Spill Test Date	05/12/2020	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	05/12/2021	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	6000	ATG Test Date	09/06/2022	Line Tightness Test Date	03/01/2022	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	09/06/2022			ATG Type	Other/Other				
Tank Code	04	Tank Age	32	Tank Installed Date	08/01/1992	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	2974	Spill Test Date	05/12/2020	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	05/12/2021	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	6000	ATG Test Date	09/06/2022	Line Tightness Test Date	04/15/2021	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	09/06/2022			ATG Type	Other/Other				

Facility Summary in Hill County in the City of Havre

Location: EZZIES CENEX CARDTROL
33 1st St
Havre, MT 59501 Hill

System Facility ID:21-07467

Facility Code: 22339
Last Inspected On: 09/05/2023
Operating Permit Renewal Date: 09/05/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Ezzies Wholesale Inc4066542331

Operator Contact: Joe Brookie;Ezzies Wholesale Inc4066542331;4066542331

Owner/Operator: Ezzies Wholesale Inc

Jimmy Kimberling, UST Class B Operator
Joe Brookie, UST Class A Operator

Tank Code	08	Tank Age	27	Tank Installed Date	06/01/1997	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	538	Spill Test Date	05/23/2023	Piping Installed Date	08/27/2008	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	05/12/2020	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	4000	ATG Test Date	05/23/2023	Line Tightness Test Date	05/23/2023	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	05/23/2023			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	09	Tank Age	27	Tank Installed Date	06/01/1997	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	539	Spill Test Date	05/23/2023	Piping Installed Date	08/27/2008	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	05/12/2020	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	4000	ATG Test Date	05/23/2023	Line Tightness Test Date	05/23/2023	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	05/23/2023			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Tank Code	10	Tank Age	27	Tank Installed Date	06/01/1997	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	540	Spill Test Date	05/23/2023	Piping Installed Date	08/27/2008	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	05/12/2020	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	4000	ATG Test Date	05/23/2023	Line Tightness Test Date	05/23/2023	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	05/23/2023			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	11	Tank Age	27	Tank Installed Date	06/28/1997	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	541	Spill Test Date	05/23/2023	Piping Installed Date	08/27/2008	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	05/12/2020	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	6000	ATG Test Date	05/23/2023	Line Tightness Test Date	05/23/2023	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	05/23/2023			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	12	Tank Age	27	Tank Installed Date	06/28/1997	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	542	Spill Test Date	05/23/2023	Piping Installed Date	08/27/2008	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	05/12/2020	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	6000	ATG Test Date	05/23/2023	Line Tightness Test Date	05/23/2023	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	05/23/2023			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	13	Tank Age	27	Tank Installed Date	06/01/1997	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	543	Spill Test Date	05/23/2023	Piping Installed Date	08/27/2008	Tank Construction		Piping Construction	Double Walled	AST	No

Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	05/12/2020	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	8000	ATG Test Date	05/23/2023	Line Tightness Test Date	05/23/2023	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	05/23/2023			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Hill County in the City of Havre

Location: EZZIES WHOLESALE HAVRE
726 1st St W
Havre, MT 59501-3418 Hill

System Facility ID:21-12751

Facility Code: 22460
Last Inspected On: 03/29/2022
Operating Permit Renewal Date: 07/09/2025

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Ezzies Wholesale Inc	4066542331
Operator Contact: Joe Brookie;Ezzies Wholesale Inc	4066542331;4066542331

Owner/Operator: Ezzies Wholesale Inc

Jimmy Kimberling, UST Class B Operator
Joe Brookie, UST Class A Operator

Tank Code	01	Tank Age	32	Tank Installed Date	07/01/1992	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	878	Spill Test Date	05/12/2021	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Temporarily Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Solvents	PLLD Test Date		Tank/Piping CP Test Date	03/29/2022	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	4000	ATG Test Date	05/12/2021	Line Tightness Test Date	03/21/2013	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	05/12/2021			ATG Type	Gilbarco/EMC Basic				
Tank Code	02	Tank Age	32	Tank Installed Date	07/01/1992	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	879	Spill Test Date	05/12/2021	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date	05/12/2021	Tank/Piping CP Test Date	05/11/2022	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	12000	ATG Test Date	05/12/2021	Line Tightness Test Date	08/29/2007	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	05/12/2021			ATG Type	Gilbarco/EMC Basic				
Tank Code	03	Tank Age	32	Tank Installed Date	07/01/1992	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	880	Spill Test Date	05/12/2021	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No

Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date	05/12/2021	Tank/Piping CP Test Date	03/29/2022	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	12000	ATG Test Date	05/12/2021	Line Tightness Test Date	08/29/2007	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	05/12/2021			ATG Type	Gilbarco/EMC Basic				
Tank Code	04	Tank Age	32	Tank Installed Date	07/01/1992	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	881	Spill Test Date	05/12/2021	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date	05/12/2021	Tank/Piping CP Test Date	03/29/2022	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	12000	ATG Test Date	05/12/2021	Line Tightness Test Date	08/29/2007	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	05/12/2021			ATG Type	Gilbarco/EMC Basic				
Tank Code	05	Tank Age	32	Tank Installed Date	07/01/1992	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	882	Spill Test Date	05/12/2021	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date	05/12/2021	Tank/Piping CP Test Date	03/29/2022	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	12000	ATG Test Date	05/12/2021	Line Tightness Test Date	08/29/2007	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	05/12/2021			ATG Type	Gilbarco/EMC Basic				
Tank Code	06	Tank Age	32	Tank Installed Date	07/01/1992	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	883	Spill Test Date	05/12/2021	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date	05/12/2021	Tank/Piping CP Test Date	03/29/2022	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	12000	ATG Test Date	05/12/2021	Line Tightness Test Date	08/29/2007	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	05/12/2021			ATG Type	Gilbarco/EMC Basic				
Tank Code	07	Tank Age	32	Tank Installed Date	07/01/1992	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm

Tag Number	884	Spill Test Date	05/12/2021	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date	05/12/2021	Tank/Piping CP Test Date	03/29/2022	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	12000	ATG Test Date	05/12/2021	Line Tightness Test Date	08/29/2007	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	05/12/2021			ATG Type	Gilbarco/EMC Basic				
Tank Code	08	Tank Age	32	Tank Installed Date	07/01/1992	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	885	Spill Test Date	05/12/2021	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date	05/12/2021	Tank/Piping CP Test Date	05/11/2022	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	12000	ATG Test Date	05/12/2021	Line Tightness Test Date	08/29/2007	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	05/12/2021			ATG Type	Gilbarco/EMC Basic				

Facility Summary in Hill County in the City of Havre

Location: HAVRE 1 TOWN PUMP
136 1st St W
Havre, MT 59501 Hill

System Facility ID:21-08705

Facility Code: 22359
Last Inspected On: 07/13/2021
Operating Permit Renewal Date: 09/09/2024

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Havre 1 Town Pump LLC4064976700

Operator Contact: Daniel Sampson;Trent Biggers4064976700

Owner/Operator: Havre 1 Town Pump LLC

Daniel Sampson, UST Class A Operator
Daniel Sampson, UST Class B Global Operator
Trent Biggers, UST Class A Operator
Trent Biggers, UST Class B Global Operator

Tank Code	03	Tank Age	35	Tank Installed Date	11/15/1989	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	2472	Spill Test Date	07/13/2021	Piping Installed Date	07/25/2014	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	07/13/2021	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	06/20/2022	Tank/Piping CP Test Date		Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	12000	ATG Test Date	06/20/2022	Line Tightness Test Date	01/29/2015	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	07/13/2021			ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	04	Tank Age	35	Tank Installed Date	11/15/1989	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	2473	Spill Test Date	09/01/2021	Piping Installed Date	07/25/2014	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	07/13/2021	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	06/20/2022	Tank/Piping CP Test Date		Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Vapor Recovery	No

Capacity	12000	ATG Test Date	06/20/2022	Line Tightness Test Date	01/29/2015	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	07/13/2021			ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	05	Tank Age	35	Tank Installed Date	11/15/1989	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	2474	Spill Test Date	07/13/2021	Piping Installed Date	07/25/2014	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	07/13/2021	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	06/20/2022	Tank/Piping CP Test Date		Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	12000	ATG Test Date	06/20/2022	Line Tightness Test Date	01/29/2015	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	07/13/2021			ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	06	Tank Age	35	Tank Installed Date	11/15/1989	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	2475	Spill Test Date	09/01/2021	Piping Installed Date	07/25/2014	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	07/13/2021	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	06/20/2022	Tank/Piping CP Test Date		Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	12000	ATG Test Date	06/20/2022	Line Tightness Test Date	01/29/2015	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	07/13/2021			ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	07	Tank Age	10	Tank Installed Date	08/01/2014	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	5510	Spill Test Date	07/13/2021	Piping Installed Date	07/25/2014	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	07/13/2021	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	06/20/2022	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	6000	ATG Test Date	06/20/2022	Line Tightness Test Date	01/29/2015	Secondary Tank Leak Detection	Statistical Inventory Reconciliation	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	Yes
		Overfill Test Date	07/13/2021			ATG Type	Gilbarco-Veeder Root/TLS-350				

Tank Code	08	Tank Age	10	Tank Installed Date	08/01/2014	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	5514	Spill Test Date	07/13/2021	Piping Installed Date	07/25/2014	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	07/13/2021	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel, Dyed	PLLD Test Date	06/20/2022	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	15000	ATG Test Date	06/20/2022	Line Tightness Test Date	01/29/2015	Secondary Tank Leak Detection	Statistical Inventory Reconciliation	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	No
		Overfill Test Date	08/07/2023			ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	09	Tank Age	10	Tank Installed Date	08/01/2014	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	5515	Spill Test Date		Piping Installed Date	07/25/2014	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Other	MLLD Test Date		Sump Tightness Test Date	02/04/2015	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	DEF (Not Regulated)	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	6000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date				ATG Type					

Facility Summary in Hill County in the City of Havre

Location: HILL COUNTY JUSTICE CENTER
1450 2nd St W
Havre, MT 59501-3497 Hill

Facility Code: 30561
Last Inspected On: 10/28/2021
System Facility ID:56-13886
Operating Permit Renewal Date: 11/05/2024

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Hill County Commissioners4062655481

Operator Contact: Daryl Anez;Joseph Smith;Richard Ricci4062623467;4069451497

Owner/Operator: Hill County Commissioners

- Daryl Anez, UST Class A Operator
- Daryl Anez, UST Class B Global Operator
- Daryl Anez, UST Class B Operator
- Joseph Smith, UST Class A Operator
- Joseph Smith, UST Class B Operator
- Mike Winchell, UST Class B Global Operator
- Richard Ricci, UST Class A Operator
- Richard Ricci, UST Class B Global Operator

Tank Code	S1	Tank Age	26	Tank Installed Date	07/20/1998	Tank Material	Concrete	Piping Material	Steel	Overfill Types	
Tag Number	1377	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	Secondary Containment Chase	AST	Yes
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Auto Dialer	Piping Type	U.S. Suction	CP Met Types	
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection		Primary Pipe Detection	3-Year Line Tightness Test	Vapor Recovery	No
Capacity	2000	ATG Test Date		Line Tightness Test Date	10/28/2021	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date				ATG Type					

Facility Summary in Hill County in the City of Havre

Location: STROMBERGS SINCLAIR
1200 1st St
Havre, MT 59501-3802 Hill

System Facility ID:21-02166

Facility Code: 22209
Last Inspected On: 10/21/2022
Operating Permit Renewal Date: 12/12/2025

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Stromberg Sinclair

Operator Contact: Todd O'Leary 4062623441

Owner/Operator: Stromberg Sinclair

Todd O'Leary, UST Class A Operator
Todd O'Leary, UST Class B Operator

Tank Code	08	Tank Age	25	Tank Installed Date	03/01/1999	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	3965	Spill Test Date	10/17/2022	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	04/30/2020	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	12000	ATG Test Date	10/09/2023	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	10/17/2022			ATG Type	Gilbarco/EMC Basic				
Tank Code	09	Tank Age	25	Tank Installed Date	03/01/1999	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	3966	Spill Test Date	10/17/2022	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	04/30/2020	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	8000	ATG Test Date	10/09/2023	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	10/17/2022			ATG Type	Gilbarco/EMC Basic				
Tank Code	10	Tank Age	25	Tank Installed Date	03/01/1999	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve

Tag Number	3967	Spill Test Date	10/17/2022	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	04/30/2020	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	4000	ATG Test Date	10/09/2023	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	10/17/2022			ATG Type	Gilbarco/EMC Basic				

Facility Summary in Hill County in the City of Havre

Location: ZIP TRIP 48
911 11th St W
Havre, MT 59501 Hill

System Facility ID:21-00089

Facility Code: 22169
Last Inspected On: 05/17/2021
Operating Permit Renewal Date: 06/27/2024

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: CHS Inc Spokane Valley

5095357701

Operator Contact: Jim Alford;Sean Hurley;Tom Savas

5095357701;5095367418

Owner/Operator: CHS Inc Spokane Valley

- Jim Alford, UST Class A Operator
- Jim Alford, UST Class B Global Operator
- Luci Tuttle, UST Class B Operator
- Sean Hurley, UST Class A Operator
- Tom Savas, UST Class A Operator

Tank Code	03	Tank Age	13	Tank Installed Date	10/01/2011	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	5341	Spill Test Date	09/29/2021	Piping Installed Date	10/11/2011	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	15000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date				ATG Type	Gilbarco/EMC Basic;Gilbarco-Veeder Root/EMC Basic				
Tank Code	04	Tank Age	13	Tank Installed Date	10/01/2011	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	5342	Spill Test Date	09/29/2021	Piping Installed Date	10/11/2011	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No

Capacity	10000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date				ATG Type	Gilbarco/EMC Basic;Gilbarco-Veeder Root/EMC Basic				
Tank Code	05	Tank Age	13	Tank Installed Date	10/01/2011	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	5343	Spill Test Date	09/29/2021	Piping Installed Date	10/11/2011	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	6000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date				ATG Type	Gilbarco/EMC Basic;Gilbarco-Veeder Root/EMC Basic				

Facility Summary in Hill County in the City of Havre

Location: ZIP TRIP 49
1004 1st St
Havre, MT 59501 Hill

System Facility ID:21-00103

Facility Code: 22170
Last Inspected On: 11/03/2022
Operating Permit Renewal Date: 12/04/2025

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: CHS Inc Spokane Valley

5095357701

Operator Contact: Jim Alford;Sean Hurley;Tom Savas

5095357701;5095367418

Owner/Operator: CHS Inc Spokane Valley

- Jim Alford, UST Class A Operator
- Jim Alford, UST Class B Global Operator
- Luci Tuttle, UST Class B Operator
- Sean Hurley, UST Class A Operator
- Tom Savas, UST Class A Operator

Tank Code	04	Tank Age	11	Tank Installed Date	05/01/2013	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	5405	Spill Test Date	01/05/2023	Piping Installed Date	11/27/2012	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	05/01/2013	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	07/28/2022	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	12000	ATG Test Date	07/28/2022	Line Tightness Test Date		Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	01/05/2023			ATG Type	Gilbarco-Veeder Root/TLS-350;Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	05	Tank Age	11	Tank Installed Date	05/01/2013	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	5406	Spill Test Date	07/06/2020	Piping Installed Date	11/27/2012	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	05/01/2013	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	07/28/2022	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No

Capacity	6000	ATG Test Date	07/28/2022	Line Tightness Test Date		Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	11/03/2022			ATG Type	Gilbarco-Veeder Root/TLS-350;Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	06	Tank Age	11	Tank Installed Date	05/01/2013	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	5407	Spill Test Date	01/05/2023	Piping Installed Date	11/27/2012	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	05/01/2013	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	07/28/2022	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	4000	ATG Test Date	07/28/2022	Line Tightness Test Date		Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	01/05/2023			ATG Type	Gilbarco-Veeder Root/TLS-350;Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Hill County in the City of Hingham

Location: HINGHAM MOTORS LLC
Central Ave & 1st St N
Hingham, MT 59528 Hill

System Facility ID:21-00783

Facility Code: 22185
Last Inspected On: 03/31/2017
Operating Permit Renewal Date: 05/14/2020

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: D's Automotive & Company4064685457

Operator Contact: Robert Spicher4063903171

Owner/Operator: D's Automotive & Company

Robert Spicher, UST Class A Operator
Robert Spicher, UST Class B Global Operator

Tank Code	S06	Tank Age	29	Tank Installed Date	07/25/1995	Tank Material	Unknown	Piping Material	Flexible Plastic	Overfill Types	
Tag Number	1383	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	Yes
Tank Status	Temporarily Out of Use	MLLD Test Date		Sump Tightness Test Date	05/13/2014	Catastrophic L.D Type 3.0	Continuous Interstitial Monitoring	Piping Type	Pressurized	CP Met Types	
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Deferred	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	12000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					
Tank Code	S07	Tank Age	26	Tank Installed Date	10/01/1998	Tank Material	Unknown	Piping Material	Flexible Plastic	Overfill Types	
Tag Number	1384	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	Yes
Tank Status	Temporarily Out of Use	MLLD Test Date		Sump Tightness Test Date	05/13/2014	Catastrophic L.D Type 3.0	Continuous Interstitial Monitoring	Piping Type	Pressurized	CP Met Types	
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Deferred	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	12000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					
Tank Code	S08	Tank Age	26	Tank Installed Date	10/01/1998	Tank Material	Unknown	Piping Material	Flexible Plastic	Overfill Types	

Tag Number	1385	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	Yes
Tank Status	Temporarily Out of Use	MLLD Test Date		Sump Tightness Test Date	05/13/2014	Catastrophic L.D Type 3.0	Continuous Interstitial Monitoring	Piping Type	Pressurized	CP Met Types	
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Deferred	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	12000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					
Tank Code	S09	Tank Age	26	Tank Installed Date	10/01/1998	Tank Material	Unknown	Piping Material	Flexible Plastic	Overfill Types	
Tag Number	1386	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	Yes
Tank Status	Temporarily Out of Use	MLLD Test Date		Sump Tightness Test Date	05/13/2014	Catastrophic L.D Type 3.0	Continuous Interstitial Monitoring	Piping Type	Pressurized	CP Met Types	
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Deferred	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	12000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					

Facility Summary in Hill County in the City of Inverness

Location: FRASER OIL INC INVERNESS
125 Main St
Inverness, MT 59530 Hill

System Facility ID:21-07327

Facility Code: 22337
Last Inspected On: 11/16/2023
Operating Permit Renewal Date: 03/27/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Fraser Oil Inc4062923833

Operator Contact: Cory Fraser

Owner/Operator: Fraser Oil Inc

Cory Fraser, UST Class A Operator
Cory Fraser, UST Class B Operator

Tank Code	04	Tank Age	32	Tank Installed Date	10/15/1992	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	1120	Spill Test Date	11/16/2023	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	11/14/2022	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection		Vapor Recovery	No
Capacity	1000	ATG Test Date	11/16/2023	Line Tightness Test Date	12/11/2008	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	11/16/2022			ATG Type	Gilbarco/EMC Basic				
Tank Code	05	Tank Age	32	Tank Installed Date	10/15/1992	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	1121	Spill Test Date	11/16/2023	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	11/14/2022	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection		Vapor Recovery	No
Capacity	1000	ATG Test Date	11/16/2023	Line Tightness Test Date	12/11/2008	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	11/16/2022			ATG Type	Gilbarco/EMC Basic				
Tank Code	06	Tank Age	32	Tank Installed Date	10/15/1992	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	1122	Spill Test Date	11/16/2023	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No

Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	11/14/2022	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection		Vapor Recovery	No
Capacity	1000	ATG Test Date	11/16/2023	Line Tightness Test Date	12/11/2008	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	11/16/2022			ATG Type	Gilbarco/EMC Basic				

Facility Summary in Hill County in the City of Rudyard

Location: C & H Tires Inc
103 Main St
Rudyard, MT 59540 Hill

System Facility ID:21-02475

Facility Code: 22212
Last Inspected On: 03/30/2022
Operating Permit Renewal Date: 09/24/2025

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: C & H Tires Inc 4063554131

Operator Contact: Rick Pester;Robert Toner 4063554131

Owner/Operator: C & H Tires Inc

Rick Pester, UST Class A Operator

Rick Pester, UST Class B Operator

Robert Toner, UST Class A Operator

Tank Code	05	Tank Age	27	Tank Installed Date	11/01/1997	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	2108	Spill Test Date	03/30/2021	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	04/14/2016	Primary Tank Leak Detection	Automatic Tank Gauging 0.1	Primary Pipe Detection		Vapor Recovery	No
Capacity	2000	ATG Test Date	03/30/2022	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	05/11/2022			ATG Type	Other/				
Tank Code	06	Tank Age	27	Tank Installed Date	11/01/1997	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	2109	Spill Test Date	03/30/2021	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	04/14/2016	Primary Tank Leak Detection	Automatic Tank Gauging 0.1	Primary Pipe Detection		Vapor Recovery	No
Capacity	2000	ATG Test Date	03/30/2022	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	05/11/2022			ATG Type	Other/				

Facility Summary in Hill County in the City of Rudyard

Location: FARMERS UNION OIL CO RUDYARD
1 Main St
Rudyard, MT 59540 Hill

System Facility ID:21-03509

Facility Code: 22239
Last Inspected On: 09/07/2022
Operating Permit Renewal Date: 09/28/2025

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Farmers Union Oil Co Rudyard 4063554543

Operator Contact: Cory Tollefson;Farmers Union Oil Co Rudyard 4064430382;4063554543

Owner/Operator: Farmers Union Oil Co Rudyard

Cory Tollefson, UST Class A Operator
Cory Tollefson, UST Class B Global Operator

Tank Code	S4	Tank Age	58	Tank Installed Date	04/23/1966	Tank Material	Bare Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	
Tag Number	947	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	Yes
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	01/10/2023	Catastrophic L.D Type 3.0	Continuous Interstitial Monitoring	Piping Type	Pressurized	CP Met Types	
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection		Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	2000	ATG Test Date	09/07/2022	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					
Tank Code	S5	Tank Age	58	Tank Installed Date	04/23/1966	Tank Material	Bare Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	
Tag Number	948	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	Yes
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	01/10/2023	Catastrophic L.D Type 3.0	Continuous Interstitial Monitoring	Piping Type	Pressurized	CP Met Types	
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection		Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	10000	ATG Test Date	09/07/2022	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					
Tank Code	S6	Tank Age	58	Tank Installed Date	04/23/1966	Tank Material	Bare Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	

Tag Number	949	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	Yes
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	01/10/2023	Catastrophic L.D Type 3.0	Continuous Interstitial Monitoring	Piping Type	Pressurized	CP Met Types	
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection		Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	5000	ATG Test Date	09/07/2022	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					