

Facility Summary in Hill County in the City of Havre

Location: BN HAVRE RAIL YARD
235 Main St
Havre, MT 59501-3523 Hill

System Facility ID:21-09548

Facility Code: 22426
Last Inspected On: 05/26/2023
Operating Permit Renewal Date: 08/26/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: BNSF Railway Company Fort Worth (817) 333-2000

Operator Contact: Robert Mantle;BNSF Railway Havre;Tavita Masau;Tim Christianson (406) 265-0483;(406) 939-4254;(773) 600-2860 bobmantle@hotmail.com;tmasau@icloud.com

Owner/Operator: BNSF Railway Company Fort Worth (817) 333-2000

Doran Loftus, UST Class B Global Operator	doran.loftus@aecom.com
Dwayne Whitaker, UST Class B Operator	
Ed Hill, UST Class B Operator	edward.hill@bnsf.com
Robert Mantle, UST Class A Operator	bobmantle@hotmail.com
Tavita Masau, UST Class A Operator	tmasau@icloud.com
Tavita Masau, UST Class B Global Operator	tmasau@icloud.com
Tim Christianson, UST Class A Operator	
Tom Swinney, UST Class B Operator	thomas.swinney@bnsf.com

Tank Code	S23	Tank Age	22	Tank Installed Date	01/22/2004	Tank Material	Concrete	Piping Material	Steel - Terminal Piping	Overfill Types	
Tag Number	4877	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	Yes
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Pressurized	CP Met Types	
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	11/02/2023	Primary Tank Leak Detection		Primary Pipe Detection	Terminal Piping Annual Line Test	Vapor Recovery	No
Capacity	640000	ATG Test Date	05/23/2023	Line Tightness Test Date	08/02/2019	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date				ATG Type					
Tank Code	S24	Tank Age	22	Tank Installed Date	01/22/2004	Tank Material	Concrete	Piping Material	Steel - Terminal Piping	Overfill Types	
Tag Number	4878	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	Yes
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Pressurized	CP Met Types	
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	11/02/2023	Primary Tank Leak Detection		Primary Pipe Detection	Terminal Piping Annual Line Test	Vapor Recovery	No

Capacity	640000	ATG Test Date	05/23/2023	Line Tightness Test Date	08/02/2019	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date				ATG Type					

Facility Summary in Hill County in the City of Havre

Location: CIRCLE K STORE 2746272
200 1st St W
Havre, MT 59501 Hill

System Facility ID:21-08068

Facility Code: 22350
Last Inspected On: 05/23/2023
Operating Permit Renewal Date: 12/04/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Rocky Mountain Oil LLC

(602) 728-8000

NT-ESS@Circlek.com

Operator Contact: Veronica Rivera

ESS-WestCoast@circlek.com

Owner/Operator: Rocky Mountain Oil LLC

(602) 728-8000

NT-ESS@Circlek.com

Brad Lee, UST Class B Global Operator
Jeff Reed, UST Class B Global Operator
Veronica Rivera, UST Class A Operator

brad.lee@holidaycompanies.com
jeff.reed@holidaycompanies.com
ESS-WestCoast@circlek.com

Tank Code	01	Tank Age	0	Tank Installed Date		Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	3013	Spill Test Date		Piping Installed Date	11/24/2020	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	05/23/2023	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date	09/09/2020	Tank/Piping CP Test Date	09/06/2022	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	Yes
Capacity	12000	ATG Test Date	05/23/2023	Line Tightness Test Date	11/12/2020	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	09/07/2022			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	02	Tank Age	41	Tank Installed Date	10/01/1985	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	3014	Spill Test Date		Piping Installed Date	11/24/2020	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	09/07/2022	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date	09/09/2020	Tank/Piping CP Test Date	09/06/2022	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	Yes
Capacity	12000	ATG Test Date	05/23/2023	Line Tightness Test Date	11/17/2020	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No

		Overfill Test Date	09/08/2022			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	03	Tank Age	41	Tank Installed Date	10/01/1985	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	3015	Spill Test Date		Piping Installed Date	11/24/2020	Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	05/23/2023	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date	09/09/2020	Tank/Piping CP Test Date	09/06/2022	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	Yes
Capacity	10000	ATG Test Date	05/23/2023	Line Tightness Test Date	11/10/2020	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	09/07/2022			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	04	Tank Age	41	Tank Installed Date	10/01/1985	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	3016	Spill Test Date		Piping Installed Date	11/24/2020	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	05/23/2023	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Diesel	PLLD Test Date	09/09/2020	Tank/Piping CP Test Date	09/06/2022	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	10000	ATG Test Date	05/23/2023	Line Tightness Test Date	11/11/2020	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	09/07/2022			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Hill County in the City of Havre

Location: EMPORIUM FOOD AND FUEL
1415 1st St
Havre, MT 59501 Hill

System Facility ID:21-12763

Facility Code: 22461
Last Inspected On: 03/18/2025
Operating Permit Renewal Date: 06/30/2028

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Duck Inn Inc

duckinninc@gmail.com

Operator Contact: Joseph Hopf;Marie Hawkins;Duck Inn Inc

(406) 344-2966

gpgekk1@yahoo.com;duckinninc@gmail.com;jhopf2016@gmail.com

Owner/Operator: Duck Inn Inc

duckinninc@gmail.com

Cindy Lee, UST Class B Operator
Dustin Rolfe, UST Class B Operator
Joseph Hopf, UST Class A Operator
Joseph Hopf, UST Class B Operator
Marie Hawkins, UST Class A Operator
Marie Hawkins, UST Class B Operator

emporiumstationhavre@gmail.com
dustinrolfe81@gmail.com
jhopf2016@gmail.com
jhopf2016@gmail.com
duckinninc@gmail.com
duckinninc@gmail.com

Tank Code	01	Tank Age	34	Tank Installed Date	08/01/1992	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	2971	Spill Test Date	03/15/2025	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	05/12/2021	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	12000	ATG Test Date	05/07/2025	Line Tightness Test Date	01/06/2025	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	05/15/2024			ATG Type	Franklin Fueling Systems/EVO 600				
Tank Code	02	Tank Age	34	Tank Installed Date	08/01/1992	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	2972	Spill Test Date	03/15/2025	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	05/12/2021	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	12000	ATG Test Date	05/07/2025	Line Tightness Test Date	03/21/2022	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No

		Overfill Test Date	05/15/2024			ATG Type	Franklin Fueling Systems/EVO 600				
Tank Code	03	Tank Age	34	Tank Installed Date	08/01/1992	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	2973	Spill Test Date	03/15/2025	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	05/12/2021	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	6000	ATG Test Date	05/07/2025	Line Tightness Test Date	01/03/2025	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	05/15/2024			ATG Type	Franklin Fueling Systems/EVO 600				
Tank Code	04	Tank Age	34	Tank Installed Date	08/01/1992	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	2974	Spill Test Date	03/15/2025	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	05/12/2021	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	6000	ATG Test Date	05/07/2025	Line Tightness Test Date	01/09/2025	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	05/15/2024			ATG Type	Franklin Fueling Systems/EVO 600				

Facility Summary in Hill County in the City of Havre

Location: EZZIES CENEX CARDTROL
33 1st St
Havre, MT 59501 Hill

System Facility ID:21-07467

Facility Code: 22339
Last Inspected On: 09/05/2023
Operating Permit Renewal Date: 09/05/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Ezzies Wholesale Inc (406) 654-2331 bill@ezzies.com

Operator Contact: Conor Moran;Ezzies Wholesale Inc (406) 654-2331 conor@ezzies.com;bill@ezzies.com

Owner/Operator: Ezzies Wholesale Inc (406) 654-2331 bill@ezzies.com

Conor Moran, UST Class A Operator bill@ezzies.com
Jimmy Kimberling, UST Class B Operator havre@ezzies.com

Tank Code	08	Tank Age	29	Tank Installed Date	06/01/1997	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	538	Spill Test Date	05/23/2023	Piping Installed Date	08/27/2008	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	05/12/2020	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	4000	ATG Test Date	05/23/2023	Line Tightness Test Date	05/23/2023	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	05/23/2023			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	09	Tank Age	29	Tank Installed Date	06/01/1997	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	539	Spill Test Date	05/23/2023	Piping Installed Date	08/27/2008	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	05/12/2020	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	4000	ATG Test Date	05/23/2023	Line Tightness Test Date	05/23/2023	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	05/23/2023			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Tank Code	10	Tank Age	29	Tank Installed Date	06/01/1997	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	540	Spill Test Date	05/23/2023	Piping Installed Date	08/27/2008	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	05/12/2020	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	4000	ATG Test Date	05/23/2023	Line Tightness Test Date	05/23/2023	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	05/23/2023			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	11	Tank Age	29	Tank Installed Date	06/28/1997	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	541	Spill Test Date	05/23/2023	Piping Installed Date	08/27/2008	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	05/12/2020	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	6000	ATG Test Date	05/23/2023	Line Tightness Test Date	05/23/2023	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	05/23/2023			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	12	Tank Age	29	Tank Installed Date	06/28/1997	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	542	Spill Test Date	05/23/2023	Piping Installed Date	08/27/2008	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	05/12/2020	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	6000	ATG Test Date	05/23/2023	Line Tightness Test Date	05/23/2023	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	05/23/2023			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	13	Tank Age	29	Tank Installed Date	06/01/1997	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	543	Spill Test Date	05/23/2023	Piping Installed Date	08/27/2008	Tank Construction		Piping Construction	Double Walled	AST	No

Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	05/12/2020	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	8000	ATG Test Date	05/23/2023	Line Tightness Test Date	05/23/2023	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	05/23/2023			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Hill County in the City of Havre

Location: EZZIES WHOLESALE HAVRE
726 1st St W
Havre, MT 59501-3418 Hill

System Facility ID:21-12751

Facility Code: 22460
Last Inspected On: 03/18/2025
Operating Permit Renewal Date: 07/09/2028

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Ezzies Wholesale Inc (406) 654-2331 bill@ezzies.com

Operator Contact: Conor Moran;Ezzies Wholesale Inc (406) 654-2331 conor@ezzies.com;bill@ezzies.com

Owner/Operator: Ezzies Wholesale Inc (406) 654-2331 bill@ezzies.com
Conor Moran, UST Class A Operator bill@ezzies.com
Jimmy Kimberling, UST Class B Operator havre@ezzies.com

Tank Code	01	Tank Age	34	Tank Installed Date	07/01/1992	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	878	Spill Test Date	05/12/2021	Piping Installed Date		Tank Construction		Piping Construction	Single Walled	AST	No
Tank Status	Temporarily Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Solvents	PLLD Test Date		Tank/Piping CP Test Date	03/18/2025	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	4000	ATG Test Date	05/12/2021	Line Tightness Test Date	03/21/2013	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	05/12/2021			ATG Type	Gilbarco/EMC				
Tank Code	02	Tank Age	34	Tank Installed Date	07/01/1992	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	879	Spill Test Date	05/15/2024	Piping Installed Date		Tank Construction		Piping Construction	Single Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date	05/15/2024	Tank/Piping CP Test Date	03/18/2025	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	12000	ATG Test Date	05/15/2024	Line Tightness Test Date	08/29/2007	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	05/15/2024			ATG Type	Gilbarco/EMC				
Tank Code	03	Tank Age	34	Tank Installed Date	07/01/1992	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	880	Spill Test Date	05/15/2024	Piping Installed Date		Tank Construction		Piping Construction	Single Walled	AST	No

Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date	05/15/2024	Tank/Piping CP Test Date	03/18/2025	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	12000	ATG Test Date	05/15/2024	Line Tightness Test Date	08/29/2007	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	05/15/2024			ATG Type	Gilbarco/EMC				
Tank Code	04	Tank Age	34	Tank Installed Date	07/01/1992	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	881	Spill Test Date	05/15/2024	Piping Installed Date		Tank Construction		Piping Construction	Single Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date	05/15/2024	Tank/Piping CP Test Date	07/16/2025	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	12000	ATG Test Date	05/15/2024	Line Tightness Test Date	08/29/2007	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	05/15/2024			ATG Type	Gilbarco/EMC				
Tank Code	05	Tank Age	34	Tank Installed Date	07/01/1992	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	882	Spill Test Date	05/15/2024	Piping Installed Date		Tank Construction		Piping Construction	Single Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date	05/15/2024	Tank/Piping CP Test Date	03/18/2025	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	12000	ATG Test Date	05/15/2024	Line Tightness Test Date	08/29/2007	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	05/15/2024			ATG Type	Gilbarco/EMC				
Tank Code	06	Tank Age	34	Tank Installed Date	07/01/1992	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	883	Spill Test Date	05/15/2024	Piping Installed Date		Tank Construction		Piping Construction	Single Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date	05/15/2024	Tank/Piping CP Test Date	03/18/2025	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	12000	ATG Test Date	05/15/2024	Line Tightness Test Date	08/29/2007	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	05/15/2024			ATG Type	Gilbarco/EMC				
Tank Code	07	Tank Age	34	Tank Installed Date	07/01/1992	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	884	Spill Test Date	05/15/2024	Piping Installed Date		Tank Construction		Piping Construction	Single Walled	AST	No

Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date	05/15/2024	Tank/Piping CP Test Date	03/18/2025	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	12000	ATG Test Date	05/15/2024	Line Tightness Test Date	08/29/2007	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	05/15/2024			ATG Type	Gilbarco/EMC				
Tank Code	08	Tank Age	34	Tank Installed Date	07/01/1992	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	885	Spill Test Date	05/15/2024	Piping Installed Date		Tank Construction		Piping Construction	Single Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date	05/15/2024	Tank/Piping CP Test Date	03/18/2025	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	12000	ATG Test Date	05/15/2024	Line Tightness Test Date	08/29/2007	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	05/15/2024			ATG Type	Gilbarco/EMC				

Facility Summary in Hill County in the City of Havre

Location: HILL COUNTY JUSTICE CENTER
1450 2nd St W
Havre, MT 59501-3497 Hill

System Facility ID:56-13886

Facility Code: 30561
Last Inspected On: 09/04/2024
Operating Permit Renewal Date: 11/05/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Hill County Commissioners (406) 265-5481

Operator Contact: Daryl Anez;Joseph Smith;Richard Ricci (406) 262-3467;(406) 945-1497 anezd@hillcounty.us;ricci@co.hill.mt.us

Owner/Operator: Hill County Commissioners (406) 265-5481

Daryl Anez, UST Class A Operator	anezd@hillcounty.us
Daryl Anez, UST Class B Global Operator	anezd@hillcounty.us
Daryl Anez, UST Class B Operator	anezd@hillcounty.us
Joseph Smith, UST Class A Operator	
Joseph Smith, UST Class B Operator	
Mike Winchell, UST Class B Global Operator	mike@lodestarlandandhome.com
Richard Ricci, UST Class A Operator	ricci@co.hill.mt.us
Richard Ricci, UST Class B Global Operator	ricci@co.hill.mt.us

Tank Code	S1	Tank Age	28	Tank Installed Date	07/20/1998	Tank Material	Concrete	Piping Material	Steel	Overfill Types	
Tag Number	1377	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	Secondary Containment Chase	AST	Yes
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Auto Dialer	Piping Type	U.S. Suction	CP Met Types	
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection		Primary Pipe Detection	3-Year Line Tightness Test	Vapor Recovery	No
Capacity	2000	ATG Test Date		Line Tightness Test Date	09/04/2024	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date				ATG Type					

Facility Summary in Hill County in the City of Havre

Location: STROMBERGS SINCLAIR
1200 1st St
Havre, MT 59501-3802 Hill

System Facility ID:21-02166

Facility Code: 22209
Last Inspected On: 07/01/2025
Operating Permit Renewal Date: 12/12/2028

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Stromberg Sinclair

toleary75@icloud.com

Operator Contact: Todd O'Leary

(406) 262-3441

toleary75@icloud.com

Owner/Operator: Stromberg Sinclair

toleary75@icloud.com

Todd O'Leary, UST Class A Operator

toleary75@icloud.com

Todd O'Leary, UST Class B Operator

toleary75@icloud.com

Tank Code	08	Tank Age	27	Tank Installed Date	03/01/1999	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	3965	Spill Test Date	07/01/2025	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	12000	ATG Test Date	07/01/2025	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	07/01/2025			ATG Type	Gilbarco/EMC Basic				
Tank Code	09	Tank Age	27	Tank Installed Date	03/01/1999	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	3966	Spill Test Date	10/17/2022	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	8000	ATG Test Date	10/09/2023	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	10/17/2022			ATG Type	Gilbarco/EMC Basic				
Tank Code	10	Tank Age	27	Tank Installed Date	03/01/1999	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve

Tag Number	3967	Spill Test Date	10/17/2022	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	4000	ATG Test Date	10/09/2023	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	10/17/2022			ATG Type	Gilbarco/EMC Basic				

Facility Summary in Hill County in the City of Havre

Location: TOWN PUMP HAVRE
136 1st St W
Havre, MT 59501 Hill

System Facility ID:21-08705

Facility Code: 22359
Last Inspected On: 02/27/2024
Operating Permit Renewal Date: 09/19/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Havre 1 Town Pump LLC (406) 497-6700 environmental@townpump.com

Operator Contact: Daniel Sampson;Trent Biggers (406) 497-6700 andrew02@directv.net;Trentb@townpump.com

Owner/Operator: Havre 1 Town Pump LLC (406) 497-6700 environmental@townpump.com

Daniel Sampson, UST Class A Operator
Daniel Sampson, UST Class B Global Operator
Trent Biggers, UST Class A Operator
Trent Biggers, UST Class B Global Operator

andrew02@directv.net
andrew02@directv.net
Trentb@townpump.com
Trentb@townpump.com

Tank Code	03	Tank Age	37	Tank Installed Date	11/15/1989	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	2472	Spill Test Date	07/26/2023	Piping Installed Date	07/25/2014	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	07/26/2023	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	06/19/2025	Tank/Piping CP Test Date		Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	12000	ATG Test Date	06/19/2025	Line Tightness Test Date	01/29/2015	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	07/26/2023			ATG Type	Veeder Root/TLS-450PLUS				
Tank Code	04	Tank Age	37	Tank Installed Date	11/15/1989	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	2473	Spill Test Date	07/26/2023	Piping Installed Date	07/25/2014	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	07/26/2023	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	06/19/2025	Tank/Piping CP Test Date		Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Vapor Recovery	No

Capacity	12000	ATG Test Date	06/19/2025	Line Tightness Test Date	01/29/2015	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	07/26/2023			ATG Type	Veeder Root/TLS-450PLUS				
Tank Code	05	Tank Age	37	Tank Installed Date	11/15/1989	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	2474	Spill Test Date	07/26/2023	Piping Installed Date	07/25/2014	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	07/26/2023	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	06/19/2025	Tank/Piping CP Test Date		Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	12000	ATG Test Date	06/19/2025	Line Tightness Test Date	01/29/2015	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	07/26/2023			ATG Type	Veeder Root/TLS-450PLUS				
Tank Code	06	Tank Age	37	Tank Installed Date	11/15/1989	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	2475	Spill Test Date	07/26/2023	Piping Installed Date	07/25/2014	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	07/26/2023	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	06/19/2025	Tank/Piping CP Test Date		Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	12000	ATG Test Date	06/19/2025	Line Tightness Test Date	01/29/2015	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	07/26/2023			ATG Type	Veeder Root/TLS-450PLUS				
Tank Code	07	Tank Age	12	Tank Installed Date	08/01/2014	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	5510	Spill Test Date	07/26/2023	Piping Installed Date	07/25/2014	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	07/26/2023	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	06/19/2025	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	6000	ATG Test Date	06/19/2025	Line Tightness Test Date	01/29/2015	Secondary Tank Leak Detection	Statistical Inventory Reconciliation	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	Yes
		Overfill Test Date	07/26/2023			ATG Type	Veeder Root/TLS-450PLUS				

Tank Code	08	Tank Age	12	Tank Installed Date	08/01/2014	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	5514	Spill Test Date	07/26/2023	Piping Installed Date	07/25/2014	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	07/26/2023	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel, Dyed	PLLD Test Date	06/19/2025	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	15000	ATG Test Date	06/19/2025	Line Tightness Test Date	01/29/2015	Secondary Tank Leak Detection	Statistical Inventory Reconciliation	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	Yes
		Overfill Test Date	08/07/2023			ATG Type	Veeder Root/TLS-450PLUS				
Tank Code	09	Tank Age	12	Tank Installed Date	08/01/2014	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	5515	Spill Test Date		Piping Installed Date	07/25/2014	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Other	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	DEF (Not Regulated)	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	6000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date				ATG Type					

Facility Summary in Hill County in the City of Havre

Location: ZIP TRIP 48
911 11th St W
Havre, MT 59501 Hill

System Facility ID:21-00089

Facility Code: 22169
Last Inspected On: 06/24/2024
Operating Permit Renewal Date: 06/27/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: CHS Inc Spokane Valley (509) 535-7701 jim.alford@chsinc.com

Operator Contact: Jim Alford;Sean Hurley (509) 535-7701;(509) 536-7418 jim.alford@chsinc.com;sean.hurley@chsinc.com

Owner/Operator: CHS Inc Spokane Valley (509) 535-7701 jim.alford@chsinc.com

Jim Alford, UST Class A Operator jim.alford@chsinc.com
 Jim Alford, UST Class B Operator jim.alford@chsinc.com
 Luci Tuttle, UST Class B Operator Lucinda.Tuttle@chsinc.com
 Sean Hurley, UST Class A Operator sean.hurley@chsinc.com
 Travis Weber, UST Class B Operator travis.weber3@chsinc.com

Tank Code	03	Tank Age	15	Tank Installed Date	10/01/2011	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	5341	Spill Test Date	08/08/2024	Piping Installed Date	10/11/2011	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	09/29/2021	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	06/24/2025	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	15000	ATG Test Date	06/24/2025	Line Tightness Test Date		Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	08/08/2024			ATG Type	Gilbarco/EMC Basic;Gilbarco-Veeder Root/EMC Basic				
Tank Code	04	Tank Age	15	Tank Installed Date	10/01/2011	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	5342	Spill Test Date	06/24/2024	Piping Installed Date	10/11/2011	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	09/29/2021	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	06/24/2025	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No

Capacity	10000	ATG Test Date	06/24/2025	Line Tightness Test Date		Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	08/08/2024			ATG Type	Gilbarco/EMC Basic;Gilbarco-Veeder Root/EMC Basic				
Tank Code	05	Tank Age	15	Tank Installed Date	10/01/2011	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	5343	Spill Test Date	06/24/2024	Piping Installed Date	10/11/2011	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	09/29/2021	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	06/24/2025	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	6000	ATG Test Date	06/24/2025	Line Tightness Test Date		Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	08/08/2024			ATG Type	Gilbarco/EMC Basic;Gilbarco-Veeder Root/EMC Basic				

Facility Summary in Hill County in the City of Havre

Location: ZIP TRIP 49
1004 1st St
Havre, MT 59501 Hill

System Facility ID:21-00103

Facility Code: 22170
Last Inspected On: 08/06/2025
Operating Permit Renewal Date: 12/04/2028

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: CHS Inc Spokane Valley (509) 535-7701 jim.alford@chsinc.com

Operator Contact: Jim Alford;Sean Hurley (509) 535-7701;(509) 536-7418 jim.alford@chsinc.com;sean.hurley@chsinc.com

Owner/Operator: CHS Inc Spokane Valley (509) 535-7701 jim.alford@chsinc.com

Jim Alford, UST Class A Operator jim.alford@chsinc.com
 Jim Alford, UST Class B Operator jim.alford@chsinc.com
 Luci Tuttle, UST Class B Operator Lucinda.Tuttle@chsinc.com
 Sean Hurley, UST Class A Operator sean.hurley@chsinc.com
 Travis Weber, UST Class B Operator jim.alford@chsinc.com

Tank Code	04	Tank Age	13	Tank Installed Date	05/01/2013	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	5405	Spill Test Date	01/05/2023	Piping Installed Date	11/27/2012	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	07/06/2020	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	06/24/2025	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	12000	ATG Test Date	06/24/2025	Line Tightness Test Date		Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	01/05/2023			ATG Type	Gilbarco-Veeder Root/TLS-350;Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	05	Tank Age	13	Tank Installed Date	05/01/2013	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	5406	Spill Test Date	07/06/2020	Piping Installed Date	11/27/2012	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	07/06/2020	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	06/24/2025	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No

Capacity	6000	ATG Test Date	06/24/2025	Line Tightness Test Date		Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	11/03/2025			ATG Type	Gilbarco-Veeder Root/TLS-350;Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	06	Tank Age	13	Tank Installed Date	05/01/2013	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	5407	Spill Test Date	01/05/2023	Piping Installed Date	11/27/2012	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	07/06/2020	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	06/24/2025	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	4000	ATG Test Date	06/24/2025	Line Tightness Test Date		Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	08/06/2025			ATG Type	Gilbarco-Veeder Root/TLS-350;Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Hill County in the City of Inverness

Location: FRASER OIL INC INVERNESS
125 Main St
Inverness, MT 59530 Hill

System Facility ID:21-07327

Facility Code: 22337
Last Inspected On: 11/16/2023
Operating Permit Renewal Date: 03/27/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Fraser Oil Inc (406) 292-3833

Operator Contact: Cory Fraser

frasfuel@yahoo.com

Owner/Operator: Fraser Oil Inc (406) 292-3833

Cory Fraser, UST Class A Operator
Cory Fraser, UST Class B Operator

frasfuel@yahoo.com
frasfuel@yahoo.com

Tank Code	04	Tank Age	34	Tank Installed Date	10/15/1992	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	1120	Spill Test Date	11/16/2023	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	11/14/2022	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection		Vapor Recovery	No
Capacity	1000	ATG Test Date	11/16/2023	Line Tightness Test Date	12/11/2008	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	11/16/2022			ATG Type	Gilbarco/EMC Basic				
Tank Code	05	Tank Age	34	Tank Installed Date	10/15/1992	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	1121	Spill Test Date	11/16/2023	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	11/14/2022	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection		Vapor Recovery	No
Capacity	1000	ATG Test Date	11/16/2023	Line Tightness Test Date	12/11/2008	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	11/16/2022			ATG Type	Gilbarco/EMC Basic				
Tank Code	06	Tank Age	34	Tank Installed Date	10/15/1992	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	1122	Spill Test Date	11/16/2023	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No

Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	11/14/2022	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection		Vapor Recovery	No
Capacity	1000	ATG Test Date	11/16/2023	Line Tightness Test Date	12/11/2008	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	11/16/2022			ATG Type	Gilbarco/EMC Basic				

Facility Summary in Hill County in the City of Rudyard

Location: C & H TIRES INC
103 Main St
Rudyard, MT 59540 Hill

System Facility ID:21-02475

Facility Code: 22212
Last Inspected On: 06/24/2025
Operating Permit Renewal Date: 09/24/2028

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: C & H Tires Inc (406) 355-4131 dunlop_12345@yahoo.com

Operator Contact: Rick Pester;Robert Toner (406) 355-4131 toners@itstriangle.com;toners@mtintouch.net

Owner/Operator: C & H Tires Inc (406) 355-4131 dunlop_12345@yahoo.com

Rick Pester, UST Class A Operator
Rick Pester, UST Class B Operator
Robert Toner, UST Class A Operator

toners@mtintouch.net
toners@mtintouch.net
toners@itstriangle.com

Tank Code	05	Tank Age	29	Tank Installed Date	11/01/1997	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	2108	Spill Test Date	06/24/2025	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	04/14/2016	Primary Tank Leak Detection	Automatic Tank Gauging 0.1	Primary Pipe Detection		Vapor Recovery	No
Capacity	2000	ATG Test Date	06/24/2025	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	06/24/2025			ATG Type	Franklin Fueling Systems/EVO 600				
Tank Code	06	Tank Age	29	Tank Installed Date	11/01/1997	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	2109	Spill Test Date	06/24/2025	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	04/14/2016	Primary Tank Leak Detection	Automatic Tank Gauging 0.1	Primary Pipe Detection		Vapor Recovery	No
Capacity	2000	ATG Test Date	06/24/2025	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	06/24/2025			ATG Type	Franklin Fueling Systems/EVO 600				

Facility Summary in Hill County in the City of Rudyard

Location: FARMERS UNION OIL CO RUDYARD
1 Main St
Rudyard, MT 59540 Hill

System Facility ID:21-03509

Facility Code: 22239
Last Inspected On: 09/11/2025
Operating Permit Renewal Date: 09/28/2028

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Farmers Union Oil Co Rudyard (406) 355-4543 farmersunionoilrudyard@yahoo.com

Operator Contact: Cory Tollefson;Farmers Union Oil Co Rudyard (406) 443-0382;(406) 355-4543 farmersunionoilrudyard@yahoo.com;farmersunionoilrudyard@yahoo.com

Owner/Operator: Farmers Union Oil Co Rudyard (406) 355-4543 farmersunionoilrudyard@yahoo.com

Cory Tollefson, UST Class A Operator

farmersunionoilrudyard@yahoo.com

Cory Tollefson, UST Class B Operator

farmersunionoilrudyard@yahoo.com

Tank Code	S4	Tank Age	60	Tank Installed Date	04/23/1966	Tank Material	Bare Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	
Tag Number	947	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	Yes
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	09/11/2025	Catastrophic L.D Type 3.0	Continuous Interstitial Monitoring	Piping Type	Pressurized	CP Met Types	
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection		Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	2000	ATG Test Date	09/07/2022	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					
Tank Code	S5	Tank Age	60	Tank Installed Date	04/23/1966	Tank Material	Bare Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	
Tag Number	948	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	Yes
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	09/11/2025	Catastrophic L.D Type 3.0	Continuous Interstitial Monitoring	Piping Type	Pressurized	CP Met Types	
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection		Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	10000	ATG Test Date	09/07/2022	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					
Tank Code	S6	Tank Age	60	Tank Installed Date	04/23/1966	Tank Material	Bare Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	

Tag Number	949	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	Yes
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	09/11/2025	Catastrophic L.D Type 3.0	Continuous Interstitial Monitoring	Piping Type	Pressurized	CP Met Types	
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection		Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	5000	ATG Test Date	09/07/2022	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					