

Facility Summary in Jefferson County in the City of Boulder

Location: HARLOWS SCHOOL BUS SERVICE INC BOULDER
101 Main St
Boulder, MT 59632 Jefferson

Legacy ID:22-12378

Facility ID: 22635
Last Inspected On: 02/10/2020
Operating Permit Renewal Date:

Owner Operator Contact: HJJ Properties LLC;N/A ZZZ - TBL_OWN :
454;Harlows School Bus Service Inc Rolette

7012241767

Operator Contact: Hugh Taylor;Sandra Hays;Wesley Tangen

4062253344;4062398845;4062938845

Owner/Operator: HJJ Properties LLC

Hugh Taylor, UST Class A Operator
Hugh Taylor, UST Class B Operator
Sandra Hays, UST Class A Operator
Sandra Hays, UST Class B Operator
Wesley Tangen, UST Class A Operator
Wesley Tangen, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
06	30	10/01/1991	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
2710	No			None	Yes
Temporarily Out of Use			Not Required	Safe Suction	Galvanic
Gasoline		07/25/2017	Automatic Tank Gauging 0.1;Automatic Tank Gauging 0.2	Not Listed	No
2,000					No
07	30	10/01/1991	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
2711	No			None	Yes
Temporarily Out of Use			Not Required	Safe Suction	Galvanic
Diesel		07/25/2017	Automatic Tank Gauging 0.1;Automatic Tank Gauging 0.2	Not Listed	No
2,000					No

Facility Summary in Jefferson County in the City of Boulder

Location: TOWN PUMP INC BOULDER
703 N Main
Boulder, MT 59632 Jefferson

Legacy ID:22-08673

Facility ID: 22598
Last Inspected On: 05/25/2021
Operating Permit Renewal Date: 05/26/2024

Owner Operator Contact: Kevin Kenneally;Major Brands Dist Imports Inc

4067829121

Operator Contact: Trent Biggers

Owner/Operator: Boulder 1 Town Pump LLC

Trent Biggers, UST Class A Operator
Trent Biggers, UST Class B Global Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
01	44	05/10/1977	Cathodically Protected Steel	Flexible Plastic	Ball Float Valve
2485	No			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		12/01/2014	Approved Remote Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
12,000		09/26/2006	Gilbarco-Veeder Root/TLS-350		No
02	44	05/10/1977	Bare Steel	Flexible Plastic	Ball Float Valve
2486	No			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Diesel		12/01/2014	Approved Remote Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
6,000		09/26/2006	Gilbarco-Veeder Root/TLS-350		No
03	44	05/10/1977	Bare Steel	Flexible Plastic	Ball Float Valve

2487	No			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		12/01/2014	Approved Remote Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
6,000		09/26/2006	Gilbarco-Veeder Root/TLS-350		No
04	32	01/01/1989	Cathodically Protected Steel	Flexible Plastic	Ball Float Valve
4477	No			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Diesel		12/01/2014	Approved Remote Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
12,000		09/26/2006	Gilbarco-Veeder Root/TLS-350		No
05	32	05/10/1989	Cathodically Protected Steel	Flexible Plastic	Ball Float Valve
4478	No			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Diesel		12/01/2014	Approved Remote Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
9,000		09/26/2006	Gilbarco-Veeder Root/TLS-350		No
06	20	04/01/2001	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4479	No		Double-Walled	Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel			Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
10,000		09/26/2006	Gilbarco-Veeder Root/TLS-350		No
07	20	04/01/2001	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve

4480	No	Double-Walled	Double Walled	Yes
Currently in Use		Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel		Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
5,000	09/26/2006	Gilbarco-Veeder Root/TLS-350		No

Facility Summary in Jefferson County in the City of Cardwell

Location: CARDWELL STORE LLC
770 MT Hwy 2 E
Cardwell, MT 59721-9615 Jefferson

Legacy ID:22-13424

Facility ID: 22656
Last Inspected On: 09/08/2020
Operating Permit Renewal Date: 09/03/2023

Owner Operator Contact: Kipp Huckaba

4062875092

Operator Contact: Kipp Huckaba

4062875092

Owner/Operator: Kipp Huckaba

Kipp Huckaba, UST Class A Operator
Kipp Huckaba, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
01	27	04/01/1994	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve
3193	No			None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		04/10/2014	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	No
9,000		04/10/2014	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
02	27	04/01/1994	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve
3194	No			None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic

Gasoline		04/10/2014	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	No
3,000		04/10/2014	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
03	27	04/01/1994	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve
3195	No			None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Diesel		04/10/2014	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	No
6,000		04/10/2014	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
04	27	04/01/1994	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve
3196	No			None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Diesel		04/10/2014	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	No
6,000		04/10/2014	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No

Facility Summary in Jefferson County in the City of Clancy

Location: CLANCY STORE
10 E Clancy St
Clancy, MT 59634-9560 Jefferson

Legacy ID:22-02898

Facility ID: 22515
Last Inspected On: 08/05/2019
Operating Permit Renewal Date:

Owner Operator Contact:

Operator Contact:

Owner/Operator: Clancy Store LLC

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
02	37	04/26/1984	Bare Steel	Steel	High Level Alarm
3534	No			None	Yes
Temporarily Out of Use			Not Required	Safe Suction	Impressed Current
Gasoline		11/12/2016	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	No
2,000					No
03	28	04/10/1993	Bare Steel	Steel	High Level Alarm
4647	No			None	Yes
Temporarily Out of Use			Not Required	Safe Suction	Impressed Current
Gasoline		11/12/2016	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	No
1,000					No

Facility Summary in Jefferson County in the City of Montana City

Location: MONTANA CITY STORE LLC
1 Jackson Creek Rd
Montana City, MT 59634-9714 Jefferson

Legacy ID:22-01822

Facility ID: 22494
Last Inspected On: 04/16/2019
Operating Permit Renewal Date: 06/01/2022

Owner Operator Contact: Chuck Hunter;Montana City Properties Inc;Montana City Properties Inc **4064430150**

Owner/Operator: Joseph Calnan**Owner/Operator:** Montana City Properties Inc

Shawn McFadden, UST Class A Operator

Shawn McFadden, UST Class B Global Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
05	33	07/01/1988	Cathodically Protected Steel	Flexible Plastic	Flapper Valve
1668	No			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		04/05/2016	Automatic Tank Gauging 0.2	ELLD 0.2	No
4,000		04/12/2016	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
06	33	07/01/1988	Cathodically Protected Steel	Flexible Plastic	Flapper Valve
1669	No			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		04/05/2016	Automatic Tank Gauging 0.2	ELLD 0.2	No
10,000		04/12/2016	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
07	33	07/01/1988	Cathodically Protected Steel	Flexible Plastic	Flapper Valve
1670	No			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		04/05/2016	Automatic Tank Gauging 0.2	ELLD 0.2	No
10,000		04/12/2016	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No

Facility Summary in Jefferson County in the City of Whitehall

Location: GOLDEN SUNLIGHT MINES INC UST
453 MT Hwy 2 E
Whitehall, MT 59759-8637 Jefferson

Legacy ID:22-04689

Facility ID: 22546
Last Inspected On: 10/18/2021
Operating Permit Renewal Date: 12/17/2021

Owner Operator Contact: Golden Sunlight Mines Inc

Operator Contact: Darrell Scharf;Debby Horne;Jerry Muething;Rick Henderson

4062872018;4062872035

Owner/Operator: Golden Sunlight Mines Inc

Darrell Scharf, UST Class A Operator
Dave Lawrence, UST Class B Global Operator
Debby Horne, UST Class A Operator
Donald Pippin, UST Class B Global Operator
George Clements, UST Class B Global Operator
Jerry Muething, UST Class A Operator
Jerry Muething, UST Class B Operator
John Clements, UST Class B Global Operator
John Perigo, UST Class B Global Operator
Joseph Dillon, UST Class B Global Operator
Ray Panisko, UST Class B Global Operator
Rick Henderson, UST Class A Operator
Seth Slatter, UST Class B Operator
Travis Nielsen, UST Class B Global Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
06	13	06/12/2008	Unknown		
5218	Yes	08/21/2018			No
Currently in Use					
Oil Substance			Deferred		No
1,000					Yes

07	13	06/12/2008	Unknown	Flexible Plastic	
5219	Yes	08/21/2018		Double Walled	No
Currently in Use		06/23/2009	Continuous Interstitial Monitoring	Pressurized	
Oil Substance			Deferred	Continuous Interstitial Monitoring	No
1,000					Yes
08	12	06/12/2009	Unknown	Flexible Plastic	
5220	Yes	08/21/2018		Double Walled	No
Currently in Use		06/23/2009	Continuous Interstitial Monitoring	Pressurized	
Oil Substance			Deferred	Continuous Interstitial Monitoring	No
1,500					Yes
09	13	06/12/2008	Unknown	Steel - Terminal Piping	
5221	Yes	08/21/2018		Double Walled	No
Currently in Use		06/23/2009	Continuous Interstitial Monitoring	Pressurized	
Oil Substance			Deferred	Continuous Interstitial Monitoring	No
2,000					Yes
10	13	06/12/2008	Unknown	Flexible Plastic	
5222	Yes	08/21/2018		Double Walled	No
Currently in Use		06/23/2009	Continuous Interstitial Monitoring	Pressurized	
Oil Substance			Deferred	Continuous Interstitial Monitoring	No
2,000					Yes

Facility Summary in Jefferson County in the City of Whitehall

Location: THRIFTWAY SUPER STOP
203 W Legion Ave
Whitehall, MT 59759 Jefferson

Legacy ID:22-00980

Facility ID: 22479
Last Inspected On: 06/27/2019
Operating Permit Renewal Date: 02/27/2022

Owner Operator Contact: Phyllis Norman;Normco Inc;Sutey Oil Co Inc

4062853710;4064942305

Owner/Operator: Sutey Oil Co Inc

Timothy Mulligan, UST Class A Operator

Timothy Mulligan, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
04	28	10/15/1993	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
527	No			None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		04/11/2018	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	No
10,000		04/11/2018	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
05	28	10/15/1993	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
528	No			None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Diesel		04/11/2018	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	No
6,000		04/11/2018	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
06	28	10/15/1993	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
529	No			None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		04/11/2018	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	No
6,000		04/11/2018	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No

Facility Summary in Jefferson County in the City of Whitehall

Location: TOWN PUMP INC WHITEHALL
 417 N Whitehall St
 Whitehall, MT 59759 Jefferson

Legacy ID:22-03645

Facility ID: 22528
Last Inspected On: 07/01/2021
Operating Permit Renewal Date: 10/14/2024

Owner Operator Contact: Don Edmisten;Town Pump Inc Whitehall PTRCB 1229 **4064976948**

Operator Contact: Trent Biggers

Owner/Operator: Whitehall 1 Town Pump LLC

Trent Biggers, UST Class A Operator
 Trent Biggers, UST Class B Global Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
01	53	01/01/1968	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve
2476	No		Lined Interior/Impressed Current	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		07/14/2018	Approved Remote Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Statistical Inventory Reconciliation	No
10,000			Gilbarco-Veeder Root/TLS-350		No
02	53	01/01/1968	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve
2477	No		Lined Interior/Impressed Current	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Diesel		07/14/2018	Approved Remote Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Statistical Inventory Reconciliation	No
6,000			Gilbarco-Veeder Root/TLS-350		No
03	43	01/01/1978	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve
2478	No		Lined Interior/Impressed Current	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current

Gasoline		07/14/2018	Approved Remote Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Statistical Inventory Reconciliation	No
6,000			Gilbarco-Veeder Root/TLS-350		No
04	45	01/01/1976	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve
2479	No		Lined Interior/Impressed Current	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		07/14/2018	Approved Remote Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Statistical Inventory Reconciliation	No
12,000			Gilbarco-Veeder Root/TLS-350		No
05	43	01/01/1978	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve
2480	No		Lined Interior/Impressed Current	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		07/14/2018	Approved Remote Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Statistical Inventory Reconciliation	No
6,000			Gilbarco-Veeder Root/TLS-350		No
06	43	01/01/1978	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve
2481	No		Lined Interior/Impressed Current	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		07/14/2018	Approved Remote Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Statistical Inventory Reconciliation	No
12,000			Gilbarco-Veeder Root/TLS-350		No
07	35	01/01/1986	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve
2482	No			None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		07/14/2018	Approved Remote Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Statistical Inventory Reconciliation	No

6,000			Gilbarco-Veeder Root/TLS-350		No
08	34	01/01/1987	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve
2483	No			Double Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Diesel		07/14/2018	Approved Remote Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
12,000			Gilbarco-Veeder Root/TLS-350		No
09	34	01/01/1987	Cathodically Protected Steel	Flexible Plastic	Flapper Valve
2484	No			Double Walled	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Diesel		07/14/2018	Approved Remote Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
12,000			Gilbarco-Veeder Root/TLS-350		No
10	21	05/01/2000	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4198	No	07/20/2018	Double-Walled	Double Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Non-corrodible
Diesel		05/04/2012	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
5,000			Gilbarco-Veeder Root/TLS-350		No
11	21	05/01/2000	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4199	No	07/20/2018	Double-Walled	Double Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Non-corrodible
Diesel		05/04/2012	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No

10,000

Gilbarco-Veeder Root/TLS-350

No
