

**Facility Summary in Jefferson County in the City of Boulder**

**Location:** HARLOWS SCHOOL BUS SERVICE INC BOULDER  
101 Main St  
Boulder, MT 59632 Jefferson

System Facility ID:22-12378

**Facility Code:** 22635  
**Last Inspected On:** 11/26/2025  
**Operating Permit Renewal Date:** 11/26/2028

**Note: Inspection is due 90 days before the Operating Permit Renewal Date.**

**Owner Operator Contact:** HJJ Properties LLC (701) 224-1767 jeremy.hageness@goharlows.com

**Operator Contact:** Hugh Taylor;Sandra Hays;Wesley Tangen (406) 225-3344;(406) 239-8845;(406) 293-8845 fireater71@hotmail.com;sandra.hays@goharlows.com

**Owner/Operator:** HJJ Properties LLC (701) 224-1767 jeremy.hageness@goharlows.com

Hugh Taylor, UST Class A Operator  
Hugh Taylor, UST Class B Operator  
Sandra Hays, UST Class A Operator  
Sandra Hays, UST Class B Operator  
Wesley Tangen, UST Class A Operator  
Wesley Tangen, UST Class B Operator

fireater71@hotmail.com  
fireater71@hotmail.com  
sandra.hays@goharlows.com  
sandra.hays@goharlows.com

<b>Tank Code</b>	06	<b>Tank Age</b>	35	<b>Tank Installed Date</b>	10/01/1991	<b>Tank Material</b>	Cathodically Protected Steel	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	High Level Alarm
<b>Tag Number</b>	2710	<b>Spill Test Date</b>		<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	None	<b>AST</b>	No
<b>Tank Status</b>	Temporarily Out of Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Not Required	<b>Piping Type</b>	Safe Suction	<b>CP Met Types</b>	Galvanic
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>	10/13/2025	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.1;Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	Not Listed	<b>Vapor Recovery</b>	No
<b>Capacity</b>	2000	<b>ATG Test Date</b>		<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>				<b>ATG Type</b>					
<b>Tank Code</b>	07	<b>Tank Age</b>	35	<b>Tank Installed Date</b>	10/01/1991	<b>Tank Material</b>	Cathodically Protected Steel	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	High Level Alarm
<b>Tag Number</b>	2711	<b>Spill Test Date</b>		<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	None	<b>AST</b>	No
<b>Tank Status</b>	Temporarily Out of Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Not Required	<b>Piping Type</b>	Safe Suction	<b>CP Met Types</b>	Galvanic
<b>Product</b>	Diesel	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>	10/13/2025	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.1;Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	Not Listed	<b>Vapor Recovery</b>	No

<b>Capacity</b>	2000	<b>ATG Test Date</b>		<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>				<b>ATG Type</b>					

**Facility Summary in Jefferson County in the City of Boulder**

**Location:** TOWN PUMP INC BOULDER  
703 N Main  
Boulder, MT 59632 Jefferson

System Facility ID:22-08673

**Facility Code:** 22598  
**Last Inspected On:** 04/30/2025  
**Operating Permit Renewal Date:** 08/16/2028

**Note: Inspection is due 90 days before the Operating Permit Renewal Date.**

**Owner Operator Contact:** Boulder 1 Town Pump LLC

**(406) 497-6700**

**environmental@townpump.com**

**Operator Contact:** Trent Biggers

**Trentb@townpump.com**

**Owner/Operator:** Boulder 1 Town Pump LLC

**(406) 497-6700**

**environmental@townpump.com**

Trent Biggers, UST Class A Operator

Trentb@townpump.com

Trent Biggers, UST Class B Global Operator

Trentb@townpump.com

<b>Tank Code</b>	08	<b>Tank Age</b>	4	<b>Tank Installed Date</b>	05/25/2022	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	6058	<b>Spill Test Date</b>	06/11/2024	<b>Piping Installed Date</b>	05/25/2022	<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	06/11/2024	<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Diesel	<b>PLLD Test Date</b>	04/30/2025	<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Continuous Interstitial Monitoring	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	No
<b>Capacity</b>	30000	<b>ATG Test Date</b>	04/30/2025	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>	Statistical Inventory Reconciliation	<b>Secondary Pipe Detection</b>	Statistical Inventory Reconciliation	<b>Energy Act</b>	Yes
		<b>Overfill Test Date</b>	06/11/2024			<b>ATG Type</b>					
<b>Tank Code</b>	09	<b>Tank Age</b>	4	<b>Tank Installed Date</b>	05/25/2022	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	6059	<b>Spill Test Date</b>	06/11/2024	<b>Piping Installed Date</b>	05/25/2022	<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	06/11/2024	<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Diesel	<b>PLLD Test Date</b>	04/30/2025	<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Continuous Interstitial Monitoring	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	No
<b>Capacity</b>	8000	<b>ATG Test Date</b>	04/30/2025	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>	Statistical Inventory Reconciliation	<b>Secondary Pipe Detection</b>	Statistical Inventory Reconciliation	<b>Energy Act</b>	Yes
		<b>Overfill Test Date</b>	06/11/2024			<b>ATG Type</b>					
<b>Tank Code</b>	10	<b>Tank Age</b>	4	<b>Tank Installed Date</b>	05/25/2022	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Flapper Valve

<b>Tag Number</b>	6060	<b>Spill Test Date</b>	06/11/2024	<b>Piping Installed Date</b>	05/25/2022	<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	06/11/2024	<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Diesel, Dyed	<b>PLLD Test Date</b>	04/30/2025	<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Continuous Interstitial Monitoring	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	No
<b>Capacity</b>	12000	<b>ATG Test Date</b>	04/30/2025	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>	Statistical Inventory Reconciliation	<b>Secondary Pipe Detection</b>	Statistical Inventory Reconciliation	<b>Energy Act</b>	Yes
		<b>Overfill Test Date</b>	06/11/2024			<b>ATG Type</b>					
<b>Tank Code</b>	11	<b>Tank Age</b>	4	<b>Tank Installed Date</b>	05/25/2022	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	6061	<b>Spill Test Date</b>	06/11/2024	<b>Piping Installed Date</b>	05/25/2022	<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	06/11/2024	<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	
<b>Product</b>	DEF (Not Regulated)	<b>PLLD Test Date</b>	04/30/2025	<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Statistical Inventory Reconciliation	<b>Primary Pipe Detection</b>	Statistical Inventory Reconciliation	<b>Vapor Recovery</b>	No
<b>Capacity</b>	10000	<b>ATG Test Date</b>	04/30/2025	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>	Continuous Interstitial Monitoring	<b>Secondary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	06/11/2024			<b>ATG Type</b>					
<b>Tank Code</b>	12	<b>Tank Age</b>	1	<b>Tank Installed Date</b>	01/15/2025	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	6062	<b>Spill Test Date</b>	06/11/2024	<b>Piping Installed Date</b>	01/15/2025	<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	06/11/2024	<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Diesel	<b>PLLD Test Date</b>	04/30/2025	<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Continuous Interstitial Monitoring	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	No
<b>Capacity</b>	15000	<b>ATG Test Date</b>	04/30/2025	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>	Statistical Inventory Reconciliation	<b>Secondary Pipe Detection</b>	Statistical Inventory Reconciliation	<b>Energy Act</b>	Yes
		<b>Overfill Test Date</b>	06/11/2024			<b>ATG Type</b>					
<b>Tank Code</b>	13	<b>Tank Age</b>	1	<b>Tank Installed Date</b>	01/15/2025	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	6063	<b>Spill Test Date</b>	06/11/2024	<b>Piping Installed Date</b>	01/15/2025	<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	06/11/2024	<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Gasoline, E10	<b>PLLD Test Date</b>	04/30/2025	<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Continuous Interstitial Monitoring	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	Yes

<b>Capacity</b>	15000	<b>ATG Test Date</b>	04/30/2025	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>	Statistical Inventory Reconciliation	<b>Secondary Pipe Detection</b>	Statistical Inventory Reconciliation	<b>Energy Act</b>	Yes
		<b>Overfill Test Date</b>	06/11/2024			<b>ATG Type</b>					
<b>Tank Code</b>	14	<b>Tank Age</b>	1	<b>Tank Installed Date</b>	01/15/2025	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	6064	<b>Spill Test Date</b>	06/11/2024	<b>Piping Installed Date</b>	01/15/2025	<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	06/11/2024	<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>	04/30/2025	<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Continuous Interstitial Monitoring	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	Yes
<b>Capacity</b>	24000	<b>ATG Test Date</b>	04/30/2025	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>	Statistical Inventory Reconciliation	<b>Secondary Pipe Detection</b>	Statistical Inventory Reconciliation	<b>Energy Act</b>	Yes
		<b>Overfill Test Date</b>	06/11/2024			<b>ATG Type</b>					
<b>Tank Code</b>	15	<b>Tank Age</b>	1	<b>Tank Installed Date</b>	01/15/2025	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	6065	<b>Spill Test Date</b>	06/11/2024	<b>Piping Installed Date</b>	01/15/2025	<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	06/11/2024	<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Continuous Interstitial Monitoring	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	Yes
<b>Capacity</b>	6000	<b>ATG Test Date</b>	04/30/2025	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>	Statistical Inventory Reconciliation	<b>Secondary Pipe Detection</b>	Statistical Inventory Reconciliation	<b>Energy Act</b>	Yes
		<b>Overfill Test Date</b>	06/11/2024			<b>ATG Type</b>					

**Facility Summary in Jefferson County in the City of Cardwell**

**Location:** CARDWELL GENERAL STORE and CAMPGROUND  
770 MT Hwy 2 E  
Cardwell, MT 59721-9615 Jefferson

System Facility ID:22-13424

**Facility Code:** 22656  
**Last Inspected On:** 06/01/2023  
**Operating Permit Renewal Date:** 09/03/2026

**Note: Inspection is due 90 days before the Operating Permit Renewal Date.**

**Owner Operator Contact:** CARDWELL CAMPGROUND LLC (510) 754-8233

**Operator Contact:** Greg Conner;CARDWELL CAMPGROUND LLC (510) 754-8233 Greg@cardwellrv.com

**Owner/Operator:** CARDWELL CAMPGROUND LLC (510) 754-8233

Greg Conner, UST Class A Operator  
Greg Conner, UST Class B Operator

Greg@cardwellrv.com  
Greg@cardwellrv.com

<b>Tank Code</b>	01	<b>Tank Age</b>	32	<b>Tank Installed Date</b>	04/01/1994	<b>Tank Material</b>	Cathodically Protected Steel	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	3193	<b>Spill Test Date</b>	06/01/2023	<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	Single Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>	03/03/2026	<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Mechanical Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Galvanic
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>	06/01/2023	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	MLLD Line Tightness Testing	<b>Vapor Recovery</b>	No
<b>Capacity</b>	9000	<b>ATG Test Date</b>	03/03/2026	<b>Line Tightness Test Date</b>	03/05/2026	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	06/01/2023			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
<b>Tank Code</b>	02	<b>Tank Age</b>	32	<b>Tank Installed Date</b>	04/01/1994	<b>Tank Material</b>	Cathodically Protected Steel	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	3194	<b>Spill Test Date</b>	06/01/2023	<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	Single Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>	03/03/2026	<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Mechanical Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Galvanic
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>	06/01/2023	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	MLLD Line Tightness Testing	<b>Vapor Recovery</b>	No
<b>Capacity</b>	3000	<b>ATG Test Date</b>	03/03/2026	<b>Line Tightness Test Date</b>	03/05/2026	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	06/01/2023			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
<b>Tank Code</b>	03	<b>Tank Age</b>	32	<b>Tank Installed Date</b>	04/01/1994	<b>Tank Material</b>	Cathodically Protected Steel	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	Flapper Valve

<b>Tag Number</b>	3195	<b>Spill Test Date</b>	06/01/2023	<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	Single Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>	03/03/2026	<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Mechanical Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Galvanic
<b>Product</b>	Diesel	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>	06/01/2023	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	MLLD Line Tightness Testing	<b>Vapor Recovery</b>	No
<b>Capacity</b>	6000	<b>ATG Test Date</b>	03/03/2026	<b>Line Tightness Test Date</b>	03/05/2026	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	06/01/2023			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
<b>Tank Code</b>	04	<b>Tank Age</b>	32	<b>Tank Installed Date</b>	04/01/1994	<b>Tank Material</b>	Cathodically Protected Steel	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	3196	<b>Spill Test Date</b>	06/01/2023	<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	Single Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>	03/03/2026	<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Mechanical Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Galvanic
<b>Product</b>	Diesel	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>	06/01/2023	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	MLLD Line Tightness Testing	<b>Vapor Recovery</b>	No
<b>Capacity</b>	6000	<b>ATG Test Date</b>	03/03/2026	<b>Line Tightness Test Date</b>	03/05/2026	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	06/01/2023			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

**Facility Summary in Jefferson County in the City of Clancy**

**Location:** CLANCY STORE  
10 E Clancy St  
Clancy, MT 59634-9560 Jefferson

System Facility ID:22-02898

**Facility Code:** 22515  
**Last Inspected On:** 08/05/2019  
**Operating Permit Renewal Date:** 08/05/2022

**Note: Inspection is due 90 days before the Operating Permit Renewal Date.**

**Owner Operator Contact:** Clancy Store LLC

**(406) 465-0540**

**Operator Contact:**

**Owner/Operator:** Clancy Store LLC

**(406) 465-0540**

<b>Tank Code</b>	02	<b>Tank Age</b>	42	<b>Tank Installed Date</b>	04/26/1984	<b>Tank Material</b>	Bare Steel	<b>Piping Material</b>	Steel	<b>Overfill Types</b>	High Level Alarm
<b>Tag Number</b>	3534	<b>Spill Test Date</b>		<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	None	<b>AST</b>	No
<b>Tank Status</b>	Temporarily Out of Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Not Required	<b>Piping Type</b>	Safe Suction	<b>CP Met Types</b>	Impressed Current
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>	08/05/2019	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	MLLD Line Tightness Testing	<b>Vapor Recovery</b>	No
<b>Capacity</b>	2000	<b>ATG Test Date</b>		<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>				<b>ATG Type</b>					
<b>Tank Code</b>	03	<b>Tank Age</b>	33	<b>Tank Installed Date</b>	04/10/1993	<b>Tank Material</b>	Bare Steel	<b>Piping Material</b>	Steel	<b>Overfill Types</b>	High Level Alarm
<b>Tag Number</b>	4647	<b>Spill Test Date</b>		<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	None	<b>AST</b>	No
<b>Tank Status</b>	Temporarily Out of Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Not Required	<b>Piping Type</b>	Safe Suction	<b>CP Met Types</b>	Impressed Current
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>	08/05/2019	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	MLLD Line Tightness Testing	<b>Vapor Recovery</b>	No
<b>Capacity</b>	1000	<b>ATG Test Date</b>		<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>				<b>ATG Type</b>					

**Facility Summary in Jefferson County in the City of Montana City**

**Location:** MONTANA CITY STORE LLC  
1 Jackson Creek Rd  
Montana City, MT 59634-9714 Jefferson

System Facility ID:22-01822

**Facility Code:** 22494  
**Last Inspected On:** 05/09/2025  
**Operating Permit Renewal Date:** 06/01/2028

**Note: Inspection is due 90 days before the Operating Permit Renewal Date.**

**Owner Operator Contact:** Montana City Properties Inc (406) 443-0150 Davidhunter@mt.net

**Operator Contact:** Heather Russell;Montana City Properties Inc;Shawn McFadden (406) 443-0150 heatherrussell404@gmail.com;Davidhunter@mt.net;mtcitystore@outlook.com

**Owner/Operator:** Montana City Properties Inc (406) 443-0150 Davidhunter@mt.net  
 Heather Russell, UST Class A Operator Davidhunter@mt.net  
 Heather Russell, UST Class B Global Operator Davidhunter@mt.net  
 Shawn McFadden, UST Class A Operator mtcitystore@outlook.com  
 Shawn McFadden, UST Class B Global Operator mtcitystore@outlook.com

<b>Tank Code</b>	05	<b>Tank Age</b>	38	<b>Tank Installed Date</b>	07/01/1988	<b>Tank Material</b>	Cathodically Protected Steel	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	1668	<b>Spill Test Date</b>	05/15/2024	<b>Piping Installed Date</b>	06/06/2005	<b>Tank Construction</b>		<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Galvanic
<b>Product</b>	Diesel	<b>PLLD Test Date</b>	04/23/2025	<b>Tank/Piping CP Test Date</b>	04/23/2025	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	3-Year Line Tightness Test	<b>Vapor Recovery</b>	No
<b>Capacity</b>	4000	<b>ATG Test Date</b>	04/23/2025	<b>Line Tightness Test Date</b>	08/18/2025	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>	ELLD 0.2	<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	05/15/2024			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
<b>Tank Code</b>	06	<b>Tank Age</b>	38	<b>Tank Installed Date</b>	07/01/1988	<b>Tank Material</b>	Cathodically Protected Steel	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	1669	<b>Spill Test Date</b>	05/15/2024	<b>Piping Installed Date</b>	06/06/2005	<b>Tank Construction</b>		<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Galvanic
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>	04/23/2025	<b>Tank/Piping CP Test Date</b>	04/23/2025	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	3-Year Line Tightness Test	<b>Vapor Recovery</b>	No
<b>Capacity</b>	10000	<b>ATG Test Date</b>	04/23/2025	<b>Line Tightness Test Date</b>	08/18/2025	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>	ELLD 0.2	<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	05/15/2024			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

<b>Tank Code</b>	07	<b>Tank Age</b>	38	<b>Tank Installed Date</b>	07/01/1988	<b>Tank Material</b>	Cathodically Protected Steel	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	1670	<b>Spill Test Date</b>	05/15/2024	<b>Piping Installed Date</b>	06/06/2005	<b>Tank Construction</b>		<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Galvanic
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>	04/23/2025	<b>Tank/Piping CP Test Date</b>	04/23/2025	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	3-Year Line Tightness Test	<b>Vapor Recovery</b>	No
<b>Capacity</b>	10000	<b>ATG Test Date</b>	04/23/2025	<b>Line Tightness Test Date</b>	08/18/2025	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>	ELLD 0.2	<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	05/15/2024			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

**Facility Summary in Jefferson County in the City of Whitehall**

**Location:** GOLDEN SUNLIGHT MINES INC UST  
453 MT Hwy 2 E  
Whitehall, MT 59759-8637 Jefferson

System Facility ID:22-04689

**Facility Code:** 22546  
**Last Inspected On:** 06/20/2024  
**Operating Permit Renewal Date:** 12/17/2027

**Note: Inspection is due 90 days before the Operating Permit Renewal Date.**

**Owner Operator Contact:** Golden Sunlight Mines Inc (406) 287-3257

**Operator Contact:** Charles Buus;Darrell Scharf;Debby Horne;Jerry Muething;Rick Henderson (406) 287-2007;(406) 287-2018;(406) 287-2035;(406) 287-3257 cbuus@barrick.com;jmuething@barrick.com

**Owner/Operator:** Golden Sunlight Mines Inc (406) 287-3257

Charles Buus, UST Class A Operator	cbuus@barrick.com
Charles Buus, UST Class B Operator	cbuus@barrick.com
Darrell Scharf, UST Class A Operator	
Dave Lawrence, UST Class B Global Operator	
Debby Horne, UST Class A Operator	
Donald Pippin, UST Class B Global Operator	
George Clements, UST Class B Global Operator	
Jerry Muething, UST Class A Operator	jmuething@barrick.com
Jerry Muething, UST Class B Operator	jmuething@barrick.com
John Clements, UST Class B Global Operator	
John Perigo, UST Class B Global Operator	
Joseph Dillon, UST Class B Global Operator	
Ray Panisko, UST Class B Global Operator	
Rick Henderson, UST Class A Operator	
Seth Slatter, UST Class B Operator	sslatter@barrick.com
Travis Nielsen, UST Class B Global Operator	

<b>Tank Code</b>	06	<b>Tank Age</b>	18	<b>Tank Installed Date</b>	06/12/2008	<b>Tank Material</b>	Unknown	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	
<b>Tag Number</b>	5218	<b>Spill Test Date</b>		<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	Double Walled	<b>AST</b>	Yes
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Continuous Interstitial Monitoring	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	
<b>Product</b>	Oil, Motor	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>		<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	No
<b>Capacity</b>	1000	<b>ATG Test Date</b>	12/23/2025	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No

		<b>Overfill Test Date</b>				<b>ATG Type</b>					
<b>Tank Code</b>	07	<b>Tank Age</b>	18	<b>Tank Installed Date</b>	06/12/2008	<b>Tank Material</b>	Unknown	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	
<b>Tag Number</b>	5219	<b>Spill Test Date</b>		<b>Piping Installed Date</b>	06/23/2009	<b>Tank Construction</b>		<b>Piping Construction</b>	Double Walled	<b>AST</b>	Yes
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Continuous Interstitial Monitoring	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	
<b>Product</b>	Oil, Motor	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>		<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	No
<b>Capacity</b>	1000	<b>ATG Test Date</b>	12/23/2025	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>				<b>ATG Type</b>					
<b>Tank Code</b>	08	<b>Tank Age</b>	17	<b>Tank Installed Date</b>	06/12/2009	<b>Tank Material</b>	Unknown	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	
<b>Tag Number</b>	5220	<b>Spill Test Date</b>		<b>Piping Installed Date</b>	06/23/2009	<b>Tank Construction</b>		<b>Piping Construction</b>	Double Walled	<b>AST</b>	Yes
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Continuous Interstitial Monitoring	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	
<b>Product</b>	Oil, Motor	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>		<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	No
<b>Capacity</b>	1500	<b>ATG Test Date</b>	12/23/2025	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>				<b>ATG Type</b>					
<b>Tank Code</b>	09	<b>Tank Age</b>	18	<b>Tank Installed Date</b>	06/12/2008	<b>Tank Material</b>	Unknown	<b>Piping Material</b>	Steel - Terminal Piping	<b>Overfill Types</b>	
<b>Tag Number</b>	5221	<b>Spill Test Date</b>		<b>Piping Installed Date</b>	06/23/2009	<b>Tank Construction</b>		<b>Piping Construction</b>	Double Walled	<b>AST</b>	Yes
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Continuous Interstitial Monitoring	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	
<b>Product</b>	Oil, Waste	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>		<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	No
<b>Capacity</b>	2000	<b>ATG Test Date</b>	12/23/2025	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>				<b>ATG Type</b>					
<b>Tank Code</b>	10	<b>Tank Age</b>	18	<b>Tank Installed Date</b>	06/12/2008	<b>Tank Material</b>	Unknown	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	
<b>Tag Number</b>	5222	<b>Spill Test Date</b>		<b>Piping Installed Date</b>	06/23/2009	<b>Tank Construction</b>		<b>Piping Construction</b>	Double Walled	<b>AST</b>	Yes
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Continuous Interstitial Monitoring	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	

<b>Product</b>	Oil, Motor	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>		<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	No
<b>Capacity</b>	2000	<b>ATG Test Date</b>	12/23/2025	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>				<b>ATG Type</b>					

## Facility Summary in Jefferson County in the City of Whitehall

**Location:** THRIFTWAY SUPER STOP 17  
203 W Legion Ave  
Whitehall, MT 59759 Jefferson

System Facility ID:22-00980

**Facility Code:** 22479  
**Last Inspected On:** 10/30/2024  
**Operating Permit Renewal Date:** 02/27/2028

**Note: Inspection is due 90 days before the Operating Permit Renewal Date.**

<b>Owner Operator Contact:</b> Sutey Oil Co Inc	(406) 494-2305	ldsutey66@thriftwayss.com
<b>Operator Contact:</b> Louie Sutey;Sutey Oil Co Inc;Louis Sutey;Marlys Weyer;Timothy Mulligan	(406) 287-3787;(406) 491-5808;(406) 491-5808;(406) 494-2305	ldsutey66@thriftwayss.com;ldsutey66@thriftwayss.com;ldsutey66@thriftwayss.com;thriftway17@thriftwayss.com;Tim.cornerstone@gmail.com

<b>Owner/Operator:</b> Sutey Oil Co Inc	(406) 494-2305	ldsutey66@thriftwayss.com
Louie Sutey, UST Class A Operator Louie Sutey, UST Class B Operator Louis Sutey, UST Class A Operator Louis Sutey, UST Class B Global Operator Marlys Weyer, UST Class A Operator Marlys Weyer, UST Class B Operator Timothy Mulligan, UST Class A Operator Timothy Mulligan, UST Class B Operator		ldsutey66@thriftwayss.com ldsutey66@thriftwayss.com ldsutey66@thriftwayss.com ldsutey66@thriftwayss.com thriftway17@thriftwayss.com thriftway17@thriftwayss.com Tim.cornerstone@gmail.com Tim.cornerstone@gmail.com

<b>Tank Code</b>	04	<b>Tank Age</b>	33	<b>Tank Installed Date</b>	10/15/1993	<b>Tank Material</b>	Cathodically Protected Steel	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	527	<b>Spill Test Date</b>	10/30/2024	<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	Single Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>	04/11/2019	<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Galvanic
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>	03/03/2026	<b>Tank/Piping CP Test Date</b>	10/30/2024	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	ELLD 0.2	<b>Vapor Recovery</b>	No
<b>Capacity</b>	10000	<b>ATG Test Date</b>	03/03/2026	<b>Line Tightness Test Date</b>	04/11/2019	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	10/30/2024			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
<b>Tank Code</b>	05	<b>Tank Age</b>	33	<b>Tank Installed Date</b>	10/15/1993	<b>Tank Material</b>	Cathodically Protected Steel	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	528	<b>Spill Test Date</b>	10/30/2024	<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	Single Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>	04/11/2019	<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Galvanic
<b>Product</b>	Diesel	<b>PLLD Test Date</b>	03/03/2026	<b>Tank/Piping CP Test Date</b>	10/30/2024	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	ELLD 0.2	<b>Vapor Recovery</b>	No

<b>Capacity</b>	6000	<b>ATG Test Date</b>	03/03/2026	<b>Line Tightness Test Date</b>	04/11/2019	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	10/30/2024			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
<b>Tank Code</b>	06	<b>Tank Age</b>	33	<b>Tank Installed Date</b>	10/15/1993	<b>Tank Material</b>	Cathodically Protected Steel	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	529	<b>Spill Test Date</b>	10/30/2024	<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	Single Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>	04/11/2019	<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Galvanic
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>	03/03/2026	<b>Tank/Piping CP Test Date</b>	10/30/2024	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	ELLD 0.2	<b>Vapor Recovery</b>	No
<b>Capacity</b>	6000	<b>ATG Test Date</b>	03/03/2026	<b>Line Tightness Test Date</b>	04/11/2019	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	10/30/2024			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

**Facility Summary in Jefferson County in the City of Whitehall**

**Location:** TOWN PUMP INC WHITEHALL  
417 N Whitehall St  
Whitehall, MT 59759 Jefferson

System Facility ID:22-03645

**Facility Code:** 22528  
**Last Inspected On:** 04/30/2025  
**Operating Permit Renewal Date:** 08/16/2028

**Note: Inspection is due 90 days before the Operating Permit Renewal Date.**

**Owner Operator Contact:** Whitehall 1 Town Pump LLC

**(406) 497-6700**

**environmental@townpump.com**

**Operator Contact:** Trent Biggers

**Trentb@townpump.com**

**Owner/Operator:** Whitehall 1 Town Pump LLC

**(406) 497-6700**

**environmental@townpump.com**

Trent Biggers, UST Class A Operator

Trentb@townpump.com

Trent Biggers, UST Class B Global Operator

Trentb@townpump.com

<b>Tank Code</b>	13	<b>Tank Age</b>	3	<b>Tank Installed Date</b>	05/23/2023	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	
<b>Tag Number</b>	6106	<b>Spill Test Date</b>	05/08/2024	<b>Piping Installed Date</b>	05/23/2023	<b>Tank Construction</b>		<b>Piping Construction</b>		<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	05/08/2024	<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	
<b>Product</b>	Diesel	<b>PLLD Test Date</b>	04/30/2025	<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Continuous Interstitial Monitoring	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	No
<b>Capacity</b>	22000	<b>ATG Test Date</b>	04/30/2025	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Secondary Pipe Detection</b>	ELLD 0.2	<b>Energy Act</b>	Yes
		<b>Overfill Test Date</b>	05/08/2024			<b>ATG Type</b>					
<b>Tank Code</b>	14	<b>Tank Age</b>	3	<b>Tank Installed Date</b>	05/23/2023	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	
<b>Tag Number</b>	6107	<b>Spill Test Date</b>	05/08/2024	<b>Piping Installed Date</b>	05/23/2023	<b>Tank Construction</b>		<b>Piping Construction</b>		<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	05/08/2024	<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>	04/30/2025	<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Continuous Interstitial Monitoring	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	Yes
<b>Capacity</b>	8000	<b>ATG Test Date</b>	04/30/2025	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Secondary Pipe Detection</b>	ELLD 0.2	<b>Energy Act</b>	Yes
		<b>Overfill Test Date</b>	05/08/2024			<b>ATG Type</b>					
<b>Tank Code</b>	15	<b>Tank Age</b>	3	<b>Tank Installed Date</b>	05/23/2023	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	

<b>Tag Number</b>	6108	<b>Spill Test Date</b>	05/08/2024	<b>Piping Installed Date</b>	05/23/2023	<b>Tank Construction</b>		<b>Piping Construction</b>		<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	05/08/2024	<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>	04/30/2025	<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Continuous Interstitial Monitoring	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	Yes
<b>Capacity</b>	30000	<b>ATG Test Date</b>	04/30/2025	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Secondary Pipe Detection</b>	ELLD 0.2	<b>Energy Act</b>	Yes
		<b>Overfill Test Date</b>	05/08/2024			<b>ATG Type</b>					
<b>Tank Code</b>	16	<b>Tank Age</b>	3	<b>Tank Installed Date</b>	12/14/2023	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	
<b>Tag Number</b>	6109	<b>Spill Test Date</b>	05/08/2024	<b>Piping Installed Date</b>	12/14/2023	<b>Tank Construction</b>		<b>Piping Construction</b>		<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	05/08/2024	<b>Catastrophic L.D Type 3.0</b>		<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	
<b>Product</b>	Diesel, Dyed	<b>PLLD Test Date</b>	04/30/2025	<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>		<b>Primary Pipe Detection</b>		<b>Vapor Recovery</b>	No
<b>Capacity</b>	9000	<b>ATG Test Date</b>	04/30/2025	<b>Line Tightness Test Date</b>	09/06/2023	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	Yes
		<b>Overfill Test Date</b>	05/08/2024			<b>ATG Type</b>					
<b>Tank Code</b>	17	<b>Tank Age</b>	3	<b>Tank Installed Date</b>	05/23/2023	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	
<b>Tag Number</b>	6110	<b>Spill Test Date</b>	05/08/2024	<b>Piping Installed Date</b>	05/23/2023	<b>Tank Construction</b>		<b>Piping Construction</b>		<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	05/08/2024	<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>	04/30/2025	<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Continuous Interstitial Monitoring	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	Yes
<b>Capacity</b>	15000	<b>ATG Test Date</b>	04/30/2025	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Secondary Pipe Detection</b>	ELLD 0.2	<b>Energy Act</b>	Yes
		<b>Overfill Test Date</b>	05/08/2024			<b>ATG Type</b>					
<b>Tank Code</b>	18	<b>Tank Age</b>	3	<b>Tank Installed Date</b>	12/14/2023	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	
<b>Tag Number</b>	6111	<b>Spill Test Date</b>	05/08/2024	<b>Piping Installed Date</b>	12/14/2023	<b>Tank Construction</b>		<b>Piping Construction</b>		<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	05/08/2024	<b>Catastrophic L.D Type 3.0</b>		<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	
<b>Product</b>	Diesel	<b>PLLD Test Date</b>	04/30/2025	<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>		<b>Primary Pipe Detection</b>		<b>Vapor Recovery</b>	No
<b>Capacity</b>	6000	<b>ATG Test Date</b>	04/30/2025	<b>Line Tightness Test Date</b>	09/06/2023	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	Yes
		<b>Overfill Test Date</b>	05/08/2024			<b>ATG Type</b>					

<b>Tank Code</b>	19	<b>Tank Age</b>	3	<b>Tank Installed Date</b>	12/14/2023	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	
<b>Tag Number</b>	6112	<b>Spill Test Date</b>	05/08/2024	<b>Piping Installed Date</b>	12/14/2023	<b>Tank Construction</b>		<b>Piping Construction</b>		<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	05/08/2024	<b>Catastrophic L.D Type 3.0</b>		<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	
<b>Product</b>	Diesel	<b>PLLD Test Date</b>	04/30/2025	<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>		<b>Primary Pipe Detection</b>		<b>Vapor Recovery</b>	No
<b>Capacity</b>	30000	<b>ATG Test Date</b>	04/30/2025	<b>Line Tightness Test Date</b>	09/06/2023	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	Yes
		<b>Overfill Test Date</b>	05/08/2024			<b>ATG Type</b>					
<b>Tank Code</b>	20	<b>Tank Age</b>	3	<b>Tank Installed Date</b>	12/14/2023	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	
<b>Tag Number</b>	6113	<b>Spill Test Date</b>	05/08/2024	<b>Piping Installed Date</b>	12/14/2023	<b>Tank Construction</b>		<b>Piping Construction</b>		<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	05/08/2024	<b>Catastrophic L.D Type 3.0</b>		<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	
<b>Product</b>	Diesel	<b>PLLD Test Date</b>	04/30/2025	<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>		<b>Primary Pipe Detection</b>		<b>Vapor Recovery</b>	No
<b>Capacity</b>	30000	<b>ATG Test Date</b>	04/30/2025	<b>Line Tightness Test Date</b>	09/06/2023	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	Yes
		<b>Overfill Test Date</b>	05/08/2024			<b>ATG Type</b>					