

Facility Summary in Jefferson County in the City of Boulder

Location: HARLOWS SCHOOL BUS SERVICE INC BOULDER
101 Main St
Boulder, MT 59632 Jefferson

System Facility ID:22-12378

Facility Code: 22635
Last Inspected On: 02/03/2023
Operating Permit Renewal Date: 02/03/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: HJJ Properties LLC	7012241767
Operator Contact: Hugh Taylor;Sandra Hays;Wesley Tangen	4062253344;4062398845

Owner/Operator: HJJ Properties LLC

Hugh Taylor, UST Class A Operator
Hugh Taylor, UST Class B Operator
Sandra Hays, UST Class A Operator
Sandra Hays, UST Class B Operator
Wesley Tangen, UST Class A Operator
Wesley Tangen, UST Class B Operator

Tank Code	06	Tank Age	33	Tank Installed Date	10/01/1991	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	2710	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Temporarily Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	02/03/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.1;Automatic Tank Gauging 0.2	Primary Pipe Detection	Not Listed	Vapor Recovery	No
Capacity	2000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					
Tank Code	07	Tank Age	33	Tank Installed Date	10/01/1991	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	2711	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Temporarily Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	02/03/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.1;Automatic Tank Gauging 0.2	Primary Pipe Detection	Not Listed	Vapor Recovery	No

Capacity	2000	ATG Test Date	Line Tightness Test Date	Secondary Tank Leak Detection	Secondary Pipe Detection	Energy Act	No
		Overfill Test Date		ATG Type			

Facility Summary in Jefferson County in the City of Boulder

Location: TOWN PUMP INC BOULDER
703 N Main
Boulder, MT 59632 Jefferson

System Facility ID:22-08673

Facility Code: 22598
Last Inspected On: 01/04/2023
Operating Permit Renewal Date: 05/26/2024

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Boulder 1 Town Pump LLC4064976700

Operator Contact: Trent Biggers

Owner/Operator: Boulder 1 Town Pump LLC

Trent Biggers, UST Class A Operator
Trent Biggers, UST Class B Global Operator

Tank Code	01	Tank Age	47	Tank Installed Date	05/10/1977	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	2485	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Permanently Out of Use	MLLD Test Date		Sump Tightness Test Date	05/24/2021	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date	05/24/2021	Tank/Piping CP Test Date	05/24/2021	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	12000	ATG Test Date		Line Tightness Test Date	09/26/2006	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	02	Tank Age	47	Tank Installed Date	05/10/1977	Tank Material	Bare Steel	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	2486	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Permanently Out of Use	MLLD Test Date		Sump Tightness Test Date	05/24/2021	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Diesel	PLLD Test Date	05/24/2021	Tank/Piping CP Test Date	05/24/2021	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	6000	ATG Test Date		Line Tightness Test Date	09/26/2006	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-350				

Tank Code	03	Tank Age	47	Tank Installed Date	05/10/1977	Tank Material	Bare Steel	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	2487	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Permanently Out of Use	MLLD Test Date		Sump Tightness Test Date	05/24/2021	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date	05/24/2021	Tank/Piping CP Test Date	05/24/2021	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	6000	ATG Test Date		Line Tightness Test Date	09/26/2006	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	04	Tank Age	35	Tank Installed Date	01/01/1989	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	4477	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Permanently Out of Use	MLLD Test Date		Sump Tightness Test Date	05/24/2021	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Diesel	PLLD Test Date	05/24/2021	Tank/Piping CP Test Date	05/24/2021	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	12000	ATG Test Date		Line Tightness Test Date	09/26/2006	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	05	Tank Age	35	Tank Installed Date	05/10/1989	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	4478	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Permanently Out of Use	MLLD Test Date		Sump Tightness Test Date	05/24/2021	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Diesel	PLLD Test Date	05/24/2021	Tank/Piping CP Test Date	05/24/2021	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	9000	ATG Test Date		Line Tightness Test Date	09/26/2006	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	06	Tank Age	23	Tank Installed Date	04/01/2001	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	4479	Spill Test Date		Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No

Tank Status	Permanently Out of Use	MLLD Test Date		Sump Tightness Test Date	05/24/2021	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	05/24/2021	Tank/Piping CP Test Date		Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	10000	ATG Test Date		Line Tightness Test Date	09/26/2006	Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	07	Tank Age	23	Tank Installed Date	04/01/2001	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	4480	Spill Test Date		Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Permanently Out of Use	MLLD Test Date		Sump Tightness Test Date	05/24/2021	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	05/24/2021	Tank/Piping CP Test Date		Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	5000	ATG Test Date		Line Tightness Test Date	09/26/2006	Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	08	Tank Age	2	Tank Installed Date	05/25/2022	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	6058	Spill Test Date	05/20/2022	Piping Installed Date	05/25/2022	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	06/01/2022	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	30000	ATG Test Date	09/30/2022	Line Tightness Test Date		Secondary Tank Leak Detection	Statistical Inventory Reconciliation	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	Yes
		Overfill Test Date	05/20/2022			ATG Type					
Tank Code	09	Tank Age	2	Tank Installed Date	05/25/2022	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	6059	Spill Test Date	05/20/2022	Piping Installed Date	05/25/2022	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	06/01/2022	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No

Capacity	8000	ATG Test Date	09/30/2022	Line Tightness Test Date		Secondary Tank Leak Detection	Statistical Inventory Reconciliation	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	Yes
		Overfill Test Date	05/20/2022			ATG Type					
Tank Code	10	Tank Age	2	Tank Installed Date	05/25/2022	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	6060	Spill Test Date	05/20/2022	Piping Installed Date	05/25/2022	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	06/01/2022	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel, Dyed	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	12000	ATG Test Date	09/30/2022	Line Tightness Test Date		Secondary Tank Leak Detection	Statistical Inventory Reconciliation	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	Yes
		Overfill Test Date	05/20/2022			ATG Type					
Tank Code	11	Tank Age	2	Tank Installed Date	05/25/2022	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	6061	Spill Test Date	05/20/2022	Piping Installed Date	05/25/2022	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	06/01/2022	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	DEF (Not Regulated)	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	10000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	05/20/2022			ATG Type					
Tank Code	12	Tank Age	0	Tank Installed Date		Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	6062	Spill Test Date	09/15/2022	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	09/15/2022	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	15000	ATG Test Date	01/04/2023	Line Tightness Test Date		Secondary Tank Leak Detection	Statistical Inventory Reconciliation	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	Yes
		Overfill Test Date	09/15/2022			ATG Type					
Tank Code	13	Tank Age	0	Tank Installed Date		Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve

Tag Number	6063	Spill Test Date	09/15/2022	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	09/15/2022	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline, E10	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	Yes
Capacity	15000	ATG Test Date	01/04/2023	Line Tightness Test Date		Secondary Tank Leak Detection	Statistical Inventory Reconciliation	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	Yes
		Overfill Test Date	09/15/2022			ATG Type					
Tank Code	14	Tank Age	0	Tank Installed Date		Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	6064	Spill Test Date	09/15/2022	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	09/15/2022	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	Yes
Capacity	24000	ATG Test Date	01/04/2023	Line Tightness Test Date		Secondary Tank Leak Detection	Statistical Inventory Reconciliation	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	Yes
		Overfill Test Date	09/15/2022			ATG Type					
Tank Code	15	Tank Age	0	Tank Installed Date		Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	6065	Spill Test Date	09/15/2022	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	09/15/2022	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	Yes
Capacity	6000	ATG Test Date	01/04/2023	Line Tightness Test Date		Secondary Tank Leak Detection	Statistical Inventory Reconciliation	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	Yes
		Overfill Test Date	09/15/2022			ATG Type					

Facility Summary in Jefferson County in the City of Cardwell

Location: CARDWELL GENERAL STORE and CAMPGROUND
770 MT Hwy 2 E
Cardwell, MT 59721-9615 Jefferson

System Facility ID:22-13424

Facility Code: 22656
Last Inspected On: 06/01/2023
Operating Permit Renewal Date: 09/03/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: CARDWELL CAMPGROUND LLC5107548233

Operator Contact: Curtis Perry4065811526

Owner/Operator: CARDWELL CAMPGROUND LLC

Curtis Perry, UST Class A Operator
Curtis Perry, UST Class B Operator

Tank Code	01	Tank Age	30	Tank Installed Date	04/01/1994	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	3193	Spill Test Date	06/01/2023	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date	06/01/2023	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	06/01/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	9000	ATG Test Date	06/01/2023	Line Tightness Test Date	06/01/2023	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	06/01/2023			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	02	Tank Age	30	Tank Installed Date	04/01/1994	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	3194	Spill Test Date	06/01/2023	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date	06/01/2023	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	06/01/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	3000	ATG Test Date	06/01/2023	Line Tightness Test Date	06/01/2023	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	06/01/2023			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	03	Tank Age	30	Tank Installed Date	04/01/1994	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve

Tag Number	3195	Spill Test Date	06/01/2023	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date	06/01/2023	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	06/01/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	6000	ATG Test Date	06/01/2023	Line Tightness Test Date	06/01/2023	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	06/01/2023			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	04	Tank Age	30	Tank Installed Date	04/01/1994	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	3196	Spill Test Date	06/01/2023	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date	06/01/2023	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	06/01/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	6000	ATG Test Date	06/01/2023	Line Tightness Test Date	06/01/2023	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	06/01/2023			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Jefferson County in the City of Clancy

Location: CLANCY STORE
10 E Clancy St
Clancy, MT 59634-9560 Jefferson

System Facility ID:22-02898

Facility Code: 22515
Last Inspected On: 08/05/2019
Operating Permit Renewal Date: 08/05/2022

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Clancy Store LLC4064650540

Operator Contact:

Owner/Operator: Clancy Store LLC

Tank Code	02	Tank Age	40	Tank Installed Date	04/26/1984	Tank Material	Bare Steel	Piping Material	Steel	Overfill Types	High Level Alarm
Tag Number	3534	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Temporarily Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	08/05/2019	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	2000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					
Tank Code	03	Tank Age	31	Tank Installed Date	04/10/1993	Tank Material	Bare Steel	Piping Material	Steel	Overfill Types	High Level Alarm
Tag Number	4647	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Temporarily Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	08/05/2019	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	1000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					

Facility Summary in Jefferson County in the City of Montana City

Location: MONTANA CITY STORE LLC
1 Jackson Creek Rd
Montana City, MT 59634-9714 Jefferson

System Facility ID:22-01822

Facility Code: 22494
Last Inspected On: 02/16/2022
Operating Permit Renewal Date: 06/01/2025

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Montana City Properties Inc 4064430150

Operator Contact: Heather Russell;Montana City Properties Inc;Shawn McFadden 4064430150

Owner/Operator: Montana City Properties Inc

Heather Russell, UST Class A Operator
Heather Russell, UST Class B Global Operator
Shawn McFadden, UST Class A Operator
Shawn McFadden, UST Class B Global Operator

Tank Code	05	Tank Age	36	Tank Installed Date	07/01/1988	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	1668	Spill Test Date	07/15/2021	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date	08/09/2021	Tank/Piping CP Test Date	02/18/2022	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	4000	ATG Test Date	08/09/2021	Line Tightness Test Date	12/20/2021	Secondary Tank Leak Detection		Secondary Pipe Detection	Manual Interstitial Monitoring	Energy Act	No
		Overfill Test Date	08/09/2021			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	06	Tank Age	36	Tank Installed Date	07/01/1988	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	1669	Spill Test Date	07/15/2021	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date	08/09/2021	Tank/Piping CP Test Date	02/18/2022	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	10000	ATG Test Date	08/09/2021	Line Tightness Test Date	10/21/2021	Secondary Tank Leak Detection		Secondary Pipe Detection	Manual Interstitial Monitoring	Energy Act	No
		Overfill Test Date	08/09/2021			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Tank Code	07	Tank Age	36	Tank Installed Date	07/01/1988	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	1670	Spill Test Date	07/15/2021	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date	08/09/2021	Tank/Piping CP Test Date	02/18/2022	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	10000	ATG Test Date	08/09/2021	Line Tightness Test Date	10/25/2021	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	08/09/2021			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Jefferson County in the City of Whitehall

Location: GOLDEN SUNLIGHT MINES INC UST
453 MT Hwy 2 E
Whitehall, MT 59759-8637 Jefferson

Facility Code: 22546
Last Inspected On: 10/21/2021
System Facility ID:22-04689
Operating Permit Renewal Date: 12/17/2024

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Golden Sunlight Mines Inc4062873257

Operator Contact: Darrell Scharf;Debby Horne;Jerry Muething;Rick Henderson4062872007;4062872018;4062872035;4062873257

Owner/Operator: Golden Sunlight Mines Inc

Darrell Scharf, UST Class A Operator
Dave Lawrence, UST Class B Global Operator
Debby Horne, UST Class A Operator
Donald Pippin, UST Class B Global Operator
George Clements, UST Class B Global Operator
Jerry Muething, UST Class A Operator
Jerry Muething, UST Class B Operator
John Clements, UST Class B Global Operator
John Perigo, UST Class B Global Operator
Joseph Dillon, UST Class B Global Operator
Ray Panisko, UST Class B Global Operator
Rick Henderson, UST Class A Operator
Seth Slatter, UST Class B Operator
Travis Nielsen, UST Class B Global Operator

Tank Code	06	Tank Age	16	Tank Installed Date	06/12/2008	Tank Material	Unknown	Piping Material	Flexible Plastic	Overfill Types	
Tag Number	5218	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	Yes
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	10/21/2021	Catastrophic L.D Type 3.0	Continuous Interstitial Monitoring	Piping Type	Pressurized	CP Met Types	
Product	Oil, Motor	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection		Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	1000	ATG Test Date	12/19/2022	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					

Tank Code	07	Tank Age	16	Tank Installed Date	06/12/2008	Tank Material	Unknown	Piping Material	Flexible Plastic	Overfill Types	
Tag Number	5219	Spill Test Date		Piping Installed Date	06/23/2009	Tank Construction		Piping Construction	Double Walled	AST	Yes
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	10/21/2021	Catastrophic L.D Type 3.0	Continuous Interstitial Monitoring	Piping Type	Pressurized	CP Met Types	
Product	Oil, Motor	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection		Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	1000	ATG Test Date	12/19/2022	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					
Tank Code	08	Tank Age	15	Tank Installed Date	06/12/2009	Tank Material	Unknown	Piping Material	Flexible Plastic	Overfill Types	
Tag Number	5220	Spill Test Date		Piping Installed Date	06/23/2009	Tank Construction		Piping Construction	Double Walled	AST	Yes
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	10/21/2021	Catastrophic L.D Type 3.0	Continuous Interstitial Monitoring	Piping Type	Pressurized	CP Met Types	
Product	Oil, Motor	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection		Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	1500	ATG Test Date	12/19/2022	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					
Tank Code	09	Tank Age	16	Tank Installed Date	06/12/2008	Tank Material	Unknown	Piping Material	Steel - Terminal Piping	Overfill Types	
Tag Number	5221	Spill Test Date		Piping Installed Date	06/23/2009	Tank Construction		Piping Construction	Double Walled	AST	Yes
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	10/21/2021	Catastrophic L.D Type 3.0	Continuous Interstitial Monitoring	Piping Type	Pressurized	CP Met Types	
Product	Oil, Waste	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection		Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	2000	ATG Test Date	12/19/2022	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					
Tank Code	10	Tank Age	16	Tank Installed Date	06/12/2008	Tank Material	Unknown	Piping Material	Flexible Plastic	Overfill Types	
Tag Number	5222	Spill Test Date		Piping Installed Date	06/23/2009	Tank Construction		Piping Construction	Double Walled	AST	Yes
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	10/21/2021	Catastrophic L.D Type 3.0	Continuous Interstitial Monitoring	Piping Type	Pressurized	CP Met Types	

Product	Oil, Motor	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection		Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	2000	ATG Test Date	12/19/2022	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					

Facility Summary in Jefferson County in the City of Whitehall

Location: THRIFTWAY SUPER STOP 17
203 W Legion Ave
Whitehall, MT 59759 Jefferson

System Facility ID:22-00980

Facility Code: 22479
Last Inspected On: 01/27/2022
Operating Permit Renewal Date: 02/27/2025

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Sutey Oil Co Inc4064942305

Operator Contact: Louie Sutey;Sutey Oil Co Inc;Louis Sutey;Marlys Weyer;Timothy Mulligan4062873787;4064915808;4064915808;4064942305

Owner/Operator: Sutey Oil Co Inc

- Louie Sutey, UST Class A Operator
- Louie Sutey, UST Class B Operator
- Louis Sutey, UST Class A Operator
- Louis Sutey, UST Class B Global Operator
- Marlys Weyer, UST Class A Operator
- Marlys Weyer, UST Class B Operator
- Timothy Mulligan, UST Class A Operator
- Timothy Mulligan, UST Class B Operator

Tank Code	04	Tank Age	31	Tank Installed Date	10/15/1993	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	527	Spill Test Date	11/19/2021	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date	04/11/2019	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date	11/19/2021	Tank/Piping CP Test Date	11/16/2021	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	10000	ATG Test Date	11/19/2021	Line Tightness Test Date	04/11/2019	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	02/04/2022			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	05	Tank Age	31	Tank Installed Date	10/15/1993	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	528	Spill Test Date	11/19/2021	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date	04/11/2019	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date	11/19/2021	Tank/Piping CP Test Date	11/16/2021	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No

Capacity	6000	ATG Test Date	11/19/2021	Line Tightness Test Date	04/11/2019	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	02/04/2022			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	06	Tank Age	31	Tank Installed Date	10/15/1993	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	529	Spill Test Date	11/19/2021	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date	04/11/2019	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date	11/19/2021	Tank/Piping CP Test Date	11/16/2021	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	6000	ATG Test Date	11/19/2021	Line Tightness Test Date	04/11/2019	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	02/04/2022			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Jefferson County in the City of Whitehall

Location: TOWN PUMP INC WHITEHALL
417 N Whitehall St
Whitehall, MT 59759 Jefferson

Facility Code: 22528
Last Inspected On: 11/01/2022
System Facility ID:22-03645
Operating Permit Renewal Date: 11/01/2025

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Whitehall 1 Town Pump LLC4064976700

Operator Contact: Trent Biggers

Owner/Operator: Whitehall 1 Town Pump LLC

Trent Biggers, UST Class A Operator
Trent Biggers, UST Class B Global Operator

Tank Code	01	Tank Age	56	Tank Installed Date	01/01/1968	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	2476	Spill Test Date	06/30/2021	Piping Installed Date		Tank Construction	Lined Interior/Impressed Current	Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Diesel	PLLD Test Date	06/15/2022	Tank/Piping CP Test Date	04/14/2021	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	10000	ATG Test Date	06/15/2022	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	06/30/2021			ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	02	Tank Age	56	Tank Installed Date	01/01/1968	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	2477	Spill Test Date	06/30/2021	Piping Installed Date		Tank Construction	Lined Interior/Impressed Current	Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Diesel	PLLD Test Date	06/15/2022	Tank/Piping CP Test Date	04/14/2021	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	6000	ATG Test Date	06/15/2022	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	06/30/2021			ATG Type	Gilbarco-Veeder Root/TLS-350				

Tank Code	03	Tank Age	46	Tank Installed Date	01/01/1978	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	2478	Spill Test Date	06/30/2021	Piping Installed Date		Tank Construction	Lined Interior/Impressed Current	Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date	06/15/2022	Tank/Piping CP Test Date	04/14/2021	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	6000	ATG Test Date	06/15/2022	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	06/30/2021			ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	04	Tank Age	48	Tank Installed Date	01/01/1976	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	2479	Spill Test Date	06/30/2021	Piping Installed Date		Tank Construction	Lined Interior/Impressed Current	Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date	06/15/2022	Tank/Piping CP Test Date	04/14/2021	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	12000	ATG Test Date	06/15/2022	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	06/30/2021			ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	05	Tank Age	46	Tank Installed Date	01/01/1978	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	2480	Spill Test Date	06/30/2021	Piping Installed Date		Tank Construction	Lined Interior/Impressed Current	Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date	06/15/2022	Tank/Piping CP Test Date	04/14/2021	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	6000	ATG Test Date	06/15/2022	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	04/15/2021			ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	06	Tank Age	46	Tank Installed Date	01/01/1978	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	2481	Spill Test Date	06/30/2021	Piping Installed Date		Tank Construction	Lined Interior/Impressed Current	Piping Construction	None	AST	No

Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date	06/15/2022	Tank/Piping CP Test Date	04/14/2021	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	12000	ATG Test Date	06/15/2022	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	06/30/2021			ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	07	Tank Age	38	Tank Installed Date	01/01/1986	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	2482	Spill Test Date	06/30/2021	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date	06/15/2022	Tank/Piping CP Test Date	04/14/2021	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	6000	ATG Test Date	06/15/2022	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	04/15/2021			ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	08	Tank Age	37	Tank Installed Date	01/01/1987	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	2483	Spill Test Date	06/30/2021	Piping Installed Date	12/23/2015	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	06/15/2022	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	04/14/2021	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	12000	ATG Test Date	06/15/2022	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	No
		Overfill Test Date	04/15/2021			ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	09	Tank Age	37	Tank Installed Date	01/01/1987	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	2484	Spill Test Date	06/30/2021	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	04/14/2021	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection		Vapor Recovery	No
Capacity	12000	ATG Test Date	06/15/2022	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No

		Overfill Test Date	06/30/2021			ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	10	Tank Age	24	Tank Installed Date	05/01/2000	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	4198	Spill Test Date	06/30/2021	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	06/15/2022	Sump Tightness Test Date	07/20/2018	Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	05/04/2012	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	5000	ATG Test Date	06/15/2022	Line Tightness Test Date	12/23/2019	Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	04/15/2021			ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	11	Tank Age	24	Tank Installed Date	05/01/2000	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	4199	Spill Test Date	06/30/2021	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	06/15/2022	Sump Tightness Test Date	07/20/2018	Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel, Dyed	PLLD Test Date		Tank/Piping CP Test Date	05/04/2012	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	10000	ATG Test Date	06/15/2022	Line Tightness Test Date	12/23/2019	Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	04/15/2021			ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	12	Tank Age	9	Tank Installed Date	08/01/2015	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Positive Shutoff
Tag Number	5598	Spill Test Date		Piping Installed Date	12/23/2015	Tank Construction	Double-Walled	Piping Construction	None	AST	No
Tank Status	Permanently Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Continuous Interstitial Monitoring	Piping Type	Pressurized	CP Met Types	
Product	DEF (Not Regulated)	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	10000	ATG Test Date		Line Tightness Test Date	12/23/2015	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring;Not Listed	Energy Act	Yes

		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	13	Tank Age	1	Tank Installed Date	05/23/2023	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	
Tag Number	6106	Spill Test Date	09/06/2023	Piping Installed Date	05/23/2023	Tank Construction		Piping Construction		AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	09/07/2023	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	22000	ATG Test Date	11/08/2023	Line Tightness Test Date		Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	09/06/2023			ATG Type					
Tank Code	14	Tank Age	1	Tank Installed Date	05/23/2023	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	
Tag Number	6107	Spill Test Date	09/06/2023	Piping Installed Date	05/23/2023	Tank Construction		Piping Construction		AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	09/07/2023	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	Yes
Capacity	8000	ATG Test Date	11/08/2023	Line Tightness Test Date		Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	09/06/2023			ATG Type					
Tank Code	15	Tank Age	1	Tank Installed Date	05/23/2023	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	
Tag Number	6108	Spill Test Date	09/06/2023	Piping Installed Date	05/23/2023	Tank Construction		Piping Construction		AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	09/07/2023	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	Yes
Capacity	30000	ATG Test Date	11/08/2023	Line Tightness Test Date		Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	09/06/2023			ATG Type					
Tank Code	16	Tank Age	1	Tank Installed Date	12/14/2023	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	
Tag Number	6109	Spill Test Date	09/06/2023	Piping Installed Date	12/14/2023	Tank Construction		Piping Construction		AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	09/06/2023	Catastrophic L.D Type 3.0		Piping Type	Pressurized	CP Met Types	

Product	Diesel, Dyed	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection		Primary Pipe Detection		Vapor Recovery	No
Capacity	9000	ATG Test Date	09/06/2023	Line Tightness Test Date	09/06/2023	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	Yes
		Overfill Test Date	09/06/2023			ATG Type					
Tank Code	17	Tank Age	1	Tank Installed Date	05/23/2023	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	
Tag Number	6110	Spill Test Date	09/06/2023	Piping Installed Date	05/23/2023	Tank Construction		Piping Construction		AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	09/07/2023	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	Yes
Capacity	15000	ATG Test Date	11/08/2023	Line Tightness Test Date		Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	09/06/2023			ATG Type					
Tank Code	18	Tank Age	1	Tank Installed Date	12/14/2023	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	
Tag Number	6111	Spill Test Date	09/06/2023	Piping Installed Date	12/14/2023	Tank Construction		Piping Construction		AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	09/06/2023	Catastrophic L.D Type 3.0		Piping Type	Pressurized	CP Met Types	
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection		Primary Pipe Detection		Vapor Recovery	No
Capacity	6000	ATG Test Date	09/06/2023	Line Tightness Test Date	09/06/2023	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	Yes
		Overfill Test Date	09/06/2023			ATG Type					
Tank Code	19	Tank Age	1	Tank Installed Date	12/14/2023	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	
Tag Number	6112	Spill Test Date	09/06/2023	Piping Installed Date	12/14/2023	Tank Construction		Piping Construction		AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	09/06/2023	Catastrophic L.D Type 3.0		Piping Type	Pressurized	CP Met Types	
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection		Primary Pipe Detection		Vapor Recovery	No
Capacity	30000	ATG Test Date	09/06/2023	Line Tightness Test Date	09/06/2023	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	Yes
		Overfill Test Date	09/06/2023			ATG Type					
Tank Code	20	Tank Age	1	Tank Installed Date	12/14/2023	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	
Tag Number	6113	Spill Test Date	09/06/2023	Piping Installed Date	12/14/2023	Tank Construction		Piping Construction		AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	09/06/2023	Catastrophic L.D Type 3.0		Piping Type	Pressurized	CP Met Types	

Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection		Primary Pipe Detection		Vapor Recovery	No
Capacity	30000	ATG Test Date	09/06/2023	Line Tightness Test Date	09/06/2023	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	Yes
		Overfill Test Date	09/06/2023			ATG Type					