

Facility Summary in Lake County in the City of Arlee

Location: WILSON FOODS  
92345 US Hwy 93  
Arlee, MT 59821-9433 Lake

System Facility ID:24-06788

Facility Code: 23006  
Last Inspected On: 02/19/2024  
Operating Permit Renewal Date: 03/21/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Wilson Foods

Operator Contact: John Carranco;Velva Stuck;Wilson Foods 4065490891

Owner/Operator: Wilson Foods

John Carranco, UST Class A Operator  
John Carranco, UST Class B Operator  
Velva Stuck, UST Class A Operator  
Velva Stuck, UST Class B Operator

Tank Code	10	Tank Age	26	Tank Installed Date	11/01/1998	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	3320	Spill Test Date	09/15/2022	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date	02/19/2024	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	10000	ATG Test Date	02/19/2024	Line Tightness Test Date	02/19/2024	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	09/15/2022			ATG Type	Gilbarco-Veeder Root/TLS-300				
Tank Code	11	Tank Age	26	Tank Installed Date	11/01/1998	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	3321	Spill Test Date	09/15/2022	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date	02/19/2024	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	4000	ATG Test Date	02/19/2024	Line Tightness Test Date	02/19/2024	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	09/15/2022			ATG Type	Gilbarco-Veeder Root/TLS-300				

Tank Code	12	Tank Age	26	Tank Installed Date	11/01/1998	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	3322	Spill Test Date	09/15/2022	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date	02/19/2024	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	4000	ATG Test Date	02/19/2024	Line Tightness Test Date	02/19/2024	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	11/15/2022			ATG Type	Gilbarco-Veeder Root/TLS-300				

Facility Summary in Lake County in the City of Charlo

Location: CHARLO SCHOOL DIST 7 J  
405 2nd Ave E  
Charlo, MT 59824 Lake

System Facility ID:24-02789

Facility Code: 22907  
Last Inspected On: 11/01/2023  
Operating Permit Renewal Date: 03/27/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: School Dist 7 J Charlo4066442207

Operator Contact: Joe Broom;School Dist 7 J Charlo4062498000;4066442207

Owner/Operator: School Dist 7 J Charlo

Joe Broom, UST Class A Operator  
Joe Broom, UST Class B Operator

Tank Code	S5	Tank Age	26	Tank Installed Date	07/01/1998	Tank Material	Unknown	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	611	Spill Test Date		Piping Installed Date	07/09/2012	Tank Construction		Piping Construction	Double Walled	AST	Yes
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	11/01/2023	Catastrophic L.D Type 3.0	Auto Dialer	Piping Type	U.S. Suction	CP Met Types	
Product	Heating Oil	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Deferred	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	10000	ATG Test Date	11/01/2023	Line Tightness Test Date	08/27/2012	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	Yes
		Overfill Test Date				ATG Type					

Facility Summary in Lake County in the City of Charlo

Location: COULTER AUTOMOTIVE INC  
104 Main St  
Charlo, MT 59824-0097 Lake

System Facility ID:24-04615

Facility Code: 22947  
Last Inspected On: 01/19/2022  
Operating Permit Renewal Date: 04/01/2025

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Coulter Automotive Inc4066442215

Operator Contact: Sandra Coulter4066442215

Owner/Operator: Coulter Automotive Inc

Sandra Coulter, UST Class A Operator  
Sandra Coulter, UST Class B Operator

Tank Code	03	Tank Age	29	Tank Installed Date	07/01/1995	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	2281	Spill Test Date	01/19/2022	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date	07/12/2021	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	11/05/2019	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	6000	ATG Test Date	01/19/2022	Line Tightness Test Date	07/12/2021	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	01/19/2022			ATG Type	EMCO Electronics/EECO 1500				
Tank Code	04	Tank Age	29	Tank Installed Date	07/01/1995	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	2282	Spill Test Date	01/19/2022	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date	07/12/2021	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	11/05/2019	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	4000	ATG Test Date	01/19/2022	Line Tightness Test Date	07/12/2021	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	01/19/2022			ATG Type	EMCO Electronics/EECO 1500				

Facility Summary in Lake County in the City of Charlo

Location: MOIESE MERCANTILE  
64620 MT Hwy 212  
Charlo, MT 59824-9004 Lake

System Facility ID:24-06382

Facility Code: 22995  
Last Inspected On: 05/06/2022  
Operating Permit Renewal Date: 05/06/2025

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Moiese Mercantile4066443454

Operator Contact: Timothy Hall4066443454

Owner/Operator: Moiese Mercantile

Leslie Muth, UST Class B Operator  
Timothy Hall, UST Class A Operator

Tank Code	03	Tank Age	25	Tank Installed Date	03/01/1999	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	3968	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Temporarily Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection		Vapor Recovery	No
Capacity	1000	ATG Test Date		Line Tightness Test Date	10/25/2004	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					

Facility Summary in Lake County in the City of Pablo

Location: PABLO ELEMENTARY SCHOOL  
608 4th Ave  
Pablo, MT 59855 Lake

System Facility ID:24-04823

Facility Code: 22952  
Last Inspected On: 05/25/2023  
Operating Permit Renewal Date: 09/25/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: School Dist 30 Ronan 4066442448

Operator Contact: Brad Benson;Lawrence Cordis;Rob Tougas 4062508008

Owner/Operator: School Dist 30 Ronan

- Brad Benson, UST Class A Operator
- Brad Benson, UST Class B Global Operator
- Lawrence Cordis, UST Class A Operator
- Lawrence Cordis, UST Class B Global Operator
- Rob Tougas, UST Class A Operator
- Rob Tougas, UST Class B Global Operator

Tank Code	S1	Tank Age	58	Tank Installed Date	04/28/1966	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	1903	Spill Test Date		Piping Installed Date		Tank Construction	Lined Interior/Impressed Current	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	10/20/2020	Catastrophic L.D Type 3.0	Auto Dialer	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Heating Oil	PLLD Test Date		Tank/Piping CP Test Date	10/20/2020	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	8000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type	Veeder Root/TLS-300				

Facility Summary in Lake County in the City of Pablo

Location: QUICKSILVER EXPRESS 52001 US Hwy 93 Pablo, MT 59855 Lake				Facility Code: 23179 Last Inspected On: 01/09/2023 Operating Permit Renewal Date: 03/16/2026			
System Facility ID:24-11124				Note: Inspection is due 90 days before the Operating Permit Renewal Date.			

Owner Operator Contact: Quick Silver Express	4066755000
--	------------

Operator Contact: Corky Sias	4062752792
------------------------------	------------

Owner/Operator: Quick Silver Express

Corky Sias, UST Class A Operator  
Corky Sias, UST Class B Operator

Tank Code	01	Tank Age	37	Tank Installed Date	01/01/1987	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve;Flapper Valve
Tag Number	3296	Spill Test Date	10/27/2021	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Diesel, Dyed	PLLD Test Date		Tank/Piping CP Test Date	07/21/2022	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	8000	ATG Test Date	07/18/2023	Line Tightness Test Date	03/16/2017	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	02/23/2022			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	02	Tank Age	37	Tank Installed Date	01/01/1987	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve;Flapper Valve
Tag Number	3297	Spill Test Date	10/27/2021	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	07/21/2022	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	8000	ATG Test Date	07/18/2023	Line Tightness Test Date	03/16/2017	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	02/23/2022			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Tank Code	03	Tank Age	37	Tank Installed Date	01/01/1987	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve;Flapper Valve
Tag Number	3298	Spill Test Date	10/27/2021	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	07/21/2022	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	8000	ATG Test Date	07/18/2023	Line Tightness Test Date	03/16/2017	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	02/23/2022			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	04	Tank Age	13	Tank Installed Date	05/01/2011	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve;Flapper Valve
Tag Number	5344	Spill Test Date	10/27/2021	Piping Installed Date	05/01/2011	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	03/16/2017	Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	12000	ATG Test Date	07/18/2023	Line Tightness Test Date	03/16/2017	Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	02/23/2022			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Lake County in the City of Polson

Location: CHERRY VALLEY SCHOOL  
107 8th Ave W  
Polson, MT 59860-2911 Lake

System Facility ID:24-02867

Facility Code: 22909  
Last Inspected On: 01/27/2021  
Operating Permit Renewal Date: 02/19/2024

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: School Dist 23 Polson4068836333

Operator Contact: Dan Giles;Dan Kinyon;John Hipp4062492564

Owner/Operator: School Dist 23 Polson

- Dan Giles, UST Class A Operator
- Dan Giles, UST Class B Operator
- Dan Kinyon, UST Class A Operator
- Dan Kinyon, UST Class B Operator
- John Hipp, UST Class A Operator
- John Hipp, UST Class B Operator

Tank Code	S2	Tank Age	34	Tank Installed Date	08/01/1990	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	1805	Spill Test Date		Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Permanently Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Galvanic
Product	Heating Oil	PLLD Test Date		Tank/Piping CP Test Date	01/27/2021	Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection		Vapor Recovery	No
Capacity	4000	ATG Test Date		Line Tightness Test Date	01/27/2021	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/ILS-250				

Facility Summary in Lake County in the City of Polson

Location: GOLDES  
33537 MT Hwy 35  
Polson, MT 59860 Lake

System Facility ID:60-15208

Facility Code: 30928  
Last Inspected On: 03/25/2024  
Operating Permit Renewal Date: 07/16/2024

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Jeffry Goldes4064430454

Operator Contact: Serena Keller;Travis Schenck4068376679;4068851530

Owner/Operator: Jeffry Goldes

Frank Jasper, UST Class B Operator  
Serena Keller, UST Class A Operator  
Serena Keller, UST Class B Operator  
Travis Schenck, UST Class A Operator

Tank Code	S2	Tank Age	12	Tank Installed Date	05/01/2012	Tank Material	Aboveground Tank	Piping Material	Flexible Plastic	Overfill Types	
Tag Number	5365	Spill Test Date		Piping Installed Date	04/17/2012	Tank Construction		Piping Construction	Double Walled	AST	Yes
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	07/12/2018	Catastrophic L.D Type 3.0	Continuous Interstitial Monitoring	Piping Type	Gravity Feed	CP Met Types	
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection		Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	500	ATG Test Date	04/05/2022	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	Yes
		Overfill Test Date				ATG Type					

Facility Summary in Lake County in the City of Polson

Location: JETTE STORE  
44613 US Hwy 93  
Polson, MT 59860-7585 Lake

System Facility ID:24-07247

Facility Code: 23026  
Last Inspected On: 01/20/2024  
Operating Permit Renewal Date: 12/02/2023

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Grits Inc

Operator Contact:

Owner/Operator: Grits Inc

Tank Code	04	Tank Age	28	Tank Installed Date	04/01/1996	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	1215	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	12000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date				ATG Type	Incon/TS-1000				
Tank Code	05	Tank Age	28	Tank Installed Date	04/01/1996	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	1216	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	8000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date				ATG Type	Incon/TS-1000				
Tank Code	06	Tank Age	28	Tank Installed Date	04/01/1996	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	1217	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No

Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	5000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date				ATG Type	Incon/TS-1000				

Facility Summary in Lake County in the City of Polson

Location: MOUNTAIN WEST CO OP POLSON  
808 Main St  
Polson, MT 59860-3227 Lake

System Facility ID:24-04560

Facility Code: 22946  
Last Inspected On: 08/16/2023  
Operating Permit Renewal Date: 12/02/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: CHS Mountain West Coop4066762201

Operator Contact: Bob Westin;Dusty Smith

Owner/Operator: CHS Mountain West Coop

- Bob Westin, UST Class A Operator
- Bob Westin, UST Class B Global Operator
- Dusty Smith, UST Class A Operator
- Dusty Smith, UST Class B Global Operator
- John Adams, UST Class B Operator

Tank Code	05	Tank Age	24	Tank Installed Date	01/01/2000	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	4155	Spill Test Date	03/27/2023	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	03/30/2020	Sump Tightness Test Date	10/30/2020	Catastrophic L.D Type 3.0	Auto Dialer;Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	04/03/2023	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	6000	ATG Test Date	03/27/2023	Line Tightness Test Date	03/30/2020	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	07/12/2023			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	06	Tank Age	24	Tank Installed Date	01/01/2000	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	4156	Spill Test Date	04/04/2023	Piping Installed Date	10/09/2013	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	03/30/2020	Sump Tightness Test Date	10/30/2019	Catastrophic L.D Type 3.0	Auto Dialer;Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible

Product	Gasoline	PLLD Test Date	04/03/2023	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	5000	ATG Test Date	03/27/2023	Line Tightness Test Date	03/30/2020	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	07/12/2023			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	08	Tank Age	24	Tank Installed Date	01/01/2000	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	4648	Spill Test Date	03/27/2023	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	03/30/2020	Sump Tightness Test Date	10/30/2019	Catastrophic L.D Type 3.0	Auto Dialer;Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	04/03/2023	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	5000	ATG Test Date	03/27/2023	Line Tightness Test Date	03/30/2020	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	07/12/2023			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	07	Tank Age	24	Tank Installed Date	01/01/2000	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	4741	Spill Test Date	04/04/2023	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	03/30/2020	Sump Tightness Test Date	10/30/2019	Catastrophic L.D Type 3.0	Auto Dialer;Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	04/03/2023	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	10000	ATG Test Date	03/27/2023	Line Tightness Test Date	03/30/2020	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	07/12/2023			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Lake County in the City of Polson

Location: PIER 93

49433 US Hwy 93

Polson, MT 59860 Lake

System Facility ID:24-05957

Facility Code: 22988

Last Inspected On: 05/05/2022

Operating Permit Renewal Date: 06/30/2025

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Jacks Pier 934068835768

Operator Contact: Donald Miller;Jacob Miller4068834531;4068835768

Owner/Operator: Jacks Pier 93

Donald Miller, UST Class A Operator

Donald Miller, UST Class B Operator

Jacob Miller, UST Class A Operator

Jacob Miller, UST Class B Global Operator

Jacob Miller, UST Class B Operator

Tank Code	01	Tank Age	38	Tank Installed Date	04/23/1986	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	1802	Spill Test Date	05/05/2022	Piping Installed Date		Tank Construction		Piping Construction	Single Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	05/05/2022	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	04/25/2022	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	4000	ATG Test Date	04/25/2022	Line Tightness Test Date	05/05/2022	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	05/05/2022			ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	02	Tank Age	38	Tank Installed Date	04/23/1986	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	1803	Spill Test Date	05/05/2022	Piping Installed Date		Tank Construction		Piping Construction	Single Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	05/05/2022	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	04/25/2022	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	6000	ATG Test Date	04/25/2022	Line Tightness Test Date	05/05/2022	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	05/05/2022			ATG Type	Gilbarco-Veeder Root/TLS-350				

Tank Code	06	Tank Age	34	Tank Installed Date	11/01/1990	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	1804	Spill Test Date	05/05/2022	Piping Installed Date		Tank Construction		Piping Construction	Single Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	05/05/2022	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	04/25/2022	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	10000	ATG Test Date	04/25/2022	Line Tightness Test Date	05/05/2022	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	05/05/2022			ATG Type	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Lake County in the City of Polson

Location: POLSON BAY GROCERY 425  
50451 US Hwy 93  
Polson, MT 59860 Lake

System Facility ID:24-05770

Facility Code: 22983  
Last Inspected On: 03/02/2023  
Operating Permit Renewal Date: 08/09/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Jays Corporation4065491750

Operator Contact: Jagpreet Ghuman;Jaspal Sandhu;Jays Corporation4065491750;4068807677

Owner/Operator: Jays Corporation

Jagpreet Ghuman, UST Class A Operator  
Jagpreet Ghuman, UST Class B Operator  
Jaspal Sandhu, UST Class A Operator  
Jaspal Sandhu, UST Class B Operator

Tank Code	04	Tank Age	22	Tank Installed Date	05/23/2002	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	4664	Spill Test Date	06/22/2021	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	04/28/2021	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	03/05/2020	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	20000	ATG Test Date	02/15/2023	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	02/25/2023			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	05	Tank Age	22	Tank Installed Date	05/23/2002	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	4665	Spill Test Date	06/22/2021	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	06/23/2013	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	03/05/2020	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	10000	ATG Test Date	02/15/2023	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No

		Overfill Test Date	02/25/2023			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	06	Tank Age	22	Tank Installed Date	05/23/2002	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	4666	Spill Test Date	04/28/2021	Piping Installed Date	10/30/2018	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	04/28/2021	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	03/05/2020	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	6000	ATG Test Date	02/15/2023	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	02/15/2023			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	07	Tank Age	22	Tank Installed Date	05/23/2002	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	4667	Spill Test Date	04/28/2021	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	06/23/2013	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	03/05/2020	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	4000	ATG Test Date	02/15/2023	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	02/25/2023			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Lake County in the City of Polson

Location: POLSON COUNTRY CLUB  
111 Bayview Dr  
Polson, MT 59860-9609 Lake

System Facility ID:24-11824

Facility Code: 23227  
Last Inspected On: 08/17/2022  
Operating Permit Renewal Date: 11/08/2025

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: City of Polson4068838505

Operator Contact: Natalia Arlint;Patrick Nowlen4068838234

Owner/Operator: City of Polson

Natalia Arlint, UST Class A Operator  
Patrick Nowlen, UST Class A Operator  
Patrick Nowlen, UST Class B Operator

Tank Code	01	Tank Age	34	Tank Installed Date	08/14/1990	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	647	Spill Test Date	08/17/2022	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	08/17/2022	Primary Tank Leak Detection	Manual Tank Gauging	Primary Pipe Detection		Vapor Recovery	No
Capacity	500	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	08/17/2022			ATG Type					

Facility Summary in Lake County in the City of Polson

Location: SAFEWAY FUEL STATION 1646  
40772 MT Hwy 35  
Polson, MT 59860 Lake

System Facility ID:60-15097

Facility Code: 30857  
Last Inspected On: 12/27/2023  
Operating Permit Renewal Date: 03/28/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact:	Safeway Stores Inc	4252016301
Operator Contact:	Aaron Nelson;Cindy Standbrook;Lynn Pehrson;Rachel Jones 2083953269;4068832340;4252016301	

Owner/Operator: Safeway Stores Inc

Aaron Nelson, UST Class A Operator  
Cindy Standbrook, UST Class A Operator  
Cindy Stankbrook, UST Class B Global Operator  
Heidi Morgan, UST Class B Global Operator  
Lynn Pehrson, UST Class A Operator  
Rachel Jones , UST Class A Operator  
Rachel Jones , UST Class B Global Operator

Tank Code	01	Tank Age	16	Tank Installed Date	05/22/2008	Tank Material	Steel Clad	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	5164	Spill Test Date	09/28/2022	Piping Installed Date	04/04/2008	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	09/28/2022	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Gasoline	PLLD Test Date	05/31/2023	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	20000	ATG Test Date	05/31/2023	Line Tightness Test Date	09/28/2022	Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	Yes
		Overfill Test Date	12/27/2023			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	02	Tank Age	16	Tank Installed Date	05/22/2008	Tank Material	Steel Clad	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	5165	Spill Test Date	09/28/2022	Piping Installed Date	04/04/2008	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	09/28/2022	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	05/31/2023	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No

Capacity	10000	ATG Test Date	05/31/2023	Line Tightness Test Date	09/28/2022	Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	Yes
		Overfill Test Date	12/27/2023			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	03	Tank Age	16	Tank Installed Date	05/22/2008	Tank Material	Steel Clad	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	5166	Spill Test Date	09/28/2022	Piping Installed Date	04/04/2008	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	09/28/2022	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	05/31/2023	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	10000	ATG Test Date	05/31/2023	Line Tightness Test Date	09/28/2022	Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	Yes
		Overfill Test Date	12/27/2023			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Lake County in the City of Polson

Location: TOWN PUMP INC POLSON  
50667 US Hwy 93  
Polson, MT 59860 Lake

System Facility ID:24-08717

Facility Code: 23066  
Last Inspected On: 03/29/2023  
Operating Permit Renewal Date: 05/16/2024

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Polson 1 Town Pump LLC4064976700

Operator Contact: Trent Biggers

Owner/Operator: Polson 1 Town Pump LLC

Trent Biggers, UST Class A Operator  
Trent Biggers, UST Class B Global Operator

Tank Code	01	Tank Age	42	Tank Installed Date	09/01/1982	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	2490	Spill Test Date	08/23/2022	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	05/06/2021	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	08/23/2022	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	12000	ATG Test Date	03/29/2023	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	08/23/2022			ATG Type	Gilbarco-Veeder Root/TLS-450				
Tank Code	02	Tank Age	42	Tank Installed Date	09/01/1982	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	2491	Spill Test Date	08/23/2022	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	05/06/2021	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	08/23/2022	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	12000	ATG Test Date	03/29/2023	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	08/23/2022			ATG Type	Gilbarco-Veeder Root/TLS-450				

Tank Code	03	Tank Age	42	Tank Installed Date	09/01/1982	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	2492	Spill Test Date	08/23/2022	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	05/06/2021	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	08/23/2022	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	12000	ATG Test Date	03/29/2023	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	08/23/2022			ATG Type	Gilbarco-Veeder Root/TLS-450				
Tank Code	04	Tank Age	42	Tank Installed Date	09/01/1982	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	2493	Spill Test Date	08/23/2022	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	05/06/2021	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	08/23/2022	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	12000	ATG Test Date	03/29/2023	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	08/23/2022			ATG Type	Gilbarco-Veeder Root/TLS-450				
Tank Code	05	Tank Age	42	Tank Installed Date	09/01/1982	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	2494	Spill Test Date	08/23/2022	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	05/06/2021	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	08/23/2022	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	12000	ATG Test Date	03/29/2023	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	08/23/2022			ATG Type	Gilbarco-Veeder Root/TLS-450				
Tank Code	11	Tank Age	22	Tank Installed Date	10/24/2002	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	4819	Spill Test Date	08/23/2022	Piping Installed Date	10/24/2002	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No

Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	05/06/2021	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	01/04/2010	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	10000	ATG Test Date	03/29/2023	Line Tightness Test Date		Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	Yes
		Overfill Test Date	08/23/2022			ATG Type	Gilbarco-Veeder Root/TLS-450				
Tank Code	12	Tank Age	22	Tank Installed Date	10/24/2002	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	4820	Spill Test Date	08/23/2022	Piping Installed Date	10/24/2002	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	05/06/2021	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	01/04/2010	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	5000	ATG Test Date	08/23/2022	Line Tightness Test Date		Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	Yes
		Overfill Test Date	08/23/2022			ATG Type	Gilbarco-Veeder Root/TLS-450				
Tank Code	13	Tank Age	7	Tank Installed Date	11/09/2017	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Positive Shutoff
Tag Number	5782	Spill Test Date	08/23/2022	Piping Installed Date	11/09/2017	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	05/06/2021	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	Yes
Capacity	4000	ATG Test Date	03/29/2023	Line Tightness Test Date		Secondary Tank Leak Detection	Statistical Inventory Reconciliation	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	Yes
		Overfill Test Date	08/23/2022			ATG Type	Gilbarco-Veeder Root/TLS-450				
Tank Code	14	Tank Age	7	Tank Installed Date	11/09/2017	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Positive Shutoff
Tag Number	5791	Spill Test Date		Piping Installed Date	11/09/2017	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Other	MLLD Test Date		Sump Tightness Test Date	11/09/2017	Catastrophic L.D Type 3.0	Continuous Interstitial Monitoring	Piping Type	Pressurized	CP Met Types	

Product	DEF (Not Regulated)	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Primary Pipe Detection	Approved Remote Monitoring;Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	2000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring;Not Listed	Energy Act	Yes
		Overfill Test Date				ATG Type					

Facility Summary in Lake County in the City of Polson

Location: U OF M FLATHEAD LAKE BIOLOGICAL STATION  
32125 Bio Station Ln  
Polson, MT 59860 Lake

System Facility ID:24-00507

Facility Code: 22853  
Last Inspected On: 12/21/2020  
Operating Permit Renewal Date: 01/14/2021

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: University of Montana Flathead Lake Biological Station 4069823301

Operator Contact: Eric Anderson 4069823301

Owner/Operator: University of Montana Flathead Lake Biological Station  
C Anderson, UST Class B Operator  
Eric Anderson, UST Class A Operator  
Reggie Heiser, UST Class B Operator

Tank Code	05	Tank Age	33	Tank Installed Date	03/15/1991	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	2185	Spill Test Date		Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Permanently Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	U.S. Suction	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	08/08/2017	Primary Tank Leak Detection	Manual Interstitial Monitoring	Primary Pipe Detection	ELLD Line Tightness Testing;Not Listed	Vapor Recovery	No
Capacity	1000	ATG Test Date		Line Tightness Test Date	08/18/2017	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					
Tank Code	S6	Tank Age	33	Tank Installed Date	03/15/1991	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	2186	Spill Test Date		Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Temporarily Out of Use	MLLD Test Date		Sump Tightness Test Date	12/21/2020	Catastrophic L.D Type 3.0	Not Required	Piping Type	U.S. Suction	CP Met Types	Galvanic
Product	Heating Oil	PLLD Test Date		Tank/Piping CP Test Date	12/21/2020	Primary Tank Leak Detection	Manual Interstitial Monitoring	Primary Pipe Detection	3-Year Line Tightness Test	Vapor Recovery	No
Capacity	2000	ATG Test Date		Line Tightness Test Date	12/21/2020	Secondary Tank Leak Detection		Secondary Pipe Detection	Manual Interstitial Monitoring	Energy Act	No
		Overfill Test Date				ATG Type					

Facility Summary in Lake County in the City of Ravalli

Location: RAVALLI STORE  
205 Buffalo St  
Ravalli, MT 59863 Lake

System Facility ID:24-09997

Facility Code: 23099  
Last Inspected On: 12/17/2020  
Operating Permit Renewal Date: 12/17/2023

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Kenneth Cameron2083153517

Operator Contact: Stacy Harris4062390655

Owner/Operator: Kenneth Cameron

Stacy Harris, UST Class A Operator  
Stacy Harris, UST Class B Global Operator

Tank Code	01	Tank Age	35	Tank Installed Date	09/01/1989	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Positive Shutoff
Tag Number	3464	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Permanently Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	12/03/2020	Primary Tank Leak Detection	Automatic Tank Gauging 0.1;Automatic Tank Gauging 0.2	Primary Pipe Detection		Vapor Recovery	No
Capacity	1000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					
Tank Code	02	Tank Age	35	Tank Installed Date	09/01/1989	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Positive Shutoff
Tag Number	3465	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Permanently Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	12/03/2020	Primary Tank Leak Detection	Automatic Tank Gauging 0.1;Automatic Tank Gauging 0.2	Primary Pipe Detection		Vapor Recovery	No
Capacity	1000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					
Tank Code	03	Tank Age	35	Tank Installed Date	09/01/1989	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Positive Shutoff

Tag Number	3466	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Permanently Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	12/03/2020	Primary Tank Leak Detection	Automatic Tank Gauging 0.1;Automatic Tank Gauging 0.2	Primary Pipe Detection		Vapor Recovery	No
Capacity	1000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					

Facility Summary in Lake County in the City of Rollins

Location: POINTS NORTH TRADING CO  
87867 US Hwy 93  
Rollins, MT 59931 Lake

System Facility ID:24-12730

Facility Code: 23274  
Last Inspected On: 03/01/2022  
Operating Permit Renewal Date: 07/22/2025

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Points North of Rollins LLC4062507058

Operator Contact: Michael Serra;Thomas Gay4062507058;4068443942

Owner/Operator: Points North of Rollins LLC

Michael Serra, UST Class A Operator  
Michael Serra, UST Class B Global Operator  
Thomas A Gay, UST Class A Operator  
Thomas A Gay, UST Class B Operator

Tank Code	03	Tank Age	29	Tank Installed Date	06/01/1995	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	3095	Spill Test Date	09/24/2021	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date	09/24/2021	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	05/28/2019	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	8000	ATG Test Date	09/28/2021	Line Tightness Test Date	09/24/2021	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	03/01/2022			ATG Type	EMCO Electronics/EECO 1500				
Tank Code	04	Tank Age	29	Tank Installed Date	06/01/1995	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	3096	Spill Test Date	09/24/2021	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date	09/24/2021	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	05/28/2019	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	8000	ATG Test Date	09/28/2021	Line Tightness Test Date	09/24/2021	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	03/01/2022			ATG Type	EMCO Electronics/EECO 1500				

Tank Code	05	Tank Age	29	Tank Installed Date	06/01/1995	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	3097	Spill Test Date	09/24/2021	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date	09/24/2021	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	05/28/2019	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	4000	ATG Test Date	09/28/2021	Line Tightness Test Date	09/24/2021	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	03/01/2022			ATG Type	EMCO Electronics/EECO 1500				

Facility Summary in Lake County in the City of Ronan

Location: ARNIES GAS AND TIRE CENTER INC  
63145 US Hwy 93  
Ronan, MT 59864-2808 Lake

System Facility ID:24-05517

Facility Code: 22970  
Last Inspected On: 05/02/2023  
Operating Permit Renewal Date: 08/15/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Arnies Gas and Tire Center Inc4066750400

Operator Contact: Amanda Hackman;Denise Aipperspach4066760400

Owner/Operator: Arnies Gas and Tire Center Inc

Amanda Hackman, UST Class A Operator  
Amanda Hackman, UST Class B Global Operator  
Denise Aipperspach, UST Class A Operator  
Denise Aipperspach, UST Class B Global Operator  
Denise Aipperspach, UST Class B Operator

Tank Code	04	Tank Age	46	Tank Installed Date	05/07/1978	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	3888	Spill Test Date	05/02/2023	Piping Installed Date		Tank Construction	Lined Interior/Impressed Current	Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date	05/02/2023	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	05/02/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	12000	ATG Test Date	05/02/2023	Line Tightness Test Date	05/02/2023	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	05/02/2023			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	03	Tank Age	53	Tank Installed Date	05/08/1971	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	3889	Spill Test Date	05/02/2023	Piping Installed Date		Tank Construction	Lined Interior/Impressed Current	Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date	05/02/2023	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	05/02/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	4000	ATG Test Date	05/02/2023	Line Tightness Test Date	05/02/2023	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No

		Overfill Test Date	05/02/2023			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	02	Tank Age	53	Tank Installed Date	05/08/1971	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	3890	Spill Test Date	05/02/2023	Piping Installed Date		Tank Construction	Lined Interior/Impressed Current	Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date	05/02/2023	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	05/02/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	6000	ATG Test Date	05/02/2023	Line Tightness Test Date	05/02/2023	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	05/02/2023			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	01	Tank Age	53	Tank Installed Date	05/08/1971	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	3891	Spill Test Date	05/02/2023	Piping Installed Date		Tank Construction	Lined Interior/Impressed Current	Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date	05/02/2023	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	05/02/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	10000	ATG Test Date	05/02/2023	Line Tightness Test Date	05/02/2023	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	05/02/2023			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Lake County in the City of Ronan

Location: DYNO MART  
62945 Hwy 93 N  
Ronan, MT 59864 Lake

System Facility ID:24-05768

Facility Code: 22981  
Last Inspected On: 04/24/2023  
Operating Permit Renewal Date: 09/08/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: One Stop 3 Inc Loc 24066763570

Operator Contact: Maureen McCrea;Tom Hoyt4062745536

Owner/Operator: One Stop 3 Inc Loc 2

Gail Matt, UST Class B Global Operator  
Gail Matt, UST Class B Operator  
Maureen McCrea, UST Class A Operator  
Tom Hoyt, UST Class A Operator  
Tom Hoyt, UST Class B Operator

Tank Code	01	Tank Age	40	Tank Installed Date	11/13/1984	Tank Material	Bare Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	1315	Spill Test Date	08/05/2020	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date	07/30/2019	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	03/27/2019	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	10000	ATG Test Date		Line Tightness Test Date	07/30/2019	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	02	Tank Age	40	Tank Installed Date	11/13/1984	Tank Material	Bare Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	1316	Spill Test Date	03/27/2019	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date	07/30/2019	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	03/27/2019	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	8000	ATG Test Date		Line Tightness Test Date	07/30/2019	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No

		Overfill Test Date	03/27/2019			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	03	Tank Age	32	Tank Installed Date	04/01/1992	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	1317	Spill Test Date	03/27/2019	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date	07/30/2019	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	03/27/2019	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	10000	ATG Test Date		Line Tightness Test Date	07/30/2019	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	03/27/2019			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Lake County in the City of Ronan

Location: EAST OF RONAN MIDDLE SCHOOL  
200 Round Butte Rd W  
Ronan, MT 59864 Lake

System Facility ID:24-04824

Facility Code: 22953  
Last Inspected On: 05/25/2023  
Operating Permit Renewal Date: 09/13/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: School Dist 30 Ronan4066442448

Operator Contact: Brad Benson;Lawrence Cordis;Rob Tougas4062508008

Owner/Operator: School Dist 30 Ronan

- Brad Benson, UST Class A Operator
- Brad Benson, UST Class B Global Operator
- Lawrence Cordis, UST Class A Operator
- Lawrence Cordis, UST Class B Global Operator
- Matt Gaut, UST Class B Operator
- Rob Tougas, UST Class A Operator
- Rob Tougas, UST Class B Global Operator

Tank Code	S5	Tank Age	28	Tank Installed Date	08/01/1996	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Copper	Overfill Types	Flapper Valve
Tag Number	1904	Spill Test Date	05/25/2023	Piping Installed Date		Tank Construction		Piping Construction	Secondary Containment Chase	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	05/25/2023	Catastrophic L.D Type 3.0	Auto Dialer	Piping Type	U.S. Suction	CP Met Types	Non-corrodible
Product	Heating Oil	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	10000	ATG Test Date	05/25/2023	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	05/25/2023			ATG Type	Gilbarco-Veeder Root/Other				

Facility Summary in Lake County in the City of Ronan

Location: JOHNS FUEL FARM AND ENERGY  
14 Cleveland St SE  
Ronan, MT 59864-3027 Lake

System Facility ID:24-07437

Facility Code: 23032  
Last Inspected On: 02/18/2022  
Operating Permit Renewal Date: 04/26/2025

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact:	Johns Fuel Farm and Energy	4066763461
Operator Contact:	Hans Lund;John Noel;Leevi Wadsworth	4062617956;4066763461

Owner/Operator: Johns Fuel Farm and Energy

Hans Lund, UST Class A Operator  
Hans Lund, UST Class B Operator  
John Noel, UST Class A Operator  
John Noel, UST Class B Global Operator  
Leevi Wadsworth, UST Class A Operator  
Leevi Wadsworth, UST Class B Operator

Tank Code	01	Tank Age	63	Tank Installed Date	04/23/1961	Tank Material	Cathodically Protected Steel	Piping Material	Steel	Overfill Types	High Level Alarm
Tag Number	3394	Spill Test Date	10/04/2021	Piping Installed Date	08/10/2009	Tank Construction	Lined Interior/Impressed Current	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date	08/30/2022	Tank/Piping CP Test Date	10/26/2021	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	10000	ATG Test Date	08/30/2022	Line Tightness Test Date	08/30/2022	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	08/30/2022			ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	02	Tank Age	63	Tank Installed Date	04/23/1961	Tank Material	Cathodically Protected Steel	Piping Material	Steel	Overfill Types	High Level Alarm
Tag Number	3395	Spill Test Date	10/04/2021	Piping Installed Date	08/10/2009	Tank Construction	Lined Interior/Impressed Current	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Diesel	PLLD Test Date	08/30/2022	Tank/Piping CP Test Date	10/26/2021	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No

Capacity	10000	ATG Test Date	08/30/2022	Line Tightness Test Date	08/30/2022	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	08/30/2022			ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	03	Tank Age	53	Tank Installed Date	04/24/1971	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Steel	Overfill Types	High Level Alarm
Tag Number	3396	Spill Test Date	10/04/2021	Piping Installed Date	08/10/2009	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	08/30/2022	Tank/Piping CP Test Date	10/26/2021	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	8000	ATG Test Date	08/30/2022	Line Tightness Test Date	08/30/2022	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	08/30/2022			ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	04	Tank Age	53	Tank Installed Date	04/24/1971	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	3397	Spill Test Date	10/04/2021	Piping Installed Date	08/10/2009	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	08/30/2022	Tank/Piping CP Test Date	10/26/2021	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	8000	ATG Test Date	08/30/2022	Line Tightness Test Date	08/30/2022	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	08/30/2022			ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	05	Tank Age	53	Tank Installed Date	04/24/1971	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Steel	Overfill Types	High Level Alarm
Tag Number	3398	Spill Test Date	10/04/2021	Piping Installed Date	08/10/2009	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	08/30/2022	Tank/Piping CP Test Date	10/26/2021	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	6000	ATG Test Date	08/30/2022	Line Tightness Test Date	08/30/2022	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	08/30/2022			ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	06	Tank Age	63	Tank Installed Date	04/23/1961	Tank Material	Cathodically Protected Steel	Piping Material	Steel	Overfill Types	High Level Alarm

Tag Number	3399	Spill Test Date	10/04/2021	Piping Installed Date	08/10/2009	Tank Construction	Lined Interior/Impressed Current	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date	08/30/2022	Tank/Piping CP Test Date	10/26/2021	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	6000	ATG Test Date	08/30/2022	Line Tightness Test Date	08/30/2022	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	08/30/2022			ATG Type	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Lake County in the City of Ronan

Location: MOUNTAIN WEST CO OP RONAN  
63932 US Hwy 93  
Ronan, MT 59864 Lake

System Facility ID:24-04530

Facility Code: 22944  
Last Inspected On: 09/13/2022  
Operating Permit Renewal Date: 12/19/2025

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact:	CHS Mountain West Coop	4066762201
Operator Contact:	Bob Westin;Dusty Smith;John Thompson;Will Dukart	4065416800;4065438383

Owner/Operator: CHS Mountain West Coop

- Bob Westin, UST Class A Operator
- Bob Westin, UST Class B Global Operator
- Carrie Clairmont, UST Class B Operator
- Dusty Smith, UST Class A Operator
- Dusty Smith, UST Class B Global Operator
- John Thompson, UST Class A Operator
- John Thompson, UST Class B Global Operator
- John Thompson, UST Class B Operator
- Will Dukart, UST Class A Operator
- Will Dukart, UST Class B Global Operator

Tank Code	09	Tank Age	27	Tank Installed Date	05/01/1997	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	2829	Spill Test Date	03/09/2022	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date	05/21/2019	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	09/13/2022	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	Yes
Capacity	10000	ATG Test Date	09/13/2022	Line Tightness Test Date	09/13/2022	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.1	Energy Act	No
		Overfill Test Date	09/13/2022			ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	10	Tank Age	27	Tank Installed Date	05/01/1997	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	2830	Spill Test Date	03/09/2022	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date	05/21/2019	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible

Product	Gasoline	PLLD Test Date	09/13/2022	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	Yes
Capacity	4000	ATG Test Date	09/13/2022	Line Tightness Test Date	09/13/2022	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.1	Energy Act	No
		Overfill Test Date	09/13/2022			ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	11	Tank Age	27	Tank Installed Date	05/01/1997	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	2831	Spill Test Date	03/09/2022	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date	05/21/2019	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	09/13/2022	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	4000	ATG Test Date	09/13/2022	Line Tightness Test Date	09/13/2022	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.1	Energy Act	No
		Overfill Test Date	09/13/2022			ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	12	Tank Age	27	Tank Installed Date	05/01/1997	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	2832	Spill Test Date	03/09/2022	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date	05/21/2019	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel, Dyed	PLLD Test Date	09/13/2022	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	6000	ATG Test Date	09/13/2022	Line Tightness Test Date	09/13/2022	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.1	Energy Act	No
		Overfill Test Date	09/13/2022			ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	13	Tank Age	27	Tank Installed Date	05/01/1997	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	2833	Spill Test Date	03/09/2022	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date	05/21/2019	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	09/13/2022	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	5000	ATG Test Date	09/13/2022	Line Tightness Test Date	09/13/2022	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.1	Energy Act	No
		Overfill Test Date	09/13/2022			ATG Type	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Lake County in the City of Ronan

Location: RONAN AIRPORT  
35564 Ronan Airport Rd  
Ronan, MT 59864-9267 Lake

System Facility ID:24-04649

Facility Code: 22948  
Last Inspected On: 09/14/2021  
Operating Permit Renewal Date: 10/22/2024

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Lake County Joint Airport Board4068837214

Operator Contact: Vinson Jennison

Owner/Operator: Lake County Joint Airport Board

Vinson Jennison, UST Class A Operator  
Vinson Jennison, UST Class B Global Operator

Tank Code	02	Tank Age	25	Tank Installed Date	04/01/1999	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve;High Level Alarm
Tag Number	3984	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	08/02/2019	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Jet Fuel (Jet-A, Jet-A1, JP5)	PLLD Test Date	03/07/2023	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	12000	ATG Test Date	03/03/2023	Line Tightness Test Date	03/03/2023	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Code	03	Tank Age	25	Tank Installed Date	04/01/1999	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve;High Level Alarm
Tag Number	3985	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	08/02/2019	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Aviation Gas	PLLD Test Date	03/07/2023	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	12000	ATG Test Date	03/03/2023	Line Tightness Test Date	03/03/2023	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No

		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS- 450PLUS				
--	--	--------------------	--	--	--	----------	---	--	--	--	--

Facility Summary in Lake County in the City of Ronan

Location: ST LUKE COMMUNITY CLINIC- RONAN  
107 6th Ave SW  
Ronan, MT 59864 Lake

System Facility ID:24-03736

Facility Code: 22926  
Last Inspected On: 06/20/2023  
Operating Permit Renewal Date: 10/16/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Saint Luke Hospital4066764441

Operator Contact: Gary Burdett;Nicholas Emerson;Steven DeLay4062405240;4066764441

Owner/Operator: Saint Luke Hospital

- Gary Burdett, UST Class A Operator
- Gary Burdett, UST Class B Operator
- Nicholas Emerson, UST Class A Operator
- Nicholas Emerson, UST Class B Operator
- Steven DeLay, UST Class A Operator
- Steven DeLay, UST Class B Operator

Tank Code	S3	Tank Age	25	Tank Installed Date	11/01/1999	Tank Material	Unknown	Piping Material	Copper	Overfill Types	
Tag Number	4369	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	Secondary Containment Chase	AST	Yes
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	08/25/2020	Catastrophic L.D Type 3.0	Auto Dialer	Piping Type	U.S. Suction	CP Met Types	
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection		Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	2000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					

Facility Summary in Lake County in the City of Ronan

Location: TOWN PUMP INC RONAN  
63459 US Hwy 93  
Ronan, MT 59864-3007 Lake

System Facility ID:24-08718

Facility Code: 23067  
Last Inspected On: 03/29/2023  
Operating Permit Renewal Date: 09/30/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Ronan 1 Town Pump LLC4064976700

Operator Contact: Trent Biggers

Owner/Operator: Ronan 1 Town Pump LLC

Trent Biggers, UST Class A Operator  
Trent Biggers, UST Class B Global Operator

Tank Code	01	Tank Age	52	Tank Installed Date	04/14/1972	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	4822	Spill Test Date	08/22/2022	Piping Installed Date		Tank Construction	Lined Interior/Impressed Current	Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date	05/13/2021	Tank/Piping CP Test Date	08/22/2022	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	12000	ATG Test Date	03/29/2023	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	08/22/2022			ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	02	Tank Age	52	Tank Installed Date	04/14/1972	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	4823	Spill Test Date	08/22/2022	Piping Installed Date		Tank Construction	Lined Interior/Impressed Current	Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date	05/13/2021	Tank/Piping CP Test Date	08/22/2022	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	12000	ATG Test Date	03/29/2023	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	08/22/2022			ATG Type	Gilbarco-Veeder Root/TLS-350				

Tank Code	03	Tank Age	52	Tank Installed Date	04/14/1972	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	4824	Spill Test Date	08/22/2022	Piping Installed Date		Tank Construction	Lined Interior/Impressed Current	Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date	05/13/2021	Tank/Piping CP Test Date	08/22/2022	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	6000	ATG Test Date	03/29/2023	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	08/22/2022			ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	04	Tank Age	0	Tank Installed Date		Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	4825	Spill Test Date	08/22/2022	Piping Installed Date		Tank Construction	Lined Interior/Impressed Current	Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Diesel	PLLD Test Date	05/13/2021	Tank/Piping CP Test Date	08/22/2022	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	6000	ATG Test Date	03/29/2023	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	08/22/2022			ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	05	Tank Age	17	Tank Installed Date	07/05/2007	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve;Flapper Valve
Tag Number	5073	Spill Test Date	08/22/2022	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	05/13/2021	Tank/Piping CP Test Date		Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	12000	ATG Test Date	03/29/2023	Line Tightness Test Date		Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	08/22/2022			ATG Type	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Lake County in the City of Saint Ignatius

Location: ALLARDS STAGE STOP LLC  
77579 US Hwy 93 N  
Saint Ignatius, MT 59865-0460 Lake

System Facility ID:24-05769

Facility Code: 22982  
Last Inspected On: 01/25/2024  
Operating Permit Renewal Date: 03/13/2024

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Mission View Properties LLC5099946599

Operator Contact: Mamie Ahlborn4062072810

Owner/Operator: Mission View Properties LLC

Mamie Ahlborn, UST Class A Operator  
Mamie Ahlborn, UST Class B Global Operator

Tank Code	04	Tank Age	19	Tank Installed Date	12/01/2005	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	5042	Spill Test Date		Piping Installed Date	06/04/2019	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	09/20/2022	Sump Tightness Test Date	02/01/2019	Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	10000	ATG Test Date	09/20/2022	Line Tightness Test Date	09/20/2022	Secondary Tank Leak Detection		Secondary Pipe Detection	MLLD Line Tightness Testing	Energy Act	Yes
		Overfill Test Date	09/20/2022			ATG Type	Veeder Root/TLS-300				
Tank Code	05	Tank Age	19	Tank Installed Date	12/01/2005	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	5043	Spill Test Date		Piping Installed Date	06/04/2019	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	09/20/2022	Sump Tightness Test Date	02/01/2019	Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	10000	ATG Test Date	09/20/2022	Line Tightness Test Date	09/20/2022	Secondary Tank Leak Detection		Secondary Pipe Detection	MLLD Line Tightness Testing	Energy Act	Yes
		Overfill Test Date	09/20/2022			ATG Type	Veeder Root/TLS-300				

Facility Summary in Lake County in the City of Saint Ignatius

Location: MOUNTAIN VIEW CENEX  
240 Mountain View Dr  
Saint Ignatius, MT 59865 Lake

System Facility ID:24-10647

Facility Code: 23153  
Last Inspected On: 09/13/2023  
Operating Permit Renewal Date: 09/13/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Mission View Properties LLC5099946599

Operator Contact: Mamie Ahlborn4062072810

Owner/Operator: Mission View Properties LLC

Mamie Ahlborn, UST Class A Operator  
Mamie Ahlborn, UST Class B Global Operator  
Mamie Ahlborn, UST Class B Operator

Tank Code	06	Tank Age	29	Tank Installed Date	05/01/1995	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	4595	Spill Test Date	06/22/2023	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	10/12/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection		Vapor Recovery	No
Capacity	8000	ATG Test Date	10/12/2023	Line Tightness Test Date	08/22/2017	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	10/12/2023			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	07	Tank Age	29	Tank Installed Date	05/01/1995	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	4596	Spill Test Date	06/22/2023	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date	10/12/2023	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	10/12/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	8000	ATG Test Date	10/12/2023	Line Tightness Test Date	09/26/2022	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	10/12/2023			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Tank Code	08	Tank Age	29	Tank Installed Date	05/01/1995	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	4597	Spill Test Date	04/13/2023	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date	10/12/2023	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	10/12/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	6000	ATG Test Date	10/12/2023	Line Tightness Test Date	09/26/2022	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	10/12/2023			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	09	Tank Age	9	Tank Installed Date	10/01/2015	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	5619	Spill Test Date	04/13/2023	Piping Installed Date	10/23/2015	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	10/12/2023	Sump Tightness Test Date	10/23/2015	Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	8000	ATG Test Date	10/12/2023	Line Tightness Test Date	09/26/2022	Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	MLLD Line Tightness Testing	Energy Act	Yes
		Overfill Test Date	10/12/2023			ATG Type	Gilbarco-Veeder Root/TLS-350;Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Lake County in the City of Saint Ignatius

Location: SAINT IGNATIUS SCHOOL  
4th & Blaine St  
Saint Ignatius, MT 59865 Lake

System Facility ID:24-03762

Facility Code: 22927  
Last Inspected On: 02/08/2024  
Operating Permit Renewal Date: 02/08/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: School Dist 28 Saint Ignatius 4067453811

Operator Contact: Stephen McCollum 4063967842

Owner/Operator: School Dist 28 Saint Ignatius

Stephen McCollum, UST Class A Operator  
Stephen McCollum, UST Class B Global Operator

Tank Code	03	Tank Age	27	Tank Installed Date	06/01/1997	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	4563	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Temporarily Out of Use	MLLD Test Date		Sump Tightness Test Date	08/18/2020	Catastrophic L.D Type 3.0	Auto Dialer	Piping Type	U.S. Suction	CP Met Types	Galvanic
Product	Heating Oil	PLLD Test Date		Tank/Piping CP Test Date	10/24/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	10000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type	EMCO Electronics/EECO 1500				