

Facility Summary in Lake County in the City of Arlee

Location: WILSON FOODS
92345 US Hwy 93
Arlee, MT 59821-9433 Lake

Legacy ID:24-06788

Facility ID: 23006
Last Inspected On: 02/22/2021
Operating Permit Renewal Date: 03/21/2024

Owner Operator Contact:

Operator Contact: John Carranco

4065490891

Owner/Operator: Wilson Foods

John Carranco, UST Class A Operator

John Carranco, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
10	23	11/01/1998	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
3320	No			None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	No
10,000		10/19/2017	Gilbarco-Veeder Root/TLS-300		No
11	23	11/01/1998	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
3321	No			None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	No
4,000		10/19/2017	Gilbarco-Veeder Root/TLS-300		No
12	23	11/01/1998	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
3322	No			None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Non-corrodible

Diesel		Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	No
4,000	10/19/2017	Gilbarco-Veeder Root/TLS-300		No

Facility Summary in Lake County in the City of Big Arm

Location: BIG ARM MARINA
509 A St
Big Arm, MT 59910 Lake

Legacy ID:24-06856

Facility ID: 23009
Last Inspected On:
Operating Permit Renewal Date:

Owner Operator Contact: Stuarts Distributing **4068835600**

Operator Contact:

Owner/Operator: Stuart A Morton

Owner/Operator: Stuarts Distributing

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
03	5	12/01/2016	Fiberglass Reinforced Plastic	Flexible Plastic	
	No				No
Currently in Use		12/01/2016		Pressurized	
Gasoline			Automatic Tank Gauging 0.2	Not Listed	No
10,000					No

Facility Summary in Lake County in the City of Charlo

Location: CHARLO SCHOOL DIST 7 J
405 2nd Ave E
Charlo, MT 59824 Lake

Legacy ID:24-02789

Facility ID: 22907
Last Inspected On: 03/19/2021
Operating Permit Renewal Date: 03/27/2024

Owner Operator Contact: School Dist 7 J Charlo **4066442207**

Operator Contact: Joe Broom;School Dist 7 J Charlo **4062498000;4066442207**

Owner/Operator: School Dist 7 J Charlo

Joe Broom, UST Class A Operator
Joe Broom, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
S5	23	07/01/1998	Unknown	Flexible Plastic	High Level Alarm
611	Yes	08/22/2017		Double Walled	Yes
Currently in Use		07/09/2012	Auto Dialer	U.S. Suction	
Heating Oil			Deferred	Continuous Interstitial Monitoring	No
10,000		08/27/2012			No

Facility Summary in Lake County in the City of Charlo

Location: COULTER AUTOMOTIVE INC
104 Main St
Charlo, MT 59824-0097 Lake

Legacy ID:24-04615

Facility ID: 22947
Last Inspected On: 03/29/2019
Operating Permit Renewal Date: 04/01/2022

Owner Operator Contact: Coulter Automotive Inc

4066442215

Operator Contact: Sandra Coulter

4066442215

Owner/Operator: Coulter Automotive Inc

Sandra Coulter, UST Class A Operator
Sandra Coulter, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
03	26	07/01/1995	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve
2281	No			None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		04/04/2018	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	No

6,000		07/18/2018	EMCO Electronics/EECO 1500		No
04	26	07/01/1995	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve
2282	No			None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		04/04/2018	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	No
4,000		07/18/2018	EMCO Electronics/EECO 1500		No

Facility Summary in Lake County in the City of Charlo

Location: MOIESE MERCANTILE
64620 MT Hwy 212
Charlo, MT 59824-9004 Lake

Legacy ID:24-06382

Facility ID: 22995
Last Inspected On: 05/27/2019
Operating Permit Renewal Date: 06/24/2022

Owner Operator Contact: Moiese Mercantile

4066442385

Operator Contact: Timothy Hall

4066442385

Owner/Operator: Moiese Mercantile

Leslie Muth, UST Class B Operator
Timothy Hall, UST Class A Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
03	22	03/01/1999	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve
3968	No			None	Yes
Temporarily Out of Use			Not Required	Safe Suction	
Gasoline			Statistical Inventory Reconciliation	Deferred	No
1,000		10/25/2004			No

Facility Summary in Lake County in the City of Pablo

Location: PABLO ELEMENTARY SCHOOL
608 4th Ave
Pablo, MT 59855 Lake

Legacy ID:24-04823

Facility ID: 22952
Last Inspected On: 10/24/2020
Operating Permit Renewal Date: 09/25/2023

Owner Operator Contact: School Dist 30 Ronan

4066763390

Operator Contact: Brad Benson;Lawrence Cordis;Rob Tougas

4062508008

Owner/Operator: School Dist 30 Ronan

Brad Benson, UST Class A Operator
Brad Benson, UST Class B Global Operator
Lawrence Cordis, UST Class A Operator
Lawrence Cordis, UST Class B Global Operator
Rob Tougas, UST Class A Operator
Rob Tougas, UST Class B Global Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
S1	55	04/28/1966	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve
1903	No	04/25/2017	Lined Interior/Impressed Current	Double Walled	Yes
Currently in Use			Auto Dialer	Pressurized	Impressed Current
Heating Oil		04/25/2017	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring	No
8,000			Veeder Root/TLS-300		No

Facility Summary in Lake County in the City of Pablo

Location: QUICKSILVER EXPRESS
52001 US Hwy 93
Pablo, MT 59855 Lake

Legacy ID:24-11124

Facility ID: 23179
Last Inspected On: 01/30/2020
Operating Permit Renewal Date: 03/16/2023

Owner Operator Contact:

Operator Contact: Lisa Vollin-Christensen

4065596643

Owner/Operator: Quick Silver Express

Corky Sias, UST Class B Operator
Lisa Vollin-Christensen, UST Class A Operator
Lisa Vollin-Christensen, UST Class B Global Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
01	34	01/01/1987	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
3296	No			None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		03/16/2017	Automatic Tank Gauging 0.2	ELLD 0.2	No
8,000		03/16/2017	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
02	34	01/01/1987	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
3297	No			None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		03/16/2017	Automatic Tank Gauging 0.2	ELLD 0.2	No
8,000		03/16/2017	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
03	34	01/01/1987	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
3298	No			None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		03/16/2017	Automatic Tank Gauging 0.2	ELLD 0.2	No
8,000		03/16/2017	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
04	10	05/01/2011	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
5344	No		Double-Walled	Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible

Gasoline	03/16/2017	Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	Continuous Interstitial Monitoring;ELLD 0.2	No
12,000	03/16/2017	Gilbarco-Veeder Root/TLS- 350/Gilbarco EMC		Yes

Facility Summary in Lake County in the City of Pablo

Location: TWO EAGLE RIVER SCHOOL
52096 US Hwy 93
Pablo, MT 59855 Lake

Legacy ID:24-12096

Facility ID: 23249
Last Inspected On:
Operating Permit Renewal Date:

Owner Operator Contact: Confederated Salish and Kootenai Tribes

Operator Contact:

Owner/Operator: Confederated Salish and Kootenai Tribes

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
S1	33	12/29/1988	Cathodically Protected Steel	Unknown	
	No		Double-Walled	None	Yes
Currently in Use				Not Listed	
Heating Oil			Vapor Monitoring	Not Listed	No
12,000					No

Facility Summary in Lake County in the City of Polson

Location: CHERRY VALLEY SCHOOL
107 8th Ave W
Polson, MT 59860-2911 Lake

Legacy ID:24-02867

Facility ID: 22909
Last Inspected On: 01/27/2021
Operating Permit Renewal Date: 02/19/2024

Owner Operator Contact: School Dist 23 Polson

4068836333

Operator Contact: Dan Giles;Dan Kinyon;John Hipp

4062492564

Owner/Operator: School Dist 23 Polson

Dan Giles, UST Class A Operator

Dan Giles, UST Class B Operator

Dan Kinyon, UST Class A Operator
 Dan Kinyon, UST Class B Operator
 John Hipp, UST Class A Operator
 John Hipp, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
S2	31	08/01/1990	Cathodically Protected Steel	Flexible Plastic	Flapper Valve
1805	No		Double-Walled	Double Walled	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Heating Oil		10/16/2017	Continuous Interstitial Monitoring	3-Year Line Tightness Test	No
4,000		10/16/2017	Gilbarco-Veeder Root/ILS-250		No

Facility Summary in Lake County in the City of Polson

Location: GOLDES
 33537 MT Hwy 35
 Polson, MT 59860 Lake

Legacy ID:60-15208

Facility ID: 30928
Last Inspected On: 06/15/2021
Operating Permit Renewal Date: 07/16/2024

Owner Operator Contact: Jeffry Goldes

4064430454

Operator Contact: Serena Keller;Travis Schenck

4068376679;4068851530

Owner/Operator: Jeffry Goldes

Frank Jasper, UST Class B Operator
 Serena Keller, UST Class A Operator
 Serena Keller, UST Class B Operator
 Travis Schenck, UST Class A Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act

S2	9	05/01/2012	Aboveground Tank	Flexible Plastic	
5365	Yes	07/12/2018		Double Walled	No
Currently in Use		04/17/2012	Continuous Interstitial Monitoring	Gravity Feed	
Gasoline			Deferred	Continuous Interstitial Monitoring	No
500					Yes

Facility Summary in Lake County in the City of Polson

Location: JETTE STORE
44613 US Hwy 93
Polson, MT 59860-7585 Lake

Legacy ID:24-07247

Facility ID: 23026
Last Inspected On: 10/02/2020
Operating Permit Renewal Date: 12/02/2023

Owner Operator Contact: Grits Inc

4068833861

Operator Contact: Jeff Schumaker;Paul Bonelli

Owner/Operator: Grits Inc

Jeff Schumaker, UST Class A Operator
Jeff Schumaker, UST Class B Global Operator
Paul Bonelli, UST Class A Operator
Paul Bonelli, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
04	25	04/01/1996	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
1215	No			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring;ELLD 0.2	No
12,000			Incon/TS-1000		No
05	25	04/01/1996	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
1216	No			Double Walled	Yes

Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring; ELLD 0.2	No
8,000			Incon/TS-1000		No
06	25	04/01/1996	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
1217	No			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel			Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring; ELLD 0.2	No
5,000			Incon/TS-1000		No

Facility Summary in Lake County in the City of Polson

Location: KWATAQNUK RESORT
49708 US Hwy 93
Polson, MT 59860-2305 Lake

Legacy ID:56-13869

Facility ID: 30548
Last Inspected On: 05/09/1997
Operating Permit Renewal Date:

Owner Operator Contact: Confederated Salish and Kootenai Tribes

Operator Contact:

Owner/Operator: Confederated Salish and Kootenai Tribes

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
01	30	05/01/1991	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
	No		Double-Walled	Double Walled	Yes
Currently in Use				Pressurized	
Gasoline			Continuous Interstitial Monitoring	Continuous Interstitial Monitoring; MLLD Line Tightness Testing	No
10,000					No

Facility Summary in Lake County in the City of Polson

Location: MOUNTAIN WEST CO OP POLSON
808 Main St
Polson, MT 59860-3227 Lake

Legacy ID:24-04560

Facility ID: 22946
Last Inspected On: 10/02/2020
Operating Permit Renewal Date: 12/02/2023

Owner Operator Contact: CHS Mountain West Coop

Operator Contact: Bob Westin;Dusty Smith;John Thompson;Will Dukart **4066651728;4067557427;4068808169**

Owner/Operator: CHS Mountain West Coop

Bob Westin, UST Class A Operator
Bob Westin, UST Class B Global Operator
Dusty Smith, UST Class A Operator
Dusty Smith, UST Class B Global Operator
John Adams, UST Class B Operator
John Thompson, UST Class A Operator
John Thompson, UST Class B Global Operator
John Thompson, UST Class B Operator
Will Dukart, UST Class A Operator
Will Dukart, UST Class B Global Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
05	21	01/01/2000	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4155	No	06/15/2017		Double Walled	Yes
Currently in Use			Auto Dialer;Mechanical Line Leak Detector	Pressurized	Non-corrodible
Diesel			Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring;MLLD Line Tightness Testing	No
6,000			Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
06	21	01/01/2000	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4156	No	06/15/2017		Double Walled	Yes
Currently in Use		10/09/2013	Auto Dialer;Mechanical Line Leak Detector	Pressurized	Non-corrodible

Gasoline			Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring;MLLD Line Tightness Testing	No
5,000			Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
08	21	01/01/2000	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4648	No	06/15/2017		Double Walled	Yes
Currently in Use			Auto Dialer;Mechanical Line Leak Detector	Pressurized	Non-corrodible
Diesel			Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring;MLLD Line Tightness Testing	No
5,000			Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
07	21	01/01/2000	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4741	No	06/15/2017		Double Walled	Yes
Currently in Use			Auto Dialer;Mechanical Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring;MLLD Line Tightness Testing	No
10,000			Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No

Facility Summary in Lake County in the City of Polson

Location: PIER 93
49433 US Hwy 93
Polson, MT 59860 Lake

Legacy ID:24-05957

Facility ID: 22988
Last Inspected On: 04/18/2019
Operating Permit Renewal Date: 06/30/2022

Owner Operator Contact: Jacks Pier 93;Jacob Miller;Jacks Pier 93

4068835768

Operator Contact: Donald Miller;Jacob Miller

4063763210;4068835768

Owner/Operator: Jacks Pier 93

Donald Miller, UST Class A Operator
Donald Miller, UST Class B Operator
Jacob Miller, UST Class A Operator
Jacob Miller, UST Class B Global Operator
Jacob Miller, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected

Status	Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types	
Product	Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery	
Capacity	Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act	
01	35	04/23/1986	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve
1802	No			Single Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Diesel		05/14/2015	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	No
4,000		08/01/2009	Gilbarco-Veeder Root/TLS-350		No
02	35	04/23/1986	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve
1803	No			Single Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		05/14/2015	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	No
6,000		08/01/2009	Gilbarco-Veeder Root/TLS-350		No
06	31	11/01/1990	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve
1804	No			Single Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		05/14/2015	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	No
10,000		09/07/2018	Gilbarco-Veeder Root/TLS-350		No

Facility Summary in Lake County in the City of Polson

Location: POLSON BAY GROCERY 425
50451 US Hwy 93
Polson, MT 59860 Lake

Legacy ID:24-05770

Facility ID: 22983
Last Inspected On: 06/17/2020
Operating Permit Renewal Date: 08/09/2023

Owner Operator Contact: Dirk Cooper;Hi Noon Petroleum Missoula

4065420384

Operator Contact: George Mahoney;Jagpreet Ghuman

4068807677

Owner/Operator: Jays Corporation

George Mahoney, UST Class A Operator
George Mahoney, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
04	19	05/23/2002	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
4664	No	06/23/2013		Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring; ELLD 0.2	No
20,000			Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
05	19	05/23/2002	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
4665	No	06/23/2013		Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring; ELLD 0.2	No
10,000			Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
06	19	05/23/2002	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
4666	No	06/23/2013		Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel			Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring; ELLD 0.2	No
6,000			Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
07	19	05/23/2002	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
4667	No	06/23/2013		Double Walled	Yes

Currently in Use	Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring; ELLD 0.2	No
4,000	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No

Facility Summary in Lake County in the City of Polson

Location: POLSON COUNTRY CLUB
111 Bayview Dr
Polson, MT 59860-9609 Lake

Legacy ID:24-11824

Facility ID: 23227
Last Inspected On: 07/16/2019
Operating Permit Renewal Date: 11/08/2022

Owner Operator Contact: City of Polson

4068832131

Operator Contact: Natalia Arlint;Patrick Nowlen

4062495141

Owner/Operator: City of Polson

Natalia Arlint, UST Class A Operator
Natalia Arlint, UST Class B Operator
Patrick Nowlen, UST Class A Operator
Patrick Nowlen, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
01	31	08/14/1990	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve
647	No			None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Gasoline		09/16/2016	Manual Tank Gauging	Deferred	No
500					No

Facility Summary in Lake County in the City of Polson

Location: SAFEWAY FUEL STATION 1646
40772 MT Hwy 35
Polson, MT 59860 Lake

Legacy ID:60-15097

Facility ID: 30857
Last Inspected On: 03/08/2021
Operating Permit Renewal Date: 03/28/2024

Owner Operator Contact: Safeway Stores Inc

Owner/Operator: Safeway Stores Inc

Aaron Nelson, UST Class A Operator
 Cindy Standbrook, UST Class A Operator
 Cindy Stankbrook, UST Class B Global Operator
 Heidi Morgan, UST Class B Global Operator
 Lynn Pehrson, UST Class A Operator
 Rachel Jones , UST Class A Operator
 Rachel Jones , UST Class B Global Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
01	13	05/22/2008	Steel Clad	Flexible Plastic	High Level Alarm
5164	No		Double-Walled	Double Walled	Yes
Currently in Use		04/04/2008	Electronic Line Leak Detector	Pressurized	
Gasoline			Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	Continuous Interstitial Monitoring;ELLD 0.2	No
20,000			Gilbarco-Veeder Root/TLS- 350/Gilbarco EMC		Yes
02	13	05/22/2008	Steel Clad	Flexible Plastic	High Level Alarm
5165	No		Double-Walled	Double Walled	Yes
Currently in Use		04/04/2008	Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	Continuous Interstitial Monitoring;ELLD 0.2	No
10,000			Gilbarco-Veeder Root/TLS- 350/Gilbarco EMC		Yes
03	13	05/22/2008	Steel Clad	Flexible Plastic	High Level Alarm
5166	No		Double-Walled	Double Walled	Yes

Currently in Use	04/04/2008	Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel		Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	Continuous Interstitial Monitoring;ELLD 0.2	No
10,000		Gilbarco-Veeder Root/TLS- 350/Gilbarco EMC		Yes

Facility Summary in Lake County in the City of Polson

Location: TOWN PUMP INC POLSON
50667 US Hwy 93
Polson, MT 59860 Lake

Legacy ID:24-08717

Facility ID: 23066
Last Inspected On: 11/25/2020
Operating Permit Renewal Date: 05/16/2024

Owner Operator Contact: Don Edmisten;Major Enterprises Inc

4064976948;4064976700

Operator Contact: Trent Biggers

Owner/Operator: Polson 1 Town Pump LLC

Trent Biggers, UST Class A Operator
Trent Biggers, UST Class B Global Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
01	39	09/01/1982	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve
2490	No			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		01/12/2016	Approved Remote Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
12,000			Gilbarco-Veeder Root/TLS-450		No
02	39	09/01/1982	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve
2491	No			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic

Gasoline		01/12/2016	Approved Remote Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
12,000			Gilbarco-Veeder Root/TLS-450		No
03	39	09/01/1982	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve
2492	No			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		01/12/2016	Approved Remote Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
12,000			Gilbarco-Veeder Root/TLS-450		No
04	39	09/01/1982	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve
2493	No			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		01/12/2016	Approved Remote Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
12,000			Gilbarco-Veeder Root/TLS-450		No
05	39	09/01/1982	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve
2494	No			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		01/12/2016	Approved Remote Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
12,000			Gilbarco-Veeder Root/TLS-450		No
11	19	10/24/2002	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4819	No		Double-Walled	Double Walled	Yes
Currently in Use		10/24/2002	Electronic Line Leak Detector	Pressurized	Non-corrodible

Diesel		01/04/2010	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
10,000			Gilbarco-Veeder Root/TLS-450		Yes
12	19	10/24/2002	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4820	No		Double-Walled	Double Walled	Yes
Currently in Use		10/24/2002	Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel		01/04/2010	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
5,000			Gilbarco-Veeder Root/TLS-450		Yes
13	4	11/09/2017	Fiberglass Reinforced Plastic	Flexible Plastic	Positive Shutoff
5782	No	11/09/2017	Double-Walled	Double Walled	Yes
Currently in Use		11/09/2017	Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Yes
4,000			Gilbarco-Veeder Root/TLS-450		Yes

Facility Summary in Lake County in the City of Polson

Location: U OF M FLATHEAD LAKE BIOLOGICAL STATION
32125 Bio Station Ln
Polson, MT 59860 Lake

Legacy ID:24-00507

Facility ID: 22853
Last Inspected On: 12/29/2020
Operating Permit Renewal Date: 01/14/2024

Owner Operator Contact: University of Montana Flathead Lake Biological Station **4069823301**

Operator Contact: Eric Anderson **4069823301**

Owner/Operator: University of Montana Flathead Lake Biological Station

C Anderson, UST Class B Operator
Eric Anderson, UST Class A Operator
Reggie Heiser, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected

Status	Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types	
Product	Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery	
Capacity	Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act	
S6	30	03/15/1991	Cathodically Protected Steel	Flexible Plastic	Flapper Valve
2186	No	07/25/2017	Double-Walled	Double Walled	Yes
Currently in Use		Not Required	U.S. Suction	Galvanic	
Heating Oil	08/08/2017	Manual Interstitial Monitoring	3-Year Line Tightness Test;Manual Interstitial Monitoring	No	
2,000				No	

Facility Summary in Lake County in the City of Ravalli

Location: RAVALLI STORE
205 Buffalo St
Ravalli, MT 59863 Lake

Legacy ID:24-09997

Facility ID: 23099
Last Inspected On: 12/17/2020
Operating Permit Renewal Date:

Owner Operator Contact:

Operator Contact: Stacy Harris

4062390655

Owner/Operator: Days Rest LLC

Owner/Operator: Verna K Gunderson

Stacy Harris, UST Class A Operator

Stacy Harris, UST Class B Global Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status	Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types	
Product	Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery	
Capacity	Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act	
01	32	09/01/1989	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Positive Shutoff
3464	No			Double Walled	Yes
Temporarily Out of Use		Not Required	Safe Suction	Galvanic	
Gasoline	04/12/2018	Automatic Tank Gauging 0.1;Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring	No	

1,000					No
02	32	09/01/1989	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Positive Shutoff
3465	No			Double Walled	Yes
Temporarily Out of Use			Not Required	Safe Suction	Galvanic
Gasoline		04/12/2018	Automatic Tank Gauging 0.1;Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring	No
1,000					No
03	32	09/01/1989	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Positive Shutoff
3466	No			Double Walled	Yes
Temporarily Out of Use			Not Required	Safe Suction	Galvanic
Diesel		04/12/2018	Automatic Tank Gauging 0.1;Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring	No
1,000					No

Facility Summary in Lake County in the City of Rollins

Location: POINTS NORTH TRADING CO
87867 US Hwy 93
Rollins, MT 59931 Lake

Legacy ID:24-12730

Facility ID: 23274
Last Inspected On: 06/05/2019
Operating Permit Renewal Date: 07/22/2022

Owner Operator Contact:

Operator Contact: Michael Serra;Thomas Gay

4062507058;4068443942

Owner/Operator: Points North of Rollins LLC

Michael Serra, UST Class A Operator
Michael Serra, UST Class B Global Operator
Thomas A Gay, UST Class A Operator
Thomas A Gay, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act

03	26	06/01/1995	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
----	----	------------	------------------------------	-------------------------------	------------------

3095	No			None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		06/26/2016	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	No
8,000		06/26/2016	EMCO Electronics/EECO 1500		No
04	26	06/01/1995	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
3096	No			None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		06/26/2016	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	No
8,000		06/26/2016	EMCO Electronics/EECO 1500		No
05	26	06/01/1995	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
3097	No			None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Diesel		06/26/2016	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	No
4,000		06/26/2016	EMCO Electronics/EECO 1500		No

Facility Summary in Lake County in the City of Ronan

Location: ARNIES GAS AND TIRE CENTER INC
63145 US Hwy 93
Ronan, MT 59864-2808 Lake

Legacy ID:24-05517

Facility ID: 22970
Last Inspected On: 08/14/2020
Operating Permit Renewal Date: 08/15/2023

Owner Operator Contact: Arnies Gas and Tire Center Inc;Kim Aipperspach;Arnies Gas and Tire Center Inc

4066750400;4066760400;4066750400

Operator Contact: Amanda Hackman;Denise Aipperspach

4066760400

Owner/Operator: Arnies Gas and Tire Center Inc

- Amanda Hackman, UST Class A Operator
- Amanda Hackman, UST Class B Global Operator
- Denise Aipperspach, UST Class A Operator
- Denise Aipperspach, UST Class B Global Operator
- Denise Aipperspach, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
-----------	-----	-----------	----------------------------	-----------------	----------------

Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
04	43	05/07/1978	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve
3888	No		Lined Interior/Impressed Current	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Impressed Current
Diesel		06/13/2017	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	No
12,000		03/16/2017	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
03	50	05/08/1971	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve
3889	No		Lined Interior/Impressed Current	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Impressed Current
Gasoline		06/13/2017	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	No
4,000		03/16/2017	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
02	50	05/08/1971	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve
3890	No		Lined Interior/Impressed Current	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Impressed Current
Gasoline		06/13/2017	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	No
6,000		03/16/2017	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
01	50	05/08/1971	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve
3891	No		Lined Interior/Impressed Current	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Impressed Current
Gasoline		06/13/2017	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	No
10,000		03/16/2017	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No

Facility Summary in Lake County in the City of Ronan

Location: DYNO MART
62945 Hwy 93 N
Ronan, MT 59864 Lake

Legacy ID:24-05768

Facility ID: 22981
Last Inspected On: 05/20/2020
Operating Permit Renewal Date: 09/09/2023

Owner Operator Contact: Binky Hall;Joes Jiffy Stop Inc;Margaret Bowman

4066753570;4066763570

Operator Contact: Maureen McCrea;Tom Hoyt

4062745536

Owner/Operator: Margaret Bowman

Gail Matt, UST Class B Global Operator
Gail Matt, UST Class B Operator
Maureen McCrea, UST Class A Operator
Tom Hoyt, UST Class A Operator
Tom Hoyt, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
01	37	11/13/1984	Bare Steel	Fiberglass Reinforced Plastic	Flapper Valve
1315	No			None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Impressed Current
Gasoline		03/16/2017	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	No
10,000		08/23/2016	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
02	37	11/13/1984	Bare Steel	Fiberglass Reinforced Plastic	Flapper Valve
1316	No			None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Impressed Current
Gasoline		03/16/2017	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	No
8,000		08/23/2016	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
03	29	04/01/1992	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve

1317	No		None	Yes
Currently in Use			Mechanical Line Leak Detector Pressurized	Impressed Current
Gasoline	03/16/2017		Automatic Tank Gauging 0.2	MLLD Line Tightness Testing
10,000	08/23/2016		Gilbarco-Veeder Root/TLS-350/Gilbarco EMC	No

Facility Summary in Lake County in the City of Ronan

Location: EAST OF RONAN MIDDLE SCHOOL
200 Round Butte Rd W
Ronan, MT 59864 Lake

Legacy ID:24-04824

Facility ID: 22953
Last Inspected On: 10/24/2020
Operating Permit Renewal Date: 09/13/2023

Owner Operator Contact: School Dist 30 Ronan **4066763390**

Operator Contact: Brad Benson;Lawrence Cordis;Rob Tougas **4062508008**

Owner/Operator: School Dist 30 Ronan

- Brad Benson, UST Class A Operator
- Brad Benson, UST Class B Global Operator
- Lawrence Cordis, UST Class A Operator
- Lawrence Cordis, UST Class B Global Operator
- Matt Gaut, UST Class B Operator
- Rob Tougas, UST Class A Operator
- Rob Tougas, UST Class B Global Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
S5	25	08/01/1996	Fiberglass Reinforced Plastic	Copper	Flapper Valve
1904	No	04/09/2014		Secondary Containment Chase	Yes
Currently in Use			Auto Dialer	U.S. Suction	Non-corrodible
Heating Oil			Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring	No
10,000			Incon/TS-1000		No

Facility Summary in Lake County in the City of Ronan

Location: JOHNS FUEL FARM and ENERGY
 14 Cleveland St SE
 Ronan, MT 59864-3027 Lake

Legacy ID:24-07437

Facility ID: 23032
Last Inspected On: 02/18/2019
Operating Permit Renewal Date: 04/26/2022

Owner Operator Contact: John Noel;Johns Fuel Farm and Energy;Johns Fuel Farm and Energy

Operator Contact: Hans Lund;John Noel;Leevi Wadsworth

4062617956

Owner/Operator: Johns Fuel Farm and Energy

Hans Lund, UST Class A Operator
 Hans Lund, UST Class B Operator
 John Noel, UST Class A Operator
 John Noel, UST Class B Global Operator
 Leevi Wadsworth, UST Class A Operator
 Leevi Wadsworth, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
01	60	04/23/1961	Cathodically Protected Steel	Steel	High Level Alarm
3394	No		Lined Interior/Impressed Current	Double Walled	Yes
Currently in Use		08/10/2009	Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		10/31/2018	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring;ELLD 0.2	No
10,000		12/18/2009	Gilbarco-Veeder Root/TLS-350		No
02	60	04/23/1961	Cathodically Protected Steel	Steel	High Level Alarm
3395	No		Lined Interior/Impressed Current	Double Walled	Yes
Currently in Use		08/10/2009	Electronic Line Leak Detector	Pressurized	Impressed Current
Diesel		10/31/2018	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring;ELLD 0.2	No
10,000		12/18/2009	Gilbarco-Veeder Root/TLS-350		No
03	50	04/24/1971	Fiberglass Reinforced Plastic	Steel	High Level Alarm

3396	No			Double Walled	Yes
Currently in Use		08/10/2009	Electronic Line Leak Detector	Pressurized	
Diesel		10/31/2018	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring; ELLD 0.2	No
8,000		12/18/2009	Gilbarco-Veeder Root/TLS-350		No
04	50	04/24/1971	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
3397	No			Double Walled	Yes
Currently in Use		08/10/2009	Electronic Line Leak Detector	Pressurized	
Diesel		10/31/2018	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring; ELLD 0.2	No
8,000		12/18/2009	Gilbarco-Veeder Root/TLS-350		No
05	50	04/24/1971	Fiberglass Reinforced Plastic	Steel	High Level Alarm
3398	No			Double Walled	Yes
Currently in Use		08/10/2009	Electronic Line Leak Detector	Pressurized	
Gasoline		10/31/2018	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring; ELLD 0.2	No
6,000		12/18/2009	Gilbarco-Veeder Root/TLS-350		No
06	60	04/23/1961	Cathodically Protected Steel	Steel	High Level Alarm
3399	No		Lined Interior/Impressed Current	Double Walled	Yes
Currently in Use		08/10/2009	Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		10/31/2018	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring; ELLD 0.2	No
6,000		12/18/2009	Gilbarco-Veeder Root/TLS-350		No

Facility Summary in Lake County in the City of Ronan

Location: KICKING HORSE JOB CORPS CENTER
33091 Mollmann Pass Trl
Ronan, MT 59864-9899 Lake

Legacy ID:24-10386

Facility ID: 23130
Last Inspected On: 05/15/1998
Operating Permit Renewal Date:

Owner Operator Contact: Confederated Salish and Kootenai Tribes

Operator Contact:

Owner/Operator: Confederated Salish and Kootenai Tribes

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
15	26	03/27/1995	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve
	No		Double-Walled	Double Walled	Yes
Currently in Use			Not Required	Safe Suction	
Gasoline			Automatic Tank Gauging 0.1;Manual Tank Gauging;Tank Tightness Testing	Continuous Interstitial Monitoring	No
1,000					No

Facility Summary in Lake County in the City of Ronan

Location: MOUNTAIN WEST CO OP RONAN
63932 US Hwy 93
Ronan, MT 59864 Lake

Legacy ID:24-04530

Facility ID: 22944
Last Inspected On: 07/10/2019
Operating Permit Renewal Date: 12/19/2022

Owner Operator Contact: CHS Mountain West Coop;Jerry Eide;Cenex Harvest States Missoula;Mark Lalum;Mountain West Cooperative **4065438383**

Operator Contact: Bob Westin;Dusty Smith;John Thompson;Will Dukart **4066651728;4067557427;4068808169**

Owner/Operator: CHS Mountain West Coop

- Bob Westin, UST Class A Operator
- Bob Westin, UST Class B Global Operator
- Carrie Clairmont, UST Class B Operator
- Dusty Smith, UST Class A Operator
- Dusty Smith, UST Class B Global Operator
- John Thompson, UST Class A Operator
- John Thompson, UST Class B Global Operator
- John Thompson, UST Class B Operator
- Will Dukart, UST Class A Operator
- Will Dukart, UST Class B Global Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
-----------	-----	-----------	----------------------------	-----------------	----------------

Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
09	24	05/01/1997	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
2829	No			None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	No
10,000		09/29/2016	Gilbarco-Veeder Root/TLS-350		No
10	24	05/01/1997	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
2830	No			None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	No
4,000		09/29/2016	Gilbarco-Veeder Root/TLS-350		No
11	24	05/01/1997	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
2831	No			None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Non-corrodible
Diesel			Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	No
4,000		09/29/2016	Gilbarco-Veeder Root/TLS-350		No
12	24	05/01/1997	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
2832	No			None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Non-corrodible
Diesel			Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	No
6,000		09/29/2016	Gilbarco-Veeder Root/TLS-350		No

13	24	05/01/1997	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
2833	No			None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Non-corrodible
Diesel			Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	No
5,000		09/29/2016	Gilbarco-Veeder Root/TLS-350		No

Facility Summary in Lake County in the City of Ronan

Location: RONAN AIRPORT
35564 Ronan Airport Rd
Ronan, MT 59864-9267 Lake

Legacy ID:24-04649

Facility ID: 22948
Last Inspected On: 09/14/2021
Operating Permit Renewal Date: 10/22/2024

Owner Operator Contact: Lake County Joint Airport Board

4068837214

Operator Contact: Vinson Jennison

Owner/Operator: Lake County Joint Airport Board

Vinson Jennison, UST Class A Operator

Vinson Jennison, UST Class B Global Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
02	22	04/01/1999	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve;High Level Alarm
3984	No			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Jet Fuel (Jet-A, Jet-A1, JP5)			Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring;ELLD 0.2	No
12,000			EMCO Electronics/EECO 1500		No
03	22	04/01/1999	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve;High Level Alarm
3985	No			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible

Aviation Gas	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring; ELLD 0.2	No
12,000	EMCO Electronics/EECO 1500		No

Facility Summary in Lake County in the City of Ronan

Location: ST LUKE COMMUNITY CLINIC- RONAN
107 6th Ave SW
Ronan, MT 59864 Lake

Legacy ID:24-03736

Facility ID: 22926
Last Inspected On: 08/25/2020
Operating Permit Renewal Date: 10/16/2023

Owner Operator Contact: Saint Luke Hospital

Operator Contact: Gary Burdett; Nicholas Emerson; Steven DeLay	4062405240;4066764441
---	------------------------------

Owner/Operator: Saint Luke Hospital

- Gary Burdett, UST Class A Operator
- Gary Burdett, UST Class B Operator
- Nicholas Emerson, UST Class A Operator
- Nicholas Emerson, UST Class B Operator
- Steven DeLay, UST Class A Operator
- Steven DeLay, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
S3	22	11/01/1999	Unknown	Copper	
4369	Yes	04/20/2017		Secondary Containment Chase	Yes
Currently in Use			Auto Dialer	U.S. Suction	
Diesel			Not Listed	Continuous Interstitial Monitoring	No
2,000					No

Facility Summary in Lake County in the City of Ronan

Location: TOWN PUMP INC RONAN
63459 US Hwy 93
Ronan, MT 59864-3007 Lake

Legacy ID:24-08718

Facility ID: 23067
Last Inspected On: 05/13/2021
Operating Permit Renewal Date: 09/22/2024

Owner Operator Contact: Don Edmisten; Town Pump Inc Ronan

4064976948;4064976700

Operator Contact: Trent Biggers

Owner/Operator: Ronan 1 Town Pump LLC

Trent Biggers, UST Class A Operator

Trent Biggers, UST Class B Global Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
01	49	04/14/1972	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve
4822	No		Lined Interior/Impressed Current	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		10/03/2018	Approved Remote Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Statistical Inventory Reconciliation	No
12,000			Gilbarco-Veeder Root/TLS-350		No
02	49	04/14/1972	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve
4823	No		Lined Interior/Impressed Current	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		10/03/2018	Approved Remote Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Statistical Inventory Reconciliation	No
12,000			Gilbarco-Veeder Root/TLS-350		No
03	49	04/14/1972	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve
4824	No		Lined Interior/Impressed Current	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		10/03/2018	Approved Remote Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Statistical Inventory Reconciliation	No
6,000			Gilbarco-Veeder Root/TLS-350		No

04	41	04/14/1980	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve
4825	No		Lined Interior/Impressed Current	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Diesel		10/03/2018	Approved Remote Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Statistical Inventory Reconciliation	No
6,000			Gilbarco-Veeder Root/TLS-350		No
05	14	07/05/2007	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve;Flapper Valve
5073	No		Double-Walled	Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
12,000			Gilbarco-Veeder Root/TLS-350		No

Facility Summary in Lake County in the City of Saint Ignatius

Location: ALLARDS STAGE STOP LLC
77579 US Hwy 93 N
Saint Ignatius, MT 59865-0460 Lake

Legacy ID:24-05769

Facility ID: 22982
Last Inspected On: 02/18/2021
Operating Permit Renewal Date: 03/13/2024

Owner Operator Contact: Dirk Cooper;Hi Noon Petroleum Missoula

4065420384

Operator Contact: Mamie Ahlborn

4062072810

Owner/Operator: Morton and Coffman LLC

Mamie Ahlborn, UST Class A Operator
Mamie Ahlborn, UST Class B Global Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act

04	16	12/01/2005	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve
----	----	------------	-------------------------------	------------------	---------------

5042	No			Double Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring;MLLD Line Tightness Testing	No
10,000			Veeder Root/TLS-300		No
05	16	12/01/2005	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve
5043	No			Double Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring;MLLD Line Tightness Testing	No
10,000			Veeder Root/TLS-300		No

Facility Summary in Lake County in the City of Saint Ignatius

Location: SAINT IGNATIUS SCHOOL
4th & Blaine St
Saint Ignatius, MT 59865 Lake

Legacy ID:24-03762

Facility ID: 22927
Last Inspected On: 02/22/2021
Operating Permit Renewal Date: 02/26/2024

Owner Operator Contact: School Dist 28 Saint Ignatius **4067453811**

Operator Contact: Stephen McCollum **4063967842**

Owner/Operator: School Dist 28 Saint Ignatius

Stephen McCollum, UST Class A Operator
Stephen McCollum, UST Class B Global Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
03	24	06/01/1997	Cathodically Protected Steel	Flexible Plastic	Flapper Valve
4563	No	08/25/2017		Double Walled	Yes
Currently in Use			Auto Dialer	U.S. Suction	Galvanic
Heating Oil		08/30/2017	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring	No
10,000			EMCO Electronics/EECO 1500		No

Facility Summary in Lake County in the City of Saint Ignatius

Location: STUARTS SERVICE CENTER INC
240 Mountain View Dr
Saint Ignatius, MT 59865 Lake

Legacy ID:24-10647

Facility ID: 23153
Last Inspected On: 01/12/2021
Operating Permit Renewal Date: 01/22/2024

Owner Operator Contact: Jerry Eide;Cenex Harvest States Missoula;Morton and Coffman LLC;Stuart Morton;Stuart Morton Operator Bjork Dist **4065438383;4067453634;4067452190**

Operator Contact: Mamie Ahlborn **4062072810**

Owner/Operator: Morton and Coffman LLC

Mamie Ahlborn, UST Class A Operator
Mamie Ahlborn, UST Class B Global Operator
Mamie Ahlborn, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
-----------	-----	-----------	----------------------------	-----------------	----------------

Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
06	26	05/01/1995	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve
4595	No			None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Gasoline		09/26/2017	Automatic Tank Gauging 0.2	Not Listed	No
8,000		08/22/2017	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
07	26	05/01/1995	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve
4596	No			None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		09/26/2017	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	No
8,000		08/22/2017	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
08	26	05/01/1995	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve
4597	No			None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Diesel		09/26/2017	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	No
6,000		08/22/2017	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
09	6	10/01/2015	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve
5619	No	10/23/2015	Double-Walled	Double Walled	Yes
Currently in Use		10/23/2015	Mechanical Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	Continuous Interstitial Monitoring;MLLD Line Tightness Testing	No

8,000

08/22/2017

Gilbarco-Veeder Root/TLS-
350;Gilbarco-Veeder Root/TLS-
350/Gilbarco EMC

Yes
