

Facility Summary in Lake County in the City of Arlee

Location: WILSON FOODS
92345 US Hwy 93
Arlee, MT 59821-9433 Lake

System Facility ID:24-06788

Facility Code: 23006
Last Inspected On: 02/19/2024
Operating Permit Renewal Date: 03/21/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Wilson Foods

Operator Contact: John Carranco;Velva Stuck;Wilson Foods

(406) 549-0891

velva1962@yahoo.com

Owner/Operator: Wilson Foods

John Carranco, UST Class A Operator

John Carranco, UST Class B Operator

Velva Stuck, UST Class A Operator

Velva Stuck, UST Class B Operator

velva1962@yahoo.com

velva1962@yahoo.com

Tank Code	10	Tank Age	28	Tank Installed Date	11/01/1998	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	3320	Spill Test Date	09/15/2022	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date	02/19/2024	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	10000	ATG Test Date	02/19/2024	Line Tightness Test Date	02/19/2024	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	09/15/2022			ATG Type	Gilbarco-Veeder Root/TLS-300				
Tank Code	11	Tank Age	28	Tank Installed Date	11/01/1998	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	3321	Spill Test Date	09/15/2022	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date	02/19/2024	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	4000	ATG Test Date	02/19/2024	Line Tightness Test Date	02/19/2024	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	09/15/2022			ATG Type	Gilbarco-Veeder Root/TLS-300				

Tank Code	12	Tank Age	28	Tank Installed Date	11/01/1998	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	3322	Spill Test Date	09/15/2022	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date	02/19/2024	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	4000	ATG Test Date	02/19/2024	Line Tightness Test Date	02/19/2024	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	11/15/2022			ATG Type	Gilbarco-Veeder Root/TLS-300				

Facility Summary in Lake County in the City of Charlo

Location: CHARLO SCHOOL DIST 7 J
405 2nd Ave E
Charlo, MT 59824 Lake

System Facility ID:24-02789

Facility Code: 22907
Last Inspected On: 11/01/2023
Operating Permit Renewal Date: 03/27/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: School Dist 7 J Charlo (406) 644-2207

Operator Contact: Joe Broom;School Dist 7 J Charlo (406) 249-8000;(406) 644-2207 jbroom@charloschools.com

Owner/Operator: School Dist 7 J Charlo (406) 644-2207

Joe Broom, UST Class A Operator

jbroom@charloschools.com

Joe Broom, UST Class B Operator

jbroom@charloschools.com

Tank Code	S5	Tank Age	28	Tank Installed Date	07/01/1998	Tank Material	Unknown	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	611	Spill Test Date		Piping Installed Date	07/09/2012	Tank Construction		Piping Construction	Double Walled	AST	Yes
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Auto Dialer	Piping Type	U.S. Suction	CP Met Types	
Product	Heating Oil	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Deferred	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	10000	ATG Test Date	11/01/2023	Line Tightness Test Date	08/27/2012	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	Yes
		Overfill Test Date				ATG Type					

Facility Summary in Lake County in the City of Charlo

Location: COULTER AUTOMOTIVE INC
104 Main St
Charlo, MT 59824-0097 Lake

System Facility ID:24-04615

Facility Code: 22947
Last Inspected On: 11/22/2024
Operating Permit Renewal Date: 04/01/2028

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Coulter Automotive Inc

(406) 644-2215

Operator Contact: Sandra Coulter

(406) 644-2215

coulterauto@charlo.net

Owner/Operator: Coulter Automotive Inc

(406) 644-2215

Sandra Coulter, UST Class A Operator

coulterauto@charlo.net

Sandra Coulter, UST Class B Operator

coulterauto@charlo.net

Tank Code	03	Tank Age	31	Tank Installed Date	07/01/1995	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	2281	Spill Test Date	11/22/2024	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date	11/22/2024	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	09/28/2022	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	6000	ATG Test Date	11/22/2024	Line Tightness Test Date	11/22/2024	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	11/22/2024			ATG Type	EMCO Electronics/EECO 1500				
Tank Code	04	Tank Age	31	Tank Installed Date	07/01/1995	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	2282	Spill Test Date	11/22/2024	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date	11/22/2024	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	09/28/2022	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	4000	ATG Test Date	11/22/2024	Line Tightness Test Date	11/22/2024	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	11/22/2024			ATG Type	EMCO Electronics/EECO 1500				

Facility Summary in Lake County in the City of Charlo

Location: MOIESE MERCANTILE
64620 MT Hwy 212
Charlo, MT 59824-9004 Lake

System Facility ID:24-06382

Facility Code: 22995
Last Inspected On: 02/04/2025
Operating Permit Renewal Date: 02/04/2028

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Moiese Mercantile (406) 644-3454 debh12703@gmail.com

Operator Contact: Debra Hall;Moiese Mercantile;Timothy Hall (406) 644-3454 debh12703@gmail.com;debh12703@gmail.com

Owner/Operator: Moiese Mercantile (406) 644-3454 debh12703@gmail.com

Debra Hall, UST Class A Operator debh12703@gmail.com
Leslie Muth, UST Class B Operator llafarinire@gmail.com
Timothy Hall, UST Class A Operator

Tank Code	03	Tank Age	27	Tank Installed Date	03/01/1999	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	3968	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	Single Walled	AST	No
Tank Status	Temporarily Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection		Vapor Recovery	No
Capacity	1000	ATG Test Date		Line Tightness Test Date	10/25/2004	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					

Facility Summary in Lake County in the City of Pablo

Location: PABLO ELEMENTARY SCHOOL
608 4th Ave
Pablo, MT 59855 Lake

System Facility ID:24-04823

Facility Code: 22952
Last Inspected On: 02/03/2025
Operating Permit Renewal Date: 10/22/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: School Dist 30 Ronan (406) 644-2448

Operator Contact: Brad Benson;Lawrence Cordis;Rob Tougas (406) 250-8008 larry.cordis@ronank12.edu;rob.tougas@ronank12.edu

Owner/Operator: School Dist 30 Ronan (406) 644-2448

Brad Benson, UST Class A Operator

Brad Benson, UST Class B Global Operator

Lawrence Cordis, UST Class A Operator

larry.cordis@ronank12.edu

Lawrence Cordis, UST Class B Global Operator

larry.cordis@ronank12.edu

Rob Tougas, UST Class A Operator

rob.tougas@ronank12.edu

Rob Tougas, UST Class B Global Operator

rob.tougas@ronank12.edu

Tank Code	02	Tank Age	2	Tank Installed Date	09/01/2024	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types
Tag Number	6250	Spill Test Date	02/03/2025	Piping Installed Date	08/21/2002	Tank Construction		Piping Construction		AST
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Auto Dialer	Piping Type	U.S. Suction	CP Met Types
Product	Heating Oil	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery
Capacity	8000	ATG Test Date	02/03/2025	Line Tightness Test Date	07/03/2024 <th>Secondary Tank Leak Detection</th> <td>Automatic Tank Gauging 0.2</td> <th>Secondary Pipe Detection</th> <td></td> <th>Energy Act</th>	Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection		Energy Act
		Overfill Test Date	02/03/2025		<th>ATG Type</th> <td></td> <td></td> <td></td> <td>Yes</td>	ATG Type				Yes

Facility Summary in Lake County in the City of Pablo

Location: QUICKSILVER EXPRESS
52001 US Hwy 93
Pablo, MT 59855 Lake

System Facility ID:24-11124

Facility Code: 23179
Last Inspected On: 01/09/2023
Operating Permit Renewal Date: 03/16/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Quick Silver Express	(406) 675-5000	corky.sias@cskt.org
---	----------------	---------------------

Operator Contact: Corky Sias	(406) 275-2792	corky.sias@cskt.org
-------------------------------------	----------------	---------------------

Owner/Operator: Quick Silver Express	(406) 675-5000	corky.sias@cskt.org
Corky Sias, UST Class A Operator		corky.sias@cskt.org
Corky Sias, UST Class B Operator		corky.sias@cskt.org

Tank Code	01	Tank Age	39	Tank Installed Date	01/01/1987	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve;Flapper Valve
Tag Number	3296	Spill Test Date	10/23/2024	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Diesel, Dyed	PLLD Test Date		Tank/Piping CP Test Date	07/18/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	8000	ATG Test Date	07/18/2023	Line Tightness Test Date	03/16/2017	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	10/23/2024			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	02	Tank Age	39	Tank Installed Date	01/01/1987	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve;Flapper Valve
Tag Number	3297	Spill Test Date	10/23/2024	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	07/18/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	8000	ATG Test Date	07/18/2023	Line Tightness Test Date	03/16/2017	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	10/23/2024			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Tank Code	03	Tank Age	39	Tank Installed Date	01/01/1987	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve;Flapper Valve
Tag Number	3298	Spill Test Date	10/23/2024	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	07/18/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	8000	ATG Test Date	07/18/2023	Line Tightness Test Date	03/16/2017	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	10/23/2024			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	04	Tank Age	15	Tank Installed Date	05/01/2011	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve;Flapper Valve
Tag Number	5344	Spill Test Date	10/23/2024	Piping Installed Date	05/01/2011	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	05/30/2023	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	03/16/2017	Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	12000	ATG Test Date	07/18/2023	Line Tightness Test Date	03/16/2017	Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	10/23/2024			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Lake County in the City of Polson

Location: GOLDES
33537 MT Hwy 35
Polson, MT 59860 Lake

System Facility ID:60-15208

Facility Code: 30928
Last Inspected On: 03/25/2024
Operating Permit Renewal Date: 07/16/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Jeffry Goldes (406) 443-0454

Operator Contact: Serena Keller;Travis Schenck (406) 837-6679;(406) 885-1530 serena@valleymaintenance.com;travis.schenck.p@gmail.com

Owner/Operator: Jeffry Goldes (406) 443-0454

Frank Jasper, UST Class B Operator

Serena Keller, UST Class A Operator

Serena Keller, UST Class B Operator

Travis Schenck, UST Class A Operator

frank.j.jasper@gmail.com

serena@valleymaintenance.com

serena@valleymaintenance.com

travis.schenck.p@gmail.com

Tank Code	S2	Tank Age	14	Tank Installed Date	05/01/2012	Tank Material	Aboveground Tank	Piping Material	Flexible Plastic	Overfill Types
Tag Number	5365	Spill Test Date		Piping Installed Date	04/17/2012	Tank Construction		Piping Construction	Double Walled	AST
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	04/05/2022	Catastrophic L.D Type 3.0	Continuous Interstitial Monitoring	Piping Type	Gravity Feed	CP Met Types
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection		Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery
Capacity	500	ATG Test Date	06/15/2023	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act
		Overfill Test Date				ATG Type				Yes

Facility Summary in Lake County in the City of Polson

Location: HILLTOP GAS AND GO
44613 US Hwy 93
Polson, MT 59860-7585 Lake

System Facility ID:24-07247

Facility Code: 23026
Last Inspected On: 01/20/2024
Operating Permit Renewal Date: 01/20/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Hilltop Gas and Go (916) 997-0412 jill-grove@comcast.net

Operator Contact: Dustin Noakes jill-grove@comcast.net

Owner/Operator: Hilltop Gas and Go (916) 997-0412 jill-grove@comcast.net

Dustin Noakes, UST Class A Operator
Dustin Noakes, UST Class B Operator jill-grove@comcast.net
jill-grove@comcast.net

Tank Code	04	Tank Age	30	Tank Installed Date	04/01/1996	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	1215	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Temporarily Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	12000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date				ATG Type	Incon/TS-1000				
Tank Code	05	Tank Age	30	Tank Installed Date	04/01/1996	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	1216	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Temporarily Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	8000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date				ATG Type	Incon/TS-1000				
Tank Code	06	Tank Age	30	Tank Installed Date	04/01/1996	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve

Tag Number	1217	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Temporarily Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	5000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date				ATG Type	Incon/TS-1000				

Facility Summary in Lake County in the City of Polson

Location: MOUNTAIN WEST CO OP POLSON
808 Main St
Polson, MT 59860-3227 Lake

System Facility ID:24-04560

Facility Code: 22946
Last Inspected On: 08/16/2023
Operating Permit Renewal Date: 12/02/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: CHS Mountain West Coop (406) 676-2201

Operator Contact: Dusty Smith;Joseph Allard;CHS Mountain West Coop (406) 676-2201 dusty.smith@chsinc.com;Joseph.Allard@chsinc.com

Owner/Operator: CHS Mountain West Coop (406) 676-2201

Dusty Smith, UST Class A Operator

dusty.smith@chsinc.com

Dusty Smith, UST Class B Global Operator

dusty.smith@chsinc.com

John Adams, UST Class B Operator

john.adams@chsinc.com

Joseph Allard, UST Class A Operator

Joseph.Allard@chsinc.com

Joseph Allard, UST Class B Operator

Joseph.Allard@chsinc.com

Tank Code	05	Tank Age	26	Tank Installed Date	01/01/2000	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	4155	Spill Test Date	03/27/2023	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	03/30/2020	Sump Tightness Test Date	03/27/2023	Catastrophic L.D Type 3.0	Auto Dialer;Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	09/22/2025	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	6000	ATG Test Date	09/22/2025	Line Tightness Test Date	03/30/2020	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	07/12/2023			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	06	Tank Age	26	Tank Installed Date	01/01/2000	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	4156	Spill Test Date	04/04/2023	Piping Installed Date	10/09/2013	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	03/30/2020	Sump Tightness Test Date	03/27/2023	Catastrophic L.D Type 3.0	Auto Dialer;Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible

Product	Gasoline	PLL D Test Date	09/22/2025	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	5000	ATG Test Date	09/22/2025	Line Tightness Test Date	03/30/2020	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	07/12/2023			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	08	Tank Age	26	Tank Installed Date	01/01/2000	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	4648	Spill Test Date	03/27/2023	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	03/30/2020	Sump Tightness Test Date	03/27/2023	Catastrophic L.D Type 3.0	Auto Dialer;Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLL D Test Date	09/22/2025	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	5000	ATG Test Date	09/22/2025	Line Tightness Test Date	03/30/2020	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	07/12/2023			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	07	Tank Age	26	Tank Installed Date	01/01/2000	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	4741	Spill Test Date	04/04/2023	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	03/30/2020	Sump Tightness Test Date	03/27/2023	Catastrophic L.D Type 3.0	Auto Dialer;Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLL D Test Date	09/22/2025	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	10000	ATG Test Date	09/22/2025	Line Tightness Test Date	03/30/2020	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	07/12/2023			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Lake County in the City of Polson

Location: PIER 93
49433 US Hwy 93
Polson, MT 59860 Lake

System Facility ID:24-05957

Facility Code: 22988
Last Inspected On: 01/06/2025
Operating Permit Renewal Date: 06/30/2028

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Jacks Pier 93	(406) 883-5768	jacobmiller1234@outlook.com
--	----------------	-----------------------------

Operator Contact: Donald Miller;Jacob Miller	(406) 883-4531;(406) 883-5768	jacobmiller1234@outlook.com;pier93@montanasky.net
---	-------------------------------	---

Owner/Operator: Jacks Pier 93	(406) 883-5768	jacobmiller1234@outlook.com
Donald Miller, UST Class A Operator		pier93@montanasky.net
Donald Miller, UST Class B Operator		pier93@montanasky.net
Jacob Miller, UST Class A Operator		jacobmiller1234@outlook.com
Jacob Miller, UST Class B Global Operator		jacobmiller1234@outlook.com
Jacob Miller, UST Class B Operator		jacobmiller1234@outlook.com

Tank Code	01	Tank Age	40	Tank Installed Date	04/23/1986	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	1802	Spill Test Date	10/03/2024	Piping Installed Date		Tank Construction		Piping Construction	Single Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	05/09/2024	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	04/25/2022	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	4000	ATG Test Date	05/09/2024	Line Tightness Test Date	05/09/2024	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	10/03/2024			ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	02	Tank Age	40	Tank Installed Date	04/23/1986	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	1803	Spill Test Date	05/05/2022	Piping Installed Date		Tank Construction		Piping Construction	Single Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	05/09/2024	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	04/25/2022	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	6000	ATG Test Date	05/09/2024	Line Tightness Test Date	05/09/2024	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	05/05/2022			ATG Type	Gilbarco-Veeder Root/TLS-350				

Tank Code	06	Tank Age	36	Tank Installed Date	11/01/1990	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	1804	Spill Test Date	05/05/2022	Piping Installed Date		Tank Construction		Piping Construction	Single Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	05/09/2024	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	04/25/2022	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	10000	ATG Test Date	05/09/2024	Line Tightness Test Date	05/09/2024	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	05/05/2022			ATG Type	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Lake County in the City of Polson

Location: POLSON BAY GROCERY 425
50451 US Hwy 93
Polson, MT 59860 Lake

System Facility ID:24-05770

Facility Code: 22983
Last Inspected On: 03/02/2023
Operating Permit Renewal Date: 08/09/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Jays Corporation (406) 549-1750 polsonbay@yahoo.com

Operator Contact: Jagpreet Ghuman;Jaspal Sandhu;Jays Corporation (406) 549-1750;(406) 880-7677 jas_sandhu75@hotmail.com;polsonbay@yahoo.com;jaysfood08@outlook.com

Owner/Operator: Jays Corporation (406) 549-1750 polsonbay@yahoo.com
Jagpreet Ghuman, UST Class A Operator jaysfood08@outlook.com
Jagpreet Ghuman, UST Class B Operator jays1stop21@outlook.com
Jaspal Sandhu, UST Class A Operator polsonbay@yahoo.com
Jaspal Sandhu, UST Class B Operator polsonbay@yahoo.com

Tank Code	04	Tank Age	24	Tank Installed Date	05/23/2002	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	4664	Spill Test Date	06/22/2021	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	03/05/2020	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	20000	ATG Test Date	02/15/2023	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	02/25/2023			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	05	Tank Age	24	Tank Installed Date	05/23/2002	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	4665	Spill Test Date	06/22/2021	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	03/05/2020	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	10000	ATG Test Date	02/15/2023	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No

		Overfill Test Date	02/25/2023			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC			
Tank Code	06	Tank Age	24	Tank Installed Date	05/23/2002	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types
Tag Number	4666	Spill Test Date	04/28/2021	Piping Installed Date	10/30/2018	Tank Construction		Piping Construction	Double Walled	AST
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types
Product	Diesel	PLLD Test Date	03/05/2020	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery
Capacity	6000	ATG Test Date	02/15/2023	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act
		Overfill Test Date	02/15/2023			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC			
Tank Code	07	Tank Age	24	Tank Installed Date	05/23/2002	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types
Tag Number	4667	Spill Test Date	04/28/2021	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types
Product	Diesel	PLLD Test Date	03/05/2020	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery
Capacity	4000	ATG Test Date	02/15/2023	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act
		Overfill Test Date	02/25/2023			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC			

Facility Summary in Lake County in the City of Polson

Location: POLSON COUNTRY CLUB
111 Bayview Dr
Polson, MT 59860-9609 Lake

System Facility ID:24-11824

Facility Code: 23227
Last Inspected On: 11/04/2025
Operating Permit Renewal Date: 11/04/2028

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: City of Polson (406) 883-8505

Operator Contact: Patrick Nowlen (406) 249-5121 golf@cityofpolson.com

Owner/Operator: City of Polson (406) 883-8505

Patrick Nowlen, UST Class A Operator
Patrick Nowlen, UST Class B Operator
golf@cityofpolson.com
golf@cityofpolson.com

Tank Code	01	Tank Age	36	Tank Installed Date	08/14/1990	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	647	Spill Test Date	11/04/2025	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Temporarily Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	11/04/2025	Primary Tank Leak Detection	Manual Tank Gauging	Primary Pipe Detection		Vapor Recovery	No
Capacity	500	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	11/04/2025			ATG Type					

Facility Summary in Lake County in the City of Polson

Location: SAFEWAY FUEL STATION 1646
40772 MT Hwy 35
Polson, MT 59860 Lake

System Facility ID:60-15097

Facility Code: 30857
Last Inspected On: 12/27/2023
Operating Permit Renewal Date: 03/28/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Safeway Stores Inc

(425) 201-6301

Operator Contact: Aaron Nelson;Cindy Standbrook;Lynn Pehrson;Martha Scott;Albertsons - Safeway;Rachel Jones

(208) 395-3269;(208) 412-2233;(406) 883-2340;(425) 201-6301

cinderella@ronan.net;ltollison@yokesfoods.com;mscot17@safeway.com;page.rost@albertsons.com;rachel.jones@albertsons.com

Owner/Operator: Safeway Stores Inc

(425) 201-6301

Aaron Nelson, UST Class A Operator

Cindy Standbrook, UST Class A Operator

Cindy Stankbrook, UST Class B Global Operator

Heidi Morgan, UST Class B Global Operator

Lynn Pehrson, UST Class A Operator

Martha Scott, UST Class A Operator

Martha Scott, UST Class B Operator

Rachel Jones , UST Class A Operator

Rachel Jones , UST Class B Global Operator

cinderella@ronan.net

ltollison@yokesfoods.com

page.rost@albertsons.com

page.rost@albertsons.com

rachel.jones@albertsons.com

rachel.jones@albertsons.com

Tank Code	01	Tank Age	18	Tank Installed Date	05/22/2008	Tank Material	Steel Clad	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	5164	Spill Test Date	09/28/2022	Piping Installed Date	04/04/2008	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Gasoline	PLLD Test Date	05/31/2023	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	20000	ATG Test Date	05/31/2023	Line Tightness Test Date	09/28/2022	Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	Yes
		Overfill Test Date	12/27/2023			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	02	Tank Age	18	Tank Installed Date	05/22/2008	Tank Material	Steel Clad	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	5165	Spill Test Date	09/28/2022	Piping Installed Date	04/04/2008	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible

Product	Gasoline	PLLD Test Date	05/31/2023	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	10000	ATG Test Date	05/31/2023	Line Tightness Test Date	09/28/2022	Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	Yes
		Overfill Test Date	12/27/2023			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	03	Tank Age	18	Tank Installed Date	05/22/2008	Tank Material	Steel Clad	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	5166	Spill Test Date	09/28/2022	Piping Installed Date	04/04/2008	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	05/31/2023	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	10000	ATG Test Date	05/31/2023	Line Tightness Test Date	09/28/2022	Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	Yes
		Overfill Test Date	12/27/2023			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Lake County in the City of Polson

Location: TOWN PUMP INC POLSON
50667 US Hwy 93
Polson, MT 59860 Lake

System Facility ID:24-08717

Facility Code: 23066
Last Inspected On: 03/29/2023
Operating Permit Renewal Date: 09/29/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Polson 1 Town Pump LLC

(406) 497-6700

environmental@townpump.com

Operator Contact: Trent Biggers

Trentb@townpump.com

Owner/Operator: Polson 1 Town Pump LLC

(406) 497-6700

environmental@townpump.com

Trent Biggers, UST Class A Operator

Trent Biggers, UST Class B Global Operator

Trentb@townpump.com

Trentb@townpump.com

Tank Code	01	Tank Age	44	Tank Installed Date	09/01/1982	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	2490	Spill Test Date	08/23/2022	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	08/23/2022	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	12000	ATG Test Date	03/29/2023	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	08/23/2022			ATG Type	Gilbarco-Veeder Root/TLS-450				
Tank Code	02	Tank Age	44	Tank Installed Date	09/01/1982	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	2491	Spill Test Date	08/23/2022	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	08/23/2022	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	12000	ATG Test Date	03/29/2023	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	08/23/2022			ATG Type	Gilbarco-Veeder Root/TLS-450				

Tank Code	03	Tank Age	44	Tank Installed Date	09/01/1982	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	2492	Spill Test Date	08/23/2022	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	08/23/2022	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	12000	ATG Test Date	03/29/2023	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	08/23/2022			ATG Type	Gilbarco-Veeder Root/TLS-450				
Tank Code	04	Tank Age	44	Tank Installed Date	09/01/1982	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	2493	Spill Test Date	08/23/2022	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	08/23/2022	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	12000	ATG Test Date	03/29/2023	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	08/23/2022			ATG Type	Gilbarco-Veeder Root/TLS-450				
Tank Code	05	Tank Age	44	Tank Installed Date	09/01/1982	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	2494	Spill Test Date	08/23/2022	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	08/23/2022	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	12000	ATG Test Date	03/29/2023	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	08/23/2022			ATG Type	Gilbarco-Veeder Root/TLS-450				
Tank Code	11	Tank Age	24	Tank Installed Date	10/24/2002	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	4819	Spill Test Date	08/23/2022	Piping Installed Date	10/24/2002	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No

Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	01/04/2010	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	10000	ATG Test Date	03/29/2023	Line Tightness Test Date		Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	Yes
		Overfill Test Date	08/23/2022			ATG Type	Gilbarco-Veeder Root/TLS-450				
Tank Code	12	Tank Age	24	Tank Installed Date	10/24/2002	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	4820	Spill Test Date	08/23/2022	Piping Installed Date	10/24/2002	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	01/04/2010	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	5000	ATG Test Date	08/23/2022	Line Tightness Test Date		Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	Yes
		Overfill Test Date	08/23/2022			ATG Type	Gilbarco-Veeder Root/TLS-450				
Tank Code	13	Tank Age	9	Tank Installed Date	11/09/2017	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Positive Shutoff
Tag Number	5782	Spill Test Date	08/23/2022	Piping Installed Date	11/09/2017	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	Yes
Capacity	4000	ATG Test Date	03/29/2023	Line Tightness Test Date		Secondary Tank Leak Detection	Statistical Inventory Reconciliation	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	Yes
		Overfill Test Date	08/23/2022			ATG Type	Gilbarco-Veeder Root/TLS-450				
Tank Code	14	Tank Age	9	Tank Installed Date	11/09/2017	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Positive Shutoff
Tag Number	5791	Spill Test Date		Piping Installed Date	11/09/2017	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Other	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Continuous Interstitial Monitoring	Piping Type	Pressurized	CP Met Types	

Product	DEF (Not Regulated)	PLL D Test Date		Tank/Piping CP Test Date	Primary Tank Leak Detection	Approved Remote Monitoring; Continuous Interstitial Monitoring; Statistical Inventory Reconciliation	Primary Pipe Detection	Approved Remote Monitoring; Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	2000	ATG Test Date		Line Tightness Test Date	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring; Not Listed	Energy Act	Yes
		Overfill Test Date			ATG Type					

Facility Summary in Lake County in the City of Rollins

Location: POINTS NORTH TRADING CO
87867 US Hwy 93
Rollins, MT 59931 Lake

System Facility ID:24-12730

Facility Code: 23274
Last Inspected On: 05/01/2025
Operating Permit Renewal Date: 07/22/2028

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Points North of Rollins LLC

(406) 250-7058

pointsnorth01@yahoo.com

Operator Contact: Michael Serra;Thomas Gay

(406) 250-7058;(406) 844-3942

mikeserra20@gmail.com;tomnjule@aboutmontana.net

Owner/Operator: Points North of Rollins LLC

(406) 250-7058

pointsnorth01@yahoo.com

Michael Serra, UST Class A Operator

mikeserra20@gmail.com

Michael Serra, UST Class B Global Operator

mikeserra20@gmail.com

Thomas A Gay, UST Class A Operator

tomnjule@aboutmontana.net

Thomas A Gay, UST Class B Operator

tomnjule@aboutmontana.net

Tank Code	03	Tank Age	31	Tank Installed Date	06/01/1995	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	3095	Spill Test Date	05/31/2024	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date	05/01/2025	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	05/28/2024	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	8000	ATG Test Date	05/01/2025	Line Tightness Test Date	05/01/2025	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	05/01/2025			ATG Type	EMCO Electronics/EECO 1500				
Tank Code	04	Tank Age	31	Tank Installed Date	06/01/1995	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	3096	Spill Test Date	05/31/2024	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date	05/01/2025	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	05/28/2024	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	8000	ATG Test Date	05/01/2025	Line Tightness Test Date	05/01/2025	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	05/01/2025			ATG Type	EMCO Electronics/EECO 1500				

Tank Code	05	Tank Age	31	Tank Installed Date	06/01/1995	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	3097	Spill Test Date	05/31/2024	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date	05/01/2025	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	05/28/2024	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	4000	ATG Test Date	05/01/2025	Line Tightness Test Date	05/01/2025	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	05/01/2025			ATG Type	EMCO Electronics/EECO 1500				

Facility Summary in Lake County in the City of Ronan

Location: ARNIES GAS AND TIRE CENTER INC
63145 US Hwy 93
Ronan, MT 59864-2808 Lake

System Facility ID:24-05517

Facility Code: 22970
Last Inspected On: 05/02/2023
Operating Permit Renewal Date: 08/15/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Arnies Gas and Tire Center Inc

(406) 675-0400

arniesgt@gmail.com

Operator Contact: Amanda Hackman;Denise Aipperspach

(406) 676-0400

Owner/Operator: Arnies Gas and Tire Center Inc

(406) 675-0400

arniesgt@gmail.com

Amanda Hackman, UST Class A Operator

Amanda Hackman, UST Class B Global Operator

Denise Aipperspach, UST Class A Operator

Denise Aipperspach, UST Class B Global Operator

Denise Aipperspach, UST Class B Operator

Tank Code	04	Tank Age	48	Tank Installed Date	05/07/1978	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	3888	Spill Test Date	05/02/2023	Piping Installed Date		Tank Construction	Lined Interior/Impressed Current	Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date	05/02/2023	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	05/02/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	12000	ATG Test Date	05/02/2023	Line Tightness Test Date	05/02/2023	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	05/02/2023			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	03	Tank Age	55	Tank Installed Date	05/08/1971	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	3889	Spill Test Date	05/02/2023	Piping Installed Date		Tank Construction	Lined Interior/Impressed Current	Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date	05/02/2023	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Diesel, Dyed	PLLD Test Date		Tank/Piping CP Test Date	05/02/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	4000	ATG Test Date	05/02/2023	Line Tightness Test Date	05/02/2023	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No

		Overfill Test Date	05/02/2023			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC			
Tank Code	02	Tank Age	55	Tank Installed Date	05/08/1971	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types
Tag Number	3890	Spill Test Date	05/02/2023	Piping Installed Date		Tank Construction	Lined Interior/Impressed Current	Piping Construction	None	AST
Tank Status	Currently in Use	MLLD Test Date	05/02/2023	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	05/02/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery
Capacity	6000	ATG Test Date	05/02/2023	Line Tightness Test Date	05/02/2023	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act
		Overfill Test Date	05/02/2023			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC			
Tank Code	01	Tank Age	55	Tank Installed Date	05/08/1971	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types
Tag Number	3891	Spill Test Date	05/02/2023	Piping Installed Date		Tank Construction	Lined Interior/Impressed Current	Piping Construction	None	AST
Tank Status	Currently in Use	MLLD Test Date	05/02/2023	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	05/02/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery
Capacity	10000	ATG Test Date	05/02/2023	Line Tightness Test Date	05/02/2023	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act
		Overfill Test Date	05/02/2023			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC			

Facility Summary in Lake County in the City of Ronan

Location: DYNO MART
62945 Hwy 93 N
Ronan, MT 59864 Lake

System Facility ID:24-05768

Facility Code: 22981
Last Inspected On: 04/24/2023
Operating Permit Renewal Date: 09/08/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: One Stop 3 Inc Loc 2

(406) 676-3570

onestop3gm@yahoo.com

Operator Contact: Maureen McCrea;Tom Hoyt

(406) 274-5536

dynamart1@yahoo.com

Owner/Operator: One Stop 3 Inc Loc 2

(406) 676-3570

onestop3gm@yahoo.com

Gail Matt, UST Class B Global Operator

dynamart1@yahoo.com

Gail Matt, UST Class B Operator

dynamart1@yahoo.com

Maureen McCrea, UST Class A Operator

dynamart1@yahoo.com

Tom Hoyt, UST Class A Operator

dynamart1@yahoo.com

Tom Hoyt, UST Class B Operator

dynamart1@yahoo.com

Tank Code	01	Tank Age	42	Tank Installed Date	11/13/1984	Tank Material	Bare Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	1315	Spill Test Date	08/05/2020	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date	07/30/2019	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	03/27/2019	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	10000	ATG Test Date		Line Tightness Test Date	07/30/2019	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	02	Tank Age	42	Tank Installed Date	11/13/1984	Tank Material	Bare Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	1316	Spill Test Date	03/27/2019	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date	07/30/2019	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	03/27/2019	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	8000	ATG Test Date		Line Tightness Test Date	07/30/2019	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No

		Overfill Test Date	03/27/2019			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC			
Tank Code	03	Tank Age	34	Tank Installed Date	04/01/1992	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types
Tag Number	1317	Spill Test Date	03/27/2019	Piping Installed Date		Tank Construction		Piping Construction	None	AST
Tank Status	Currently in Use	MLLD Test Date	07/30/2019	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	03/27/2019	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery
Capacity	10000	ATG Test Date		Line Tightness Test Date	07/30/2019	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act
		Overfill Test Date	03/27/2019			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC			

Facility Summary in Lake County in the City of Ronan

Location: EAST OF RONAN MIDDLE SCHOOL
200 Round Butte Rd W
Ronan, MT 59864 Lake

System Facility ID:24-04824

Facility Code: 22953
Last Inspected On: 05/25/2023
Operating Permit Renewal Date: 09/13/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: School Dist 30 Ronan (406) 644-2448

Operator Contact: Brad Benson;Lawrence Cordis;Rob Tougas (406) 250-8008 larry.cordis@ronank12.edu;rob.tougas@ronank12.edu

Owner/Operator: School Dist 30 Ronan (406) 644-2448

Brad Benson, UST Class A Operator

Brad Benson, UST Class B Global Operator

Lawrence Cordis, UST Class A Operator

larry.cordis@ronank12.edu

Lawrence Cordis, UST Class B Global Operator

larry.cordis@ronank12.edu

Matt Gaut, UST Class B Operator

matt.gaut@ronank12.edu

Rob Tougas, UST Class A Operator

rob.tougas@ronank12.edu

Rob Tougas, UST Class B Global Operator

rob.tougas@ronank12.edu

Tank Code	S5	Tank Age	30	Tank Installed Date	08/01/1996	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Copper	Overfill Types	Flapper Valve
Tag Number	1904	Spill Test Date	05/25/2023	Piping Installed Date		Tank Construction		Piping Construction	Secondary Containment Chase	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Auto Dialer	Piping Type	U.S. Suction	CP Met Types	Non-corrodible
Product	Heating Oil	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	10000	ATG Test Date	05/25/2023	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	05/25/2023			ATG Type	Gilbarco-Veeder Root/Other				

Facility Summary in Lake County in the City of Ronan

Location: JOHNS FUEL FARM AND ENERGY
14 Cleveland St SE
Ronan, MT 59864-3027 Lake

System Facility ID:24-07437

Facility Code: 23032
Last Inspected On: 11/20/2024
Operating Permit Renewal Date: 04/26/2028

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Johns Fuel Farm and Energy	(406) 676-3461	hans.lund@tradhm.com
---	----------------	----------------------

Operator Contact: Hans Lund;John Noel;Leevi Wadsworth	(406) 261-7956;(406) 676-3461	fuelfarm@ronan.net;hans.lund@johnsfuelfarm.com;leevij@hotmail.co
--	-------------------------------	--

Owner/Operator: Johns Fuel Farm and Energy	(406) 676-3461	hans.lund@tradhm.com
Hans Lund, UST Class A Operator		hans.lund@johnsfuelfarm.com
Hans Lund, UST Class B Operator		hans.lund@johnsfuelfarm.com
John Noel, UST Class A Operator		fuelfarm@ronan.net
John Noel, UST Class B Global Operator		fuelfarm@ronan.net
Leevi Wadsworth, UST Class A Operator		leevij@hotmail.co
Leevi Wadsworth, UST Class B Operator		leevij@hotmail.co

Tank Code	01	Tank Age	65	Tank Installed Date	04/23/1961	Tank Material	Cathodically Protected Steel	Piping Material	Steel	Overfill Types	High Level Alarm
Tag Number	3394	Spill Test Date	08/21/2024	Piping Installed Date	08/10/2009	Tank Construction	Lined Interior/Impressed Current	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	08/21/2024	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date	08/21/2024	Tank/Piping CP Test Date	11/20/2024	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	10000	ATG Test Date	08/21/2024	Line Tightness Test Date	08/30/2022	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	08/21/2024			ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	02	Tank Age	0	Tank Installed Date		Tank Material	Cathodically Protected Steel	Piping Material	Steel	Overfill Types	High Level Alarm
Tag Number	3395	Spill Test Date	08/21/2024	Piping Installed Date	08/10/2009	Tank Construction	Lined Interior/Impressed Current	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	08/21/2024	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Diesel	PLLD Test Date	08/21/2024	Tank/Piping CP Test Date	11/20/2024	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No

Capacity	10000	ATG Test Date	08/21/2024	Line Tightness Test Date	08/30/2022	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	08/21/2024			ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	03	Tank Age	55	Tank Installed Date	04/24/1971	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Steel	Overfill Types	High Level Alarm
Tag Number	3396	Spill Test Date	10/04/2021	Piping Installed Date	08/10/2009	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	10/26/2021	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	08/30/2022	Tank/Piping CP Test Date	10/26/2021	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	8000	ATG Test Date	08/30/2022	Line Tightness Test Date	08/30/2022	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	08/30/2022			ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	04	Tank Age	55	Tank Installed Date	04/24/1971	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	3397	Spill Test Date	10/04/2021	Piping Installed Date	08/10/2009	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	10/26/2021	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	08/30/2022	Tank/Piping CP Test Date	10/26/2021	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	8000	ATG Test Date	08/30/2022	Line Tightness Test Date	08/30/2022	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	08/30/2022			ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	05	Tank Age	55	Tank Installed Date	04/24/1971	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Steel	Overfill Types	High Level Alarm
Tag Number	3398	Spill Test Date	10/04/2021	Piping Installed Date	08/10/2009	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	10/26/2021	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	08/30/2022	Tank/Piping CP Test Date	10/26/2021	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	6000	ATG Test Date	08/30/2022	Line Tightness Test Date	08/30/2022	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	08/30/2022			ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	06	Tank Age	65	Tank Installed Date	04/23/1961	Tank Material	Cathodically Protected Steel	Piping Material	Steel	Overfill Types	High Level Alarm

Tag Number	3399	Spill Test Date	10/04/2021	Piping Installed Date	08/10/2009	Tank Construction	Lined Interior/Impressed Current	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	10/26/2021	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Solvent, Stoddard	PLLD Test Date	08/30/2022	Tank/Piping CP Test Date	10/26/2021	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	6000	ATG Test Date	08/30/2022	Line Tightness Test Date	08/30/2022	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	08/30/2022			ATG Type	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Lake County in the City of Ronan

Location: MOUNTAIN WEST CENEX
63980 Us Hwy 93
Ronan, MT 59864 Lake

System Facility ID:00-32579

Facility Code: 32579
Last Inspected On: 10/03/2025
Operating Permit Renewal Date: 10/14/2025

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: CHS Mountain West

Operator Contact: Joseph Allard;CHS Mountain West Coop

(406) 676-2201

Joseph.Allard@chsinc.com

Owner/Operator: CHS Mountain West

Joseph Allard, UST Class A Operator

Joseph.Allard@chsinc.com

Joseph Allard, UST Class B Operator

Joseph.Allard@chsinc.com

Tank Code	01	Tank Age	2	Tank Installed Date	10/10/2024	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	6260	Spill Test Date	12/10/2024	Piping Installed Date	04/10/2025	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Gasoline	PLLD Test Date	04/14/2025	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	Yes
Capacity	20000	ATG Test Date	04/01/2025	Line Tightness Test Date		Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	04/01/2025			ATG Type					
Tank Code	02	Tank Age	2	Tank Installed Date	10/10/2024	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	6261	Spill Test Date	12/10/2024	Piping Installed Date	04/10/2025	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Gasoline	PLLD Test Date	04/14/2025	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	Yes
Capacity	12000	ATG Test Date	04/01/2025	Line Tightness Test Date		Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	04/01/2025			ATG Type					
Tank Code	03	Tank Age	2	Tank Installed Date	10/10/2024	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve

Tag Number	6262	Spill Test Date	12/10/2024	Piping Installed Date	04/10/2025	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Diesel, Dyed	PLLD Test Date	04/14/2025	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	8000	ATG Test Date	04/01/2025	Line Tightness Test Date		Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	04/01/2025			ATG Type					
Tank Code	04	Tank Age	2	Tank Installed Date	10/10/2024	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	6263	Spill Test Date	12/10/2024	Piping Installed Date	04/10/2025	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Diesel	PLLD Test Date	04/14/2025	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	20000	ATG Test Date	04/01/2025	Line Tightness Test Date		Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	04/01/2025			ATG Type					
Tank Code	05	Tank Age	2	Tank Installed Date	10/10/2024	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	6264	Spill Test Date	12/10/2024	Piping Installed Date	04/10/2025	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Diesel, Dyed	PLLD Test Date	04/14/2025	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	20000	ATG Test Date	04/01/2025	Line Tightness Test Date		Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	04/01/2025			ATG Type					
Tank Code	06	Tank Age	2	Tank Installed Date	10/10/2024	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	6265	Spill Test Date	12/10/2024	Piping Installed Date	04/10/2025	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Diesel	PLLD Test Date	04/14/2025	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	20000	ATG Test Date	04/01/2025	Line Tightness Test Date		Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	04/01/2025			ATG Type					

Tank Code	07	Tank Age	2	Tank Installed Date	10/10/2024	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	6266	Spill Test Date	12/10/2024	Piping Installed Date	04/10/2025	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Diesel	PLLD Test Date	04/14/2025	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	20000	ATG Test Date	04/01/2025	Line Tightness Test Date		Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	04/01/2025			ATG Type					

Facility Summary in Lake County in the City of Ronan

Location: MOUNTAIN WEST CO OP RONAN
63932 US Hwy 93
Ronan, MT 59864 Lake

System Facility ID:24-04530

Facility Code: 22944
Last Inspected On: 10/03/2025
Operating Permit Renewal Date: 12/19/2028

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: CHS Mountain West Coop

(406) 676-2201

Operator Contact: Bob Westin;Dusty Smith;John Thompson;Joseph Allard;CHS Mountain West Coop;Will Dukart (406) 541-6800;(406) 543-8383;(406) 676-2201

chuck.thompson@chsinc.com;dusty.smith@chsinc.com;Joseph.Allard@chsinc.com;will.dukart@chsinc.com

Owner/Operator: CHS Mountain West Coop

(406) 676-2201

Bob Westin, UST Class A Operator

Bob Westin, UST Class B Global Operator

Carrie Clairmont, UST Class B Operator

carrie.clairmont@chsinc.com

Dusty Smith, UST Class A Operator

dusty.smith@chsinc.com

Dusty Smith, UST Class B Global Operator

dusty.smith@chsinc.com

John Thompson, UST Class A Operator

chuck.thompson@chsinc.com

John Thompson, UST Class B Global Operator

chuck.thompson@chsinc.com

John Thompson, UST Class B Operator

chuck.thompson@chsinc.com

Joseph Allard, UST Class A Operator

Joseph.Allard@chsinc.com

Joseph Allard, UST Class B Operator

Joseph.Allard@chsinc.com

Will Dukart, UST Class A Operator

will.dukart@chsinc.com

Will Dukart, UST Class B Global Operator

will.dukart@chsinc.com

Tank Code	09	Tank Age	29	Tank Installed Date	05/01/1997	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	2829	Spill Test Date	09/23/2025	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date	05/21/2019	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	09/23/2025	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	Yes
Capacity	10000	ATG Test Date	09/23/2025	Line Tightness Test Date	09/13/2022	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.1	Energy Act	No
		Overfill Test Date	09/23/2025			ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	10	Tank Age	29	Tank Installed Date	05/01/1997	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	2830	Spill Test Date	09/23/2025	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No

Tank Status	Currently in Use	MLLD Test Date	05/21/2019	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	09/23/2025	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	Yes
Capacity	4000	ATG Test Date	09/23/2025	Line Tightness Test Date	09/13/2022	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.1	Energy Act	No
		Overfill Test Date	09/23/2025			ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	11	Tank Age	29	Tank Installed Date	05/01/1997	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	2831	Spill Test Date	09/23/2025	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date	05/21/2019	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	09/23/2025	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	4000	ATG Test Date	09/23/2025	Line Tightness Test Date	09/13/2022	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.1	Energy Act	No
		Overfill Test Date	09/23/2025			ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	12	Tank Age	29	Tank Installed Date	05/01/1997	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	2832	Spill Test Date	09/23/2025	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date	05/21/2019	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel, Dyed	PLLD Test Date	09/23/2025	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	6000	ATG Test Date	09/23/2025	Line Tightness Test Date	09/13/2022	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.1	Energy Act	No
		Overfill Test Date	09/23/2025			ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	13	Tank Age	29	Tank Installed Date	05/01/1997	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	2833	Spill Test Date	09/23/2025	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date	05/21/2019	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	09/23/2025	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	5000	ATG Test Date	09/23/2025	Line Tightness Test Date	09/13/2022	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.1	Energy Act	No
		Overfill Test Date	09/23/2025			ATG Type	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Lake County in the City of Ronan

Location: RONAN AIRPORT
35564 Ronan Airport Rd
Ronan, MT 59864-9267 Lake

System Facility ID:24-04649

Facility Code: 22948
Last Inspected On: 05/01/2024
Operating Permit Renewal Date: 10/22/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Lake County Joint Airport Board

(406) 883-7214

Operator Contact: Vinson Jennison

vinsu@centurytel.net

Owner/Operator: Lake County Joint Airport Board

(406) 883-7214

Vinson Jennison, UST Class A Operator

Vinson Jennison, UST Class B Global Operator

vinsu@centurytel.net

vinsu@centurytel.net

Tank Code	02	Tank Age	27	Tank Installed Date	04/01/1999	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve;High Level Alarm
Tag Number	3984	Spill Test Date	05/31/2022	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Jet Fuel (Jet-A, Jet-A1, JP5)	PLLD Test Date	03/20/2024	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	12000	ATG Test Date	03/20/2024	Line Tightness Test Date	03/03/2023	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	05/31/2022			ATG Type	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Code	03	Tank Age	27	Tank Installed Date	04/01/1999	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve;High Level Alarm
Tag Number	3985	Spill Test Date	05/31/2022	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Aviation Gas	PLLD Test Date	03/20/2024	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	12000	ATG Test Date	03/20/2024	Line Tightness Test Date	03/03/2023	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No

	Overflow Test Date	05/31/2022		ATG Type	Gilbarco-Veeder Root/TLS- 450PLUS		
--	---------------------------	------------	--	-----------------	---	--	--

Facility Summary in Lake County in the City of Ronan

Location: ST LUKE COMMUNITY CLINIC- RONAN
107 6th Ave SW
Ronan, MT 59864 Lake

System Facility ID:24-03736

Facility Code: 22926
Last Inspected On: 06/20/2023
Operating Permit Renewal Date: 10/16/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Saint Luke Hospital		(406) 676-4441		gburdett@stlukehealthnet.org							
Operator Contact: Gary Burdett;Nicholas Emerson;Steven DeLay		(406) 240-5240;(406) 676-4441		gburdett@stlukehealthnet.org;nemerson@stlukehealthcare.org;sdelay57@gmail.com							
Owner/Operator: Saint Luke Hospital		(406) 676-4441		gburdett@stlukehealthnet.org							
	Gary Burdett, UST Class A Operator				gburdett@stlukehealthnet.org						
	Gary Burdett, UST Class B Operator				gburdett@stlukehealthnet.org						
	Nicholas Emerson, UST Class A Operator				nemerson@stlukehealthcare.org						
	Nicholas Emerson, UST Class B Operator				nemerson@stlukehealthcare.org						
	Steven DeLay, UST Class A Operator				sdelay57@gmail.com						
	Steven DeLay, UST Class B Operator				sdelay57@gmail.com						
Tank Code	S3	Tank Age	27	Tank Installed Date	11/01/1999	Tank Material	Unknown	Piping Material	Copper	Overfill Types	
Tag Number	4369	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	Secondary Containment Chase	AST	Yes
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Auto Dialer	Piping Type	U.S. Suction	CP Met Types	
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection		Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	2000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					

Facility Summary in Lake County in the City of Ronan

Location: TOWN PUMP INC RONAN
63459 US Hwy 93
Ronan, MT 59864-3007 Lake

System Facility ID:24-08718

Facility Code: 23067
Last Inspected On: 03/29/2023
Operating Permit Renewal Date: 09/30/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Ronan 1 Town Pump LLC

(406) 497-6700

environmental@townpump.com

Operator Contact: Trent Biggers

Trentb@townpump.com

Owner/Operator: Ronan 1 Town Pump LLC

(406) 497-6700

environmental@townpump.com

Trent Biggers, UST Class A Operator

Trent Biggers, UST Class B Global Operator

Trentb@townpump.com

Trentb@townpump.com

Tank Code	01	Tank Age	54	Tank Installed Date	04/14/1972	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	4822	Spill Test Date	09/02/2025	Piping Installed Date		Tank Construction	Lined Interior/Impressed Current	Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date	05/13/2021	Tank/Piping CP Test Date	08/22/2022	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	12000	ATG Test Date	10/24/2024	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	08/22/2022			ATG Type	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Code	02	Tank Age	54	Tank Installed Date	04/14/1972	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	4823	Spill Test Date	08/22/2022	Piping Installed Date		Tank Construction	Lined Interior/Impressed Current	Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date	05/13/2021	Tank/Piping CP Test Date	08/22/2022	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	12000	ATG Test Date	10/24/2024	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No

		Overfill Test Date	08/22/2022			ATG Type	Gilbarco-Veeder Root/TLS-450PLUS			
Tank Code	03	Tank Age	54	Tank Installed Date	04/14/1972	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types
Tag Number	4824	Spill Test Date	08/22/2022	Piping Installed Date		Tank Construction	Lined Interior/Impressed Current	Piping Construction	None	AST
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types
Product	Gasoline	PLLD Test Date	05/13/2021	Tank/Piping CP Test Date	08/22/2022	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery
Capacity	6000	ATG Test Date	10/24/2024	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act
		Overfill Test Date	08/22/2022			ATG Type	Gilbarco-Veeder Root/TLS-450PLUS			
Tank Code	04	Tank Age	46	Tank Installed Date	04/14/1980	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types
Tag Number	4825	Spill Test Date	08/22/2022	Piping Installed Date		Tank Construction	Lined Interior/Impressed Current	Piping Construction	None	AST
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types
Product	Diesel	PLLD Test Date	05/13/2021	Tank/Piping CP Test Date	08/22/2022	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery
Capacity	6000	ATG Test Date	10/24/2024	Line Tightness Test Date	09/19/2024	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act
		Overfill Test Date	08/22/2022			ATG Type	Gilbarco-Veeder Root/TLS-450PLUS			
Tank Code	05	Tank Age	19	Tank Installed Date	07/05/2007	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types
Tag Number	5073	Spill Test Date	08/22/2022	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types
Product	Gasoline	PLLD Test Date	05/13/2021	Tank/Piping CP Test Date		Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery
Capacity	12000	ATG Test Date	10/24/2024	Line Tightness Test Date		Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act

	Overfill Test Date	08/22/2022		ATG Type	Gilbarco-Veeder Root/TLS- 450PLUS		
--	---------------------------	------------	--	-----------------	---	--	--

Facility Summary in Lake County in the City of Saint Ignatius

Location: ALLARDS STAGE STOP LLC
77579 US Hwy 93 N
Saint Ignatius, MT 59865-0460 Lake

System Facility ID:24-05769

Facility Code: 22982
Last Inspected On: 01/25/2024
Operating Permit Renewal Date: 03/13/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Mission View Properties LLC

(509) 994-6599

histarms01@yahoo.com

Operator Contact: Mamie Ahlborn

(406) 207-2810

mamie_ahlborn@hotmail.com

Owner/Operator: Mission View Properties LLC

(509) 994-6599

histarms01@yahoo.com

Mamie Ahlborn, UST Class A Operator

Mamie Ahlborn, UST Class B Global Operator

mamie_ahlborn@hotmail.com

mamie_ahlborn@hotmail.com

Tank Code	04	Tank Age	21	Tank Installed Date	12/01/2005	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	5042	Spill Test Date	04/14/2023	Piping Installed Date	06/04/2019	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	10/12/2023	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	10000	ATG Test Date	10/12/2023	Line Tightness Test Date	09/20/2022	Secondary Tank Leak Detection		Secondary Pipe Detection	MLLD Line Tightness Testing	Energy Act	Yes
		Overfill Test Date	10/12/2023			ATG Type	Veeder Root/TLS-300				
Tank Code	05	Tank Age	21	Tank Installed Date	12/01/2005	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	5043	Spill Test Date	04/14/2023	Piping Installed Date	06/04/2019	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	10/12/2023	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	10000	ATG Test Date	10/12/2023	Line Tightness Test Date	09/20/2022	Secondary Tank Leak Detection		Secondary Pipe Detection	MLLD Line Tightness Testing	Energy Act	Yes
		Overfill Test Date	10/12/2023			ATG Type	Veeder Root/TLS-300				

Facility Summary in Lake County in the City of Saint Ignatius

Location: MOUNTAIN VIEW CENEX
240 Mountain View Dr
Saint Ignatius, MT 59865 Lake

System Facility ID:24-10647

Facility Code: 23153
Last Inspected On: 09/13/2023
Operating Permit Renewal Date: 09/13/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Mission View Properties LLC

(509) 994-6599

histarms01@yahoo.com

Operator Contact: Mamie Ahlborn

(406) 207-2810

mamie_ahlborn@hotmail.com

Owner/Operator: Mission View Properties LLC

(509) 994-6599

histarms01@yahoo.com

Mamie Ahlborn, UST Class A Operator

mamie_ahlborn@hotmail.com

Mamie Ahlborn, UST Class B Global Operator

mamie_ahlborn@hotmail.com

Mamie Ahlborn, UST Class B Operator

mamie_ahlborn@hotmail.com

Tank Code	06	Tank Age	31	Tank Installed Date	05/01/1995	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	4595	Spill Test Date	06/22/2023	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	10/12/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection		Vapor Recovery	No
Capacity	8000	ATG Test Date	10/12/2023	Line Tightness Test Date	08/22/2017	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	10/12/2023			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	07	Tank Age	31	Tank Installed Date	05/01/1995	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	4596	Spill Test Date	06/22/2023	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date	10/12/2023	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	10/12/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	8000	ATG Test Date	10/12/2023	Line Tightness Test Date	09/26/2022	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	10/12/2023			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Tank Code	08	Tank Age	31	Tank Installed Date	05/01/1995	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	4597	Spill Test Date	04/13/2023	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date	10/12/2023	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	10/12/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	6000	ATG Test Date	10/12/2023	Line Tightness Test Date	09/26/2022	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	10/12/2023			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	09	Tank Age	11	Tank Installed Date	10/01/2015	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	5619	Spill Test Date	04/13/2023	Piping Installed Date	10/23/2015	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	10/12/2023	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	8000	ATG Test Date	10/12/2023	Line Tightness Test Date	09/26/2022	Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	MLLD Line Tightness Testing	Energy Act	Yes
		Overfill Test Date	10/12/2023			ATG Type	Gilbarco-Veeder Root/TLS-350;Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Lake County in the City of Saint Ignatius

Location: SAINT IGNATIUS SCHOOL
4th & Blaine St
Saint Ignatius, MT 59865 Lake

System Facility ID:24-03762

Facility Code: 22927
Last Inspected On: 02/08/2024
Operating Permit Renewal Date: 02/08/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: School Dist 28 Saint Ignatius (406) 745-3811

Operator Contact: Stephen McCollum (406) 396-7842 smccollum@stignatiusschools.org

Owner/Operator: School Dist 28 Saint Ignatius (406) 745-3811

Stephen McCollum, UST Class A Operator
Stephen McCollum, UST Class B Global Operator
smccollum@stignatiusschools.org
smccollum@stignatiusschools.org

Tank Code	03	Tank Age	29	Tank Installed Date	06/01/1997	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	4563	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Temporarily Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Auto Dialer	Piping Type	U.S. Suction	CP Met Types	Galvanic
Product	Heating Oil	PLLD Test Date		Tank/Piping CP Test Date	10/24/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	10000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type	EMCO Electronics/EECO 1500				