

Facility Summary in Lake County in the City of Arlee

Location: WILSON FOODS
92345 US Hwy 93
Arlee, MT 59821-9433 Lake

System Facility ID:24-06788

Facility Code: 23006
Last Inspected On: 02/19/2024
Operating Permit Renewal Date: 03/21/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Wilson Foods

Operator Contact: John Carranco;Velva Stuck;Wilson Foods

(406) 549-0891

velva1962@yahoo.com

Owner/Operator: Wilson Foods

John Carranco, UST Class A Operator
John Carranco, UST Class B Operator
Velva Stuck, UST Class A Operator
Velva Stuck, UST Class B Operator

velva1962@yahoo.com
velva1962@yahoo.com

| | | | | | | | | | | | |
|--------------------|------------------|---------------------------|------------|---------------------------------|------------|--------------------------------------|-------------------------------|---------------------------------|-------------------------------|-----------------------|------------------|
| Tank Code | 10 | Tank Age | 28 | Tank Installed Date | 11/01/1998 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | High Level Alarm |
| Tag Number | 3320 | Spill Test Date | 09/15/2022 | Piping Installed Date | | Tank Construction | | Piping Construction | None | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | 01/19/2026 | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Mechanical Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Gasoline | PLLD Test Date | | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | MLLD Line Tightness Testing | Vapor Recovery | No |
| Capacity | 10000 | ATG Test Date | 01/19/2026 | Line Tightness Test Date | 01/19/2026 | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | No |
| | | Overfill Test Date | 09/15/2022 | | | ATG Type | Gilbarco-Veeder Root/TLS-300 | | | | |
| Tank Code | 11 | Tank Age | 28 | Tank Installed Date | 11/01/1998 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | High Level Alarm |
| Tag Number | 3321 | Spill Test Date | 09/15/2022 | Piping Installed Date | | Tank Construction | | Piping Construction | None | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | 01/19/2026 | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Mechanical Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Gasoline | PLLD Test Date | | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | MLLD Line Tightness Testing | Vapor Recovery | No |
| Capacity | 4000 | ATG Test Date | 01/19/2026 | Line Tightness Test Date | 01/19/2026 | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | No |
| | | Overfill Test Date | 09/15/2022 | | | ATG Type | Gilbarco-Veeder Root/TLS-300 | | | | |

| | | | | | | | | | | | |
|--------------------|------------------|---------------------------|------------|---------------------------------|------------|--------------------------------------|-------------------------------|---------------------------------|-------------------------------|-----------------------|------------------|
| Tank Code | 12 | Tank Age | 28 | Tank Installed Date | 11/01/1998 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | High Level Alarm |
| Tag Number | 3322 | Spill Test Date | 09/15/2022 | Piping Installed Date | | Tank Construction | | Piping Construction | None | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | 01/19/2026 | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Mechanical Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Diesel | PLLD Test Date | | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | MLLD Line Tightness Testing | Vapor Recovery | No |
| Capacity | 4000 | ATG Test Date | 01/19/2026 | Line Tightness Test Date | 01/19/2026 | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | No |
| | | Overfill Test Date | 11/15/2022 | | | ATG Type | Gilbarco-Veeder Root/TLS-300 | | | | |

Facility Summary in Lake County in the City of Charlo

Location: CHARLO SCHOOL DIST 7 J
405 2nd Ave E
Charlo, MT 59824 Lake

System Facility ID:24-02789

Facility Code: 22907
Last Inspected On: 11/01/2023
Operating Permit Renewal Date: 03/27/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: School Dist 7 J Charlo (406) 644-2207

Operator Contact: Joe Broom;School Dist 7 J Charlo (406) 249-8000;(406) 644-2207 jbroom@charloschools.com

Owner/Operator: School Dist 7 J Charlo (406) 644-2207

Joe Broom, UST Class A Operator

jbroom@charloschools.com

Joe Broom, UST Class B Operator

jbroom@charloschools.com

| | | | | | | | | | | | |
|--------------------|------------------|---------------------------|------------|---------------------------------|------------|--------------------------------------|-------------|---------------------------------|------------------------------------|-----------------------|------------------|
| Tank Code | S5 | Tank Age | 28 | Tank Installed Date | 07/01/1998 | Tank Material | Unknown | Piping Material | Flexible Plastic | Overfill Types | High Level Alarm |
| Tag Number | 611 | Spill Test Date | | Piping Installed Date | 07/09/2012 | Tank Construction | | Piping Construction | Double Walled | AST | Yes |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Auto Dialer | Piping Type | U.S. Suction | CP Met Types | |
| Product | Heating Oil | PLLD Test Date | | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Deferred | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery | No |
| Capacity | 10000 | ATG Test Date | 11/01/2023 | Line Tightness Test Date | 08/27/2012 | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | Yes |
| | | Overfill Test Date | | | | ATG Type | | | | | |

Facility Summary in Lake County in the City of Charlo

Location: COULTER AUTOMOTIVE INC
104 Main St
Charlo, MT 59824-0097 Lake

System Facility ID:24-04615

Facility Code: 22947
Last Inspected On: 11/22/2024
Operating Permit Renewal Date: 04/01/2028

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Coulter Automotive Inc (406) 644-2215

Operator Contact: Sandra Coulter (406) 644-2215 coulterauto@charlo.net

Owner/Operator: Coulter Automotive Inc (406) 644-2215

Sandra Coulter, UST Class A Operator
Sandra Coulter, UST Class B Operator

coulterauto@charlo.net
coulterauto@charlo.net

| | | | | | | | | | | | |
|--------------------|------------------|---------------------------|------------|---------------------------------|------------|--------------------------------------|-------------------------------|---------------------------------|-------------------------------|-----------------------|---------------|
| Tank Code | 03 | Tank Age | 31 | Tank Installed Date | 07/01/1995 | Tank Material | Cathodically Protected Steel | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | Flapper Valve |
| Tag Number | 2281 | Spill Test Date | 11/22/2024 | Piping Installed Date | | Tank Construction | | Piping Construction | None | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | 11/22/2024 | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Mechanical Line Leak Detector | Piping Type | Pressurized | CP Met Types | Galvanic |
| Product | Gasoline | PLLD Test Date | | Tank/Piping CP Test Date | 09/28/2022 | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | MLLD Line Tightness Testing | Vapor Recovery | No |
| Capacity | 6000 | ATG Test Date | 11/22/2024 | Line Tightness Test Date | 11/22/2024 | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | No |
| | | Overfill Test Date | 11/22/2024 | | | ATG Type | EMCO Electronics/EECO 1500 | | | | |
| Tank Code | 04 | Tank Age | 31 | Tank Installed Date | 07/01/1995 | Tank Material | Cathodically Protected Steel | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | Flapper Valve |
| Tag Number | 2282 | Spill Test Date | 11/22/2024 | Piping Installed Date | | Tank Construction | | Piping Construction | None | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | 11/22/2024 | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Mechanical Line Leak Detector | Piping Type | Pressurized | CP Met Types | Galvanic |
| Product | Gasoline | PLLD Test Date | | Tank/Piping CP Test Date | 09/28/2022 | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | MLLD Line Tightness Testing | Vapor Recovery | No |
| Capacity | 4000 | ATG Test Date | 11/22/2024 | Line Tightness Test Date | 11/22/2024 | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | No |
| | | Overfill Test Date | 11/22/2024 | | | ATG Type | EMCO Electronics/EECO 1500 | | | | |

Facility Summary in Lake County in the City of Charlo

Location: MOIESE MERCANTILE
64620 MT Hwy 212
Charlo, MT 59824-9004 Lake

System Facility ID:24-06382

Facility Code: 22995
Last Inspected On: 02/04/2025
Operating Permit Renewal Date: 02/04/2028

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Moiese Mercantile (406) 644-3454 debh12703@gmail.com

Operator Contact: Debra Hall;Moiese Mercantile;Timothy Hall (406) 644-3454 debh12703@gmail.com;debh12703@gmail.com

Owner/Operator: Moiese Mercantile (406) 644-3454 debh12703@gmail.com
Debra Hall, UST Class A Operator debh12703@gmail.com
Leslie Muth, UST Class B Operator llafrinire@gmail.com
Timothy Hall, UST Class A Operator

| | | | | | | | | | | | |
|--------------------|------------------------|---------------------------|----|---------------------------------|------------|--------------------------------------|--------------------------------------|---------------------------------|-------------------------------|-----------------------|----------------|
| Tank Code | 03 | Tank Age | 27 | Tank Installed Date | 03/01/1999 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | Flapper Valve |
| Tag Number | 3968 | Spill Test Date | | Piping Installed Date | | Tank Construction | | Piping Construction | Single Walled | AST | No |
| Tank Status | Temporarily Out of Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Not Required | Piping Type | Safe Suction | CP Met Types | Non-corrodible |
| Product | Gasoline | PLLD Test Date | | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Statistical Inventory Reconciliation | Primary Pipe Detection | | Vapor Recovery | No |
| Capacity | 1000 | ATG Test Date | | Line Tightness Test Date | 10/25/2004 | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | No |
| | | Overfill Test Date | | | | ATG Type | | | | | |

Facility Summary in Lake County in the City of Pablo

Location: PABLO ELEMENTARY SCHOOL
608 4th Ave
Pablo, MT 59855 Lake

System Facility ID:24-04823

Facility Code: 22952
Last Inspected On: 02/03/2025
Operating Permit Renewal Date: 10/22/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: School Dist 30 Ronan (406) 644-2448

Operator Contact: Brad Benson;Lawrence Cordis;Rob Tougas (406) 250-8008 larry.cordis@ronank12.edu;rob.tougas@ronank12.edu

Owner/Operator: School Dist 30 Ronan (406) 644-2448

Brad Benson, UST Class A Operator
Brad Benson, UST Class B Global Operator
Lawrence Cordis, UST Class A Operator
Lawrence Cordis, UST Class B Global Operator
Rob Tougas, UST Class A Operator
Rob Tougas, UST Class B Global Operator

larry.cordis@ronank12.edu
larry.cordis@ronank12.edu
rob.tougas@ronank12.edu
rob.tougas@ronank12.edu

| | | | | | | | | | | | |
|--------------------|------------------|---------------------------|------------|---------------------------------|------------|--------------------------------------|------------------------------------|---------------------------------|------------------------------------|-----------------------|-----|
| Tank Code | 02 | Tank Age | 2 | Tank Installed Date | 09/01/2024 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Flexible Plastic | Overfill Types | |
| Tag Number | 6250 | Spill Test Date | 02/03/2025 | Piping Installed Date | 08/21/2002 | Tank Construction | | Piping Construction | | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Auto Dialer | Piping Type | U.S. Suction | CP Met Types | |
| Product | Heating Oil | PLLD Test Date | | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Continuous Interstitial Monitoring | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery | No |
| Capacity | 8000 | ATG Test Date | 03/04/2026 | Line Tightness Test Date | 07/03/2024 | Secondary Tank Leak Detection | Automatic Tank Gauging 0.2 | Secondary Pipe Detection | | Energy Act | Yes |
| | | Overfill Test Date | 03/04/2026 | | | ATG Type | | | | | |

Facility Summary in Lake County in the City of Pablo

Location: QUICKSILVER EXPRESS
52001 US Hwy 93
Pablo, MT 59855 Lake

System Facility ID:24-11124

Facility Code: 23179
Last Inspected On: 12/02/2025
Operating Permit Renewal Date: 03/16/2029

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Quick Silver Express (406) 675-5000 corky.sias@cskt.org

Operator Contact: Corky Sias (406) 275-2792 corky.sias@cskt.org

Owner/Operator: Quick Silver Express (406) 675-5000 corky.sias@cskt.org
Corky Sias, UST Class A Operator corky.sias@cskt.org
Corky Sias, UST Class B Operator corky.sias@cskt.org

| | | | | | | | | | | | |
|--------------------|------------------|---------------------------|------------|---------------------------------|------------|--------------------------------------|---|---------------------------------|-------------------------------|-----------------------|--------------------------------|
| Tank Code | 01 | Tank Age | 39 | Tank Installed Date | 01/01/1987 | Tank Material | Cathodically Protected Steel | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | Ball Float Valve;Flapper Valve |
| Tag Number | 3296 | Spill Test Date | 10/23/2024 | Piping Installed Date | | Tank Construction | | Piping Construction | None | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | 05/30/2023 | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Galvanic |
| Product | Diesel, Dyed | PLLD Test Date | | Tank/Piping CP Test Date | 07/18/2023 | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | ELLD 0.2 | Vapor Recovery | No |
| Capacity | 8000 | ATG Test Date | 07/23/2025 | Line Tightness Test Date | 03/16/2017 | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | No |
| | | Overfill Test Date | 10/23/2024 | | | ATG Type | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | | | |
| Tank Code | 02 | Tank Age | 39 | Tank Installed Date | 01/01/1987 | Tank Material | Cathodically Protected Steel | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | Ball Float Valve;Flapper Valve |
| Tag Number | 3297 | Spill Test Date | 10/23/2024 | Piping Installed Date | | Tank Construction | | Piping Construction | None | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | 10/23/2024 | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Galvanic |
| Product | Gasoline | PLLD Test Date | | Tank/Piping CP Test Date | 07/18/2023 | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | ELLD 0.2 | Vapor Recovery | No |
| Capacity | 8000 | ATG Test Date | 07/23/2025 | Line Tightness Test Date | 03/16/2017 | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | No |
| | | Overfill Test Date | 10/23/2024 | | | ATG Type | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | | | |

| | | | | | | | | | | | |
|--------------------|------------------|---------------------------|------------|---------------------------------|------------|--------------------------------------|---|---------------------------------|------------------------------------|-----------------------|---------------------------------|
| Tank Code | 03 | Tank Age | 39 | Tank Installed Date | 01/01/1987 | Tank Material | Cathodically Protected Steel | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | Ball Float Valve; Flapper Valve |
| Tag Number | 3298 | Spill Test Date | 10/23/2024 | Piping Installed Date | | Tank Construction | | Piping Construction | None | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | 05/30/2023 | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Galvanic |
| Product | Diesel | PLLD Test Date | | Tank/Piping CP Test Date | 07/18/2023 | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | ELLD 0.2 | Vapor Recovery | No |
| Capacity | 8000 | ATG Test Date | 07/23/2025 | Line Tightness Test Date | 03/16/2017 | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | No |
| | | Overfill Test Date | 10/23/2024 | | | ATG Type | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | | | |
| Tank Code | 04 | Tank Age | 15 | Tank Installed Date | 05/01/2011 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Flexible Plastic | Overfill Types | Ball Float Valve; Flapper Valve |
| Tag Number | 5344 | Spill Test Date | 10/23/2024 | Piping Installed Date | 05/01/2011 | Tank Construction | Double-Walled | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | 05/30/2023 | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Gasoline | PLLD Test Date | | Tank/Piping CP Test Date | 03/16/2017 | Primary Tank Leak Detection | Continuous Interstitial Monitoring | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery | No |
| Capacity | 12000 | ATG Test Date | 07/23/2025 | Line Tightness Test Date | 03/16/2017 | Secondary Tank Leak Detection | Automatic Tank Gauging 0.2 | Secondary Pipe Detection | ELLD 0.2 | Energy Act | Yes |
| | | Overfill Test Date | 10/23/2024 | | | ATG Type | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | | | |

Facility Summary in Lake County in the City of Polson

Location: GOLDES
33537 MT Hwy 35
Polson, MT 59860 Lake

System Facility ID:60-15208

Facility Code: 30928
Last Inspected On: 03/25/2024
Operating Permit Renewal Date: 07/16/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Jeffrey Goldes (406) 443-0454

Operator Contact: Serena Keller;Travis Schenck (406) 837-6679;(406) 885-1530 serena@valleymaintenance.com;travis.schenck.p@gmail.com

Owner/Operator: Jeffrey Goldes (406) 443-0454

Frank Jasper, UST Class B Operator
Serena Keller, UST Class A Operator
Serena Keller, UST Class B Operator
Travis Schenck, UST Class A Operator

frank.j.jasper@gmail.com
serena@valleymaintenance.com
serena@valleymaintenance.com
travis.schenck.p@gmail.com

| | | | | | | | | | | | |
|--------------------|------------------|---------------------------|------------|---------------------------------|------------|--------------------------------------|------------------------------------|---------------------------------|------------------------------------|-----------------------|-----|
| Tank Code | S2 | Tank Age | 14 | Tank Installed Date | 05/01/2012 | Tank Material | Aboveground Tank | Piping Material | Flexible Plastic | Overfill Types | |
| Tag Number | 5365 | Spill Test Date | | Piping Installed Date | 04/17/2012 | Tank Construction | | Piping Construction | Double Walled | AST | Yes |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | 04/05/2022 | Catastrophic L.D Type 3.0 | Continuous Interstitial Monitoring | Piping Type | Gravity Feed | CP Met Types | |
| Product | Gasoline | PLLD Test Date | | Tank/Piping CP Test Date | | Primary Tank Leak Detection | | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery | No |
| Capacity | 500 | ATG Test Date | 06/15/2023 | Line Tightness Test Date | | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | Yes |
| | | Overfill Test Date | | | | ATG Type | | | | | |

Facility Summary in Lake County in the City of Polson

Location: HILLTOP GAS AND GO
44613 US Hwy 93
Polson, MT 59860-7585 Lake

System Facility ID:24-07247

Facility Code: 23026
Last Inspected On: 01/20/2024
Operating Permit Renewal Date: 01/20/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Hilltop Gas and Go (916) 997-0412 jill-grove@comcast.net

Operator Contact: Dustin Noakes jill-grove@comcast.net

Owner/Operator: Hilltop Gas and Go (916) 997-0412 jill-grove@comcast.net

Dustin Noakes, UST Class A Operator
Dustin Noakes, UST Class B Operator

jill-grove@comcast.net
jill-grove@comcast.net

| | | | | | | | | | | | |
|--------------------|------------------------|---------------------------|----|---------------------------------|------------|--------------------------------------|-------------------------------|---------------------------------|------------------------------------|-----------------------|------------------|
| Tank Code | 04 | Tank Age | 30 | Tank Installed Date | 04/01/1996 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Flexible Plastic | Overfill Types | Ball Float Valve |
| Tag Number | 1215 | Spill Test Date | | Piping Installed Date | | Tank Construction | | Piping Construction | Double Walled | AST | No |
| Tank Status | Temporarily Out of Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Gasoline | PLLD Test Date | | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | ELLD 0.2 | Vapor Recovery | No |
| Capacity | 12000 | ATG Test Date | | Line Tightness Test Date | | Secondary Tank Leak Detection | | Secondary Pipe Detection | Continuous Interstitial Monitoring | Energy Act | No |
| | | Overfill Test Date | | | | ATG Type | Incon/TS-1000 | | | | |
| Tank Code | 05 | Tank Age | 30 | Tank Installed Date | 04/01/1996 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Flexible Plastic | Overfill Types | Ball Float Valve |
| Tag Number | 1216 | Spill Test Date | | Piping Installed Date | | Tank Construction | | Piping Construction | Double Walled | AST | No |
| Tank Status | Temporarily Out of Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Gasoline | PLLD Test Date | | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | ELLD 0.2 | Vapor Recovery | No |
| Capacity | 8000 | ATG Test Date | | Line Tightness Test Date | | Secondary Tank Leak Detection | | Secondary Pipe Detection | Continuous Interstitial Monitoring | Energy Act | No |
| | | Overfill Test Date | | | | ATG Type | Incon/TS-1000 | | | | |
| Tank Code | 06 | Tank Age | 30 | Tank Installed Date | 04/01/1996 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Flexible Plastic | Overfill Types | Ball Float Valve |

| | | | | | | | | | | | |
|--------------------|------------------------|---------------------------|--|---------------------------------|--|--------------------------------------|-------------------------------|---------------------------------|------------------------------------|-----------------------|----------------|
| Tag Number | 1217 | Spill Test Date | | Piping Installed Date | | Tank Construction | | Piping Construction | Double Walled | AST | No |
| Tank Status | Temporarily Out of Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Diesel | PLLD Test Date | | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | ELLD 0.2 | Vapor Recovery | No |
| Capacity | 5000 | ATG Test Date | | Line Tightness Test Date | | Secondary Tank Leak Detection | | Secondary Pipe Detection | Continuous Interstitial Monitoring | Energy Act | No |
| | | Overfill Test Date | | | | ATG Type | Incon/TS-1000 | | | | |

Facility Summary in Lake County in the City of Polson

Location: MOUNTAIN WEST CO OP POLSON
808 Main St
Polson, MT 59860-3227 Lake

System Facility ID:24-04560

Facility Code: 22946
Last Inspected On: 08/16/2023
Operating Permit Renewal Date: 12/02/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: CHS Mountain West Coop (406) 676-2201

Operator Contact: Dusty Smith;Joseph Allard;CHS Mountain West Coop (406) 676-2201 dusty.smith@chsinc.com;Joseph.Allard@chsinc.com

Owner/Operator: CHS Mountain West Coop (406) 676-2201

Dusty Smith, UST Class A Operator
Dusty Smith, UST Class B Global Operator
John Adams, UST Class B Operator
Joseph Allard, UST Class A Operator
Joseph Allard, UST Class B Operator

dusty.smith@chsinc.com
dusty.smith@chsinc.com
john.adams@chsinc.com
Joseph.Allard@chsinc.com
Joseph.Allard@chsinc.com

| | | | | | | | | | | | |
|--------------------|------------------|---------------------------|------------|---------------------------------|------------|--------------------------------------|---|---------------------------------|------------------------------------|-----------------------|------------------|
| Tank Code | 05 | Tank Age | 26 | Tank Installed Date | 01/01/2000 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Flexible Plastic | Overfill Types | Ball Float Valve |
| Tag Number | 4155 | Spill Test Date | 03/27/2023 | Piping Installed Date | | Tank Construction | | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | 03/30/2020 | Sump Tightness Test Date | 03/27/2023 | Catastrophic L.D Type 3.0 | Auto Dialer;Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Diesel | PLLD Test Date | 09/22/2025 | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery | No |
| Capacity | 6000 | ATG Test Date | 09/22/2025 | Line Tightness Test Date | 03/30/2020 | Secondary Tank Leak Detection | | Secondary Pipe Detection | ELLD 0.2 | Energy Act | No |
| | | Overfill Test Date | 07/12/2023 | | | ATG Type | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | | | |
| Tank Code | 06 | Tank Age | 26 | Tank Installed Date | 01/01/2000 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Flexible Plastic | Overfill Types | Ball Float Valve |
| Tag Number | 4156 | Spill Test Date | 04/04/2023 | Piping Installed Date | 10/09/2013 | Tank Construction | | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | 03/30/2020 | Sump Tightness Test Date | 03/27/2023 | Catastrophic L.D Type 3.0 | Auto Dialer;Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |

| | | | | | | | | | | | |
|--------------------|------------------|---------------------------|------------|---------------------------------|------------|--------------------------------------|---|---------------------------------|------------------------------------|-----------------------|------------------|
| Product | Gasoline | PLLD Test Date | 09/22/2025 | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery | No |
| Capacity | 5000 | ATG Test Date | 09/22/2025 | Line Tightness Test Date | 03/30/2020 | Secondary Tank Leak Detection | | Secondary Pipe Detection | ELLD 0.2 | Energy Act | No |
| | | Overfill Test Date | 07/12/2023 | | | ATG Type | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | | | |
| Tank Code | 08 | Tank Age | 26 | Tank Installed Date | 01/01/2000 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Flexible Plastic | Overfill Types | Ball Float Valve |
| Tag Number | 4648 | Spill Test Date | 03/27/2023 | Piping Installed Date | | Tank Construction | | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | 03/30/2020 | Sump Tightness Test Date | 03/27/2023 | Catastrophic L.D Type 3.0 | Auto Dialer;Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Diesel | PLLD Test Date | 09/22/2025 | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery | No |
| Capacity | 5000 | ATG Test Date | 09/22/2025 | Line Tightness Test Date | 03/30/2020 | Secondary Tank Leak Detection | | Secondary Pipe Detection | ELLD 0.2 | Energy Act | No |
| | | Overfill Test Date | 07/12/2023 | | | ATG Type | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | | | |
| Tank Code | 07 | Tank Age | 26 | Tank Installed Date | 01/01/2000 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Flexible Plastic | Overfill Types | Ball Float Valve |
| Tag Number | 4741 | Spill Test Date | 04/04/2023 | Piping Installed Date | | Tank Construction | | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | 03/30/2020 | Sump Tightness Test Date | 03/27/2023 | Catastrophic L.D Type 3.0 | Auto Dialer;Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Gasoline | PLLD Test Date | 09/22/2025 | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery | No |
| Capacity | 10000 | ATG Test Date | 09/22/2025 | Line Tightness Test Date | 03/30/2020 | Secondary Tank Leak Detection | | Secondary Pipe Detection | ELLD 0.2 | Energy Act | No |
| | | Overfill Test Date | 07/12/2023 | | | ATG Type | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | | | |

Facility Summary in Lake County in the City of Polson

Location: PIER 93
49433 US Hwy 93
Polson, MT 59860 Lake

System Facility ID:24-05957

Facility Code: 22988
Last Inspected On: 01/06/2025
Operating Permit Renewal Date: 06/30/2028

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Jacks Pier 93 (406) 883-5768 jacobmiller1234@outlook.com

Operator Contact: Donald Miller; Jacob Miller (406) 883-4531; (406) 883-5768 jacobmiller1234@outlook.com; pier93@montanasky.net

Owner/Operator: Jacks Pier 93 (406) 883-5768 jacobmiller1234@outlook.com

| | |
|---|-----------------------------|
| Donald Miller, UST Class A Operator | pier93@montanasky.net |
| Donald Miller, UST Class B Operator | pier93@montanasky.net |
| Jacob Miller, UST Class A Operator | jacobmiller1234@outlook.com |
| Jacob Miller, UST Class B Global Operator | jacobmiller1234@outlook.com |
| Jacob Miller, UST Class B Operator | jacobmiller1234@outlook.com |

| | | | | | | | | | | | |
|--------------------|------------------|---------------------------|------------|---------------------------------|------------|--------------------------------------|-------------------------------|---------------------------------|-------------------------------|-----------------------|---------------|
| Tank Code | 01 | Tank Age | 40 | Tank Installed Date | 04/23/1986 | Tank Material | Cathodically Protected Steel | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | Flapper Valve |
| Tag Number | 1802 | Spill Test Date | 10/03/2024 | Piping Installed Date | | Tank Construction | | Piping Construction | Single Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | 05/09/2024 | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Mechanical Line Leak Detector | Piping Type | Pressurized | CP Met Types | Galvanic |
| Product | Diesel | PLLD Test Date | | Tank/Piping CP Test Date | 04/25/2022 | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | MLLD Line Tightness Testing | Vapor Recovery | No |
| Capacity | 4000 | ATG Test Date | 05/09/2024 | Line Tightness Test Date | 05/09/2024 | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | No |
| | | Overfill Test Date | 10/03/2024 | | | ATG Type | Gilbarco-Veeder Root/TLS-350 | | | | |
| Tank Code | 02 | Tank Age | 40 | Tank Installed Date | 04/23/1986 | Tank Material | Cathodically Protected Steel | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | Flapper Valve |
| Tag Number | 1803 | Spill Test Date | 05/05/2022 | Piping Installed Date | | Tank Construction | | Piping Construction | Single Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | 05/09/2024 | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Mechanical Line Leak Detector | Piping Type | Pressurized | CP Met Types | Galvanic |
| Product | Gasoline | PLLD Test Date | | Tank/Piping CP Test Date | 04/25/2022 | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | MLLD Line Tightness Testing | Vapor Recovery | No |
| Capacity | 6000 | ATG Test Date | 05/09/2024 | Line Tightness Test Date | 05/09/2024 | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | No |
| | | Overfill Test Date | 05/05/2022 | | | ATG Type | Gilbarco-Veeder Root/TLS-350 | | | | |

| | | | | | | | | | | | |
|--------------------|------------------|---------------------------|------------|---------------------------------|------------|--------------------------------------|-------------------------------|---------------------------------|-------------------------------|-----------------------|---------------|
| Tank Code | 06 | Tank Age | 36 | Tank Installed Date | 11/01/1990 | Tank Material | Cathodically Protected Steel | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | Flapper Valve |
| Tag Number | 1804 | Spill Test Date | 05/05/2022 | Piping Installed Date | | Tank Construction | | Piping Construction | Single Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | 05/09/2024 | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Mechanical Line Leak Detector | Piping Type | Pressurized | CP Met Types | Galvanic |
| Product | Gasoline | PLLD Test Date | | Tank/Piping CP Test Date | 04/25/2022 | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | MLLD Line Tightness Testing | Vapor Recovery | No |
| Capacity | 10000 | ATG Test Date | 05/09/2024 | Line Tightness Test Date | 05/09/2024 | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | No |
| | | Overfill Test Date | 05/05/2022 | | | ATG Type | Gilbarco-Veeder Root/TLS-350 | | | | |

Facility Summary in Lake County in the City of Polson

Location: POLSON BAY GROCERY 425
50451 US Hwy 93
Polson, MT 59860 Lake

System Facility ID:24-05770

Facility Code: 22983
Last Inspected On: 01/28/2026
Operating Permit Renewal Date: 08/09/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Jays Corporation (406) 549-1750 polsonbay@yahoo.com

Operator Contact: Jagpreet Ghuman;Jaspal Sandhu;Jays Corporation (406) 549-1750;(406) 880-7677 jas_sandhu75@hotmail.com;polsonbay@yahoo.com;jaysfood08@outlook.com

Owner/Operator: Jays Corporation (406) 549-1750 polsonbay@yahoo.com
 Jagpreet Ghuman, UST Class A Operator jaysfood08@outlook.com
 Jagpreet Ghuman, UST Class B Operator jays1stop21@outlook.com
 Jaspal Sandhu, UST Class A Operator polsonbay@yahoo.com
 Jaspal Sandhu, UST Class B Operator polsonbay@yahoo.com

| | | | | | | | | | | | |
|--------------------|------------------|---------------------------|------------|---------------------------------|------------|--------------------------------------|---|---------------------------------|------------------------------------|-----------------------|------------------|
| Tank Code | 04 | Tank Age | 24 | Tank Installed Date | 05/23/2002 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Flexible Plastic | Overfill Types | High Level Alarm |
| Tag Number | 4664 | Spill Test Date | 06/22/2021 | Piping Installed Date | | Tank Construction | | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Gasoline | PLLD Test Date | 03/05/2020 | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | ELLD 0.2 | Vapor Recovery | No |
| Capacity | 20000 | ATG Test Date | 02/15/2023 | Line Tightness Test Date | | Secondary Tank Leak Detection | | Secondary Pipe Detection | Continuous Interstitial Monitoring | Energy Act | No |
| | | Overfill Test Date | 02/25/2023 | | | ATG Type | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | | | |
| Tank Code | 05 | Tank Age | 24 | Tank Installed Date | 05/23/2002 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Flexible Plastic | Overfill Types | High Level Alarm |
| Tag Number | 4665 | Spill Test Date | 06/22/2021 | Piping Installed Date | | Tank Construction | | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Gasoline | PLLD Test Date | 03/05/2020 | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | ELLD 0.2 | Vapor Recovery | No |
| Capacity | 10000 | ATG Test Date | 02/15/2023 | Line Tightness Test Date | | Secondary Tank Leak Detection | | Secondary Pipe Detection | Continuous Interstitial Monitoring | Energy Act | No |

| | | | | | | | | | | | |
|--------------------|------------------|---------------------------|------------|---------------------------------|------------|--------------------------------------|---|---------------------------------|------------------------------------|-----------------------|------------------|
| | | Overfill Test Date | 02/25/2023 | | | ATG Type | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | | | |
| Tank Code | 06 | Tank Age | 24 | Tank Installed Date | 05/23/2002 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Flexible Plastic | Overfill Types | High Level Alarm |
| Tag Number | 4666 | Spill Test Date | 04/28/2021 | Piping Installed Date | 10/30/2018 | Tank Construction | | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Diesel | PLLD Test Date | 03/05/2020 | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery | No |
| Capacity | 6000 | ATG Test Date | 02/15/2023 | Line Tightness Test Date | | Secondary Tank Leak Detection | | Secondary Pipe Detection | ELLD 0.2 | Energy Act | No |
| | | Overfill Test Date | 02/15/2023 | | | ATG Type | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | | | |
| Tank Code | 07 | Tank Age | 24 | Tank Installed Date | 05/23/2002 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Flexible Plastic | Overfill Types | High Level Alarm |
| Tag Number | 4667 | Spill Test Date | 04/28/2021 | Piping Installed Date | | Tank Construction | | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Diesel | PLLD Test Date | 03/05/2020 | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | ELLD 0.2 | Vapor Recovery | No |
| Capacity | 4000 | ATG Test Date | 02/15/2023 | Line Tightness Test Date | | Secondary Tank Leak Detection | | Secondary Pipe Detection | Continuous Interstitial Monitoring | Energy Act | No |
| | | Overfill Test Date | 02/25/2023 | | | ATG Type | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | | | |

Facility Summary in Lake County in the City of Polson

Location: POLSON COUNTRY CLUB
111 Bayview Dr
Polson, MT 59860-9609 Lake

System Facility ID:24-11824

Facility Code: 23227
Last Inspected On: 11/04/2025
Operating Permit Renewal Date: 11/04/2028

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: City of Polson (406) 883-8505

Operator Contact: Patrick Nowlen (406) 249-5121 golf@cityofpolson.com

Owner/Operator: City of Polson (406) 883-8505

Patrick Nowlen, UST Class A Operator
Patrick Nowlen, UST Class B Operator

golf@cityofpolson.com
golf@cityofpolson.com

| | | | | | | | | | | | |
|--------------------|------------------------|---------------------------|------------|---------------------------------|------------|--------------------------------------|------------------------------|---------------------------------|-------------------------------|-----------------------|---------------|
| Tank Code | 01 | Tank Age | 36 | Tank Installed Date | 08/14/1990 | Tank Material | Cathodically Protected Steel | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | Flapper Valve |
| Tag Number | 647 | Spill Test Date | 11/04/2025 | Piping Installed Date | | Tank Construction | | Piping Construction | None | AST | No |
| Tank Status | Temporarily Out of Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Not Required | Piping Type | Safe Suction | CP Met Types | Galvanic |
| Product | Gasoline | PLLD Test Date | | Tank/Piping CP Test Date | 11/04/2025 | Primary Tank Leak Detection | Manual Tank Gauging | Primary Pipe Detection | | Vapor Recovery | No |
| Capacity | 500 | ATG Test Date | | Line Tightness Test Date | | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | No |
| | | Overfill Test Date | 11/04/2025 | | | ATG Type | | | | | |

Facility Summary in Lake County in the City of Polson

Location: SAFEWAY FUEL STATION 1646
40772 MT Hwy 35
Polson, MT 59860 Lake

System Facility ID:60-15097

Facility Code: 30857
Last Inspected On: 12/27/2023
Operating Permit Renewal Date: 03/28/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Safeway Stores Inc (425) 201-6301

Operator Contact: Aaron Nelson;Cindy Standbrook;Lynn Pehrson;Martha Scott;Albertsons - Safeway;Rachel Jones (208) 395-3269;(208) 412-2233;(406) 883-2340;(425) 201-6301 cinderella@ronan.net;ltollison@yokesfoods.com;mscot17@safeway.com;page.rost@albertsons.com;rachel.jones@albertsons.com

Owner/Operator: Safeway Stores Inc (425) 201-6301

Aaron Nelson, UST Class A Operator
Cindy Standbrook, UST Class A Operator
Cindy Stankbrook, UST Class B Global Operator
Heidi Morgan, UST Class B Global Operator
Lynn Pehrson, UST Class A Operator
Martha Scott, UST Class A Operator
Martha Scott, UST Class B Operator
Rachel Jones , UST Class A Operator
Rachel Jones , UST Class B Global Operator

cinderella@ronan.net

ltollison@yokesfoods.com
page.rost@albertsons.com
page.rost@albertsons.com
rachel.jones@albertsons.com
rachel.jones@albertsons.com

| | | | | | | | | | | | |
|--------------------|------------------|---------------------------|------------|---------------------------------|------------|--------------------------------------|---|---------------------------------|------------------------------------|-----------------------|------------------|
| Tank Code | 01 | Tank Age | 18 | Tank Installed Date | 05/22/2008 | Tank Material | Steel Clad | Piping Material | Flexible Plastic | Overfill Types | High Level Alarm |
| Tag Number | 5164 | Spill Test Date | 09/28/2022 | Piping Installed Date | 04/04/2008 | Tank Construction | Double-Walled | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | |
| Product | Gasoline | PLLD Test Date | 05/31/2023 | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | ELLD 0.2 | Vapor Recovery | No |
| Capacity | 20000 | ATG Test Date | 05/31/2023 | Line Tightness Test Date | 09/28/2022 | Secondary Tank Leak Detection | Continuous Interstitial Monitoring | Secondary Pipe Detection | Continuous Interstitial Monitoring | Energy Act | Yes |
| | | Overfill Test Date | 12/27/2023 | | | ATG Type | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | | | |
| Tank Code | 02 | Tank Age | 18 | Tank Installed Date | 05/22/2008 | Tank Material | Steel Clad | Piping Material | Flexible Plastic | Overfill Types | High Level Alarm |
| Tag Number | 5165 | Spill Test Date | 09/28/2022 | Piping Installed Date | 04/04/2008 | Tank Construction | Double-Walled | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |

| | | | | | | | | | | | |
|--------------------|------------------|---------------------------|------------|---------------------------------|------------|--------------------------------------|---|---------------------------------|------------------------------------|-----------------------|------------------|
| Product | Gasoline | PLLD Test Date | 05/31/2023 | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | ELLD 0.2 | Vapor Recovery | No |
| Capacity | 10000 | ATG Test Date | 05/31/2023 | Line Tightness Test Date | 09/28/2022 | Secondary Tank Leak Detection | Continuous Interstitial Monitoring | Secondary Pipe Detection | Continuous Interstitial Monitoring | Energy Act | Yes |
| | | Overfill Test Date | 12/27/2023 | | | ATG Type | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | | | |
| Tank Code | 03 | Tank Age | 18 | Tank Installed Date | 05/22/2008 | Tank Material | Steel Clad | Piping Material | Flexible Plastic | Overfill Types | High Level Alarm |
| Tag Number | 5166 | Spill Test Date | 09/28/2022 | Piping Installed Date | 04/04/2008 | Tank Construction | Double-Walled | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Diesel | PLLD Test Date | 05/31/2023 | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | ELLD 0.2 | Vapor Recovery | No |
| Capacity | 10000 | ATG Test Date | 05/31/2023 | Line Tightness Test Date | 09/28/2022 | Secondary Tank Leak Detection | Continuous Interstitial Monitoring | Secondary Pipe Detection | Continuous Interstitial Monitoring | Energy Act | Yes |
| | | Overfill Test Date | 12/27/2023 | | | ATG Type | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | | | |

Facility Summary in Lake County in the City of Polson

Location: TOWN PUMP INC POLSON
50667 US Hwy 93
Polson, MT 59860 Lake

System Facility ID:24-08717

Facility Code: 23066
Last Inspected On: 03/29/2023
Operating Permit Renewal Date: 09/29/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Polson 1 Town Pump LLC (406) 497-6700 environmental@townpump.com

Operator Contact: Trent Biggers Trentb@townpump.com

Owner/Operator: Polson 1 Town Pump LLC (406) 497-6700 environmental@townpump.com

Trent Biggers, UST Class A Operator

Trentb@townpump.com

Trent Biggers, UST Class B Global Operator

Trentb@townpump.com

| | | | | | | | | | | | |
|--------------------|------------------|---------------------------|------------|---------------------------------|------------|--------------------------------------|--------------------------------------|---------------------------------|--------------------------------------|-----------------------|---------------|
| Tank Code | 01 | Tank Age | 44 | Tank Installed Date | 09/01/1982 | Tank Material | Cathodically Protected Steel | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | Flapper Valve |
| Tag Number | 2490 | Spill Test Date | 08/23/2022 | Piping Installed Date | | Tank Construction | | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Galvanic |
| Product | Gasoline | PLLD Test Date | | Tank/Piping CP Test Date | 08/23/2022 | Primary Tank Leak Detection | Statistical Inventory Reconciliation | Primary Pipe Detection | Statistical Inventory Reconciliation | Vapor Recovery | No |
| Capacity | 12000 | ATG Test Date | 03/29/2023 | Line Tightness Test Date | | Secondary Tank Leak Detection | | Secondary Pipe Detection | Continuous Interstitial Monitoring | Energy Act | No |
| | | Overfill Test Date | 08/23/2022 | | | ATG Type | Gilbarco-Veeder Root/TLS-450 | | | | |
| Tank Code | 02 | Tank Age | 44 | Tank Installed Date | 09/01/1982 | Tank Material | Cathodically Protected Steel | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | Flapper Valve |
| Tag Number | 2491 | Spill Test Date | 08/23/2022 | Piping Installed Date | | Tank Construction | | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Galvanic |
| Product | Gasoline | PLLD Test Date | | Tank/Piping CP Test Date | 08/23/2022 | Primary Tank Leak Detection | Statistical Inventory Reconciliation | Primary Pipe Detection | Statistical Inventory Reconciliation | Vapor Recovery | No |
| Capacity | 12000 | ATG Test Date | 03/29/2023 | Line Tightness Test Date | | Secondary Tank Leak Detection | | Secondary Pipe Detection | Continuous Interstitial Monitoring | Energy Act | No |
| | | Overfill Test Date | 08/23/2022 | | | ATG Type | Gilbarco-Veeder Root/TLS-450 | | | | |

| | | | | | | | | | | | |
|--------------------|------------------|---------------------------|------------|---------------------------------|------------|--------------------------------------|--------------------------------------|---------------------------------|--------------------------------------|-----------------------|------------------|
| Tank Code | 03 | Tank Age | 44 | Tank Installed Date | 09/01/1982 | Tank Material | Cathodically Protected Steel | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | Flapper Valve |
| Tag Number | 2492 | Spill Test Date | 08/23/2022 | Piping Installed Date | | Tank Construction | | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Galvanic |
| Product | Gasoline | PLLD Test Date | | Tank/Piping CP Test Date | 08/23/2022 | Primary Tank Leak Detection | Statistical Inventory Reconciliation | Primary Pipe Detection | Statistical Inventory Reconciliation | Vapor Recovery | No |
| Capacity | 12000 | ATG Test Date | 03/29/2023 | Line Tightness Test Date | | Secondary Tank Leak Detection | | Secondary Pipe Detection | Continuous Interstitial Monitoring | Energy Act | No |
| | | Overfill Test Date | 08/23/2022 | | | ATG Type | Gilbarco-Veeder Root/TLS-450 | | | | |
| Tank Code | 04 | Tank Age | 44 | Tank Installed Date | 09/01/1982 | Tank Material | Cathodically Protected Steel | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | Flapper Valve |
| Tag Number | 2493 | Spill Test Date | 08/23/2022 | Piping Installed Date | | Tank Construction | | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Galvanic |
| Product | Diesel | PLLD Test Date | | Tank/Piping CP Test Date | 08/23/2022 | Primary Tank Leak Detection | Statistical Inventory Reconciliation | Primary Pipe Detection | Statistical Inventory Reconciliation | Vapor Recovery | No |
| Capacity | 12000 | ATG Test Date | 03/29/2023 | Line Tightness Test Date | | Secondary Tank Leak Detection | | Secondary Pipe Detection | Continuous Interstitial Monitoring | Energy Act | No |
| | | Overfill Test Date | 08/23/2022 | | | ATG Type | Gilbarco-Veeder Root/TLS-450 | | | | |
| Tank Code | 05 | Tank Age | 44 | Tank Installed Date | 09/01/1982 | Tank Material | Cathodically Protected Steel | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | Flapper Valve |
| Tag Number | 2494 | Spill Test Date | 08/23/2022 | Piping Installed Date | | Tank Construction | | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Galvanic |
| Product | Gasoline | PLLD Test Date | | Tank/Piping CP Test Date | 08/23/2022 | Primary Tank Leak Detection | Statistical Inventory Reconciliation | Primary Pipe Detection | Statistical Inventory Reconciliation | Vapor Recovery | No |
| Capacity | 12000 | ATG Test Date | 03/29/2023 | Line Tightness Test Date | | Secondary Tank Leak Detection | | Secondary Pipe Detection | Continuous Interstitial Monitoring | Energy Act | No |
| | | Overfill Test Date | 08/23/2022 | | | ATG Type | Gilbarco-Veeder Root/TLS-450 | | | | |
| Tank Code | 11 | Tank Age | 24 | Tank Installed Date | 10/24/2002 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Flexible Plastic | Overfill Types | Ball Float Valve |
| Tag Number | 4819 | Spill Test Date | 08/23/2022 | Piping Installed Date | 10/24/2002 | Tank Construction | Double-Walled | Piping Construction | Double Walled | AST | No |

| | | | | | | | | | | | |
|--------------------|------------------|---------------------------|------------|---------------------------------|------------|--------------------------------------|--------------------------------------|---------------------------------|--------------------------------------|-----------------------|------------------|
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Diesel | PLLD Test Date | | Tank/Piping CP Test Date | 01/04/2010 | Primary Tank Leak Detection | Statistical Inventory Reconciliation | Primary Pipe Detection | Statistical Inventory Reconciliation | Vapor Recovery | No |
| Capacity | 10000 | ATG Test Date | 03/29/2023 | Line Tightness Test Date | | Secondary Tank Leak Detection | Continuous Interstitial Monitoring | Secondary Pipe Detection | Continuous Interstitial Monitoring | Energy Act | Yes |
| | | Overfill Test Date | 08/23/2022 | | | ATG Type | Gilbarco-Veeder Root/TLS-450 | | | | |
| Tank Code | 12 | Tank Age | 24 | Tank Installed Date | 10/24/2002 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Flexible Plastic | Overfill Types | Ball Float Valve |
| Tag Number | 4820 | Spill Test Date | 08/23/2022 | Piping Installed Date | 10/24/2002 | Tank Construction | Double-Walled | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Diesel | PLLD Test Date | | Tank/Piping CP Test Date | 01/04/2010 | Primary Tank Leak Detection | Statistical Inventory Reconciliation | Primary Pipe Detection | Statistical Inventory Reconciliation | Vapor Recovery | No |
| Capacity | 5000 | ATG Test Date | 08/23/2022 | Line Tightness Test Date | | Secondary Tank Leak Detection | Continuous Interstitial Monitoring | Secondary Pipe Detection | Continuous Interstitial Monitoring | Energy Act | Yes |
| | | Overfill Test Date | 08/23/2022 | | | ATG Type | Gilbarco-Veeder Root/TLS-450 | | | | |
| Tank Code | 13 | Tank Age | 9 | Tank Installed Date | 11/09/2017 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Flexible Plastic | Overfill Types | Positive Shutoff |
| Tag Number | 5782 | Spill Test Date | 08/23/2022 | Piping Installed Date | 11/09/2017 | Tank Construction | Double-Walled | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Gasoline | PLLD Test Date | | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Continuous Interstitial Monitoring | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery | Yes |
| Capacity | 4000 | ATG Test Date | 03/29/2023 | Line Tightness Test Date | | Secondary Tank Leak Detection | Statistical Inventory Reconciliation | Secondary Pipe Detection | Statistical Inventory Reconciliation | Energy Act | Yes |
| | | Overfill Test Date | 08/23/2022 | | | ATG Type | Gilbarco-Veeder Root/TLS-450 | | | | |
| Tank Code | 14 | Tank Age | 9 | Tank Installed Date | 11/09/2017 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Flexible Plastic | Overfill Types | Positive Shutoff |
| Tag Number | 5791 | Spill Test Date | | Piping Installed Date | 11/09/2017 | Tank Construction | Double-Walled | Piping Construction | Double Walled | AST | No |
| Tank Status | Other | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Continuous Interstitial Monitoring | Piping Type | Pressurized | CP Met Types | |

| | | | | | | | | | | | |
|-----------------|---------------------|---------------------------|--|---------------------------------|--|--------------------------------------|--|---------------------------------|---|-----------------------|-----|
| Product | DEF (Not Regulated) | PLLD Test Date | | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation | Primary Pipe Detection | Approved Remote Monitoring;Statistical Inventory Reconciliation | Vapor Recovery | No |
| Capacity | 2000 | ATG Test Date | | Line Tightness Test Date | | Secondary Tank Leak Detection | | Secondary Pipe Detection | Continuous Interstitial Monitoring;Not Listed | Energy Act | Yes |
| | | Overfill Test Date | | | | ATG Type | | | | | |

Facility Summary in Lake County in the City of Rollins

Location: POINTS NORTH TRADING CO
87867 US Hwy 93
Rollins, MT 59931 Lake

System Facility ID:24-12730

Facility Code: 23274
Last Inspected On: 05/01/2025
Operating Permit Renewal Date: 07/22/2028

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Points North of Rollins LLC (406) 250-7058 pointsnorth01@yahoo.com

Operator Contact: Michael Serra;Thomas Gay (406) 250-7058;(406) 844-3942 mikeserra20@gmail.com;tomnjule@aboutmontana.net

Owner/Operator: Points North of Rollins LLC (406) 250-7058 pointsnorth01@yahoo.com

Michael Serra, UST Class A Operator mikeserra20@gmail.com
 Michael Serra, UST Class B Global Operator mikeserra20@gmail.com
 Thomas A Gay, UST Class A Operator tomnjule@aboutmontana.net
 Thomas A Gay, UST Class B Operator tomnjule@aboutmontana.net

| | | | | | | | | | | | |
|--------------------|------------------|---------------------------|------------|---------------------------------|------------|--------------------------------------|-------------------------------|---------------------------------|-------------------------------|-----------------------|---------------|
| Tank Code | 03 | Tank Age | 31 | Tank Installed Date | 06/01/1995 | Tank Material | Cathodically Protected Steel | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | Flapper Valve |
| Tag Number | 3095 | Spill Test Date | 05/31/2024 | Piping Installed Date | | Tank Construction | | Piping Construction | None | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | 05/01/2025 | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Mechanical Line Leak Detector | Piping Type | Pressurized | CP Met Types | Galvanic |
| Product | Gasoline | PLLD Test Date | | Tank/Piping CP Test Date | 05/28/2024 | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | MLLD Line Tightness Testing | Vapor Recovery | No |
| Capacity | 8000 | ATG Test Date | 05/01/2025 | Line Tightness Test Date | 05/01/2025 | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | No |
| | | Overfill Test Date | 05/01/2025 | | | ATG Type | EMCO Electronics/EECO 1500 | | | | |
| Tank Code | 04 | Tank Age | 31 | Tank Installed Date | 06/01/1995 | Tank Material | Cathodically Protected Steel | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | Flapper Valve |
| Tag Number | 3096 | Spill Test Date | 05/31/2024 | Piping Installed Date | | Tank Construction | | Piping Construction | None | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | 05/01/2025 | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Mechanical Line Leak Detector | Piping Type | Pressurized | CP Met Types | Galvanic |
| Product | Gasoline | PLLD Test Date | | Tank/Piping CP Test Date | 05/28/2024 | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | MLLD Line Tightness Testing | Vapor Recovery | No |
| Capacity | 8000 | ATG Test Date | 05/01/2025 | Line Tightness Test Date | 05/01/2025 | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | No |
| | | Overfill Test Date | 05/01/2025 | | | ATG Type | EMCO Electronics/EECO 1500 | | | | |

| | | | | | | | | | | | |
|--------------------|------------------|---------------------------|------------|---------------------------------|------------|--------------------------------------|-------------------------------|---------------------------------|-------------------------------|-----------------------|---------------|
| Tank Code | 05 | Tank Age | 31 | Tank Installed Date | 06/01/1995 | Tank Material | Cathodically Protected Steel | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | Flapper Valve |
| Tag Number | 3097 | Spill Test Date | 05/31/2024 | Piping Installed Date | | Tank Construction | | Piping Construction | None | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | 05/01/2025 | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Mechanical Line Leak Detector | Piping Type | Pressurized | CP Met Types | Galvanic |
| Product | Diesel | PLLD Test Date | | Tank/Piping CP Test Date | 05/28/2024 | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | MLLD Line Tightness Testing | Vapor Recovery | No |
| Capacity | 4000 | ATG Test Date | 05/01/2025 | Line Tightness Test Date | 05/01/2025 | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | No |
| | | Overfill Test Date | 05/01/2025 | | | ATG Type | EMCO Electronics/EECO 1500 | | | | |

Facility Summary in Lake County in the City of Ronan

Location: ARNIES GAS AND TIRE CENTER INC
63145 US Hwy 93
Ronan, MT 59864-2808 Lake

System Facility ID:24-05517

Facility Code: 22970
Last Inspected On: 05/02/2023
Operating Permit Renewal Date: 08/15/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Arnies Gas and Tire Center Inc (406) 675-0400 arniesgt@gmail.com

Operator Contact: Amanda Hackman;Denise Aipperspach (406) 676-0400

Owner/Operator: Arnies Gas and Tire Center Inc (406) 675-0400 arniesgt@gmail.com

- Amanda Hackman, UST Class A Operator
- Amanda Hackman, UST Class B Global Operator
- Denise Aipperspach, UST Class A Operator
- Denise Aipperspach, UST Class B Global Operator
- Denise Aipperspach, UST Class B Operator

| | | | | | | | | | | | |
|--------------------|------------------|---------------------------|------------|---------------------------------|------------|--------------------------------------|---|---------------------------------|-------------------------------|-----------------------|-------------------|
| Tank Code | 04 | Tank Age | 48 | Tank Installed Date | 05/07/1978 | Tank Material | Cathodically Protected Steel | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | Flapper Valve |
| Tag Number | 3888 | Spill Test Date | 05/02/2023 | Piping Installed Date | | Tank Construction | Lined Interior/Impressed Current | Piping Construction | None | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | 05/02/2023 | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Mechanical Line Leak Detector | Piping Type | Pressurized | CP Met Types | Impressed Current |
| Product | Diesel | PLLD Test Date | | Tank/Piping CP Test Date | 05/02/2023 | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | MLLD Line Tightness Testing | Vapor Recovery | No |
| Capacity | 12000 | ATG Test Date | 05/02/2023 | Line Tightness Test Date | 05/02/2023 | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | No |
| | | Overfill Test Date | 05/02/2023 | | | ATG Type | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | | | |
| Tank Code | 03 | Tank Age | 55 | Tank Installed Date | 05/08/1971 | Tank Material | Cathodically Protected Steel | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | Flapper Valve |
| Tag Number | 3889 | Spill Test Date | 05/02/2023 | Piping Installed Date | | Tank Construction | Lined Interior/Impressed Current | Piping Construction | None | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | 05/02/2023 | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Mechanical Line Leak Detector | Piping Type | Pressurized | CP Met Types | Impressed Current |
| Product | Diesel, Dyed | PLLD Test Date | | Tank/Piping CP Test Date | 05/02/2023 | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | MLLD Line Tightness Testing | Vapor Recovery | No |
| Capacity | 4000 | ATG Test Date | 05/02/2023 | Line Tightness Test Date | 05/02/2023 | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | No |

| | | | | | | | | | | | |
|--------------------|------------------|---------------------------|------------|---------------------------------|------------|--------------------------------------|---|---------------------------------|-------------------------------|-----------------------|-------------------|
| | | Overfill Test Date | 05/02/2023 | | | ATG Type | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | | | |
| Tank Code | 02 | Tank Age | 55 | Tank Installed Date | 05/08/1971 | Tank Material | Cathodically Protected Steel | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | Flapper Valve |
| Tag Number | 3890 | Spill Test Date | 05/02/2023 | Piping Installed Date | | Tank Construction | Lined Interior/Impressed Current | Piping Construction | None | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | 05/02/2023 | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Mechanical Line Leak Detector | Piping Type | Pressurized | CP Met Types | Impressed Current |
| Product | Gasoline | PLLD Test Date | | Tank/Piping CP Test Date | 05/02/2023 | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | MLLD Line Tightness Testing | Vapor Recovery | No |
| Capacity | 6000 | ATG Test Date | 05/02/2023 | Line Tightness Test Date | 05/02/2023 | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | No |
| | | Overfill Test Date | 05/02/2023 | | | ATG Type | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | | | |
| Tank Code | 01 | Tank Age | 55 | Tank Installed Date | 05/08/1971 | Tank Material | Cathodically Protected Steel | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | Flapper Valve |
| Tag Number | 3891 | Spill Test Date | 05/02/2023 | Piping Installed Date | | Tank Construction | Lined Interior/Impressed Current | Piping Construction | None | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | 05/02/2023 | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Mechanical Line Leak Detector | Piping Type | Pressurized | CP Met Types | Impressed Current |
| Product | Gasoline | PLLD Test Date | | Tank/Piping CP Test Date | 05/02/2023 | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | MLLD Line Tightness Testing | Vapor Recovery | No |
| Capacity | 10000 | ATG Test Date | 05/02/2023 | Line Tightness Test Date | 05/02/2023 | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | No |
| | | Overfill Test Date | 05/02/2023 | | | ATG Type | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | | | |

Facility Summary in Lake County in the City of Ronan

Location: DYNO MART
62945 Hwy 93 N
Ronan, MT 59864 Lake

System Facility ID:24-05768

Facility Code: 22981
Last Inspected On: 04/24/2023
Operating Permit Renewal Date: 09/08/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: One Stop 3 Inc Loc 2 (406) 676-3570 onestop3gm@yahoo.com

Operator Contact: Maureen McCrea;Tom Hoyt (406) 274-5536 dynamart1@yahoo.com

Owner/Operator: One Stop 3 Inc Loc 2 (406) 676-3570 onestop3gm@yahoo.com

| | |
|--|---------------------|
| Gail Matt, UST Class B Global Operator | dynamart1@yahoo.com |
| Gail Matt, UST Class B Operator | dynamart1@yahoo.com |
| Maureen McCrea, UST Class A Operator | dynamart1@yahoo.com |
| Tom Hoyt, UST Class A Operator | dynamart1@yahoo.com |
| Tom Hoyt, UST Class B Operator | dynamart1@yahoo.com |

| | | | | | | | | | | | |
|--------------------|------------------|---------------------------|------------|---------------------------------|------------|--------------------------------------|---|---------------------------------|-------------------------------|-----------------------|-------------------|
| Tank Code | 01 | Tank Age | 42 | Tank Installed Date | 11/13/1984 | Tank Material | Bare Steel | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | Flapper Valve |
| Tag Number | 1315 | Spill Test Date | 08/05/2020 | Piping Installed Date | | Tank Construction | | Piping Construction | None | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | 07/30/2019 | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Mechanical Line Leak Detector | Piping Type | Pressurized | CP Met Types | Impressed Current |
| Product | Gasoline | PLLD Test Date | | Tank/Piping CP Test Date | 03/27/2019 | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | MLLD Line Tightness Testing | Vapor Recovery | No |
| Capacity | 10000 | ATG Test Date | | Line Tightness Test Date | 07/30/2019 | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | No |
| | | Overfill Test Date | | | | ATG Type | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | | | |
| Tank Code | 02 | Tank Age | 42 | Tank Installed Date | 11/13/1984 | Tank Material | Bare Steel | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | Flapper Valve |
| Tag Number | 1316 | Spill Test Date | 03/27/2019 | Piping Installed Date | | Tank Construction | | Piping Construction | None | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | 07/30/2019 | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Mechanical Line Leak Detector | Piping Type | Pressurized | CP Met Types | Impressed Current |
| Product | Gasoline | PLLD Test Date | | Tank/Piping CP Test Date | 03/27/2019 | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | MLLD Line Tightness Testing | Vapor Recovery | No |
| Capacity | 8000 | ATG Test Date | | Line Tightness Test Date | 07/30/2019 | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | No |

| | | | | | | | | | | | |
|--------------------|------------------|---------------------------|------------|---------------------------------|------------|--------------------------------------|---|---------------------------------|-------------------------------|-----------------------|-------------------|
| | | Overfill Test Date | 03/27/2019 | | | ATG Type | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | | | |
| Tank Code | 03 | Tank Age | 34 | Tank Installed Date | 04/01/1992 | Tank Material | Cathodically Protected Steel | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | Flapper Valve |
| Tag Number | 1317 | Spill Test Date | 03/27/2019 | Piping Installed Date | | Tank Construction | | Piping Construction | None | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | 07/30/2019 | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Mechanical Line Leak Detector | Piping Type | Pressurized | CP Met Types | Impressed Current |
| Product | Diesel | PLLD Test Date | | Tank/Piping CP Test Date | 03/27/2019 | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | MLLD Line Tightness Testing | Vapor Recovery | No |
| Capacity | 10000 | ATG Test Date | | Line Tightness Test Date | 07/30/2019 | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | No |
| | | Overfill Test Date | 03/27/2019 | | | ATG Type | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | | | |

Facility Summary in Lake County in the City of Ronan

Location: EAST OF RONAN MIDDLE SCHOOL
 200 Round Butte Rd W
 Ronan, MT 59864 Lake

System Facility ID:24-04824

Facility Code: 22953
Last Inspected On: 03/04/2026
Operating Permit Renewal Date: 09/13/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: School Dist 30 Ronan (406) 644-2448

Operator Contact: Brad Benson;Lawrence Cordis;Rob Tougas (406) 250-8008 larry.cordis@ronank12.edu;rob.tougas@ronank12.edu

Owner/Operator: School Dist 30 Ronan (406) 644-2448

Brad Benson, UST Class A Operator
 Brad Benson, UST Class B Global Operator
 Lawrence Cordis, UST Class A Operator
 Lawrence Cordis, UST Class B Global Operator
 Matt Gaut, UST Class B Operator
 Rob Tougas, UST Class A Operator
 Rob Tougas, UST Class B Global Operator

larry.cordis@ronank12.edu
 larry.cordis@ronank12.edu
 matt.gaut@ronank12.edu
 rob.tougas@ronank12.edu
 rob.tougas@ronank12.edu

| | | | | | | | | | | | |
|--------------------|------------------|---------------------------|------------|---------------------------------|------------|--------------------------------------|-------------------------------|---------------------------------|------------------------------------|-----------------------|----------------|
| Tank Code | S5 | Tank Age | 30 | Tank Installed Date | 08/01/1996 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Copper | Overfill Types | Flapper Valve |
| Tag Number | 1904 | Spill Test Date | 05/25/2023 | Piping Installed Date | | Tank Construction | | Piping Construction | Secondary Containment Chase | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Auto Dialer | Piping Type | U.S. Suction | CP Met Types | Non-corrodible |
| Product | Heating Oil | PLLD Test Date | | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery | No |
| Capacity | 10000 | ATG Test Date | 05/25/2023 | Line Tightness Test Date | | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | No |
| | | Overfill Test Date | 05/25/2023 | | | ATG Type | Gilbarco-Veeder Root/Other | | | | |

Facility Summary in Lake County in the City of Ronan

Location: JOHNS FUEL FARM AND ENERGY
 14 Cleveland St SE
 Ronan, MT 59864-3027 Lake

System Facility ID:24-07437

Facility Code: 23032
Last Inspected On: 11/20/2024
Operating Permit Renewal Date: 04/26/2028

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Johns Fuel Farm and Energy (406) 676-3461 hans.lund@tradh.com

Operator Contact: Hans Lund;John Noel;Leevi Wadsworth (406) 261-7956;(406) 676-3461 fuelfarm@ronan.net;hans.lund@johnsfuelfarm.com;leevij@hotmail.com

Owner/Operator: Johns Fuel Farm and Energy (406) 676-3461 hans.lund@tradh.com

Hans Lund, UST Class A Operator
 Hans Lund, UST Class B Operator
 John Noel, UST Class A Operator
 John Noel, UST Class B Global Operator
 Leevi Wadsworth, UST Class A Operator
 Leevi Wadsworth, UST Class B Operator

hans.lund@johnsfuelfarm.com
 hans.lund@johnsfuelfarm.com
 fuelfarm@ronan.net
 fuelfarm@ronan.net
 leevij@hotmail.com
 leevij@hotmail.com

| | | | | | | | | | | | |
|--------------------|------------------|---------------------------|------------|---------------------------------|------------|--------------------------------------|----------------------------------|---------------------------------|------------------------------------|-----------------------|-------------------|
| Tank Code | 01 | Tank Age | 65 | Tank Installed Date | 04/23/1961 | Tank Material | Cathodically Protected Steel | Piping Material | Steel | Overfill Types | High Level Alarm |
| Tag Number | 3394 | Spill Test Date | 08/21/2024 | Piping Installed Date | 08/10/2009 | Tank Construction | Lined Interior/Impressed Current | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | 08/21/2024 | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Impressed Current |
| Product | Gasoline | PLLD Test Date | 08/21/2024 | Tank/Piping CP Test Date | 11/20/2024 | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | ELLD 0.2 | Vapor Recovery | No |
| Capacity | 10000 | ATG Test Date | 08/21/2024 | Line Tightness Test Date | 08/30/2022 | Secondary Tank Leak Detection | | Secondary Pipe Detection | Continuous Interstitial Monitoring | Energy Act | No |
| | | Overfill Test Date | 08/21/2024 | | | ATG Type | Gilbarco-Veeder Root/TLS-350 | | | | |
| Tank Code | 02 | Tank Age | 0 | Tank Installed Date | | Tank Material | Cathodically Protected Steel | Piping Material | Steel | Overfill Types | High Level Alarm |
| Tag Number | 3395 | Spill Test Date | 08/21/2024 | Piping Installed Date | 08/10/2009 | Tank Construction | Lined Interior/Impressed Current | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | 08/21/2024 | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Impressed Current |
| Product | Diesel | PLLD Test Date | 08/21/2024 | Tank/Piping CP Test Date | 11/20/2024 | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | ELLD 0.2 | Vapor Recovery | No |

| | | | | | | | | | | | |
|--------------------|------------------|---------------------------|------------|---------------------------------|------------|--------------------------------------|-------------------------------|---------------------------------|------------------------------------|-----------------------|------------------|
| Capacity | 10000 | ATG Test Date | 08/21/2024 | Line Tightness Test Date | 08/30/2022 | Secondary Tank Leak Detection | | Secondary Pipe Detection | Continuous Interstitial Monitoring | Energy Act | No |
| | | Overfill Test Date | 08/21/2024 | | | ATG Type | Gilbarco-Veeder Root/TLS-350 | | | | |
| Tank Code | 03 | Tank Age | 55 | Tank Installed Date | 04/24/1971 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Steel | Overfill Types | High Level Alarm |
| Tag Number | 3396 | Spill Test Date | 10/04/2021 | Piping Installed Date | 08/10/2009 | Tank Construction | | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | 10/26/2021 | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Diesel | PLLD Test Date | 08/30/2022 | Tank/Piping CP Test Date | 10/26/2021 | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | ELLD 0.2 | Vapor Recovery | No |
| Capacity | 8000 | ATG Test Date | 08/30/2022 | Line Tightness Test Date | 08/30/2022 | Secondary Tank Leak Detection | | Secondary Pipe Detection | Continuous Interstitial Monitoring | Energy Act | No |
| | | Overfill Test Date | 08/30/2022 | | | ATG Type | Gilbarco-Veeder Root/TLS-350 | | | | |
| Tank Code | 04 | Tank Age | 55 | Tank Installed Date | 04/24/1971 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | High Level Alarm |
| Tag Number | 3397 | Spill Test Date | 10/04/2021 | Piping Installed Date | 08/10/2009 | Tank Construction | | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | 10/26/2021 | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Diesel | PLLD Test Date | 08/30/2022 | Tank/Piping CP Test Date | 10/26/2021 | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | ELLD 0.2 | Vapor Recovery | No |
| Capacity | 8000 | ATG Test Date | 08/30/2022 | Line Tightness Test Date | 08/30/2022 | Secondary Tank Leak Detection | | Secondary Pipe Detection | Continuous Interstitial Monitoring | Energy Act | No |
| | | Overfill Test Date | 08/30/2022 | | | ATG Type | Gilbarco-Veeder Root/TLS-350 | | | | |
| Tank Code | 05 | Tank Age | 55 | Tank Installed Date | 04/24/1971 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Steel | Overfill Types | High Level Alarm |
| Tag Number | 3398 | Spill Test Date | 10/04/2021 | Piping Installed Date | 08/10/2009 | Tank Construction | | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | 10/26/2021 | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Gasoline | PLLD Test Date | 08/30/2022 | Tank/Piping CP Test Date | 10/26/2021 | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | ELLD 0.2 | Vapor Recovery | No |
| Capacity | 6000 | ATG Test Date | 08/30/2022 | Line Tightness Test Date | 08/30/2022 | Secondary Tank Leak Detection | | Secondary Pipe Detection | Continuous Interstitial Monitoring | Energy Act | No |
| | | Overfill Test Date | 08/30/2022 | | | ATG Type | Gilbarco-Veeder Root/TLS-350 | | | | |
| Tank Code | 06 | Tank Age | 65 | Tank Installed Date | 04/23/1961 | Tank Material | Cathodically Protected Steel | Piping Material | Steel | Overfill Types | High Level Alarm |

| | | | | | | | | | | | |
|--------------------|-------------------|---------------------------|------------|---------------------------------|------------|--------------------------------------|----------------------------------|---------------------------------|------------------------------------|-----------------------|-------------------|
| Tag Number | 3399 | Spill Test Date | 10/04/2021 | Piping Installed Date | 08/10/2009 | Tank Construction | Lined Interior/Impressed Current | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | 10/26/2021 | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Impressed Current |
| Product | Solvent, Stoddard | PLLD Test Date | 08/30/2022 | Tank/Piping CP Test Date | 10/26/2021 | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | ELLD 0.2 | Vapor Recovery | No |
| Capacity | 6000 | ATG Test Date | 08/30/2022 | Line Tightness Test Date | 08/30/2022 | Secondary Tank Leak Detection | | Secondary Pipe Detection | Continuous Interstitial Monitoring | Energy Act | No |
| | | Overfill Test Date | 08/30/2022 | | | ATG Type | Gilbarco-Veeder Root/TLS-350 | | | | |

Facility Summary in Lake County in the City of Ronan

Location: MOUNTAIN WEST CENEX
63980 Us Hwy 93
Ronan, MT 59864 Lake

System Facility ID:00-32579

Facility Code: 32579
Last Inspected On: 10/03/2025
Operating Permit Renewal Date: 10/03/2028

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: CHS Mountain West

Operator Contact: Joseph Allard;CHS Mountain West Coop

(406) 676-2201

Joseph.Allard@chsinc.com

Owner/Operator: CHS Mountain West

Joseph Allard, UST Class A Operator
Joseph Allard, UST Class B Operator

Joseph.Allard@chsinc.com
Joseph.Allard@chsinc.com

| | | | | | | | | | | | |
|--------------------|------------------|---------------------------|------------|---------------------------------|------------|--------------------------------------|------------------------------------|---------------------------------|------------------------------------|-----------------------|--------------------------------|
| Tank Code | 01 | Tank Age | 2 | Tank Installed Date | 10/10/2024 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Flexible Plastic | Overfill Types | Flapper Valve;High Level Alarm |
| Tag Number | 6260 | Spill Test Date | 12/10/2024 | Piping Installed Date | 04/10/2025 | Tank Construction | Double-Walled | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Gasoline | PLLD Test Date | 04/14/2025 | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Continuous Interstitial Monitoring | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery | Yes |
| Capacity | 20000 | ATG Test Date | 04/01/2025 | Line Tightness Test Date | 04/09/2025 | Secondary Tank Leak Detection | Automatic Tank Gauging 0.2 | Secondary Pipe Detection | ELLD 0.2 | Energy Act | Yes |
| | | Overfill Test Date | 04/01/2025 | | | ATG Type | | | | | |
| Tank Code | 02 | Tank Age | 2 | Tank Installed Date | 10/10/2024 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Flexible Plastic | Overfill Types | Flapper Valve |
| Tag Number | 6261 | Spill Test Date | 12/10/2024 | Piping Installed Date | 04/10/2025 | Tank Construction | Double-Walled | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | |
| Product | Gasoline | PLLD Test Date | 04/14/2025 | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Continuous Interstitial Monitoring | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery | Yes |
| Capacity | 12000 | ATG Test Date | 04/01/2025 | Line Tightness Test Date | | Secondary Tank Leak Detection | Automatic Tank Gauging 0.2 | Secondary Pipe Detection | ELLD 0.2 | Energy Act | Yes |
| | | Overfill Test Date | 04/01/2025 | | | ATG Type | | | | | |
| Tank Code | 03 | Tank Age | 2 | Tank Installed Date | 10/10/2024 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Flexible Plastic | Overfill Types | Flapper Valve |

| | | | | | | | | | | | |
|--------------------|------------------|---------------------------|------------|---------------------------------|------------|--------------------------------------|------------------------------------|---------------------------------|------------------------------------|-----------------------|---------------|
| Tag Number | 6262 | Spill Test Date | 12/10/2024 | Piping Installed Date | 04/10/2025 | Tank Construction | Double-Walled | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | |
| Product | Diesel, Dyed | PLLD Test Date | 04/14/2025 | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Continuous Interstitial Monitoring | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery | No |
| Capacity | 8000 | ATG Test Date | 04/01/2025 | Line Tightness Test Date | | Secondary Tank Leak Detection | Automatic Tank Gauging 0.2 | Secondary Pipe Detection | ELLD 0.2 | Energy Act | Yes |
| | | Overfill Test Date | 04/01/2025 | | | ATG Type | | | | | |
| Tank Code | 04 | Tank Age | 2 | Tank Installed Date | 10/10/2024 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Flexible Plastic | Overfill Types | Flapper Valve |
| Tag Number | 6263 | Spill Test Date | 12/10/2024 | Piping Installed Date | 04/10/2025 | Tank Construction | Double-Walled | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | |
| Product | Diesel | PLLD Test Date | 04/14/2025 | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Continuous Interstitial Monitoring | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery | No |
| Capacity | 20000 | ATG Test Date | 04/01/2025 | Line Tightness Test Date | | Secondary Tank Leak Detection | Automatic Tank Gauging 0.2 | Secondary Pipe Detection | ELLD 0.2 | Energy Act | Yes |
| | | Overfill Test Date | 04/01/2025 | | | ATG Type | | | | | |
| Tank Code | 05 | Tank Age | 2 | Tank Installed Date | 10/10/2024 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Flexible Plastic | Overfill Types | Flapper Valve |
| Tag Number | 6264 | Spill Test Date | 12/10/2024 | Piping Installed Date | 04/10/2025 | Tank Construction | Double-Walled | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | |
| Product | Diesel, Dyed | PLLD Test Date | 04/14/2025 | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Continuous Interstitial Monitoring | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery | No |
| Capacity | 20000 | ATG Test Date | 04/01/2025 | Line Tightness Test Date | | Secondary Tank Leak Detection | Automatic Tank Gauging 0.2 | Secondary Pipe Detection | ELLD 0.2 | Energy Act | Yes |
| | | Overfill Test Date | 04/01/2025 | | | ATG Type | | | | | |
| Tank Code | 06 | Tank Age | 2 | Tank Installed Date | 10/10/2024 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Flexible Plastic | Overfill Types | Flapper Valve |
| Tag Number | 6265 | Spill Test Date | 12/10/2024 | Piping Installed Date | 04/10/2025 | Tank Construction | Double-Walled | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | |
| Product | Diesel | PLLD Test Date | 04/14/2025 | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Continuous Interstitial Monitoring | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery | No |
| Capacity | 20000 | ATG Test Date | 04/01/2025 | Line Tightness Test Date | | Secondary Tank Leak Detection | Automatic Tank Gauging 0.2 | Secondary Pipe Detection | ELLD 0.2 | Energy Act | Yes |
| | | Overfill Test Date | 04/01/2025 | | | ATG Type | | | | | |

| | | | | | | | | | | | |
|--------------------|------------------|---------------------------|------------|---------------------------------|------------|--------------------------------------|------------------------------------|---------------------------------|------------------------------------|-----------------------|---------------|
| Tank Code | 07 | Tank Age | 2 | Tank Installed Date | 10/10/2024 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Flexible Plastic | Overfill Types | Flapper Valve |
| Tag Number | 6266 | Spill Test Date | 12/10/2024 | Piping Installed Date | 04/10/2025 | Tank Construction | Double-Walled | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | |
| Product | Diesel | PLLD Test Date | 04/14/2025 | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Continuous Interstitial Monitoring | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery | No |
| Capacity | 20000 | ATG Test Date | 04/01/2025 | Line Tightness Test Date | | Secondary Tank Leak Detection | Automatic Tank Gauging 0.2 | Secondary Pipe Detection | ELLD 0.2 | Energy Act | Yes |
| | | Overfill Test Date | 04/01/2025 | | | ATG Type | | | | | |

Facility Summary in Lake County in the City of Ronan

Location: MOUNTAIN WEST CO OP RONAN
63932 US Hwy 93
Ronan, MT 59864 Lake

System Facility ID:24-04530

Facility Code: 22944
Last Inspected On: 10/03/2025
Operating Permit Renewal Date: 12/19/2028

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: CHS Mountain West Coop (406) 676-2201

Operator Contact: Bob Westin;Dusty Smith;John Thompson;Joseph Allard;CHS Mountain West Coop;Will Dukart (406) 541-6800;(406) 543-8383;(406) 676-2201 chuck.thompson@chsinc.com;dusty.smith@chsinc.com;Joseph.Allard@chsinc.com;will.dukart@chsinc.com

Owner/Operator: CHS Mountain West Coop (406) 676-2201

- Bob Westin, UST Class A Operator
- Bob Westin, UST Class B Global Operator
- Carrie Clairmont, UST Class B Operator carrie.clairmont@chsinc.com
- Dusty Smith, UST Class A Operator dusty.smith@chsinc.com
- Dusty Smith, UST Class B Global Operator dusty.smith@chsinc.com
- John Thompson, UST Class A Operator chuck.thompson@chsinc.com
- John Thompson, UST Class B Global Operator chuck.thompson@chsinc.com
- John Thompson, UST Class B Operator chuck.thompson@chsinc.com
- Joseph Allard, UST Class A Operator Joseph.Allard@chsinc.com
- Joseph Allard, UST Class B Operator Joseph.Allard@chsinc.com
- Will Dukart, UST Class A Operator will.dukart@chsinc.com
- Will Dukart, UST Class B Global Operator will.dukart@chsinc.com

| | | | | | | | | | | | |
|--------------------|------------------|---------------------------|------------|---------------------------------|------------|--------------------------------------|-------------------------------|---------------------------------|-------------------------------|-----------------------|----------------|
| Tank Code | 09 | Tank Age | 29 | Tank Installed Date | 05/01/1997 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | Flapper Valve |
| Tag Number | 2829 | Spill Test Date | 09/23/2025 | Piping Installed Date | | Tank Construction | | Piping Construction | None | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | 05/21/2019 | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Gasoline | PLLD Test Date | 09/23/2025 | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | ELLD 0.2 | Vapor Recovery | Yes |
| Capacity | 10000 | ATG Test Date | 09/23/2025 | Line Tightness Test Date | 09/13/2022 | Secondary Tank Leak Detection | | Secondary Pipe Detection | ELLD 0.1 | Energy Act | No |
| | | Overfill Test Date | 09/23/2025 | | | ATG Type | Gilbarco-Veeder Root/TLS-350 | | | | |
| Tank Code | 10 | Tank Age | 29 | Tank Installed Date | 05/01/1997 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | Flapper Valve |
| Tag Number | 2830 | Spill Test Date | 09/23/2025 | Piping Installed Date | | Tank Construction | | Piping Construction | None | AST | No |

| | | | | | | | | | | | |
|--------------------|------------------|---------------------------|------------|---------------------------------|------------|--------------------------------------|-------------------------------|---------------------------------|-------------------------------|-----------------------|----------------|
| Tank Status | Currently in Use | MLLD Test Date | 05/21/2019 | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Gasoline | PLLD Test Date | 09/23/2025 | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | ELLD 0.2 | Vapor Recovery | Yes |
| Capacity | 4000 | ATG Test Date | 09/23/2025 | Line Tightness Test Date | 09/13/2022 | Secondary Tank Leak Detection | | Secondary Pipe Detection | ELLD 0.1 | Energy Act | No |
| | | Overfill Test Date | 09/23/2025 | | | ATG Type | Gilbarco-Veeder Root/TLS-350 | | | | |
| Tank Code | 11 | Tank Age | 29 | Tank Installed Date | 05/01/1997 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | Flapper Valve |
| Tag Number | 2831 | Spill Test Date | 09/23/2025 | Piping Installed Date | | Tank Construction | | Piping Construction | None | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | 05/21/2019 | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Diesel | PLLD Test Date | 09/23/2025 | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | ELLD 0.2 | Vapor Recovery | No |
| Capacity | 4000 | ATG Test Date | 09/23/2025 | Line Tightness Test Date | 09/13/2022 | Secondary Tank Leak Detection | | Secondary Pipe Detection | ELLD 0.1 | Energy Act | No |
| | | Overfill Test Date | 09/23/2025 | | | ATG Type | Gilbarco-Veeder Root/TLS-350 | | | | |
| Tank Code | 12 | Tank Age | 29 | Tank Installed Date | 05/01/1997 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | Flapper Valve |
| Tag Number | 2832 | Spill Test Date | 09/23/2025 | Piping Installed Date | | Tank Construction | | Piping Construction | None | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | 05/21/2019 | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Diesel, Dyed | PLLD Test Date | 09/23/2025 | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | ELLD 0.2 | Vapor Recovery | No |
| Capacity | 6000 | ATG Test Date | 09/23/2025 | Line Tightness Test Date | 09/13/2022 | Secondary Tank Leak Detection | | Secondary Pipe Detection | ELLD 0.1 | Energy Act | No |
| | | Overfill Test Date | 09/23/2025 | | | ATG Type | Gilbarco-Veeder Root/TLS-350 | | | | |
| Tank Code | 13 | Tank Age | 29 | Tank Installed Date | 05/01/1997 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | Flapper Valve |
| Tag Number | 2833 | Spill Test Date | 09/23/2025 | Piping Installed Date | | Tank Construction | | Piping Construction | None | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | 05/21/2019 | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Diesel | PLLD Test Date | 09/23/2025 | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | ELLD 0.2 | Vapor Recovery | No |
| Capacity | 5000 | ATG Test Date | 09/23/2025 | Line Tightness Test Date | 09/13/2022 | Secondary Tank Leak Detection | | Secondary Pipe Detection | ELLD 0.1 | Energy Act | No |
| | | Overfill Test Date | 09/23/2025 | | | ATG Type | Gilbarco-Veeder Root/TLS-350 | | | | |

Facility Summary in Lake County in the City of Ronan

Location: RONAN AIRPORT
 35564 Ronan Airport Rd
 Ronan, MT 59864-9267 Lake

System Facility ID:24-04649

Facility Code: 22948
Last Inspected On: 05/01/2024
Operating Permit Renewal Date: 10/22/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Lake County Joint Airport Board (406) 883-7214

Operator Contact: Vinson Jennison vinsu@centurytel.net

Owner/Operator: Lake County Joint Airport Board (406) 883-7214

Vinson Jennison, UST Class A Operator vinsu@centurytel.net
 Vinson Jennison, UST Class B Global Operator vinsu@centurytel.net

| | | | | | | | | | | | |
|--------------------|-------------------------------|---------------------------|------------|---------------------------------|------------|--------------------------------------|----------------------------------|---------------------------------|------------------------------------|-----------------------|-----------------------------------|
| Tank Code | 02 | Tank Age | 27 | Tank Installed Date | 04/01/1999 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Flexible Plastic | Overfill Types | Ball Float Valve;High Level Alarm |
| Tag Number | 3984 | Spill Test Date | 05/31/2022 | Piping Installed Date | | Tank Construction | | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Jet Fuel (Jet-A, Jet-A1, JP5) | PLLD Test Date | 03/20/2024 | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | ELLD 0.2 | Vapor Recovery | No |
| Capacity | 12000 | ATG Test Date | 03/20/2024 | Line Tightness Test Date | 03/03/2023 | Secondary Tank Leak Detection | | Secondary Pipe Detection | Continuous Interstitial Monitoring | Energy Act | No |
| | | Overfill Test Date | 05/31/2022 | | | ATG Type | Gilbarco-Veeder Root/TLS-450PLUS | | | | |
| Tank Code | 03 | Tank Age | 27 | Tank Installed Date | 04/01/1999 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Flexible Plastic | Overfill Types | Ball Float Valve;High Level Alarm |
| Tag Number | 3985 | Spill Test Date | 05/31/2022 | Piping Installed Date | | Tank Construction | | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Aviation Gas | PLLD Test Date | 03/20/2024 | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | ELLD 0.2 | Vapor Recovery | No |
| Capacity | 12000 | ATG Test Date | 03/20/2024 | Line Tightness Test Date | 03/03/2023 | Secondary Tank Leak Detection | | Secondary Pipe Detection | Continuous Interstitial Monitoring | Energy Act | No |

| | | | | | | | | | | | |
|--|--|---------------------------|------------|--|--|-----------------|---|--|--|--|--|
| | | Overfill Test Date | 05/31/2022 | | | ATG Type | Gilbarco-Veeder Root/TLS- 450PLUS | | | | |
|--|--|---------------------------|------------|--|--|-----------------|---|--|--|--|--|

Facility Summary in Lake County in the City of Ronan

Location: ST LUKE COMMUNITY CLINIC- RONAN
107 6th Ave SW
Ronan, MT 59864 Lake

System Facility ID:24-03736

Facility Code: 22926
Last Inspected On: 06/20/2023
Operating Permit Renewal Date: 10/16/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Saint Luke Hospital (406) 676-4441 gburdett@stlukehealthnet.org

Operator Contact: Gary Burdett;Nicholas Emerson;Steven DeLay (406) 240-5240;(406) 676-4441 gburdett@stlukehealthnet.org;nemerson@stlukehealthcare.org;sdelay57@gmail.com

Owner/Operator: Saint Luke Hospital (406) 676-4441 gburdett@stlukehealthnet.org

Gary Burdett, UST Class A Operator gburdett@stlukehealthnet.org
 Gary Burdett, UST Class B Operator gburdett@stlukehealthnet.org
 Nicholas Emerson, UST Class A Operator nemerson@stlukehealthcare.org
 Nicholas Emerson, UST Class B Operator nemerson@stlukehealthcare.org
 Steven DeLay, UST Class A Operator sdelay57@gmail.com
 Steven DeLay, UST Class B Operator sdelay57@gmail.com

| | | | | | | | | | | | |
|--------------------|------------------|---------------------------|----|---------------------------------|------------|--------------------------------------|-------------|---------------------------------|------------------------------------|-----------------------|-----|
| Tank Code | S3 | Tank Age | 27 | Tank Installed Date | 11/01/1999 | Tank Material | Unknown | Piping Material | Copper | Overfill Types | |
| Tag Number | 4369 | Spill Test Date | | Piping Installed Date | | Tank Construction | | Piping Construction | Secondary Containment Chase | AST | Yes |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Auto Dialer | Piping Type | U.S. Suction | CP Met Types | |
| Product | Diesel | PLLD Test Date | | Tank/Piping CP Test Date | | Primary Tank Leak Detection | | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery | No |
| Capacity | 2000 | ATG Test Date | | Line Tightness Test Date | | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | No |
| | | Overfill Test Date | | | | ATG Type | | | | | |

Facility Summary in Lake County in the City of Ronan

Location: TOWN PUMP INC RONAN
63459 US Hwy 93
Ronan, MT 59864-3007 Lake

System Facility ID:24-08718

Facility Code: 23067
Last Inspected On: 03/29/2023
Operating Permit Renewal Date: 09/30/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Ronan 1 Town Pump LLC (406) 497-6700 environmental@townpump.com

Operator Contact: Trent Biggers Trentb@townpump.com

Owner/Operator: Ronan 1 Town Pump LLC (406) 497-6700 environmental@townpump.com

Trent Biggers, UST Class A Operator Trentb@townpump.com
Trent Biggers, UST Class B Global Operator Trentb@townpump.com

| | | | | | | | | | | | |
|--------------------|------------------|---------------------------|------------|---------------------------------|------------|--------------------------------------|--------------------------------------|---------------------------------|--------------------------------------|-----------------------|-------------------|
| Tank Code | 01 | Tank Age | 54 | Tank Installed Date | 04/14/1972 | Tank Material | Cathodically Protected Steel | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | Flapper Valve |
| Tag Number | 4822 | Spill Test Date | 11/11/2025 | Piping Installed Date | | Tank Construction | Lined Interior/Impressed Current | Piping Construction | None | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Impressed Current |
| Product | Gasoline | PLLD Test Date | 05/13/2021 | Tank/Piping CP Test Date | 08/22/2022 | Primary Tank Leak Detection | Statistical Inventory Reconciliation | Primary Pipe Detection | Statistical Inventory Reconciliation | Vapor Recovery | No |
| Capacity | 12000 | ATG Test Date | 10/24/2024 | Line Tightness Test Date | | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | No |
| | | Overfill Test Date | 08/22/2022 | | | ATG Type | Gilbarco-Veeder Root/TLS-450PLUS | | | | |
| Tank Code | 02 | Tank Age | 54 | Tank Installed Date | 04/14/1972 | Tank Material | Cathodically Protected Steel | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | Flapper Valve |
| Tag Number | 4823 | Spill Test Date | 08/22/2022 | Piping Installed Date | | Tank Construction | Lined Interior/Impressed Current | Piping Construction | None | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Impressed Current |
| Product | Gasoline | PLLD Test Date | 05/13/2021 | Tank/Piping CP Test Date | 08/22/2022 | Primary Tank Leak Detection | Statistical Inventory Reconciliation | Primary Pipe Detection | Statistical Inventory Reconciliation | Vapor Recovery | No |
| Capacity | 12000 | ATG Test Date | 10/24/2024 | Line Tightness Test Date | | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | No |

| | | | | | | | | | | | |
|--------------------|------------------|---------------------------|------------|---------------------------------|------------|--------------------------------------|--------------------------------------|---------------------------------|--------------------------------------|-----------------------|--------------------------------|
| | | Overfill Test Date | 08/22/2022 | | | ATG Type | Gilbarco-Veeder Root/TLS-450PLUS | | | | |
| Tank Code | 03 | Tank Age | 54 | Tank Installed Date | 04/14/1972 | Tank Material | Cathodically Protected Steel | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | Flapper Valve |
| Tag Number | 4824 | Spill Test Date | 08/22/2022 | Piping Installed Date | | Tank Construction | Lined Interior/Impressed Current | Piping Construction | None | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Impressed Current |
| Product | Gasoline | PLLD Test Date | 05/13/2021 | Tank/Piping CP Test Date | 08/22/2022 | Primary Tank Leak Detection | Statistical Inventory Reconciliation | Primary Pipe Detection | Statistical Inventory Reconciliation | Vapor Recovery | No |
| Capacity | 6000 | ATG Test Date | 10/24/2024 | Line Tightness Test Date | | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | No |
| | | Overfill Test Date | 08/22/2022 | | | ATG Type | Gilbarco-Veeder Root/TLS-450PLUS | | | | |
| Tank Code | 04 | Tank Age | 46 | Tank Installed Date | 04/14/1980 | Tank Material | Cathodically Protected Steel | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | Flapper Valve |
| Tag Number | 4825 | Spill Test Date | 08/22/2022 | Piping Installed Date | | Tank Construction | Lined Interior/Impressed Current | Piping Construction | None | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Impressed Current |
| Product | Diesel | PLLD Test Date | 05/13/2021 | Tank/Piping CP Test Date | 08/22/2022 | Primary Tank Leak Detection | Statistical Inventory Reconciliation | Primary Pipe Detection | Statistical Inventory Reconciliation | Vapor Recovery | No |
| Capacity | 6000 | ATG Test Date | 10/24/2024 | Line Tightness Test Date | 09/19/2024 | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | No |
| | | Overfill Test Date | 08/22/2022 | | | ATG Type | Gilbarco-Veeder Root/TLS-450PLUS | | | | |
| Tank Code | 05 | Tank Age | 19 | Tank Installed Date | 07/05/2007 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | Ball Float Valve;Flapper Valve |
| Tag Number | 5073 | Spill Test Date | 08/22/2022 | Piping Installed Date | | Tank Construction | Double-Walled | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Gasoline | PLLD Test Date | 05/13/2021 | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Statistical Inventory Reconciliation | Primary Pipe Detection | Statistical Inventory Reconciliation | Vapor Recovery | No |
| Capacity | 12000 | ATG Test Date | 10/24/2024 | Line Tightness Test Date | | Secondary Tank Leak Detection | Continuous Interstitial Monitoring | Secondary Pipe Detection | Continuous Interstitial Monitoring | Energy Act | No |

| | | | | | | | | | | | |
|--|--|---------------------------|------------|--|--|-----------------|---|--|--|--|--|
| | | Overfill Test Date | 08/22/2022 | | | ATG Type | Gilbarco-Veeder Root/TLS- 450PLUS | | | | |
|--|--|---------------------------|------------|--|--|-----------------|---|--|--|--|--|

Facility Summary in Lake County in the City of Saint Ignatius

Location: ALLARDS STAGE STOP LLC
77579 US Hwy 93 N
Saint Ignatius, MT 59865-0460 Lake

System Facility ID:24-05769

Facility Code: 22982
Last Inspected On: 01/25/2024
Operating Permit Renewal Date: 03/13/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Mission View Properties LLC (509) 994-6599 histarms01@yahoo.com

Operator Contact: Mamie Ahlborn (406) 207-2810 mamie_ahlborn@hotmail.com

Owner/Operator: Mission View Properties LLC (509) 994-6599 histarms01@yahoo.com
Mamie Ahlborn, UST Class A Operator mamie_ahlborn@hotmail.com
Mamie Ahlborn, UST Class B Global Operator mamie_ahlborn@hotmail.com

| | | | | | | | | | | | |
|--------------------|------------------|---------------------------|------------|---------------------------------|------------|--------------------------------------|-------------------------------|---------------------------------|------------------------------------|-----------------------|----------------|
| Tank Code | 04 | Tank Age | 21 | Tank Installed Date | 12/01/2005 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Flexible Plastic | Overfill Types | Flapper Valve |
| Tag Number | 5042 | Spill Test Date | 04/14/2023 | Piping Installed Date | 06/04/2019 | Tank Construction | | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | 10/12/2023 | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Mechanical Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Gasoline | PLLD Test Date | | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery | No |
| Capacity | 10000 | ATG Test Date | 10/12/2023 | Line Tightness Test Date | 09/20/2022 | Secondary Tank Leak Detection | | Secondary Pipe Detection | MLLD Line Tightness Testing | Energy Act | Yes |
| | | Overfill Test Date | 10/12/2023 | | | ATG Type | Veeder Root/TLS-300 | | | | |
| Tank Code | 05 | Tank Age | 21 | Tank Installed Date | 12/01/2005 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Flexible Plastic | Overfill Types | Flapper Valve |
| Tag Number | 5043 | Spill Test Date | 04/14/2023 | Piping Installed Date | 06/04/2019 | Tank Construction | | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | 10/12/2023 | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Mechanical Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Gasoline | PLLD Test Date | | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery | No |
| Capacity | 10000 | ATG Test Date | 10/12/2023 | Line Tightness Test Date | 09/20/2022 | Secondary Tank Leak Detection | | Secondary Pipe Detection | MLLD Line Tightness Testing | Energy Act | Yes |
| | | Overfill Test Date | 10/12/2023 | | | ATG Type | Veeder Root/TLS-300 | | | | |

Facility Summary in Lake County in the City of Saint Ignatius

Location: MOUNTAIN VIEW CENEX
240 Mountain View Dr
Saint Ignatius, MT 59865 Lake

System Facility ID:24-10647

Facility Code: 23153
Last Inspected On: 09/13/2023
Operating Permit Renewal Date: 09/13/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Mission View Properties LLC (509) 994-6599 histarms01@yahoo.com

Operator Contact: Mamie Ahlborn (406) 207-2810 mamie_ahlborn@hotmail.com

Owner/Operator: Mission View Properties LLC (509) 994-6599 histarms01@yahoo.com
Mamie Ahlborn, UST Class A Operator mamie_ahlborn@hotmail.com
Mamie Ahlborn, UST Class B Global Operator mamie_ahlborn@hotmail.com
Mamie Ahlborn, UST Class B Operator mamie_ahlborn@hotmail.com

| | | | | | | | | | | | |
|--------------------|------------------|---------------------------|------------|---------------------------------|------------|--------------------------------------|---|---------------------------------|-------------------------------|-----------------------|---------------|
| Tank Code | 06 | Tank Age | 31 | Tank Installed Date | 05/01/1995 | Tank Material | Cathodically Protected Steel | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | Flapper Valve |
| Tag Number | 4595 | Spill Test Date | 06/22/2023 | Piping Installed Date | | Tank Construction | | Piping Construction | None | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Not Required | Piping Type | Safe Suction | CP Met Types | Galvanic |
| Product | Gasoline | PLLD Test Date | | Tank/Piping CP Test Date | 10/12/2023 | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | | Vapor Recovery | No |
| Capacity | 8000 | ATG Test Date | 10/12/2023 | Line Tightness Test Date | 08/22/2017 | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | No |
| | | Overfill Test Date | 10/12/2023 | | | ATG Type | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | | | |
| Tank Code | 07 | Tank Age | 31 | Tank Installed Date | 05/01/1995 | Tank Material | Cathodically Protected Steel | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | Flapper Valve |
| Tag Number | 4596 | Spill Test Date | 06/22/2023 | Piping Installed Date | | Tank Construction | | Piping Construction | None | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | 10/12/2023 | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Mechanical Line Leak Detector | Piping Type | Pressurized | CP Met Types | Galvanic |
| Product | Gasoline | PLLD Test Date | | Tank/Piping CP Test Date | 10/12/2023 | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | MLLD Line Tightness Testing | Vapor Recovery | No |
| Capacity | 8000 | ATG Test Date | 10/12/2023 | Line Tightness Test Date | 09/26/2022 | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | No |
| | | Overfill Test Date | 10/12/2023 | | | ATG Type | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | | | |

| | | | | | | | | | | | |
|--------------------|------------------|---------------------------|------------|---------------------------------|------------|--------------------------------------|--|---------------------------------|------------------------------------|-----------------------|----------------|
| Tank Code | 08 | Tank Age | 31 | Tank Installed Date | 05/01/1995 | Tank Material | Cathodically Protected Steel | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | Flapper Valve |
| Tag Number | 4597 | Spill Test Date | 04/13/2023 | Piping Installed Date | | Tank Construction | | Piping Construction | None | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | 10/12/2023 | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Mechanical Line Leak Detector | Piping Type | Pressurized | CP Met Types | Galvanic |
| Product | Diesel | PLLD Test Date | | Tank/Piping CP Test Date | 10/12/2023 | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | MLLD Line Tightness Testing | Vapor Recovery | No |
| Capacity | 6000 | ATG Test Date | 10/12/2023 | Line Tightness Test Date | 09/26/2022 | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | No |
| | | Overfill Test Date | 10/12/2023 | | | ATG Type | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | | | |
| Tank Code | 09 | Tank Age | 11 | Tank Installed Date | 10/01/2015 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | Flapper Valve |
| Tag Number | 5619 | Spill Test Date | 04/13/2023 | Piping Installed Date | 10/23/2015 | Tank Construction | Double-Walled | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | 10/12/2023 | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Mechanical Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Gasoline | PLLD Test Date | | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Continuous Interstitial Monitoring | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery | No |
| Capacity | 8000 | ATG Test Date | 10/12/2023 | Line Tightness Test Date | 09/26/2022 | Secondary Tank Leak Detection | Automatic Tank Gauging 0.2 | Secondary Pipe Detection | MLLD Line Tightness Testing | Energy Act | Yes |
| | | Overfill Test Date | 10/12/2023 | | | ATG Type | Gilbarco-Veeder Root/TLS-350;Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | | | |

Facility Summary in Lake County in the City of Saint Ignatius

Location: SAINT IGNATIUS SCHOOL
4th & Blaine St
Saint Ignatius, MT 59865 Lake

System Facility ID:24-03762

Facility Code: 22927
Last Inspected On: 02/08/2024
Operating Permit Renewal Date: 02/08/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: School Dist 28 Saint Ignatius (406) 745-3811

Operator Contact: Stephen McCollum (406) 396-7842 smccollum@stignatiusschools.org

Owner/Operator: School Dist 28 Saint Ignatius (406) 745-3811

Stephen McCollum, UST Class A Operator
Stephen McCollum, UST Class B Global Operator

smccollum@stignatiusschools.org
smccollum@stignatiusschools.org

| | | | | | | | | | | | |
|--------------------|------------------------|---------------------------|----|---------------------------------|------------|--------------------------------------|------------------------------|---------------------------------|------------------------------------|-----------------------|---------------|
| Tank Code | 03 | Tank Age | 29 | Tank Installed Date | 06/01/1997 | Tank Material | Cathodically Protected Steel | Piping Material | Flexible Plastic | Overfill Types | Flapper Valve |
| Tag Number | 4563 | Spill Test Date | | Piping Installed Date | | Tank Construction | | Piping Construction | Double Walled | AST | No |
| Tank Status | Temporarily Out of Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Auto Dialer | Piping Type | U.S. Suction | CP Met Types | Galvanic |
| Product | Heating Oil | PLLD Test Date | | Tank/Piping CP Test Date | 10/24/2023 | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery | No |
| Capacity | 10000 | ATG Test Date | | Line Tightness Test Date | | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | No |
| | | Overfill Test Date | | | | ATG Type | EMCO Electronics/EECO 1500 | | | | |